DOCKETED	
Docket Number:	06-AFC-09C
Project Title:	Colusa Generating Station - Compliance
TN #:	241281
Document Title:	2021 3rd Quarter Operating Report
Description:	N/A
Filer:	Anthony TJ Gomez
Organization:	Pacific Gas and Electric
Submitter Role:	Applicant
Submission Date:	1/26/2022 7:53:12 AM
Docketed Date:	1/26/2022

ATTACHMENT 1
Complaints
FCD: AQ-5
Title V: #5

During the third quarter of 2021, there were no complaints issued from the public for the Colusa Generating Station. The site continues to be available for inspection by representatives of the CCAPCD.

ATTACHMENT 2
Fuel Quality Data

FCD: AQ-10 & 11
Title V: #16

2021 Monthly Sulfur Content - Colusa Generating Station

All Units in Grains of Sulfur per 100 Standard Cubic Foot

Month	Jan-21	Feb-21	Mar-21	Apr-21	May-21	Jun-21	Jul-21	Aug-21	Sep-21	Oct-21	Nov-21	Dec-21	Avg
Gr/100SCF	0.127	0.142	Outage	0.126	0.156	0.156	0.181	0.166	0.221				0.134

Permit Limits:

0.75 Grains/100SCF per Month (PSD Condition X.I.4); 0.3 Grains/100SCF Annual Average (Title V # 16)

Atmospheric Analysis & Consulting, Inc.

CLIENT	: PG&E
PROJECT NAME	: Nat'l Gas Sampling
AAC PROJECT NO.	: 211237
REPORT DATE	: 07/28/2021

On July 15, 2021, Atmospheric Analysis & Consulting, Inc. received one (1) 1.0-Liter Silonite Canister for TRS analysis by ASTM D-5504. Also received was one (1) Tedlar Bag for BTU analysis by ASTM D-3588. Upon receipt, the samples were assigned unique Laboratory ID numbers as follows:

Client ID	Lab No.	Return Pressure (mmHg)
CPP-GS-JUL-1	211237-21399	NA
CPP-GS-JUL-A	211237-21400	638.6

This analysis is performed in accordance with AAC's Quality Manual. Test results apply to the sample(s) as received. For detailed information pertaining to specific EPA, NCASI, ASTM and SCAQMD accreditations (Methods & Analytes), please visit our website at www.aaclab.com.

I certify that this data is technically accurate, complete, and in compliance with the terms and conditions of the contract. Sample "CPP-GS-JUL-1" (21399) was transferred to a Tedlar Bag by ATS on July 14, 2021. No problems were encountered during receiving, preparation, and/or analysis of these samples. The Technical Director or his/her designee, as verified by the following signature, has authorized release of the data.

If you have any questions or require further explanation of data results, please contact the undersigned.

Sucha Parmar, Ph.D.
Technical Director

This report consists of 9 pages.

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com • (805) 650-1642

Atmospheric Analysis & Consulting, Inc.

Laboratory Analysis Report
ASTM-D3588 (BTU and F-Factor)

CLIENT : PG&E
PROJECT NO. : 211237

SAMPLING DATE : 07/14/2021
ANALYSIS DATE : 07/16-17/2021

	Client ID:	CPP-GS-JUL-1			
	AAC ID:	211237-21399			
	Component	Mole %	Mole % SRL	Weight %	Weight % SRL
FIXED GASES	H_2	< 1.00	1.00	< 0.001	0.001
	O_2	0.29	0.100	0.55	0.002
	N_2	1.23	0.100	2.02	0.001
	CO	< 0.100	0.100	< 0.001	0.001
	CO_2	0.56	0.100	1.44	0.002
	CH_4	93.80	0.00005	88.27	0.004
	He	NM	NM	NM	NM
	Ar	< 0.100	0.100	< 0.002	0.002
HYDROCARBONS	C_2 (as Ethane)	3.7139	0.00025	6.5509	0.0004
	C_3 (as Propane)	0.2906	0.00005	0.7516	0.0001
	C_4 (as Butane)	0.0779	0.00005	0.2654	0.0002
	C_5 (as Pentane)	0.0141	0.00005	0.0598	0.0002
	C_6 (as Hexane)	0.0036	0.00005	0.0184	0.0002
	C_{6+} (as Hexane)	0.0074	0.00005	0.0374	0.0002
TRS	Total Reduced Sulfur	NM	NM	NM	NM
H2O	Moisture content	NM	NM	NM	NM

All results have been normalized to 100% on a dry basis.

Fuel Gas Specifications				
Atomic Breakdown - (scf/lb) / %			*HHV Btu/lb*	22794
Carbon (C)	72.6		*LHV Btu/lb*	20542
Hydrogen (H)	23.7		*HHV Btu/dscf*	1024
Oxygen (O)	1.6		*LHV Btu/dscf*	923
Nitrogen (N)	2.0		*F-Factor*	8641
Helium (He)	0.00		*Relative Density*	0.5887
Argon (Ar)	0.04		*C2-C6+ Weight %*	7.6835
Sulfur (S)	0.00		*MW lb/lb-mole*	17.048
Motor Octane Number	131.12		*Methane Number*	93.84

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com • (805) 650-1642

LABORATORY ANALYSIS REPORT

CLIENT : **PG&E**
PROJECT NO. : **211237**
MATRIX : **AIR**
UNITS : **ppmV**

SAMPLING DATE : **07/13/2021**
ANALYSIS DATE : **07/20/2021**

Total Reduced Sulfur Compounds Analysis by ASTM D-5504

Client ID	**CPP-GS-Jul-A**
AAC ID	**211237-21400**
Canister Dil. Fac.	**2.4**
Analyte	**Result**
Hydrogen Sulfide	**1.12**
COS / SO2	**0.411**
Methyl Mercaptan	**0.175**
Ethyl Mercaptan	< 0.122
Dimethyl Sulfide	< 0.122
Carbon Disulfide	< 0.122
Isopropyl Mercaptan	< 0.122
tert-Butyl Mercaptan	**0.737**
n-Propyl Mercaptan	< 0.122
Methylethylsulfide	< 0.122
sec-Butyl Mercaptan / Thiophene	< 0.122
iso-Butyl Mercaptan	< 0.122
Diethyl Sulfide	< 0.122
n-Butyl Mercaptan	< 0.122
Dimethyl Disulfide	< 0.122
2-Methylthiophene	< 0.122
3-Methylthiophene	< 0.122
Tetrahydrothiophene	**0.936**
Bromothiophene	< 0.122
Thiophenol	< 0.122
Diethyl Disulfide	< 0.122
Total Unidentified Sulfur	< 0.122
Total Reduced Sulfurs	**2.97**

All unidentified compound's concentrations expressed in terms of H_2S (TRS does not include COS and SO_2)
Sample Reporting Limit (SRL) is equal to Reporting Limit x Canister Dil. Fac. x Analysis Dil. Fac.

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com • (805) 650-1642

LABORATORY ANALYSIS REPORT

CLIENT	**: PG&E**	**SAMPLING DATE**	**: 07/13/2021**
PROJECT NO.	**: 211237**	**ANALYSIS DATE**	**: 07/20/2021**
MATRIX	**: AIR**		
UNITS	**: grains/100 dscf**		

Total Reduced Sulfur Compounds Analysis by ASTM D-5504

Client ID	**CPP-GS-Jul-A**
AAC ID	**211237-21400**
Canister Dil. Fac.	**2.4**
Analyte	**Result**
Hydrogen Sulfide	**0.06823**
COS / SO2	**0.02504**
Methyl Mercaptan	**0.01066**
Ethyl Mercaptan	< 0.00743
Dimethyl Sulfide	< 0.00743
Carbon Disulfide	< 0.00743
Isopropyl Mercaptan	< 0.00743
tert-Butyl Mercaptan	**0.04490**
n-Propyl Mercaptan	< 0.00743
Methylethylsulfide	< 0.00743
sec-Butyl Mercaptan / Thiophene	< 0.00743
iso-Butyl Mercaptan	< 0.00743
Diethyl Sulfide	< 0.00743
n-Butyl Mercaptan	< 0.00743
Dimethyl Disulfide	< 0.00743
2-Methylthiophene	< 0.00743
3-Methylthiophene	< 0.00743
Tetrahydrothiophene	**0.05700**
Bromothiophene	< 0.00743
Thiophenol	< 0.00743
Diethyl Disulfide	< 0.00743
Total Unidentified Sulfur	< 0.00743
Total Reduced Sulfurs	**0.18079**

All unidentified compound's concentrations expressed in terms of H_2S (TRS does not include COS and SO_2)
Sample Reporting Limit (SRL) is equal to Reporting Limit x Canister Dil. Fac. x Analysis Dil. Fac.

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com • (805) 650-1642

Atmospheric Analysis & Consulting, Inc.

Quality Control/Quality Assurance Report

Date Analyzed : 07/16/2021
Analyst : CM/ZD
Units : %

Instrument ID : TCD #1
Calb Date : 10/05/20
Reporting Limit : 0.1%

I - Opening Continuing Calibration Verification - BTU/ASTM D-1945

AAC ID	Analyte	H_2	O_2	N_2	CH_4	CO	CO_2
CCV	Spike Conc	9.9	10.4	20.2	10.0	10.0	10.0
	Result	9.6	10.3	20.1	10.0	9.9	9.7
	% Rec *	97.3	99.1	99.8	100.4	99.1	97.4

II - Method Blank - BTU/ASTM D-1945

AAC ID	Analyte	H_2	O_2	N_2	CH_4	CO	CO_2
MB	Concentration	ND	ND	ND	ND	ND	ND

III - Laboratory Control Spike & Duplicate - BTU/ASTM D-1945

AAC ID	Analyte	H_2	O_2	N_2	CH_4	CO	CO_2
Lab Control Standards	Sample Conc	0.0	0.0	0.0	0.0	0.0	0.0
	Spike Conc	9.9	10.4	20.2	10.0	10.0	10.0
	LCS Result	9.8	10.3	20.2	10.1	9.9	9.8
	LCSD Result	9.7	10.4	20.3	10.1	10.0	9.8
	LCS % Rec *	99.1	99.2	100.2	100.9	99.4	97.8
	LCSD % Rec *	97.6	99.8	100.8	101.5	100.0	98.7
	% RPD ***	1.5	0.5	0.6	0.7	0.6	0.9

IV -Sample & Sample Duplicate - BTU/ASTM D-1945

AAC ID	Analyte	H_2	O_2	N_2	CH_4	CO	CO_2
211170-20985	Sample	0.0	6.0	37.2	0.0	0.0	2.8
	Sample Dup	0.0	6.1	37.6	0.0	0.0	2.9
	Mean	0.0	6.1	37.4	0.0	0.0	2.9
	% RPD ***	0.0	2.5	1.1	0.0	0.0	0.7

V - Matrix Spike & Duplicate- BTU/ASTM D-1945

AAC ID	Analyte	H_2	N_2	CH_4	CO	CO_2
211170-20985	Sample Conc	0.0	18.7	0.0	0.0	1.4
	Spike Conc	9.9	10.1	10.0	10.0	10.0
	MS Result	9.8	29.2	10.2	10.1	11.3
	MSD Result	9.7	28.8	10.0	10.1	11.2
	MS % Rec **	98.7	103.7	102.2	100.8	98.5
	MSD % Rec **	97.7	100.0	100.0	100.6	97.4
	% RPD ***	1.0	3.7	2.2	0.2	1.1

VI - Closing Continuing Calibration Verification - BTU/ASTM D-1945

AAC ID	Analyte	H_2	O_2	N_2	CH_4	CO	CO_2
CCV	Spike Conc	9.9	10.4	20.2	10.0	10.0	10.0
	Result	9.8	10.4	20.4	10.1	10.0	9.7
	% Rec *	98.9	100.2	101.1	101.5	100.3	96.9

** Must be 85-115%*

*** Must be 75-125%*

**** Must be < 25%*

ND = Not Detected

<RL = less than Reporting Limit

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com • (805) 650-1642

Atmospheric Analysis & Consulting, Inc.

Quality Control/Quality Assurance Report

Date Analyzed : 07/17/2021
Analyst : CM/ZD
Units : ppmv

Instrument ID : FID #3
Calb Date : 03/31/21
Reporting Limit : 0.5 ppmv

I - Opening Continuing Calibration Verification - BTU/ASTM D-1945

AAC ID	Analyte	Methane	Ethane	Propane	Butane	Pentane	Hexane
CCV	Spike Conc	98.9	99.1	98.7	98.1	98.1	99.7
	Result	97.0	98.7	97.5	100.2	101.7	101.8
	% Rec *	98.1	99.6	98.8	102.2	103.6	102.1

II - Method Blank - BTU/ASTM D-1945

AAC ID	Analyte	Methane	Ethane	Propane	Butane	Pentane	Hexane
MB	Concentration	ND	ND	ND	ND	ND	ND

III - Laboratory Control Spike & Duplicate - BTU/ASTM D-1945

AAC ID	Analyte	Methane	Ethane	Propane	Butane	Pentane	Hexane
Lab Control Standards	Sample Conc	0.0	0.0	0.0	0.0	0.0	0.0
	Spike Conc	98.9	99.1	98.7	98.1	98.1	99.7
	LCS Result	94.6	96.2	94.7	96.8	98.3	98.7
	LCSD Result	97.9	99.1	94.4	100.6	101.4	103.0
	LCS % Rec *	95.7	97.0	96.0	98.7	100.2	98.9
	LCSD % Rec *	99.1	100.0	95.6	102.6	103.3	103.3
	% RPD ***	3.5	3.0	0.3	3.8	3.1	4.3

IV - Sample & Sample Duplicate - BTU/ASTM D-1945

AAC ID	Analyte	Methane	Ethane	Propane	Butane	Pentane	Hexane
211072-20433	Sample	29.9	2.8	3.2	2.1	0.0	0.0
	Sample Dup	27.5	2.6	3.0	2.0	0.0	0.0
	Mean	28.7	2.7	3.1	2.1	0.0	0.0
	% RPD ***	8.3	7.8	5.4	6.8	0.0	0.0

V - Matrix Spike & Duplicate - BTU/ASTM D-1945

AAC ID	Analyte	Methane	Ethane	Propane	Butane	Pentane	Hexane
211072-20433	Sample Conc	14.3	1.4	1.6	1.0	0.0	0.0
	Spike Conc	49.4	49.6	49.4	49.0	49.1	49.9
	MS Result	63.1	51.5	50.8	51.2	51.4	52.3
	MSD Result	61.8	49.9	49.3	49.9	50.0	51.0
	MS % Rec **	98.6	101.2	99.7	102.2	104.6	104.9
	MSD % Rec **	96.1	97.9	96.7	99.6	101.8	102.3
	% RPD ***	2.6	3.2	3.1	2.6	2.8	2.5

VI - Closing Continuing Calibration Verification - BTU/ASTM D-1945

AAC ID	Analyte	Methane	Ethane	Propane	Butane	Pentane	Hexane
CCV	Spike Conc	98.9	99.1	98.7	98.1	98.1	99.7
	Result	99.1	100.7	99.2	102.4	104.9	105.6
	% Rec *	100.2	101.6	100.5	104.4	106.9	105.8

** Must be 85-115%*

*** Must be 75-125%*

**** Must be < 25%*

ND = Not Detected

<RL = less than Reporting Limit

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com • (805) 650-1642

Quality Control/Quality Assurance Report
ASTM D-5504

Date Analyzed: 7/20/2021
Analyst: DL
Units: ppbV

Instrument ID: SCD#10
Calb. Date: 6/1/2021

Opening Calibration Verification Standard

519.8 ppbV H2S (SS1289)

H_2S	Resp. (area)	Result	% Rec *	% RPD ****
Initial	3610	533	102.6	0.2
Duplicate	3601	532	102.3	0.0
Triplicate	3594	531	102.1	0.2

527.0 ppbV H2S (SS1289)

MeSH	Resp. (area)	Result	% Rec *	% RPD ****
Initial	4322	515	97.8	0.7
Duplicate	4384	523	99.2	0.7
Triplicate	4352	519	98.5	0.0

522.0 ppbV H2S (SS1289)

DMS	Resp. (area)	Result	% Rec *	% RPD ****
Initial	4754	510	97.7	1.1
Duplicate	4816	517	99.0	0.2
Triplicate	4850	520	99.7	0.9

Method Blank

Analyte	Result
H_2S	<PQL
MeSH	<PQL
DMS	<PQL

Duplicate Analysis **Sample ID** 211084-20480

Analyte	Sample Result	Duplicate Result	Mean	% RPD ***
H_2S	<PQL	<PQL	0.0	0.0
MeSH	<PQL	<PQL	0.0	0.0
DMS	<PQL	<PQL	0.0	0.0

Matrix Spike & Duplicate **Sample ID** 211084-20480 x10

Analyte	Sample Conc.	Spike Added	MS Result	MSD Result	MS % Rec **	MSD % Rec **	% RPD ***
H_2S	<PQL	259.9	254.0	258.2	97.8	99.4	1.6
MeSH	<PQL	263.5	254.2	254.7	96.5	96.7	0.2
DMS	<PQL	261.0	255.2	263.2	97.8	100.8	3.1

Closing Calibration Verification Standard

Analyte	Std. Conc.	Result	% Rec **
H_2S	519.8	546.0	105.1
MeSH	527.0	519.3	98.5
DMS	522.0	529.5	101.4

** Must be 95-105%, ** Must be 90-110%, *** Must be < 10%, **** Must be < 5% RPD from Mean result.*

H2S: PQL = 10.5 ppbV, MDL = 1.12 ppbV
MeSH: PQL = 10.5 ppbV, MDL = 1.12 ppbV
DMS: PQL = 11.0 ppbV, MDL = 1.12 ppbV

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com • (805) 650-1642

211237

Colusa Fuel Gas Sampling

Client: PG&E Applied technical Services	Project Manager: Surinder Sidhu		Date: 07/14/21
Address: 3400 Crow Canyon Road	Telephone Number: 925-866-5245	Email: SKSG@pge.com	Laboratory: AAC
City: San Ramon / State: CA / Zip: 94583	Site Contacat:		Laboratory Phone: 805-650-1642
Project Number/Name: Nat'l Gas Sampling	Sampler: Steve North 925-785-3039		Laboratory Fax:
Contract Number, PO Number:	Laboratory Contact:		

PG&E Sample ID	SAM#-ID#	Date	Time	Sample Type	Containers: Volume	Type	No.	Preservative	Condition on Receipt/Comments	Preparation and Analysis: BTU
CPP-GS- JHL -1	21399	7/13/21	1652	Gas	500cc	cyl	1	None	Line pressure	
↓		7/14/21	1045	Gas	1L	bag	1	None	Ambient Pressure	X

Special Instruction:

Email results to Surinder Sidhu (SKSG@PGE.COM), Evan Cavalli (EMCM@PGE.COM), TJ Gomez (AJGU@PGE.COM)

Turn Around Time Required	QC Level	Project Specific Requirements (Specify)
☑ Normal ☐ Rush ☐ Other	☑ I. ☐ II. ☐ III.	

		Date	Time		Date	Time
1. Relinquished By	Steve North (self/lab)	7/14/21	0900	1. Received By	7/14/21	1000
2. Relinquished By		7/14/21	1100	2. Received By	7/15/21	0933
3. Relinquished By		Date	Time	3. Received By	Date	Time

Comments: Gas transferred from SS Cyl to 1L Tedlar bag at ATS for transport to AAC (date/time recorded above)

211237

Colusa Fuel Gas Sampling

Client: PG&E Environmental Services		Project Manager: Surinder Sidhu		Date: 7/14/21
Address: 3400 Crow Canyon Road		Telephone Number: 925-866-5245	Email: SKSG@pge.com	Laboratory: AAC Labs
City: San Ramon	State: CA	Zip: 94583	Site Contacat	Laboratory Phone: 805-650-1642
Project Number/Name: Natural Gas Sampling			Sampler: Steve North 925-785-3039	Laboratory Fax
Contract Number, PO Number		Laboratory Contact: Eric Grosjean - 1534 Eastman Ave. Suite A Ventura CA 93003		

Preparation and Analysis

PG&E Sample ID	SAM#-ID#	Date	Time	Sample Type	Containers: Volume	Type	No.	Preservative	Condition on Receipt/Comments	Sulfur ASTM D-5504	TO-15
CPP-GS- JWL - A	~~21399~~ 21400 MD	7/13/21	1700	Gas	1 liter	cyl	1	None		X	X

Special Instruction:

Email results to Surinder Sidhu (SKSG@PGE.COM) , Evan Cavalli (EMCM@PGE.COM), A.J. Gomez (AJGU@PGE.COM)

Turn Around Time Required	QC Level	Project Specific Requirements (Specify)
☑ Normal ☐ Rush ☐ Other	☑ I. ☐ II. ☐ III.	

	Date	Time		Date	Time
1. Relinquished By: Steve North (UPS 650)	7/14/21	0900	1. Received By	7/15/21	1457
2. Relinquished By	Date	Time	2. Received By	Date	Time
3. Relinquished By	Date	Time	3. Received By	Date	Time

Comments: Separate report for TO-15 analysis

Sample collected in 3L Tedlar bag and immediately field transferred to evacuated 1L mini-can onsite.

Atmospheric Analysis & Consulting, Inc.

CLIENT	: PG&E
PROJECT NAME	: Natural Gas Sampling
AAC PROJECT NO.	: 211420
REPORT DATE	: 08/25/2021

On August 13, 2021, Atmospheric Analysis & Consulting, Inc. received one (1) 1.0-Liter Silonite Canister for Total Reduced Sulfur analysis by ASTM D-5504. Upon receipt, the sample was assigned a unique Laboratory ID number as follows:

Client ID	Lab No.	Return Pressure (mmHg)
CPP-GS-AUG-A	211420-22369	621.8

This analysis is performed in accordance with AAC's Quality Manual. Test results apply to the sample(s) as received. For detailed information pertaining to specific EPA, NCASI, ASTM and SCAQMD accreditations (Methods & Analytes), please visit our website at www.aaclab.com.

I certify that this data is technically accurate, complete, and in compliance with the terms and conditions of the contract. No problems were encountered during receiving, preparation, and/or analysis of this sample.

The Technical Director or his/her designee, as verified by the following signature, has authorized release of the data.

If you have any questions or require further explanation of data results, please contact the undersigned.

Sucha Parmar, Ph.D.
Technical Director

This report consists of 5 pages.

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com • (805) 650-1642

LABORATORY ANALYSIS REPORT

CLIENT	**: PG&E**	**SAMPLING DATE**	**: 08/11/2021**
PROJECT NO.	**: 211420**	**RECEIVING DATE**	**: 08/13/2021**
MATRIX	**: AIR**	**ANALYSIS DATE**	**: 08/17/2021**
UNITS	**: ppmV**	**REPORT DATE**	**: 08/25/2021**

Total Reduced Sulfur Compounds Analysis by ASTM D-5504

Client ID	**CPP-GS-AUG-A**
AAC ID	**211420-22369**
Canister Dil. Fac.	**2.5**
Analyte	**Result**
Hydrogen Sulfide	**0.777**
COS / SO2	**0.589**
Methyl Mercaptan	**0.137**
Ethyl Mercaptan	< 0.125
Dimethyl Sulfide	< 0.125
Carbon Disulfide	< 0.125
Isopropyl Mercaptan	< 0.125
tert-Butyl Mercaptan	**0.405**
n-Propyl Mercaptan	< 0.125
Methylethylsulfide	< 0.125
sec-Butyl Mercaptan / Thiophene	< 0.125
iso-Butyl Mercaptan	< 0.125
Diethyl Sulfide	< 0.125
n-Butyl Mercaptan	< 0.125
Dimethyl Disulfide	< 0.125
2-Methylthiophene	< 0.125
3-Methylthiophene	< 0.125
Tetrahydrothiophene	**0.819**
Bromothiophene	< 0.125
Thiophenol	< 0.125
Diethyl Disulfide	< 0.125
Total Unidentified Sulfur	< 0.125
Total Reduced Sulfurs	**2.14**
Total Sulfurs	**2.73**

All unidentified compound's concentrations expressed in terms of H_2S (TRS does not include COS and SO_2)
Sample Reporting Limit (SRL) is equal to Reporting Limit x Canister Dil. Fac. x Analysis Dil. Fac.

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com • (805) 650-1642

LABORATORY ANALYSIS REPORT

CLIENT	**: PG&E**	**SAMPLING DATE**	**: 08/11/2021**
PROJECT NO.	**: 211420**	**RECEIVING DATE**	**: 08/13/2021**
MATRIX	**: AIR**	**ANALYSIS DATE**	**: 08/17/2021**
UNITS	**: grains/100 dscf**	**REPORT DATE**	**: 08/25/2021**

Total Reduced Sulfur Compounds Analysis by ASTM D-5504

Client ID	**CPP-GS-AUG-A**
AAC ID	**211420-22369**
Canister Dil. Fac.	**2.5**
Analyte	**Result**
Hydrogen Sulfide	**0.04735**
COS / SO2	**0.03589**
Methyl Mercaptan	**0.00833**
Ethyl Mercaptan	< 0.00764
Dimethyl Sulfide	< 0.00764
Carbon Disulfide	< 0.00764
Isopropyl Mercaptan	< 0.00764
tert-Butyl Mercaptan	**0.02464**
n-Propyl Mercaptan	< 0.00764
Methylethylsulfide	< 0.00764
sec-Butyl Mercaptan / Thiophene	< 0.00764
iso-Butyl Mercaptan	< 0.00764
Diethyl Sulfide	< 0.00764
n-Butyl Mercaptan	< 0.00764
Dimethyl Disulfide	< 0.00764
2-Methylthiophene	< 0.00764
3-Methylthiophene	< 0.00764
Tetrahydrothiophene	**0.04988**
Bromothiophene	< 0.00764
Thiophenol	< 0.00764
Diethyl Disulfide	< 0.00764
Total Unidentified Sulfur	< 0.00764
Total Reduced Sulfurs	**0.13020**
Total Sulfurs	**0.16609**

All unidentified compound's concentrations expressed in terms of H_2S (TRS does not include COS and SO_2)
Sample Reporting Limit (SRL) is equal to Reporting Limit x Canister Dil. Fac. x Analysis Dil. Fac.

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com • (805) 650-1642

Quality Control/Quality Assurance Report
ASTM D-5504

Date Analyzed: 8/17/2021
Analyst: DL
Units: ppbV

Instrument ID: SCD#10
Calb. Date: 6/1/2021

Opening Calibration Verification Standard

519.8 ppbV H2S (SS1289)

H_2S	Resp. (area)	Result	% Rec *	% RPD ****
Initial	3541	523	100.6	0.1
Duplicate	3520	520	100.0	0.7
Triplicate	3574	528	101.6	0.8

527.0 ppbV H2S (SS1289)

MeSH	Resp. (area)	Result	% Rec *	% RPD ****
Initial	4409	526	99.8	1.0
Duplicate	4316	515	97.7	1.2
Triplicate	4376	522	99.0	0.2

522.0 ppbV H2S (SS1289)

DMS	Resp. (area)	Result	% Rec *	% RPD ****
Initial	4780	513	98.3	0.6
Duplicate	4686	503	96.3	1.4
Triplicate	4785	514	98.4	0.7

Method Blank

Analyte	Result
H_2S	<PQL
MeSH	<PQL
DMS	<PQL

Duplicate Analysis **Sample ID** 211084-20479

Analyte	Sample Result	Duplicate Result	Mean	% RPD ***
H_2S	<PQL	<PQL	0.0	0.0
MeSH	<PQL	<PQL	0.0	0.0
DMS	<PQL	<PQL	0.0	0.0

Matrix Spike & Duplicate **Sample ID** 211084-20479 x10

Analyte	Sample Conc.	Spike Added	MS Result	MSD Result	MS % Rec **	MSD % Rec **	% RPD ***
H_2S	<PQL	259.9	249.1	258.6	95.9	99.5	3.7
MeSH	<PQL	263.5	253.4	253.9	96.2	96.4	0.2
DMS	<PQL	261.0	253.4	262.2	97.1	100.4	3.4

Closing Calibration Verification Standard

Analyte	Std. Conc.	Result	% Rec **
H_2S	519.8	507.5	97.6
MeSH	527.0	527.0	100.0
DMS	522.0	530.0	101.5

Must be 95-105%, ** Must be 90-110%, *** Must be < 10%, * Must be < 5% RPD from Mean result.*

H2S: PQL = 10.5 ppbV, MDL = 1.12 ppbV
MeSH: PQL = 10.5 ppbV, MDL = 1.12 ppbV
DMS: PQL = 11.0 ppbV, MDL = 1.12 ppbV

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com • (805) 650-1642

211420

Colusa Fuel Gas Sampling

Client: PG&E Environmental Services	Project Manager: Surinder Sidhu		Date: 8/12/21	
Address: 3400 Crow Canyon Road	Telephone Number: 925-866-5245	Email: SKSG@pge.com	Laboratory: AAC Labs	
City: San Ramon / State: CA / Zip: 94583	Site Contacat		Laboratory Phone: 805-650-1642	
Project Number/Name: Natural Gas Sampling	Sampler: Steve North 925-785-3039		Laboratory Fax	
Contract Number, PO Number	Laboratory Contact: Eric Grosjean - 1534 Eastman Ave. Suite A Ventura CA 93003			

PG&E Sample ID	SAM#-ID#	Date	Time	Sample Type	Containers: Volume	Type	No.	Preservative	Condition on Receipt/Comments	Preparation and Analysis: Sulfur ASTM D-5504
CPP-GS- AUG - A	22369	8/11/21	1440	Gas	1 liter	cyl	1	None		X

Special Instruction:

Email results to Surinder Sidhu (SKSG@PGE.COM) , Evan Cavalli (EMCM@PGE.COM), A.J. Gomez (AJGU@PGE.COM)

Turn Around Time Required	QC Level	Project Specific Requirements (Specify)
☑ Normal ☐ Rush ☐ Other	☑ I. ☐ II. ☐ III.	

1. Relinquished By: Steve North (via GSO)	Date: 8/12/21	Time: 10:00	1. Received By	Date	Time
2. Relinquished By	Date	Time	2. Received By	Date	Time
3. Relinquished By	Date	Time	3. Received By	Date: 8/13/21	Time: 1434

Comments

Sample collected in 3L Tedlar bag and immediately field transferred to evacuated 1L mini-can onsite.

GLS 1x 1.0L can

Atmospheric Analysis & Consulting, Inc.

CLIENT	: PG&E
PROJECT NAME	: Natural Gas Sampling
AAC PROJECT NO.	: 211593
REPORT DATE	: 09/17/2021

On September 10, 2021, Atmospheric Analysis & Consulting, Inc. received one (1) 1.0-Liter Silonite Canister for Total Reduced Sulfur analysis by ASTM D-5504. Upon receipt, the sample was assigned a unique Laboratory ID number as follows:

Client ID	Lab No.	Return Pressure (mmHg)
CPP-GS-SEP-A	211593-23251	671.7

This analysis is performed in accordance with AAC's Quality Manual. Test results apply to the sample(s) as received. For detailed information pertaining to specific EPA, NCASI, ASTM and SCAQMD accreditations (Methods & Analytes), please visit our website at www.aaclab.com.

I certify that this data is technically accurate, complete, and in compliance with the terms and conditions of the contract. No problems were encountered during receiving, preparation, and/or analysis of this sample.

The Technical Director or his/her designee, as verified by the following signature, has authorized release of the data.

If you have any questions or require further explanation of data results, please contact the undersigned.

Sucha Parmar, Ph.D.
Technical Director

This report consists of 6 pages.

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com • (805) 650-1642

LABORATORY ANALYSIS REPORT

CLIENT	**: PG&E**	**SAMPLING DATE**	**: 09/09/2021**
PROJECT NO.	**: 211593**	**RECEIVING DATE**	**: 09/10/2021**
MATRIX	**: AIR**	**ANALYSIS DATE**	**: 09/10/2021**
UNITS	**: ppmV**	**REPORT DATE**	**: 09/17/2021**

Total Reduced Sulfur Compounds Analysis by ASTM D-5504

Client ID	**CPP-GS-SEP-A**
AAC ID	**211420-22369**
Canister Dil. Fac.	**2.3**
Analyte	**Result**
Hydrogen Sulfide	**0.710**
COS / SO2	**0.628**
Methyl Mercaptan	**0.326**
Ethyl Mercaptan	**0.127**
Dimethyl Sulfide	< 0.115
Carbon Disulfide	< 0.115
Isopropyl Mercaptan	< 0.115
tert-Butyl Mercaptan	**0.615**
n-Propyl Mercaptan	< 0.115
Methylethylsulfide	< 0.115
sec-Butyl Mercaptan / Thiophene	< 0.115
iso-Butyl Mercaptan	< 0.115
Diethyl Sulfide	< 0.115
n-Butyl Mercaptan	< 0.115
Dimethyl Disulfide	< 0.115
2-Methylthiophene	< 0.115
3-Methylthiophene	< 0.115
Tetrahydrothiophene	**1.08**
Bromothiophene	< 0.115
Thiophenol	< 0.115
Diethyl Disulfide	< 0.115
Total Unidentified Sulfur	< 0.115
Total Reduced Sulfurs	**2.85**
Total Sulfurs	**3.48**

All unidentified compound's concentrations expressed in terms of H_2S (TRS does not include COS and SO_2)
Sample Reporting Limit (SRL) is equal to Reporting Limit x Canister Dil. Fac. x Analysis Dil. Fac.

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com • (805) 650-1642

LABORATORY ANALYSIS REPORT

CLIENT	**: PG&E**	**SAMPLING DATE**	**: 09/09/2021**
PROJECT NO.	**: 211593**	**RECEIVING DATE**	**: 09/10/2021**
MATRIX	**: AIR**	**ANALYSIS DATE**	**: 09/10/2021**
UNITS	**: grains/100 dscf**	**REPORT DATE**	**: 09/17/2021**

Total Reduced Sulfur Compounds Analysis by ASTM D-5504

Client ID	**CPP-GS-SEP-A**
AAC ID	**211420-22369**
Canister Dil. Fac.	**2.3**
Analyte	**Result**
Hydrogen Sulfide	**0.04323**
COS / SO2	**0.03825**
Methyl Mercaptan	**0.01986**
Ethyl Mercaptan	**0.00773**
Dimethyl Sulfide	< 0.00703
Carbon Disulfide	< 0.00703
Isopropyl Mercaptan	< 0.00703
tert-Butyl Mercaptan	**0.03744**
n-Propyl Mercaptan	< 0.00703
Methylethylsulfide	< 0.00703
sec-Butyl Mercaptan / Thiophene	< 0.00703
iso-Butyl Mercaptan	< 0.00703
Diethyl Sulfide	< 0.00703
n-Butyl Mercaptan	< 0.00703
Dimethyl Disulfide	< 0.00703
2-Methylthiophene	< 0.00703
3-Methylthiophene	< 0.00703
Tetrahydrothiophene	**0.06553**
Bromothiophene	< 0.00703
Thiophenol	< 0.00703
Diethyl Disulfide	< 0.00703
Total Unidentified Sulfur	< 0.00703
Total Reduced Sulfurs	**0.17379**
Total Sulfurs	**0.21205**

All unidentified compound's concentrations expressed in terms of H_2S (TRS does not include COS and SO_2)
Sample Reporting Limit (SRL) is equal to Reporting Limit x Canister Dil. Fac. x Analysis Dil. Fac.

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com • (805) 650-1642

Quality Control/Quality Assurance Report
ASTM D-5504

Date Analyzed: 9/10/2021
Analyst: DL
Units: ppbV

Instrument ID: SCD#10
Calb. Date: 6/1/2021

Opening Calibration Verification Standard

519.8 ppbV H2S (SS1289)

H_2S	Resp. (area)	Result	% Rec *	% RPD ****
Initial	3600	532	102.3	1.8
Duplicate	3591	530	102.0	1.5
Triplicate	3418	505	97.1	3.3

527.0 ppbV H2S (SS1289)

MeSH	Resp. (area)	Result	% Rec *	% RPD ****
Initial	4426	528	100.2	1.0
Duplicate	4405	525	99.7	0.5
Triplicate	4316	515	97.7	1.5

522.0 ppbV H2S (SS1289)

DMS	Resp. (area)	Result	% Rec *	% RPD ****
Initial	4900	526	100.7	1.2
Duplicate	5008	537	103.0	0.9
Triplicate	4975	534	102.3	0.3

Method Blank

Analyte	Result
H_2S	<PQL
MeSH	<PQL
DMS	<PQL

Duplicate Analysis **Sample ID** 211519-22866

Analyte	Sample Result	Duplicate Result	Mean	% RPD ***
H_2S	<PQL	<PQL	0.0	0.0
MeSH	<PQL	<PQL	0.0	0.0
DMS	<PQL	<PQL	0.0	0.0

Matrix Spike & Duplicate **Sample ID** 211519-22866 x10

Analyte	Sample Conc.	Spike Added	MS Result	MSD Result	MS % Rec **	MSD % Rec **	% RPD ***
H_2S	<PQL	259.9	254.9	259.1	98.1	99.7	1.6
MeSH	<PQL	263.5	268.1	267.5	101.7	101.5	0.2
DMS	<PQL	261.0	286.5	282.3	109.8	108.2	1.5

Closing Calibration Verification Standard

Analyte	Std. Conc.	Result	% Rec **
H_2S	519.8	545.9	105.0
MeSH	527.0	534.4	101.4
DMS	522.0	553.4	106.0

** Must be 95-105%, ** Must be 90-110%, *** Must be < 10%, **** Must be < 5% RPD from Mean result.*

H2S: PQL = 10.5 ppbV, MDL = 1.12 ppbV
MeSH: PQL = 10.5 ppbV, MDL = 1.12 ppbV
DMS: PQL = 11.0 ppbV, MDL = 1.12 ppbV

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com • (805) 650-1642

211593

Colusa Fuel Gas Sampling

Client: PG&E Environmental Services	Project Manager: Surinder Sidhu		Date: 9/9/21
Address: 3400 Crow Canyon Road	Telephone Number: 925-866-5245	Email: SKSG@pge.com	Laboratory: AAC Labs
City: San Ramon / State: CA / Zip: 94583	Site Contacat:		Laboratory Phone: 805-650-1642
Project Number/Name: Natural Gas Sampling	Sampler: Steve North 925-785-3039		Laboratory Fax:
Contract Number, PO Number:	Laboratory Contact: Eric Grosjean - 1534 Eastman Ave. Suite A Ventura CA 93003		

Preparation and Analysis: Sulfur ASTM D 5504

PG&E Sample ID	SAM#-ID#	Date	Time	Sample Type	Containers: Volume	Type	No.	Preservative	Condition on Receipt/Comments	Sulfur ASTM D 5504
~~CPP-GS-AUG-A~~ CPP-GS-SEP-A 9/15/21 dm	23251	9/9/21	12:10	Gas	1 liter	cyl	1	None		X

Special Instruction:

Email results to Surinder Sidhu (SKSG@PGE.COM) , Evan Cavalli (EMCM@PGE.COM), A.J. Gomez (AJGU@PGE.COM)

Turn Around Time Required	QC Level	Project Specific Requirements (Specify)
☑ Normal ☐ Rush ☐ Other	☑ I. ☐ II. ☐ III.	

	Date	Time		Date	Time
1. Relinquished By: Steve North (via GSO)	9/9/21	1510	1. Received By		
2. Relinquished By			2. Received By		
3. Relinquished By			3. Received By	9/10/21	1026

Comments

Sample collected in 3L Tedlar bag and immediately field transferred to evacuated 1L mini-can onsite.

GLS 1x 1.0L can

211593

Colusa Fuel Gas Sampling

Client: PG&E Environmental Services		Project Manager: Surinder Sidhu		Date: 9/9/21
Address: 3400 Crow Canyon Road		Telephone Number: 925-866-5245	Email: SKSG@pge.com	Laboratory: AAC Labs
City: San Ramon	State: CA	Zip: 94583	Site Contacat	Laboratory Phone: 805-650-1642
Project Number/Name: Natural Gas Sampling			Sampler: Steve North 925-785-3039	Laboratory Fax
Contract Number, PO Number		Laboratory Contact: Eric Grosjean - 1534 Eastman Ave. Suite A Ventura CA 93003		

PG&E Sample ID	SAM#-ID#	Date	Time	Sample Type	Containers: Volume	Containers: Type	Containers: No.	Preservative	Condition on Receipt/Comments	Preparation and Analysis: Sulfur ASTM D-5504
CPP-GS- AUG - A	23251	9/9/21	12:10	Gas	1 liter	cyl	1	None		X

Special Instruction:

Email results to Surinder Sidhu (SKSG@PGE.COM) , Evan Cavalli (EMCM@PGE.COM), A.J. Gomez (AJGU@PGE.COM)

Turn Around Time Required	QC Level	Project Specific Requirements (Specify)
☑ Normal ☐ Rush ☐ Other	☑ I. ☐ II. ☐ III.	

1. Relinquished By: Steve North (via GSO)	Date: 9/9/21	Time: 1510	1. Received By		Date	Time
2. Relinquished By	Date	Time	2. Received By		Date	Time
3. Relinquished By	Date	Time	3. Received By		Date: 9/10/21	Time: 1026

Comments

Sample collected in 3L Tedlar bag and immediately field transferred to evacuated 1L mini-can onsite.

GLS 1x 1.0L can

ATTACHMENT 3
40 CFR 60 Section KKKK

FCD: AQ-13
Title V: #8, 9, 25, 25, 30

Excess Emission Report

CT1 NOx 30 Day Rolling Average (KKKK)

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/04/2021 08:50 **Location:** Maxwell, CA

Tag Name: CT1_NOx_30D_Ppmvdc_1D
Total Operating Time: 79.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 13.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**79.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 NOx 30 Day Rolling Average (KKKK)

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/04/2021 08:51 **Location:** Maxwell, CA

Tag Name: CT2_NOx_30D_Ppmvdc_1D
Total Operating Time: 80.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 12.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**80.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 08:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
07/01/2021 00:00	1	2
07/01/2021 01:00	1	2
07/01/2021 02:00	1	2
07/01/2021 03:00	1	2
07/01/2021 04:00	1	2
07/01/2021 05:00	1	2
07/01/2021 06:00	1	2
07/01/2021 07:00	1	2
07/01/2021 08:00	1	2
07/01/2021 09:00	1	2
07/01/2021 10:00	1	2
07/01/2021 11:00	1	2
07/01/2021 12:00	1	2
07/01/2021 13:00	1	2
07/01/2021 14:00	1	2
07/01/2021 15:00	1	2
07/01/2021 16:00	1	2
07/01/2021 17:00	1	2
07/01/2021 18:00	1	2
07/01/2021 19:00	1	2
07/01/2021 20:00	1	2
07/01/2021 21:00	1	2
07/01/2021 22:00	1	2
07/01/2021 23:00	1	2
Average/Sum#:	1	2
Minimum:	1	2
Maximum:	1	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 08:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
07/02/2021 00:00	1	2
07/02/2021 01:00	1	2
07/02/2021 02:00	1	2
07/02/2021 03:00	1	2
07/02/2021 04:00	1	2
07/02/2021 05:00	1	2
07/02/2021 06:00	1	2
07/02/2021 07:00	1	2
07/02/2021 08:00	1	2
07/02/2021 09:00	1	2
07/02/2021 10:00	1	2
07/02/2021 11:00	1	2
07/02/2021 12:00	1	2
07/02/2021 13:00	1	2
07/02/2021 14:00	1	2
07/02/2021 15:00	1	2
07/02/2021 16:00	1	2
07/02/2021 17:00	1	2
07/02/2021 18:00	1	2
07/02/2021 19:00	1	2
07/02/2021 20:00	1	2
07/02/2021 21:00	1	2
07/02/2021 22:00	1	2
07/02/2021 23:00	1	2
Average/Sum#:	1	2
Minimum:	1	2
Maximum:	1	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 08:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
07/03/2021 00:00	1	2
07/03/2021 01:00	1	2
07/03/2021 02:00	1	2
07/03/2021 03:00	1	2
07/03/2021 04:00	1	2
07/03/2021 05:00	1	2
07/03/2021 06:00	1	2
07/03/2021 07:00	1	2
07/03/2021 08:00	1	2
07/03/2021 09:00	1	2
07/03/2021 10:00	1	2
07/03/2021 11:00	1	2
07/03/2021 12:00	1	2
07/03/2021 13:00	1	2
07/03/2021 14:00	1	2
07/03/2021 15:00	1	2
07/03/2021 16:00	1	2
07/03/2021 17:00	1	2
07/03/2021 18:00	1	2
07/03/2021 19:00	1	2
07/03/2021 20:00	1	2
07/03/2021 21:00	1	2
07/03/2021 22:00	1	2
07/03/2021 23:00	1	2
Average/Sum#:	1	2
Minimum:	1	2
Maximum:	1	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 08:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
07/04/2021 00:00	1	2
07/04/2021 01:00	1	2
07/04/2021 02:00	1	2
07/04/2021 03:00	1	2
07/04/2021 04:00	1	2
07/04/2021 05:00	1	2
07/04/2021 06:00	1	2
07/04/2021 07:00	1	2
07/04/2021 08:00	1	2
07/04/2021 09:00	1	2
07/04/2021 10:00	1	2
07/04/2021 11:00	1	2
07/04/2021 12:00	1	2
07/04/2021 13:00	1	2
07/04/2021 14:00	1	2
07/04/2021 15:00	1	2
07/04/2021 16:00	1	2
07/04/2021 17:00	1	2
07/04/2021 18:00	1	2
07/04/2021 19:00	1	2
07/04/2021 20:00	1	2
07/04/2021 21:00	1	2
07/04/2021 22:00	1	2
07/04/2021 23:00	1	2
Average/Sum#:	1	2
Minimum:	1	2
Maximum:	1	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 08:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
07/05/2021 00:00	1	2
07/05/2021 01:00	1	2
07/05/2021 02:00	1	2
07/05/2021 03:00	1	2
07/05/2021 04:00	1	2
07/05/2021 05:00	1	2
07/05/2021 06:00	1	2
07/05/2021 07:00	1	2
07/05/2021 08:00	1	2
07/05/2021 09:00	1	2
07/05/2021 10:00	1	2
07/05/2021 11:00	1	2
07/05/2021 12:00	1	2
07/05/2021 13:00	1	2
07/05/2021 14:00	1	2
07/05/2021 15:00	1	2
07/05/2021 16:00	1	2
07/05/2021 17:00	1	2
07/05/2021 18:00	1	2
07/05/2021 19:00	1	2
07/05/2021 20:00	1	2
07/05/2021 21:00	1	2
07/05/2021 22:00	1	2
07/05/2021 23:00	1	2
Average/Sum#:	1	2
Minimum:	1	2
Maximum:	1	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 08:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
07/06/2021 00:00	1	2
07/06/2021 01:00	1	2
07/06/2021 02:00	1	2
07/06/2021 03:00	1	2
07/06/2021 04:00	1	2
07/06/2021 05:00	1	2
07/06/2021 06:00	1	2
07/06/2021 07:00	1	2
07/06/2021 08:00	1	2
07/06/2021 09:00	1	2
07/06/2021 10:00	1	2
07/06/2021 11:00	1	2
07/06/2021 12:00	1	2
07/06/2021 13:00	1	2
07/06/2021 14:00	1	2
07/06/2021 15:00	1	2
07/06/2021 16:00	1	2
07/06/2021 17:00	1	2
07/06/2021 18:00	1	2
07/06/2021 19:00	1	2
07/06/2021 20:00	1	2
07/06/2021 21:00	1	2
07/06/2021 22:00	1	2
07/06/2021 23:00	1	2
Average/Sum#:	1	2
Minimum:	1	2
Maximum:	1	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 08:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
07/07/2021 00:00	1	2
07/07/2021 01:00	1	2
07/07/2021 02:00	1	2
07/07/2021 03:00	1	2
07/07/2021 04:00	1	2
07/07/2021 05:00	1	2
07/07/2021 06:00	1	2
07/07/2021 07:00	1	2
07/07/2021 08:00	1	2
07/07/2021 09:00	1	2
07/07/2021 10:00	1	2
07/07/2021 11:00	1	2
07/07/2021 12:00	1	2
07/07/2021 13:00	1	2
07/07/2021 14:00	1	2
07/07/2021 15:00	1	2
07/07/2021 16:00	1	2
07/07/2021 17:00	1	2
07/07/2021 18:00	1	2
07/07/2021 19:00	1	2
07/07/2021 20:00	1	2
07/07/2021 21:00	1	2
07/07/2021 22:00	1	2
07/07/2021 23:00	1	2
Average/Sum#:	1	2
Minimum:	1	2
Maximum:	1	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 08:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
07/08/2021 00:00	1	2
07/08/2021 01:00	1	2
07/08/2021 02:00	1	2
07/08/2021 03:00	1	2
07/08/2021 04:00	1	2
07/08/2021 05:00	1	2
07/08/2021 06:00	1	2
07/08/2021 07:00	1	2
07/08/2021 08:00	1	2
07/08/2021 09:00	1	2
07/08/2021 10:00	1	2
07/08/2021 11:00	1	2
07/08/2021 12:00	1	2
07/08/2021 13:00	1	2
07/08/2021 14:00	1	2
07/08/2021 15:00	1	2
07/08/2021 16:00	1	2
07/08/2021 17:00	1	2
07/08/2021 18:00	1	2
07/08/2021 19:00	1	2
07/08/2021 20:00	1	2
07/08/2021 21:00	1	2
07/08/2021 22:00	1	2
07/08/2021 23:00	1	2
Average/Sum#:	1	2
Minimum:	1	2
Maximum:	1	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 08:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
07/09/2021 00:00	1	2
07/09/2021 01:00	1	2
07/09/2021 02:00	1	2
07/09/2021 03:00	1	2
07/09/2021 04:00	1	2
07/09/2021 05:00	1	2
07/09/2021 06:00	1	2
07/09/2021 07:00	1	2
07/09/2021 08:00	1	2
07/09/2021 09:00	1	2
07/09/2021 10:00	1	2
07/09/2021 11:00	1	2
07/09/2021 12:00	1	2
07/09/2021 13:00	1	2
07/09/2021 14:00	1	2
07/09/2021 15:00	1	2
07/09/2021 16:00	1	2
07/09/2021 17:00	1	2
07/09/2021 18:00	1	2
07/09/2021 19:00	1	2
07/09/2021 20:00	1	2
07/09/2021 21:00	1	2
07/09/2021 22:00	1	2
07/09/2021 23:00	1	2
Average/Sum#:	1	2
Minimum:	1	2
Maximum:	1	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 08:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
07/10/2021 00:00	1	2
07/10/2021 01:00	1	2
07/10/2021 02:00	1	2
07/10/2021 03:00	1	2
07/10/2021 04:00	1	2
07/10/2021 05:00	1	2
07/10/2021 06:00	1	2
07/10/2021 07:00	1	2
07/10/2021 08:00	1	2
07/10/2021 09:00	1	2
07/10/2021 10:00	1	2
07/10/2021 11:00	1	2
07/10/2021 12:00	1	2
07/10/2021 13:00	14	2
07/10/2021 14:00	23	2
07/10/2021 15:00	25	2
07/10/2021 16:00	25	10
07/10/2021 17:00	13	22
07/10/2021 18:00	4	22
07/10/2021 19:00	1	22
07/10/2021 20:00	1	22
07/10/2021 21:00	1	22
07/10/2021 22:00	1	22
07/10/2021 23:00	1	22
Average/Sum#:	5	8
Minimum:	1	2
Maximum:	25	22
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 08:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
07/11/2021 00:00	1	22
07/11/2021 01:00	1	22
07/11/2021 02:00	1	22
07/11/2021 03:00	1	22
07/11/2021 04:00	1	22
07/11/2021 05:00	1	22
07/11/2021 06:00	1	22
07/11/2021 07:00	1	22
07/11/2021 08:00	1	22
07/11/2021 09:00	12	22
07/11/2021 10:00	15	22
07/11/2021 11:00	16	22
07/11/2021 12:00	16	22
07/11/2021 13:00	5	22
07/11/2021 14:00	2	22
07/11/2021 15:00	1	22
07/11/2021 16:00	1	22
07/11/2021 17:00	1	22
07/11/2021 18:00	1	22
07/11/2021 19:00	1	22
07/11/2021 20:00	1	22
07/11/2021 21:00	1	22
07/11/2021 22:00	1	22
07/11/2021 23:00	1	22
Average/Sum#:	4	22
Minimum:	1	22
Maximum:	16	22
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 08:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
07/12/2021 00:00	1	22
07/12/2021 01:00	1	22
07/12/2021 02:00	1	22
07/12/2021 03:00	1	22
07/12/2021 04:00	1	22
07/12/2021 05:00	1	22
07/12/2021 06:00	1	22
07/12/2021 07:00	1	28
07/12/2021 08:00	1	0
07/12/2021 09:00	1	0
07/12/2021 10:00	1	0
07/12/2021 11:00	1	0
07/12/2021 12:00	1	1
07/12/2021 13:00	1	1
07/12/2021 14:00	1	1
07/12/2021 15:00	9	1
07/12/2021 16:00	12	1
07/12/2021 17:00	12	1
07/12/2021 18:00	12	1
07/12/2021 19:00	4	1
07/12/2021 20:00	1	1
07/12/2021 21:00	1	1
07/12/2021 22:00	1	1
07/12/2021 23:00	1	1
Average/Sum#:	3	10
Minimum:	1	1
Maximum:	12	28
%SI	0.00	16.67

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 08:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
07/13/2021 00:00	1	1
07/13/2021 01:00	1	1
07/13/2021 02:00	1	1
07/13/2021 03:00	1	1
07/13/2021 04:00	1	1
07/13/2021 05:00	1	1
07/13/2021 06:00	1	1
07/13/2021 07:00	8	1
07/13/2021 08:00	9	1
07/13/2021 09:00	10	1
07/13/2021 10:00	10	1
07/13/2021 11:00	10	1
07/13/2021 12:00	11	1
07/13/2021 13:00	7	1
07/13/2021 14:00	5	1
07/13/2021 15:00	6	1
07/13/2021 16:00	6	1
07/13/2021 17:00	3	11
07/13/2021 18:00	3	13
07/13/2021 19:00	2	13
07/13/2021 20:00	1	13
07/13/2021 21:00	1	3
07/13/2021 22:00	1	1
07/13/2021 23:00	1	1
Average/Sum#:	4	3
Minimum:	1	1
Maximum:	11	13
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 08:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
07/14/2021 00:00	1	1
07/14/2021 01:00	1	1
07/14/2021 02:00	1	1
07/14/2021 03:00	2	1
07/14/2021 04:00	2	1
07/14/2021 05:00	3	1
07/14/2021 06:00	3	1
07/14/2021 07:00	1	1
07/14/2021 08:00	1	1
07/14/2021 09:00	1	1
07/14/2021 10:00	1	1
07/14/2021 11:00	1	1
07/14/2021 12:00	1	1
07/14/2021 13:00	1	1
07/14/2021 14:00	1	1
07/14/2021 15:00	1	1
07/14/2021 16:00	1	1
07/14/2021 17:00	1	1
07/14/2021 18:00	1	1
07/14/2021 19:00	1	1
07/14/2021 20:00	1	1
07/14/2021 21:00	1	1
07/14/2021 22:00	1	1
07/14/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	3	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 08:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
07/15/2021 00:00	1	1
07/15/2021 01:00	1	1
07/15/2021 02:00	1	1
07/15/2021 03:00	1	1
07/15/2021 04:00	1	1
07/15/2021 05:00	1	1
07/15/2021 06:00	1	1
07/15/2021 07:00	1	1
07/15/2021 08:00	1	1
07/15/2021 09:00	1	1
07/15/2021 10:00	1	1
07/15/2021 11:00	1	1
07/15/2021 12:00	1	1
07/15/2021 13:00	1	1
07/15/2021 14:00	1	1
07/15/2021 15:00	1	1
07/15/2021 16:00	1	1
07/15/2021 17:00	1	1
07/15/2021 18:00	1	1
07/15/2021 19:00	1	1
07/15/2021 20:00	1	1
07/15/2021 21:00	1	1
07/15/2021 22:00	1	1
07/15/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 08:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
07/16/2021 00:00	1	1
07/16/2021 01:00	1	1
07/16/2021 02:00	1	1
07/16/2021 03:00	1	1
07/16/2021 04:00	1	1
07/16/2021 05:00	1	1
07/16/2021 06:00	1	1
07/16/2021 07:00	1	1
07/16/2021 08:00	1	1
07/16/2021 09:00	1	1
07/16/2021 10:00	1	1
07/16/2021 11:00	1	1
07/16/2021 12:00	1	1
07/16/2021 13:00	1	1
07/16/2021 14:00	1	1
07/16/2021 15:00	1	1
07/16/2021 16:00	1	1
07/16/2021 17:00	1	1
07/16/2021 18:00	1	1
07/16/2021 19:00	1	1
07/16/2021 20:00	1	1
07/16/2021 21:00	1	1
07/16/2021 22:00	1	1
07/16/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 08:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
07/17/2021 00:00	1	1
07/17/2021 01:00	1	1
07/17/2021 02:00	1	1
07/17/2021 03:00	1	1
07/17/2021 04:00	1	1
07/17/2021 05:00	1	1
07/17/2021 06:00	1	1
07/17/2021 07:00	1	1
07/17/2021 08:00	1	1
07/17/2021 09:00	1	1
07/17/2021 10:00	1	1
07/17/2021 11:00	1	1
07/17/2021 12:00	1	1
07/17/2021 13:00	1	1
07/17/2021 14:00	1	1
07/17/2021 15:00	1	1
07/17/2021 16:00	1	1
07/17/2021 17:00	1	1
07/17/2021 18:00	1	1
07/17/2021 19:00	1	1
07/17/2021 20:00	1	1
07/17/2021 21:00	1	1
07/17/2021 22:00	1	1
07/17/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 08:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
07/18/2021 00:00	1	1
07/18/2021 01:00	1	1
07/18/2021 02:00	1	1
07/18/2021 03:00	1	1
07/18/2021 04:00	1	1
07/18/2021 05:00	1	1
07/18/2021 06:00	1	1
07/18/2021 07:00	1	1
07/18/2021 08:00	1	1
07/18/2021 09:00	1	1
07/18/2021 10:00	1	1
07/18/2021 11:00	1	1
07/18/2021 12:00	1	1
07/18/2021 13:00	1	1
07/18/2021 14:00	1	1
07/18/2021 15:00	1	1
07/18/2021 16:00	1	1
07/18/2021 17:00	1	1
07/18/2021 18:00	1	1
07/18/2021 19:00	1	1
07/18/2021 20:00	1	1
07/18/2021 21:00	1	1
07/18/2021 22:00	1	1
07/18/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 08:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
07/19/2021 00:00	1	1
07/19/2021 01:00	1	1
07/19/2021 02:00	1	1
07/19/2021 03:00	1	1
07/19/2021 04:00	1	1
07/19/2021 05:00	1	1
07/19/2021 06:00	1	1
07/19/2021 07:00	1	1
07/19/2021 08:00	1	1
07/19/2021 09:00	1	1
07/19/2021 10:00	1	1
07/19/2021 11:00	1	1
07/19/2021 12:00	1	1
07/19/2021 13:00	1	1
07/19/2021 14:00	1	1
07/19/2021 15:00	1	1
07/19/2021 16:00	1	1
07/19/2021 17:00	1	1
07/19/2021 18:00	1	1
07/19/2021 19:00	1	1
07/19/2021 20:00	1	1
07/19/2021 21:00	1	1
07/19/2021 22:00	1	1
07/19/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 08:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
07/20/2021 00:00	1	1
07/20/2021 01:00	1	1
07/20/2021 02:00	1	1
07/20/2021 03:00	1	1
07/20/2021 04:00	1	1
07/20/2021 05:00	1	1
07/20/2021 06:00	1	1
07/20/2021 07:00	1	1
07/20/2021 08:00	1	1
07/20/2021 09:00	1	1
07/20/2021 10:00	1	1
07/20/2021 11:00	1	1
07/20/2021 12:00	1	1
07/20/2021 13:00	1	1
07/20/2021 14:00	1	1
07/20/2021 15:00	1	1
07/20/2021 16:00	1	1
07/20/2021 17:00	1	1
07/20/2021 18:00	1	1
07/20/2021 19:00	1	1
07/20/2021 20:00	1	1
07/20/2021 21:00	1	1
07/20/2021 22:00	2	1
07/20/2021 23:00	2	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	2	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 08:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
07/21/2021 00:00	2	1
07/21/2021 01:00	1	1
07/21/2021 02:00	1	1
07/21/2021 03:00	1	1
07/21/2021 04:00	1	1
07/21/2021 05:00	1	1
07/21/2021 06:00	1	1
07/21/2021 07:00	1	1
07/21/2021 08:00	1	1
07/21/2021 09:00	1	1
07/21/2021 10:00	1	1
07/21/2021 11:00	1	1
07/21/2021 12:00	1	1
07/21/2021 13:00	1	1
07/21/2021 14:00	1	1
07/21/2021 15:00	1	1
07/21/2021 16:00	1	1
07/21/2021 17:00	1	1
07/21/2021 18:00	1	1
07/21/2021 19:00	1	1
07/21/2021 20:00	1	1
07/21/2021 21:00	1	1
07/21/2021 22:00	1	1
07/21/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	2	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 08:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
07/22/2021 00:00	1	1
07/22/2021 01:00	1	1
07/22/2021 02:00	1	1
07/22/2021 03:00	1	1
07/22/2021 04:00	1	1
07/22/2021 05:00	1	1
07/22/2021 06:00	1	1
07/22/2021 07:00	1	1
07/22/2021 08:00	1	1
07/22/2021 09:00	1	1
07/22/2021 10:00	1	1
07/22/2021 11:00	1	1
07/22/2021 12:00	1	1
07/22/2021 13:00	1	1
07/22/2021 14:00	1	1
07/22/2021 15:00	1	1
07/22/2021 16:00	1	1
07/22/2021 17:00	1	1
07/22/2021 18:00	1	1
07/22/2021 19:00	1	1
07/22/2021 20:00	1	1
07/22/2021 21:00	1	1
07/22/2021 22:00	1	1
07/22/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 08:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
07/23/2021 00:00	1	1
07/23/2021 01:00	1	1
07/23/2021 02:00	1	1
07/23/2021 03:00	1	1
07/23/2021 04:00	1	1
07/23/2021 05:00	1	1
07/23/2021 06:00	1	1
07/23/2021 07:00	1	1
07/23/2021 08:00	1	1
07/23/2021 09:00	1	1
07/23/2021 10:00	1	1
07/23/2021 11:00	1	1
07/23/2021 12:00	1	1
07/23/2021 13:00	1	1
07/23/2021 14:00	1	1
07/23/2021 15:00	1	1
07/23/2021 16:00	1	1
07/23/2021 17:00	1	1
07/23/2021 18:00	1	1
07/23/2021 19:00	1	1
07/23/2021 20:00	1	1
07/23/2021 21:00	1	1
07/23/2021 22:00	1	1
07/23/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 08:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
07/24/2021 00:00	1	1
07/24/2021 01:00	1	1
07/24/2021 02:00	1	1
07/24/2021 03:00	1	1
07/24/2021 04:00	1	1
07/24/2021 05:00	1	1
07/24/2021 06:00	1	1
07/24/2021 07:00	1	1
07/24/2021 08:00	1	1
07/24/2021 09:00	1	1
07/24/2021 10:00	1	1
07/24/2021 11:00	1	1
07/24/2021 12:00	1	1
07/24/2021 13:00	1	1
07/24/2021 14:00	1	1
07/24/2021 15:00	1	1
07/24/2021 16:00	1	1
07/24/2021 17:00	1	1
07/24/2021 18:00	1	1
07/24/2021 19:00	1	1
07/24/2021 20:00	1	1
07/24/2021 21:00	1	1
07/24/2021 22:00	1	1
07/24/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 08:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
07/25/2021 00:00	1	1
07/25/2021 01:00	1	1
07/25/2021 02:00	1	1
07/25/2021 03:00	1	1
07/25/2021 04:00	1	1
07/25/2021 05:00	1	1
07/25/2021 06:00	1	1
07/25/2021 07:00	1	1
07/25/2021 08:00	1	1
07/25/2021 09:00	1	1
07/25/2021 10:00	1	1
07/25/2021 11:00	1	1
07/25/2021 12:00	1	1
07/25/2021 13:00	1	1
07/25/2021 14:00	1	1
07/25/2021 15:00	1	1
07/25/2021 16:00	1	1
07/25/2021 17:00	1	1
07/25/2021 18:00	1	1
07/25/2021 19:00	1	1
07/25/2021 20:00	1	1
07/25/2021 21:00	1	1
07/25/2021 22:00	1	1
07/25/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 08:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
07/26/2021 00:00	1	1
07/26/2021 01:00	1	1
07/26/2021 02:00	1	1
07/26/2021 03:00	1	1
07/26/2021 04:00	1	1
07/26/2021 05:00	1	1
07/26/2021 06:00	1	1
07/26/2021 07:00	1	1
07/26/2021 08:00	1	1
07/26/2021 09:00	1	1
07/26/2021 10:00	1	1
07/26/2021 11:00	1	1
07/26/2021 12:00	1	1
07/26/2021 13:00	1	1
07/26/2021 14:00	1	1
07/26/2021 15:00	1	1
07/26/2021 16:00	1	1
07/26/2021 17:00	1	1
07/26/2021 18:00	1	1
07/26/2021 19:00	1	1
07/26/2021 20:00	1	1
07/26/2021 21:00	1	1
07/26/2021 22:00	1	1
07/26/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 08:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
07/27/2021 00:00	1	1
07/27/2021 01:00	1	1
07/27/2021 02:00	1	1
07/27/2021 03:00	1	1
07/27/2021 04:00	1	1
07/27/2021 05:00	1	1
07/27/2021 06:00	1	1
07/27/2021 07:00	1	1
07/27/2021 08:00	1	1
07/27/2021 09:00	1	1
07/27/2021 10:00	1	1
07/27/2021 11:00	1	1
07/27/2021 12:00	1	1
07/27/2021 13:00	1	1
07/27/2021 14:00	1	1
07/27/2021 15:00	1	1
07/27/2021 16:00	1	1
07/27/2021 17:00	1	1
07/27/2021 18:00	1	1
07/27/2021 19:00	1	1
07/27/2021 20:00	1	1
07/27/2021 21:00	1	1
07/27/2021 22:00	1	1
07/27/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 08:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
07/28/2021 00:00	1	1
07/28/2021 01:00	1	1
07/28/2021 02:00	1	1
07/28/2021 03:00	1	1
07/28/2021 04:00	1	1
07/28/2021 05:00	1	1
07/28/2021 06:00	1	1
07/28/2021 07:00	1	1
07/28/2021 08:00	1	1
07/28/2021 09:00	1	1
07/28/2021 10:00	1	1
07/28/2021 11:00	1	1
07/28/2021 12:00	1	1
07/28/2021 13:00	1	1
07/28/2021 14:00	1	1
07/28/2021 15:00	1	1
07/28/2021 16:00	1	1
07/28/2021 17:00	1	1
07/28/2021 18:00	1	1
07/28/2021 19:00	1	1
07/28/2021 20:00	1	1
07/28/2021 21:00	1	1
07/28/2021 22:00	1	1
07/28/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 08:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
07/29/2021 00:00	1	1
07/29/2021 01:00	1	1
07/29/2021 02:00	1	1
07/29/2021 03:00	1	1
07/29/2021 04:00	1	1
07/29/2021 05:00	1	1
07/29/2021 06:00	1	1
07/29/2021 07:00	1	1
07/29/2021 08:00	1	1
07/29/2021 09:00	1	1
07/29/2021 10:00	1	1
07/29/2021 11:00	1	1
07/29/2021 12:00	1	1
07/29/2021 13:00	1	1
07/29/2021 14:00	1	1
07/29/2021 15:00	1	1
07/29/2021 16:00	1	1
07/29/2021 17:00	1	1
07/29/2021 18:00	1	1
07/29/2021 19:00	1	1
07/29/2021 20:00	1	1
07/29/2021 21:00	1	1
07/29/2021 22:00	1	1
07/29/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 08:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
07/30/2021 00:00	1	1
07/30/2021 01:00	1	1
07/30/2021 02:00	1	1
07/30/2021 03:00	1	1
07/30/2021 04:00	1	1
07/30/2021 05:00	1	1
07/30/2021 06:00	1	1
07/30/2021 07:00	1	1
07/30/2021 08:00	1	1
07/30/2021 09:00	1	1
07/30/2021 10:00	1	1
07/30/2021 11:00	1	1
07/30/2021 12:00	1	1
07/30/2021 13:00	1	1
07/30/2021 14:00	1	1
07/30/2021 15:00	1	1
07/30/2021 16:00	1	1
07/30/2021 17:00	1	1
07/30/2021 18:00	1	1
07/30/2021 19:00	1	1
07/30/2021 20:00	1	1
07/30/2021 21:00	1	1
07/30/2021 22:00	1	1
07/30/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 08:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
07/31/2021 00:00	1	1
07/31/2021 01:00	1	1
07/31/2021 02:00	1	1
07/31/2021 03:00	1	1
07/31/2021 04:00	1	1
07/31/2021 05:00	1	1
07/31/2021 06:00	1	1
07/31/2021 07:00	1	1
07/31/2021 08:00	1	1
07/31/2021 09:00	1	1
07/31/2021 10:00	1	1
07/31/2021 11:00	1	1
07/31/2021 12:00	1	1
07/31/2021 13:00	1	1
07/31/2021 14:00	1	1
07/31/2021 15:00	1	1
07/31/2021 16:00	1	1
07/31/2021 17:00	1	1
07/31/2021 18:00	1	1
07/31/2021 19:00	1	1
07/31/2021 20:00	1	1
07/31/2021 21:00	1	1
07/31/2021 22:00	1	1
07/31/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 08:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
08/01/2021 00:00	1	1
08/01/2021 01:00	1	1
08/01/2021 02:00	1	1
08/01/2021 03:00	1	1
08/01/2021 04:00	1	1
08/01/2021 05:00	1	1
08/01/2021 06:00	1	1
08/01/2021 07:00	1	1
08/01/2021 08:00	1	1
08/01/2021 09:00	1	1
08/01/2021 10:00	1	1
08/01/2021 11:00	1	1
08/01/2021 12:00	1	1
08/01/2021 13:00	1	1
08/01/2021 14:00	1	1
08/01/2021 15:00	1	1
08/01/2021 16:00	1	1
08/01/2021 17:00	1	1
08/01/2021 18:00	1	1
08/01/2021 19:00	1	1
08/01/2021 20:00	1	1
08/01/2021 21:00	1	1
08/01/2021 22:00	1	1
08/01/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 08:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
08/02/2021 00:00	1	1
08/02/2021 01:00	1	1
08/02/2021 02:00	1	1
08/02/2021 03:00	1	1
08/02/2021 04:00	1	1
08/02/2021 05:00	1	1
08/02/2021 06:00	1	1
08/02/2021 07:00	1	1
08/02/2021 08:00	1	1
08/02/2021 09:00	1	1
08/02/2021 10:00	1	1
08/02/2021 11:00	1	1
08/02/2021 12:00	1	1
08/02/2021 13:00	1	1
08/02/2021 14:00	1	1
08/02/2021 15:00	1	1
08/02/2021 16:00	1	1
08/02/2021 17:00	1	1
08/02/2021 18:00	1	1
08/02/2021 19:00	1	1
08/02/2021 20:00	1	1
08/02/2021 21:00	1	1
08/02/2021 22:00	1	1
08/02/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 08:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
08/03/2021 00:00	1	1
08/03/2021 01:00	1	1
08/03/2021 02:00	1	1
08/03/2021 03:00	1	1
08/03/2021 04:00	1	1
08/03/2021 05:00	1	1
08/03/2021 06:00	1	1
08/03/2021 07:00	1	1
08/03/2021 08:00	1	1
08/03/2021 09:00	1	1
08/03/2021 10:00	1	1
08/03/2021 11:00	1	7
08/03/2021 12:00	1	7
08/03/2021 13:00	1	7
08/03/2021 14:00	1	7
08/03/2021 15:00	1	1
08/03/2021 16:00	1	1
08/03/2021 17:00	1	1
08/03/2021 18:00	1	1
08/03/2021 19:00	1	1
08/03/2021 20:00	1	1
08/03/2021 21:00	1	1
08/03/2021 22:00	1	1
08/03/2021 23:00	1	1
Average/Sum#:	1	2
Minimum:	1	1
Maximum:	1	7
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 08:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
08/04/2021 00:00	1	1
08/04/2021 01:00	1	1
08/04/2021 02:00	1	1
08/04/2021 03:00	1	1
08/04/2021 04:00	1	1
08/04/2021 05:00	1	1
08/04/2021 06:00	1	1
08/04/2021 07:00	1	1
08/04/2021 08:00	1	1
08/04/2021 09:00	1	1
08/04/2021 10:00	1	1
08/04/2021 11:00	1	1
08/04/2021 12:00	1	1
08/04/2021 13:00	1	1
08/04/2021 14:00	1	1
08/04/2021 15:00	1	1
08/04/2021 16:00	1	1
08/04/2021 17:00	1	1
08/04/2021 18:00	1	1
08/04/2021 19:00	1	1
08/04/2021 20:00	1	1
08/04/2021 21:00	1	1
08/04/2021 22:00	1	1
08/04/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 08:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
08/05/2021 00:00	1	1
08/05/2021 01:00	1	1
08/05/2021 02:00	1	1
08/05/2021 03:00	1	1
08/05/2021 04:00	1	1
08/05/2021 05:00	1	1
08/05/2021 06:00	1	1
08/05/2021 07:00	1	1
08/05/2021 08:00	1	1
08/05/2021 09:00	1	1
08/05/2021 10:00	1	1
08/05/2021 11:00	1	1
08/05/2021 12:00	1	1
08/05/2021 13:00	1	1
08/05/2021 14:00	1	1
08/05/2021 15:00	1	1
08/05/2021 16:00	1	1
08/05/2021 17:00	1	1
08/05/2021 18:00	1	1
08/05/2021 19:00	1	1
08/05/2021 20:00	1	1
08/05/2021 21:00	1	1
08/05/2021 22:00	1	1
08/05/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 08:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
08/06/2021 00:00	1	1
08/06/2021 01:00	1	1
08/06/2021 02:00	1	1
08/06/2021 03:00	1	1
08/06/2021 04:00	1	1
08/06/2021 05:00	1	1
08/06/2021 06:00	1	1
08/06/2021 07:00	1	1
08/06/2021 08:00	1	1
08/06/2021 09:00	1	1
08/06/2021 10:00	1	1
08/06/2021 11:00	1	1
08/06/2021 12:00	1	1
08/06/2021 13:00	1	1
08/06/2021 14:00	1	1
08/06/2021 15:00	1	1
08/06/2021 16:00	1	1
08/06/2021 17:00	1	1
08/06/2021 18:00	1	1
08/06/2021 19:00	1	1
08/06/2021 20:00	1	1
08/06/2021 21:00	1	1
08/06/2021 22:00	1	1
08/06/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 08:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
08/07/2021 00:00	1	1
08/07/2021 01:00	1	1
08/07/2021 02:00	1	1
08/07/2021 03:00	1	1
08/07/2021 04:00	1	1
08/07/2021 05:00	1	1
08/07/2021 06:00	1	1
08/07/2021 07:00	1	1
08/07/2021 08:00	1	1
08/07/2021 09:00	1	2
08/07/2021 10:00	1	5
08/07/2021 11:00	1	8
08/07/2021 12:00	1	9
08/07/2021 13:00	5	9
08/07/2021 14:00	9	6
08/07/2021 15:00	9	3
08/07/2021 16:00	9	1
08/07/2021 17:00	5	1
08/07/2021 18:00	1	1
08/07/2021 19:00	1	1
08/07/2021 20:00	1	1
08/07/2021 21:00	1	1
08/07/2021 22:00	1	1
08/07/2021 23:00	1	1
Average/Sum#:	2	2
Minimum:	1	1
Maximum:	9	9
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 08:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
08/08/2021 00:00	1	1
08/08/2021 01:00	1	1
08/08/2021 02:00	1	1
08/08/2021 03:00	1	1
08/08/2021 04:00	2	1
08/08/2021 05:00	2	1
08/08/2021 06:00	2	1
08/08/2021 07:00	2	1
08/08/2021 08:00	2	1
08/08/2021 09:00	2	1
08/08/2021 10:00	2	1
08/08/2021 11:00	2	1
08/08/2021 12:00	2	1
08/08/2021 13:00	2	1
08/08/2021 14:00	5	1
08/08/2021 15:00	10	1
08/08/2021 16:00	10	1
08/08/2021 17:00	9	1
08/08/2021 18:00	6	1
08/08/2021 19:00	1	1
08/08/2021 20:00	1	1
08/08/2021 21:00	1	1
08/08/2021 22:00	1	1
08/08/2021 23:00	1	1
Average/Sum#:	3	1
Minimum:	1	1
Maximum:	10	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 08:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
08/09/2021 00:00	1	1
08/09/2021 01:00	1	1
08/09/2021 02:00	1	1
08/09/2021 03:00	1	1
08/09/2021 04:00	1	1
08/09/2021 05:00	1	1
08/09/2021 06:00	1	1
08/09/2021 07:00	1	1
08/09/2021 08:00	1	1
08/09/2021 09:00	1	1
08/09/2021 10:00	1	1
08/09/2021 11:00	1	1
08/09/2021 12:00	1	1
08/09/2021 13:00	1	1
08/09/2021 14:00	1	1
08/09/2021 15:00	1	1
08/09/2021 16:00	1	1
08/09/2021 17:00	1	1
08/09/2021 18:00	1	1
08/09/2021 19:00	1	1
08/09/2021 20:00	1	1
08/09/2021 21:00	1	1
08/09/2021 22:00	1	1
08/09/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 08:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
08/10/2021 00:00	1	1
08/10/2021 01:00	1	1
08/10/2021 02:00	1	1
08/10/2021 03:00	1	1
08/10/2021 04:00	1	1
08/10/2021 05:00	1	1
08/10/2021 06:00	1	1
08/10/2021 07:00	1	1
08/10/2021 08:00	1	1
08/10/2021 09:00	1	1
08/10/2021 10:00	1	1
08/10/2021 11:00	1	1
08/10/2021 12:00	1	1
08/10/2021 13:00	1	1
08/10/2021 14:00	1	1
08/10/2021 15:00	1	1
08/10/2021 16:00	1	1
08/10/2021 17:00	1	1
08/10/2021 18:00	1	1
08/10/2021 19:00	1	1
08/10/2021 20:00	1	1
08/10/2021 21:00	1	1
08/10/2021 22:00	1	1
08/10/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 08:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
08/11/2021 00:00	1	1
08/11/2021 01:00	1	1
08/11/2021 02:00	1	1
08/11/2021 03:00	1	1
08/11/2021 04:00	1	1
08/11/2021 05:00	1	1
08/11/2021 06:00	1	1
08/11/2021 07:00	1	1
08/11/2021 08:00	1	1
08/11/2021 09:00	1	1
08/11/2021 10:00	1	1
08/11/2021 11:00	1	1
08/11/2021 12:00	1	1
08/11/2021 13:00	1	1
08/11/2021 14:00	1	1
08/11/2021 15:00	1	1
08/11/2021 16:00	1	1
08/11/2021 17:00	1	1
08/11/2021 18:00	1	1
08/11/2021 19:00	1	1
08/11/2021 20:00	1	1
08/11/2021 21:00	1	1
08/11/2021 22:00	1	1
08/11/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 08:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
08/12/2021 00:00	1	1
08/12/2021 01:00	1	1
08/12/2021 02:00	1	1
08/12/2021 03:00	1	1
08/12/2021 04:00	1	1
08/12/2021 05:00	1	1
08/12/2021 06:00	1	1
08/12/2021 07:00	1	1
08/12/2021 08:00	1	1
08/12/2021 09:00	1	1
08/12/2021 10:00	1	1
08/12/2021 11:00	1	1
08/12/2021 12:00	1	1
08/12/2021 13:00	1	1
08/12/2021 14:00	1	1
08/12/2021 15:00	1	1
08/12/2021 16:00	1	1
08/12/2021 17:00	1	1
08/12/2021 18:00	1	1
08/12/2021 19:00	1	1
08/12/2021 20:00	1	1
08/12/2021 21:00	1	1
08/12/2021 22:00	1	1
08/12/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 08:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
08/13/2021 00:00	1	1
08/13/2021 01:00	1	1
08/13/2021 02:00	1	1
08/13/2021 03:00	1	1
08/13/2021 04:00	1	1
08/13/2021 05:00	1	1
08/13/2021 06:00	1	1
08/13/2021 07:00	1	1
08/13/2021 08:00	1	1
08/13/2021 09:00	1	1
08/13/2021 10:00	1	1
08/13/2021 11:00	1	1
08/13/2021 12:00	1	1
08/13/2021 13:00	1	1
08/13/2021 14:00	1	1
08/13/2021 15:00	1	1
08/13/2021 16:00	1	1
08/13/2021 17:00	1	1
08/13/2021 18:00	1	1
08/13/2021 19:00	1	1
08/13/2021 20:00	1	1
08/13/2021 21:00	1	1
08/13/2021 22:00	1	1
08/13/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 08:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
08/14/2021 00:00	1	1
08/14/2021 01:00	1	1
08/14/2021 02:00	1	1
08/14/2021 03:00	1	1
08/14/2021 04:00	1	1
08/14/2021 05:00	1	1
08/14/2021 06:00	1	1
08/14/2021 07:00	1	1
08/14/2021 08:00	1	1
08/14/2021 09:00	1	1
08/14/2021 10:00	1	1
08/14/2021 11:00	1	1
08/14/2021 12:00	1	1
08/14/2021 13:00	1	1
08/14/2021 14:00	1	1
08/14/2021 15:00	1	1
08/14/2021 16:00	1	1
08/14/2021 17:00	1	1
08/14/2021 18:00	1	1
08/14/2021 19:00	1	1
08/14/2021 20:00	1	1
08/14/2021 21:00	1	1
08/14/2021 22:00	1	1
08/14/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 08:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
08/15/2021 00:00	1	1
08/15/2021 01:00	1	1
08/15/2021 02:00	1	1
08/15/2021 03:00	1	1
08/15/2021 04:00	1	1
08/15/2021 05:00	1	1
08/15/2021 06:00	1	1
08/15/2021 07:00	1	1
08/15/2021 08:00	1	1
08/15/2021 09:00	1	1
08/15/2021 10:00	1	1
08/15/2021 11:00	1	1
08/15/2021 12:00	1	1
08/15/2021 13:00	1	1
08/15/2021 14:00	1	1
08/15/2021 15:00	1	1
08/15/2021 16:00	1	1
08/15/2021 17:00	1	1
08/15/2021 18:00	1	1
08/15/2021 19:00	1	1
08/15/2021 20:00	1	1
08/15/2021 21:00	1	1
08/15/2021 22:00	1	1
08/15/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 08:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
08/16/2021 00:00	1	1
08/16/2021 01:00	1	1
08/16/2021 02:00	1	1
08/16/2021 03:00	1	1
08/16/2021 04:00	1	1
08/16/2021 05:00	1	1
08/16/2021 06:00	1	1
08/16/2021 07:00	1	1
08/16/2021 08:00	1	1
08/16/2021 09:00	1	1
08/16/2021 10:00	1	1
08/16/2021 11:00	1	1
08/16/2021 12:00	1	1
08/16/2021 13:00	1	1
08/16/2021 14:00	1	1
08/16/2021 15:00	1	1
08/16/2021 16:00	1	1
08/16/2021 17:00	1	1
08/16/2021 18:00	1	1
08/16/2021 19:00	1	1
08/16/2021 20:00	1	1
08/16/2021 21:00	1	1
08/16/2021 22:00	1	1
08/16/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 08:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
08/17/2021 00:00	1	1
08/17/2021 01:00	1	1
08/17/2021 02:00	1	1
08/17/2021 03:00	1	1
08/17/2021 04:00	1	1
08/17/2021 05:00	1	1
08/17/2021 06:00	1	1
08/17/2021 07:00	1	1
08/17/2021 08:00	1	1
08/17/2021 09:00	1	1
08/17/2021 10:00	1	1
08/17/2021 11:00	1	1
08/17/2021 12:00	1	1
08/17/2021 13:00	1	1
08/17/2021 14:00	1	1
08/17/2021 15:00	1	1
08/17/2021 16:00	1	1
08/17/2021 17:00	1	1
08/17/2021 18:00	1	1
08/17/2021 19:00	1	1
08/17/2021 20:00	1	1
08/17/2021 21:00	1	1
08/17/2021 22:00	1	1
08/17/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 08:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
08/18/2021 00:00	1	1
08/18/2021 01:00	1	1
08/18/2021 02:00	1	1
08/18/2021 03:00	1	1
08/18/2021 04:00	1	1
08/18/2021 05:00	1	1
08/18/2021 06:00	1	1
08/18/2021 07:00	1	1
08/18/2021 08:00	1	1
08/18/2021 09:00	1	1
08/18/2021 10:00	1	1
08/18/2021 11:00	1	1
08/18/2021 12:00	1	1
08/18/2021 13:00	1	1
08/18/2021 14:00	1	1
08/18/2021 15:00	1	1
08/18/2021 16:00	1	1
08/18/2021 17:00	1	1
08/18/2021 18:00	1	1
08/18/2021 19:00	1	1
08/18/2021 20:00	1	1
08/18/2021 21:00	1	1
08/18/2021 22:00	1	1
08/18/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 08:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
08/19/2021 00:00	1	1
08/19/2021 01:00	1	1
08/19/2021 02:00	1	1
08/19/2021 03:00	1	1
08/19/2021 04:00	1	1
08/19/2021 05:00	1	1
08/19/2021 06:00	1	1
08/19/2021 07:00	1	1
08/19/2021 08:00	1	1
08/19/2021 09:00	1	1
08/19/2021 10:00	1	1
08/19/2021 11:00	0	1
08/19/2021 12:00	0	1
08/19/2021 13:00	0	1
08/19/2021 14:00	0	1
08/19/2021 15:00	1	1
08/19/2021 16:00	1	1
08/19/2021 17:00	1	1
08/19/2021 18:00	1	1
08/19/2021 19:00	1	1
08/19/2021 20:00	1	1
08/19/2021 21:00	1	1
08/19/2021 22:00	1	1
08/19/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	0	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 08:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
08/20/2021 00:00	1	1
08/20/2021 01:00	1	1
08/20/2021 02:00	1	1
08/20/2021 03:00	1	1
08/20/2021 04:00	1	1
08/20/2021 05:00	1	1
08/20/2021 06:00	1	1
08/20/2021 07:00	1	1
08/20/2021 08:00	1	1
08/20/2021 09:00	1	1
08/20/2021 10:00	1	1
08/20/2021 11:00	1	1
08/20/2021 12:00	1	1
08/20/2021 13:00	1	1
08/20/2021 14:00	1	1
08/20/2021 15:00	1	1
08/20/2021 16:00	1	1
08/20/2021 17:00	1	1
08/20/2021 18:00	1	1
08/20/2021 19:00	1	1
08/20/2021 20:00	1	1
08/20/2021 21:00	1	1
08/20/2021 22:00	1	1
08/20/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 08:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
08/21/2021 00:00	2	2
08/21/2021 01:00	2	2
08/21/2021 02:00	2	2
08/21/2021 03:00	2	2
08/21/2021 04:00	2	1
08/21/2021 05:00	2	1
08/21/2021 06:00	2	1
08/21/2021 07:00	2	1
08/21/2021 08:00	2	1
08/21/2021 09:00	2	1
08/21/2021 10:00	2	1
08/21/2021 11:00	2	1
08/21/2021 12:00	2	1
08/21/2021 13:00	2	1
08/21/2021 14:00	2	1
08/21/2021 15:00	2	1
08/21/2021 16:00	2	1
08/21/2021 17:00	2	1
08/21/2021 18:00	2	1
08/21/2021 19:00	2	1
08/21/2021 20:00	2	1
08/21/2021 21:00	2	1
08/21/2021 22:00	2	1
08/21/2021 23:00	2	1
Average/Sum#:	2	1
Minimum:	2	1
Maximum:	2	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 08:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
08/22/2021 00:00	2	1
08/22/2021 01:00	2	1
08/22/2021 02:00	2	1
08/22/2021 03:00	2	1
08/22/2021 04:00	2	1
08/22/2021 05:00	2	1
08/22/2021 06:00	2	1
08/22/2021 07:00	2	1
08/22/2021 08:00	2	1
08/22/2021 09:00	2	1
08/22/2021 10:00	2	1
08/22/2021 11:00	2	1
08/22/2021 12:00	2	1
08/22/2021 13:00	2	1
08/22/2021 14:00	2	1
08/22/2021 15:00	2	1
08/22/2021 16:00	2	1
08/22/2021 17:00	2	1
08/22/2021 18:00	2	1
08/22/2021 19:00	2	1
08/22/2021 20:00	2	1
08/22/2021 21:00	2	1
08/22/2021 22:00	2	1
08/22/2021 23:00	2	1
Average/Sum#:	2	1
Minimum:	2	1
Maximum:	2	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 08:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
08/23/2021 00:00	2	1
08/23/2021 01:00	2	1
08/23/2021 02:00	2	1
08/23/2021 03:00	2	1
08/23/2021 04:00	2	1
08/23/2021 05:00	2	1
08/23/2021 06:00	2	1
08/23/2021 07:00	2	1
08/23/2021 08:00	2	1
08/23/2021 09:00	2	12
08/23/2021 10:00	2	17
08/23/2021 11:00	2	19
08/23/2021 12:00	2	19
08/23/2021 13:00	2	10
08/23/2021 14:00	2	7
08/23/2021 15:00	2	4
08/23/2021 16:00	17	4
08/23/2021 17:00	21	3
08/23/2021 18:00	21	1
08/23/2021 19:00	20	1
08/23/2021 20:00	5	1
08/23/2021 21:00	1	1
08/23/2021 22:00	1	1
08/23/2021 23:00	1	1
Average/Sum#:	5	5
Minimum:	1	1
Maximum:	21	19
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 08:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
08/24/2021 00:00	1	1
08/24/2021 01:00	1	1
08/24/2021 02:00	1	1
08/24/2021 03:00	1	1
08/24/2021 04:00	1	1
08/24/2021 05:00	1	1
08/24/2021 06:00	1	1
08/24/2021 07:00	1	1
08/24/2021 08:00	1	1
08/24/2021 09:00	1	1
08/24/2021 10:00	1	1
08/24/2021 11:00	1	1
08/24/2021 12:00	0	1
08/24/2021 13:00	0	1
08/24/2021 14:00	1	1
08/24/2021 15:00	1	1
08/24/2021 16:00	1	1
08/24/2021 17:00	1	1
08/24/2021 18:00	1	1
08/24/2021 19:00	1	1
08/24/2021 20:00	1	1
08/24/2021 21:00	1	1
08/24/2021 22:00	1	1
08/24/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	0	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 08:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
08/25/2021 00:00	1	1
08/25/2021 01:00	1	1
08/25/2021 02:00	1	1
08/25/2021 03:00	1	1
08/25/2021 04:00	1	1
08/25/2021 05:00	1	1
08/25/2021 06:00	1	1
08/25/2021 07:00	1	1
08/25/2021 08:00	1	1
08/25/2021 09:00	1	1
08/25/2021 10:00	1	1
08/25/2021 11:00	1	1
08/25/2021 12:00	1	1
08/25/2021 13:00	1	1
08/25/2021 14:00	1	1
08/25/2021 15:00	1	1
08/25/2021 16:00	1	1
08/25/2021 17:00	1	1
08/25/2021 18:00	1	1
08/25/2021 19:00	1	1
08/25/2021 20:00	1	1
08/25/2021 21:00	1	1
08/25/2021 22:00	1	1
08/25/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 08:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
08/26/2021 00:00	1	1
08/26/2021 01:00	1	1
08/26/2021 02:00	1	1
08/26/2021 03:00	1	1
08/26/2021 04:00	1	1
08/26/2021 05:00	1	1
08/26/2021 06:00	1	1
08/26/2021 07:00	1	1
08/26/2021 08:00	1	1
08/26/2021 09:00	1	1
08/26/2021 10:00	1	1
08/26/2021 11:00	1	1
08/26/2021 12:00	1	1
08/26/2021 13:00	1	1
08/26/2021 14:00	1	1
08/26/2021 15:00	1	1
08/26/2021 16:00	1	1
08/26/2021 17:00	1	1
08/26/2021 18:00	1	1
08/26/2021 19:00	1	1
08/26/2021 20:00	1	1
08/26/2021 21:00	1	1
08/26/2021 22:00	1	1
08/26/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 08:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
08/27/2021 00:00	1	1
08/27/2021 01:00	1	1
08/27/2021 02:00	1	1
08/27/2021 03:00	1	1
08/27/2021 04:00	1	1
08/27/2021 05:00	1	1
08/27/2021 06:00	1	1
08/27/2021 07:00	1	1
08/27/2021 08:00	1	1
08/27/2021 09:00	1	1
08/27/2021 10:00	1	1
08/27/2021 11:00	1	1
08/27/2021 12:00	1	1
08/27/2021 13:00	1	1
08/27/2021 14:00	1	1
08/27/2021 15:00	1	1
08/27/2021 16:00	1	1
08/27/2021 17:00	1	1
08/27/2021 18:00	1	1
08/27/2021 19:00	1	1
08/27/2021 20:00	1	1
08/27/2021 21:00	1	1
08/27/2021 22:00	1	1
08/27/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 08:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
08/28/2021 00:00	1	1
08/28/2021 01:00	1	1
08/28/2021 02:00	1	1
08/28/2021 03:00	1	1
08/28/2021 04:00	1	1
08/28/2021 05:00	1	1
08/28/2021 06:00	1	1
08/28/2021 07:00	1	1
08/28/2021 08:00	0	1
08/28/2021 09:00	0	1
08/28/2021 10:00	1	1
08/28/2021 11:00	1	1
08/28/2021 12:00	1	1
08/28/2021 13:00	1	1
08/28/2021 14:00	1	1
08/28/2021 15:00	1	1
08/28/2021 16:00	1	1
08/28/2021 17:00	1	1
08/28/2021 18:00	1	1
08/28/2021 19:00	1	1
08/28/2021 20:00	1	1
08/28/2021 21:00	1	1
08/28/2021 22:00	1	1
08/28/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	0	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 08:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
08/29/2021 00:00	1	1
08/29/2021 01:00	1	1
08/29/2021 02:00	1	1
08/29/2021 03:00	1	1
08/29/2021 04:00	1	1
08/29/2021 05:00	1	1
08/29/2021 06:00	1	1
08/29/2021 07:00	0	1
08/29/2021 08:00	0	1
08/29/2021 09:00	0	1
08/29/2021 10:00	1	1
08/29/2021 11:00	1	1
08/29/2021 12:00	1	1
08/29/2021 13:00	1	1
08/29/2021 14:00	1	1
08/29/2021 15:00	1	1
08/29/2021 16:00	1	1
08/29/2021 17:00	1	1
08/29/2021 18:00	1	1
08/29/2021 19:00	1	1
08/29/2021 20:00	1	1
08/29/2021 21:00	1	1
08/29/2021 22:00	1	1
08/29/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	0	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 08:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
08/30/2021 00:00	1	1
08/30/2021 01:00	1	1
08/30/2021 02:00	1	1
08/30/2021 03:00	1	1
08/30/2021 04:00	1	1
08/30/2021 05:00	1	1
08/30/2021 06:00	1	1
08/30/2021 07:00	1	1
08/30/2021 08:00	1	1
08/30/2021 09:00	1	1
08/30/2021 10:00	1	1
08/30/2021 11:00	1	1
08/30/2021 12:00	1	1
08/30/2021 13:00	1	1
08/30/2021 14:00	1	1
08/30/2021 15:00	1	1
08/30/2021 16:00	1	1
08/30/2021 17:00	1	1
08/30/2021 18:00	1	1
08/30/2021 19:00	1	1
08/30/2021 20:00	1	1
08/30/2021 21:00	1	1
08/30/2021 22:00	1	1
08/30/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 08:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
08/31/2021 00:00	1	1
08/31/2021 01:00	1	1
08/31/2021 02:00	1	1
08/31/2021 03:00	1	1
08/31/2021 04:00	1	1
08/31/2021 05:00	1	1
08/31/2021 06:00	1	1
08/31/2021 07:00	1	1
08/31/2021 08:00	1	1
08/31/2021 09:00	1	1
08/31/2021 10:00	1	1
08/31/2021 11:00	1	1
08/31/2021 12:00	1	1
08/31/2021 13:00	1	1
08/31/2021 14:00	1	1
08/31/2021 15:00	1	1
08/31/2021 16:00	1	1
08/31/2021 17:00	1	1
08/31/2021 18:00	1	1
08/31/2021 19:00	1	1
08/31/2021 20:00	1	1
08/31/2021 21:00	1	1
08/31/2021 22:00	1	1
08/31/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 08:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
09/01/2021 00:00	1	1
09/01/2021 01:00	1	1
09/01/2021 02:00	1	1
09/01/2021 03:00	1	1
09/01/2021 04:00	1	1
09/01/2021 05:00	1	1
09/01/2021 06:00	1	1
09/01/2021 07:00	1	1
09/01/2021 08:00	1	1
09/01/2021 09:00	1	1
09/01/2021 10:00	1	1
09/01/2021 11:00	1	1
09/01/2021 12:00	1	1
09/01/2021 13:00	1	1
09/01/2021 14:00	1	1
09/01/2021 15:00	1	1
09/01/2021 16:00	1	1
09/01/2021 17:00	1	1
09/01/2021 18:00	1	1
09/01/2021 19:00	1	1
09/01/2021 20:00	1	1
09/01/2021 21:00	1	1
09/01/2021 22:00	1	1
09/01/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 08:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
09/02/2021 00:00	1	1
09/02/2021 01:00	1	1
09/02/2021 02:00	1	1
09/02/2021 03:00	1	1
09/02/2021 04:00	1	1
09/02/2021 05:00	1	1
09/02/2021 06:00	1	1
09/02/2021 07:00	1	1
09/02/2021 08:00	1	1
09/02/2021 09:00	1	1
09/02/2021 10:00	1	1
09/02/2021 11:00	1	1
09/02/2021 12:00	1	1
09/02/2021 13:00	1	1
09/02/2021 14:00	1	1
09/02/2021 15:00	1	1
09/02/2021 16:00	1	1
09/02/2021 17:00	1	1
09/02/2021 18:00	1	1
09/02/2021 19:00	1	1
09/02/2021 20:00	1	1
09/02/2021 21:00	1	1
09/02/2021 22:00	1	1
09/02/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 08:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
09/03/2021 00:00	1	1
09/03/2021 01:00	1	1
09/03/2021 02:00	1	1
09/03/2021 03:00	1	1
09/03/2021 04:00	1	1
09/03/2021 05:00	1	1
09/03/2021 06:00	1	1
09/03/2021 07:00	1	1
09/03/2021 08:00	1	1
09/03/2021 09:00	1	1
09/03/2021 10:00	1	1
09/03/2021 11:00	1	1
09/03/2021 12:00	1	1
09/03/2021 13:00	1	1
09/03/2021 14:00	1	1
09/03/2021 15:00	1	1
09/03/2021 16:00	1	1
09/03/2021 17:00	1	1
09/03/2021 18:00	1	1
09/03/2021 19:00	1	1
09/03/2021 20:00	1	1
09/03/2021 21:00	1	1
09/03/2021 22:00	1	1
09/03/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 08:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
09/04/2021 00:00	1	1
09/04/2021 01:00	1	1
09/04/2021 02:00	1	1
09/04/2021 03:00	1	1
09/04/2021 04:00	1	1
09/04/2021 05:00	1	1
09/04/2021 06:00	1	1
09/04/2021 07:00	1	1
09/04/2021 08:00	1	1
09/04/2021 09:00	2	1
09/04/2021 10:00	4	1
09/04/2021 11:00	4	1
09/04/2021 12:00	4	1
09/04/2021 13:00	3	10
09/04/2021 14:00	1	12
09/04/2021 15:00	1	12
09/04/2021 16:00	1	12
09/04/2021 17:00	1	3
09/04/2021 18:00	1	1
09/04/2021 19:00	1	1
09/04/2021 20:00	1	1
09/04/2021 21:00	1	1
09/04/2021 22:00	1	1
09/04/2021 23:00	1	1
Average/Sum#:	2	3
Minimum:	1	1
Maximum:	4	12
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 08:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
09/05/2021 00:00	1	1
09/05/2021 01:00	1	1
09/05/2021 02:00	1	1
09/05/2021 03:00	1	1
09/05/2021 04:00	1	1
09/05/2021 05:00	1	1
09/05/2021 06:00	1	1
09/05/2021 07:00	1	1
09/05/2021 08:00	1	1
09/05/2021 09:00	1	1
09/05/2021 10:00	1	1
09/05/2021 11:00	1	1
09/05/2021 12:00	1	1
09/05/2021 13:00	1	1
09/05/2021 14:00	1	1
09/05/2021 15:00	1	1
09/05/2021 16:00	1	1
09/05/2021 17:00	1	1
09/05/2021 18:00	1	1
09/05/2021 19:00	1	1
09/05/2021 20:00	1	1
09/05/2021 21:00	1	1
09/05/2021 22:00	1	1
09/05/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 08:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
09/06/2021 00:00	1	1
09/06/2021 01:00	1	1
09/06/2021 02:00	1	1
09/06/2021 03:00	1	1
09/06/2021 04:00	1	1
09/06/2021 05:00	1	1
09/06/2021 06:00	1	1
09/06/2021 07:00	1	1
09/06/2021 08:00	1	1
09/06/2021 09:00	1	1
09/06/2021 10:00	1	1
09/06/2021 11:00	1	1
09/06/2021 12:00	1	1
09/06/2021 13:00	1	1
09/06/2021 14:00	1	1
09/06/2021 15:00	1	1
09/06/2021 16:00	1	1
09/06/2021 17:00	1	1
09/06/2021 18:00	1	1
09/06/2021 19:00	1	1
09/06/2021 20:00	1	1
09/06/2021 21:00	1	1
09/06/2021 22:00	1	1
09/06/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 08:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
09/07/2021 00:00	1	1
09/07/2021 01:00	1	1
09/07/2021 02:00	1	1
09/07/2021 03:00	1	1
09/07/2021 04:00	1	1
09/07/2021 05:00	1	1
09/07/2021 06:00	1	1
09/07/2021 07:00	1	1
09/07/2021 08:00	1	1
09/07/2021 09:00	1	1
09/07/2021 10:00	1	1
09/07/2021 11:00	1	1
09/07/2021 12:00	1	1
09/07/2021 13:00	1	1
09/07/2021 14:00	1	1
09/07/2021 15:00	1	1
09/07/2021 16:00	1	1
09/07/2021 17:00	1	1
09/07/2021 18:00	1	1
09/07/2021 19:00	1	1
09/07/2021 20:00	1	1
09/07/2021 21:00	1	1
09/07/2021 22:00	1	1
09/07/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 08:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
09/08/2021 00:00	1	1
09/08/2021 01:00	1	1
09/08/2021 02:00	1	1
09/08/2021 03:00	1	1
09/08/2021 04:00	1	1
09/08/2021 05:00	1	1
09/08/2021 06:00	1	1
09/08/2021 07:00	1	1
09/08/2021 08:00	1	1
09/08/2021 09:00	1	1
09/08/2021 10:00	1	1
09/08/2021 11:00	1	1
09/08/2021 12:00	1	1
09/08/2021 13:00	1	1
09/08/2021 14:00	1	1
09/08/2021 15:00	1	1
09/08/2021 16:00	1	1
09/08/2021 17:00	1	1
09/08/2021 18:00	1	1
09/08/2021 19:00	1	1
09/08/2021 20:00	1	1
09/08/2021 21:00	1	1
09/08/2021 22:00	1	1
09/08/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 08:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
09/09/2021 00:00	1	1
09/09/2021 01:00	1	1
09/09/2021 02:00	1	1
09/09/2021 03:00	1	1
09/09/2021 04:00	1	1
09/09/2021 05:00	1	1
09/09/2021 06:00	1	1
09/09/2021 07:00	1	1
09/09/2021 08:00	1	1
09/09/2021 09:00	1	1
09/09/2021 10:00	1	1
09/09/2021 11:00	1	1
09/09/2021 12:00	1	1
09/09/2021 13:00	1	1
09/09/2021 14:00	1	1
09/09/2021 15:00	1	1
09/09/2021 16:00	1	1
09/09/2021 17:00	1	1
09/09/2021 18:00	1	1
09/09/2021 19:00	1	1
09/09/2021 20:00	1	1
09/09/2021 21:00	1	1
09/09/2021 22:00	1	1
09/09/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 08:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
09/10/2021 00:00	1	1
09/10/2021 01:00	1	1
09/10/2021 02:00	1	1
09/10/2021 03:00	1	1
09/10/2021 04:00	1	1
09/10/2021 05:00	1	1
09/10/2021 06:00	1	1
09/10/2021 07:00	1	1
09/10/2021 08:00	1	1
09/10/2021 09:00	1	1
09/10/2021 10:00	1	1
09/10/2021 11:00	1	1
09/10/2021 12:00	1	1
09/10/2021 13:00	1	1
09/10/2021 14:00	1	1
09/10/2021 15:00	1	1
09/10/2021 16:00	1	1
09/10/2021 17:00	1	1
09/10/2021 18:00	1	1
09/10/2021 19:00	1	1
09/10/2021 20:00	1	1
09/10/2021 21:00	1	1
09/10/2021 22:00	1	1
09/10/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 08:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
09/11/2021 00:00	1	1
09/11/2021 01:00	1	1
09/11/2021 02:00	1	1
09/11/2021 03:00	1	1
09/11/2021 04:00	1	1
09/11/2021 05:00	1	1
09/11/2021 06:00	1	1
09/11/2021 07:00	1	1
09/11/2021 08:00	1	1
09/11/2021 09:00	1	1
09/11/2021 10:00	1	1
09/11/2021 11:00	1	1
09/11/2021 12:00	1	1
09/11/2021 13:00	1	1
09/11/2021 14:00	1	1
09/11/2021 15:00	1	1
09/11/2021 16:00	1	1
09/11/2021 17:00	1	1
09/11/2021 18:00	1	1
09/11/2021 19:00	1	1
09/11/2021 20:00	1	1
09/11/2021 21:00	1	1
09/11/2021 22:00	1	1
09/11/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 08:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
09/12/2021 00:00	1	1
09/12/2021 01:00	1	1
09/12/2021 02:00	1	1
09/12/2021 03:00	1	1
09/12/2021 04:00	1	1
09/12/2021 05:00	1	1
09/12/2021 06:00	1	1
09/12/2021 07:00	1	1
09/12/2021 08:00	1	1
09/12/2021 09:00	1	1
09/12/2021 10:00	1	1
09/12/2021 11:00	1	1
09/12/2021 12:00	1	1
09/12/2021 13:00	1	1
09/12/2021 14:00	1	1
09/12/2021 15:00	1	1
09/12/2021 16:00	1	1
09/12/2021 17:00	1	1
09/12/2021 18:00	1	1
09/12/2021 19:00	1	1
09/12/2021 20:00	1	1
09/12/2021 21:00	1	1
09/12/2021 22:00	1	1
09/12/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 08:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
09/13/2021 00:00	1	1
09/13/2021 01:00	1	1
09/13/2021 02:00	1	1
09/13/2021 03:00	1	1
09/13/2021 04:00	1	1
09/13/2021 05:00	1	1
09/13/2021 06:00	1	1
09/13/2021 07:00	1	1
09/13/2021 08:00	1	1
09/13/2021 09:00	1	1
09/13/2021 10:00	1	1
09/13/2021 11:00	1	1
09/13/2021 12:00	1	1
09/13/2021 13:00	1	1
09/13/2021 14:00	1	1
09/13/2021 15:00	1	1
09/13/2021 16:00	1	1
09/13/2021 17:00	1	1
09/13/2021 18:00	1	1
09/13/2021 19:00	1	1
09/13/2021 20:00	1	1
09/13/2021 21:00	1	1
09/13/2021 22:00	1	1
09/13/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 08:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
09/14/2021 00:00	1	1
09/14/2021 01:00	1	1
09/14/2021 02:00	1	1
09/14/2021 03:00	1	1
09/14/2021 04:00	1	1
09/14/2021 05:00	1	1
09/14/2021 06:00	1	1
09/14/2021 07:00	1	1
09/14/2021 08:00	1	1
09/14/2021 09:00	1	1
09/14/2021 10:00	1	1
09/14/2021 11:00	1	1
09/14/2021 12:00	1	1
09/14/2021 13:00	1	1
09/14/2021 14:00	1	1
09/14/2021 15:00	1	1
09/14/2021 16:00	1	1
09/14/2021 17:00	1	1
09/14/2021 18:00	1	1
09/14/2021 19:00	1	1
09/14/2021 20:00	1	1
09/14/2021 21:00	1	1
09/14/2021 22:00	1	1
09/14/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 08:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
09/15/2021 00:00	1	1
09/15/2021 01:00	1	1
09/15/2021 02:00	1	1
09/15/2021 03:00	1	1
09/15/2021 04:00	1	1
09/15/2021 05:00	1	1
09/15/2021 06:00	1	1
09/15/2021 07:00	1	1
09/15/2021 08:00	1	1
09/15/2021 09:00	1	1
09/15/2021 10:00	1	1
09/15/2021 11:00	1	1
09/15/2021 12:00	1	1
09/15/2021 13:00	1	1
09/15/2021 14:00	1	1
09/15/2021 15:00	1	1
09/15/2021 16:00	1	1
09/15/2021 17:00	1	1
09/15/2021 18:00	1	1
09/15/2021 19:00	1	1
09/15/2021 20:00	1	1
09/15/2021 21:00	1	1
09/15/2021 22:00	1	1
09/15/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 08:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
09/16/2021 00:00	1	1
09/16/2021 01:00	1	1
09/16/2021 02:00	1	1
09/16/2021 03:00	1	1
09/16/2021 04:00	1	1
09/16/2021 05:00	1	1
09/16/2021 06:00	1	1
09/16/2021 07:00	1	1
09/16/2021 08:00	1	1
09/16/2021 09:00	1	1
09/16/2021 10:00	1	1
09/16/2021 11:00	1	1
09/16/2021 12:00	1	5
09/16/2021 13:00	1	10
09/16/2021 14:00	1	10
09/16/2021 15:00	1	10
09/16/2021 16:00	1	6
09/16/2021 17:00	1	1
09/16/2021 18:00	1	1
09/16/2021 19:00	1	1
09/16/2021 20:00	1	1
09/16/2021 21:00	1	1
09/16/2021 22:00	1	1
09/16/2021 23:00	1	1
Average/Sum#:	1	3
Minimum:	1	1
Maximum:	1	10
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 08:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
09/17/2021 00:00	1	1
09/17/2021 01:00	1	1
09/17/2021 02:00	1	2
09/17/2021 03:00	1	2
09/17/2021 04:00	1	2
09/17/2021 05:00	1	2
09/17/2021 06:00	1	2
09/17/2021 07:00	1	2
09/17/2021 08:00	1	2
09/17/2021 09:00	1	2
09/17/2021 10:00	1	2
09/17/2021 11:00	1	2
09/17/2021 12:00	1	2
09/17/2021 13:00	1	12
09/17/2021 14:00	1	15
09/17/2021 15:00	1	15
09/17/2021 16:00	1	14
09/17/2021 17:00	1	4
09/17/2021 18:00	1	1
09/17/2021 19:00	1	1
09/17/2021 20:00	1	1
09/17/2021 21:00	1	1
09/17/2021 22:00	1	1
09/17/2021 23:00	1	1
Average/Sum#:	1	4
Minimum:	1	1
Maximum:	1	15
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 08:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
09/18/2021 00:00	1	2
09/18/2021 01:00	1	2
09/18/2021 02:00	1	2
09/18/2021 03:00	1	2
09/18/2021 04:00	1	2
09/18/2021 05:00	1	2
09/18/2021 06:00	1	2
09/18/2021 07:00	1	2
09/18/2021 08:00	1	2
09/18/2021 09:00	1	2
09/18/2021 10:00	1	2
09/18/2021 11:00	1	2
09/18/2021 12:00	1	2
09/18/2021 13:00	1	2
09/18/2021 14:00	1	2
09/18/2021 15:00	1	2
09/18/2021 16:00	1	2
09/18/2021 17:00	1	2
09/18/2021 18:00	1	2
09/18/2021 19:00	1	2
09/18/2021 20:00	1	2
09/18/2021 21:00	1	2
09/18/2021 22:00	1	2
09/18/2021 23:00	1	2
Average/Sum#:	1	2
Minimum:	1	2
Maximum:	1	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 08:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
09/19/2021 00:00	1	2
09/19/2021 01:00	1	2
09/19/2021 02:00	1	2
09/19/2021 03:00	1	2
09/19/2021 04:00	1	2
09/19/2021 05:00	1	2
09/19/2021 06:00	1	2
09/19/2021 07:00	1	2
09/19/2021 08:00	1	2
09/19/2021 09:00	1	2
09/19/2021 10:00	1	2
09/19/2021 11:00	1	2
09/19/2021 12:00	1	2
09/19/2021 13:00	1	2
09/19/2021 14:00	1	2
09/19/2021 15:00	1	2
09/19/2021 16:00	1	2
09/19/2021 17:00	1	2
09/19/2021 18:00	1	2
09/19/2021 19:00	1	2
09/19/2021 20:00	1	2
09/19/2021 21:00	1	2
09/19/2021 22:00	1	2
09/19/2021 23:00	1	2
Average/Sum#:	1	2
Minimum:	1	2
Maximum:	1	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 08:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
09/20/2021 00:00	1	2
09/20/2021 01:00	1	12
09/20/2021 02:00	1	20
09/20/2021 03:00	1	21
09/20/2021 04:00	1	20
09/20/2021 05:00	1	10
09/20/2021 06:00	1	1
09/20/2021 07:00	1	1
09/20/2021 08:00	1	1
09/20/2021 09:00	1	1
09/20/2021 10:00	1	1
09/20/2021 11:00	1	1
09/20/2021 12:00	1	1
09/20/2021 13:00	1	1
09/20/2021 14:00	1	1
09/20/2021 15:00	1	1
09/20/2021 16:00	1	1
09/20/2021 17:00	1	1
09/20/2021 18:00	1	1
09/20/2021 19:00	1	1
09/20/2021 20:00	1	1
09/20/2021 21:00	1	1
09/20/2021 22:00	1	1
09/20/2021 23:00	1	1
Average/Sum#:	1	4
Minimum:	1	1
Maximum:	1	21
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 08:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
09/21/2021 00:00	1	1
09/21/2021 01:00	1	1
09/21/2021 02:00	1	1
09/21/2021 03:00	1	1
09/21/2021 04:00	1	1
09/21/2021 05:00	1	1
09/21/2021 06:00	1	1
09/21/2021 07:00	1	1
09/21/2021 08:00	1	1
09/21/2021 09:00	1	1
09/21/2021 10:00	1	1
09/21/2021 11:00	1	1
09/21/2021 12:00	1	1
09/21/2021 13:00	1	1
09/21/2021 14:00	1	1
09/21/2021 15:00	1	1
09/21/2021 16:00	1	1
09/21/2021 17:00	1	1
09/21/2021 18:00	1	1
09/21/2021 19:00	1	1
09/21/2021 20:00	1	1
09/21/2021 21:00	1	1
09/21/2021 22:00	1	1
09/21/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 08:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
09/22/2021 00:00	1	1
09/22/2021 01:00	1	1
09/22/2021 02:00	1	1
09/22/2021 03:00	1	1
09/22/2021 04:00	1	1
09/22/2021 05:00	1	1
09/22/2021 06:00	1	1
09/22/2021 07:00	1	1
09/22/2021 08:00	1	1
09/22/2021 09:00	1	1
09/22/2021 10:00	1	1
09/22/2021 11:00	1	1
09/22/2021 12:00	1	1
09/22/2021 13:00	1	1
09/22/2021 14:00	1	1
09/22/2021 15:00	1	1
09/22/2021 16:00	1	1
09/22/2021 17:00	1	1
09/22/2021 18:00	1	1
09/22/2021 19:00	1	1
09/22/2021 20:00	1	1
09/22/2021 21:00	1	1
09/22/2021 22:00	1	1
09/22/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 08:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
09/23/2021 00:00	1	1
09/23/2021 01:00	1	1
09/23/2021 02:00	1	1
09/23/2021 03:00	1	1
09/23/2021 04:00	1	1
09/23/2021 05:00	1	1
09/23/2021 06:00	1	1
09/23/2021 07:00	1	1
09/23/2021 08:00	1	1
09/23/2021 09:00	1	1
09/23/2021 10:00	1	1
09/23/2021 11:00	1	1
09/23/2021 12:00	1	1
09/23/2021 13:00	1	1
09/23/2021 14:00	1	1
09/23/2021 15:00	1	1
09/23/2021 16:00	1	1
09/23/2021 17:00	1	1
09/23/2021 18:00	1	1
09/23/2021 19:00	1	1
09/23/2021 20:00	1	1
09/23/2021 21:00	1	1
09/23/2021 22:00	1	1
09/23/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 08:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
09/24/2021 00:00	1	1
09/24/2021 01:00	1	1
09/24/2021 02:00	1	1
09/24/2021 03:00	1	1
09/24/2021 04:00	1	1
09/24/2021 05:00	1	1
09/24/2021 06:00	1	1
09/24/2021 07:00	1	1
09/24/2021 08:00	1	1
09/24/2021 09:00	1	1
09/24/2021 10:00	1	1
09/24/2021 11:00	1	1
09/24/2021 12:00	1	1
09/24/2021 13:00	1	1
09/24/2021 14:00	1	1
09/24/2021 15:00	1	1
09/24/2021 16:00	1	1
09/24/2021 17:00	1	1
09/24/2021 18:00	1	1
09/24/2021 19:00	1	1
09/24/2021 20:00	1	1
09/24/2021 21:00	1	1
09/24/2021 22:00	1	1
09/24/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 08:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
09/25/2021 00:00	1	1
09/25/2021 01:00	1	1
09/25/2021 02:00	1	1
09/25/2021 03:00	1	1
09/25/2021 04:00	1	1
09/25/2021 05:00	1	1
09/25/2021 06:00	1	1
09/25/2021 07:00	1	1
09/25/2021 08:00	1	1
09/25/2021 09:00	1	1
09/25/2021 10:00	1	1
09/25/2021 11:00	1	1
09/25/2021 12:00	1	1
09/25/2021 13:00	1	1
09/25/2021 14:00	1	1
09/25/2021 15:00	1	1
09/25/2021 16:00	1	1
09/25/2021 17:00	1	1
09/25/2021 18:00	1	1
09/25/2021 19:00	1	1
09/25/2021 20:00	1	1
09/25/2021 21:00	1	1
09/25/2021 22:00	1	1
09/25/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 08:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
09/26/2021 00:00	1	1
09/26/2021 01:00	1	1
09/26/2021 02:00	1	1
09/26/2021 03:00	1	1
09/26/2021 04:00	1	1
09/26/2021 05:00	1	1
09/26/2021 06:00	1	1
09/26/2021 07:00	1	1
09/26/2021 08:00	1	1
09/26/2021 09:00	1	1
09/26/2021 10:00	1	1
09/26/2021 11:00	1	1
09/26/2021 12:00	1	1
09/26/2021 13:00	1	1
09/26/2021 14:00	1	1
09/26/2021 15:00	1	1
09/26/2021 16:00	1	1
09/26/2021 17:00	1	1
09/26/2021 18:00	1	1
09/26/2021 19:00	1	1
09/26/2021 20:00	1	1
09/26/2021 21:00	1	1
09/26/2021 22:00	1	1
09/26/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 08:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
09/27/2021 00:00	1	1
09/27/2021 01:00	1	1
09/27/2021 02:00	1	1
09/27/2021 03:00	1	1
09/27/2021 04:00	1	1
09/27/2021 05:00	1	1
09/27/2021 06:00	1	1
09/27/2021 07:00	1	1
09/27/2021 08:00	1	1
09/27/2021 09:00	1	1
09/27/2021 10:00	1	1
09/27/2021 11:00	1	1
09/27/2021 12:00	1	1
09/27/2021 13:00	1	1
09/27/2021 14:00	1	1
09/27/2021 15:00	1	1
09/27/2021 16:00	1	1
09/27/2021 17:00	1	1
09/27/2021 18:00	1	1
09/27/2021 19:00	1	1
09/27/2021 20:00	1	1
09/27/2021 21:00	1	1
09/27/2021 22:00	1	1
09/27/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 08:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
09/28/2021 00:00	1	1
09/28/2021 01:00	1	1
09/28/2021 02:00	1	1
09/28/2021 03:00	1	1
09/28/2021 04:00	1	1
09/28/2021 05:00	1	1
09/28/2021 06:00	1	1
09/28/2021 07:00	1	1
09/28/2021 08:00	1	1
09/28/2021 09:00	1	1
09/28/2021 10:00	1	1
09/28/2021 11:00	1	1
09/28/2021 12:00	1	1
09/28/2021 13:00	1	1
09/28/2021 14:00	1	1
09/28/2021 15:00	1	1
09/28/2021 16:00	1	1
09/28/2021 17:00	1	1
09/28/2021 18:00	1	1
09/28/2021 19:00	1	1
09/28/2021 20:00	1	1
09/28/2021 21:00	1	1
09/28/2021 22:00	1	1
09/28/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 08:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
09/29/2021 00:00	1	1
09/29/2021 01:00	1	1
09/29/2021 02:00	1	1
09/29/2021 03:00	17	1
09/29/2021 04:00	17	1
09/29/2021 05:00	17	1
09/29/2021 06:00	17	1
09/29/2021 07:00	17	1
09/29/2021 08:00	24	1
09/29/2021 09:00	28	1
09/29/2021 10:00	28	1
09/29/2021 11:00	16	1
09/29/2021 12:00	0	1
09/29/2021 13:00	0	1
09/29/2021 14:00	0	1
09/29/2021 15:00	1	1
09/29/2021 16:00	1	1
09/29/2021 17:00	1	1
09/29/2021 18:00	1	1
09/29/2021 19:00	1	1
09/29/2021 20:00	1	1
09/29/2021 21:00	1	1
09/29/2021 22:00	1	1
09/29/2021 23:00	1	1
Average/Sum#:	9	1
Minimum:	1	1
Maximum:	28	1
%SI	12.50	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 08:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
09/30/2021 00:00	1	1
09/30/2021 01:00	1	1
09/30/2021 02:00	1	1
09/30/2021 03:00	1	1
09/30/2021 04:00	1	1
09/30/2021 05:00	1	1
09/30/2021 06:00	1	3
09/30/2021 07:00	1	3
09/30/2021 08:00	1	3
09/30/2021 09:00	1	3
09/30/2021 10:00	1	3
09/30/2021 11:00	1	3
09/30/2021 12:00	1	3
09/30/2021 13:00	1	3
09/30/2021 14:00	0	3
09/30/2021 15:00	1	3
09/30/2021 16:00	1	3
09/30/2021 17:00	1	3
09/30/2021 18:00	1	3
09/30/2021 19:00	1	3
09/30/2021 20:00	1	3
09/30/2021 21:00	1	3
09/30/2021 22:00	1	3
09/30/2021 23:00	1	3
Average/Sum#:	1	3
Minimum:	0	1
Maximum:	1	3
%SI	0.00	0.00

ATTACHMENT 4
Excess Emission/Downtime Report

FCD: AQ-4
Title V: #29

EDS-CMS Reports

EDS/CMS Summary Report

CT1 - CO LbPerHr

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59
Generated: 10/04/2021 08:52

Facility Name: COLUSA GENERATING STATION
Location: Maxwell, CA
Description: Electric Utility

CMS Data from: CT1_CO_LbPerHr_1H
EDS Data from: CT1_CONormalOp_LbPerHr_1H
Emission Limitation: CT1_COLimit_LbPerHr_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML30
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Process Unit(s) Description:

Operating time for EDS: 1,776.00 Hour(s)
Operating time for CMS: 1,776.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	1
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	1
4. Time of Excess Emission as a percentage of operating time	0.06
5. Time in compliance as percentage of operating time	99.94

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	5
e. Unknown causes	0
2. Total CMS Downtime	5
3. Total Downtime as a percentage of operating time	0.28
4. Total Availability as a percentage of operating time	99.72

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

EDS/CMS Summary Report

CT1 - CO Ppmvdc

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/04/2021 08:53 **Location:** Maxwell, CA
Description: Electric Utility

CMS Data from: CT1_CO_Ppmvdc_1H
EDS Data from: CT1_CO_3Hr_Ppmvdc_1H
Emission Limitation: CT1_COLimit_3Hr_Ppmvdc_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML30
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Process Unit(s) Description:

Operating time for EDS: 1,776.00 Hour(s)
Operating time for CMS: 1,776.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	4
e. Unknown causes	1
2. Total CMS Downtime	5
3. Total Downtime as a percentage of operating time	0.28
4. Total Availability as a percentage of operating time	99.72

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

EDS/CMS Summary Report

CT1 - NOx LbPerHr

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/04/2021 08:53 **Location:** Maxwell, CA
Description: Electric Utility

CMS Data from: CT1_NOx_LbPerHr_1H
EDS Data from: CT1_NOxNormalOp_LbPerHr_1H
Emission Limitation: CT1_NOxLimit_LbPerHr_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML41-O2
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Process Unit(s) Description:

Operating time for EDS: 1,776.00 Hour(s)
Operating time for CMS: 1,776.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	3
e. Unknown causes	2
2. Total CMS Downtime	5
3. Total Downtime as a percentage of operating time	0.28
4. Total Availability as a percentage of operating time	99.72

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

EDS/CMS Summary Report

CT1 - NOx Ppmvdc

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/04/2021 08:54 **Location:** Maxwell, CA
Description: Electric Utility

CMS Data from: CT1_NOx_Ppmvdc_1H
EDS Data from: CT1_NOx_Ppmvdc_1H
Emission Limitation: CT1_NOxLimit_Ppmvdc_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML41-O2
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Process Unit(s) Description:

Operating time for EDS: 1,776.00 Hour(s)
Operating time for CMS: 1,776.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	5
e. Unknown causes	0
2. Total CMS Downtime	5
3. Total Downtime as a percentage of operating time	0.28
4. Total Availability as a percentage of operating time	99.72

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

EDS/CMS Summary Report

CT2 - CO LbPerHr

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/04/2021 08:54 **Location:** Maxwell, CA
Description: Electric Utility

CMS Data from: CT2_CO_LbPerHr_1H
EDS Data from: CT2_CONormalOp_LbPerHr_1H
Emission Limitation: CT2_COLimit_LbPerHr_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML30
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Process Unit(s) Description:

Operating time for EDS: 1,779.00 Hour(s)
Operating time for CMS: 1,779.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	4
e. Unknown causes	1
2. Total CMS Downtime	5
3. Total Downtime as a percentage of operating time	0.28
4. Total Availability as a percentage of operating time	99.72

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

EDS/CMS Summary Report

CT2 - CO Ppmvdc

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/04/2021 08:55 **Location:** Maxwell, CA
Description: Electric Utility

CMS Data from: CT2_CO_Ppmvdc_1H
EDS Data from: CT2_CO_3Hr_Ppmvdc_1H
Emission Limitation: CT2_COLimit_3Hr_Ppmvdc_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML30
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Process Unit(s) Description:

Operating time for EDS: 1,779.00 Hour(s)
Operating time for CMS: 1,779.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	3
e. Unknown causes	2
2. Total CMS Downtime	5
3. Total Downtime as a percentage of operating time	0.28
4. Total Availability as a percentage of operating time	99.72

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

EDS/CMS Summary Report

CT2 - NOx LbPerHr

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/04/2021 08:56 **Location:** Maxwell, CA
Description: Electric Utility

CMS Data from: CT2_NOx_LbPerHr_1H
EDS Data from: CT2_NOxNormalOp_LbPerHr_1H
Emission Limitation: CT2_NOxLimit_LbPerHr_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML41-O2
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Process Unit(s) Description:

Operating time for EDS: 1,779.00 Hour(s)
Operating time for CMS: 1,779.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	4
e. Unknown causes	1
2. Total CMS Downtime	5
3. Total Downtime as a percentage of operating time	0.28
4. Total Availability as a percentage of operating time	99.72

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

EDS/CMS Summary Report

CT2 - NOx Ppmvdc

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/04/2021 08:57 **Location:** Maxwell, CA
Description: Electric Utility

CMS Data from: CT2_NOx_Ppmvdc_1H
EDS Data from: CT2_NOx_Ppmvdc_1H
Emission Limitation: CT2_NOxLimit_Ppmvdc_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML41-O2
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Process Unit(s) Description:

Operating time for EDS: 1,779.00 Hour(s)
Operating time for CMS: 1,779.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	3
e. Unknown causes	2
2. Total CMS Downtime	5
3. Total Downtime as a percentage of operating time	0.28
4. Total Availability as a percentage of operating time	99.72

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

Excess Emission Report

CT1 - CO LbPerHr Normal Operating 1-Hour Block Average

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/13/2021 08:27 **Location:** Maxwell, CA

Tag Name: CT1_CONormalOp_LbPerHr_1H
Total Operating Time: 1,776.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 432.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,776.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 - CO Ppmvdc 3-Hour Rolling Average

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/04/2021 10:00 **Location:** Maxwell, CA

Tag Name: CT1_CO_3Hr_Ppmvdc_1H
Total Operating Time: 1,776.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 432.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,776.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 - NOx LbPerHr Normal Operating 1-Hour Block Average

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/04/2021 10:12 **Location:** Maxwell, CA

Tag Name: CT1_NOxNormalOp_LbPerHr_1H
Total Operating Time: 1,776.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 432.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,776.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 - NOx Ppmvdc 1-Hour Block Average

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/04/2021 10:13 **Location:** Maxwell, CA

Tag Name: CT1_NOx_Ppmvdc_1H
Total Operating Time: 1,776.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 432.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,776.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - CO LbPerHr Normal Operating 1-Hour Block Average

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/04/2021 10:13 **Location:** Maxwell, CA

Tag Name: CT2_CONormalOp_LbPerHr_1H
Total Operating Time: 1,779.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 429.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,779.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - CO Ppmvdc 3-Hour Rolling Average

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/04/2021 10:21 **Location:** Maxwell, CA

Tag Name: CT2_CO_3Hr_Ppmvdc_1H
Total Operating Time: 1,779.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 429.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,779.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - NOx LbPerHr Normal Operating 1-Hour Block Average

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/04/2021 10:22 **Location:** Maxwell, CA

Tag Name: CT2_NOxNormalOp_LbPerHr_1H
Total Operating Time: 1,779.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 429.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,779.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - NOx Ppmvdc 1-Hour Block Average

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/04/2021 10:23 **Location:** Maxwell, CA

Tag Name: CT2_NOx_Ppmvdc_1H
Total Operating Time: 1,779.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 429.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,779.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Invalid Data Report

CT1 - Stack CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/04/2021 10:23 **Location:** Maxwell, CA

Tag Name: CT1_CO_LbPerHr_1H
Total Operating Time: 1,776.00 Hour(s)
Non-Operating Time: 432.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	08/18/2021 09:00	08/18/2021 09:59	1	13 - Maintenance	3 - Performed manual calibration
2	08/19/2021 09:00	08/19/2021 09:59	1	13 - Maintenance	10 - Performed Linearity
3	08/19/2021 13:00	08/19/2021 13:59	1	13 - Maintenance	10 - Performed Linearity
4	09/29/2021 11:00	09/29/2021 12:59	2	13 - Maintenance	3 - Performed manual calibration

Total Operating Time:	**1,776.00 Hour(s)**
Total Monitor Downtime (Online only):	**5.00 Hour(s)**
Percent Monitor Availability:	**99.72 %**
Percent Monitor Downtime:	**0.28 %**

Report Code	Type	Text	Duration	Duration Percent
13	Reason	Maintenance	5	100.00
10	Action	Performed Linearity	2	40.00
3	Action	Performed manual calibration	3	60.00

Invalid Data Report

CT2 - Stack NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/04/2021 10:24 **Location:** Maxwell, CA

Tag Name: CT2_NOx_LbPerHr_1H
Total Operating Time: 1,779.00 Hour(s)
Non-Operating Time: 429.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	07/12/2021 07:00	07/12/2021 09:59	3	9 - CEMS failed calibration	3 - Performed manual calibration
2	08/18/2021 10:00	08/18/2021 10:59	1	13 - Maintenance	10 - Performed Linearity
3	08/23/2021 17:00	08/23/2021 17:59	1	3 - Quality assurance calibration	3 - Performed manual calibration

Total Operating Time:	**1,779.00 Hour(s)**
Total Monitor Downtime (Online only):	**5.00 Hour(s)**
Percent Monitor Availability:	**99.72 %**
Percent Monitor Downtime:	**0.28 %**

Report Code	Type	Text	Duration	Duration Percent
9	Reason	CEMS failed calibration	3	60.00
13	Reason	Maintenance	1	20.00
3	Reason	Quality assurance calibration	1	20.00
10	Action	Performed Linearity	1	20.00
3	Action	Performed manual calibration	4	80.00

Invalid Data Report

CT2 - Stack CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/04/2021 10:25 **Location:** Maxwell, CA

Tag Name: CT2_CO_LbPerHr_1H
Total Operating Time: 1,779.00 Hour(s)
Non-Operating Time: 429.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	07/12/2021 07:00	07/12/2021 09:59	3	9 - CEMS failed calibration	3 - Performed manual calibration
2	08/18/2021 10:00	08/18/2021 10:59	1	13 - Maintenance	10 - Performed Linearity
3	08/23/2021 17:00	08/23/2021 17:59	1	3 - Quality assurance calibration	3 - Performed manual calibration

Total Operating Time:	**1,779.00 Hour(s)**
Total Monitor Downtime (Online only):	**5.00 Hour(s)**
Percent Monitor Availability:	**99.72 %**
Percent Monitor Downtime:	**0.28 %**

Report Code	Type	Text	Duration	Duration Percent
9	Reason	CEMS failed calibration	3	60.00
13	Reason	Maintenance	1	20.00
3	Reason	Quality assurance calibration	1	20.00
10	Action	Performed Linearity	1	20.00
3	Action	Performed manual calibration	4	80.00

Invalid Data Report

CT2 - Stack NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/04/2021 10:25 **Location:** Maxwell, CA

Tag Name: CT2_NOx_LbPerHr_1H
Total Operating Time: 1,779.00 Hour(s)
Non-Operating Time: 429.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	07/12/2021 07:00	07/12/2021 09:59	3	9 - CEMS failed calibration	3 - Performed manual calibration
2	08/18/2021 10:00	08/18/2021 10:59	1	13 - Maintenance	10 - Performed Linearity
3	08/23/2021 17:00	08/23/2021 17:59	1	3 - Quality assurance calibration	3 - Performed manual calibration

Total Operating Time:	**1,779.00 Hour(s)**
Total Monitor Downtime (Online only):	**5.00 Hour(s)**
Percent Monitor Availability:	**99.72 %**
Percent Monitor Downtime:	**0.28 %**

Report Code	Type	Text	Duration	Duration Percent
9	Reason	CEMS failed calibration	3	60.00
13	Reason	Maintenance	1	20.00
3	Reason	Quality assurance calibration	1	20.00
10	Action	Performed Linearity	1	20.00
3	Action	Performed manual calibration	4	80.00

ATTACHMENT 5
Hourly Emissions – VOC

FCD: AQ-14
Title V: #6

Daily Summary Report

CT1 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/01/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/02/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/03/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/04/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/05/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/06/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/07/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/08/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/08/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/08/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/08/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/08/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/08/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/08/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/08/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/08/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/08/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/08/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/08/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/08/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/08/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/08/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/08/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/08/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/08/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/08/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/08/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/08/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/08/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/08/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/08/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/09/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/09/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/09/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/09/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/09/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/09/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/09/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/09/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/09/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/09/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/09/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/09/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/09/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/09/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/09/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/09/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/09/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/09/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/09/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/09/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/09/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/09/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/09/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/09/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/10/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/10/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/10/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/10/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/10/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/10/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/10/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/10/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/10/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/10/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/10/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/10/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/10/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/10/2021 13:00	0.0	17.5	277.5	0.0	0.2	1	0	0
07/10/2021 14:00	0.0	16.9	364.5	0.0	0.3	1	0	0
07/10/2021 15:00	0.0	15.6	636.7	0.0	0.4	1	0	0
07/10/2021 16:00	0.0	14.0	1,294.4	0.0	0.9	1	0	0
07/10/2021 17:00	0.5	13.5	1,643.7	0.5	1.2	1	1	0
07/10/2021 18:00	0.4	13.4	1,705.4	0.4	1.2	1	1	0
07/10/2021 19:00	0.4	13.4	1,711.6	0.4	1.2	1	1	0
07/10/2021 20:00	0.4	13.4	1,730.2	0.4	1.2	1	1	0
07/10/2021 21:00	0.4	13.4	1,742.3	0.4	1.2	1	1	0
07/10/2021 22:00	0.4	13.4	1,743.5	0.4	1.2	1	1	0
07/10/2021 23:00	0.0	14.1	1,326.0	0.0	0.9	1	0	0
Average/Sum#:	0.2	14.4	1,288.7	0.2	0.9	11 #	6 #	0 #
Minimum:	0.0	13.4	277.5	0.0	0.2	0	0	0
Maximum:	0.5	17.5	1,743.5	0.5	1.2	1	1	0
%SI	54.17	54.17	54.17	54.17	54.17	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/11/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/11/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/11/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/11/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/11/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/11/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/11/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/11/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/11/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/11/2021 09:00	0.0	17.5	319.9	0.0	0.2	1	0	0
07/11/2021 10:00	0.0	16.9	408.6	0.0	0.3	1	0	0
07/11/2021 11:00	0.0	14.4	1,082.8	0.0	0.8	1	0	0
07/11/2021 12:00	0.5	13.8	1,380.4	0.5	1.0	1	1	0
07/11/2021 13:00	0.5	13.7	1,485.8	0.5	1.0	1	1	0
07/11/2021 14:00	0.5	13.5	1,680.2	0.5	1.2	1	1	0
07/11/2021 15:00	0.4	13.5	1,625.7	0.4	1.1	1	1	0
07/11/2021 16:00	0.5	13.3	1,704.5	0.5	1.2	1	1	0
07/11/2021 17:00	0.5	13.4	1,707.9	0.5	1.2	1	1	0
07/11/2021 18:00	0.4	13.4	1,715.3	0.4	1.2	1	1	0
07/11/2021 19:00	0.4	13.4	1,723.8	0.4	1.2	1	1	0
07/11/2021 20:00	0.4	13.4	1,722.9	0.4	1.2	1	1	0
07/11/2021 21:00	0.4	13.5	1,709.5	0.4	1.2	1	1	0
07/11/2021 22:00	0.4	13.6	1,704.6	0.4	1.2	1	1	0
07/11/2021 23:00	0.4	13.5	1,673.2	0.4	1.2	1	1	0
Average/Sum#:	0.4	14.1	1,443.0	0.4	1.0	15 #	12 #	0 #
Minimum:	0.0	13.3	319.9	0.0	0.2	0	0	0
Maximum:	0.5	17.5	1,723.8	0.5	1.2	1	1	0
%SI	37.50	37.50	37.50	37.50	37.50	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/12/2021 00:00	0.4	13.5	1,705.3	0.4	1.2	1	1	0
07/12/2021 01:00	0.0	15.6	501.7	0.0	0.4	1	0	0
07/12/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/12/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/12/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/12/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/12/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/12/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/12/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/12/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/12/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/12/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/12/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/12/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/12/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/12/2021 15:00	0.0	17.9	277.5	0.0	0.2	1	0	0
07/12/2021 16:00	0.0	14.9	1,085.2	0.0	0.8	1	0	0
07/12/2021 17:00	0.5	13.4	1,748.9	0.5	1.2	1	1	0
07/12/2021 18:00	0.5	13.5	1,731.1	0.5	1.2	1	1	0
07/12/2021 19:00	0.5	13.5	1,735.7	0.5	1.2	1	1	0
07/12/2021 20:00	0.4	13.4	1,771.0	0.4	1.2	1	1	0
07/12/2021 21:00	0.4	13.4	1,756.0	0.4	1.2	1	1	0
07/12/2021 22:00	0.0	14.1	1,360.8	0.0	1.0	1	0	0
07/12/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.3	14.3	1,367.3	0.3	1.0	10 #	6 #	0 #
Minimum:	0.0	13.4	277.5	0.0	0.2	0	0	0
Maximum:	0.5	17.9	1,771.0	0.5	1.2	1	1	0
%SI	58.33	58.33	58.33	58.33	58.33	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/13/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/13/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/13/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/13/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/13/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/13/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/13/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/13/2021 07:00	0.0	17.6	333.6	0.0	0.2	1	0	0
07/13/2021 08:00	0.0	17.0	390.2	0.0	0.3	1	0	0
07/13/2021 09:00	0.0	17.1	345.5	0.0	0.2	1	0	0
07/13/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/13/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/13/2021 12:00	0.0	17.2	390.1	0.0	0.3	1	0	0
07/13/2021 13:00	0.0	15.8	618.9	0.0	0.4	1	0	0
07/13/2021 14:00	0.0	18.3	220.8	0.0	0.2	1	0	0
07/13/2021 15:00	0.0	15.9	661.2	0.0	0.5	1	0	0
07/13/2021 16:00	0.0	14.4	1,270.7	0.0	0.9	1	0	0
07/13/2021 17:00	0.5	13.4	1,757.7	0.5	1.2	1	1	0
07/13/2021 18:00	0.4	13.5	1,553.6	0.4	1.1	1	1	0
07/13/2021 19:00	0.4	13.4	1,726.7	0.4	1.2	1	1	0
07/13/2021 20:00	0.5	13.4	1,774.9	0.5	1.2	1	1	0
07/13/2021 21:00	0.0	14.0	1,397.2	0.0	1.0	1	0	0
07/13/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/13/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.1	15.5	957.0	0.1	0.7	13 #	4 #	0 #
Minimum:	0.0	13.4	220.8	0.0	0.2	0	0	0
Maximum:	0.5	18.3	1,774.9	0.5	1.2	1	1	0
%SI	45.83	45.83	45.83	45.83	45.83	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/14/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/14/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/14/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/14/2021 03:00	0.0	16.5	562.5	0.0	0.4	1	0	0
07/14/2021 04:00	0.0	13.9	1,425.1	0.0	1.0	1	0	0
07/14/2021 05:00	0.5	13.6	1,702.9	0.5	1.2	1	1	0
07/14/2021 06:00	0.4	13.6	1,641.4	0.4	1.1	1	1	0
07/14/2021 07:00	-0.5	13.6	1,679.9	-0.2	1.2	1	1	1
07/14/2021 08:00	-1.1	12.3	1,910.2	-0.5	1.3	1	1	1
07/14/2021 09:00	-1.7	12.4	1,992.3	-0.9	1.4	1	1	1
07/14/2021 10:00	0.5	13.6	1,664.5	0.5	1.2	1	1	0
07/14/2021 11:00	0.2	13.6	1,595.0	0.4	1.1	1	1	1
07/14/2021 12:00	-0.4	12.0	2,096.4	-0.1	1.5	1	1	1
07/14/2021 13:00	0.2	11.2	2,237.6	0.4	1.6	1	1	1
07/14/2021 14:00	0.4	11.2	2,233.0	0.5	1.6	1	1	1
07/14/2021 15:00	0.4	11.3	2,218.1	0.5	1.6	1	1	1
07/14/2021 16:00	0.5	11.2	2,235.0	0.5	1.6	1	1	1
07/14/2021 17:00	0.4	11.2	2,238.8	0.5	1.6	1	1	1
07/14/2021 18:00	0.4	11.3	2,222.0	0.5	1.6	1	1	1
07/14/2021 19:00	0.2	11.6	2,174.9	0.4	1.5	1	1	1
07/14/2021 20:00	0.2	11.6	2,159.8	0.4	1.5	1	1	1
07/14/2021 21:00	0.1	11.9	2,112.7	0.2	1.5	1	1	1
07/14/2021 22:00	-0.1	11.9	2,111.8	0.2	1.5	1	1	1
07/14/2021 23:00	-0.2	12.0	2,105.2	0.1	1.5	1	1	1
Average/Sum#:	0.0	12.5	1,920.0	0.2	1.4	21 #	19 #	16 #
Minimum:	-1.7	11.2	562.5	-0.9	0.4	0	0	0
Maximum:	0.5	16.5	2,238.8	0.5	1.6	1	1	1
%SI	12.50	12.50	12.50	12.50	12.50	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/15/2021 00:00	-0.9	12.3	2,016.4	-0.5	1.4	1	1	1
07/15/2021 01:00	0.4	13.6	1,562.9	0.4	1.1	1	1	0
07/15/2021 02:00	0.4	13.7	1,509.7	0.4	1.1	1	1	0
07/15/2021 03:00	0.4	13.7	1,490.1	0.4	1.0	1	1	0
07/15/2021 04:00	0.5	13.6	1,712.7	0.5	1.2	1	1	0
07/15/2021 05:00	-0.7	12.4	1,975.5	-0.2	1.4	1	1	1
07/15/2021 06:00	-0.7	12.3	2,039.9	-0.2	1.4	1	1	1
07/15/2021 07:00	0.5	13.6	1,646.3	0.5	1.2	1	1	1
07/15/2021 08:00	0.5	13.6	1,646.6	0.5	1.2	1	1	0
07/15/2021 09:00	0.5	13.7	1,574.1	0.5	1.1	1	1	0
07/15/2021 10:00	0.6	13.7	1,677.1	0.6	1.2	1	1	0
07/15/2021 11:00	0.2	13.7	1,575.4	0.4	1.1	1	1	1
07/15/2021 12:00	-0.9	12.0	2,105.0	-0.4	1.5	1	1	1
07/15/2021 13:00	-0.1	11.7	2,152.1	0.2	1.5	1	1	1
07/15/2021 14:00	-0.1	11.6	2,176.0	0.2	1.5	1	1	1
07/15/2021 15:00	0.1	11.6	2,180.0	0.2	1.5	1	1	1
07/15/2021 16:00	0.1	11.5	2,189.0	0.2	1.5	1	1	1
07/15/2021 17:00	0.1	11.5	2,181.1	0.2	1.5	1	1	1
07/15/2021 18:00	0.1	11.4	2,216.8	0.4	1.6	1	1	1
07/15/2021 19:00	0.1	11.3	2,224.1	0.4	1.6	1	1	1
07/15/2021 20:00	0.1	11.4	2,234.4	0.4	1.6	1	1	1
07/15/2021 21:00	-0.1	11.7	2,169.3	0.2	1.5	1	1	1
07/15/2021 22:00	-0.4	12.0	2,110.6	-0.1	1.5	1	1	1
07/15/2021 23:00	-0.4	12.0	2,120.0	-0.1	1.5	1	1	1
Average/Sum#:	0.0	12.5	1,936.9	0.2	1.4	24 #	24 #	17 #
Minimum:	-0.9	11.3	1,490.1	-0.5	1.0	1	1	0
Maximum:	0.6	13.7	2,234.4	0.6	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/16/2021 00:00	-0.4	12.1	2,113.2	-0.1	1.5	1	1	1
07/16/2021 01:00	-2.0	12.5	1,998.9	-1.2	1.4	1	1	1
07/16/2021 02:00	0.5	13.6	1,639.8	0.5	1.1	1	1	0
07/16/2021 03:00	0.4	13.6	1,483.0	0.4	1.0	1	1	0
07/16/2021 04:00	0.5	13.6	1,636.0	0.5	1.1	1	1	0
07/16/2021 05:00	-2.6	12.9	1,820.7	-1.7	1.3	1	1	1
07/16/2021 06:00	-0.8	12.7	1,887.8	-0.4	1.3	1	1	1
07/16/2021 07:00	0.5	13.6	1,686.1	0.5	1.2	1	1	0
07/16/2021 08:00	0.5	13.6	1,688.3	0.5	1.2	1	1	0
07/16/2021 09:00	0.5	13.6	1,657.6	0.5	1.2	1	1	0
07/16/2021 10:00	0.5	13.6	1,705.4	0.5	1.2	1	1	0
07/16/2021 11:00	0.4	13.6	1,530.9	0.4	1.1	1	1	0
07/16/2021 12:00	-0.9	12.3	2,041.8	-0.5	1.4	1	1	1
07/16/2021 13:00	-0.5	12.2	2,025.2	-0.1	1.4	1	1	1
07/16/2021 14:00	0.5	13.6	1,667.1	0.5	1.2	1	1	0
07/16/2021 15:00	0.2	13.6	1,614.4	0.4	1.1	1	1	1
07/16/2021 16:00	-0.9	12.0	2,126.2	-0.4	1.5	1	1	1
07/16/2021 17:00	0.1	11.2	2,262.6	0.4	1.6	1	1	1
07/16/2021 18:00	0.2	11.1	2,284.9	0.4	1.6	1	1	1
07/16/2021 19:00	0.2	11.1	2,280.3	0.4	1.6	1	1	1
07/16/2021 20:00	0.1	11.3	2,263.6	0.4	1.6	1	1	1
07/16/2021 21:00	0.1	11.5	2,207.6	0.2	1.5	1	1	1
07/16/2021 22:00	-0.1	11.7	2,174.9	0.2	1.5	1	1	1
07/16/2021 23:00	-0.4	11.9	2,129.1	-0.1	1.5	1	1	1
Average/Sum#:	-0.1	12.6	1,913.6	0.1	1.3	24 #	24 #	15 #
Minimum:	-2.6	11.1	1,483.0	-1.7	1.0	1	1	0
Maximum:	0.5	13.6	2,284.9	0.5	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/17/2021 00:00	-1.2	12.5	1,972.6	-0.7	1.4	1	1	1
07/17/2021 01:00	0.4	13.6	1,666.8	0.4	1.2	1	1	0
07/17/2021 02:00	0.1	13.7	1,328.0	0.1	0.9	1	1	0
07/17/2021 03:00	0.5	13.7	1,634.2	0.5	1.1	1	1	0
07/17/2021 04:00	-0.7	13.1	1,844.6	-0.4	1.3	1	1	1
07/17/2021 05:00	-0.7	12.9	1,879.3	-0.4	1.3	1	1	1
07/17/2021 06:00	0.5	13.6	1,645.7	0.5	1.2	1	1	0
07/17/2021 07:00	0.5	13.7	1,649.0	0.5	1.2	1	1	0
07/17/2021 08:00	0.5	13.7	1,609.6	0.5	1.1	1	1	0
07/17/2021 09:00	0.5	13.6	1,703.5	0.5	1.2	1	1	0
07/17/2021 10:00	0.5	13.7	1,622.1	0.5	1.1	1	1	0
07/17/2021 11:00	0.5	13.7	1,538.1	0.5	1.1	1	1	0
07/17/2021 12:00	0.4	13.6	1,639.8	0.4	1.1	1	1	1
07/17/2021 13:00	-0.7	11.9	2,136.6	-0.2	1.5	1	1	1
07/17/2021 14:00	0.1	11.3	2,246.5	0.4	1.6	1	1	1
07/17/2021 15:00	0.2	11.3	2,243.6	0.4	1.6	1	1	1
07/17/2021 16:00	0.2	11.2	2,262.7	0.4	1.6	1	1	1
07/17/2021 17:00	0.4	11.1	2,283.0	0.5	1.6	1	1	1
07/17/2021 18:00	0.2	11.1	2,286.9	0.4	1.6	1	1	1
07/17/2021 19:00	0.2	11.0	2,279.2	0.4	1.6	1	1	1
07/17/2021 20:00	0.2	11.2	2,258.8	0.4	1.6	1	1	1
07/17/2021 21:00	0.2	11.3	2,224.9	0.4	1.6	1	1	1
07/17/2021 22:00	-0.1	11.7	2,172.0	0.2	1.5	1	1	1
07/17/2021 23:00	-0.1	11.7	2,167.3	0.2	1.5	1	1	1
Average/Sum#:	0.1	12.5	1,929.0	0.3	1.4	24 #	24 #	15 #
Minimum:	-1.2	11.0	1,328.0	-0.7	0.9	1	1	0
Maximum:	0.5	13.7	2,286.9	0.5	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/18/2021 00:00	-0.5	12.2	2,036.6	-0.1	1.4	1	1	1
07/18/2021 01:00	0.4	13.6	1,668.4	0.4	1.2	1	1	0
07/18/2021 02:00	0.1	13.6	1,587.1	0.2	1.1	1	1	1
07/18/2021 03:00	-0.9	12.3	2,060.2	-0.5	1.4	1	1	1
07/18/2021 04:00	-0.8	12.4	2,004.2	-0.4	1.4	1	1	1
07/18/2021 05:00	0.4	13.6	1,675.6	0.4	1.2	1	1	0
07/18/2021 06:00	0.5	13.6	1,676.3	0.5	1.2	1	1	0
07/18/2021 07:00	0.5	13.7	1,669.6	0.5	1.2	1	1	0
07/18/2021 08:00	0.5	13.6	1,691.3	0.5	1.2	1	1	0
07/18/2021 09:00	0.6	13.7	1,665.4	0.6	1.2	1	1	0
07/18/2021 10:00	0.5	13.7	1,606.5	0.5	1.1	1	1	0
07/18/2021 11:00	0.4	13.6	1,723.2	0.4	1.2	1	1	1
07/18/2021 12:00	-0.7	11.9	2,125.3	-0.2	1.5	1	1	1
07/18/2021 13:00	0.2	11.1	2,274.2	0.4	1.6	1	1	1
07/18/2021 14:00	0.4	11.1	2,280.6	0.5	1.6	1	1	1
07/18/2021 15:00	0.4	11.1	2,277.0	0.5	1.6	1	1	1
07/18/2021 16:00	0.4	11.0	2,268.0	0.5	1.6	1	1	1
07/18/2021 17:00	0.4	11.0	2,262.4	0.5	1.6	1	1	1
07/18/2021 18:00	0.2	11.2	2,228.6	0.4	1.6	1	1	1
07/18/2021 19:00	0.2	11.4	2,208.5	0.4	1.5	1	1	1
07/18/2021 20:00	0.1	11.5	2,203.7	0.2	1.5	1	1	1
07/18/2021 21:00	0.2	11.3	2,246.1	0.4	1.6	1	1	1
07/18/2021 22:00	0.1	11.4	2,236.8	0.4	1.6	1	1	1
07/18/2021 23:00	0.2	11.4	2,233.9	0.4	1.6	1	1	1
Average/Sum#:	0.2	12.3	1,996.2	0.3	1.4	24 #	24 #	17 #
Minimum:	-0.9	11.0	1,587.1	-0.5	1.1	1	1	0
Maximum:	0.6	13.7	2,280.6	0.6	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/19/2021 00:00	0.1	11.5	2,213.9	0.2	1.5	1	1	1
07/19/2021 01:00	0.4	13.3	1,723.8	0.4	1.2	1	1	1
07/19/2021 02:00	0.5	13.6	1,698.0	0.5	1.2	1	1	0
07/19/2021 03:00	0.4	13.6	1,645.9	0.4	1.2	1	1	0
07/19/2021 04:00	0.4	13.6	1,714.6	0.4	1.2	1	1	1
07/19/2021 05:00	-0.5	11.9	2,086.0	-0.1	1.5	1	1	1
07/19/2021 06:00	-0.4	11.8	2,125.0	-0.1	1.5	1	1	1
07/19/2021 07:00	0.4	13.6	1,614.4	0.4	1.1	1	1	0
07/19/2021 08:00	0.4	13.6	1,636.5	0.4	1.1	1	1	0
07/19/2021 09:00	0.4	13.6	1,598.9	0.4	1.1	1	1	0
07/19/2021 10:00	-0.2	12.0	2,098.5	0.1	1.5	1	1	1
07/19/2021 11:00	0.2	11.2	2,247.4	0.4	1.6	1	1	1
07/19/2021 12:00	0.2	11.1	2,271.4	0.4	1.6	1	1	1
07/19/2021 13:00	0.2	11.1	2,271.8	0.4	1.6	1	1	1
07/19/2021 14:00	0.2	11.1	2,276.4	0.4	1.6	1	1	1
07/19/2021 15:00	0.2	11.0	2,265.0	0.4	1.6	1	1	1
07/19/2021 16:00	0.4	11.0	2,276.1	0.5	1.6	1	1	1
07/19/2021 17:00	0.2	11.1	2,275.8	0.4	1.6	1	1	1
07/19/2021 18:00	0.2	11.1	2,278.6	0.4	1.6	1	1	1
07/19/2021 19:00	0.2	11.1	2,290.5	0.4	1.6	1	1	1
07/19/2021 20:00	0.2	11.1	2,284.8	0.4	1.6	1	1	1
07/19/2021 21:00	0.2	11.2	2,252.2	0.4	1.6	1	1	1
07/19/2021 22:00	-0.1	11.8	2,141.8	0.2	1.5	1	1	1
07/19/2021 23:00	-0.2	11.9	2,128.5	0.1	1.5	1	1	1
Average/Sum#:	0.2	12.0	2,059.0	0.3	1.4	24 #	24 #	19 #
Minimum:	-0.5	11.0	1,598.9	-0.1	1.1	1	1	0
Maximum:	0.5	13.6	2,290.5	0.5	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/20/2021 00:00	-0.4	12.0	2,099.3	-0.1	1.5	1	1	1
07/20/2021 01:00	0.4	13.5	1,690.0	0.4	1.2	1	1	1
07/20/2021 02:00	0.5	13.6	1,700.2	0.5	1.2	1	1	0
07/20/2021 03:00	0.4	13.6	1,701.4	0.4	1.2	1	1	1
07/20/2021 04:00	-1.1	12.3	2,073.1	-0.5	1.5	1	1	1
07/20/2021 05:00	-0.2	11.7	2,204.6	0.1	1.5	1	1	1
07/20/2021 06:00	0.2	13.3	1,694.2	0.4	1.2	1	1	1
07/20/2021 07:00	0.5	13.6	1,657.8	0.5	1.2	1	1	0
07/20/2021 08:00	0.4	13.6	1,606.9	0.4	1.1	1	1	0
07/20/2021 09:00	0.5	13.6	1,643.0	0.5	1.2	1	1	0
07/20/2021 10:00	0.5	13.6	1,677.9	0.5	1.2	1	1	0
07/20/2021 11:00	0.4	13.6	1,603.9	0.4	1.1	1	1	0
07/20/2021 12:00	0.5	13.6	1,675.6	0.5	1.2	1	1	1
07/20/2021 13:00	-0.9	12.0	2,089.1	-0.4	1.5	1	1	1
07/20/2021 14:00	0.1	11.3	2,204.6	0.4	1.5	1	1	1
07/20/2021 15:00	0.2	11.2	2,237.2	0.4	1.6	1	1	1
07/20/2021 16:00	0.4	11.0	2,268.2	0.5	1.6	1	1	1
07/20/2021 17:00	0.4	11.0	2,269.9	0.5	1.6	1	1	1
07/20/2021 18:00	0.2	11.0	2,272.6	0.4	1.6	1	1	1
07/20/2021 19:00	0.2	11.0	2,266.0	0.4	1.6	1	1	1
07/20/2021 20:00	0.2	11.0	2,288.8	0.4	1.6	1	1	1
07/20/2021 21:00	0.1	11.3	2,224.6	0.4	1.6	1	1	1
07/20/2021 22:00	-0.1	11.5	2,198.7	0.2	1.5	1	1	1
07/20/2021 23:00	-0.1	11.7	2,174.3	0.2	1.5	1	1	1
Average/Sum#:	0.1	12.3	1,980.1	0.3	1.4	24 #	24 #	18 #
Minimum:	-1.1	11.0	1,603.9	-0.5	1.1	1	1	0
Maximum:	0.5	13.6	2,288.8	0.5	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/21/2021 00:00	-0.4	12.2	2,055.4	-0.1	1.4	1	1	1
07/21/2021 01:00	0.5	13.6	1,647.8	0.5	1.2	1	1	0
07/21/2021 02:00	0.6	13.6	1,669.5	0.6	1.2	1	1	0
07/21/2021 03:00	-0.1	12.9	1,864.7	0.1	1.3	1	1	1
07/21/2021 04:00	-0.2	12.1	2,071.1	0.1	1.4	1	1	1
07/21/2021 05:00	0.5	13.6	1,635.7	0.5	1.1	1	1	0
07/21/2021 06:00	0.4	13.6	1,593.0	0.4	1.1	1	1	1
07/21/2021 07:00	-0.8	12.3	2,065.1	-0.4	1.4	1	1	1
07/21/2021 08:00	-0.8	12.5	1,992.1	-0.4	1.4	1	1	1
07/21/2021 09:00	0.5	13.6	1,705.7	0.5	1.2	1	1	0
07/21/2021 10:00	0.2	13.6	1,619.9	0.4	1.1	1	1	1
07/21/2021 11:00	-0.5	12.0	2,109.5	-0.1	1.5	1	1	1
07/21/2021 12:00	-0.2	11.7	2,154.6	0.1	1.5	1	1	1
07/21/2021 13:00	-0.2	11.7	2,175.1	0.1	1.5	1	1	1
07/21/2021 14:00	-0.1	11.5	2,188.9	0.2	1.5	1	1	1
07/21/2021 15:00	-0.1	11.4	2,210.2	0.2	1.5	1	1	1
07/21/2021 16:00	0.1	11.4	2,206.1	0.4	1.5	1	1	1
07/21/2021 17:00	0.1	11.3	2,229.6	0.4	1.6	1	1	1
07/21/2021 18:00	0.1	11.0	2,270.4	0.4	1.6	1	1	1
07/21/2021 19:00	0.1	11.0	2,270.4	0.4	1.6	1	1	1
07/21/2021 20:00	0.1	11.0	2,281.4	0.4	1.6	1	1	1
07/21/2021 21:00	-0.1	11.3	2,240.9	0.2	1.6	1	1	1
07/21/2021 22:00	-0.2	11.5	2,206.0	0.1	1.5	1	1	1
07/21/2021 23:00	-0.4	11.8	2,143.1	-0.1	1.5	1	1	1
Average/Sum#:	0.0	12.2	2,025.3	0.2	1.4	24 #	24 #	20 #
Minimum:	-0.8	11.0	1,593.0	-0.4	1.1	1	1	0
Maximum:	0.6	13.6	2,281.4	0.6	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/22/2021 00:00	-0.7	12.2	2,045.5	-0.2	1.4	1	1	1
07/22/2021 01:00	0.4	13.6	1,676.7	0.4	1.2	1	1	0
07/22/2021 02:00	-0.1	13.5	1,576.1	0.1	1.1	1	1	1
07/22/2021 03:00	-0.4	12.2	2,056.5	-0.1	1.4	1	1	1
07/22/2021 04:00	-0.2	12.4	1,998.4	0.1	1.4	1	1	1
07/22/2021 05:00	0.5	13.6	1,615.0	0.5	1.1	1	1	0
07/22/2021 06:00	0.5	13.5	1,705.5	0.5	1.2	1	1	1
07/22/2021 07:00	-0.7	12.2	2,067.2	-0.2	1.4	1	1	1
07/22/2021 08:00	-0.8	12.5	2,005.3	-0.4	1.4	1	1	1
07/22/2021 09:00	0.2	13.5	1,627.9	0.4	1.1	1	1	1
07/22/2021 10:00	0.4	13.6	1,651.1	0.4	1.2	1	1	0
07/22/2021 11:00	0.5	13.5	1,770.1	0.5	1.2	1	1	1
07/22/2021 12:00	-0.8	11.9	2,135.0	-0.4	1.5	1	1	1
07/22/2021 13:00	-0.1	11.3	2,257.4	0.2	1.6	1	1	1
07/22/2021 14:00	-0.1	11.4	2,230.9	0.2	1.6	1	1	1
07/22/2021 15:00	-0.1	11.4	2,225.0	0.2	1.6	1	1	1
07/22/2021 16:00	0.1	11.2	2,264.5	0.4	1.6	1	1	1
07/22/2021 17:00	0.1	11.3	2,246.1	0.4	1.6	1	1	1
07/22/2021 18:00	0.1	11.1	2,284.5	0.4	1.6	1	1	1
07/22/2021 19:00	0.1	11.1	2,277.1	0.4	1.6	1	1	1
07/22/2021 20:00	0.1	11.2	2,257.8	0.4	1.6	1	1	1
07/22/2021 21:00	-0.1	11.6	2,172.3	0.2	1.5	1	1	1
07/22/2021 22:00	-0.2	11.7	2,155.3	0.1	1.5	1	1	1
07/22/2021 23:00	-0.4	12.0	2,074.1	-0.1	1.5	1	1	1
Average/Sum#:	-0.1	12.2	2,015.6	0.2	1.4	24 #	24 #	21 #
Minimum:	-0.8	11.1	1,576.1	-0.4	1.1	1	1	0
Maximum:	0.5	13.6	2,284.5	0.5	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/23/2021 00:00	0.5	13.6	1,691.2	0.5	1.2	1	1	0
07/23/2021 01:00	0.4	13.6	1,662.7	0.4	1.2	1	1	1
07/23/2021 02:00	-1.1	12.2	2,074.7	-0.5	1.5	1	1	1
07/23/2021 03:00	-0.8	12.5	1,976.9	-0.4	1.4	1	1	1
07/23/2021 04:00	0.5	13.6	1,696.4	0.5	1.2	1	1	0
07/23/2021 05:00	0.4	13.6	1,664.0	0.4	1.2	1	1	0
07/23/2021 06:00	0.4	13.6	1,678.0	0.4	1.2	1	1	0
07/23/2021 07:00	0.4	13.6	1,651.9	0.4	1.2	1	1	0
07/23/2021 08:00	0.5	13.6	1,690.7	0.5	1.2	1	1	0
07/23/2021 09:00	0.5	13.6	1,674.8	0.5	1.2	1	1	0
07/23/2021 10:00	0.5	13.6	1,713.8	0.5	1.2	1	1	0
07/23/2021 11:00	0.4	13.5	1,725.3	0.4	1.2	1	1	1
07/23/2021 12:00	-0.4	11.7	2,166.0	0.1	1.5	1	1	1
07/23/2021 13:00	0.2	11.1	2,284.6	0.4	1.6	1	1	1
07/23/2021 14:00	0.2	11.1	2,290.7	0.4	1.6	1	1	1
07/23/2021 15:00	0.4	11.1	2,287.8	0.5	1.6	1	1	1
07/23/2021 16:00	0.4	11.1	2,284.9	0.5	1.6	1	1	1
07/23/2021 17:00	0.4	11.1	2,289.6	0.5	1.6	1	1	1
07/23/2021 18:00	0.2	11.0	2,287.2	0.4	1.6	1	1	1
07/23/2021 19:00	0.2	11.0	2,294.7	0.4	1.6	1	1	1
07/23/2021 20:00	0.2	11.1	2,284.1	0.4	1.6	1	1	1
07/23/2021 21:00	-0.1	11.5	2,224.0	0.2	1.6	1	1	1
07/23/2021 22:00	-0.4	11.8	2,143.6	-0.1	1.5	1	1	1
07/23/2021 23:00	-0.4	11.9	2,134.5	-0.1	1.5	1	1	1
Average/Sum#:	0.1	12.3	1,994.7	0.3	1.4	24 #	24 #	16 #
Minimum:	-1.1	11.0	1,651.9	-0.5	1.2	1	1	0
Maximum:	0.5	13.6	2,294.7	0.5	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/24/2021 00:00	-0.4	12.0	2,122.2	-0.1	1.5	1	1	1
07/24/2021 01:00	-0.7	12.5	1,978.3	-0.2	1.4	1	1	1
07/24/2021 02:00	0.4	13.6	1,669.3	0.4	1.2	1	1	0
07/24/2021 03:00	0.2	13.6	1,738.0	0.4	1.2	1	1	1
07/24/2021 04:00	-0.8	12.3	2,058.4	-0.4	1.4	1	1	1
07/24/2021 05:00	-0.9	12.6	1,980.7	-0.5	1.4	1	1	1
07/24/2021 06:00	0.4	13.6	1,663.6	0.4	1.2	1	1	0
07/24/2021 07:00	0.4	13.6	1,622.5	0.4	1.1	1	1	0
07/24/2021 08:00	0.4	13.6	1,633.2	0.4	1.1	1	1	0
07/24/2021 09:00	0.5	13.6	1,662.8	0.5	1.2	1	1	0
07/24/2021 10:00	0.5	13.6	1,624.6	0.5	1.1	1	1	0
07/24/2021 11:00	0.6	13.6	1,664.4	0.6	1.2	1	1	0
07/24/2021 12:00	-0.8	12.0	2,089.7	-0.4	1.5	1	1	1
07/24/2021 13:00	-0.2	11.4	2,191.7	0.1	1.5	1	1	1
07/24/2021 14:00	-0.2	11.6	2,142.8	0.1	1.5	1	1	1
07/24/2021 15:00	0.6	13.6	1,687.8	0.6	1.2	1	1	0
07/24/2021 16:00	0.5	13.6	1,711.0	0.5	1.2	1	1	1
07/24/2021 17:00	-0.7	11.9	2,094.4	-0.2	1.5	1	1	1
07/24/2021 18:00	-0.2	11.3	2,201.5	0.1	1.5	1	1	1
07/24/2021 19:00	0.1	11.0	2,273.6	0.4	1.6	1	1	1
07/24/2021 20:00	0.1	11.0	2,282.5	0.4	1.6	1	1	1
07/24/2021 21:00	-0.1	11.2	2,252.2	0.2	1.6	1	1	1
07/24/2021 22:00	-0.2	11.6	2,176.1	0.1	1.5	1	1	1
07/24/2021 23:00	-0.2	11.5	2,189.6	0.1	1.5	1	1	1
Average/Sum#:	0.0	12.5	1,946.3	0.2	1.4	24 #	24 #	16 #
Minimum:	-0.9	11.0	1,622.5	-0.5	1.1	1	1	0
Maximum:	0.6	13.6	2,282.5	0.6	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/25/2021 00:00	-0.5	12.3	2,006.6	-0.1	1.4	1	1	1
07/25/2021 01:00	0.4	13.6	1,660.5	0.4	1.2	1	1	0
07/25/2021 02:00	0.2	13.6	1,601.6	0.4	1.1	1	1	1
07/25/2021 03:00	-0.5	12.1	2,080.6	-0.1	1.5	1	1	1
07/25/2021 04:00	-0.4	12.4	1,978.5	-0.1	1.4	1	1	1
07/25/2021 05:00	0.4	13.6	1,686.6	0.4	1.2	1	1	0
07/25/2021 06:00	0.4	13.6	1,676.1	0.4	1.2	1	1	0
07/25/2021 07:00	0.4	13.6	1,686.1	0.4	1.2	1	1	0
07/25/2021 08:00	0.4	13.6	1,697.9	0.4	1.2	1	1	0
07/25/2021 09:00	0.4	13.6	1,692.5	0.4	1.2	1	1	0
07/25/2021 10:00	0.5	13.6	1,688.9	0.5	1.2	1	1	0
07/25/2021 11:00	0.1	13.6	1,538.8	0.2	1.1	1	1	1
07/25/2021 12:00	-0.7	11.8	2,117.2	-0.2	1.5	1	1	1
07/25/2021 13:00	-0.2	11.6	2,129.1	0.1	1.5	1	1	1
07/25/2021 14:00	0.6	13.6	1,683.6	0.6	1.2	1	1	0
07/25/2021 15:00	0.6	13.5	1,719.6	0.6	1.2	1	1	0
07/25/2021 16:00	0.7	13.4	1,730.4	0.7	1.2	1	1	1
07/25/2021 17:00	-0.5	11.5	2,141.1	-0.1	1.5	1	1	1
07/25/2021 18:00	0.1	11.0	2,253.0	0.4	1.6	1	1	1
07/25/2021 19:00	-0.1	11.3	2,206.5	0.2	1.5	1	1	1
07/25/2021 20:00	-0.2	11.5	2,160.7	0.1	1.5	1	1	1
07/25/2021 21:00	-0.4	11.8	2,123.6	-0.1	1.5	1	1	1
07/25/2021 22:00	-0.5	11.9	2,108.7	-0.1	1.5	1	1	1
07/25/2021 23:00	-0.4	11.8	2,133.2	-0.1	1.5	1	1	1
Average/Sum#:	0.0	12.7	1,895.9	0.2	1.3	24 #	24 #	15 #
Minimum:	-0.7	11.0	1,538.8	-0.2	1.1	1	1	0
Maximum:	0.7	13.6	2,253.0	0.7	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/26/2021 00:00	-0.7	12.4	2,001.4	-0.2	1.4	1	1	1
07/26/2021 01:00	0.4	13.6	1,617.4	0.4	1.1	1	1	0
07/26/2021 02:00	0.5	13.6	1,646.6	0.5	1.2	1	1	1
07/26/2021 03:00	-0.5	12.2	2,062.3	-0.1	1.4	1	1	1
07/26/2021 04:00	-0.4	12.0	2,085.0	-0.1	1.5	1	1	1
07/26/2021 05:00	0.7	13.6	1,698.6	0.7	1.2	1	1	1
07/26/2021 06:00	0.6	13.6	1,624.4	0.6	1.1	1	1	0
07/26/2021 07:00	0.4	13.6	1,538.3	0.4	1.1	1	1	0
07/26/2021 08:00	0.5	13.6	1,683.2	0.5	1.2	1	1	0
07/26/2021 09:00	0.4	13.6	1,565.3	0.4	1.1	1	1	0
07/26/2021 10:00	0.5	13.6	1,679.6	0.5	1.2	1	1	1
07/26/2021 11:00	-0.8	12.0	2,101.0	-0.4	1.5	1	1	1
07/26/2021 12:00	-0.1	11.2	2,245.3	0.2	1.6	1	1	1
07/26/2021 13:00	-0.1	11.2	2,241.8	0.2	1.6	1	1	1
07/26/2021 14:00	-0.1	11.4	2,207.6	0.2	1.5	1	1	1
07/26/2021 15:00	0.1	11.1	2,268.8	0.4	1.6	1	1	1
07/26/2021 16:00	0.1	11.0	2,267.0	0.4	1.6	1	1	1
07/26/2021 17:00	-0.1	11.2	2,234.1	0.2	1.6	1	1	1
07/26/2021 18:00	-0.1	11.2	2,247.4	0.2	1.6	1	1	1
07/26/2021 19:00	-0.1	11.2	2,243.5	0.2	1.6	1	1	1
07/26/2021 20:00	-0.2	11.3	2,234.6	0.1	1.6	1	1	1
07/26/2021 21:00	-0.1	11.2	2,281.9	0.2	1.6	1	1	1
07/26/2021 22:00	-0.2	11.5	2,214.6	0.1	1.6	1	1	1
07/26/2021 23:00	-0.7	12.2	2,057.6	-0.2	1.4	1	1	1
Average/Sum#:	0.0	12.2	2,002.0	0.2	1.4	24 #	24 #	19 #
Minimum:	-0.8	11.0	1,538.3	-0.4	1.1	1	1	0
Maximum:	0.7	13.6	2,281.9	0.7	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/27/2021 00:00	0.4	13.6	1,632.3	0.4	1.1	1	1	0
07/27/2021 01:00	0.4	13.6	1,700.7	0.4	1.2	1	1	1
07/27/2021 02:00	-1.1	12.6	1,981.7	-0.7	1.4	1	1	1
07/27/2021 03:00	-1.1	12.6	1,950.6	-0.7	1.4	1	1	1
07/27/2021 04:00	0.4	13.6	1,654.6	0.4	1.2	1	1	0
07/27/2021 05:00	0.5	13.6	1,738.1	0.5	1.2	1	1	1
07/27/2021 06:00	-0.8	12.3	2,067.6	-0.4	1.4	1	1	1
07/27/2021 07:00	-0.2	12.6	1,958.7	0.1	1.4	1	1	1
07/27/2021 08:00	0.6	13.7	1,686.7	0.6	1.2	1	1	0
07/27/2021 09:00	0.5	13.7	1,700.5	0.5	1.2	1	1	0
07/27/2021 10:00	0.5	13.6	1,701.0	0.5	1.2	1	1	0
07/27/2021 11:00	0.5	13.6	1,710.7	0.5	1.2	1	1	0
07/27/2021 12:00	-0.7	12.1	2,118.3	-0.2	1.5	1	1	1
07/27/2021 13:00	-0.2	11.3	2,264.0	0.1	1.6	1	1	1
07/27/2021 14:00	-0.1	11.4	2,257.6	0.2	1.6	1	1	1
07/27/2021 15:00	-0.1	11.4	2,252.5	0.2	1.6	1	1	1
07/27/2021 16:00	-0.2	11.6	2,215.2	0.1	1.6	1	1	1
07/27/2021 17:00	-0.1	11.3	2,263.8	0.2	1.6	1	1	1
07/27/2021 18:00	-0.1	11.3	2,273.8	0.2	1.6	1	1	1
07/27/2021 19:00	-0.1	11.3	2,274.4	0.2	1.6	1	1	1
07/27/2021 20:00	-0.1	11.3	2,269.4	0.2	1.6	1	1	1
07/27/2021 21:00	-0.1	11.4	2,267.5	0.2	1.6	1	1	1
07/27/2021 22:00	-0.1	11.5	2,240.1	0.2	1.6	1	1	1
07/27/2021 23:00	-0.2	11.5	2,227.1	0.1	1.6	1	1	1
Average/Sum#:	-0.1	12.4	2,017.0	0.2	1.4	24 #	24 #	18 #
Minimum:	-1.1	11.3	1,632.3	-0.7	1.1	1	1	0
Maximum:	0.6	13.7	2,274.4	0.6	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/28/2021 00:00	-0.2	11.8	2,180.2	0.1	1.5	1	1	1
07/28/2021 01:00	-0.7	12.5	1,979.6	-0.2	1.4	1	1	1
07/28/2021 02:00	0.5	13.6	1,690.5	0.5	1.2	1	1	0
07/28/2021 03:00	0.4	13.6	1,679.4	0.4	1.2	1	1	1
07/28/2021 04:00	-1.1	12.2	2,087.5	-0.5	1.5	1	1	1
07/28/2021 05:00	-0.2	11.5	2,230.0	0.1	1.6	1	1	1
07/28/2021 06:00	-0.4	11.7	2,149.9	0.1	1.5	1	1	1
07/28/2021 07:00	0.5	13.6	1,669.3	0.5	1.2	1	1	0
07/28/2021 08:00	0.5	13.5	1,712.9	0.5	1.2	1	1	1
07/28/2021 09:00	-0.2	11.8	2,093.3	0.1	1.5	1	1	1
07/28/2021 10:00	-0.1	11.1	2,252.5	0.2	1.6	1	1	1
07/28/2021 11:00	0.1	11.1	2,248.6	0.4	1.6	1	1	1
07/28/2021 12:00	0.1	11.2	2,237.6	0.4	1.6	1	1	1
07/28/2021 13:00	0.1	11.1	2,239.8	0.4	1.6	1	1	1
07/28/2021 14:00	0.1	11.2	2,236.4	0.4	1.6	1	1	1
07/28/2021 15:00	0.1	11.1	2,227.9	0.4	1.6	1	1	1
07/28/2021 16:00	0.1	11.1	2,228.3	0.4	1.6	1	1	1
07/28/2021 17:00	0.1	11.1	2,224.5	0.4	1.6	1	1	1
07/28/2021 18:00	0.1	11.2	2,209.0	0.4	1.5	1	1	1
07/28/2021 19:00	-0.1	11.4	2,182.4	0.2	1.5	1	1	1
07/28/2021 20:00	-0.2	11.5	2,166.0	0.1	1.5	1	1	1
07/28/2021 21:00	-0.1	11.2	2,228.9	0.2	1.6	1	1	1
07/28/2021 22:00	-0.1	11.4	2,202.9	0.2	1.5	1	1	1
07/28/2021 23:00	-0.2	11.3	2,217.5	0.1	1.6	1	1	1
Average/Sum#:	0.0	11.8	2,107.3	0.2	1.5	24 #	24 #	22 #
Minimum:	-1.1	11.1	1,669.3	-0.5	1.2	1	1	0
Maximum:	0.5	13.6	2,252.5	0.5	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/29/2021 00:00	-0.2	11.2	2,249.3	0.1	1.6	1	1	1
07/29/2021 01:00	-0.2	11.4	2,211.3	0.1	1.5	1	1	1
07/29/2021 02:00	0.1	13.2	1,628.3	0.2	1.1	1	1	1
07/29/2021 03:00	0.2	13.6	1,728.2	0.4	1.2	1	1	1
07/29/2021 04:00	-0.8	12.0	2,104.2	-0.4	1.5	1	1	1
07/29/2021 05:00	-0.2	11.4	2,237.5	0.1	1.6	1	1	1
07/29/2021 06:00	-0.4	11.8	2,127.8	-0.1	1.5	1	1	1
07/29/2021 07:00	0.5	13.6	1,658.6	0.5	1.2	1	1	0
07/29/2021 08:00	0.2	13.6	1,688.4	0.4	1.2	1	1	1
07/29/2021 09:00	-0.9	12.1	2,056.7	-0.4	1.4	1	1	1
07/29/2021 10:00	-0.1	11.0	2,272.3	0.2	1.6	1	1	1
07/29/2021 11:00	0.1	11.0	2,271.4	0.4	1.6	1	1	1
07/29/2021 12:00	0.1	11.0	2,262.6	0.4	1.6	1	1	1
07/29/2021 13:00	0.1	11.0	2,258.5	0.4	1.6	1	1	1
07/29/2021 14:00	0.1	11.0	2,250.1	0.4	1.6	1	1	1
07/29/2021 15:00	0.2	11.0	2,246.5	0.4	1.6	1	1	1
07/29/2021 16:00	0.2	11.0	2,241.6	0.4	1.6	1	1	1
07/29/2021 17:00	0.1	11.0	2,241.8	0.4	1.6	1	1	1
07/29/2021 18:00	0.1	11.0	2,240.1	0.4	1.6	1	1	1
07/29/2021 19:00	0.1	11.0	2,241.8	0.4	1.6	1	1	1
07/29/2021 20:00	-0.1	11.1	2,218.7	0.2	1.6	1	1	1
07/29/2021 21:00	-0.1	11.1	2,246.9	0.2	1.6	1	1	1
07/29/2021 22:00	-0.1	11.2	2,240.0	0.2	1.6	1	1	1
07/29/2021 23:00	-0.1	11.2	2,229.3	0.2	1.6	1	1	1
Average/Sum#:	0.0	11.6	2,131.3	0.2	1.5	24 #	24 #	23 #
Minimum:	-0.9	11.0	1,628.3	-0.4	1.1	1	1	0
Maximum:	0.5	13.6	2,272.3	0.5	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/30/2021 00:00	-0.2	11.4	2,209.5	0.1	1.5	1	1	1
07/30/2021 01:00	-0.2	11.6	2,137.2	0.1	1.5	1	1	1
07/30/2021 02:00	0.2	13.5	1,702.8	0.4	1.2	1	1	1
07/30/2021 03:00	0.4	13.6	1,742.5	0.4	1.2	1	1	1
07/30/2021 04:00	-0.7	11.8	2,141.4	-0.2	1.5	1	1	1
07/30/2021 05:00	-0.2	11.1	2,285.8	0.1	1.6	1	1	1
07/30/2021 06:00	-0.2	11.3	2,246.4	0.1	1.6	1	1	1
07/30/2021 07:00	-0.2	11.3	2,237.5	0.1	1.6	1	1	1
07/30/2021 08:00	-0.2	11.3	2,217.5	0.1	1.6	1	1	1
07/30/2021 09:00	-0.1	11.2	2,240.6	0.2	1.6	1	1	1
07/30/2021 10:00	-0.1	11.1	2,244.0	0.2	1.6	1	1	1
07/30/2021 11:00	0.1	11.0	2,257.2	0.4	1.6	1	1	1
07/30/2021 12:00	0.1	11.0	2,250.5	0.4	1.6	1	1	1
07/30/2021 13:00	0.1	11.0	2,247.3	0.4	1.6	1	1	1
07/30/2021 14:00	0.1	11.0	2,241.3	0.4	1.6	1	1	1
07/30/2021 15:00	0.1	11.0	2,235.8	0.4	1.6	1	1	1
07/30/2021 16:00	0.1	11.1	2,228.6	0.4	1.6	1	1	1
07/30/2021 17:00	0.1	11.1	2,227.9	0.4	1.6	1	1	1
07/30/2021 18:00	0.1	11.1	2,219.0	0.4	1.6	1	1	1
07/30/2021 19:00	0.1	11.0	2,238.0	0.4	1.6	1	1	1
07/30/2021 20:00	0.1	11.0	2,246.4	0.4	1.6	1	1	1
07/30/2021 21:00	0.1	11.1	2,226.5	0.4	1.6	1	1	1
07/30/2021 22:00	0.1	11.1	2,236.3	0.4	1.6	1	1	1
07/30/2021 23:00	-0.1	11.1	2,250.8	0.2	1.6	1	1	1
Average/Sum#:	0.0	11.4	2,188.0	0.3	1.6	24 #	24 #	24 #
Minimum:	-0.7	11.0	1,702.8	-0.2	1.2	1	1	1
Maximum:	0.4	13.6	2,285.8	0.4	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/31/2021 00:00	-0.1	11.1	2,278.6	0.2	1.6	1	1	1
07/31/2021 01:00	-0.1	11.3	2,268.1	0.2	1.6	1	1	1
07/31/2021 02:00	-0.2	11.5	2,221.4	0.1	1.6	1	1	1
07/31/2021 03:00	0.2	13.3	1,705.9	0.4	1.2	1	1	1
07/31/2021 04:00	0.5	13.5	1,783.4	0.5	1.2	1	1	0
07/31/2021 05:00	-1.1	12.5	1,944.3	-0.5	1.4	1	1	1
07/31/2021 06:00	-0.5	11.8	2,128.1	-0.1	1.5	1	1	1
07/31/2021 07:00	0.5	13.6	1,692.5	0.5	1.2	1	1	0
07/31/2021 08:00	0.1	13.6	1,592.9	0.2	1.1	1	1	1
07/31/2021 09:00	-0.9	12.2	2,072.5	-0.4	1.5	1	1	1
07/31/2021 10:00	-0.7	11.9	2,124.4	-0.2	1.5	1	1	1
07/31/2021 11:00	-0.5	11.8	2,137.8	-0.1	1.5	1	1	1
07/31/2021 12:00	-0.4	11.7	2,147.2	0.1	1.5	1	1	1
07/31/2021 13:00	-0.4	11.7	2,140.4	0.1	1.5	1	1	1
07/31/2021 14:00	-0.4	11.7	2,146.8	0.1	1.5	1	1	1
07/31/2021 15:00	-0.4	11.6	2,155.2	0.1	1.5	1	1	1
07/31/2021 16:00	-0.2	11.5	2,161.5	0.1	1.5	1	1	1
07/31/2021 17:00	-0.2	11.4	2,195.2	0.1	1.5	1	1	1
07/31/2021 18:00	-0.2	11.3	2,221.4	0.1	1.6	1	1	1
07/31/2021 19:00	-0.2	11.4	2,218.5	0.1	1.6	1	1	1
07/31/2021 20:00	-0.2	11.2	2,264.0	0.1	1.6	1	1	1
07/31/2021 21:00	-0.2	11.3	2,237.7	0.1	1.6	1	1	1
07/31/2021 22:00	-0.2	11.5	2,210.9	0.1	1.5	1	1	1
07/31/2021 23:00	-0.5	11.9	2,144.6	-0.1	1.5	1	1	1
Average/Sum#:	-0.3	11.9	2,091.4	0.1	1.5	24 #	24 #	22 #
Minimum:	-1.1	11.1	1,592.9	-0.5	1.1	1	1	0
Maximum:	0.5	13.6	2,278.6	0.5	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/01/2021 00:00	-0.9	12.5	1,998.4	-0.5	1.4	1	1	1
08/01/2021 01:00	0.4	13.6	1,662.9	0.4	1.2	1	1	0
08/01/2021 02:00	0.2	13.6	1,707.2	0.4	1.2	1	1	1
08/01/2021 03:00	-1.1	12.3	2,048.0	-0.5	1.4	1	1	1
08/01/2021 04:00	-0.8	12.4	2,006.0	-0.4	1.4	1	1	1
08/01/2021 05:00	0.4	13.6	1,692.6	0.4	1.2	1	1	0
08/01/2021 06:00	0.4	13.6	1,641.8	0.4	1.1	1	1	0
08/01/2021 07:00	0.4	13.6	1,623.5	0.4	1.1	1	1	0
08/01/2021 08:00	0.3	13.7	1,418.4	0.4	1.0	1	1	0
08/01/2021 09:00	0.2	13.6	1,582.5	0.4	1.1	1	1	1
08/01/2021 10:00	-0.8	12.1	2,082.3	-0.4	1.5	1	1	1
08/01/2021 11:00	-0.7	12.1	2,028.7	-0.2	1.4	1	1	1
08/01/2021 12:00	0.5	13.6	1,635.4	0.5	1.1	1	1	0
08/01/2021 13:00	0.5	13.6	1,680.1	0.5	1.2	1	1	0
08/01/2021 14:00	0.6	13.6	1,693.6	0.6	1.2	1	1	0
08/01/2021 15:00	0.6	13.6	1,713.5	0.6	1.2	1	1	0
08/01/2021 16:00	-0.2	12.9	1,838.5	0.1	1.3	1	1	1
08/01/2021 17:00	-0.2	11.2	2,247.6	0.1	1.6	1	1	1
08/01/2021 18:00	-0.1	11.0	2,288.1	0.2	1.6	1	1	1
08/01/2021 19:00	-0.1	11.1	2,280.7	0.2	1.6	1	1	1
08/01/2021 20:00	-0.1	11.0	2,299.7	0.2	1.6	1	1	1
08/01/2021 21:00	-0.1	11.1	2,297.8	0.2	1.6	1	1	1
08/01/2021 22:00	-0.2	11.2	2,274.7	0.1	1.6	1	1	1
08/01/2021 23:00	-0.2	11.4	2,243.3	0.1	1.6	1	1	1
Average/Sum#:	0.0	12.6	1,916.1	0.2	1.3	24 #	24 #	15 #
Minimum:	-1.1	11.0	1,418.4	-0.5	1.0	1	1	0
Maximum:	0.6	13.7	2,299.7	0.6	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/02/2021 00:00	-0.2	11.4	2,258.7	0.1	1.6	1	1	1
08/02/2021 01:00	-0.4	11.6	2,221.7	0.1	1.6	1	1	1
08/02/2021 02:00	0.1	13.4	1,665.6	0.2	1.2	1	1	1
08/02/2021 03:00	0.4	13.6	1,701.4	0.4	1.2	1	1	1
08/02/2021 04:00	-0.9	12.3	2,093.8	-0.5	1.5	1	1	1
08/02/2021 05:00	-0.4	11.5	2,260.2	0.1	1.6	1	1	1
08/02/2021 06:00	-0.5	11.8	2,177.6	-0.1	1.5	1	1	1
08/02/2021 07:00	0.1	13.3	1,710.0	0.2	1.2	1	1	1
08/02/2021 08:00	0.1	13.6	1,606.7	0.2	1.1	1	1	1
08/02/2021 09:00	-0.8	12.2	2,095.5	-0.4	1.5	1	1	1
08/02/2021 10:00	-0.5	11.6	2,204.1	-0.1	1.5	1	1	1
08/02/2021 11:00	-0.4	11.5	2,224.2	0.1	1.6	1	1	1
08/02/2021 12:00	-0.4	11.6	2,202.4	0.1	1.5	1	1	1
08/02/2021 13:00	-0.4	11.6	2,197.5	0.1	1.5	1	1	1
08/02/2021 14:00	-0.4	11.6	2,192.2	0.1	1.5	1	1	1
08/02/2021 15:00	-0.4	11.6	2,194.6	0.1	1.5	1	1	1
08/02/2021 16:00	-0.4	11.6	2,195.5	0.1	1.5	1	1	1
08/02/2021 17:00	-0.2	11.5	2,217.6	0.1	1.6	1	1	1
08/02/2021 18:00	-0.2	11.2	2,277.9	0.1	1.6	1	1	1
08/02/2021 19:00	-0.2	11.1	2,289.2	0.1	1.6	1	1	1
08/02/2021 20:00	-0.1	11.1	2,302.7	0.2	1.6	1	1	1
08/02/2021 21:00	-0.1	11.2	2,302.3	0.2	1.6	1	1	1
08/02/2021 22:00	-0.1	11.2	2,300.8	0.2	1.6	1	1	1
08/02/2021 23:00	-0.1	11.2	2,302.2	0.2	1.6	1	1	1
Average/Sum#:	-0.3	11.8	2,133.1	0.1	1.5	24 #	24 #	24 #
Minimum:	-0.9	11.1	1,606.7	-0.5	1.1	1	1	1
Maximum:	0.4	13.6	2,302.7	0.4	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/03/2021 00:00	-0.2	11.5	2,242.8	0.1	1.6	1	1	1
08/03/2021 01:00	-0.2	11.5	2,238.0	0.1	1.6	1	1	1
08/03/2021 02:00	0.2	13.3	1,752.8	0.4	1.2	1	1	1
08/03/2021 03:00	0.2	13.5	1,785.3	0.4	1.2	1	1	1
08/03/2021 04:00	-1.4	12.2	2,099.5	-0.7	1.5	1	1	1
08/03/2021 05:00	-1.2	11.8	2,204.3	-0.5	1.5	1	1	1
08/03/2021 06:00	-1.2	11.8	2,170.9	-0.5	1.5	1	1	1
08/03/2021 07:00	-1.1	11.7	2,187.0	-0.5	1.5	1	1	1
08/03/2021 08:00	-0.9	11.6	2,210.3	-0.4	1.5	1	1	1
08/03/2021 09:00	-0.8	11.5	2,231.7	-0.2	1.6	1	1	1
08/03/2021 10:00	-0.7	11.3	2,271.6	-0.2	1.6	1	1	1
08/03/2021 11:00	-0.4	12.0	1,974.7	-0.1	1.4	1	1	1
08/03/2021 12:00	0.4	13.8	1,332.6	0.4	0.9	1	1	0
08/03/2021 13:00	0.5	13.6	1,718.2	0.5	1.2	1	1	1
08/03/2021 14:00	-0.7	11.9	2,133.2	-0.2	1.5	1	1	1
08/03/2021 15:00	-0.4	11.6	2,189.3	0.1	1.5	1	1	1
08/03/2021 16:00	-0.2	11.5	2,195.3	0.1	1.5	1	1	1
08/03/2021 17:00	-0.2	11.4	2,208.6	0.1	1.5	1	1	1
08/03/2021 18:00	-0.2	11.2	2,267.7	0.1	1.6	1	1	1
08/03/2021 19:00	-0.1	11.1	2,280.8	0.2	1.6	1	1	1
08/03/2021 20:00	-0.1	11.1	2,294.7	0.2	1.6	1	1	1
08/03/2021 21:00	-0.1	11.1	2,288.8	0.2	1.6	1	1	1
08/03/2021 22:00	-0.1	11.2	2,276.6	0.2	1.6	1	1	1
08/03/2021 23:00	-0.2	11.4	2,258.9	0.1	1.6	1	1	1
Average/Sum#:	-0.4	11.9	2,117.2	0.0	1.5	24 #	24 #	23 #
Minimum:	-1.4	11.1	1,332.6	-0.7	0.9	1	1	0
Maximum:	0.5	13.8	2,294.7	0.5	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/04/2021 00:00	-0.5	11.9	2,097.3	-0.1	1.5	1	1	1
08/04/2021 01:00	0.5	13.6	1,678.6	0.5	1.2	1	1	0
08/04/2021 02:00	0.4	13.5	1,780.1	0.4	1.2	1	1	1
08/04/2021 03:00	-0.9	12.3	2,071.5	-0.5	1.5	1	1	1
08/04/2021 04:00	-0.4	11.5	2,242.4	0.1	1.6	1	1	1
08/04/2021 05:00	-0.4	11.3	2,265.6	0.1	1.6	1	1	1
08/04/2021 06:00	-0.7	11.9	2,127.2	-0.2	1.5	1	1	1
08/04/2021 07:00	-0.7	12.5	1,984.9	-0.2	1.4	1	1	1
08/04/2021 08:00	0.5	13.6	1,645.9	0.5	1.2	1	1	0
08/04/2021 09:00	0.5	13.5	1,717.4	0.5	1.2	1	1	0
08/04/2021 10:00	-0.8	12.1	2,079.9	-0.4	1.5	1	1	1
08/04/2021 11:00	-0.2	11.4	2,222.3	0.1	1.6	1	1	1
08/04/2021 12:00	-0.2	11.5	2,189.0	0.1	1.5	1	1	1
08/04/2021 13:00	-0.2	11.5	2,176.6	0.1	1.5	1	1	1
08/04/2021 14:00	-0.2	11.5	2,176.9	0.1	1.5	1	1	1
08/04/2021 15:00	-0.2	11.4	2,183.3	0.1	1.5	1	1	1
08/04/2021 16:00	-0.1	11.2	2,213.6	0.2	1.5	1	1	1
08/04/2021 17:00	-0.1	11.2	2,226.0	0.2	1.6	1	1	1
08/04/2021 18:00	-0.1	11.2	2,240.1	0.2	1.6	1	1	1
08/04/2021 19:00	-0.1	11.1	2,262.3	0.2	1.6	1	1	1
08/04/2021 20:00	-0.1	11.1	2,280.6	0.2	1.6	1	1	1
08/04/2021 21:00	-0.1	11.1	2,289.4	0.2	1.6	1	1	1
08/04/2021 22:00	-0.1	11.2	2,285.8	0.2	1.6	1	1	1
08/04/2021 23:00	-0.4	11.6	2,192.1	0.1	1.5	1	1	1
Average/Sum#:	-0.2	11.9	2,109.5	0.1	1.5	24 #	24 #	21 #
Minimum:	-0.9	11.1	1,645.9	-0.5	1.2	1	1	0
Maximum:	0.5	13.6	2,289.4	0.5	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/05/2021 00:00	-0.5	11.8	2,174.5	-0.1	1.5	1	1	1
08/05/2021 01:00	-0.4	11.7	2,188.6	0.1	1.5	1	1	1
08/05/2021 02:00	-0.1	11.7	2,182.7	0.2	1.5	1	1	1
08/05/2021 03:00	0.1	11.5	2,230.8	0.2	1.6	1	1	1
08/05/2021 04:00	0.1	11.4	2,253.0	0.4	1.6	1	1	1
08/05/2021 05:00	0.1	11.5	2,245.7	0.2	1.6	1	1	1
08/05/2021 06:00	-0.2	12.3	2,038.3	0.1	1.4	1	1	1
08/05/2021 07:00	0.5	13.6	1,662.7	0.5	1.2	1	1	0
08/05/2021 08:00	0.4	13.6	1,644.7	0.4	1.2	1	1	1
08/05/2021 09:00	-1.1	12.6	1,997.8	-0.7	1.4	1	1	1
08/05/2021 10:00	-0.5	12.1	2,080.9	-0.1	1.5	1	1	1
08/05/2021 11:00	0.5	13.6	1,690.5	0.5	1.2	1	1	0
08/05/2021 12:00	0.7	13.6	1,759.6	0.7	1.2	1	1	1
08/05/2021 13:00	-0.8	12.1	2,087.9	-0.4	1.5	1	1	1
08/05/2021 14:00	-0.4	11.8	2,141.6	-0.1	1.5	1	1	1
08/05/2021 15:00	-0.4	11.8	2,152.2	-0.1	1.5	1	1	1
08/05/2021 16:00	-0.4	11.6	2,184.5	0.1	1.5	1	1	1
08/05/2021 17:00	-0.4	11.7	2,164.5	0.1	1.5	1	1	1
08/05/2021 18:00	-0.2	11.3	2,259.7	0.1	1.6	1	1	1
08/05/2021 19:00	-0.2	11.2	2,278.3	0.1	1.6	1	1	1
08/05/2021 20:00	-0.1	11.2	2,282.9	0.2	1.6	1	1	1
08/05/2021 21:00	-0.2	11.4	2,236.3	0.1	1.6	1	1	1
08/05/2021 22:00	-0.4	11.7	2,165.0	0.1	1.5	1	1	1
08/05/2021 23:00	-0.5	11.9	2,137.0	-0.1	1.5	1	1	1
Average/Sum#:	-0.2	12.0	2,093.3	0.1	1.5	24 #	24 #	22 #
Minimum:	-1.1	11.2	1,644.7	-0.7	1.2	1	1	0
Maximum:	0.7	13.6	2,282.9	0.7	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/06/2021 00:00	-0.5	12.0	2,076.7	-0.1	1.5	1	1	1
08/06/2021 01:00	0.4	13.6	1,695.4	0.4	1.2	1	1	0
08/06/2021 02:00	0.4	13.6	1,691.4	0.4	1.2	1	1	0
08/06/2021 03:00	0.2	13.6	1,639.6	0.4	1.1	1	1	1
08/06/2021 04:00	-1.4	12.3	2,055.5	-0.8	1.4	1	1	1
08/06/2021 05:00	-0.7	12.3	2,077.3	-0.2	1.5	1	1	1
08/06/2021 06:00	0.5	13.7	1,600.7	0.5	1.1	1	1	0
08/06/2021 07:00	0.5	13.7	1,665.4	0.5	1.2	1	1	0
08/06/2021 08:00	0.4	13.6	1,667.2	0.4	1.2	1	1	0
08/06/2021 09:00	-0.9	12.4	2,007.8	-0.5	1.4	1	1	1
08/06/2021 10:00	-0.8	12.4	1,995.8	-0.4	1.4	1	1	1
08/06/2021 11:00	0.4	13.6	1,660.3	0.4	1.2	1	1	0
08/06/2021 12:00	0.4	13.7	1,530.6	0.4	1.1	1	1	0
08/06/2021 13:00	-0.9	12.3	2,034.7	-0.5	1.4	1	1	1
08/06/2021 14:00	-0.5	11.8	2,128.3	-0.1	1.5	1	1	1
08/06/2021 15:00	-0.5	11.8	2,112.5	-0.1	1.5	1	1	1
08/06/2021 16:00	-0.4	11.5	2,166.2	0.1	1.5	1	1	1
08/06/2021 17:00	-0.2	11.4	2,170.9	0.1	1.5	1	1	1
08/06/2021 18:00	-0.1	11.2	2,221.4	0.2	1.6	1	1	1
08/06/2021 19:00	-0.2	11.5	2,173.4	0.1	1.5	1	1	1
08/06/2021 20:00	-0.2	11.5	2,141.6	0.1	1.5	1	1	1
08/06/2021 21:00	-0.2	11.7	2,111.7	0.1	1.5	1	1	1
08/06/2021 22:00	-0.7	11.9	2,096.0	-0.2	1.5	1	1	1
08/06/2021 23:00	-0.5	12.4	1,955.7	-0.2	1.4	1	1	1
Average/Sum#:	-0.2	12.5	1,944.8	0.0	1.4	24 #	24 #	17 #
Minimum:	-1.4	11.2	1,530.6	-0.8	1.1	1	1	0
Maximum:	0.5	13.7	2,221.4	0.5	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/07/2021 00:00	0.4	13.6	1,703.0	0.4	1.2	1	1	0
08/07/2021 01:00	0.1	13.5	1,630.7	0.2	1.1	1	1	1
08/07/2021 02:00	-0.7	12.4	1,991.3	-0.2	1.4	1	1	1
08/07/2021 03:00	0.0	13.9	1,196.2	0.0	0.8	1	0	1
08/07/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/07/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/07/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/07/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/07/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/07/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/07/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/07/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/07/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/07/2021 13:00	0.0	18.5	172.7	0.0	0.1	1	0	0
08/07/2021 14:00	0.0	15.4	813.4	0.0	0.6	1	0	0
08/07/2021 15:00	0.5	13.6	1,657.0	0.5	1.2	1	1	0
08/07/2021 16:00	0.2	13.6	1,536.5	0.4	1.1	1	1	1
08/07/2021 17:00	-1.1	11.9	2,068.8	-0.5	1.4	1	1	1
08/07/2021 18:00	-0.5	11.6	2,140.2	-0.1	1.5	1	1	1
08/07/2021 19:00	-0.5	11.9	2,049.0	-0.1	1.4	1	1	1
08/07/2021 20:00	0.5	13.5	1,687.8	0.5	1.2	1	1	0
08/07/2021 21:00	0.4	13.5	1,656.9	0.4	1.2	1	1	1
08/07/2021 22:00	-1.5	12.4	1,999.2	-0.8	1.4	1	1	1
08/07/2021 23:00	-0.8	11.9	2,078.2	-0.4	1.5	1	1	1
Average/Sum#:	-0.2	13.4	1,625.4	0.0	1.1	15 #	12 #	10 #
Minimum:	-1.5	11.6	172.7	-0.8	0.1	0	0	0
Maximum:	0.5	18.5	2,140.2	0.5	1.5	1	1	1
%SI	37.50	37.50	37.50	37.50	37.50	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/08/2021 00:00	0.4	13.6	1,601.3	0.4	1.1	1	1	0
08/08/2021 01:00	0.1	13.5	1,571.0	0.2	1.1	1	1	1
08/08/2021 02:00	-0.8	12.5	1,979.4	-0.4	1.4	1	1	1
08/08/2021 03:00	-0.1	13.4	1,496.5	0.1	1.0	1	1	1
08/08/2021 04:00	0.0	16.3	332.8	0.0	0.2	1	0	0
08/08/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/08/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/08/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/08/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/08/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/08/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/08/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/08/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/08/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/08/2021 14:00	0.0	18.6	165.6	0.0	0.1	1	0	0
08/08/2021 15:00	0.0	15.4	815.0	0.0	0.6	1	0	0
08/08/2021 16:00	0.6	13.6	1,604.6	0.6	1.1	1	1	0
08/08/2021 17:00	-0.2	12.8	1,811.1	0.1	1.3	1	1	1
08/08/2021 18:00	-0.5	11.5	2,154.8	-0.1	1.5	1	1	1
08/08/2021 19:00	-0.4	11.4	2,181.1	0.1	1.5	1	1	1
08/08/2021 20:00	-0.1	11.3	2,225.9	0.2	1.6	1	1	1
08/08/2021 21:00	-0.2	11.5	2,174.0	0.1	1.5	1	1	1
08/08/2021 22:00	-0.4	11.9	2,090.8	-0.1	1.5	1	1	1
08/08/2021 23:00	-0.4	12.4	1,968.1	-0.1	1.4	1	1	1
Average/Sum#:	-0.1	13.3	1,611.5	0.1	1.1	15 #	12 #	10 #
Minimum:	-0.8	11.3	165.6	-0.4	0.1	0	0	0
Maximum:	0.6	18.6	2,225.9	0.6	1.6	1	1	1
%SI	37.50	37.50	37.50	37.50	37.50	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/09/2021 00:00	0.5	13.6	1,595.0	0.5	1.1	1	1	0
08/09/2021 01:00	0.4	13.5	1,755.9	0.4	1.2	1	1	1
08/09/2021 02:00	-0.8	12.3	2,038.3	-0.4	1.4	1	1	1
08/09/2021 03:00	-0.5	12.5	1,963.2	-0.2	1.4	1	1	1
08/09/2021 04:00	0.5	13.6	1,692.9	0.5	1.2	1	1	0
08/09/2021 05:00	0.4	13.4	1,767.7	0.4	1.2	1	1	1
08/09/2021 06:00	-0.8	12.4	2,019.5	-0.4	1.4	1	1	1
08/09/2021 07:00	-0.5	12.2	2,022.1	-0.1	1.4	1	1	1
08/09/2021 08:00	0.5	13.6	1,592.2	0.5	1.1	1	1	0
08/09/2021 09:00	0.5	13.6	1,650.0	0.5	1.2	1	1	0
08/09/2021 10:00	0.5	13.5	1,682.3	0.5	1.2	1	1	0
08/09/2021 11:00	-0.5	12.2	2,001.9	-0.1	1.4	1	1	1
08/09/2021 12:00	-0.4	11.6	2,089.2	0.1	1.5	1	1	1
08/09/2021 13:00	0.6	13.6	1,718.3	0.6	1.2	1	1	0
08/09/2021 14:00	-0.1	12.8	1,829.5	0.1	1.3	1	1	1
08/09/2021 15:00	-0.2	11.4	2,178.7	0.1	1.5	1	1	1
08/09/2021 16:00	-0.1	11.3	2,187.8	0.2	1.5	1	1	1
08/09/2021 17:00	-0.1	11.3	2,189.8	0.2	1.5	1	1	1
08/09/2021 18:00	-0.2	11.3	2,191.4	0.1	1.5	1	1	1
08/09/2021 19:00	-0.1	11.1	2,246.4	0.2	1.6	1	1	1
08/09/2021 20:00	-0.1	11.0	2,265.8	0.2	1.6	1	1	1
08/09/2021 21:00	-0.1	11.2	2,231.9	0.2	1.6	1	1	1
08/09/2021 22:00	-0.4	11.8	2,133.8	-0.1	1.5	1	1	1
08/09/2021 23:00	-0.5	11.8	2,139.5	-0.1	1.5	1	1	1
Average/Sum#:	-0.1	12.4	1,966.0	0.2	1.4	24 #	24 #	18 #
Minimum:	-0.8	11.0	1,592.2	-0.4	1.1	1	1	0
Maximum:	0.6	13.6	2,265.8	0.6	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/10/2021 00:00	-0.5	12.2	2,030.6	-0.1	1.4	1	1	1
08/10/2021 01:00	0.5	13.6	1,631.7	0.5	1.1	1	1	0
08/10/2021 02:00	0.5	13.6	1,637.3	0.5	1.1	1	1	0
08/10/2021 03:00	0.4	13.5	1,746.1	0.4	1.2	1	1	1
08/10/2021 04:00	-0.7	12.2	2,079.9	-0.2	1.5	1	1	1
08/10/2021 05:00	-0.5	12.2	2,086.2	-0.1	1.5	1	1	1
08/10/2021 06:00	0.5	13.6	1,661.3	0.5	1.2	1	1	0
08/10/2021 07:00	0.2	13.5	1,633.4	0.4	1.1	1	1	1
08/10/2021 08:00	-0.9	12.3	2,050.1	-0.5	1.4	1	1	1
08/10/2021 09:00	-0.5	12.5	1,978.1	-0.2	1.4	1	1	1
08/10/2021 10:00	0.6	13.6	1,703.6	0.6	1.2	1	1	0
08/10/2021 11:00	0.5	13.6	1,715.4	0.5	1.2	1	1	1
08/10/2021 12:00	-0.5	12.0	2,086.5	-0.1	1.5	1	1	1
08/10/2021 13:00	-0.2	11.5	2,182.7	0.1	1.5	1	1	1
08/10/2021 14:00	-0.1	11.4	2,177.7	0.2	1.5	1	1	1
08/10/2021 15:00	-0.2	11.4	2,181.0	0.1	1.5	1	1	1
08/10/2021 16:00	-0.2	11.3	2,202.8	0.1	1.5	1	1	1
08/10/2021 17:00	-0.2	11.3	2,207.7	0.1	1.5	1	1	1
08/10/2021 18:00	-0.1	11.1	2,250.4	0.2	1.6	1	1	1
08/10/2021 19:00	-0.1	11.0	2,266.3	0.2	1.6	1	1	1
08/10/2021 20:00	-0.1	11.0	2,267.5	0.2	1.6	1	1	1
08/10/2021 21:00	-0.1	11.1	2,258.8	0.2	1.6	1	1	1
08/10/2021 22:00	-0.2	11.5	2,180.8	0.1	1.5	1	1	1
08/10/2021 23:00	-0.4	11.7	2,157.9	0.1	1.5	1	1	1
Average/Sum#:	-0.1	12.2	2,015.6	0.2	1.4	24 #	24 #	20 #
Minimum:	-0.9	11.0	1,631.7	-0.5	1.1	1	1	0
Maximum:	0.6	13.6	2,267.5	0.6	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/11/2021 00:00	-0.5	11.9	2,094.7	-0.1	1.5	1	1	1
08/11/2021 01:00	0.5	13.5	1,699.9	0.5	1.2	1	1	0
08/11/2021 02:00	0.5	13.6	1,633.8	0.5	1.1	1	1	0
08/11/2021 03:00	0.4	13.6	1,622.4	0.4	1.1	1	1	0
08/11/2021 04:00	0.4	13.5	1,644.3	0.4	1.2	1	1	1
08/11/2021 05:00	-0.5	12.1	2,066.9	-0.1	1.4	1	1	1
08/11/2021 06:00	-0.4	12.1	2,092.2	-0.1	1.5	1	1	1
08/11/2021 07:00	0.5	13.6	1,664.7	0.5	1.2	1	1	0
08/11/2021 08:00	0.5	13.5	1,764.9	0.5	1.2	1	1	0
08/11/2021 09:00	-0.8	12.0	2,101.4	-0.4	1.5	1	1	1
08/11/2021 10:00	-0.2	11.4	2,206.8	0.1	1.5	1	1	1
08/11/2021 11:00	-0.2	11.4	2,194.0	0.1	1.5	1	1	1
08/11/2021 12:00	-0.2	11.6	2,149.1	0.1	1.5	1	1	1
08/11/2021 13:00	-0.2	11.5	2,149.9	0.1	1.5	1	1	1
08/11/2021 14:00	0.1	11.5	2,137.2	0.2	1.5	1	1	1
08/11/2021 15:00	-0.1	11.9	2,002.5	0.2	1.4	1	1	1
08/11/2021 16:00	-0.2	11.5	2,157.0	0.1	1.5	1	1	1
08/11/2021 17:00	-0.1	11.4	2,171.9	0.2	1.5	1	1	1
08/11/2021 18:00	0.1	11.1	2,230.3	0.4	1.6	1	1	1
08/11/2021 19:00	-0.1	11.0	2,244.4	0.2	1.6	1	1	1
08/11/2021 20:00	-0.1	11.0	2,252.9	0.2	1.6	1	1	1
08/11/2021 21:00	-0.2	11.3	2,219.2	0.1	1.6	1	1	1
08/11/2021 22:00	-0.4	11.6	2,161.8	0.1	1.5	1	1	1
08/11/2021 23:00	-0.4	11.7	2,164.1	0.1	1.5	1	1	1
Average/Sum#:	-0.1	12.1	2,034.4	0.2	1.4	24 #	24 #	19 #
Minimum:	-0.8	11.0	1,622.4	-0.4	1.1	1	1	0
Maximum:	0.5	13.6	2,252.9	0.5	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/12/2021 00:00	-0.5	11.9	2,120.6	-0.1	1.5	1	1	1
08/12/2021 01:00	0.4	13.6	1,693.4	0.4	1.2	1	1	1
08/12/2021 02:00	0.4	13.5	1,651.0	0.4	1.2	1	1	1
08/12/2021 03:00	-0.5	12.2	2,052.6	-0.1	1.4	1	1	1
08/12/2021 04:00	-0.5	12.2	2,033.5	-0.1	1.4	1	1	1
08/12/2021 05:00	0.4	13.6	1,699.4	0.4	1.2	1	1	0
08/12/2021 06:00	0.4	13.5	1,780.9	0.4	1.2	1	1	1
08/12/2021 07:00	-1.1	12.3	2,048.0	-0.5	1.4	1	1	1
08/12/2021 08:00	-0.7	12.4	1,978.2	-0.2	1.4	1	1	1
08/12/2021 09:00	0.5	13.6	1,709.6	0.5	1.2	1	1	0
08/12/2021 10:00	0.5	13.6	1,722.3	0.5	1.2	1	1	1
08/12/2021 11:00	-0.7	12.0	2,091.6	-0.2	1.5	1	1	1
08/12/2021 12:00	-0.4	11.6	2,141.2	0.1	1.5	1	1	1
08/12/2021 13:00	-0.4	11.7	2,124.6	0.1	1.5	1	1	1
08/12/2021 14:00	-0.4	11.7	2,111.7	0.1	1.5	1	1	1
08/12/2021 15:00	-0.4	11.6	2,119.3	0.1	1.5	1	1	1
08/12/2021 16:00	-0.2	11.6	2,133.9	0.1	1.5	1	1	1
08/12/2021 17:00	-0.2	11.5	2,145.0	0.1	1.5	1	1	1
08/12/2021 18:00	-0.1	11.3	2,196.1	0.2	1.5	1	1	1
08/12/2021 19:00	-0.1	11.2	2,203.9	0.2	1.5	1	1	1
08/12/2021 20:00	-0.1	11.2	2,239.6	0.2	1.6	1	1	1
08/12/2021 21:00	-0.2	11.4	2,201.1	0.1	1.5	1	1	1
08/12/2021 22:00	-0.4	11.8	2,145.5	-0.1	1.5	1	1	1
08/12/2021 23:00	-0.5	12.1	2,082.4	-0.1	1.5	1	1	1
Average/Sum#:	-0.2	12.2	2,017.7	0.1	1.4	24 #	24 #	22 #
Minimum:	-1.1	11.2	1,651.0	-0.5	1.2	1	1	0
Maximum:	0.5	13.6	2,239.6	0.5	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/13/2021 00:00	-0.5	12.5	1,980.3	-0.2	1.4	1	1	1
08/13/2021 01:00	0.2	13.5	1,655.2	0.4	1.2	1	1	1
08/13/2021 02:00	0.2	13.6	1,502.2	0.4	1.1	1	1	1
08/13/2021 03:00	-0.7	12.3	2,040.5	-0.2	1.4	1	1	1
08/13/2021 04:00	-0.7	12.6	1,963.8	-0.2	1.4	1	1	1
08/13/2021 05:00	0.5	13.6	1,684.7	0.5	1.2	1	1	0
08/13/2021 06:00	0.5	13.6	1,652.6	0.5	1.2	1	1	0
08/13/2021 07:00	0.1	13.6	1,568.8	0.2	1.1	1	1	1
08/13/2021 08:00	-1.7	12.3	2,033.2	-0.9	1.4	1	1	1
08/13/2021 09:00	-0.7	12.4	1,989.1	-0.2	1.4	1	1	1
08/13/2021 10:00	0.6	13.6	1,599.3	0.6	1.1	1	1	0
08/13/2021 11:00	0.7	13.6	1,600.0	0.7	1.1	1	1	1
08/13/2021 12:00	-0.8	12.1	2,076.3	-0.4	1.5	1	1	1
08/13/2021 13:00	-0.5	11.9	2,112.6	-0.1	1.5	1	1	1
08/13/2021 14:00	-0.5	11.9	2,105.4	-0.1	1.5	1	1	1
08/13/2021 15:00	-0.4	11.8	2,102.1	-0.1	1.5	1	1	1
08/13/2021 16:00	-0.4	11.7	2,109.3	0.1	1.5	1	1	1
08/13/2021 17:00	-0.4	11.6	2,129.1	0.1	1.5	1	1	1
08/13/2021 18:00	-0.2	11.4	2,179.8	0.1	1.5	1	1	1
08/13/2021 19:00	-0.2	11.3	2,221.0	0.1	1.6	1	1	1
08/13/2021 20:00	-0.2	11.4	2,199.3	0.1	1.5	1	1	1
08/13/2021 21:00	-0.5	11.7	2,129.2	-0.1	1.5	1	1	1
08/13/2021 22:00	-0.5	11.8	2,126.3	-0.1	1.5	1	1	1
08/13/2021 23:00	-0.5	11.8	2,125.0	-0.1	1.5	1	1	1
Average/Sum#:	-0.3	12.4	1,953.5	0.0	1.4	24 #	24 #	21 #
Minimum:	-1.7	11.3	1,502.2	-0.9	1.1	1	1	0
Maximum:	0.7	13.6	2,221.0	0.7	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/14/2021 00:00	-0.7	12.2	2,009.9	-0.2	1.4	1	1	1
08/14/2021 01:00	0.5	13.6	1,710.5	0.5	1.2	1	1	0
08/14/2021 02:00	0.4	13.5	1,751.2	0.4	1.2	1	1	1
08/14/2021 03:00	-0.9	12.2	2,055.0	-0.4	1.4	1	1	1
08/14/2021 04:00	-0.8	12.4	1,975.7	-0.4	1.4	1	1	1
08/14/2021 05:00	0.4	13.6	1,717.7	0.4	1.2	1	1	0
08/14/2021 06:00	0.4	13.6	1,630.6	0.4	1.1	1	1	0
08/14/2021 07:00	0.3	13.6	1,519.8	0.4	1.1	1	1	0
08/14/2021 08:00	0.4	13.7	1,317.3	0.4	0.9	1	1	0
08/14/2021 09:00	0.6	13.6	1,594.8	0.6	1.1	1	1	0
08/14/2021 10:00	0.6	13.6	1,665.3	0.6	1.2	1	1	0
08/14/2021 11:00	0.6	13.6	1,689.3	0.6	1.2	1	1	0
08/14/2021 12:00	0.7	13.6	1,693.4	0.7	1.2	1	1	1
08/14/2021 13:00	-0.7	12.0	2,046.4	-0.2	1.4	1	1	1
08/14/2021 14:00	-0.4	11.6	2,090.5	0.1	1.5	1	1	1
08/14/2021 15:00	0.6	13.6	1,592.7	0.6	1.1	1	1	0
08/14/2021 16:00	0.6	13.7	1,510.0	0.6	1.1	1	1	0
08/14/2021 17:00	-0.5	11.8	2,075.0	-0.1	1.5	1	1	1
08/14/2021 18:00	-0.1	11.1	2,194.8	0.2	1.5	1	1	1
08/14/2021 19:00	-0.1	11.0	2,210.3	0.2	1.5	1	1	1
08/14/2021 20:00	-0.1	11.2	2,201.9	0.2	1.5	1	1	1
08/14/2021 21:00	-0.2	11.4	2,179.8	0.1	1.5	1	1	1
08/14/2021 22:00	-0.4	11.6	2,145.3	0.1	1.5	1	1	1
08/14/2021 23:00	-0.5	11.8	2,121.5	-0.1	1.5	1	1	1
Average/Sum#:	0.0	12.7	1,862.4	0.2	1.3	24 #	24 #	14 #
Minimum:	-0.9	11.0	1,317.3	-0.4	0.9	1	1	0
Maximum:	0.7	13.7	2,210.3	0.7	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/15/2021 00:00	-0.5	12.4	1,993.4	-0.2	1.4	1	1	1
08/15/2021 01:00	0.5	13.6	1,707.4	0.5	1.2	1	1	0
08/15/2021 02:00	0.4	13.5	1,645.3	0.4	1.2	1	1	1
08/15/2021 03:00	-0.7	12.2	2,057.7	-0.2	1.4	1	1	1
08/15/2021 04:00	-0.7	12.5	1,972.3	-0.2	1.4	1	1	1
08/15/2021 05:00	0.4	13.6	1,687.4	0.4	1.2	1	1	0
08/15/2021 06:00	0.4	13.6	1,606.4	0.4	1.1	1	1	0
08/15/2021 07:00	0.5	13.6	1,684.1	0.5	1.2	1	1	0
08/15/2021 08:00	0.4	13.6	1,513.1	0.4	1.1	1	1	0
08/15/2021 09:00	0.5	13.6	1,638.4	0.5	1.1	1	1	0
08/15/2021 10:00	0.5	13.6	1,697.0	0.5	1.2	1	1	0
08/15/2021 11:00	0.5	13.6	1,523.7	0.5	1.1	1	1	0
08/15/2021 12:00	0.1	12.8	1,761.4	0.2	1.2	1	1	1
08/15/2021 13:00	-0.5	11.6	2,076.9	-0.1	1.5	1	1	1
08/15/2021 14:00	0.6	13.5	1,644.2	0.6	1.2	1	1	0
08/15/2021 15:00	0.7	13.5	1,654.9	0.7	1.2	1	1	1
08/15/2021 16:00	-0.7	11.7	2,090.7	-0.2	1.5	1	1	1
08/15/2021 17:00	-0.2	11.3	2,146.6	0.1	1.5	1	1	1
08/15/2021 18:00	-0.2	11.1	2,191.1	0.1	1.5	1	1	1
08/15/2021 19:00	-0.2	11.3	2,180.2	0.1	1.5	1	1	1
08/15/2021 20:00	-0.4	11.4	2,163.3	0.1	1.5	1	1	1
08/15/2021 21:00	-0.4	11.5	2,159.1	0.1	1.5	1	1	1
08/15/2021 22:00	-0.5	11.6	2,135.4	-0.1	1.5	1	1	1
08/15/2021 23:00	-0.5	11.7	2,126.5	-0.1	1.5	1	1	1
Average/Sum#:	0.0	12.6	1,877.4	0.2	1.3	24 #	24 #	15 #
Minimum:	-0.7	11.1	1,513.1	-0.2	1.1	1	1	0
Maximum:	0.7	13.6	2,191.1	0.7	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/16/2021 00:00	-0.7	12.2	1,998.1	-0.2	1.4	1	1	1
08/16/2021 01:00	0.5	13.6	1,707.9	0.5	1.2	1	1	0
08/16/2021 02:00	0.2	13.5	1,542.2	0.4	1.1	1	1	1
08/16/2021 03:00	-0.9	12.2	2,031.8	-0.4	1.4	1	1	1
08/16/2021 04:00	-0.8	12.3	2,002.7	-0.4	1.4	1	1	1
08/16/2021 05:00	0.4	13.6	1,715.7	0.4	1.2	1	1	1
08/16/2021 06:00	0.5	13.5	1,750.3	0.5	1.2	1	1	1
08/16/2021 07:00	-0.9	12.1	2,031.2	-0.4	1.4	1	1	1
08/16/2021 08:00	-0.7	12.0	2,035.4	-0.2	1.4	1	1	1
08/16/2021 09:00	0.5	13.5	1,685.7	0.5	1.2	1	1	0
08/16/2021 10:00	0.5	13.6	1,631.4	0.5	1.1	1	1	1
08/16/2021 11:00	-0.8	11.8	2,088.4	-0.2	1.5	1	1	1
08/16/2021 12:00	-0.5	11.5	2,130.0	-0.1	1.5	1	1	1
08/16/2021 13:00	-0.4	11.5	2,123.1	0.1	1.5	1	1	1
08/16/2021 14:00	-0.5	11.7	2,083.8	-0.1	1.5	1	1	1
08/16/2021 15:00	-0.2	11.3	2,157.0	0.1	1.5	1	1	1
08/16/2021 16:00	-0.2	11.2	2,178.3	0.1	1.5	1	1	1
08/16/2021 17:00	-0.1	11.0	2,211.6	0.2	1.5	1	1	1
08/16/2021 18:00	-0.1	10.9	2,241.1	0.2	1.6	1	1	1
08/16/2021 19:00	-0.2	11.0	2,228.5	0.1	1.6	1	1	1
08/16/2021 20:00	-0.2	11.2	2,201.6	0.1	1.5	1	1	1
08/16/2021 21:00	-0.2	11.1	2,210.1	0.1	1.5	1	1	1
08/16/2021 22:00	-0.4	11.6	2,144.2	0.1	1.5	1	1	1
08/16/2021 23:00	-0.5	11.7	2,138.5	-0.1	1.5	1	1	1
Average/Sum#:	-0.2	12.1	2,011.2	0.1	1.4	24 #	24 #	22 #
Minimum:	-0.9	10.9	1,542.2	-0.4	1.1	1	1	0
Maximum:	0.5	13.6	2,241.1	0.5	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/17/2021 00:00	-0.5	11.9	2,101.8	-0.1	1.5	1	1	1
08/17/2021 01:00	0.5	13.5	1,690.4	0.5	1.2	1	1	1
08/17/2021 02:00	0.2	13.5	1,651.6	0.4	1.2	1	1	1
08/17/2021 03:00	-0.8	12.0	2,088.3	-0.4	1.5	1	1	1
08/17/2021 04:00	-0.5	11.6	2,168.9	-0.1	1.5	1	1	1
08/17/2021 05:00	-0.2	11.3	2,217.7	0.1	1.6	1	1	1
08/17/2021 06:00	-0.4	11.8	2,104.1	-0.1	1.5	1	1	1
08/17/2021 07:00	0.5	13.6	1,663.8	0.5	1.2	1	1	0
08/17/2021 08:00	0.4	13.6	1,607.8	0.4	1.1	1	1	1
08/17/2021 09:00	-0.8	12.3	2,044.4	-0.4	1.4	1	1	1
08/17/2021 10:00	-0.5	12.5	1,970.1	-0.2	1.4	1	1	1
08/17/2021 11:00	0.5	13.6	1,663.1	0.5	1.2	1	1	0
08/17/2021 12:00	0.4	13.6	1,486.4	0.4	1.0	1	1	0
08/17/2021 13:00	0.6	13.5	1,761.0	0.6	1.2	1	1	0
08/17/2021 14:00	-0.2	12.9	1,849.5	0.1	1.3	1	1	1
08/17/2021 15:00	-0.4	12.6	1,872.6	-0.1	1.3	1	1	1
08/17/2021 16:00	0.5	13.6	1,565.3	0.5	1.1	1	1	1
08/17/2021 17:00	-0.8	12.0	2,077.4	-0.4	1.5	1	1	1
08/17/2021 18:00	-0.4	11.4	2,192.1	0.1	1.5	1	1	1
08/17/2021 19:00	-0.1	11.2	2,237.3	0.2	1.6	1	1	1
08/17/2021 20:00	-0.1	11.1	2,258.0	0.2	1.6	1	1	1
08/17/2021 21:00	-0.1	11.3	2,221.8	0.2	1.6	1	1	1
08/17/2021 22:00	-0.4	11.7	2,170.8	0.1	1.5	1	1	1
08/17/2021 23:00	-0.5	12.4	2,032.3	-0.2	1.4	1	1	1
Average/Sum#:	-0.1	12.4	1,945.7	0.1	1.4	24 #	24 #	20 #
Minimum:	-0.8	11.1	1,486.4	-0.4	1.0	1	1	0
Maximum:	0.6	13.6	2,258.0	0.6	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/18/2021 00:00	0.5	13.6	1,649.7	0.5	1.2	1	1	0
08/18/2021 01:00	0.4	13.7	1,562.7	0.4	1.1	1	1	1
08/18/2021 02:00	-0.7	12.7	1,985.3	-0.2	1.4	1	1	1
08/18/2021 03:00	-0.8	12.7	1,965.1	-0.4	1.4	1	1	1
08/18/2021 04:00	0.4	13.6	1,715.8	0.4	1.2	1	1	0
08/18/2021 05:00	0.5	13.5	1,694.9	0.5	1.2	1	1	1
08/18/2021 06:00	-0.9	12.5	2,032.6	-0.5	1.4	1	1	1
08/18/2021 07:00	-0.7	12.6	1,982.0	-0.2	1.4	1	1	1
08/18/2021 08:00	0.4	13.7	1,458.9	0.4	1.0	1	1	0
08/18/2021 09:00	0.6	0.0	1,569.1	0.6	1.1	1	1	0
08/18/2021 10:00	0.5	14.0	1,541.4	0.5	1.1	1	1	0
08/18/2021 11:00	0.6	14.0	1,482.0	0.6	1.0	1	1	0
08/18/2021 12:00	0.7	13.9	1,527.9	0.7	1.1	1	1	1
08/18/2021 13:00	-0.7	12.4	2,102.0	-0.2	1.5	1	1	1
08/18/2021 14:00	-0.7	12.1	2,088.5	-0.2	1.5	1	1	1
08/18/2021 15:00	0.4	13.8	1,692.3	0.4	1.2	1	1	0
08/18/2021 16:00	0.5	13.9	1,547.5	0.5	1.1	1	1	0
08/18/2021 17:00	-0.7	12.4	2,040.2	-0.2	1.4	1	1	1
08/18/2021 18:00	-0.5	11.8	2,188.5	-0.1	1.5	1	1	1
08/18/2021 19:00	-0.7	12.4	2,028.9	-0.2	1.4	1	1	1
08/18/2021 20:00	0.5	13.8	1,724.9	0.5	1.2	1	1	0
08/18/2021 21:00	0.5	13.7	1,749.7	0.5	1.2	1	1	1
08/18/2021 22:00	-0.9	12.4	2,079.3	-0.5	1.5	1	1	1
08/18/2021 23:00	-0.7	12.7	1,968.6	-0.2	1.4	1	1	1
Average/Sum#:	-0.1	13.1	1,807.4	0.1	1.3	24 #	24 #	15 #
Minimum:	-0.9	11.8	1,458.9	-0.5	1.0	1	1	0
Maximum:	0.7	14.0	2,188.5	0.7	1.5	1	1	1
%SI	4.17	4.17	0.00	4.17	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/19/2021 00:00	0.4	13.8	1,628.3	0.4	1.1	1	1	0
08/19/2021 01:00	0.5	13.8	1,660.5	0.5	1.2	1	1	0
08/19/2021 02:00	0.4	13.8	1,522.6	0.4	1.1	1	1	0
08/19/2021 03:00	0.2	13.8	1,557.9	0.4	1.1	1	1	1
08/19/2021 04:00	-0.9	12.4	2,070.5	-0.5	1.4	1	1	1
08/19/2021 05:00	-0.8	12.8	1,990.8	-0.4	1.4	1	1	1
08/19/2021 06:00	0.5	13.8	1,670.2	0.5	1.2	1	1	0
08/19/2021 07:00	0.5	13.8	1,701.0	0.5	1.2	1	1	0
08/19/2021 08:00	0.4	13.9	1,364.1	0.4	1.0	1	1	0
08/19/2021 09:00	0.6	0.0	1,688.3	0.6	1.2	1	1	0
08/19/2021 10:00	0.6	14.0	1,654.6	0.6	1.2	1	1	0
08/19/2021 11:00	0.5	13.9	1,623.7	0.5	1.1	1	1	0
08/19/2021 12:00	-0.1	13.9	1,708.0	0.1	1.2	1	1	1
08/19/2021 13:00	0.7	0.0	2,118.7	0.7	1.5	1	1	1
08/19/2021 14:00	-1.4	12.5	2,052.8	-0.8	1.4	1	1	1
08/19/2021 15:00	0.1	13.9	1,586.0	0.1	1.1	1	1	0
08/19/2021 16:00	-0.4	13.9	1,669.5	-0.2	1.2	1	1	1
08/19/2021 17:00	-1.5	12.3	2,091.5	-0.8	1.5	1	1	1
08/19/2021 18:00	-1.2	11.9	2,168.3	-0.7	1.5	1	1	1
08/19/2021 19:00	-1.2	12.2	2,081.9	-0.7	1.5	1	1	1
08/19/2021 20:00	0.1	13.9	1,714.6	0.2	1.2	1	1	0
08/19/2021 21:00	-0.5	13.8	1,621.2	-0.4	1.1	1	1	1
08/19/2021 22:00	-1.5	12.5	2,043.6	-0.9	1.4	1	1	1
08/19/2021 23:00	-1.4	12.8	1,963.7	-0.8	1.4	1	1	1
Average/Sum#:	-0.3	13.3	1,789.7	-0.1	1.3	24 #	24 #	13 #
Minimum:	-1.5	11.9	1,364.1	-0.9	1.0	1	1	0
Maximum:	0.6	14.0	2,168.3	0.6	1.5	1	1	1
%SI	8.33	8.33	0.00	8.33	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/20/2021 00:00	0.1	13.9	1,690.4	0.1	1.2	1	1	0
08/20/2021 01:00	0.1	13.9	1,688.0	0.1	1.2	1	1	0
08/20/2021 02:00	0.0	13.9	1,546.8	0.1	1.1	1	1	0
08/20/2021 03:00	-0.2	13.9	1,355.8	-0.1	0.9	1	1	0
08/20/2021 04:00	0.1	13.9	1,652.9	0.2	1.2	1	1	0
08/20/2021 05:00	-2.7	13.4	1,729.8	-2.0	1.2	1	1	1
08/20/2021 06:00	-1.7	13.1	1,865.4	-1.1	1.3	1	1	1
08/20/2021 07:00	0.1	13.9	1,660.7	0.1	1.2	1	1	0
08/20/2021 08:00	0.0	13.9	1,526.6	0.1	1.1	1	1	0
08/20/2021 09:00	-0.1	14.0	1,320.0	0.0	0.9	1	1	0
08/20/2021 10:00	0.0	14.0	1,308.3	0.1	0.9	1	1	0
08/20/2021 11:00	0.0	14.0	1,310.3	0.1	0.9	1	1	0
08/20/2021 12:00	-0.4	13.9	1,524.4	-0.2	1.1	1	1	1
08/20/2021 13:00	-1.7	12.3	2,070.7	-0.9	1.4	1	1	1
08/20/2021 14:00	-1.4	12.5	2,004.6	-0.8	1.4	1	1	1
08/20/2021 15:00	0.1	13.9	1,544.0	0.1	1.1	1	1	0
08/20/2021 16:00	0.0	13.8	1,552.9	0.1	1.1	1	1	0
08/20/2021 17:00	-1.4	12.2	2,093.1	-0.7	1.5	1	1	1
08/20/2021 18:00	-1.2	11.9	2,156.3	-0.7	1.5	1	1	1
08/20/2021 19:00	-1.2	12.1	2,093.0	-0.7	1.5	1	1	1
08/20/2021 20:00	0.1	13.9	1,676.8	0.1	1.2	1	1	0
08/20/2021 21:00	-0.4	13.7	1,722.8	-0.2	1.2	1	1	1
08/20/2021 22:00	-1.7	12.4	2,063.8	-0.9	1.4	1	1	1
08/20/2021 23:00	-1.5	12.8	1,944.1	-0.9	1.4	1	1	1
Average/Sum#:	-0.6	13.4	1,712.6	-0.3	1.2	24 #	24 #	11 #
Minimum:	-2.7	11.9	1,308.3	-2.0	0.9	1	1	0
Maximum:	0.1	14.0	2,156.3	0.2	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/21/2021 00:00	0.0	15.7	595.3	0.0	0.4	1	0	0
08/21/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	15.7	595.3	0.0	0.4	1 #	0 #	0 #
Minimum:	0.0	15.7	595.3	0.0	0.4	0	0	0
Maximum:	0.0	15.7	595.3	0.0	0.4	1	0	0
%SI	95.83	95.83	95.83	95.83	95.83	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/22/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/23/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2021 16:00	0.0	17.8	320.6	0.0	0.2	1	0	0
08/23/2021 17:00	0.0	15.9	783.7	0.0	0.5	1	0	0
08/23/2021 18:00	0.2	14.1	1,703.5	0.3	1.2	1	1	0
08/23/2021 19:00	-0.8	13.6	1,820.0	-0.5	1.3	1	1	1
08/23/2021 20:00	-1.4	13.1	1,884.9	-0.9	1.3	1	1	1
08/23/2021 21:00	-0.2	14.0	1,788.3	-0.1	1.3	1	1	1
08/23/2021 22:00	-1.7	13.0	2,028.3	-1.1	1.4	1	1	1
08/23/2021 23:00	-1.2	13.2	1,964.9	-0.8	1.4	1	1	1
Average/Sum#:	-0.6	14.3	1,536.8	-0.4	1.1	8 #	6 #	5 #
Minimum:	-1.7	13.0	320.6	-1.1	0.2	0	0	0
Maximum:	0.2	17.8	2,028.3	0.3	1.4	1	1	1
%SI	66.67	66.67	66.67	66.67	66.67	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/24/2021 00:00	0.1	14.2	1,562.4	0.1	1.1	1	1	0
08/24/2021 01:00	0.1	14.2	1,629.4	0.2	1.1	1	1	0
08/24/2021 02:00	-0.2	14.1	1,680.4	-0.1	1.2	1	1	1
08/24/2021 03:00	-1.2	13.4	1,948.6	-0.8	1.4	1	1	1
08/24/2021 04:00	-1.1	13.4	1,926.1	-0.7	1.3	1	1	1
08/24/2021 05:00	0.1	14.2	1,667.1	0.2	1.2	1	1	0
08/24/2021 06:00	0.1	14.2	1,616.4	0.2	1.1	1	1	0
08/24/2021 07:00	0.2	14.2	1,658.7	0.3	1.2	1	1	0
08/24/2021 08:00	0.2	14.2	1,544.5	0.3	1.1	1	1	0
08/24/2021 09:00	0.2	14.2	1,704.8	0.3	1.2	1	1	0
08/24/2021 10:00	0.2	14.2	1,687.9	0.3	1.2	1	1	0
08/24/2021 11:00	0.2	14.2	1,652.2	0.3	1.2	1	1	0
08/24/2021 12:00	0.3	14.3	1,580.3	0.3	1.1	1	1	0
08/24/2021 13:00	-0.1	14.2	1,661.3	0.1	1.2	1	1	1
08/24/2021 14:00	-1.5	12.7	2,084.6	-0.9	1.5	1	1	1
08/24/2021 15:00	-1.4	12.7	2,079.1	-0.8	1.5	1	1	1
08/24/2021 16:00	0.2	14.2	1,719.6	0.3	1.2	1	1	0
08/24/2021 17:00	-0.2	14.0	1,770.8	-0.1	1.2	1	1	1
08/24/2021 18:00	-1.5	12.6	2,098.5	-0.9	1.5	1	1	1
08/24/2021 19:00	-1.1	12.2	2,154.7	-0.5	1.5	1	1	1
08/24/2021 20:00	0.1	14.1	1,674.7	0.2	1.2	1	1	0
08/24/2021 21:00	-0.4	14.0	1,798.3	-0.2	1.3	1	1	1
08/24/2021 22:00	-1.5	12.9	2,066.9	-0.9	1.4	1	1	1
08/24/2021 23:00	-1.4	12.5	2,164.1	-0.8	1.5	1	1	1
Average/Sum#:	-0.4	13.7	1,797.1	-0.2	1.3	24 #	24 #	12 #
Minimum:	-1.5	12.2	1,544.5	-0.9	1.1	1	1	0
Maximum:	0.3	14.3	2,164.1	0.3	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/25/2021 00:00	-0.5	13.9	1,651.0	-0.4	1.2	1	1	1
08/25/2021 01:00	0.1	14.1	1,639.7	0.1	1.1	1	1	0
08/25/2021 02:00	-0.4	14.1	1,590.9	-0.2	1.1	1	1	1
08/25/2021 03:00	-1.2	13.1	2,017.4	-0.8	1.4	1	1	1
08/25/2021 04:00	-1.1	12.8	2,088.8	-0.7	1.5	1	1	1
08/25/2021 05:00	-0.9	13.4	1,955.8	-0.7	1.4	1	1	1
08/25/2021 06:00	0.1	14.2	1,607.1	0.2	1.1	1	1	0
08/25/2021 07:00	0.1	14.2	1,567.2	0.2	1.1	1	1	0
08/25/2021 08:00	-0.2	14.1	1,642.5	-0.1	1.1	1	1	1
08/25/2021 09:00	-1.4	13.1	2,033.4	-0.9	1.4	1	1	1
08/25/2021 10:00	-1.2	13.3	1,972.7	-0.8	1.4	1	1	1
08/25/2021 11:00	-0.4	14.1	1,683.0	-0.2	1.2	1	1	1
08/25/2021 12:00	-0.4	14.1	1,650.6	-0.2	1.2	1	1	1
08/25/2021 13:00	-1.4	12.7	2,087.9	-0.8	1.5	1	1	1
08/25/2021 14:00	-1.4	12.6	2,077.7	-0.8	1.5	1	1	1
08/25/2021 15:00	0.1	14.2	1,625.2	0.2	1.1	1	1	0
08/25/2021 16:00	-0.4	14.2	1,482.5	-0.2	1.0	1	1	1
08/25/2021 17:00	-1.7	12.7	2,080.3	-1.1	1.5	1	1	1
08/25/2021 18:00	-1.2	12.2	2,175.5	-0.7	1.5	1	1	1
08/25/2021 19:00	-1.4	12.6	2,078.9	-0.8	1.5	1	1	1
08/25/2021 20:00	0.1	14.1	1,666.9	0.2	1.2	1	1	0
08/25/2021 21:00	-0.4	14.0	1,713.5	-0.2	1.2	1	1	1
08/25/2021 22:00	-1.5	12.9	2,057.5	-0.9	1.4	1	1	1
08/25/2021 23:00	-1.4	13.2	1,975.4	-0.9	1.4	1	1	1
Average/Sum#:	-0.8	13.5	1,838.4	-0.4	1.3	24 #	24 #	19 #
Minimum:	-1.7	12.2	1,482.5	-1.1	1.0	1	1	0
Maximum:	0.1	14.2	2,175.5	0.2	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/26/2021 00:00	0.1	14.1	1,670.7	0.1	1.2	1	1	0
08/26/2021 01:00	0.1	14.1	1,636.5	0.1	1.1	1	1	0
08/26/2021 02:00	-0.1	14.2	1,426.6	0.0	1.0	1	1	0
08/26/2021 03:00	-0.4	14.1	1,591.5	-0.2	1.1	1	1	1
08/26/2021 04:00	-1.5	12.9	2,071.1	-0.9	1.4	1	1	1
08/26/2021 05:00	-1.5	12.8	2,103.5	-0.9	1.5	1	1	1
08/26/2021 06:00	-1.4	13.2	1,981.1	-0.9	1.4	1	1	1
08/26/2021 07:00	-0.4	14.1	1,698.6	-0.2	1.2	1	1	1
08/26/2021 08:00	0.0	14.1	1,569.6	0.1	1.1	1	1	0
08/26/2021 09:00	-0.8	13.5	1,865.4	-0.5	1.3	1	1	1
08/26/2021 10:00	-1.4	13.1	1,987.7	-0.9	1.4	1	1	1
08/26/2021 11:00	0.1	14.1	1,726.8	0.1	1.2	1	1	0
08/26/2021 12:00	0.1	14.1	1,708.9	0.2	1.2	1	1	0
08/26/2021 13:00	-1.4	12.8	2,066.9	-0.8	1.4	1	1	1
08/26/2021 14:00	-1.4	12.7	2,033.7	-0.8	1.4	1	1	1
08/26/2021 15:00	0.1	14.1	1,725.7	0.2	1.2	1	1	0
08/26/2021 16:00	-0.2	14.0	1,659.2	-0.1	1.2	1	1	1
08/26/2021 17:00	-1.4	12.3	2,150.8	-0.8	1.5	1	1	1
08/26/2021 18:00	-1.1	11.6	2,282.5	-0.5	1.6	1	1	1
08/26/2021 19:00	-0.9	11.6	2,300.4	-0.4	1.6	1	1	1
08/26/2021 20:00	-0.9	11.8	2,249.0	-0.4	1.6	1	1	1
08/26/2021 21:00	-1.1	11.9	2,232.7	-0.5	1.6	1	1	1
08/26/2021 22:00	-1.1	12.0	2,215.2	-0.5	1.6	1	1	1
08/26/2021 23:00	-1.4	12.4	2,112.7	-0.8	1.5	1	1	1
Average/Sum#:	-0.7	13.2	1,919.5	-0.4	1.3	24 #	24 #	17 #
Minimum:	-1.5	11.6	1,426.6	-0.9	1.0	1	1	0
Maximum:	0.1	14.2	2,300.4	0.2	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/27/2021 00:00	0.1	14.0	1,712.6	0.2	1.2	1	1	0
08/27/2021 01:00	0.1	14.1	1,676.9	0.2	1.2	1	1	0
08/27/2021 02:00	0.2	14.0	1,708.6	0.3	1.2	1	1	0
08/27/2021 03:00	-0.2	13.9	1,757.8	-0.1	1.2	1	1	1
08/27/2021 04:00	-1.7	12.6	2,098.9	-0.9	1.5	1	1	1
08/27/2021 05:00	-1.4	12.5	2,116.0	-0.8	1.5	1	1	1
08/27/2021 06:00	0.1	14.0	1,610.2	0.1	1.1	1	1	0
08/27/2021 07:00	0.1	14.0	1,698.6	0.1	1.2	1	1	0
08/27/2021 08:00	0.0	14.0	1,554.4	0.1	1.1	1	1	0
08/27/2021 09:00	-1.5	12.9	1,988.1	-0.9	1.4	1	1	1
08/27/2021 10:00	-1.5	12.7	2,014.5	-0.9	1.4	1	1	1
08/27/2021 11:00	0.2	14.0	1,740.0	0.3	1.2	1	1	0
08/27/2021 12:00	-0.1	14.0	1,736.3	0.1	1.2	1	1	1
08/27/2021 13:00	-1.4	12.4	2,096.7	-0.8	1.5	1	1	1
08/27/2021 14:00	-0.9	11.8	2,210.8	-0.4	1.5	1	1	1
08/27/2021 15:00	-0.9	11.7	2,202.0	-0.4	1.5	1	1	1
08/27/2021 16:00	-0.9	11.7	2,198.8	-0.4	1.5	1	1	1
08/27/2021 17:00	-0.9	11.6	2,220.2	-0.4	1.6	1	1	1
08/27/2021 18:00	-0.9	11.6	2,231.5	-0.4	1.6	1	1	1
08/27/2021 19:00	-0.9	11.6	2,230.2	-0.4	1.6	1	1	1
08/27/2021 20:00	-0.9	11.6	2,235.5	-0.4	1.6	1	1	1
08/27/2021 21:00	-0.9	11.6	2,256.9	-0.4	1.6	1	1	1
08/27/2021 22:00	-1.1	11.9	2,210.2	-0.5	1.5	1	1	1
08/27/2021 23:00	-1.2	12.2	2,118.0	-0.7	1.5	1	1	1
Average/Sum#:	-0.7	12.8	1,984.3	-0.3	1.4	24 #	24 #	17 #
Minimum:	-1.7	11.6	1,554.4	-0.9	1.1	1	1	0
Maximum:	0.2	14.1	2,256.9	0.3	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/28/2021 00:00	0.1	14.0	1,703.5	0.2	1.2	1	1	0
08/28/2021 01:00	-0.4	13.8	1,792.7	-0.2	1.3	1	1	1
08/28/2021 02:00	-1.5	12.6	2,069.5	-0.9	1.4	1	1	1
08/28/2021 03:00	-1.2	13.0	1,965.6	-0.8	1.4	1	1	1
08/28/2021 04:00	0.1	14.0	1,670.8	0.1	1.2	1	1	0
08/28/2021 05:00	0.1	14.1	1,666.0	0.2	1.2	1	1	0
08/28/2021 06:00	0.2	14.1	1,655.6	0.3	1.2	1	1	0
08/28/2021 07:00	0.2	14.0	1,692.8	0.3	1.2	1	1	0
08/28/2021 08:00	0.2	14.1	1,655.0	0.3	1.2	1	1	0
08/28/2021 09:00	0.2	13.9	1,694.6	0.3	1.2	1	1	0
08/28/2021 10:00	-0.1	14.0	1,653.6	0.1	1.2	1	1	1
08/28/2021 11:00	-1.5	12.3	2,114.8	-0.8	1.5	1	1	1
08/28/2021 12:00	-1.2	12.0	2,120.6	-0.7	1.5	1	1	1
08/28/2021 13:00	0.2	14.0	1,704.8	0.3	1.2	1	1	0
08/28/2021 14:00	-0.2	14.0	1,723.2	-0.1	1.2	1	1	1
08/28/2021 15:00	-1.5	12.4	2,080.0	-0.8	1.5	1	1	1
08/28/2021 16:00	-1.1	11.8	2,195.1	-0.5	1.5	1	1	1
08/28/2021 17:00	-0.9	11.6	2,230.8	-0.4	1.6	1	1	1
08/28/2021 18:00	-0.9	11.5	2,270.2	-0.4	1.6	1	1	1
08/28/2021 19:00	-0.8	11.4	2,290.7	-0.2	1.6	1	1	1
08/28/2021 20:00	-0.8	11.4	2,294.1	-0.2	1.6	1	1	1
08/28/2021 21:00	-0.8	11.5	2,276.2	-0.2	1.6	1	1	1
08/28/2021 22:00	-1.1	11.9	2,210.2	-0.5	1.5	1	1	1
08/28/2021 23:00	-1.2	12.2	2,147.8	-0.7	1.5	1	1	1
Average/Sum#:	-0.6	12.9	1,953.3	-0.2	1.4	24 #	24 #	16 #
Minimum:	-1.5	11.4	1,653.6	-0.9	1.2	1	1	0
Maximum:	0.2	14.1	2,294.1	0.3	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/29/2021 00:00	-1.2	12.7	2,008.0	-0.7	1.4	1	1	1
08/29/2021 01:00	0.1	13.9	1,713.5	0.2	1.2	1	1	0
08/29/2021 02:00	-0.4	13.7	1,797.6	-0.2	1.3	1	1	1
08/29/2021 03:00	-1.5	12.5	2,077.9	-0.9	1.5	1	1	1
08/29/2021 04:00	-1.5	12.3	2,082.6	-0.8	1.5	1	1	1
08/29/2021 05:00	0.2	14.0	1,715.6	0.3	1.2	1	1	0
08/29/2021 06:00	0.2	14.0	1,647.3	0.3	1.2	1	1	0
08/29/2021 07:00	0.2	14.0	1,621.7	0.3	1.1	1	1	0
08/29/2021 08:00	0.2	14.1	1,544.6	0.3	1.1	1	1	0
08/29/2021 09:00	0.2	14.1	1,495.7	0.3	1.0	1	1	0
08/29/2021 10:00	-0.8	13.3	1,824.9	-0.5	1.3	1	1	1
08/29/2021 11:00	-1.7	12.6	2,022.3	-0.9	1.4	1	1	1
08/29/2021 12:00	-0.2	13.8	1,734.4	-0.1	1.2	1	1	1
08/29/2021 13:00	-0.4	13.9	1,715.0	-0.2	1.2	1	1	1
08/29/2021 14:00	-1.5	12.1	2,115.5	-0.8	1.5	1	1	1
08/29/2021 15:00	-1.1	11.7	2,187.1	-0.5	1.5	1	1	1
08/29/2021 16:00	-1.1	11.6	2,203.9	-0.5	1.5	1	1	1
08/29/2021 17:00	-0.9	11.4	2,248.6	-0.4	1.6	1	1	1
08/29/2021 18:00	-0.9	11.4	2,257.6	-0.4	1.6	1	1	1
08/29/2021 19:00	-0.9	11.3	2,267.8	-0.4	1.6	1	1	1
08/29/2021 20:00	-0.8	11.3	2,265.7	-0.2	1.6	1	1	1
08/29/2021 21:00	-0.8	11.3	2,266.7	-0.2	1.6	1	1	1
08/29/2021 22:00	-0.9	11.6	2,216.8	-0.4	1.6	1	1	1
08/29/2021 23:00	-1.2	12.2	2,074.9	-0.7	1.5	1	1	1
Average/Sum#:	-0.7	12.7	1,962.7	-0.3	1.4	24 #	24 #	18 #
Minimum:	-1.7	11.3	1,495.7	-0.9	1.0	1	1	0
Maximum:	0.2	14.1	2,267.8	0.3	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/30/2021 00:00	0.1	13.9	1,651.0	0.1	1.2	1	1	0
08/30/2021 01:00	-0.4	13.9	1,696.1	-0.2	1.2	1	1	1
08/30/2021 02:00	-1.5	12.8	1,985.9	-0.9	1.4	1	1	1
08/30/2021 03:00	-1.5	12.3	2,078.8	-0.8	1.5	1	1	1
08/30/2021 04:00	0.1	13.9	1,656.6	0.1	1.2	1	1	0
08/30/2021 05:00	-0.5	13.9	1,556.2	-0.4	1.1	1	1	1
08/30/2021 06:00	-1.7	12.5	2,066.0	-0.9	1.4	1	1	1
08/30/2021 07:00	-1.5	12.5	2,034.9	-0.9	1.4	1	1	1
08/30/2021 08:00	0.1	13.9	1,695.3	0.1	1.2	1	1	0
08/30/2021 09:00	0.1	13.8	1,666.0	0.1	1.2	1	1	0
08/30/2021 10:00	-1.4	12.8	1,959.6	-0.8	1.4	1	1	1
08/30/2021 11:00	-1.4	12.1	2,092.0	-0.7	1.5	1	1	1
08/30/2021 12:00	0.1	13.9	1,714.4	0.2	1.2	1	1	0
08/30/2021 13:00	-0.4	13.9	1,700.3	-0.2	1.2	1	1	1
08/30/2021 14:00	-1.4	12.1	2,122.8	-0.7	1.5	1	1	1
08/30/2021 15:00	-1.1	11.6	2,198.3	-0.5	1.5	1	1	1
08/30/2021 16:00	-0.9	11.6	2,206.6	-0.4	1.5	1	1	1
08/30/2021 17:00	-0.9	11.4	2,239.3	-0.4	1.6	1	1	1
08/30/2021 18:00	-0.8	11.3	2,256.6	-0.2	1.6	1	1	1
08/30/2021 19:00	-0.8	11.3	2,272.2	-0.2	1.6	1	1	1
08/30/2021 20:00	-0.8	11.4	2,298.6	-0.2	1.6	1	1	1
08/30/2021 21:00	-0.9	11.5	2,279.5	-0.4	1.6	1	1	1
08/30/2021 22:00	-1.1	11.8	2,219.8	-0.5	1.6	1	1	1
08/30/2021 23:00	-1.2	12.2	2,099.9	-0.7	1.5	1	1	1
Average/Sum#:	-0.8	12.6	1,989.4	-0.4	1.4	24 #	24 #	19 #
Minimum:	-1.7	11.3	1,556.2	-0.9	1.1	1	1	0
Maximum:	0.1	13.9	2,298.6	0.2	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/31/2021 00:00	0.1	13.9	1,680.9	0.1	1.2	1	1	0
08/31/2021 01:00	0.1	13.9	1,701.9	0.1	1.2	1	1	0
08/31/2021 02:00	-0.2	14.0	1,331.1	-0.1	0.9	1	1	0
08/31/2021 03:00	0.1	13.9	1,669.0	0.2	1.2	1	1	0
08/31/2021 04:00	-0.9	13.4	1,835.1	-0.7	1.3	1	1	1
08/31/2021 05:00	-1.4	13.1	1,913.5	-0.9	1.3	1	1	1
08/31/2021 06:00	0.1	13.7	1,797.8	0.2	1.3	1	1	0
08/31/2021 07:00	-1.7	12.8	2,017.4	-1.1	1.4	1	1	1
08/31/2021 08:00	-1.4	12.3	2,098.8	-0.8	1.5	1	1	1
08/31/2021 09:00	0.1	13.9	1,694.7	0.1	1.2	1	1	0
08/31/2021 10:00	0.1	13.8	1,710.3	0.1	1.2	1	1	0
08/31/2021 11:00	-1.5	12.6	2,040.7	-0.9	1.4	1	1	1
08/31/2021 12:00	-1.4	12.1	2,106.5	-0.7	1.5	1	1	1
08/31/2021 13:00	0.1	13.9	1,666.0	0.2	1.2	1	1	0
08/31/2021 14:00	0.1	13.8	1,726.0	0.2	1.2	1	1	0
08/31/2021 15:00	-1.7	12.5	2,037.7	-0.9	1.4	1	1	1
08/31/2021 16:00	-1.2	11.7	2,188.2	-0.5	1.5	1	1	1
08/31/2021 17:00	-1.1	11.6	2,213.8	-0.5	1.5	1	1	1
08/31/2021 18:00	-1.1	11.6	2,221.7	-0.5	1.6	1	1	1
08/31/2021 19:00	-1.1	11.8	2,142.2	-0.5	1.5	1	1	1
08/31/2021 20:00	0.1	13.9	1,665.8	0.2	1.2	1	1	0
08/31/2021 21:00	-0.4	13.8	1,727.7	-0.2	1.2	1	1	1
08/31/2021 22:00	-1.1	12.6	2,039.4	-0.7	1.4	1	1	1
08/31/2021 23:00	-0.9	12.3	2,104.3	-0.5	1.5	1	1	1
Average/Sum#:	-0.7	13.0	1,888.8	-0.3	1.3	24 #	24 #	14 #
Minimum:	-1.7	11.6	1,331.1	-1.1	0.9	1	1	0
Maximum:	0.1	14.0	2,221.7	0.2	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/01/2021 00:00	-0.5	12.2	2,119.6	-0.1	1.5	1	1	1
09/01/2021 01:00	-0.5	12.9	1,948.2	-0.2	1.4	1	1	1
09/01/2021 02:00	0.2	13.9	1,611.5	0.3	1.1	1	1	0
09/01/2021 03:00	-0.2	13.8	1,708.0	-0.1	1.2	1	1	1
09/01/2021 04:00	-1.2	12.7	2,026.0	-0.7	1.4	1	1	1
09/01/2021 05:00	-1.1	12.2	2,137.0	-0.5	1.5	1	1	1
09/01/2021 06:00	-0.9	12.7	2,014.6	-0.5	1.4	1	1	1
09/01/2021 07:00	0.3	13.9	1,688.3	0.4	1.2	1	1	0
09/01/2021 08:00	0.2	13.9	1,627.2	0.3	1.1	1	1	0
09/01/2021 09:00	-1.1	13.2	1,903.9	-0.7	1.3	1	1	1
09/01/2021 10:00	-1.2	12.8	2,008.3	-0.7	1.4	1	1	1
09/01/2021 11:00	-0.8	13.7	1,502.1	-0.5	1.1	1	1	1
09/01/2021 12:00	-0.4	13.9	1,567.5	-0.2	1.1	1	1	1
09/01/2021 13:00	-1.7	12.6	2,028.4	-0.9	1.4	1	1	1
09/01/2021 14:00	-1.5	12.6	2,015.2	-0.9	1.4	1	1	1
09/01/2021 15:00	-0.5	13.6	1,702.8	-0.2	1.2	1	1	1
09/01/2021 16:00	-0.4	13.8	1,707.8	-0.2	1.2	1	1	1
09/01/2021 17:00	-1.7	12.4	2,082.1	-0.9	1.5	1	1	1
09/01/2021 18:00	-1.5	12.1	2,135.8	-0.8	1.5	1	1	1
09/01/2021 19:00	-1.4	12.1	2,131.5	-0.7	1.5	1	1	1
09/01/2021 20:00	0.1	13.9	1,700.1	0.2	1.2	1	1	0
09/01/2021 21:00	-0.2	14.0	1,393.2	-0.1	1.0	1	1	0
09/01/2021 22:00	0.1	13.9	1,652.8	0.2	1.2	1	1	0
09/01/2021 23:00	0.2	13.9	1,715.5	0.3	1.2	1	1	0
Average/Sum#:	-0.7	13.2	1,838.6	-0.3	1.3	24 #	24 #	17 #
Minimum:	-1.7	12.1	1,393.2	-0.9	1.0	1	1	0
Maximum:	0.3	14.0	2,137.0	0.4	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/02/2021 00:00	-0.8	13.3	1,857.1	-0.5	1.3	1	1	1
09/02/2021 01:00	-0.8	13.1	1,876.2	-0.5	1.3	1	1	1
09/02/2021 02:00	-0.2	14.0	1,370.3	-0.1	1.0	1	1	0
09/02/2021 03:00	0.1	13.9	1,683.9	0.2	1.2	1	1	0
09/02/2021 04:00	-0.1	14.0	1,400.5	0.0	1.0	1	1	0
09/02/2021 05:00	0.1	13.9	1,663.2	0.2	1.2	1	1	0
09/02/2021 06:00	-0.7	13.5	1,825.7	-0.4	1.3	1	1	1
09/02/2021 07:00	-1.1	13.4	1,846.9	-0.7	1.3	1	1	1
09/02/2021 08:00	0.0	14.0	1,369.4	0.1	1.0	1	1	0
09/02/2021 09:00	0.1	14.0	1,457.6	0.1	1.0	1	1	0
09/02/2021 10:00	0.1	14.0	1,514.8	0.2	1.1	1	1	0
09/02/2021 11:00	0.0	14.0	1,439.1	0.1	1.0	1	1	0
09/02/2021 12:00	-0.2	13.9	1,706.5	-0.1	1.2	1	1	1
09/02/2021 13:00	-1.7	12.6	2,063.2	-0.9	1.4	1	1	1
09/02/2021 14:00	-1.4	12.6	2,016.1	-0.8	1.4	1	1	1
09/02/2021 15:00	0.1	13.9	1,683.5	0.2	1.2	1	1	0
09/02/2021 16:00	-0.4	13.9	1,647.4	-0.2	1.2	1	1	1
09/02/2021 17:00	-1.7	12.4	2,091.0	-0.9	1.5	1	1	1
09/02/2021 18:00	-1.5	12.2	2,123.3	-0.8	1.5	1	1	1
09/02/2021 19:00	-1.5	12.3	2,091.3	-0.8	1.5	1	1	1
09/02/2021 20:00	0.1	13.9	1,588.0	0.1	1.1	1	1	0
09/02/2021 21:00	0.1	14.0	1,400.2	0.1	1.0	1	1	0
09/02/2021 22:00	0.1	14.0	1,624.0	0.2	1.1	1	1	0
09/02/2021 23:00	-1.1	13.4	1,853.7	-0.7	1.3	1	1	1
Average/Sum#:	-0.5	13.5	1,716.4	-0.2	1.2	24 #	24 #	12 #
Minimum:	-1.7	12.2	1,369.4	-0.9	1.0	1	1	0
Maximum:	0.1	14.0	2,123.3	0.2	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/03/2021 00:00	-1.4	13.0	1,910.7	-0.8	1.3	1	1	1
09/03/2021 01:00	0.0	13.8	1,617.8	0.1	1.1	1	1	0
09/03/2021 02:00	-0.2	13.7	1,793.5	-0.1	1.3	1	1	1
09/03/2021 03:00	-1.5	13.1	1,925.9	-0.9	1.3	1	1	1
09/03/2021 04:00	0.1	13.9	1,590.6	0.2	1.1	1	1	0
09/03/2021 05:00	-0.2	13.7	1,755.9	-0.1	1.2	1	1	1
09/03/2021 06:00	-1.2	12.7	2,045.0	-0.7	1.4	1	1	1
09/03/2021 07:00	-0.9	12.9	1,969.9	-0.5	1.4	1	1	1
09/03/2021 08:00	0.2	13.9	1,715.3	0.3	1.2	1	1	0
09/03/2021 09:00	0.2	14.0	1,526.3	0.3	1.1	1	1	0
09/03/2021 10:00	0.2	14.0	1,614.6	0.3	1.1	1	1	0
09/03/2021 11:00	-0.3	14.0	1,620.6	-0.2	1.1	1	1	0
09/03/2021 12:00	0.2	14.0	1,628.9	0.3	1.1	1	1	0
09/03/2021 13:00	0.2	14.0	1,643.2	0.3	1.2	1	1	0
09/03/2021 14:00	-0.2	14.0	1,562.2	-0.1	1.1	1	1	1
09/03/2021 15:00	-1.7	12.3	2,094.4	-0.9	1.5	1	1	1
09/03/2021 16:00	-1.4	12.0	2,163.6	-0.7	1.5	1	1	1
09/03/2021 17:00	-1.2	11.7	2,230.1	-0.5	1.6	1	1	1
09/03/2021 18:00	-1.2	11.7	2,225.2	-0.5	1.6	1	1	1
09/03/2021 19:00	-1.2	12.0	2,132.1	-0.7	1.5	1	1	1
09/03/2021 20:00	0.1	13.9	1,709.0	0.2	1.2	1	1	0
09/03/2021 21:00	-0.4	13.7	1,806.1	-0.2	1.3	1	1	1
09/03/2021 22:00	-1.7	12.7	2,041.0	-1.1	1.4	1	1	1
09/03/2021 23:00	-1.5	12.9	1,978.4	-0.9	1.4	1	1	1
Average/Sum#:	-0.6	13.2	1,845.8	-0.3	1.3	24 #	24 #	15 #
Minimum:	-1.7	11.7	1,526.3	-1.1	1.1	1	1	0
Maximum:	0.2	14.0	2,230.1	0.3	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/04/2021 00:00	0.1	13.9	1,650.1	0.1	1.2	1	1	0
09/04/2021 01:00	-0.5	13.8	1,674.7	-0.4	1.2	1	1	1
09/04/2021 02:00	-1.8	12.7	2,039.5	-1.1	1.4	1	1	1
09/04/2021 03:00	0.0	14.0	1,289.6	0.0	0.9	1	0	1
09/04/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2021 09:00	0.0	18.5	252.8	0.0	0.2	1	0	0
09/04/2021 10:00	0.0	15.6	860.7	0.0	0.6	1	0	0
09/04/2021 11:00	0.2	14.1	1,392.6	0.3	1.0	1	1	0
09/04/2021 12:00	0.2	14.1	1,380.3	0.3	1.0	1	1	0
09/04/2021 13:00	0.2	13.9	1,672.0	0.3	1.2	1	1	0
09/04/2021 14:00	0.1	14.0	1,458.3	0.1	1.0	1	1	0
09/04/2021 15:00	0.1	13.9	1,725.1	0.2	1.2	1	1	0
09/04/2021 16:00	-0.4	13.9	1,622.1	-0.2	1.1	1	1	1
09/04/2021 17:00	-1.7	12.1	2,143.0	-0.9	1.5	1	1	1
09/04/2021 18:00	-1.2	11.5	2,257.2	-0.5	1.6	1	1	1
09/04/2021 19:00	-1.1	11.5	2,278.9	-0.5	1.6	1	1	1
09/04/2021 20:00	-1.2	11.8	2,210.2	-0.5	1.5	1	1	1
09/04/2021 21:00	-1.4	12.1	2,164.2	-0.7	1.5	1	1	1
09/04/2021 22:00	-1.5	12.3	2,115.0	-0.8	1.5	1	1	1
09/04/2021 23:00	-1.5	12.4	2,102.2	-0.8	1.5	1	1	1
Average/Sum#:	-0.6	13.5	1,699.4	-0.3	1.2	19 #	16 #	11 #
Minimum:	-1.8	11.5	252.8	-1.1	0.2	0	0	0
Maximum:	0.2	18.5	2,278.9	0.3	1.6	1	1	1
%SI	20.83	20.83	20.83	20.83	20.83	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/05/2021 00:00	-1.4	12.8	1,980.3	-0.8	1.4	1	1	1
09/05/2021 01:00	0.1	13.9	1,662.6	0.1	1.2	1	1	0
09/05/2021 02:00	-0.4	13.9	1,674.5	-0.2	1.2	1	1	1
09/05/2021 03:00	-1.7	12.7	2,044.6	-1.1	1.4	1	1	1
09/05/2021 04:00	-1.5	13.0	1,964.0	-0.9	1.4	1	1	1
09/05/2021 05:00	0.1	13.9	1,654.9	0.1	1.2	1	1	0
09/05/2021 06:00	0.1	13.9	1,643.1	0.1	1.2	1	1	0
09/05/2021 07:00	0.1	13.9	1,615.9	0.1	1.1	1	1	0
09/05/2021 08:00	0.1	13.9	1,646.7	0.1	1.2	1	1	0
09/05/2021 09:00	0.1	13.9	1,636.0	0.1	1.1	1	1	0
09/05/2021 10:00	0.1	13.9	1,704.5	0.2	1.2	1	1	0
09/05/2021 11:00	0.1	13.9	1,730.3	0.2	1.2	1	1	0
09/05/2021 12:00	0.1	13.9	1,717.8	0.2	1.2	1	1	0
09/05/2021 13:00	0.1	13.9	1,734.3	0.2	1.2	1	1	0
09/05/2021 14:00	-1.5	12.5	2,046.7	-0.9	1.4	1	1	1
09/05/2021 15:00	-1.2	11.9	2,203.4	-0.7	1.5	1	1	1
09/05/2021 16:00	-1.1	11.7	2,225.0	-0.5	1.6	1	1	1
09/05/2021 17:00	-0.9	11.5	2,263.7	-0.4	1.6	1	1	1
09/05/2021 18:00	-1.1	11.6	2,250.1	-0.5	1.6	1	1	1
09/05/2021 19:00	-0.9	11.5	2,281.4	-0.4	1.6	1	1	1
09/05/2021 20:00	-1.2	11.8	2,210.7	-0.5	1.5	1	1	1
09/05/2021 21:00	-1.4	12.1	2,164.2	-0.7	1.5	1	1	1
09/05/2021 22:00	-1.4	12.2	2,142.8	-0.7	1.5	1	1	1
09/05/2021 23:00	-1.4	12.5	2,050.0	-0.8	1.4	1	1	1
Average/Sum#:	-0.7	12.9	1,927.0	-0.3	1.4	24 #	24 #	14 #
Minimum:	-1.7	11.5	1,615.9	-1.1	1.1	1	1	0
Maximum:	0.1	13.9	2,281.4	0.2	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/06/2021 00:00	0.1	13.9	1,652.7	0.1	1.2	1	1	0
09/06/2021 01:00	-0.4	13.9	1,625.0	-0.2	1.1	1	1	1
09/06/2021 02:00	-1.1	12.8	1,957.6	-0.7	1.4	1	1	1
09/06/2021 03:00	-0.8	12.8	1,935.8	-0.4	1.4	1	1	1
09/06/2021 04:00	0.2	14.0	1,604.9	0.3	1.1	1	1	0
09/06/2021 05:00	0.1	13.9	1,680.6	0.1	1.2	1	1	0
09/06/2021 06:00	0.1	13.9	1,635.7	0.1	1.1	1	1	0
09/06/2021 07:00	0.1	14.0	1,635.3	0.2	1.1	1	1	0
09/06/2021 08:00	0.2	14.0	1,706.4	0.3	1.2	1	1	0
09/06/2021 09:00	0.2	14.0	1,567.3	0.3	1.1	1	1	0
09/06/2021 10:00	0.3	13.9	1,706.1	0.4	1.2	1	1	0
09/06/2021 11:00	-0.1	13.9	1,699.3	0.1	1.2	1	1	1
09/06/2021 12:00	-1.7	12.2	2,137.3	-0.9	1.5	1	1	1
09/06/2021 13:00	-1.2	11.7	2,221.8	-0.5	1.6	1	1	1
09/06/2021 14:00	-1.1	11.7	2,213.1	-0.5	1.5	1	1	1
09/06/2021 15:00	-1.1	11.6	2,219.5	-0.5	1.6	1	1	1
09/06/2021 16:00	-0.9	11.6	2,226.8	-0.4	1.6	1	1	1
09/06/2021 17:00	-0.9	11.5	2,239.8	-0.4	1.6	1	1	1
09/06/2021 18:00	-0.9	11.4	2,242.5	-0.4	1.6	1	1	1
09/06/2021 19:00	-0.9	11.5	2,252.5	-0.4	1.6	1	1	1
09/06/2021 20:00	-0.9	11.5	2,261.6	-0.4	1.6	1	1	1
09/06/2021 21:00	-0.9	11.6	2,238.3	-0.4	1.6	1	1	1
09/06/2021 22:00	-1.2	11.9	2,174.2	-0.7	1.5	1	1	1
09/06/2021 23:00	-1.4	12.4	2,074.3	-0.8	1.5	1	1	1
Average/Sum#:	-0.6	12.7	1,954.5	-0.2	1.4	24 #	24 #	16 #
Minimum:	-1.7	11.4	1,567.3	-0.9	1.1	1	1	0
Maximum:	0.3	14.0	2,261.6	0.4	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/07/2021 00:00	0.1	13.9	1,717.1	0.2	1.2	1	1	0
09/07/2021 01:00	-0.2	13.8	1,693.8	-0.1	1.2	1	1	1
09/07/2021 02:00	-1.2	12.8	2,023.7	-0.7	1.4	1	1	1
09/07/2021 03:00	-1.1	13.0	1,958.1	-0.7	1.4	1	1	1
09/07/2021 04:00	0.1	13.9	1,720.2	0.1	1.2	1	1	0
09/07/2021 05:00	-0.5	13.7	1,806.0	-0.4	1.3	1	1	1
09/07/2021 06:00	-1.7	12.7	2,046.2	-1.1	1.4	1	1	1
09/07/2021 07:00	-1.4	12.7	2,011.4	-0.8	1.4	1	1	1
09/07/2021 08:00	0.1	13.9	1,708.1	0.2	1.2	1	1	0
09/07/2021 09:00	0.1	13.8	1,750.7	0.2	1.2	1	1	0
09/07/2021 10:00	-1.5	12.6	2,039.3	-0.9	1.4	1	1	1
09/07/2021 11:00	-1.1	11.7	2,224.5	-0.5	1.6	1	1	1
09/07/2021 12:00	-1.1	11.7	2,207.4	-0.5	1.5	1	1	1
09/07/2021 13:00	-1.1	11.8	2,182.0	-0.5	1.5	1	1	1
09/07/2021 14:00	-1.1	11.8	2,170.1	-0.5	1.5	1	1	1
09/07/2021 15:00	-0.9	11.7	2,180.3	-0.4	1.5	1	1	1
09/07/2021 16:00	-0.9	11.6	2,201.9	-0.4	1.5	1	1	1
09/07/2021 17:00	-0.9	11.7	2,194.2	-0.4	1.5	1	1	1
09/07/2021 18:00	-1.1	12.0	2,154.8	-0.5	1.5	1	1	1
09/07/2021 19:00	-1.2	12.1	2,140.7	-0.7	1.5	1	1	1
09/07/2021 20:00	-1.4	12.1	2,150.4	-0.7	1.5	1	1	1
09/07/2021 21:00	-1.1	11.7	2,252.7	-0.5	1.6	1	1	1
09/07/2021 22:00	-0.9	11.4	2,283.7	-0.4	1.6	1	1	1
09/07/2021 23:00	-0.9	11.5	2,284.5	-0.4	1.6	1	1	1
Average/Sum#:	-0.9	12.5	2,045.9	-0.4	1.4	24 #	24 #	20 #
Minimum:	-1.7	11.4	1,693.8	-1.1	1.2	1	1	0
Maximum:	0.1	13.9	2,284.5	0.2	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/08/2021 00:00	-0.9	11.6	2,263.8	-0.4	1.6	1	1	1
09/08/2021 01:00	-1.1	11.9	2,186.0	-0.5	1.5	1	1	1
09/08/2021 02:00	-1.4	12.2	2,133.6	-0.7	1.5	1	1	1
09/08/2021 03:00	-1.4	12.2	2,144.7	-0.7	1.5	1	1	1
09/08/2021 04:00	-1.1	11.7	2,254.9	-0.5	1.6	1	1	1
09/08/2021 05:00	-1.1	11.6	2,279.4	-0.5	1.6	1	1	1
09/08/2021 06:00	-1.1	11.7	2,238.7	-0.5	1.6	1	1	1
09/08/2021 07:00	-1.4	12.5	2,044.9	-0.8	1.4	1	1	1
09/08/2021 08:00	0.1	13.9	1,716.5	0.2	1.2	1	1	0
09/08/2021 09:00	-0.2	13.8	1,728.7	-0.1	1.2	1	1	1
09/08/2021 10:00	-1.5	12.4	2,089.6	-0.8	1.5	1	1	1
09/08/2021 11:00	-1.2	11.7	2,191.9	-0.5	1.5	1	1	1
09/08/2021 12:00	-1.2	11.8	2,166.9	-0.5	1.5	1	1	1
09/08/2021 13:00	-1.1	11.7	2,166.2	-0.5	1.5	1	1	1
09/08/2021 14:00	-1.1	11.6	2,167.2	-0.5	1.5	1	1	1
09/08/2021 15:00	-0.9	11.6	2,165.3	-0.4	1.5	1	1	1
09/08/2021 16:00	-0.9	11.5	2,186.0	-0.4	1.5	1	1	1
09/08/2021 17:00	-0.9	11.4	2,203.1	-0.4	1.5	1	1	1
09/08/2021 18:00	-0.9	11.5	2,204.6	-0.4	1.5	1	1	1
09/08/2021 19:00	-0.9	11.5	2,220.7	-0.4	1.6	1	1	1
09/08/2021 20:00	-0.9	11.6	2,210.2	-0.4	1.5	1	1	1
09/08/2021 21:00	-1.1	11.8	2,171.2	-0.5	1.5	1	1	1
09/08/2021 22:00	-1.2	11.9	2,146.3	-0.7	1.5	1	1	1
09/08/2021 23:00	-1.1	11.6	2,213.3	-0.5	1.5	1	1	1
Average/Sum#:	-1.0	11.9	2,145.6	-0.5	1.5	24 #	24 #	23 #
Minimum:	-1.5	11.4	1,716.5	-0.8	1.2	1	1	0
Maximum:	0.1	13.9	2,279.4	0.2	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/09/2021 00:00	-0.9	11.5	2,226.4	-0.4	1.6	1	1	1
09/09/2021 01:00	-0.9	11.5	2,235.7	-0.4	1.6	1	1	1
09/09/2021 02:00	-0.9	11.6	2,241.1	-0.4	1.6	1	1	1
09/09/2021 03:00	-0.9	11.6	2,238.9	-0.4	1.6	1	1	1
09/09/2021 04:00	-0.9	11.5	2,242.2	-0.4	1.6	1	1	1
09/09/2021 05:00	-0.9	11.5	2,245.9	-0.4	1.6	1	1	1
09/09/2021 06:00	-0.9	11.6	2,235.2	-0.4	1.6	1	1	1
09/09/2021 07:00	-1.1	11.8	2,188.7	-0.5	1.5	1	1	1
09/09/2021 08:00	-1.1	11.8	2,180.0	-0.5	1.5	1	1	1
09/09/2021 09:00	-1.1	11.7	2,181.9	-0.5	1.5	1	1	1
09/09/2021 10:00	-1.1	11.7	2,180.9	-0.5	1.5	1	1	1
09/09/2021 11:00	-1.1	11.7	2,165.1	-0.5	1.5	1	1	1
09/09/2021 12:00	-0.9	11.8	2,145.6	-0.4	1.5	1	1	1
09/09/2021 13:00	-0.9	11.6	2,155.1	-0.4	1.5	1	1	1
09/09/2021 14:00	-0.9	11.7	2,142.4	-0.4	1.5	1	1	1
09/09/2021 15:00	-1.1	11.7	2,137.4	-0.5	1.5	1	1	1
09/09/2021 16:00	-0.9	11.6	2,152.0	-0.4	1.5	1	1	1
09/09/2021 17:00	-0.9	11.6	2,162.8	-0.4	1.5	1	1	1
09/09/2021 18:00	-0.9	11.4	2,199.0	-0.4	1.5	1	1	1
09/09/2021 19:00	-0.9	11.4	2,204.7	-0.4	1.5	1	1	1
09/09/2021 20:00	-0.9	11.5	2,219.3	-0.4	1.6	1	1	1
09/09/2021 21:00	-0.9	11.5	2,220.9	-0.4	1.6	1	1	1
09/09/2021 22:00	-0.9	11.6	2,192.1	-0.4	1.5	1	1	1
09/09/2021 23:00	-1.1	11.6	2,206.7	-0.5	1.5	1	1	1
Average/Sum#:	-1.0	11.6	2,195.8	-0.4	1.5	24 #	24 #	24 #
Minimum:	-1.1	11.4	2,137.4	-0.5	1.5	1	1	1
Maximum:	-0.9	11.8	2,245.9	-0.4	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/10/2021 00:00	-1.1	11.9	2,121.5	-0.5	1.5	1	1	1
09/10/2021 01:00	0.1	13.9	1,595.7	0.2	1.1	1	1	0
09/10/2021 02:00	-0.2	13.7	1,762.7	-0.1	1.2	1	1	1
09/10/2021 03:00	-1.5	12.4	2,082.3	-0.8	1.5	1	1	1
09/10/2021 04:00	-1.1	11.8	2,203.4	-0.5	1.5	1	1	1
09/10/2021 05:00	-1.1	11.9	2,162.2	-0.5	1.5	1	1	1
09/10/2021 06:00	-0.9	11.8	2,217.1	-0.4	1.6	1	1	1
09/10/2021 07:00	-0.5	13.5	1,658.1	-0.2	1.2	1	1	1
09/10/2021 08:00	0.1	13.9	1,527.7	0.2	1.1	1	1	0
09/10/2021 09:00	0.3	13.9	1,649.6	0.4	1.2	1	1	0
09/10/2021 10:00	-0.1	13.8	1,627.3	0.1	1.1	1	1	1
09/10/2021 11:00	-1.5	12.4	2,066.7	-0.8	1.4	1	1	1
09/10/2021 12:00	-1.4	12.3	2,038.6	-0.8	1.4	1	1	1
09/10/2021 13:00	0.2	13.9	1,607.4	0.3	1.1	1	1	0
09/10/2021 14:00	-0.1	13.8	1,726.8	0.1	1.2	1	1	1
09/10/2021 15:00	-1.5	12.2	2,089.8	-0.8	1.5	1	1	1
09/10/2021 16:00	-1.2	11.9	2,151.3	-0.7	1.5	1	1	1
09/10/2021 17:00	-1.1	11.6	2,212.6	-0.5	1.5	1	1	1
09/10/2021 18:00	-0.9	11.5	2,232.2	-0.4	1.6	1	1	1
09/10/2021 19:00	-0.9	11.5	2,232.9	-0.4	1.6	1	1	1
09/10/2021 20:00	-1.1	11.6	2,229.3	-0.5	1.6	1	1	1
09/10/2021 21:00	-1.1	11.6	2,229.1	-0.5	1.6	1	1	1
09/10/2021 22:00	-1.2	11.9	2,159.0	-0.7	1.5	1	1	1
09/10/2021 23:00	-1.4	12.3	2,087.1	-0.8	1.5	1	1	1
Average/Sum#:	-0.8	12.5	1,986.3	-0.4	1.4	24 #	24 #	20 #
Minimum:	-1.5	11.5	1,527.7	-0.8	1.1	1	1	0
Maximum:	0.3	13.9	2,232.9	0.4	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/11/2021 00:00	-1.4	12.8	1,952.2	-0.8	1.4	1	1	1
09/11/2021 01:00	0.1	13.9	1,709.2	0.2	1.2	1	1	0
09/11/2021 02:00	0.1	13.9	1,694.1	0.2	1.2	1	1	0
09/11/2021 03:00	-0.7	13.8	1,583.2	-0.4	1.1	1	1	1
09/11/2021 04:00	-1.8	12.6	2,039.4	-1.1	1.4	1	1	1
09/11/2021 05:00	-1.4	13.0	1,962.4	-0.8	1.4	1	1	1
09/11/2021 06:00	0.1	13.9	1,672.1	0.2	1.2	1	1	0
09/11/2021 07:00	0.1	13.8	1,644.5	0.1	1.2	1	1	0
09/11/2021 08:00	0.1	13.9	1,525.9	0.2	1.1	1	1	0
09/11/2021 09:00	0.2	13.9	1,608.1	0.3	1.1	1	1	0
09/11/2021 10:00	0.3	13.9	1,703.1	0.4	1.2	1	1	0
09/11/2021 11:00	-0.2	13.8	1,688.8	-0.1	1.2	1	1	1
09/11/2021 12:00	-1.5	12.2	2,095.8	-0.8	1.5	1	1	1
09/11/2021 13:00	-1.4	12.1	2,076.8	-0.7	1.5	1	1	1
09/11/2021 14:00	0.2	13.9	1,695.9	0.3	1.2	1	1	0
09/11/2021 15:00	-0.1	13.7	1,735.3	0.1	1.2	1	1	1
09/11/2021 16:00	-1.4	12.3	2,087.0	-0.8	1.5	1	1	1
09/11/2021 17:00	-0.9	11.4	2,270.9	-0.4	1.6	1	1	1
09/11/2021 18:00	-0.9	11.5	2,236.7	-0.4	1.6	1	1	1
09/11/2021 19:00	-1.1	11.9	2,176.8	-0.5	1.5	1	1	1
09/11/2021 20:00	-1.1	11.7	2,220.5	-0.5	1.6	1	1	1
09/11/2021 21:00	-0.9	11.6	2,242.3	-0.4	1.6	1	1	1
09/11/2021 22:00	-1.1	11.9	2,189.2	-0.5	1.5	1	1	1
09/11/2021 23:00	-1.1	11.8	2,202.1	-0.5	1.5	1	1	1
Average/Sum#:	-0.7	12.9	1,917.2	-0.3	1.4	24 #	24 #	16 #
Minimum:	-1.8	11.4	1,525.9	-1.1	1.1	1	1	0
Maximum:	0.3	13.9	2,270.9	0.4	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/12/2021 00:00	-1.4	12.4	2,055.2	-0.8	1.4	1	1	1
09/12/2021 01:00	0.2	13.9	1,710.0	0.3	1.2	1	1	0
09/12/2021 02:00	0.3	14.0	1,667.0	0.4	1.2	1	1	0
09/12/2021 03:00	-0.9	13.7	1,666.4	-0.7	1.2	1	1	1
09/12/2021 04:00	-1.8	12.7	2,028.8	-1.1	1.4	1	1	1
09/12/2021 05:00	-1.5	13.0	1,969.1	-0.9	1.4	1	1	1
09/12/2021 06:00	-0.7	13.8	1,557.1	-0.4	1.1	1	1	1
09/12/2021 07:00	0.1	13.9	1,601.5	0.2	1.1	1	1	0
09/12/2021 08:00	0.1	14.0	1,367.1	0.2	1.0	1	1	0
09/12/2021 09:00	0.2	14.0	1,298.1	0.3	0.9	1	1	0
09/12/2021 10:00	0.3	13.9	1,676.8	0.4	1.2	1	1	0
09/12/2021 11:00	-0.2	13.8	1,746.7	-0.1	1.2	1	1	1
09/12/2021 12:00	-1.7	12.3	2,083.6	-0.9	1.5	1	1	1
09/12/2021 13:00	-1.2	11.9	2,115.0	-0.7	1.5	1	1	1
09/12/2021 14:00	0.2	13.9	1,670.3	0.3	1.2	1	1	0
09/12/2021 15:00	-0.4	13.8	1,657.2	-0.2	1.2	1	1	1
09/12/2021 16:00	-1.5	12.1	2,116.2	-0.8	1.5	1	1	1
09/12/2021 17:00	-1.1	11.4	2,257.9	-0.4	1.6	1	1	1
09/12/2021 18:00	-1.1	11.6	2,220.7	-0.5	1.6	1	1	1
09/12/2021 19:00	-1.2	11.8	2,183.1	-0.5	1.5	1	1	1
09/12/2021 20:00	-1.4	12.0	2,151.7	-0.7	1.5	1	1	1
09/12/2021 21:00	-1.4	12.1	2,128.6	-0.7	1.5	1	1	1
09/12/2021 22:00	-1.4	12.2	2,114.7	-0.7	1.5	1	1	1
09/12/2021 23:00	-1.4	12.3	2,107.9	-0.8	1.5	1	1	1
Average/Sum#:	-0.8	12.9	1,881.3	-0.4	1.3	24 #	24 #	17 #
Minimum:	-1.8	11.4	1,298.1	-1.1	0.9	1	1	0
Maximum:	0.3	14.0	2,257.9	0.4	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/13/2021 00:00	-1.4	12.8	1,967.5	-0.8	1.4	1	1	1
09/13/2021 01:00	0.1	13.9	1,606.9	0.2	1.1	1	1	0
09/13/2021 02:00	0.1	13.9	1,592.6	0.1	1.1	1	1	0
09/13/2021 03:00	0.1	13.9	1,667.3	0.2	1.2	1	1	0
09/13/2021 04:00	0.1	14.0	1,347.6	0.1	0.9	1	1	0
09/13/2021 05:00	0.2	14.0	1,695.4	0.3	1.2	1	1	0
09/13/2021 06:00	-0.9	13.4	1,826.7	-0.7	1.3	1	1	1
09/13/2021 07:00	-1.4	13.0	1,875.7	-0.8	1.3	1	1	1
09/13/2021 08:00	0.1	13.9	1,544.6	0.1	1.1	1	1	0
09/13/2021 09:00	-1.7	12.7	1,991.2	-1.1	1.4	1	1	1
09/13/2021 10:00	-1.5	12.6	1,997.8	-0.9	1.4	1	1	1
09/13/2021 11:00	0.1	13.9	1,724.6	0.2	1.2	1	1	0
09/13/2021 12:00	0.1	13.8	1,697.5	0.2	1.2	1	1	0
09/13/2021 13:00	-1.7	12.4	2,062.3	-0.9	1.4	1	1	1
09/13/2021 14:00	-1.1	11.5	2,232.7	-0.5	1.6	1	1	1
09/13/2021 15:00	-0.9	11.6	2,216.2	-0.4	1.6	1	1	1
09/13/2021 16:00	-0.9	11.5	2,210.5	-0.4	1.5	1	1	1
09/13/2021 17:00	-0.9	11.4	2,243.4	-0.4	1.6	1	1	1
09/13/2021 18:00	-0.9	11.4	2,248.1	-0.4	1.6	1	1	1
09/13/2021 19:00	-0.9	11.4	2,243.6	-0.4	1.6	1	1	1
09/13/2021 20:00	-1.1	11.6	2,222.3	-0.5	1.6	1	1	1
09/13/2021 21:00	-1.2	11.9	2,166.7	-0.7	1.5	1	1	1
09/13/2021 22:00	-1.4	12.2	2,106.5	-0.7	1.5	1	1	1
09/13/2021 23:00	-1.4	12.7	1,990.8	-0.8	1.4	1	1	1
Average/Sum#:	-0.8	12.7	1,936.6	-0.4	1.4	24 #	24 #	16 #
Minimum:	-1.7	11.4	1,347.6	-1.1	0.9	1	1	0
Maximum:	0.2	14.0	2,248.1	0.3	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/14/2021 00:00	-1.4	12.8	1,965.4	-0.8	1.4	1	1	1
09/14/2021 01:00	0.1	13.9	1,588.9	0.1	1.1	1	1	0
09/14/2021 02:00	0.1	13.9	1,566.1	0.1	1.1	1	1	0
09/14/2021 03:00	0.1	13.9	1,565.7	0.1	1.1	1	1	0
09/14/2021 04:00	-0.1	13.9	1,509.7	0.0	1.1	1	1	0
09/14/2021 05:00	-1.7	12.5	2,022.2	-0.9	1.4	1	1	1
09/14/2021 06:00	-1.5	12.6	2,022.1	-0.9	1.4	1	1	1
09/14/2021 07:00	-0.2	13.9	1,665.4	0.0	1.2	1	1	0
09/14/2021 08:00	0.0	13.9	1,523.2	0.1	1.1	1	1	0
09/14/2021 09:00	0.0	13.9	1,489.7	0.1	1.0	1	1	0
09/14/2021 10:00	0.1	13.9	1,664.4	0.2	1.2	1	1	0
09/14/2021 11:00	0.1	13.9	1,712.1	0.2	1.2	1	1	0
09/14/2021 12:00	-0.2	13.9	1,557.2	-0.1	1.1	1	1	1
09/14/2021 13:00	-1.7	12.5	2,045.9	-0.9	1.4	1	1	1
09/14/2021 14:00	-1.4	12.0	2,114.7	-0.7	1.5	1	1	1
09/14/2021 15:00	0.1	13.8	1,698.1	0.2	1.2	1	1	0
09/14/2021 16:00	-0.2	13.8	1,625.0	-0.1	1.1	1	1	1
09/14/2021 17:00	-1.7	12.1	2,108.7	-0.9	1.5	1	1	1
09/14/2021 18:00	-1.2	11.5	2,212.1	-0.5	1.5	1	1	1
09/14/2021 19:00	-1.4	12.2	2,057.0	-0.7	1.4	1	1	1
09/14/2021 20:00	0.1	13.8	1,711.4	0.2	1.2	1	1	0
09/14/2021 21:00	-0.2	13.7	1,772.0	-0.1	1.2	1	1	1
09/14/2021 22:00	-1.8	12.5	2,062.5	-1.1	1.4	1	1	1
09/14/2021 23:00	-1.5	12.7	1,979.7	-0.9	1.4	1	1	1
Average/Sum#:	-0.6	13.2	1,801.6	-0.3	1.3	24 #	24 #	13 #
Minimum:	-1.8	11.5	1,489.7	-1.1	1.0	1	1	0
Maximum:	0.1	13.9	2,212.1	0.2	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/15/2021 00:00	0.1	13.9	1,558.6	0.1	1.1	1	1	0
09/15/2021 01:00	-0.5	13.8	1,587.9	-0.4	1.1	1	1	1
09/15/2021 02:00	-1.8	12.6	2,035.2	-1.1	1.4	1	1	1
09/15/2021 03:00	-1.5	12.8	1,989.8	-0.9	1.4	1	1	1
09/15/2021 04:00	-0.5	13.8	1,697.9	-0.4	1.2	1	1	1
09/15/2021 05:00	-0.4	13.7	1,608.1	-0.2	1.1	1	1	1
09/15/2021 06:00	-2.1	12.8	2,006.8	-1.4	1.4	1	1	1
09/15/2021 07:00	-1.5	12.9	1,957.5	-0.9	1.4	1	1	1
09/15/2021 08:00	0.0	13.9	1,483.0	0.1	1.0	1	1	0
09/15/2021 09:00	0.1	14.0	1,420.2	0.2	1.0	1	1	0
09/15/2021 10:00	0.2	14.0	1,552.3	0.3	1.1	1	1	0
09/15/2021 11:00	0.1	13.9	1,619.9	0.2	1.1	1	1	0
09/15/2021 12:00	-0.4	13.9	1,547.8	-0.2	1.1	1	1	1
09/15/2021 13:00	-1.7	12.3	2,080.9	-0.9	1.5	1	1	1
09/15/2021 14:00	-1.5	12.1	2,096.8	-0.8	1.5	1	1	1
09/15/2021 15:00	-0.4	13.8	1,576.0	-0.2	1.1	1	1	1
09/15/2021 16:00	-0.7	13.8	1,587.1	-0.4	1.1	1	1	1
09/15/2021 17:00	-1.5	12.2	2,081.4	-0.8	1.5	1	1	1
09/15/2021 18:00	-1.4	12.1	2,092.8	-0.7	1.5	1	1	1
09/15/2021 19:00	-1.4	12.6	1,995.0	-0.8	1.4	1	1	1
09/15/2021 20:00	-0.5	13.6	1,706.4	-0.2	1.2	1	1	1
09/15/2021 21:00	-0.4	13.9	1,628.6	-0.2	1.1	1	1	1
09/15/2021 22:00	-1.7	12.9	1,959.9	-1.1	1.4	1	1	1
09/15/2021 23:00	-1.5	13.0	1,951.9	-0.9	1.4	1	1	1
Average/Sum#:	-0.9	13.3	1,784.2	-0.5	1.3	24 #	24 #	19 #
Minimum:	-2.1	12.1	1,420.2	-1.4	1.0	1	1	0
Maximum:	0.2	14.0	2,096.8	0.3	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/16/2021 00:00	-0.9	13.5	1,720.7	-0.7	1.2	1	1	1
09/16/2021 01:00	0.0	13.9	1,542.6	0.1	1.1	1	1	0
09/16/2021 02:00	0.1	13.8	1,778.0	0.2	1.2	1	1	0
09/16/2021 03:00	0.1	13.8	1,780.3	0.2	1.2	1	1	0
09/16/2021 04:00	0.0	14.0	1,407.5	0.1	1.0	1	1	0
09/16/2021 05:00	-0.1	14.0	1,331.1	0.0	0.9	1	1	0
09/16/2021 06:00	0.0	13.9	1,385.8	0.1	1.0	1	1	0
09/16/2021 07:00	-0.1	13.9	1,359.7	0.0	1.0	1	1	0
09/16/2021 08:00	0.0	13.9	1,364.4	0.1	1.0	1	1	0
09/16/2021 09:00	0.1	13.9	1,368.0	0.1	1.0	1	1	0
09/16/2021 10:00	0.1	14.0	1,375.5	0.2	1.0	1	1	0
09/16/2021 11:00	0.1	14.0	1,376.0	0.2	1.0	1	1	0
09/16/2021 12:00	0.1	13.9	1,607.3	0.2	1.1	1	1	0
09/16/2021 13:00	0.1	13.9	1,543.6	0.1	1.1	1	1	0
09/16/2021 14:00	0.1	13.9	1,709.6	0.2	1.2	1	1	0
09/16/2021 15:00	0.1	13.9	1,651.1	0.2	1.2	1	1	0
09/16/2021 16:00	-0.5	13.9	1,547.5	-0.4	1.1	1	1	1
09/16/2021 17:00	-1.7	12.1	2,136.0	-0.9	1.5	1	1	1
09/16/2021 18:00	-1.4	11.9	2,149.0	-0.7	1.5	1	1	1
09/16/2021 19:00	-1.4	12.6	1,998.5	-0.8	1.4	1	1	1
09/16/2021 20:00	-0.7	13.6	1,730.7	-0.4	1.2	1	1	1
09/16/2021 21:00	-0.4	13.7	1,691.7	-0.2	1.2	1	1	1
09/16/2021 22:00	-1.4	12.5	2,056.9	-0.8	1.4	1	1	1
09/16/2021 23:00	-1.2	12.8	1,977.6	-0.7	1.4	1	1	1
Average/Sum#:	-0.4	13.6	1,649.5	-0.2	1.2	24 #	24 #	9 #
Minimum:	-1.7	11.9	1,331.1	-0.9	0.9	1	1	0
Maximum:	0.1	14.0	2,149.0	0.2	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/17/2021 00:00	-1.2	12.9	1,950.3	-0.8	1.4	1	1	1
09/17/2021 01:00	-0.8	13.7	1,501.4	-0.5	1.1	1	1	1
09/17/2021 02:00	0.1	13.9	1,529.8	0.1	1.1	1	1	0
09/17/2021 03:00	0.1	13.9	1,529.3	0.1	1.1	1	1	0
09/17/2021 04:00	0.1	13.9	1,510.5	0.2	1.1	1	1	0
09/17/2021 05:00	0.1	13.9	1,541.5	0.1	1.1	1	1	0
09/17/2021 06:00	0.1	13.9	1,479.7	0.1	1.0	1	1	0
09/17/2021 07:00	0.1	13.9	1,439.4	0.1	1.0	1	1	0
09/17/2021 08:00	0.0	13.9	1,355.1	0.1	0.9	1	1	0
09/17/2021 09:00	0.1	14.0	1,358.1	0.1	1.0	1	1	0
09/17/2021 10:00	0.1	14.0	1,359.8	0.2	1.0	1	1	0
09/17/2021 11:00	0.1	14.0	1,368.7	0.2	1.0	1	1	0
09/17/2021 12:00	0.1	14.0	1,368.2	0.2	1.0	1	1	0
09/17/2021 13:00	0.1	13.9	1,607.2	0.2	1.1	1	1	0
09/17/2021 14:00	0.2	13.9	1,491.4	0.3	1.0	1	1	0
09/17/2021 15:00	0.1	13.9	1,504.1	0.2	1.1	1	1	0
09/17/2021 16:00	-0.4	13.8	1,606.3	-0.2	1.1	1	1	1
09/17/2021 17:00	-1.5	12.1	2,109.7	-0.8	1.5	1	1	1
09/17/2021 18:00	-1.2	11.8	2,191.9	-0.5	1.5	1	1	1
09/17/2021 19:00	-1.2	12.5	2,036.8	-0.7	1.4	1	1	1
09/17/2021 20:00	-1.4	12.9	1,957.5	-0.8	1.4	1	1	1
09/17/2021 21:00	-1.5	12.8	1,977.9	-0.9	1.4	1	1	1
09/17/2021 22:00	-1.5	12.8	1,973.1	-0.9	1.4	1	1	1
09/17/2021 23:00	-0.9	13.7	1,516.1	-0.7	1.1	1	1	1
Average/Sum#:	-0.4	13.5	1,636.0	-0.2	1.2	24 #	24 #	10 #
Minimum:	-1.5	11.8	1,355.1	-0.9	0.9	1	1	0
Maximum:	0.2	14.0	2,191.9	0.3	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/18/2021 00:00	0.0	14.0	1,371.7	0.1	1.0	1	1	0
09/18/2021 01:00	0.0	14.0	1,347.8	0.1	0.9	1	1	0
09/18/2021 02:00	0.0	14.0	1,350.6	0.1	0.9	1	1	0
09/18/2021 03:00	0.0	14.0	1,356.0	0.1	0.9	1	1	0
09/18/2021 04:00	0.1	13.9	1,430.5	0.1	1.0	1	1	0
09/18/2021 05:00	0.0	13.9	1,380.1	0.1	1.0	1	1	0
09/18/2021 06:00	0.0	13.9	1,391.4	0.1	1.0	1	1	0
09/18/2021 07:00	0.0	13.9	1,368.4	0.1	1.0	1	1	0
09/18/2021 08:00	0.0	13.9	1,370.3	0.1	1.0	1	1	0
09/18/2021 09:00	0.1	13.9	1,371.9	0.1	1.0	1	1	0
09/18/2021 10:00	0.1	14.0	1,376.0	0.1	1.0	1	1	0
09/18/2021 11:00	0.1	14.0	1,374.9	0.2	1.0	1	1	0
09/18/2021 12:00	0.1	14.0	1,371.2	0.2	1.0	1	1	0
09/18/2021 13:00	0.2	14.0	1,369.9	0.3	1.0	1	1	0
09/18/2021 14:00	0.1	14.0	1,366.4	0.2	1.0	1	1	0
09/18/2021 15:00	0.1	14.0	1,363.9	0.2	1.0	1	1	0
09/18/2021 16:00	0.1	14.0	1,402.4	0.2	1.0	1	1	0
09/18/2021 17:00	0.1	14.0	1,414.2	0.2	1.0	1	1	0
09/18/2021 18:00	0.1	14.0	1,397.7	0.2	1.0	1	1	0
09/18/2021 19:00	0.1	14.0	1,364.0	0.2	1.0	1	1	0
09/18/2021 20:00	0.2	13.9	1,566.9	0.3	1.1	1	1	0
09/18/2021 21:00	0.1	13.9	1,489.9	0.2	1.0	1	1	0
09/18/2021 22:00	0.1	13.9	1,526.8	0.2	1.1	1	1	0
09/18/2021 23:00	0.1	13.9	1,355.6	0.1	0.9	1	1	0
Average/Sum#:	0.1	14.0	1,394.9	0.2	1.0	24 #	24 #	0 #
Minimum:	0.0	13.9	1,347.8	0.1	0.9	1	1	0
Maximum:	0.2	14.0	1,566.9	0.3	1.1	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/19/2021 00:00	0.1	13.9	1,357.3	0.1	1.0	1	1	0
09/19/2021 01:00	0.0	13.9	1,356.0	0.1	0.9	1	1	0
09/19/2021 02:00	0.0	13.9	1,353.3	0.1	0.9	1	1	0
09/19/2021 03:00	0.0	13.9	1,358.9	0.1	1.0	1	1	0
09/19/2021 04:00	0.1	13.9	1,409.4	0.1	1.0	1	1	0
09/19/2021 05:00	0.0	13.9	1,420.9	0.1	1.0	1	1	0
09/19/2021 06:00	0.0	13.9	1,358.3	0.1	1.0	1	1	0
09/19/2021 07:00	0.0	13.9	1,359.8	0.1	1.0	1	1	0
09/19/2021 08:00	0.0	13.9	1,356.8	0.1	0.9	1	1	0
09/19/2021 09:00	0.1	13.9	1,360.6	0.1	1.0	1	1	0
09/19/2021 10:00	0.1	14.0	1,387.7	0.2	1.0	1	1	0
09/19/2021 11:00	0.2	14.0	1,372.1	0.3	1.0	1	1	0
09/19/2021 12:00	0.2	14.0	1,372.9	0.3	1.0	1	1	0
09/19/2021 13:00	0.2	14.0	1,369.1	0.3	1.0	1	1	0
09/19/2021 14:00	0.2	14.0	1,400.8	0.3	1.0	1	1	0
09/19/2021 15:00	0.2	14.0	1,369.5	0.3	1.0	1	1	0
09/19/2021 16:00	0.2	14.0	1,551.9	0.3	1.1	1	1	0
09/19/2021 17:00	0.2	13.9	1,729.4	0.3	1.2	1	1	0
09/19/2021 18:00	0.2	13.9	1,563.0	0.3	1.1	1	1	0
09/19/2021 19:00	0.2	14.0	1,424.6	0.3	1.0	1	1	0
09/19/2021 20:00	0.2	14.0	1,559.1	0.3	1.1	1	1	0
09/19/2021 21:00	0.2	14.0	1,400.9	0.3	1.0	1	1	0
09/19/2021 22:00	0.2	14.0	1,364.0	0.3	1.0	1	1	0
09/19/2021 23:00	0.1	14.0	1,363.1	0.2	1.0	1	1	0
Average/Sum#:	0.1	14.0	1,413.3	0.2	1.0	24 #	24 #	0 #
Minimum:	0.0	13.9	1,353.3	0.1	0.9	1	1	0
Maximum:	0.2	14.0	1,729.4	0.3	1.2	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/20/2021 00:00	0.1	14.0	1,361.9	0.2	1.0	1	1	0
09/20/2021 01:00	0.2	13.9	1,520.4	0.3	1.1	1	1	0
09/20/2021 02:00	0.2	13.9	1,724.2	0.3	1.2	1	1	0
09/20/2021 03:00	0.1	14.0	1,304.8	0.2	0.9	1	1	0
09/20/2021 04:00	0.2	14.0	1,469.6	0.3	1.0	1	1	0
09/20/2021 05:00	-3.5	13.1	1,899.9	-2.4	1.3	1	1	1
09/20/2021 06:00	-1.7	12.8	2,007.4	-1.1	1.4	1	1	1
09/20/2021 07:00	-0.8	13.8	1,514.1	-0.5	1.1	1	1	1
09/20/2021 08:00	0.2	14.1	1,307.3	0.3	0.9	1	1	0
09/20/2021 09:00	0.2	14.1	1,310.2	0.3	0.9	1	1	0
09/20/2021 10:00	0.3	14.1	1,312.2	0.4	0.9	1	1	0
09/20/2021 11:00	-0.1	13.9	1,605.4	0.1	1.1	1	1	1
09/20/2021 12:00	-1.7	12.7	2,034.5	-1.1	1.4	1	1	1
09/20/2021 13:00	-1.4	12.7	2,034.2	-0.8	1.4	1	1	1
09/20/2021 14:00	-0.4	13.7	1,596.8	-0.2	1.1	1	1	1
09/20/2021 15:00	-0.1	13.9	1,562.1	0.1	1.1	1	1	1
09/20/2021 16:00	-1.8	12.4	2,103.8	-1.1	1.5	1	1	1
09/20/2021 17:00	-0.9	11.5	2,286.4	-0.4	1.6	1	1	1
09/20/2021 18:00	-0.9	11.5	2,280.4	-0.4	1.6	1	1	1
09/20/2021 19:00	-0.9	11.7	2,243.1	-0.4	1.6	1	1	1
09/20/2021 20:00	-1.1	11.9	2,203.6	-0.5	1.5	1	1	1
09/20/2021 21:00	-1.2	12.2	2,143.5	-0.7	1.5	1	1	1
09/20/2021 22:00	-1.4	12.9	1,994.7	-0.8	1.4	1	1	1
09/20/2021 23:00	-1.5	13.0	1,945.9	-0.9	1.4	1	1	1
Average/Sum#:	-0.7	13.2	1,781.9	-0.4	1.2	24 #	24 #	16 #
Minimum:	-3.5	11.5	1,304.8	-2.4	0.9	1	1	0
Maximum:	0.3	14.1	2,286.4	0.4	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/21/2021 00:00	0.1	13.9	1,703.3	0.2	1.2	1	1	0
09/21/2021 01:00	-0.5	13.9	1,604.3	-0.4	1.1	1	1	1
09/21/2021 02:00	-3.0	13.1	1,966.7	-2.1	1.4	1	1	1
09/21/2021 03:00	-1.8	13.1	1,958.2	-1.2	1.4	1	1	1
09/21/2021 04:00	-2.0	13.1	1,954.7	-1.4	1.4	1	1	1
09/21/2021 05:00	-1.8	13.0	1,969.9	-1.2	1.4	1	1	1
09/21/2021 06:00	-1.5	12.5	2,101.0	-0.9	1.5	1	1	1
09/21/2021 07:00	-1.7	13.1	1,949.9	-1.1	1.4	1	1	1
09/21/2021 08:00	0.1	13.9	1,493.1	0.1	1.0	1	1	0
09/21/2021 09:00	0.2	14.0	1,549.6	0.3	1.1	1	1	0
09/21/2021 10:00	0.3	13.9	1,682.3	0.4	1.2	1	1	0
09/21/2021 11:00	-0.1	14.0	1,653.4	0.1	1.2	1	1	1
09/21/2021 12:00	-1.7	12.5	2,070.7	-0.9	1.4	1	1	1
09/21/2021 13:00	-1.2	11.8	2,198.1	-0.5	1.5	1	1	1
09/21/2021 14:00	-1.1	11.8	2,201.4	-0.5	1.5	1	1	1
09/21/2021 15:00	-1.1	11.7	2,212.8	-0.5	1.5	1	1	1
09/21/2021 16:00	-0.9	11.6	2,228.5	-0.4	1.6	1	1	1
09/21/2021 17:00	-0.9	11.6	2,235.1	-0.4	1.6	1	1	1
09/21/2021 18:00	-0.9	11.5	2,251.1	-0.4	1.6	1	1	1
09/21/2021 19:00	-0.9	11.7	2,218.9	-0.4	1.6	1	1	1
09/21/2021 20:00	-0.9	11.7	2,237.7	-0.4	1.6	1	1	1
09/21/2021 21:00	-1.1	11.9	2,184.0	-0.5	1.5	1	1	1
09/21/2021 22:00	-1.2	12.2	2,143.1	-0.7	1.5	1	1	1
09/21/2021 23:00	-1.2	12.5	2,064.6	-0.7	1.4	1	1	1
Average/Sum#:	-1.0	12.7	1,993.0	-0.6	1.4	24 #	24 #	20 #
Minimum:	-3.0	11.5	1,493.1	-2.1	1.0	1	1	0
Maximum:	0.3	14.0	2,251.1	0.4	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/22/2021 00:00	-0.5	13.8	1,648.7	-0.4	1.2	1	1	1
09/22/2021 01:00	-0.4	13.8	1,682.3	-0.2	1.2	1	1	1
09/22/2021 02:00	-4.5	13.0	1,957.6	-3.2	1.4	1	1	1
09/22/2021 03:00	-3.9	13.1	1,955.1	-2.7	1.4	1	1	1
09/22/2021 04:00	-2.4	12.7	2,066.4	-1.5	1.4	1	1	1
09/22/2021 05:00	-1.4	12.0	2,188.9	-0.7	1.5	1	1	1
09/22/2021 06:00	-1.4	12.3	2,111.4	-0.8	1.5	1	1	1
09/22/2021 07:00	-1.7	13.0	1,948.2	-1.1	1.4	1	1	1
09/22/2021 08:00	0.1	13.9	1,657.2	0.1	1.2	1	1	0
09/22/2021 09:00	0.1	13.8	1,755.2	0.2	1.2	1	1	0
09/22/2021 10:00	-1.7	12.9	1,972.5	-1.1	1.4	1	1	1
09/22/2021 11:00	-1.5	12.3	2,083.3	-0.8	1.5	1	1	1
09/22/2021 12:00	0.1	13.9	1,639.6	0.2	1.1	1	1	0
09/22/2021 13:00	-0.2	13.8	1,735.7	-0.1	1.2	1	1	1
09/22/2021 14:00	-1.5	12.2	2,113.9	-0.8	1.5	1	1	1
09/22/2021 15:00	-1.1	11.6	2,224.9	-0.5	1.6	1	1	1
09/22/2021 16:00	-0.8	11.5	2,252.4	-0.2	1.6	1	1	1
09/22/2021 17:00	-0.9	11.5	2,241.3	-0.4	1.6	1	1	1
09/22/2021 18:00	-0.9	11.6	2,247.3	-0.4	1.6	1	1	1
09/22/2021 19:00	-1.1	12.1	2,112.8	-0.5	1.5	1	1	1
09/22/2021 20:00	0.1	13.9	1,674.1	0.2	1.2	1	1	0
09/22/2021 21:00	-0.4	13.7	1,798.4	-0.2	1.3	1	1	1
09/22/2021 22:00	-1.7	12.6	2,042.1	-0.9	1.4	1	1	1
09/22/2021 23:00	-1.5	12.3	2,097.0	-0.8	1.5	1	1	1
Average/Sum#:	-1.2	12.8	1,966.9	-0.7	1.4	24 #	24 #	20 #
Minimum:	-4.5	11.5	1,639.6	-3.2	1.1	1	1	0
Maximum:	0.1	13.9	2,252.4	0.2	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/23/2021 00:00	-1.4	12.8	1,975.9	-0.8	1.4	1	1	1
09/23/2021 01:00	0.1	13.9	1,584.6	0.1	1.1	1	1	0
09/23/2021 02:00	0.1	14.0	1,549.0	0.2	1.1	1	1	0
09/23/2021 03:00	0.2	14.0	1,658.9	0.3	1.2	1	1	0
09/23/2021 04:00	-0.1	13.9	1,608.1	0.1	1.1	1	1	1
09/23/2021 05:00	-1.7	12.4	2,061.1	-0.9	1.4	1	1	1
09/23/2021 06:00	-1.4	12.6	2,023.1	-0.8	1.4	1	1	1
09/23/2021 07:00	0.1	13.9	1,684.9	0.2	1.2	1	1	0
09/23/2021 08:00	0.1	14.0	1,419.6	0.1	1.0	1	1	0
09/23/2021 09:00	0.1	13.8	1,783.4	0.2	1.2	1	1	0
09/23/2021 10:00	0.1	13.7	1,784.9	0.2	1.2	1	1	0
09/23/2021 11:00	0.1	13.7	1,787.1	0.2	1.3	1	1	0
09/23/2021 12:00	0.1	13.7	1,781.7	0.2	1.2	1	1	0
09/23/2021 13:00	0.1	13.7	1,779.9	0.2	1.2	1	1	0
09/23/2021 14:00	0.2	13.7	1,779.4	0.3	1.2	1	1	0
09/23/2021 15:00	0.2	13.7	1,779.1	0.3	1.2	1	1	0
09/23/2021 16:00	0.2	13.7	1,778.1	0.3	1.2	1	1	0
09/23/2021 17:00	0.1	13.7	1,781.0	0.2	1.2	1	1	0
09/23/2021 18:00	0.1	13.7	1,788.5	0.2	1.3	1	1	0
09/23/2021 19:00	0.1	13.7	1,794.0	0.1	1.3	1	1	0
09/23/2021 20:00	0.1	13.7	1,801.3	0.1	1.3	1	1	0
09/23/2021 21:00	0.1	13.7	1,801.3	0.2	1.3	1	1	0
09/23/2021 22:00	0.1	13.7	1,799.1	0.2	1.3	1	1	0
09/23/2021 23:00	0.1	13.7	1,796.4	0.2	1.3	1	1	0
Average/Sum#:	-0.1	13.6	1,765.9	0.1	1.2	24 #	24 #	4 #
Minimum:	-1.7	12.4	1,419.6	-0.9	1.0	1	1	0
Maximum:	0.2	14.0	2,061.1	0.3	1.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/24/2021 00:00	0.1	13.7	1,797.5	0.2	1.3	1	1	0
09/24/2021 01:00	0.1	13.7	1,797.8	0.2	1.3	1	1	0
09/24/2021 02:00	0.1	13.7	1,798.8	0.2	1.3	1	1	0
09/24/2021 03:00	0.1	13.7	1,799.7	0.2	1.3	1	1	0
09/24/2021 04:00	0.1	13.7	1,803.6	0.2	1.3	1	1	0
09/24/2021 05:00	0.1	13.7	1,799.4	0.1	1.3	1	1	0
09/24/2021 06:00	0.1	13.7	1,802.9	0.1	1.3	1	1	0
09/24/2021 07:00	0.1	13.7	1,805.4	0.1	1.3	1	1	0
09/24/2021 08:00	0.1	13.7	1,802.4	0.2	1.3	1	1	0
09/24/2021 09:00	0.1	13.9	1,677.0	0.2	1.2	1	1	0
09/24/2021 10:00	0.1	13.9	1,557.3	0.2	1.1	1	1	0
09/24/2021 11:00	0.3	14.0	1,630.3	0.4	1.1	1	1	0
09/24/2021 12:00	0.3	13.9	1,630.4	0.4	1.1	1	1	0
09/24/2021 13:00	0.2	13.9	1,683.8	0.3	1.2	1	1	0
09/24/2021 14:00	0.2	13.9	1,722.1	0.3	1.2	1	1	0
09/24/2021 15:00	0.1	13.8	1,713.7	0.2	1.2	1	1	0
09/24/2021 16:00	0.1	13.9	1,698.6	0.2	1.2	1	1	0
09/24/2021 17:00	0.1	13.7	1,741.7	0.2	1.2	1	1	0
09/24/2021 18:00	0.1	13.9	1,678.0	0.2	1.2	1	1	0
09/24/2021 19:00	0.1	13.9	1,712.1	0.2	1.2	1	1	0
09/24/2021 20:00	0.1	13.9	1,655.7	0.1	1.2	1	1	0
09/24/2021 21:00	0.1	13.9	1,633.4	0.1	1.1	1	1	0
09/24/2021 22:00	0.1	13.8	1,669.3	0.1	1.2	1	1	0
09/24/2021 23:00	0.1	13.9	1,665.3	0.1	1.2	1	1	0
Average/Sum#:	0.1	13.8	1,719.8	0.2	1.2	24 #	24 #	0 #
Minimum:	0.1	13.7	1,557.3	0.1	1.1	1	1	0
Maximum:	0.3	14.0	1,805.4	0.4	1.3	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/25/2021 00:00	0.1	13.9	1,591.8	0.1	1.1	1	1	0
09/25/2021 01:00	0.1	13.8	1,658.5	0.1	1.2	1	1	0
09/25/2021 02:00	0.1	13.8	1,686.9	0.1	1.2	1	1	0
09/25/2021 03:00	0.1	13.8	1,685.7	0.1	1.2	1	1	0
09/25/2021 04:00	0.1	13.9	1,639.5	0.2	1.1	1	1	0
09/25/2021 05:00	0.1	13.9	1,620.9	0.2	1.1	1	1	0
09/25/2021 06:00	0.1	13.9	1,665.6	0.2	1.2	1	1	0
09/25/2021 07:00	0.1	13.9	1,660.0	0.2	1.2	1	1	0
09/25/2021 08:00	0.1	13.9	1,553.0	0.2	1.1	1	1	0
09/25/2021 09:00	0.1	14.0	1,356.2	0.1	0.9	1	1	0
09/25/2021 10:00	0.2	13.9	1,545.0	0.3	1.1	1	1	0
09/25/2021 11:00	0.2	13.9	1,675.0	0.3	1.2	1	1	0
09/25/2021 12:00	0.1	13.9	1,685.3	0.2	1.2	1	1	0
09/25/2021 13:00	0.1	13.9	1,672.1	0.2	1.2	1	1	0
09/25/2021 14:00	0.1	13.9	1,704.6	0.2	1.2	1	1	0
09/25/2021 15:00	0.1	13.8	1,701.0	0.2	1.2	1	1	0
09/25/2021 16:00	0.1	13.8	1,650.4	0.2	1.2	1	1	0
09/25/2021 17:00	0.0	14.0	1,344.2	0.1	0.9	1	1	0
09/25/2021 18:00	0.1	13.9	1,643.0	0.2	1.2	1	1	0
09/25/2021 19:00	0.1	13.9	1,701.4	0.2	1.2	1	1	0
09/25/2021 20:00	0.1	13.9	1,664.9	0.1	1.2	1	1	0
09/25/2021 21:00	0.0	13.9	1,575.6	0.1	1.1	1	1	0
09/25/2021 22:00	0.0	15.0	907.9	0.0	0.6	1	0	0
09/25/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.1	13.9	1,590.8	0.2	1.1	23 #	22 #	0 #
Minimum:	0.0	13.8	907.9	0.0	0.6	0	0	0
Maximum:	0.2	15.0	1,704.6	0.3	1.2	1	1	0
%SI	4.17	4.17	4.17	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/26/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/26/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/27/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/27/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/28/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/28/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/29/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/29/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/29/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/29/2021 03:00	0.0	17.9	263.9	0.0	0.2	1	0	0
09/29/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/29/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/29/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/29/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/29/2021 08:00	0.0	18.1	223.9	0.0	0.2	1	0	0
09/29/2021 09:00	0.0	15.4	866.8	0.0	0.6	1	0	0
09/29/2021 10:00	0.4	14.0	1,574.3	0.4	1.1	1	1	0
09/29/2021 11:00	0.3	0.0	1,499.4	0.5	1.0	1	1	0
09/29/2021 12:00	0.4	0.0	1,487.6	0.5	1.0	1	1	0
09/29/2021 13:00	0.4	14.0	1,660.5	0.4	1.2	1	1	0
09/29/2021 14:00	0.4	13.9	1,691.4	0.4	1.2	1	1	0
09/29/2021 15:00	0.4	13.9	1,700.0	0.4	1.2	1	1	0
09/29/2021 16:00	0.4	13.9	1,687.6	0.4	1.2	1	1	0
09/29/2021 17:00	0.3	14.0	1,449.6	0.4	1.0	1	1	0
09/29/2021 18:00	0.4	14.1	1,406.0	0.4	1.0	1	1	0
09/29/2021 19:00	0.4	13.9	1,663.2	0.4	1.2	1	1	0
09/29/2021 20:00	0.4	13.9	1,672.2	0.4	1.2	1	1	0
09/29/2021 21:00	0.3	13.9	1,642.1	0.4	1.1	1	1	0
09/29/2021 22:00	0.4	13.9	1,677.9	0.4	1.2	1	1	0
09/29/2021 23:00	0.3	13.9	1,549.8	0.4	1.1	1	1	0
Average/Sum#:	0.3	14.6	1,395.1	0.3	1.0	17 #	14 #	0 #
Minimum:	0.0	13.9	223.9	0.0	0.2	0	0	0
Maximum:	0.4	18.1	1,700.0	0.4	1.2	1	1	0
%SI	29.17	37.50	29.17	37.50	29.17	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/30/2021 00:00	0.4	14.0	1,520.5	0.4	1.1	1	1	0
09/30/2021 01:00	0.4	14.1	1,336.6	0.4	0.9	1	1	0
09/30/2021 02:00	0.4	14.1	1,310.2	0.4	0.9	1	1	0
09/30/2021 03:00	0.4	14.0	1,569.4	0.4	1.1	1	1	0
09/30/2021 04:00	0.4	14.0	1,630.0	0.4	1.1	1	1	0
09/30/2021 05:00	0.4	14.1	1,357.1	0.4	0.9	1	1	0
09/30/2021 06:00	0.3	14.0	1,460.2	0.4	1.0	1	1	0
09/30/2021 07:00	0.4	14.1	1,350.2	0.4	0.9	1	1	0
09/30/2021 08:00	0.4	14.1	1,348.2	0.4	0.9	1	1	0
09/30/2021 09:00	0.4	14.1	1,362.1	0.4	1.0	1	1	0
09/30/2021 10:00	0.4	14.1	1,366.0	0.4	1.0	1	1	0
09/30/2021 11:00	0.4	14.1	1,366.5	0.4	1.0	1	1	0
09/30/2021 12:00	0.5	14.1	1,367.6	0.5	1.0	1	1	0
09/30/2021 13:00	0.5	14.1	1,362.4	0.5	1.0	1	1	0
09/30/2021 14:00	0.4	14.1	1,386.1	0.4	1.0	1	1	1
09/30/2021 15:00	-2.1	13.0	1,970.2	-1.4	1.4	1	1	1
09/30/2021 16:00	-1.4	12.7	2,026.7	-0.8	1.4	1	1	1
09/30/2021 17:00	-1.2	12.8	1,997.0	-0.7	1.4	1	1	1
09/30/2021 18:00	-1.4	13.0	1,967.0	-0.8	1.4	1	1	1
09/30/2021 19:00	-1.4	13.0	1,965.3	-0.8	1.4	1	1	1
09/30/2021 20:00	-1.4	13.0	1,950.1	-0.8	1.4	1	1	1
09/30/2021 21:00	-1.5	13.0	1,953.0	-0.9	1.4	1	1	1
09/30/2021 22:00	-1.7	13.2	1,921.7	-1.1	1.3	1	1	1
09/30/2021 23:00	0.2	14.0	1,410.1	0.3	1.0	1	1	0
Average/Sum#:	-0.2	13.7	1,593.9	0.0	1.1	24 #	24 #	9 #
Minimum:	-2.1	12.7	1,310.2	-1.4	0.9	1	1	0
Maximum:	0.5	14.1	2,026.7	0.5	1.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/01/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/02/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/03/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/04/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/05/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/06/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/07/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/08/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/08/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/08/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/08/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/08/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/08/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/08/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/08/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/08/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/08/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/08/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/08/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/08/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/08/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/08/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/08/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/08/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/08/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/08/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/08/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/08/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/08/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/08/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/08/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/09/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/09/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/09/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/09/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/09/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/09/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/09/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/09/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/09/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/09/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/09/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/09/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/09/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/09/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/09/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/09/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/09/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/09/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/09/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/09/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/09/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/09/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/09/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/09/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/10/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/10/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/10/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/10/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/10/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/10/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/10/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/10/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/10/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/10/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/10/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/10/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/10/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/10/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/10/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/10/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/10/2021 16:00	0.0	18.1	174.5	0.0	0.1	1	0	0
07/10/2021 17:00	0.0	17.6	205.2	0.0	0.1	1	0	0
07/10/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/10/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/10/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/10/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/10/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/10/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	17.9	189.9	0.0	0.1	2 #	0 #	0 #
Minimum:	0.0	17.6	174.5	0.0	0.1	0	0	0
Maximum:	0.0	18.1	205.2	0.0	0.1	1	0	0
%SI	91.67	91.67	91.67	91.67	91.67	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/11/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/11/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/11/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/11/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/11/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/11/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/11/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/11/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/11/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/11/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/11/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/11/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/11/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/11/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/11/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/11/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/11/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/11/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/11/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/11/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/11/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/11/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/11/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/11/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/12/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/12/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/12/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/12/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/12/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/12/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/12/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/12/2021 07:00	0.0	0.0	307.2	0.0	0.1	1	0	0
07/12/2021 08:00	0.0	0.0	373.7	0.0	0.1	1	0	0
07/12/2021 09:00	0.0	0.0	649.9	0.0	0.2	1	0	0
07/12/2021 10:00	0.4	13.9	1,339.1	0.4	0.4	1	1	0
07/12/2021 11:00	0.4	13.7	1,666.6	0.4	0.5	1	1	0
07/12/2021 12:00	0.4	13.6	1,721.4	0.4	0.5	1	1	0
07/12/2021 13:00	0.4	13.6	1,719.6	0.4	0.5	1	1	0
07/12/2021 14:00	0.4	13.6	1,715.2	0.4	0.5	1	1	0
07/12/2021 15:00	0.4	13.6	1,707.5	0.4	0.5	1	1	0
07/12/2021 16:00	0.4	13.8	1,546.3	0.4	0.5	1	1	0
07/12/2021 17:00	0.4	13.6	1,697.5	0.4	0.5	1	1	0
07/12/2021 18:00	0.4	13.6	1,692.4	0.4	0.5	1	1	0
07/12/2021 19:00	0.4	13.7	1,692.1	0.4	0.5	1	1	0
07/12/2021 20:00	0.4	13.6	1,716.2	0.4	0.5	1	1	0
07/12/2021 21:00	0.3	13.6	1,715.7	0.4	0.5	1	1	0
07/12/2021 22:00	0.3	13.7	1,684.2	0.4	0.5	1	1	0
07/12/2021 23:00	0.3	13.6	1,741.8	0.4	0.5	1	1	0
Average/Sum#:	0.3	13.7	1,452.1	0.4	0.4	17 #	14 #	0 #
Minimum:	0.0	13.6	307.2	0.4	0.1	0	0	0
Maximum:	0.4	13.9	1,741.8	0.4	0.5	1	1	0
%SI	29.17	41.67	29.17	41.67	29.17	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/13/2021 00:00	0.3	13.6	1,747.3	0.4	0.5	1	1	0
07/13/2021 01:00	0.3	13.6	1,751.2	0.4	0.5	1	1	0
07/13/2021 02:00	0.0	14.8	1,048.1	0.0	0.3	1	0	0
07/13/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/13/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/13/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/13/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/13/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/13/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/13/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/13/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/13/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/13/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/13/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/13/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/13/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/13/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/13/2021 17:00	0.0	17.7	326.6	0.0	0.1	1	0	0
07/13/2021 18:00	0.0	14.9	990.6	0.0	0.3	1	0	0
07/13/2021 19:00	0.6	13.7	1,674.6	0.6	0.5	1	1	0
07/13/2021 20:00	-0.1	12.8	1,882.4	0.1	0.6	1	1	1
07/13/2021 21:00	0.4	13.5	1,539.9	0.4	0.5	1	1	1
07/13/2021 22:00	0.6	14.0	1,292.6	0.6	0.4	1	1	0
07/13/2021 23:00	0.6	13.8	1,692.2	0.6	0.5	1	1	0
Average/Sum#:	0.3	14.2	1,394.6	0.3	0.4	10 #	7 #	2 #
Minimum:	-0.1	12.8	326.6	0.0	0.1	0	0	0
Maximum:	0.6	17.7	1,882.4	0.6	0.6	1	1	1
%SI	58.33	58.33	58.33	58.33	58.33	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/14/2021 00:00	0.6	13.9	1,549.0	0.6	0.5	1	1	0
07/14/2021 01:00	0.6	13.9	1,513.0	0.6	0.5	1	1	0
07/14/2021 02:00	0.6	13.9	1,523.5	0.6	0.5	1	1	0
07/14/2021 03:00	0.6	13.9	1,608.3	0.6	0.5	1	1	0
07/14/2021 04:00	0.6	13.9	1,484.0	0.6	0.4	1	1	0
07/14/2021 05:00	0.6	13.9	1,671.9	0.6	0.5	1	1	0
07/14/2021 06:00	0.6	13.9	1,601.0	0.6	0.5	1	1	0
07/14/2021 07:00	0.7	13.8	1,643.1	0.7	0.5	1	1	1
07/14/2021 08:00	-1.4	12.7	1,971.0	-0.8	0.6	1	1	1
07/14/2021 09:00	-1.4	12.8	1,909.3	-0.8	0.6	1	1	1
07/14/2021 10:00	0.6	13.9	1,625.4	0.6	0.5	1	1	0
07/14/2021 11:00	0.7	13.9	1,561.8	0.7	0.5	1	1	1
07/14/2021 12:00	-1.2	12.6	1,971.1	-0.7	0.6	1	1	1
07/14/2021 13:00	0.5	12.1	2,046.9	0.5	0.6	1	1	1
07/14/2021 14:00	0.5	12.1	2,041.2	0.5	0.6	1	1	1
07/14/2021 15:00	0.5	12.2	2,032.1	0.5	0.6	1	1	1
07/14/2021 16:00	0.7	12.1	2,034.4	0.7	0.6	1	1	1
07/14/2021 17:00	0.7	12.1	2,044.1	0.7	0.6	1	1	1
07/14/2021 18:00	0.7	12.2	2,039.3	0.7	0.6	1	1	1
07/14/2021 19:00	0.4	12.3	2,021.2	0.5	0.6	1	1	1
07/14/2021 20:00	0.2	12.3	2,015.5	0.4	0.6	1	1	1
07/14/2021 21:00	-0.2	12.5	1,990.7	0.1	0.6	1	1	1
07/14/2021 22:00	-0.2	12.5	1,992.9	0.1	0.6	1	1	1
07/14/2021 23:00	-0.4	12.6	1,990.3	-0.1	0.6	1	1	1
Average/Sum#:	0.2	13.0	1,828.4	0.4	0.6	24 #	24 #	16 #
Minimum:	-1.4	12.1	1,484.0	-0.8	0.4	1	1	0
Maximum:	0.7	13.9	2,046.9	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/15/2021 00:00	-1.1	12.8	1,929.1	-0.7	0.6	1	1	1
07/15/2021 01:00	0.6	13.9	1,534.2	0.6	0.5	1	1	0
07/15/2021 02:00	0.6	13.9	1,485.1	0.6	0.4	1	1	0
07/15/2021 03:00	0.6	13.9	1,466.4	0.6	0.4	1	1	0
07/15/2021 04:00	0.6	13.9	1,674.5	0.6	0.5	1	1	0
07/15/2021 05:00	-1.4	13.0	1,913.8	-0.8	0.6	1	1	1
07/15/2021 06:00	-0.5	12.8	1,950.4	-0.2	0.6	1	1	1
07/15/2021 07:00	0.7	13.9	1,607.5	0.7	0.5	1	1	1
07/15/2021 08:00	0.6	13.9	1,606.7	0.6	0.5	1	1	0
07/15/2021 09:00	0.6	13.9	1,535.6	0.6	0.5	1	1	0
07/15/2021 10:00	0.6	13.9	1,636.1	0.6	0.5	1	1	0
07/15/2021 11:00	0.7	14.0	1,533.8	0.7	0.5	1	1	1
07/15/2021 12:00	-1.5	12.6	2,000.2	-0.9	0.6	1	1	1
07/15/2021 13:00	-0.2	12.3	2,048.0	0.1	0.6	1	1	1
07/15/2021 14:00	0.2	12.2	2,064.3	0.4	0.6	1	1	1
07/15/2021 15:00	0.4	12.2	2,065.4	0.5	0.6	1	1	1
07/15/2021 16:00	0.4	12.1	2,069.6	0.5	0.6	1	1	1
07/15/2021 17:00	0.4	12.2	2,071.0	0.5	0.6	1	1	1
07/15/2021 18:00	0.7	12.1	2,096.3	0.7	0.6	1	1	1
07/15/2021 19:00	0.7	12.0	2,101.8	0.7	0.6	1	1	1
07/15/2021 20:00	0.7	12.0	2,104.1	0.7	0.6	1	1	1
07/15/2021 21:00	0.2	12.3	2,058.4	0.4	0.6	1	1	1
07/15/2021 22:00	-0.5	12.5	2,015.7	-0.2	0.6	1	1	1
07/15/2021 23:00	-0.7	12.5	2,027.7	-0.2	0.6	1	1	1
Average/Sum#:	0.1	13.0	1,858.2	0.3	0.6	24 #	24 #	17 #
Minimum:	-1.5	12.0	1,466.4	-0.9	0.4	1	1	0
Maximum:	0.7	14.0	2,104.1	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/16/2021 00:00	-0.7	12.6	2,030.5	-0.2	0.6	1	1	1
07/16/2021 01:00	-2.6	12.9	1,931.7	-1.7	0.6	1	1	1
07/16/2021 02:00	0.6	13.9	1,601.5	0.6	0.5	1	1	0
07/16/2021 03:00	0.6	13.9	1,447.7	0.6	0.4	1	1	0
07/16/2021 04:00	0.6	13.9	1,595.9	0.6	0.5	1	1	0
07/16/2021 05:00	-1.7	13.5	1,777.5	-1.2	0.5	1	1	1
07/16/2021 06:00	-0.9	13.3	1,839.7	-0.7	0.6	1	1	1
07/16/2021 07:00	0.6	13.9	1,650.3	0.6	0.5	1	1	0
07/16/2021 08:00	0.6	13.9	1,646.5	0.6	0.5	1	1	0
07/16/2021 09:00	0.6	13.9	1,615.7	0.6	0.5	1	1	0
07/16/2021 10:00	0.6	13.9	1,662.6	0.6	0.5	1	1	0
07/16/2021 11:00	0.6	13.9	1,491.7	0.6	0.4	1	1	0
07/16/2021 12:00	-2.1	12.8	1,949.3	-1.4	0.6	1	1	1
07/16/2021 13:00	-1.5	12.7	1,941.8	-0.9	0.6	1	1	1
07/16/2021 14:00	0.6	13.9	1,627.9	0.6	0.5	1	1	0
07/16/2021 15:00	0.7	13.9	1,565.9	0.7	0.5	1	1	1
07/16/2021 16:00	-1.7	12.6	2,009.2	-0.9	0.6	1	1	1
07/16/2021 17:00	0.7	12.0	2,122.2	0.7	0.6	1	1	1
07/16/2021 18:00	0.7	11.9	2,140.2	0.7	0.6	1	1	1
07/16/2021 19:00	0.7	11.9	2,141.8	0.7	0.6	1	1	1
07/16/2021 20:00	0.7	12.0	2,127.2	0.7	0.6	1	1	1
07/16/2021 21:00	0.4	12.1	2,089.3	0.5	0.6	1	1	1
07/16/2021 22:00	0.1	12.3	2,060.5	0.2	0.6	1	1	1
07/16/2021 23:00	-0.7	12.4	2,028.6	-0.2	0.6	1	1	1
Average/Sum#:	-0.1	13.1	1,837.3	0.1	0.5	24 #	24 #	15 #
Minimum:	-2.6	11.9	1,447.7	-1.7	0.4	1	1	0
Maximum:	0.7	13.9	2,141.8	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/17/2021 00:00	-3.0	12.9	1,901.5	-2.0	0.6	1	1	1
07/17/2021 01:00	0.6	13.9	1,626.2	0.6	0.5	1	1	0
07/17/2021 02:00	0.6	14.0	1,296.9	0.6	0.4	1	1	0
07/17/2021 03:00	0.6	13.9	1,595.3	0.6	0.5	1	1	0
07/17/2021 04:00	-2.9	13.4	1,785.2	-2.1	0.5	1	1	1
07/17/2021 05:00	-1.2	13.1	1,811.7	-0.8	0.5	1	1	1
07/17/2021 06:00	0.6	13.9	1,606.1	0.6	0.5	1	1	0
07/17/2021 07:00	0.6	13.9	1,609.3	0.6	0.5	1	1	0
07/17/2021 08:00	0.6	14.0	1,571.3	0.6	0.5	1	1	0
07/17/2021 09:00	0.6	13.8	1,664.0	0.6	0.5	1	1	0
07/17/2021 10:00	0.6	13.9	1,587.3	0.6	0.5	1	1	0
07/17/2021 11:00	0.6	14.0	1,512.4	0.6	0.5	1	1	0
07/17/2021 12:00	0.7	13.9	1,599.6	0.7	0.5	1	1	1
07/17/2021 13:00	-1.2	12.4	2,023.8	-0.7	0.6	1	1	1
07/17/2021 14:00	0.5	12.0	2,111.8	0.5	0.6	1	1	1
07/17/2021 15:00	0.7	12.0	2,109.8	0.7	0.6	1	1	1
07/17/2021 16:00	0.7	11.9	2,119.4	0.7	0.6	1	1	1
07/17/2021 17:00	0.7	11.8	2,137.7	0.7	0.6	1	1	1
07/17/2021 18:00	0.7	11.8	2,141.2	0.7	0.6	1	1	1
07/17/2021 19:00	0.7	11.8	2,140.3	0.7	0.6	1	1	1
07/17/2021 20:00	0.7	11.9	2,123.7	0.7	0.6	1	1	1
07/17/2021 21:00	0.7	12.0	2,100.9	0.7	0.6	1	1	1
07/17/2021 22:00	0.2	12.3	2,052.5	0.4	0.6	1	1	1
07/17/2021 23:00	0.2	12.3	2,057.4	0.4	0.6	1	1	1
Average/Sum#:	0.2	13.0	1,845.2	0.3	0.5	24 #	24 #	15 #
Minimum:	-3.0	11.8	1,296.9	-2.1	0.4	1	1	0
Maximum:	0.7	14.0	2,141.2	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/18/2021 00:00	-1.2	12.7	1,954.7	-0.7	0.6	1	1	1
07/18/2021 01:00	0.6	13.9	1,627.7	0.6	0.5	1	1	0
07/18/2021 02:00	0.7	13.9	1,551.8	0.7	0.5	1	1	1
07/18/2021 03:00	-1.4	12.7	1,978.9	-0.8	0.6	1	1	1
07/18/2021 04:00	-2.0	12.8	1,946.2	-1.2	0.6	1	1	1
07/18/2021 05:00	0.6	13.9	1,635.2	0.6	0.5	1	1	0
07/18/2021 06:00	0.6	13.9	1,635.6	0.6	0.5	1	1	0
07/18/2021 07:00	0.6	13.9	1,629.0	0.6	0.5	1	1	0
07/18/2021 08:00	0.6	13.8	1,651.5	0.6	0.5	1	1	0
07/18/2021 09:00	0.6	13.9	1,620.6	0.6	0.5	1	1	0
07/18/2021 10:00	0.6	14.0	1,568.9	0.6	0.5	1	1	0
07/18/2021 11:00	0.7	13.9	1,682.7	0.7	0.5	1	1	1
07/18/2021 12:00	-0.9	12.5	2,012.7	-0.5	0.6	1	1	1
07/18/2021 13:00	0.7	11.9	2,130.5	0.7	0.6	1	1	1
07/18/2021 14:00	0.7	11.8	2,133.9	0.7	0.6	1	1	1
07/18/2021 15:00	0.7	11.8	2,132.0	0.7	0.6	1	1	1
07/18/2021 16:00	0.7	11.8	2,124.8	0.7	0.6	1	1	1
07/18/2021 17:00	0.7	11.8	2,123.5	0.7	0.6	1	1	1
07/18/2021 18:00	0.7	11.9	2,103.3	0.7	0.6	1	1	1
07/18/2021 19:00	0.7	12.1	2,087.1	0.7	0.6	1	1	1
07/18/2021 20:00	0.7	12.1	2,085.7	0.7	0.6	1	1	1
07/18/2021 21:00	0.7	12.0	2,119.4	0.7	0.6	1	1	1
07/18/2021 22:00	0.7	12.0	2,114.2	0.7	0.6	1	1	1
07/18/2021 23:00	0.7	12.0	2,113.9	0.7	0.6	1	1	1
Average/Sum#:	0.3	12.8	1,906.8	0.4	0.6	24 #	24 #	17 #
Minimum:	-2.0	11.8	1,551.8	-1.2	0.5	1	1	0
Maximum:	0.7	14.0	2,133.9	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/19/2021 00:00	0.7	12.1	2,099.9	0.7	0.6	1	1	1
07/19/2021 01:00	0.5	13.6	1,678.5	0.5	0.5	1	1	1
07/19/2021 02:00	0.6	13.9	1,655.1	0.6	0.5	1	1	0
07/19/2021 03:00	0.6	13.9	1,603.6	0.6	0.5	1	1	0
07/19/2021 04:00	0.7	13.9	1,672.3	0.7	0.5	1	1	1
07/19/2021 05:00	-2.6	12.7	2,010.3	-1.7	0.6	1	1	1
07/19/2021 06:00	-0.7	12.6	2,020.6	-0.2	0.6	1	1	1
07/19/2021 07:00	0.6	13.9	1,574.5	0.6	0.5	1	1	0
07/19/2021 08:00	0.6	13.9	1,595.5	0.6	0.5	1	1	0
07/19/2021 09:00	0.7	13.9	1,560.4	0.7	0.5	1	1	1
07/19/2021 10:00	-0.8	12.6	2,007.6	-0.4	0.6	1	1	1
07/19/2021 11:00	0.7	11.8	2,143.7	0.7	0.6	1	1	1
07/19/2021 12:00	0.7	11.8	2,141.9	0.7	0.6	1	1	1
07/19/2021 13:00	0.7	11.8	2,132.7	0.7	0.6	1	1	1
07/19/2021 14:00	0.7	11.8	2,137.1	0.7	0.6	1	1	1
07/19/2021 15:00	0.7	11.8	2,129.4	0.7	0.6	1	1	1
07/19/2021 16:00	0.7	11.8	2,138.3	0.7	0.6	1	1	1
07/19/2021 17:00	0.7	11.9	2,136.9	0.7	0.6	1	1	1
07/19/2021 18:00	0.7	11.9	2,140.8	0.7	0.6	1	1	1
07/19/2021 19:00	0.7	11.9	2,142.5	0.7	0.6	1	1	1
07/19/2021 20:00	0.7	11.9	2,140.0	0.7	0.6	1	1	1
07/19/2021 21:00	0.7	11.9	2,122.1	0.7	0.6	1	1	1
07/19/2021 22:00	-0.1	12.4	2,038.8	0.2	0.6	1	1	1
07/19/2021 23:00	-0.2	12.4	2,026.9	0.1	0.6	1	1	1
Average/Sum#:	0.3	12.6	1,960.4	0.4	0.6	24 #	24 #	20 #
Minimum:	-2.6	11.8	1,560.4	-1.7	0.5	1	1	0
Maximum:	0.7	13.9	2,143.7	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/20/2021 00:00	-0.7	12.5	2,010.8	-0.2	0.6	1	1	1
07/20/2021 01:00	0.7	13.8	1,650.2	0.7	0.5	1	1	1
07/20/2021 02:00	0.6	13.9	1,659.6	0.6	0.5	1	1	0
07/20/2021 03:00	0.7	13.9	1,661.2	0.7	0.5	1	1	1
07/20/2021 04:00	-2.0	12.7	2,001.4	-1.2	0.6	1	1	1
07/20/2021 05:00	0.4	12.3	2,100.5	0.5	0.6	1	1	1
07/20/2021 06:00	0.2	13.6	1,651.5	0.4	0.5	1	1	1
07/20/2021 07:00	0.6	13.9	1,618.2	0.6	0.5	1	1	0
07/20/2021 08:00	0.6	13.9	1,568.9	0.6	0.5	1	1	0
07/20/2021 09:00	0.6	13.9	1,603.5	0.6	0.5	1	1	0
07/20/2021 10:00	0.6	13.9	1,639.1	0.6	0.5	1	1	0
07/20/2021 11:00	0.6	13.9	1,568.7	0.6	0.5	1	1	0
07/20/2021 12:00	0.7	13.9	1,636.5	0.7	0.5	1	1	1
07/20/2021 13:00	-1.1	12.7	1,978.7	-0.7	0.6	1	1	1
07/20/2021 14:00	0.5	12.0	2,080.2	0.5	0.6	1	1	1
07/20/2021 15:00	0.7	11.9	2,104.9	0.7	0.6	1	1	1
07/20/2021 16:00	0.7	11.8	2,128.0	0.7	0.6	1	1	1
07/20/2021 17:00	0.7	11.8	2,130.3	0.7	0.6	1	1	1
07/20/2021 18:00	0.7	11.8	2,132.8	0.7	0.6	1	1	1
07/20/2021 19:00	0.7	11.8	2,129.0	0.7	0.6	1	1	1
07/20/2021 20:00	0.7	11.8	2,144.6	0.7	0.6	1	1	1
07/20/2021 21:00	0.5	12.0	2,103.2	0.5	0.6	1	1	1
07/20/2021 22:00	0.4	12.2	2,087.1	0.5	0.6	1	1	1
07/20/2021 23:00	0.2	12.2	2,071.3	0.4	0.6	1	1	1
Average/Sum#:	0.3	12.8	1,894.2	0.4	0.6	24 #	24 #	18 #
Minimum:	-2.0	11.8	1,568.7	-1.2	0.5	1	1	0
Maximum:	0.7	13.9	2,144.6	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/21/2021 00:00	-1.1	12.7	1,969.4	-0.7	0.6	1	1	1
07/21/2021 01:00	0.6	13.9	1,609.0	0.6	0.5	1	1	0
07/21/2021 02:00	0.6	13.9	1,635.6	0.6	0.5	1	1	0
07/21/2021 03:00	-0.9	13.3	1,809.6	-0.7	0.5	1	1	1
07/21/2021 04:00	-0.5	12.6	1,986.5	-0.2	0.6	1	1	1
07/21/2021 05:00	0.6	13.9	1,596.8	0.6	0.5	1	1	0
07/21/2021 06:00	0.7	13.9	1,556.5	0.7	0.5	1	1	1
07/21/2021 07:00	-1.2	12.8	1,978.9	-0.7	0.6	1	1	1
07/21/2021 08:00	-2.3	12.9	1,918.1	-1.5	0.6	1	1	1
07/21/2021 09:00	0.6	13.9	1,664.0	0.6	0.5	1	1	0
07/21/2021 10:00	0.7	13.9	1,577.3	0.7	0.5	1	1	1
07/21/2021 11:00	-0.9	12.6	2,003.1	-0.5	0.6	1	1	1
07/21/2021 12:00	-0.2	12.3	2,052.4	0.1	0.6	1	1	1
07/21/2021 13:00	-0.1	12.3	2,060.2	0.2	0.6	1	1	1
07/21/2021 14:00	0.1	12.1	2,070.6	0.2	0.6	1	1	1
07/21/2021 15:00	0.2	12.1	2,087.0	0.4	0.6	1	1	1
07/21/2021 16:00	0.2	12.0	2,085.8	0.4	0.6	1	1	1
07/21/2021 17:00	0.4	12.0	2,102.3	0.5	0.6	1	1	1
07/21/2021 18:00	0.7	11.8	2,131.7	0.7	0.6	1	1	1
07/21/2021 19:00	0.7	11.8	2,133.7	0.7	0.6	1	1	1
07/21/2021 20:00	0.7	11.8	2,141.9	0.7	0.6	1	1	1
07/21/2021 21:00	0.5	12.0	2,116.8	0.5	0.6	1	1	1
07/21/2021 22:00	0.2	12.1	2,093.2	0.4	0.6	1	1	1
07/21/2021 23:00	-0.2	12.4	2,045.1	0.1	0.6	1	1	1
Average/Sum#:	0.0	12.7	1,934.4	0.2	0.6	24 #	24 #	20 #
Minimum:	-2.3	11.8	1,556.5	-1.5	0.5	1	1	0
Maximum:	0.7	13.9	2,141.9	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/22/2021 00:00	-1.2	12.7	1,966.0	-0.7	0.6	1	1	1
07/22/2021 01:00	0.6	13.9	1,636.5	0.6	0.5	1	1	0
07/22/2021 02:00	0.7	13.8	1,535.6	0.7	0.5	1	1	1
07/22/2021 03:00	-0.9	12.7	1,977.8	-0.5	0.6	1	1	1
07/22/2021 04:00	-1.2	12.9	1,923.0	-0.8	0.6	1	1	1
07/22/2021 05:00	0.6	13.9	1,577.5	0.6	0.5	1	1	0
07/22/2021 06:00	0.7	13.8	1,665.6	0.7	0.5	1	1	1
07/22/2021 07:00	-1.5	12.7	1,979.6	-0.9	0.6	1	1	1
07/22/2021 08:00	-2.6	12.9	1,928.8	-1.7	0.6	1	1	1
07/22/2021 09:00	0.7	13.8	1,590.3	0.7	0.5	1	1	1
07/22/2021 10:00	0.6	13.9	1,613.2	0.6	0.5	1	1	0
07/22/2021 11:00	0.7	13.7	1,730.7	0.7	0.5	1	1	1
07/22/2021 12:00	-1.4	12.5	2,028.7	-0.8	0.6	1	1	1
07/22/2021 13:00	0.2	12.0	2,128.6	0.4	0.6	1	1	1
07/22/2021 14:00	0.1	12.1	2,104.7	0.2	0.6	1	1	1
07/22/2021 15:00	0.1	12.1	2,100.7	0.2	0.6	1	1	1
07/22/2021 16:00	0.4	11.9	2,130.2	0.5	0.6	1	1	1
07/22/2021 17:00	0.4	12.0	2,115.4	0.5	0.6	1	1	1
07/22/2021 18:00	0.5	11.9	2,140.1	0.5	0.6	1	1	1
07/22/2021 19:00	0.5	11.9	2,133.9	0.5	0.6	1	1	1
07/22/2021 20:00	0.5	11.9	2,127.4	0.5	0.6	1	1	1
07/22/2021 21:00	-0.1	12.2	2,065.2	0.2	0.6	1	1	1
07/22/2021 22:00	-0.2	12.3	2,054.6	0.1	0.6	1	1	1
07/22/2021 23:00	-0.7	12.5	1,986.9	-0.2	0.6	1	1	1
Average/Sum#:	-0.1	12.8	1,926.7	0.1	0.6	24 #	24 #	21 #
Minimum:	-2.6	11.9	1,535.6	-1.7	0.5	1	1	0
Maximum:	0.7	13.9	2,140.1	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/23/2021 00:00	0.6	13.9	1,649.8	0.6	0.5	1	1	0
07/23/2021 01:00	0.7	13.9	1,621.3	0.7	0.5	1	1	1
07/23/2021 02:00	-1.2	12.8	1,980.5	-0.7	0.6	1	1	1
07/23/2021 03:00	-1.7	13.0	1,904.4	-1.1	0.6	1	1	1
07/23/2021 04:00	0.6	13.9	1,655.8	0.6	0.5	1	1	0
07/23/2021 05:00	0.6	13.9	1,623.0	0.6	0.5	1	1	0
07/23/2021 06:00	0.6	13.9	1,634.9	0.6	0.5	1	1	0
07/23/2021 07:00	0.6	13.9	1,610.7	0.6	0.5	1	1	0
07/23/2021 08:00	0.6	13.9	1,648.3	0.6	0.5	1	1	0
07/23/2021 09:00	0.6	13.9	1,632.5	0.6	0.5	1	1	0
07/23/2021 10:00	0.6	13.9	1,672.3	0.6	0.5	1	1	0
07/23/2021 11:00	0.4	13.8	1,683.2	0.4	0.5	1	1	1
07/23/2021 12:00	-0.8	12.3	2,057.3	-0.4	0.6	1	1	1
07/23/2021 13:00	0.7	11.8	2,147.1	0.7	0.6	1	1	1
07/23/2021 14:00	0.7	11.8	2,144.2	0.7	0.6	1	1	1
07/23/2021 15:00	0.7	11.8	2,147.1	0.7	0.6	1	1	1
07/23/2021 16:00	0.7	11.8	2,147.4	0.7	0.6	1	1	1
07/23/2021 17:00	0.7	11.8	2,150.6	0.7	0.6	1	1	1
07/23/2021 18:00	0.7	11.8	2,149.6	0.7	0.6	1	1	1
07/23/2021 19:00	0.7	11.8	2,150.1	0.7	0.6	1	1	1
07/23/2021 20:00	0.7	11.9	2,142.8	0.7	0.6	1	1	1
07/23/2021 21:00	0.2	12.1	2,098.2	0.4	0.6	1	1	1
07/23/2021 22:00	-0.4	12.4	2,041.0	-0.1	0.6	1	1	1
07/23/2021 23:00	-0.5	12.4	2,037.4	-0.2	0.6	1	1	1
Average/Sum#:	0.3	12.9	1,905.4	0.4	0.6	24 #	24 #	16 #
Minimum:	-1.7	11.8	1,610.7	-1.1	0.5	1	1	0
Maximum:	0.7	13.9	2,150.6	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/24/2021 00:00	-0.5	12.5	2,024.5	-0.2	0.6	1	1	1
07/24/2021 01:00	-2.0	12.9	1,904.0	-1.2	0.6	1	1	1
07/24/2021 02:00	0.6	13.9	1,628.7	0.6	0.5	1	1	0
07/24/2021 03:00	0.7	13.9	1,695.4	0.7	0.5	1	1	1
07/24/2021 04:00	-2.3	12.8	1,975.1	-1.5	0.6	1	1	1
07/24/2021 05:00	-2.6	13.0	1,916.7	-1.7	0.6	1	1	1
07/24/2021 06:00	0.6	13.9	1,622.6	0.6	0.5	1	1	0
07/24/2021 07:00	0.6	13.9	1,582.5	0.6	0.5	1	1	0
07/24/2021 08:00	0.6	13.9	1,593.8	0.6	0.5	1	1	0
07/24/2021 09:00	0.6	13.9	1,622.7	0.6	0.5	1	1	0
07/24/2021 10:00	0.6	13.9	1,587.8	0.6	0.5	1	1	0
07/24/2021 11:00	0.7	13.9	1,613.8	0.7	0.5	1	1	1
07/24/2021 12:00	-1.8	12.6	1,995.9	-1.1	0.6	1	1	1
07/24/2021 13:00	-0.2	12.1	2,074.0	0.1	0.6	1	1	1
07/24/2021 14:00	-0.2	12.2	2,033.6	0.1	0.6	1	1	1
07/24/2021 15:00	0.6	13.9	1,648.3	0.6	0.5	1	1	0
07/24/2021 16:00	0.7	13.9	1,670.3	0.7	0.5	1	1	1
07/24/2021 17:00	-1.5	12.5	1,995.3	-0.9	0.6	1	1	1
07/24/2021 18:00	0.1	12.0	2,084.0	0.2	0.6	1	1	1
07/24/2021 19:00	0.7	11.8	2,137.7	0.7	0.6	1	1	1
07/24/2021 20:00	0.7	11.8	2,142.0	0.7	0.6	1	1	1
07/24/2021 21:00	0.4	11.9	2,113.9	0.5	0.6	1	1	1
07/24/2021 22:00	-0.1	12.2	2,060.9	0.2	0.6	1	1	1
07/24/2021 23:00	0.1	12.2	2,073.4	0.2	0.6	1	1	1
Average/Sum#:	-0.1	13.0	1,866.5	0.1	0.6	24 #	24 #	17 #
Minimum:	-2.6	11.8	1,582.5	-1.7	0.5	1	1	0
Maximum:	0.7	13.9	2,142.0	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/25/2021 00:00	-1.4	12.8	1,921.7	-0.8	0.6	1	1	1
07/25/2021 01:00	0.6	13.9	1,618.3	0.6	0.5	1	1	0
07/25/2021 02:00	0.7	13.9	1,569.9	0.7	0.5	1	1	1
07/25/2021 03:00	-0.8	12.6	1,986.5	-0.4	0.6	1	1	1
07/25/2021 04:00	-1.2	12.9	1,906.0	-0.8	0.6	1	1	1
07/25/2021 05:00	0.6	13.9	1,646.6	0.6	0.5	1	1	0
07/25/2021 06:00	0.6	13.9	1,635.3	0.6	0.5	1	1	0
07/25/2021 07:00	0.6	13.9	1,645.9	0.6	0.5	1	1	0
07/25/2021 08:00	0.6	13.9	1,658.8	0.6	0.5	1	1	0
07/25/2021 09:00	0.6	13.9	1,652.5	0.6	0.5	1	1	0
07/25/2021 10:00	0.6	13.9	1,651.5	0.6	0.5	1	1	0
07/25/2021 11:00	0.7	13.9	1,508.0	0.7	0.5	1	1	1
07/25/2021 12:00	-1.1	12.4	2,032.8	-0.5	0.6	1	1	1
07/25/2021 13:00	-0.1	12.1	2,043.7	0.2	0.6	1	1	1
07/25/2021 14:00	0.6	13.8	1,646.0	0.6	0.5	1	1	0
07/25/2021 15:00	0.6	13.7	1,678.7	0.6	0.5	1	1	0
07/25/2021 16:00	0.7	13.7	1,679.0	0.7	0.5	1	1	1
07/25/2021 17:00	-0.8	12.2	2,023.5	-0.4	0.6	1	1	1
07/25/2021 18:00	0.5	11.8	2,113.1	0.5	0.6	1	1	1
07/25/2021 19:00	0.4	12.0	2,085.4	0.5	0.6	1	1	1
07/25/2021 20:00	0.1	12.2	2,052.2	0.2	0.6	1	1	1
07/25/2021 21:00	-0.2	12.3	2,018.7	0.1	0.6	1	1	1
07/25/2021 22:00	-0.4	12.4	2,007.0	-0.1	0.6	1	1	1
07/25/2021 23:00	-0.2	12.4	2,027.4	0.1	0.6	1	1	1
Average/Sum#:	0.1	13.1	1,825.4	0.3	0.6	24 #	24 #	15 #
Minimum:	-1.4	11.8	1,508.0	-0.8	0.5	1	1	0
Maximum:	0.7	13.9	2,113.1	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/26/2021 00:00	-1.8	12.8	1,917.7	-1.1	0.6	1	1	1
07/26/2021 01:00	0.6	13.9	1,586.0	0.6	0.5	1	1	0
07/26/2021 02:00	0.7	13.9	1,608.8	0.7	0.5	1	1	1
07/26/2021 03:00	-0.7	12.7	1,972.0	-0.2	0.6	1	1	1
07/26/2021 04:00	-0.1	12.5	1,993.3	0.1	0.6	1	1	1
07/26/2021 05:00	0.7	13.8	1,659.8	0.7	0.5	1	1	1
07/26/2021 06:00	0.6	13.9	1,587.1	0.6	0.5	1	1	0
07/26/2021 07:00	0.6	13.9	1,504.7	0.6	0.5	1	1	0
07/26/2021 08:00	0.6	13.9	1,650.7	0.6	0.5	1	1	0
07/26/2021 09:00	0.6	13.9	1,533.4	0.6	0.5	1	1	0
07/26/2021 10:00	0.7	13.8	1,642.4	0.7	0.5	1	1	1
07/26/2021 11:00	-1.8	12.6	2,000.8	-1.1	0.6	1	1	1
07/26/2021 12:00	0.2	11.9	2,121.8	0.4	0.6	1	1	1
07/26/2021 13:00	0.4	12.0	2,119.2	0.5	0.6	1	1	1
07/26/2021 14:00	0.2	12.1	2,095.6	0.4	0.6	1	1	1
07/26/2021 15:00	0.5	11.8	2,140.9	0.5	0.6	1	1	1
07/26/2021 16:00	0.5	11.8	2,142.0	0.5	0.6	1	1	1
07/26/2021 17:00	0.4	11.9	2,124.4	0.5	0.6	1	1	1
07/26/2021 18:00	0.5	11.9	2,127.0	0.5	0.6	1	1	1
07/26/2021 19:00	0.4	11.9	2,126.3	0.5	0.6	1	1	1
07/26/2021 20:00	0.2	11.9	2,126.3	0.4	0.6	1	1	1
07/26/2021 21:00	0.4	11.9	2,152.1	0.5	0.6	1	1	1
07/26/2021 22:00	0.1	12.1	2,105.2	0.2	0.6	1	1	1
07/26/2021 23:00	-1.1	12.6	1,976.6	-0.7	0.6	1	1	1
Average/Sum#:	0.1	12.7	1,917.3	0.3	0.6	24 #	24 #	19 #
Minimum:	-1.8	11.8	1,504.7	-1.1	0.5	1	1	0
Maximum:	0.7	13.9	2,152.1	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/27/2021 00:00	0.6	13.9	1,591.4	0.6	0.5	1	1	0
07/27/2021 01:00	0.7	13.9	1,659.8	0.7	0.5	1	1	1
07/27/2021 02:00	-4.1	13.0	1,912.0	-2.9	0.6	1	1	1
07/27/2021 03:00	-3.9	13.0	1,884.5	-2.7	0.6	1	1	1
07/27/2021 04:00	0.6	13.9	1,614.5	0.6	0.5	1	1	0
07/27/2021 05:00	0.7	13.9	1,696.3	0.7	0.5	1	1	1
07/27/2021 06:00	-2.0	12.7	1,994.8	-1.2	0.6	1	1	1
07/27/2021 07:00	-2.3	12.9	1,934.5	-1.5	0.6	1	1	1
07/27/2021 08:00	0.6	13.9	1,639.3	0.6	0.5	1	1	0
07/27/2021 09:00	0.6	13.9	1,653.7	0.6	0.5	1	1	0
07/27/2021 10:00	0.6	13.9	1,657.0	0.6	0.5	1	1	0
07/27/2021 11:00	0.6	13.9	1,668.3	0.6	0.5	1	1	0
07/27/2021 12:00	-1.7	12.6	2,016.6	-0.9	0.6	1	1	1
07/27/2021 13:00	0.1	12.0	2,135.2	0.2	0.6	1	1	1
07/27/2021 14:00	0.2	12.1	2,134.1	0.4	0.6	1	1	1
07/27/2021 15:00	0.2	12.1	2,129.9	0.4	0.6	1	1	1
07/27/2021 16:00	0.1	12.2	2,097.5	0.2	0.6	1	1	1
07/27/2021 17:00	0.2	12.0	2,133.9	0.4	0.6	1	1	1
07/27/2021 18:00	0.4	12.0	2,143.9	0.5	0.6	1	1	1
07/27/2021 19:00	0.2	12.0	2,146.6	0.4	0.6	1	1	1
07/27/2021 20:00	0.2	12.0	2,147.9	0.4	0.6	1	1	1
07/27/2021 21:00	0.2	12.0	2,146.4	0.4	0.6	1	1	1
07/27/2021 22:00	0.2	12.1	2,128.4	0.4	0.6	1	1	1
07/27/2021 23:00	0.1	12.2	2,119.7	0.2	0.6	1	1	1
Average/Sum#:	-0.3	12.8	1,932.8	0.0	0.6	24 #	24 #	18 #
Minimum:	-4.1	12.0	1,591.4	-2.9	0.5	1	1	0
Maximum:	0.7	13.9	2,147.9	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/28/2021 00:00	-0.1	12.3	2,084.0	0.2	0.6	1	1	1
07/28/2021 01:00	-2.4	13.0	1,910.8	-1.7	0.6	1	1	1
07/28/2021 02:00	0.6	13.9	1,648.8	0.6	0.5	1	1	0
07/28/2021 03:00	0.7	13.9	1,638.9	0.7	0.5	1	1	1
07/28/2021 04:00	-1.7	12.7	2,001.1	-1.1	0.6	1	1	1
07/28/2021 05:00	0.2	12.2	2,119.3	0.4	0.6	1	1	1
07/28/2021 06:00	-0.5	12.4	2,051.9	-0.2	0.6	1	1	1
07/28/2021 07:00	0.6	13.9	1,625.2	0.6	0.5	1	1	0
07/28/2021 08:00	0.7	13.9	1,665.1	0.7	0.5	1	1	1
07/28/2021 09:00	-0.7	12.3	2,042.5	-0.2	0.6	1	1	1
07/28/2021 10:00	0.5	11.8	2,134.9	0.5	0.6	1	1	1
07/28/2021 11:00	0.7	11.8	2,139.3	0.7	0.6	1	1	1
07/28/2021 12:00	0.7	11.8	2,134.6	0.7	0.6	1	1	1
07/28/2021 13:00	0.7	11.8	2,138.0	0.7	0.6	1	1	1
07/28/2021 14:00	0.7	11.8	2,136.4	0.7	0.6	1	1	1
07/28/2021 15:00	0.7	11.8	2,121.5	0.7	0.6	1	1	1
07/28/2021 16:00	0.7	11.8	2,129.0	0.7	0.6	1	1	1
07/28/2021 17:00	0.7	11.8	2,125.0	0.7	0.6	1	1	1
07/28/2021 18:00	0.7	11.8	2,114.1	0.7	0.6	1	1	1
07/28/2021 19:00	0.5	11.9	2,096.7	0.5	0.6	1	1	1
07/28/2021 20:00	0.4	12.0	2,082.4	0.5	0.6	1	1	1
07/28/2021 21:00	0.7	11.8	2,131.3	0.7	0.6	1	1	1
07/28/2021 22:00	0.5	12.0	2,109.8	0.5	0.6	1	1	1
07/28/2021 23:00	0.4	11.9	2,120.6	0.5	0.6	1	1	1
Average/Sum#:	0.3	12.3	2,020.9	0.4	0.6	24 #	24 #	22 #
Minimum:	-2.4	11.8	1,625.2	-1.7	0.5	1	1	0
Maximum:	0.7	13.9	2,139.3	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/29/2021 00:00	0.5	11.8	2,147.7	0.5	0.6	1	1	1
07/29/2021 01:00	0.4	11.9	2,121.2	0.5	0.6	1	1	1
07/29/2021 02:00	0.4	13.6	1,583.8	0.4	0.5	1	1	1
07/29/2021 03:00	0.7	13.9	1,688.6	0.7	0.5	1	1	1
07/29/2021 04:00	-1.2	12.6	2,008.6	-0.7	0.6	1	1	1
07/29/2021 05:00	0.2	12.1	2,117.5	0.4	0.6	1	1	1
07/29/2021 06:00	-0.5	12.5	2,026.8	-0.2	0.6	1	1	1
07/29/2021 07:00	0.6	13.9	1,617.3	0.6	0.5	1	1	0
07/29/2021 08:00	0.7	13.8	1,645.9	0.7	0.5	1	1	1
07/29/2021 09:00	-1.8	12.6	1,965.2	-1.1	0.6	1	1	1
07/29/2021 10:00	0.5	11.8	2,131.6	0.5	0.6	1	1	1
07/29/2021 11:00	0.7	11.8	2,132.3	0.7	0.6	1	1	1
07/29/2021 12:00	0.7	11.8	2,130.5	0.7	0.6	1	1	1
07/29/2021 13:00	0.7	11.7	2,127.4	0.7	0.6	1	1	1
07/29/2021 14:00	0.7	11.7	2,117.5	0.7	0.6	1	1	1
07/29/2021 15:00	0.7	11.7	2,110.6	0.7	0.6	1	1	1
07/29/2021 16:00	0.7	11.7	2,107.1	0.7	0.6	1	1	1
07/29/2021 17:00	0.7	11.7	2,109.8	0.7	0.6	1	1	1
07/29/2021 18:00	0.7	11.7	2,110.3	0.7	0.6	1	1	1
07/29/2021 19:00	0.7	11.7	2,112.1	0.7	0.6	1	1	1
07/29/2021 20:00	0.5	11.8	2,102.6	0.5	0.6	1	1	1
07/29/2021 21:00	0.7	11.8	2,119.3	0.7	0.6	1	1	1
07/29/2021 22:00	0.5	11.9	2,117.9	0.5	0.6	1	1	1
07/29/2021 23:00	0.5	11.9	2,112.8	0.5	0.6	1	1	1
Average/Sum#:	0.4	12.2	2,023.5	0.5	0.6	24 #	24 #	23 #
Minimum:	-1.8	11.7	1,583.8	-1.1	0.5	1	1	0
Maximum:	0.7	13.9	2,147.7	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/30/2021 00:00	0.4	12.0	2,101.0	0.5	0.6	1	1	1
07/30/2021 01:00	-0.1	12.2	2,044.9	0.2	0.6	1	1	1
07/30/2021 02:00	0.5	13.8	1,657.9	0.5	0.5	1	1	1
07/30/2021 03:00	0.7	13.8	1,698.6	0.7	0.5	1	1	1
07/30/2021 04:00	-0.8	12.4	2,027.8	-0.4	0.6	1	1	1
07/30/2021 05:00	0.5	11.9	2,145.3	0.5	0.6	1	1	1
07/30/2021 06:00	0.4	11.9	2,127.9	0.5	0.6	1	1	1
07/30/2021 07:00	0.5	11.9	2,135.8	0.5	0.6	1	1	1
07/30/2021 08:00	0.5	11.9	2,119.7	0.5	0.6	1	1	1
07/30/2021 09:00	0.7	11.8	2,141.0	0.7	0.6	1	1	1
07/30/2021 10:00	0.7	11.8	2,137.2	0.7	0.6	1	1	1
07/30/2021 11:00	0.7	11.7	2,143.6	0.7	0.6	1	1	1
07/30/2021 12:00	0.7	11.7	2,141.3	0.7	0.6	1	1	1
07/30/2021 13:00	0.7	11.6	2,136.5	0.7	0.6	1	1	1
07/30/2021 14:00	0.7	11.6	2,129.0	0.7	0.6	1	1	1
07/30/2021 15:00	0.7	11.7	2,124.5	0.7	0.6	1	1	1
07/30/2021 16:00	0.7	11.7	2,120.2	0.7	0.6	1	1	1
07/30/2021 17:00	0.7	11.7	2,118.8	0.7	0.6	1	1	1
07/30/2021 18:00	0.7	11.7	2,117.4	0.7	0.6	1	1	1
07/30/2021 19:00	0.7	11.6	2,130.8	0.7	0.6	1	1	1
07/30/2021 20:00	0.7	11.6	2,138.7	0.7	0.6	1	1	1
07/30/2021 21:00	0.7	11.7	2,127.4	0.7	0.6	1	1	1
07/30/2021 22:00	0.7	11.7	2,133.5	0.7	0.6	1	1	1
07/30/2021 23:00	0.7	11.7	2,145.3	0.7	0.6	1	1	1
Average/Sum#:	0.5	12.0	2,085.2	0.6	0.6	24 #	24 #	24 #
Minimum:	-0.8	11.6	1,657.9	-0.4	0.5	1	1	1
Maximum:	0.7	13.8	2,145.3	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/31/2021 00:00	0.7	11.7	2,171.5	0.7	0.7	1	1	1
07/31/2021 01:00	0.7	11.8	2,167.1	0.7	0.7	1	1	1
07/31/2021 02:00	0.5	12.0	2,135.1	0.5	0.6	1	1	1
07/31/2021 03:00	0.5	13.6	1,662.2	0.5	0.5	1	1	1
07/31/2021 04:00	0.6	13.7	1,738.8	0.6	0.5	1	1	0
07/31/2021 05:00	-1.7	13.1	1,885.5	-1.1	0.6	1	1	1
07/31/2021 06:00	-0.4	12.4	2,050.9	-0.1	0.6	1	1	1
07/31/2021 07:00	0.6	13.9	1,653.5	0.6	0.5	1	1	0
07/31/2021 08:00	0.7	13.9	1,556.8	0.7	0.5	1	1	1
07/31/2021 09:00	-1.5	12.6	1,991.9	-0.9	0.6	1	1	1
07/31/2021 10:00	-0.2	12.3	2,042.1	0.1	0.6	1	1	1
07/31/2021 11:00	-0.1	12.3	2,052.9	0.2	0.6	1	1	1
07/31/2021 12:00	-0.1	12.2	2,063.6	0.2	0.6	1	1	1
07/31/2021 13:00	-0.1	12.2	2,055.3	0.2	0.6	1	1	1
07/31/2021 14:00	-0.1	12.2	2,059.5	0.2	0.6	1	1	1
07/31/2021 15:00	0.1	12.1	2,067.7	0.2	0.6	1	1	1
07/31/2021 16:00	0.2	12.0	2,071.5	0.4	0.6	1	1	1
07/31/2021 17:00	0.4	11.9	2,101.0	0.5	0.6	1	1	1
07/31/2021 18:00	0.5	11.9	2,120.4	0.5	0.6	1	1	1
07/31/2021 19:00	0.5	11.9	2,113.7	0.5	0.6	1	1	1
07/31/2021 20:00	0.7	11.8	2,148.5	0.7	0.6	1	1	1
07/31/2021 21:00	0.5	11.9	2,139.0	0.5	0.6	1	1	1
07/31/2021 22:00	0.4	12.0	2,113.7	0.5	0.6	1	1	1
07/31/2021 23:00	-0.1	12.3	2,057.7	0.2	0.6	1	1	1
Average/Sum#:	0.1	12.4	2,009.2	0.3	0.6	24 #	24 #	22 #
Minimum:	-1.7	11.7	1,556.8	-1.1	0.5	1	1	0
Maximum:	0.7	13.9	2,171.5	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/01/2021 00:00	-1.8	12.8	1,926.0	-1.1	0.6	1	1	1
08/01/2021 01:00	0.6	13.9	1,622.4	0.6	0.5	1	1	0
08/01/2021 02:00	0.7	13.8	1,665.8	0.7	0.5	1	1	1
08/01/2021 03:00	-1.5	12.7	1,987.6	-0.9	0.6	1	1	1
08/01/2021 04:00	-1.4	12.8	1,950.4	-0.8	0.6	1	1	1
08/01/2021 05:00	0.6	13.9	1,652.6	0.6	0.5	1	1	0
08/01/2021 06:00	0.6	13.9	1,602.6	0.6	0.5	1	1	0
08/01/2021 07:00	0.6	13.9	1,593.7	0.6	0.5	1	1	0
08/01/2021 08:00	0.6	13.9	1,393.0	0.6	0.4	1	1	0
08/01/2021 09:00	0.7	13.9	1,539.5	0.7	0.5	1	1	1
08/01/2021 10:00	-1.7	12.6	2,000.8	-0.9	0.6	1	1	1
08/01/2021 11:00	-1.1	12.6	1,965.6	-0.7	0.6	1	1	1
08/01/2021 12:00	0.6	13.9	1,598.3	0.6	0.5	1	1	0
08/01/2021 13:00	0.6	13.8	1,643.0	0.6	0.5	1	1	0
08/01/2021 14:00	0.6	13.8	1,654.7	0.6	0.5	1	1	0
08/01/2021 15:00	0.6	13.8	1,673.6	0.6	0.5	1	1	0
08/01/2021 16:00	-0.7	13.2	1,782.2	-0.4	0.5	1	1	1
08/01/2021 17:00	0.5	11.8	2,137.7	0.5	0.6	1	1	1
08/01/2021 18:00	0.7	11.7	2,170.2	0.7	0.7	1	1	1
08/01/2021 19:00	0.7	11.8	2,161.9	0.7	0.6	1	1	1
08/01/2021 20:00	0.7	11.7	2,178.7	0.7	0.7	1	1	1
08/01/2021 21:00	0.7	11.7	2,185.4	0.7	0.7	1	1	1
08/01/2021 22:00	0.7	11.8	2,171.6	0.7	0.7	1	1	1
08/01/2021 23:00	0.5	11.9	2,148.3	0.5	0.6	1	1	1
Average/Sum#:	0.1	13.0	1,850.2	0.3	0.6	24 #	24 #	15 #
Minimum:	-1.8	11.7	1,393.0	-1.1	0.4	1	1	0
Maximum:	0.7	13.9	2,185.4	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/02/2021 00:00	0.7	11.9	2,165.2	0.7	0.6	1	1	1
08/02/2021 01:00	0.4	12.1	2,135.9	0.5	0.6	1	1	1
08/02/2021 02:00	0.4	13.7	1,624.9	0.4	0.5	1	1	1
08/02/2021 03:00	0.7	13.8	1,665.0	0.7	0.5	1	1	1
08/02/2021 04:00	-1.1	12.6	2,031.6	-0.7	0.6	1	1	1
08/02/2021 05:00	0.4	12.0	2,170.4	0.5	0.7	1	1	1
08/02/2021 06:00	-0.1	12.4	2,104.8	0.2	0.6	1	1	1
08/02/2021 07:00	0.4	13.6	1,666.9	0.4	0.5	1	1	1
08/02/2021 08:00	0.6	13.8	1,570.7	0.6	0.5	1	1	0
08/02/2021 09:00	-1.4	12.7	2,013.4	-0.8	0.6	1	1	1
08/02/2021 10:00	0.2	12.1	2,112.0	0.4	0.6	1	1	1
08/02/2021 11:00	0.5	12.0	2,126.2	0.5	0.6	1	1	1
08/02/2021 12:00	0.4	12.1	2,111.3	0.5	0.6	1	1	1
08/02/2021 13:00	0.2	12.1	2,109.2	0.4	0.6	1	1	1
08/02/2021 14:00	0.2	12.1	2,102.4	0.4	0.6	1	1	1
08/02/2021 15:00	0.2	12.1	2,100.4	0.4	0.6	1	1	1
08/02/2021 16:00	0.2	12.1	2,100.3	0.4	0.6	1	1	1
08/02/2021 17:00	0.4	12.0	2,115.4	0.5	0.6	1	1	1
08/02/2021 18:00	0.7	11.8	2,163.2	0.7	0.6	1	1	1
08/02/2021 19:00	0.7	11.7	2,174.9	0.7	0.7	1	1	1
08/02/2021 20:00	0.7	11.8	2,182.3	0.7	0.7	1	1	1
08/02/2021 21:00	0.7	11.8	2,187.4	0.7	0.7	1	1	1
08/02/2021 22:00	0.7	11.8	2,189.6	0.7	0.7	1	1	1
08/02/2021 23:00	0.7	11.8	2,192.8	0.7	0.7	1	1	1
Average/Sum#:	0.3	12.3	2,046.5	0.4	0.6	24 #	24 #	23 #
Minimum:	-1.4	11.7	1,570.7	-0.8	0.5	1	1	0
Maximum:	0.7	13.8	2,192.8	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/03/2021 00:00	0.5	12.0	2,150.5	0.5	0.6	1	1	1
08/03/2021 01:00	0.5	12.0	2,142.2	0.5	0.6	1	1	1
08/03/2021 02:00	0.5	13.6	1,706.1	0.5	0.5	1	1	1
08/03/2021 03:00	0.7	13.8	1,743.4	0.7	0.5	1	1	1
08/03/2021 04:00	0.0	13.0	1,929.7	0.0	0.6	1	0	1
08/03/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/03/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/03/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/03/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/03/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/03/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/03/2021 11:00	0.0	16.6	578.5	0.0	0.2	1	0	0
08/03/2021 12:00	0.0	14.1	1,305.3	0.0	0.4	1	0	0
08/03/2021 13:00	0.7	13.8	1,681.1	0.7	0.5	1	1	1
08/03/2021 14:00	0.1	12.3	2,042.2	0.2	0.6	1	1	1
08/03/2021 15:00	0.7	12.1	2,097.4	0.7	0.6	1	1	1
08/03/2021 16:00	0.7	12.0	2,102.5	0.7	0.6	1	1	1
08/03/2021 17:00	0.7	12.0	2,114.9	0.7	0.6	1	1	1
08/03/2021 18:00	0.7	11.8	2,157.6	0.7	0.6	1	1	1
08/03/2021 19:00	0.7	11.7	2,165.7	0.7	0.6	1	1	1
08/03/2021 20:00	0.7	11.7	2,174.2	0.7	0.7	1	1	1
08/03/2021 21:00	0.7	11.7	2,172.4	0.7	0.7	1	1	1
08/03/2021 22:00	0.7	11.8	2,167.7	0.7	0.7	1	1	1
08/03/2021 23:00	0.7	11.9	2,151.9	0.7	0.6	1	1	1
Average/Sum#:	0.5	12.7	1,921.3	0.5	0.6	18 #	15 #	16 #
Minimum:	0.0	11.7	578.5	0.0	0.2	0	0	0
Maximum:	0.7	16.6	2,174.2	0.7	0.7	1	1	1
%SI	25.00	25.00	25.00	25.00	25.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/04/2021 00:00	0.5	12.4	2,031.1	0.5	0.6	1	1	1
08/04/2021 01:00	0.6	13.9	1,635.9	0.6	0.5	1	1	0
08/04/2021 02:00	0.7	13.7	1,741.2	0.7	0.5	1	1	1
08/04/2021 03:00	-0.9	12.7	2,000.0	-0.5	0.6	1	1	1
08/04/2021 04:00	0.7	12.0	2,147.6	0.7	0.6	1	1	1
08/04/2021 05:00	0.7	11.9	2,169.2	0.7	0.7	1	1	1
08/04/2021 06:00	0.5	12.4	2,053.5	0.5	0.6	1	1	1
08/04/2021 07:00	-0.8	12.8	1,920.2	-0.4	0.6	1	1	1
08/04/2021 08:00	0.6	13.9	1,608.0	0.6	0.5	1	1	0
08/04/2021 09:00	0.6	13.8	1,679.0	0.6	0.5	1	1	0
08/04/2021 10:00	-0.4	12.6	2,001.1	-0.1	0.6	1	1	1
08/04/2021 11:00	0.7	11.9	2,120.9	0.7	0.6	1	1	1
08/04/2021 12:00	0.7	12.0	2,095.2	0.7	0.6	1	1	1
08/04/2021 13:00	0.7	12.0	2,089.5	0.7	0.6	1	1	1
08/04/2021 14:00	0.7	12.0	2,088.2	0.7	0.6	1	1	1
08/04/2021 15:00	0.7	11.9	2,091.3	0.7	0.6	1	1	1
08/04/2021 16:00	0.7	11.8	2,112.6	0.7	0.6	1	1	1
08/04/2021 17:00	0.7	11.8	2,122.7	0.7	0.6	1	1	1
08/04/2021 18:00	0.7	11.8	2,136.8	0.7	0.6	1	1	1
08/04/2021 19:00	0.7	11.7	2,149.2	0.7	0.6	1	1	1
08/04/2021 20:00	0.7	11.7	2,162.6	0.7	0.6	1	1	1
08/04/2021 21:00	0.7	11.7	2,174.4	0.7	0.7	1	1	1
08/04/2021 22:00	0.7	11.8	2,177.9	0.7	0.7	1	1	1
08/04/2021 23:00	0.7	12.1	2,112.1	0.7	0.6	1	1	1
Average/Sum#:	0.5	12.3	2,025.8	0.5	0.6	24 #	24 #	21 #
Minimum:	-0.9	11.7	1,608.0	-0.5	0.5	1	1	0
Maximum:	0.7	13.9	2,177.9	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/05/2021 00:00	0.7	12.2	2,100.7	0.7	0.6	1	1	1
08/05/2021 01:00	0.7	12.2	2,120.0	0.7	0.6	1	1	1
08/05/2021 02:00	0.7	12.2	2,118.7	0.7	0.6	1	1	1
08/05/2021 03:00	0.7	12.0	2,162.2	0.7	0.6	1	1	1
08/05/2021 04:00	0.7	12.0	2,170.9	0.7	0.7	1	1	1
08/05/2021 05:00	0.7	12.0	2,165.4	0.7	0.6	1	1	1
08/05/2021 06:00	-0.7	12.8	1,990.6	-0.4	0.6	1	1	1
08/05/2021 07:00	0.6	13.9	1,630.9	0.6	0.5	1	1	0
08/05/2021 08:00	0.7	13.9	1,609.8	0.7	0.5	1	1	1
08/05/2021 09:00	-2.0	13.0	1,939.5	-1.2	0.6	1	1	1
08/05/2021 10:00	0.1	12.5	2,007.0	0.2	0.6	1	1	1
08/05/2021 11:00	0.6	13.8	1,652.7	0.6	0.5	1	1	0
08/05/2021 12:00	0.7	13.8	1,720.3	0.7	0.5	1	1	1
08/05/2021 13:00	-0.2	12.5	2,007.3	0.1	0.6	1	1	1
08/05/2021 14:00	0.7	12.3	2,054.8	0.7	0.6	1	1	1
08/05/2021 15:00	0.7	12.2	2,064.2	0.7	0.6	1	1	1
08/05/2021 16:00	0.7	12.1	2,093.1	0.7	0.6	1	1	1
08/05/2021 17:00	0.7	12.2	2,071.3	0.7	0.6	1	1	1
08/05/2021 18:00	0.7	11.9	2,148.0	0.7	0.6	1	1	1
08/05/2021 19:00	0.7	11.8	2,162.0	0.7	0.6	1	1	1
08/05/2021 20:00	0.7	11.7	2,167.7	0.7	0.7	1	1	1
08/05/2021 21:00	0.7	11.9	2,137.4	0.7	0.6	1	1	1
08/05/2021 22:00	0.7	12.1	2,084.5	0.7	0.6	1	1	1
08/05/2021 23:00	0.7	12.3	2,061.4	0.7	0.6	1	1	1
Average/Sum#:	0.5	12.5	2,018.4	0.5	0.6	24 #	24 #	22 #
Minimum:	-2.0	11.7	1,609.8	-1.2	0.5	1	1	0
Maximum:	0.7	13.9	2,170.9	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/06/2021 00:00	0.5	12.4	2,006.9	0.5	0.6	1	1	1
08/06/2021 01:00	0.6	13.9	1,655.7	0.6	0.5	1	1	0
08/06/2021 02:00	0.6	13.9	1,650.5	0.6	0.5	1	1	0
08/06/2021 03:00	0.7	13.8	1,596.5	0.7	0.5	1	1	1
08/06/2021 04:00	-1.2	12.7	1,985.9	-0.7	0.6	1	1	1
08/06/2021 05:00	-0.1	12.5	2,005.7	0.1	0.6	1	1	1
08/06/2021 06:00	0.6	13.9	1,572.2	0.6	0.5	1	1	0
08/06/2021 07:00	0.6	13.9	1,638.9	0.6	0.5	1	1	0
08/06/2021 08:00	0.6	13.9	1,634.5	0.6	0.5	1	1	0
08/06/2021 09:00	-1.2	12.8	1,960.6	-0.7	0.6	1	1	1
08/06/2021 10:00	-0.9	12.8	1,933.7	-0.5	0.6	1	1	1
08/06/2021 11:00	0.6	13.9	1,630.7	0.6	0.5	1	1	0
08/06/2021 12:00	0.6	14.0	1,504.0	0.6	0.5	1	1	0
08/06/2021 13:00	-0.8	12.8	1,960.0	-0.4	0.6	1	1	1
08/06/2021 14:00	0.5	12.3	2,050.8	0.5	0.6	1	1	1
08/06/2021 15:00	0.5	12.3	2,039.2	0.5	0.6	1	1	1
08/06/2021 16:00	0.7	12.1	2,083.3	0.7	0.6	1	1	1
08/06/2021 17:00	0.7	12.0	2,094.5	0.7	0.6	1	1	1
08/06/2021 18:00	0.7	11.8	2,140.5	0.7	0.6	1	1	1
08/06/2021 19:00	0.7	12.0	2,093.1	0.7	0.6	1	1	1
08/06/2021 20:00	0.7	12.0	2,087.9	0.7	0.6	1	1	1
08/06/2021 21:00	0.5	12.1	2,063.0	0.5	0.6	1	1	1
08/06/2021 22:00	0.5	12.3	2,027.9	0.5	0.6	1	1	1
08/06/2021 23:00	-0.5	12.7	1,916.9	-0.2	0.6	1	1	1
Average/Sum#:	0.3	12.9	1,888.9	0.4	0.6	24 #	24 #	17 #
Minimum:	-1.2	11.8	1,504.0	-0.7	0.5	1	1	0
Maximum:	0.7	14.0	2,140.5	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/07/2021 00:00	0.6	13.9	1,660.6	0.6	0.5	1	1	0
08/07/2021 01:00	0.7	13.8	1,585.9	0.7	0.5	1	1	1
08/07/2021 02:00	-0.4	12.8	1,919.9	-0.1	0.6	1	1	1
08/07/2021 03:00	0.0	14.3	1,164.1	0.0	0.3	1	0	1
08/07/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/07/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/07/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/07/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/07/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/07/2021 09:00	0.0	18.7	181.5	0.0	0.1	1	0	0
08/07/2021 10:00	0.0	16.4	552.2	0.0	0.2	1	0	0
08/07/2021 11:00	0.0	15.9	597.4	0.0	0.2	1	0	0
08/07/2021 12:00	0.0	16.0	737.1	0.0	0.2	1	0	0
08/07/2021 13:00	0.6	13.9	1,548.6	0.6	0.5	1	1	0
08/07/2021 14:00	0.6	13.9	1,453.5	0.6	0.4	1	1	0
08/07/2021 15:00	0.6	13.9	1,620.2	0.6	0.5	1	1	0
08/07/2021 16:00	0.7	14.0	1,498.8	0.7	0.4	1	1	1
08/07/2021 17:00	-0.2	12.5	1,986.9	0.1	0.6	1	1	1
08/07/2021 18:00	0.5	12.1	2,049.2	0.5	0.6	1	1	1
08/07/2021 19:00	0.5	12.4	1,973.2	0.5	0.6	1	1	1
08/07/2021 20:00	0.6	13.8	1,646.0	0.6	0.5	1	1	0
08/07/2021 21:00	0.7	13.8	1,613.3	0.7	0.5	1	1	1
08/07/2021 22:00	-1.7	12.9	1,928.0	-1.1	0.6	1	1	1
08/07/2021 23:00	0.4	12.4	2,004.3	0.5	0.6	1	1	1
Average/Sum#:	0.2	14.1	1,459.0	0.3	0.4	19 #	14 #	10 #
Minimum:	-1.7	12.1	181.5	-1.1	0.1	0	0	0
Maximum:	0.7	18.7	2,049.2	0.7	0.6	1	1	1
%SI	20.83	20.83	20.83	20.83	20.83	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/08/2021 00:00	0.6	13.9	1,561.0	0.6	0.5	1	1	0
08/08/2021 01:00	0.7	13.8	1,529.1	0.7	0.5	1	1	1
08/08/2021 02:00	-2.4	13.0	1,908.5	-1.7	0.6	1	1	1
08/08/2021 03:00	0.2	13.7	1,462.5	0.4	0.4	1	1	1
08/08/2021 04:00	0.6	14.0	1,363.8	0.6	0.4	1	1	0
08/08/2021 05:00	0.6	14.0	1,350.3	0.6	0.4	1	1	0
08/08/2021 06:00	0.6	14.0	1,352.9	0.6	0.4	1	1	0
08/08/2021 07:00	0.6	14.0	1,357.3	0.6	0.4	1	1	0
08/08/2021 08:00	0.6	14.0	1,361.9	0.6	0.4	1	1	0
08/08/2021 09:00	0.6	14.0	1,362.8	0.6	0.4	1	1	0
08/08/2021 10:00	0.6	14.0	1,363.1	0.6	0.4	1	1	0
08/08/2021 11:00	0.6	14.0	1,367.2	0.6	0.4	1	1	0
08/08/2021 12:00	0.6	14.0	1,370.8	0.6	0.4	1	1	0
08/08/2021 13:00	0.6	14.0	1,438.0	0.6	0.4	1	1	0
08/08/2021 14:00	0.6	13.9	1,563.7	0.6	0.5	1	1	0
08/08/2021 15:00	0.6	13.9	1,469.3	0.6	0.4	1	1	0
08/08/2021 16:00	0.6	13.9	1,568.8	0.6	0.5	1	1	0
08/08/2021 17:00	0.1	13.2	1,745.4	0.2	0.5	1	1	1
08/08/2021 18:00	0.7	12.1	2,066.5	0.7	0.6	1	1	1
08/08/2021 19:00	0.7	12.0	2,088.5	0.7	0.6	1	1	1
08/08/2021 20:00	0.7	11.9	2,123.8	0.7	0.6	1	1	1
08/08/2021 21:00	0.7	12.0	2,085.2	0.7	0.6	1	1	1
08/08/2021 22:00	0.5	12.4	2,013.0	0.5	0.6	1	1	1
08/08/2021 23:00	-0.7	12.8	1,904.5	-0.4	0.6	1	1	1
Average/Sum#:	0.4	13.4	1,615.7	0.5	0.5	24 #	24 #	10 #
Minimum:	-2.4	11.9	1,350.3	-1.7	0.4	1	1	0
Maximum:	0.7	14.0	2,123.8	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/09/2021 00:00	0.6	13.9	1,554.3	0.6	0.5	1	1	0
08/09/2021 01:00	0.7	13.8	1,703.8	0.7	0.5	1	1	1
08/09/2021 02:00	-0.9	12.7	1,963.1	-0.5	0.6	1	1	1
08/09/2021 03:00	-1.4	12.9	1,906.6	-0.8	0.6	1	1	1
08/09/2021 04:00	0.6	13.9	1,652.3	0.6	0.5	1	1	0
08/09/2021 05:00	0.7	13.7	1,731.1	0.7	0.5	1	1	1
08/09/2021 06:00	-1.4	12.8	1,962.9	-0.8	0.6	1	1	1
08/09/2021 07:00	-0.4	12.6	1,959.9	-0.1	0.6	1	1	1
08/09/2021 08:00	0.6	13.9	1,553.5	0.6	0.5	1	1	0
08/09/2021 09:00	0.6	13.9	1,608.7	0.6	0.5	1	1	0
08/09/2021 10:00	0.6	13.8	1,641.4	0.6	0.5	1	1	0
08/09/2021 11:00	-0.9	12.7	1,955.3	-0.5	0.6	1	1	1
08/09/2021 12:00	0.7	12.1	2,018.6	0.7	0.6	1	1	1
08/09/2021 13:00	0.6	13.8	1,679.6	0.6	0.5	1	1	0
08/09/2021 14:00	0.2	13.2	1,773.7	0.4	0.5	1	1	1
08/09/2021 15:00	0.7	12.0	2,085.0	0.7	0.6	1	1	1
08/09/2021 16:00	0.7	11.9	2,093.5	0.7	0.6	1	1	1
08/09/2021 17:00	0.7	11.9	2,097.0	0.7	0.6	1	1	1
08/09/2021 18:00	0.7	11.9	2,099.9	0.7	0.6	1	1	1
08/09/2021 19:00	0.7	11.7	2,137.6	0.7	0.6	1	1	1
08/09/2021 20:00	0.7	11.7	2,149.8	0.7	0.6	1	1	1
08/09/2021 21:00	0.7	11.9	2,127.8	0.7	0.6	1	1	1
08/09/2021 22:00	0.7	12.3	2,048.8	0.7	0.6	1	1	1
08/09/2021 23:00	0.7	12.3	2,056.0	0.7	0.6	1	1	1
Average/Sum#:	0.3	12.8	1,898.3	0.4	0.6	24 #	24 #	18 #
Minimum:	-1.4	11.7	1,553.5	-0.8	0.5	1	1	0
Maximum:	0.7	13.9	2,149.8	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/10/2021 00:00	-0.1	12.6	1,960.3	0.1	0.6	1	1	1
08/10/2021 01:00	0.6	13.9	1,593.3	0.6	0.5	1	1	0
08/10/2021 02:00	0.6	13.9	1,596.1	0.6	0.5	1	1	0
08/10/2021 03:00	0.7	13.8	1,698.6	0.7	0.5	1	1	1
08/10/2021 04:00	-0.7	12.6	2,014.3	-0.2	0.6	1	1	1
08/10/2021 05:00	0.2	12.4	2,021.4	0.4	0.6	1	1	1
08/10/2021 06:00	0.6	13.9	1,620.6	0.6	0.5	1	1	0
08/10/2021 07:00	0.7	13.8	1,590.5	0.7	0.5	1	1	1
08/10/2021 08:00	-0.9	12.7	1,975.6	-0.5	0.6	1	1	1
08/10/2021 09:00	-0.8	12.9	1,909.7	-0.4	0.6	1	1	1
08/10/2021 10:00	0.6	13.9	1,660.0	0.6	0.5	1	1	0
08/10/2021 11:00	0.7	13.8	1,675.5	0.7	0.5	1	1	1
08/10/2021 12:00	-0.7	12.5	2,008.1	-0.2	0.6	1	1	1
08/10/2021 13:00	0.7	12.0	2,102.4	0.7	0.6	1	1	1
08/10/2021 14:00	0.7	11.9	2,102.6	0.7	0.6	1	1	1
08/10/2021 15:00	0.7	11.9	2,097.3	0.7	0.6	1	1	1
08/10/2021 16:00	0.7	11.9	2,107.9	0.7	0.6	1	1	1
08/10/2021 17:00	0.7	11.8	2,112.5	0.7	0.6	1	1	1
08/10/2021 18:00	0.7	11.7	2,145.2	0.7	0.6	1	1	1
08/10/2021 19:00	0.7	11.7	2,157.2	0.7	0.6	1	1	1
08/10/2021 20:00	0.7	11.7	2,159.3	0.7	0.6	1	1	1
08/10/2021 21:00	0.7	11.7	2,157.0	0.7	0.6	1	1	1
08/10/2021 22:00	0.7	12.0	2,100.8	0.7	0.6	1	1	1
08/10/2021 23:00	0.7	12.1	2,086.9	0.7	0.6	1	1	1
Average/Sum#:	0.4	12.6	1,943.9	0.5	0.6	24 #	24 #	20 #
Minimum:	-0.9	11.7	1,590.5	-0.5	0.5	1	1	0
Maximum:	0.7	13.9	2,159.3	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/11/2021 00:00	0.5	12.3	2,032.6	0.5	0.6	1	1	1
08/11/2021 01:00	0.6	13.8	1,656.6	0.6	0.5	1	1	0
08/11/2021 02:00	0.6	13.9	1,592.8	0.6	0.5	1	1	0
08/11/2021 03:00	0.6	13.9	1,581.0	0.6	0.5	1	1	0
08/11/2021 04:00	0.7	13.8	1,606.8	0.7	0.5	1	1	1
08/11/2021 05:00	-0.9	12.6	2,023.6	-0.5	0.6	1	1	1
08/11/2021 06:00	0.1	12.5	2,037.3	0.2	0.6	1	1	1
08/11/2021 07:00	0.6	13.9	1,622.1	0.6	0.5	1	1	0
08/11/2021 08:00	0.7	13.7	1,716.3	0.7	0.5	1	1	1
08/11/2021 09:00	-0.5	12.5	2,008.6	-0.2	0.6	1	1	1
08/11/2021 10:00	0.7	12.0	2,106.4	0.7	0.6	1	1	1
08/11/2021 11:00	0.7	12.0	2,108.9	0.7	0.6	1	1	1
08/11/2021 12:00	0.7	12.1	2,074.1	0.7	0.6	1	1	1
08/11/2021 13:00	0.7	12.1	2,078.0	0.7	0.6	1	1	1
08/11/2021 14:00	0.7	11.9	2,095.8	0.7	0.6	1	1	1
08/11/2021 15:00	0.5	12.1	2,037.4	0.5	0.6	1	1	1
08/11/2021 16:00	0.7	12.0	2,067.6	0.7	0.6	1	1	1
08/11/2021 17:00	0.7	11.9	2,091.5	0.7	0.6	1	1	1
08/11/2021 18:00	0.7	11.7	2,134.0	0.7	0.6	1	1	1
08/11/2021 19:00	0.7	11.7	2,137.5	0.7	0.6	1	1	1
08/11/2021 20:00	0.7	11.7	2,144.0	0.7	0.6	1	1	1
08/11/2021 21:00	0.7	11.8	2,117.6	0.7	0.6	1	1	1
08/11/2021 22:00	0.7	12.1	2,078.6	0.7	0.6	1	1	1
08/11/2021 23:00	0.7	12.2	2,083.5	0.7	0.6	1	1	1
Average/Sum#:	0.5	12.5	1,968.0	0.6	0.6	24 #	24 #	20 #
Minimum:	-0.9	11.7	1,581.0	-0.5	0.5	1	1	0
Maximum:	0.7	13.9	2,144.0	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/12/2021 00:00	0.4	12.3	2,043.0	0.5	0.6	1	1	1
08/12/2021 01:00	0.6	13.9	1,652.2	0.6	0.5	1	1	0
08/12/2021 02:00	0.7	13.8	1,606.3	0.7	0.5	1	1	1
08/12/2021 03:00	0.2	12.7	1,974.9	0.4	0.6	1	1	1
08/12/2021 04:00	0.1	12.6	1,974.7	0.2	0.6	1	1	1
08/12/2021 05:00	0.6	13.9	1,657.7	0.6	0.5	1	1	0
08/12/2021 06:00	0.7	13.8	1,736.6	0.7	0.5	1	1	1
08/12/2021 07:00	-0.9	12.7	1,981.0	-0.5	0.6	1	1	1
08/12/2021 08:00	-0.8	12.8	1,915.9	-0.4	0.6	1	1	1
08/12/2021 09:00	0.6	13.9	1,668.4	0.6	0.5	1	1	0
08/12/2021 10:00	0.7	13.9	1,680.0	0.7	0.5	1	1	1
08/12/2021 11:00	-0.2	12.5	2,006.9	0.1	0.6	1	1	1
08/12/2021 12:00	0.7	12.1	2,053.9	0.7	0.6	1	1	1
08/12/2021 13:00	0.7	12.2	2,043.5	0.7	0.6	1	1	1
08/12/2021 14:00	0.7	12.2	2,034.6	0.7	0.6	1	1	1
08/12/2021 15:00	0.7	12.1	2,039.2	0.7	0.6	1	1	1
08/12/2021 16:00	0.7	12.1	2,054.7	0.7	0.6	1	1	1
08/12/2021 17:00	0.7	12.0	2,064.9	0.7	0.6	1	1	1
08/12/2021 18:00	0.7	11.9	2,108.2	0.7	0.6	1	1	1
08/12/2021 19:00	0.7	11.8	2,117.5	0.7	0.6	1	1	1
08/12/2021 20:00	0.7	11.8	2,137.9	0.7	0.6	1	1	1
08/12/2021 21:00	0.7	12.0	2,110.9	0.7	0.6	1	1	1
08/12/2021 22:00	0.7	12.2	2,062.5	0.7	0.6	1	1	1
08/12/2021 23:00	0.7	12.5	2,016.3	0.7	0.6	1	1	1
Average/Sum#:	0.5	12.7	1,947.6	0.5	0.6	24 #	24 #	21 #
Minimum:	-0.9	11.8	1,606.3	-0.5	0.5	1	1	0
Maximum:	0.7	13.9	2,137.9	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/13/2021 00:00	-0.9	12.9	1,922.2	-0.5	0.6	1	1	1
08/13/2021 01:00	0.4	13.8	1,613.8	0.4	0.5	1	1	1
08/13/2021 02:00	0.7	13.9	1,468.4	0.7	0.4	1	1	1
08/13/2021 03:00	-0.5	12.7	1,977.5	-0.2	0.6	1	1	1
08/13/2021 04:00	-1.7	13.0	1,908.9	-1.1	0.6	1	1	1
08/13/2021 05:00	0.6	13.9	1,643.1	0.6	0.5	1	1	0
08/13/2021 06:00	0.6	13.9	1,611.3	0.6	0.5	1	1	0
08/13/2021 07:00	0.7	13.9	1,536.4	0.7	0.5	1	1	1
08/13/2021 08:00	-1.4	12.8	1,965.9	-0.8	0.6	1	1	1
08/13/2021 09:00	-0.5	12.7	1,927.0	-0.2	0.6	1	1	1
08/13/2021 10:00	0.6	13.9	1,564.2	0.6	0.5	1	1	0
08/13/2021 11:00	0.7	13.9	1,564.0	0.7	0.5	1	1	1
08/13/2021 12:00	-0.4	12.5	1,989.4	-0.1	0.6	1	1	1
08/13/2021 13:00	0.5	12.3	2,027.9	0.5	0.6	1	1	1
08/13/2021 14:00	0.7	12.3	2,023.3	0.7	0.6	1	1	1
08/13/2021 15:00	0.7	12.3	2,022.3	0.7	0.6	1	1	1
08/13/2021 16:00	0.7	12.2	2,033.0	0.7	0.6	1	1	1
08/13/2021 17:00	0.7	12.1	2,052.7	0.7	0.6	1	1	1
08/13/2021 18:00	0.7	12.0	2,093.7	0.7	0.6	1	1	1
08/13/2021 19:00	0.7	11.9	2,127.1	0.7	0.6	1	1	1
08/13/2021 20:00	0.7	11.9	2,108.1	0.7	0.6	1	1	1
08/13/2021 21:00	0.7	12.2	2,052.5	0.7	0.6	1	1	1
08/13/2021 22:00	0.7	12.3	2,050.2	0.7	0.6	1	1	1
08/13/2021 23:00	0.7	12.3	2,049.7	0.7	0.6	1	1	1
Average/Sum#:	0.3	12.8	1,888.9	0.4	0.6	24 #	24 #	21 #
Minimum:	-1.7	11.9	1,468.4	-1.1	0.4	1	1	0
Maximum:	0.7	13.9	2,127.1	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/14/2021 00:00	-0.1	12.6	1,945.9	0.1	0.6	1	1	1
08/14/2021 01:00	0.6	13.9	1,668.4	0.6	0.5	1	1	0
08/14/2021 02:00	0.7	13.8	1,700.9	0.7	0.5	1	1	1
08/14/2021 03:00	-0.5	12.6	1,982.9	-0.2	0.6	1	1	1
08/14/2021 04:00	-1.4	12.8	1,912.3	-0.8	0.6	1	1	1
08/14/2021 05:00	0.6	13.9	1,676.1	0.6	0.5	1	1	0
08/14/2021 06:00	0.6	13.9	1,590.6	0.6	0.5	1	1	0
08/14/2021 07:00	0.6	13.9	1,484.1	0.6	0.4	1	1	0
08/14/2021 08:00	0.6	14.0	1,288.9	0.6	0.4	1	1	0
08/14/2021 09:00	0.6	13.9	1,566.6	0.6	0.5	1	1	0
08/14/2021 10:00	0.6	13.9	1,627.9	0.6	0.5	1	1	0
08/14/2021 11:00	0.6	13.9	1,647.0	0.6	0.5	1	1	0
08/14/2021 12:00	0.7	13.8	1,652.4	0.7	0.5	1	1	1
08/14/2021 13:00	-0.1	12.4	1,984.1	0.2	0.6	1	1	1
08/14/2021 14:00	0.5	12.1	2,018.7	0.5	0.6	1	1	1
08/14/2021 15:00	0.6	13.9	1,558.2	0.6	0.5	1	1	0
08/14/2021 16:00	0.7	13.9	1,485.5	0.7	0.4	1	1	1
08/14/2021 17:00	0.4	12.2	2,011.9	0.5	0.6	1	1	1
08/14/2021 18:00	0.7	11.7	2,110.5	0.7	0.6	1	1	1
08/14/2021 19:00	0.7	11.6	2,129.1	0.7	0.6	1	1	1
08/14/2021 20:00	0.7	11.8	2,125.8	0.7	0.6	1	1	1
08/14/2021 21:00	0.7	11.9	2,104.4	0.7	0.6	1	1	1
08/14/2021 22:00	0.7	12.1	2,071.9	0.7	0.6	1	1	1
08/14/2021 23:00	0.7	12.3	2,041.4	0.7	0.6	1	1	1
Average/Sum#:	0.4	13.0	1,807.7	0.5	0.5	24 #	24 #	15 #
Minimum:	-1.4	11.6	1,288.9	-0.8	0.4	1	1	0
Maximum:	0.7	14.0	2,129.1	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/15/2021 00:00	-0.7	12.8	1,927.5	-0.4	0.6	1	1	1
08/15/2021 01:00	0.6	13.9	1,665.2	0.6	0.5	1	1	0
08/15/2021 02:00	0.7	13.8	1,607.7	0.7	0.5	1	1	1
08/15/2021 03:00	-0.4	12.6	1,987.6	-0.1	0.6	1	1	1
08/15/2021 04:00	-1.2	12.8	1,910.4	-0.7	0.6	1	1	1
08/15/2021 05:00	0.6	13.9	1,645.3	0.6	0.5	1	1	0
08/15/2021 06:00	0.6	13.9	1,566.2	0.6	0.5	1	1	0
08/15/2021 07:00	0.6	13.9	1,641.8	0.6	0.5	1	1	0
08/15/2021 08:00	0.6	13.9	1,477.4	0.6	0.4	1	1	0
08/15/2021 09:00	0.6	13.8	1,599.7	0.6	0.5	1	1	0
08/15/2021 10:00	0.6	13.8	1,656.6	0.6	0.5	1	1	0
08/15/2021 11:00	0.6	13.9	1,483.4	0.6	0.4	1	1	0
08/15/2021 12:00	0.5	13.2	1,707.6	0.5	0.5	1	1	1
08/15/2021 13:00	0.5	12.1	2,010.2	0.5	0.6	1	1	1
08/15/2021 14:00	0.6	13.8	1,606.3	0.6	0.5	1	1	0
08/15/2021 15:00	0.7	13.8	1,614.9	0.7	0.5	1	1	1
08/15/2021 16:00	0.2	12.2	2,002.4	0.4	0.6	1	1	1
08/15/2021 17:00	0.7	11.8	2,052.0	0.7	0.6	1	1	1
08/15/2021 18:00	0.7	11.8	2,091.8	0.7	0.6	1	1	1
08/15/2021 19:00	0.7	11.9	2,082.9	0.7	0.6	1	1	1
08/15/2021 20:00	0.7	12.0	2,073.1	0.7	0.6	1	1	1
08/15/2021 21:00	0.7	12.0	2,071.7	0.7	0.6	1	1	1
08/15/2021 22:00	0.7	12.1	2,051.9	0.7	0.6	1	1	1
08/15/2021 23:00	0.7	12.2	2,044.9	0.7	0.6	1	1	1
Average/Sum#:	0.4	13.0	1,815.8	0.5	0.5	24 #	24 #	15 #
Minimum:	-1.2	11.8	1,477.4	-0.7	0.4	1	1	0
Maximum:	0.7	13.9	2,091.8	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/16/2021 00:00	-0.1	12.6	1,929.8	0.1	0.6	1	1	1
08/16/2021 01:00	0.6	13.9	1,664.6	0.6	0.5	1	1	0
08/16/2021 02:00	0.7	13.8	1,497.9	0.7	0.4	1	1	1
08/16/2021 03:00	-0.8	12.6	1,958.8	-0.4	0.6	1	1	1
08/16/2021 04:00	-0.7	12.7	1,930.8	-0.2	0.6	1	1	1
08/16/2021 05:00	0.7	13.8	1,667.6	0.7	0.5	1	1	1
08/16/2021 06:00	0.7	13.8	1,697.9	0.7	0.5	1	1	1
08/16/2021 07:00	-0.4	12.6	1,947.8	-0.1	0.6	1	1	1
08/16/2021 08:00	0.2	12.4	1,963.8	0.4	0.6	1	1	1
08/16/2021 09:00	0.6	13.8	1,650.0	0.6	0.5	1	1	0
08/16/2021 10:00	0.7	13.8	1,591.7	0.7	0.5	1	1	1
08/16/2021 11:00	-0.1	12.3	2,001.3	0.2	0.6	1	1	1
08/16/2021 12:00	0.5	12.0	2,042.6	0.5	0.6	1	1	1
08/16/2021 13:00	0.5	12.0	2,036.5	0.5	0.6	1	1	1
08/16/2021 14:00	0.5	12.2	2,001.7	0.5	0.6	1	1	1
08/16/2021 15:00	0.7	11.9	2,060.3	0.7	0.6	1	1	1
08/16/2021 16:00	0.7	11.8	2,074.6	0.7	0.6	1	1	1
08/16/2021 17:00	0.7	11.6	2,100.2	0.7	0.6	1	1	1
08/16/2021 18:00	0.7	11.6	2,123.0	0.7	0.6	1	1	1
08/16/2021 19:00	0.7	11.7	2,119.4	0.7	0.6	1	1	1
08/16/2021 20:00	0.7	11.8	2,101.6	0.7	0.6	1	1	1
08/16/2021 21:00	0.7	11.8	2,110.5	0.7	0.6	1	1	1
08/16/2021 22:00	0.7	12.1	2,061.4	0.7	0.6	1	1	1
08/16/2021 23:00	0.7	12.2	2,063.7	0.7	0.6	1	1	1
Average/Sum#:	0.4	12.5	1,933.2	0.5	0.6	24 #	24 #	22 #
Minimum:	-0.8	11.6	1,497.9	-0.4	0.4	1	1	0
Maximum:	0.7	13.9	2,123.0	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/17/2021 00:00	0.5	12.4	2,026.8	0.5	0.6	1	1	1
08/17/2021 01:00	0.7	13.8	1,646.4	0.7	0.5	1	1	1
08/17/2021 02:00	0.7	13.8	1,603.5	0.7	0.5	1	1	1
08/17/2021 03:00	-0.1	12.5	2,015.4	0.1	0.6	1	1	1
08/17/2021 04:00	0.7	12.1	2,089.8	0.7	0.6	1	1	1
08/17/2021 05:00	0.7	12.0	2,133.1	0.7	0.6	1	1	1
08/17/2021 06:00	0.4	12.4	2,034.7	0.5	0.6	1	1	1
08/17/2021 07:00	0.6	13.9	1,623.8	0.6	0.5	1	1	0
08/17/2021 08:00	0.7	13.9	1,571.2	0.7	0.5	1	1	1
08/17/2021 09:00	-0.4	12.7	1,977.1	-0.1	0.6	1	1	1
08/17/2021 10:00	-0.5	12.8	1,906.1	-0.2	0.6	1	1	1
08/17/2021 11:00	0.6	13.9	1,620.7	0.6	0.5	1	1	0
08/17/2021 12:00	0.6	13.9	1,450.2	0.6	0.4	1	1	0
08/17/2021 13:00	0.6	13.8	1,699.1	0.6	0.5	1	1	0
08/17/2021 14:00	-0.1	13.3	1,774.5	0.1	0.5	1	1	1
08/17/2021 15:00	-0.2	13.1	1,799.3	-0.1	0.5	1	1	1
08/17/2021 16:00	0.7	13.9	1,524.8	0.7	0.5	1	1	1
08/17/2021 17:00	-0.2	12.5	1,990.6	0.1	0.6	1	1	1
08/17/2021 18:00	0.7	12.0	2,089.3	0.7	0.6	1	1	1
08/17/2021 19:00	0.7	11.8	2,131.2	0.7	0.6	1	1	1
08/17/2021 20:00	0.7	11.7	2,146.4	0.7	0.6	1	1	1
08/17/2021 21:00	0.7	11.9	2,122.8	0.7	0.6	1	1	1
08/17/2021 22:00	0.7	12.2	2,084.1	0.7	0.6	1	1	1
08/17/2021 23:00	-0.4	12.8	1,958.0	-0.1	0.6	1	1	1
Average/Sum#:	0.4	12.9	1,875.8	0.5	0.6	24 #	24 #	20 #
Minimum:	-0.5	11.7	1,450.2	-0.2	0.4	1	1	0
Maximum:	0.7	13.9	2,146.4	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/18/2021 00:00	0.6	13.9	1,608.1	0.6	0.5	1	1	0
08/18/2021 01:00	0.7	14.0	1,524.6	0.7	0.5	1	1	1
08/18/2021 02:00	-0.8	13.1	1,927.7	-0.5	0.6	1	1	1
08/18/2021 03:00	-1.1	13.1	1,902.0	-0.7	0.6	1	1	1
08/18/2021 04:00	0.6	13.9	1,675.3	0.6	0.5	1	1	0
08/18/2021 05:00	0.7	13.8	1,654.9	0.7	0.5	1	1	1
08/18/2021 06:00	-1.2	12.9	1,962.3	-0.8	0.6	1	1	1
08/18/2021 07:00	-1.2	13.0	1,920.8	-0.8	0.6	1	1	1
08/18/2021 08:00	0.6	13.9	1,432.2	0.6	0.4	1	1	0
08/18/2021 09:00	0.6	14.0	1,536.3	0.6	0.5	1	1	0
08/18/2021 10:00	0.6	0.0	1,508.6	0.6	0.5	1	1	0
08/18/2021 11:00	0.6	14.1	1,452.4	0.6	0.4	1	1	0
08/18/2021 12:00	0.7	14.0	1,490.1	0.7	0.4	1	1	1
08/18/2021 13:00	-0.4	12.7	2,029.5	-0.1	0.6	1	1	1
08/18/2021 14:00	0.4	12.4	2,009.0	0.5	0.6	1	1	1
08/18/2021 15:00	0.6	13.9	1,651.4	0.6	0.5	1	1	0
08/18/2021 16:00	0.6	14.0	1,505.5	0.6	0.5	1	1	0
08/18/2021 17:00	-0.1	12.7	1,969.6	0.1	0.6	1	1	1
08/18/2021 18:00	0.7	12.2	2,095.5	0.7	0.6	1	1	1
08/18/2021 19:00	0.1	12.7	1,957.0	0.2	0.6	1	1	1
08/18/2021 20:00	0.6	13.9	1,680.5	0.6	0.5	1	1	0
08/18/2021 21:00	0.7	13.8	1,694.8	0.7	0.5	1	1	1
08/18/2021 22:00	-0.4	12.7	1,997.6	-0.1	0.6	1	1	1
08/18/2021 23:00	-1.2	13.0	1,903.8	-0.8	0.6	1	1	1
Average/Sum#:	0.1	13.4	1,753.7	0.2	0.5	24 #	24 #	15 #
Minimum:	-1.2	12.2	1,432.2	-0.8	0.4	1	1	0
Maximum:	0.7	14.1	2,095.5	0.7	0.6	1	1	1
%SI	4.17	4.17	0.00	4.17	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/19/2021 00:00	0.6	13.9	1,585.9	0.6	0.5	1	1	0
08/19/2021 01:00	0.6	13.9	1,619.0	0.6	0.5	1	1	0
08/19/2021 02:00	0.6	13.9	1,486.9	0.6	0.4	1	1	0
08/19/2021 03:00	0.7	13.9	1,515.6	0.7	0.5	1	1	1
08/19/2021 04:00	-0.4	12.7	1,996.4	-0.1	0.6	1	1	1
08/19/2021 05:00	-0.9	12.9	1,921.8	-0.5	0.6	1	1	1
08/19/2021 06:00	0.6	13.9	1,628.2	0.6	0.5	1	1	0
08/19/2021 07:00	0.6	13.9	1,657.6	0.6	0.5	1	1	0
08/19/2021 08:00	0.6	14.0	1,342.2	0.6	0.4	1	1	0
08/19/2021 09:00	0.6	13.9	1,639.0	0.6	0.5	1	1	0
08/19/2021 10:00	0.6	14.0	1,614.0	0.6	0.5	1	1	0
08/19/2021 11:00	0.6	14.0	1,581.0	0.6	0.5	1	1	0
08/19/2021 12:00	0.7	13.9	1,665.7	0.7	0.5	1	1	1
08/19/2021 13:00	-0.2	12.4	2,030.3	0.1	0.6	1	1	1
08/19/2021 14:00	0.2	12.5	1,978.7	0.4	0.6	1	1	1
08/19/2021 15:00	0.6	13.9	1,545.6	0.6	0.5	1	1	0
08/19/2021 16:00	0.7	13.8	1,637.8	0.7	0.5	1	1	1
08/19/2021 17:00	-0.2	12.5	2,012.8	0.1	0.6	1	1	1
08/19/2021 18:00	0.7	12.2	2,079.1	0.7	0.6	1	1	1
08/19/2021 19:00	0.5	12.4	2,001.0	0.5	0.6	1	1	1
08/19/2021 20:00	0.6	13.9	1,671.2	0.6	0.5	1	1	0
08/19/2021 21:00	0.7	13.8	1,581.3	0.7	0.5	1	1	1
08/19/2021 22:00	-0.7	12.7	1,972.2	-0.2	0.6	1	1	1
08/19/2021 23:00	-1.2	12.9	1,904.6	-0.8	0.6	1	1	1
Average/Sum#:	0.3	13.4	1,736.2	0.4	0.5	24 #	24 #	13 #
Minimum:	-1.2	12.2	1,342.2	-0.8	0.4	1	1	0
Maximum:	0.7	14.0	2,079.1	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/20/2021 00:00	0.6	13.9	1,649.0	0.6	0.5	1	1	0
08/20/2021 01:00	0.6	13.9	1,647.5	0.6	0.5	1	1	0
08/20/2021 02:00	0.6	13.9	1,509.2	0.6	0.5	1	1	0
08/20/2021 03:00	0.6	14.0	1,327.0	0.6	0.4	1	1	0
08/20/2021 04:00	0.6	13.9	1,613.8	0.6	0.5	1	1	0
08/20/2021 05:00	-1.2	13.7	1,689.3	-0.9	0.5	1	1	1
08/20/2021 06:00	-2.0	13.3	1,823.9	-1.4	0.5	1	1	1
08/20/2021 07:00	0.6	13.9	1,620.6	0.6	0.5	1	1	0
08/20/2021 08:00	0.6	13.9	1,501.2	0.6	0.5	1	1	0
08/20/2021 09:00	0.6	14.0	1,292.6	0.6	0.4	1	1	0
08/20/2021 10:00	0.6	14.0	1,280.1	0.6	0.4	1	1	0
08/20/2021 11:00	0.6	14.0	1,282.2	0.6	0.4	1	1	0
08/20/2021 12:00	0.7	13.9	1,495.5	0.7	0.4	1	1	1
08/20/2021 13:00	-0.4	12.6	1,991.8	-0.1	0.6	1	1	1
08/20/2021 14:00	0.1	12.6	1,941.3	0.2	0.6	1	1	1
08/20/2021 15:00	0.6	13.9	1,511.6	0.6	0.5	1	1	0
08/20/2021 16:00	0.6	13.9	1,518.9	0.6	0.5	1	1	0
08/20/2021 17:00	0.2	12.4	2,012.4	0.4	0.6	1	1	1
08/20/2021 18:00	0.7	12.1	2,070.0	0.7	0.6	1	1	1
08/20/2021 19:00	0.5	12.3	2,014.4	0.5	0.6	1	1	1
08/20/2021 20:00	0.6	13.9	1,635.5	0.6	0.5	1	1	0
08/20/2021 21:00	0.7	13.8	1,674.6	0.7	0.5	1	1	1
08/20/2021 22:00	-0.4	12.6	1,989.2	-0.1	0.6	1	1	1
08/20/2021 23:00	-1.4	12.9	1,888.3	-0.8	0.6	1	1	1
Average/Sum#:	0.2	13.5	1,665.8	0.3	0.5	24 #	24 #	11 #
Minimum:	-2.0	12.1	1,280.1	-1.4	0.4	1	1	0
Maximum:	0.7	14.0	2,070.0	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/21/2021 00:00	0.0	15.6	587.4	0.0	0.2	1	0	0
08/21/2021 01:00	0.0	17.7	399.7	0.0	0.1	1	0	0
08/21/2021 02:00	0.0	14.4	1,115.1	0.0	0.3	1	0	0
08/21/2021 03:00	0.6	14.0	1,211.7	0.6	0.4	1	1	0
08/21/2021 04:00	0.6	14.0	1,217.6	0.6	0.4	1	1	0
08/21/2021 05:00	0.6	14.0	1,330.2	0.6	0.4	1	1	0
08/21/2021 06:00	0.6	14.0	1,331.2	0.6	0.4	1	1	0
08/21/2021 07:00	0.6	14.0	1,334.0	0.6	0.4	1	1	0
08/21/2021 08:00	0.6	14.0	1,335.8	0.6	0.4	1	1	0
08/21/2021 09:00	0.6	14.0	1,340.2	0.6	0.4	1	1	0
08/21/2021 10:00	0.6	14.0	1,340.9	0.6	0.4	1	1	0
08/21/2021 11:00	0.6	14.0	1,347.3	0.6	0.4	1	1	0
08/21/2021 12:00	0.6	14.0	1,349.1	0.6	0.4	1	1	0
08/21/2021 13:00	0.6	14.0	1,349.4	0.6	0.4	1	1	0
08/21/2021 14:00	0.6	14.0	1,348.0	0.6	0.4	1	1	0
08/21/2021 15:00	0.0	14.6	1,093.6	0.0	0.3	1	0	0
08/21/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.5	14.4	1,189.5	0.5	0.4	16 #	12 #	0 #
Minimum:	0.0	14.0	399.7	0.0	0.1	0	0	0
Maximum:	0.6	17.7	1,349.4	0.6	0.4	1	1	0
%SI	33.33	33.33	33.33	33.33	33.33	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/22/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/23/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2021 09:00	0.0	17.6	326.0	0.0	0.1	1	0	0
08/23/2021 10:00	0.0	17.2	389.9	0.0	0.1	1	0	0
08/23/2021 11:00	0.0	15.5	805.7	0.0	0.2	1	0	0
08/23/2021 12:00	0.0	14.8	1,070.5	0.0	0.3	1	0	0
08/23/2021 13:00	0.0	16.9	514.9	0.0	0.2	1	0	0
08/23/2021 14:00	0.0	14.5	1,103.4	0.0	0.3	1	0	0
08/23/2021 15:00	0.6	14.0	1,428.2	0.6	0.4	1	1	0
08/23/2021 16:00	0.6	13.8	1,683.5	0.6	0.5	1	1	0
08/23/2021 17:00	0.6	0.0	1,610.8	0.6	0.5	1	1	0
08/23/2021 18:00	0.6	13.8	1,656.7	0.6	0.5	1	1	0
08/23/2021 19:00	0.1	13.3	1,764.6	0.2	0.5	1	1	1
08/23/2021 20:00	0.1	13.1	1,825.4	0.2	0.5	1	1	1
08/23/2021 21:00	0.7	13.7	1,737.3	0.7	0.5	1	1	1
08/23/2021 22:00	-0.8	12.8	1,964.3	-0.4	0.6	1	1	1
08/23/2021 23:00	-0.9	12.9	1,910.8	-0.5	0.6	1	1	1
Average/Sum#:	0.1	14.6	1,319.5	0.1	0.4	15 #	9 #	5 #
Minimum:	-0.9	12.8	326.0	-0.5	0.1	0	0	0
Maximum:	0.7	17.6	1,964.3	0.7	0.6	1	1	1
%SI	37.50	41.67	37.50	41.67	37.50	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/24/2021 00:00	0.6	13.9	1,525.3	0.6	0.5	1	1	0
08/24/2021 01:00	0.6	13.9	1,590.8	0.6	0.5	1	1	0
08/24/2021 02:00	0.7	13.8	1,647.5	0.7	0.5	1	1	1
08/24/2021 03:00	-3.6	13.1	1,915.7	-2.6	0.6	1	1	1
08/24/2021 04:00	-3.0	13.1	1,898.4	-2.1	0.6	1	1	1
08/24/2021 05:00	0.6	13.9	1,641.6	0.6	0.5	1	1	0
08/24/2021 06:00	0.6	13.9	1,582.8	0.6	0.5	1	1	0
08/24/2021 07:00	0.6	13.9	1,618.6	0.6	0.5	1	1	0
08/24/2021 08:00	0.6	13.9	1,508.0	0.6	0.5	1	1	0
08/24/2021 09:00	0.6	13.9	1,662.4	0.6	0.5	1	1	0
08/24/2021 10:00	0.6	13.9	1,644.4	0.6	0.5	1	1	0
08/24/2021 11:00	0.6	13.9	1,607.9	0.6	0.5	1	1	0
08/24/2021 12:00	0.6	13.9	1,541.3	0.6	0.5	1	1	0
08/24/2021 13:00	0.7	13.8	1,630.7	0.7	0.5	1	1	1
08/24/2021 14:00	-0.1	12.6	2,004.7	0.1	0.6	1	1	1
08/24/2021 15:00	0.4	12.5	2,005.7	0.5	0.6	1	1	1
08/24/2021 16:00	0.6	13.9	1,682.7	0.6	0.5	1	1	0
08/24/2021 17:00	0.7	13.7	1,725.8	0.7	0.5	1	1	1
08/24/2021 18:00	0.1	12.5	2,015.0	0.2	0.6	1	1	1
08/24/2021 19:00	0.7	12.1	2,068.0	0.7	0.6	1	1	1
08/24/2021 20:00	0.6	13.9	1,632.7	0.6	0.5	1	1	0
08/24/2021 21:00	0.7	13.7	1,746.8	0.7	0.5	1	1	1
08/24/2021 22:00	0.1	12.7	1,993.7	0.2	0.6	1	1	1
08/24/2021 23:00	0.5	12.4	2,077.0	0.5	0.6	1	1	1
Average/Sum#:	0.2	13.5	1,748.6	0.3	0.5	24 #	24 #	12 #
Minimum:	-3.6	12.1	1,508.0	-2.6	0.5	1	1	0
Maximum:	0.7	13.9	2,077.0	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/25/2021 00:00	0.7	13.7	1,611.4	0.7	0.5	1	1	1
08/25/2021 01:00	0.6	13.9	1,599.9	0.6	0.5	1	1	0
08/25/2021 02:00	0.7	13.9	1,550.8	0.7	0.5	1	1	1
08/25/2021 03:00	-0.4	12.9	1,974.5	-0.1	0.6	1	1	1
08/25/2021 04:00	0.5	12.6	2,034.8	0.5	0.6	1	1	1
08/25/2021 05:00	0.1	13.0	1,922.6	0.2	0.6	1	1	1
08/25/2021 06:00	0.6	13.9	1,573.2	0.6	0.5	1	1	0
08/25/2021 07:00	0.6	13.9	1,531.3	0.6	0.5	1	1	0
08/25/2021 08:00	0.7	13.8	1,609.4	0.7	0.5	1	1	1
08/25/2021 09:00	-0.7	12.9	1,969.7	-0.4	0.6	1	1	1
08/25/2021 10:00	-1.4	13.0	1,915.0	-0.8	0.6	1	1	1
08/25/2021 11:00	0.4	13.8	1,639.5	0.4	0.5	1	1	1
08/25/2021 12:00	0.7	13.8	1,615.2	0.7	0.5	1	1	1
08/25/2021 13:00	-0.2	12.6	2,007.5	0.1	0.6	1	1	1
08/25/2021 14:00	0.4	12.5	1,996.5	0.5	0.6	1	1	1
08/25/2021 15:00	0.6	13.9	1,588.4	0.6	0.5	1	1	0
08/25/2021 16:00	0.7	14.0	1,463.0	0.7	0.4	1	1	1
08/25/2021 17:00	0.1	12.6	1,993.5	0.2	0.6	1	1	1
08/25/2021 18:00	0.7	12.3	2,074.6	0.7	0.6	1	1	1
08/25/2021 19:00	0.5	12.5	1,992.9	0.5	0.6	1	1	1
08/25/2021 20:00	0.6	13.9	1,623.2	0.6	0.5	1	1	0
08/25/2021 21:00	0.7	13.8	1,664.9	0.7	0.5	1	1	1
08/25/2021 22:00	-0.2	12.7	1,987.6	0.1	0.6	1	1	1
08/25/2021 23:00	-0.8	12.9	1,925.2	-0.4	0.6	1	1	1
Average/Sum#:	0.3	13.3	1,786.0	0.4	0.5	24 #	24 #	19 #
Minimum:	-1.4	12.3	1,463.0	-0.8	0.4	1	1	0
Maximum:	0.7	14.0	2,074.6	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/26/2021 00:00	0.6	13.9	1,628.7	0.6	0.5	1	1	0
08/26/2021 01:00	0.6	13.9	1,595.5	0.6	0.5	1	1	0
08/26/2021 02:00	0.6	14.0	1,402.9	0.6	0.4	1	1	0
08/26/2021 03:00	0.7	13.9	1,559.9	0.7	0.5	1	1	1
08/26/2021 04:00	-0.2	12.7	2,007.5	0.1	0.6	1	1	1
08/26/2021 05:00	0.2	12.6	2,038.1	0.4	0.6	1	1	1
08/26/2021 06:00	-0.7	12.9	1,940.6	-0.4	0.6	1	1	1
08/26/2021 07:00	0.7	13.8	1,657.1	0.7	0.5	1	1	1
08/26/2021 08:00	0.6	13.9	1,522.7	0.6	0.5	1	1	0
08/26/2021 09:00	-0.4	13.3	1,811.3	-0.1	0.5	1	1	1
08/26/2021 10:00	-0.8	12.9	1,926.9	-0.4	0.6	1	1	1
08/26/2021 11:00	0.6	13.9	1,695.7	0.6	0.5	1	1	0
08/26/2021 12:00	0.6	13.9	1,677.0	0.6	0.5	1	1	0
08/26/2021 13:00	-0.4	12.7	1,988.0	-0.1	0.6	1	1	1
08/26/2021 14:00	0.1	12.6	1,968.3	0.2	0.6	1	1	1
08/26/2021 15:00	0.6	13.8	1,691.0	0.6	0.5	1	1	0
08/26/2021 16:00	0.7	13.8	1,625.3	0.7	0.5	1	1	1
08/26/2021 17:00	0.4	12.3	1,992.0	0.5	0.6	1	1	1
08/26/2021 18:00	0.7	11.9	2,065.9	0.7	0.6	1	1	1
08/26/2021 19:00	0.7	11.8	2,135.9	0.7	0.6	1	1	1
08/26/2021 20:00	0.7	11.9	2,141.8	0.7	0.6	1	1	1
08/26/2021 21:00	0.7	12.0	2,133.0	0.7	0.6	1	1	1
08/26/2021 22:00	0.7	12.0	2,121.0	0.7	0.6	1	1	1
08/26/2021 23:00	0.1	12.3	2,036.6	0.2	0.6	1	1	1
Average/Sum#:	0.3	13.0	1,848.4	0.4	0.6	24 #	24 #	17 #
Minimum:	-0.8	11.8	1,402.9	-0.4	0.4	1	1	0
Maximum:	0.7	14.0	2,141.8	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/27/2021 00:00	0.6	13.9	1,669.8	0.6	0.5	1	1	0
08/27/2021 01:00	0.6	13.9	1,637.2	0.6	0.5	1	1	0
08/27/2021 02:00	0.6	13.9	1,659.6	0.6	0.5	1	1	0
08/27/2021 03:00	0.7	13.8	1,693.4	0.7	0.5	1	1	1
08/27/2021 04:00	-0.2	12.6	2,016.6	0.1	0.6	1	1	1
08/27/2021 05:00	0.4	12.4	2,031.5	0.5	0.6	1	1	1
08/27/2021 06:00	0.6	13.9	1,569.5	0.6	0.5	1	1	0
08/27/2021 07:00	0.6	13.9	1,654.5	0.6	0.5	1	1	0
08/27/2021 08:00	0.6	13.9	1,511.2	0.6	0.5	1	1	0
08/27/2021 09:00	-0.4	12.9	1,923.0	-0.1	0.6	1	1	1
08/27/2021 10:00	0.2	12.7	1,940.6	0.4	0.6	1	1	1
08/27/2021 11:00	0.6	13.8	1,699.0	0.6	0.5	1	1	0
08/27/2021 12:00	0.7	13.8	1,694.0	0.7	0.5	1	1	1
08/27/2021 13:00	-0.1	12.4	2,017.3	0.2	0.6	1	1	1
08/27/2021 14:00	0.7	11.8	2,132.2	0.7	0.6	1	1	1
08/27/2021 15:00	0.7	11.8	2,125.5	0.7	0.6	1	1	1
08/27/2021 16:00	0.7	11.8	2,126.0	0.7	0.6	1	1	1
08/27/2021 17:00	0.7	11.7	2,147.5	0.7	0.6	1	1	1
08/27/2021 18:00	0.7	11.7	2,155.6	0.7	0.6	1	1	1
08/27/2021 19:00	0.7	11.7	2,159.2	0.7	0.6	1	1	1
08/27/2021 20:00	0.7	11.7	2,167.3	0.7	0.7	1	1	1
08/27/2021 21:00	0.7	11.7	2,172.3	0.7	0.7	1	1	1
08/27/2021 22:00	0.7	12.0	2,121.9	0.7	0.6	1	1	1
08/27/2021 23:00	0.5	12.3	2,037.1	0.5	0.6	1	1	1
Average/Sum#:	0.5	12.8	1,919.2	0.6	0.6	24 #	24 #	17 #
Minimum:	-0.4	11.7	1,511.2	-0.1	0.5	1	1	0
Maximum:	0.7	13.9	2,172.3	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/28/2021 00:00	0.6	13.9	1,656.8	0.6	0.5	1	1	0
08/28/2021 01:00	0.7	13.7	1,736.2	0.7	0.5	1	1	1
08/28/2021 02:00	-0.1	12.7	1,996.3	0.1	0.6	1	1	1
08/28/2021 03:00	-0.5	13.0	1,904.4	-0.2	0.6	1	1	1
08/28/2021 04:00	0.6	13.9	1,626.9	0.6	0.5	1	1	0
08/28/2021 05:00	0.6	14.0	1,626.3	0.6	0.5	1	1	0
08/28/2021 06:00	0.6	14.0	1,610.2	0.6	0.5	1	1	0
08/28/2021 07:00	0.6	13.9	1,635.5	0.6	0.5	1	1	0
08/28/2021 08:00	0.6	14.0	1,614.8	0.6	0.5	1	1	0
08/28/2021 09:00	0.6	13.9	1,633.2	0.6	0.5	1	1	0
08/28/2021 10:00	0.7	13.9	1,609.9	0.7	0.5	1	1	1
08/28/2021 11:00	-0.1	12.4	2,030.7	0.2	0.6	1	1	1
08/28/2021 12:00	0.7	12.1	2,043.6	0.7	0.6	1	1	1
08/28/2021 13:00	0.6	13.9	1,665.0	0.6	0.5	1	1	0
08/28/2021 14:00	0.7	13.8	1,683.7	0.7	0.5	1	1	1
08/28/2021 15:00	-0.4	12.5	2,004.5	-0.1	0.6	1	1	1
08/28/2021 16:00	0.7	11.9	2,102.8	0.7	0.6	1	1	1
08/28/2021 17:00	0.7	11.8	2,129.3	0.7	0.6	1	1	1
08/28/2021 18:00	0.7	11.7	2,152.9	0.7	0.6	1	1	1
08/28/2021 19:00	0.7	11.7	2,168.0	0.7	0.7	1	1	1
08/28/2021 20:00	0.7	11.7	2,172.3	0.7	0.7	1	1	1
08/28/2021 21:00	0.7	11.7	2,159.9	0.7	0.6	1	1	1
08/28/2021 22:00	0.7	12.0	2,114.4	0.7	0.6	1	1	1
08/28/2021 23:00	0.7	12.3	2,064.7	0.7	0.6	1	1	1
Average/Sum#:	0.5	12.9	1,880.9	0.6	0.6	24 #	24 #	16 #
Minimum:	-0.5	11.7	1,609.9	-0.2	0.5	1	1	0
Maximum:	0.7	14.0	2,172.3	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/29/2021 00:00	0.2	12.7	1,939.1	0.4	0.6	1	1	1
08/29/2021 01:00	0.6	13.9	1,668.0	0.6	0.5	1	1	0
08/29/2021 02:00	0.7	13.7	1,737.0	0.7	0.5	1	1	1
08/29/2021 03:00	-0.1	12.6	1,998.1	0.1	0.6	1	1	1
08/29/2021 04:00	0.2	12.5	2,009.1	0.4	0.6	1	1	1
08/29/2021 05:00	0.6	13.9	1,674.9	0.6	0.5	1	1	0
08/29/2021 06:00	0.6	14.0	1,608.9	0.6	0.5	1	1	0
08/29/2021 07:00	0.6	14.0	1,582.5	0.6	0.5	1	1	0
08/29/2021 08:00	0.6	14.0	1,507.1	0.6	0.5	1	1	0
08/29/2021 09:00	0.6	14.0	1,459.3	0.6	0.4	1	1	0
08/29/2021 10:00	-2.6	13.2	1,829.3	-1.8	0.5	1	1	1
08/29/2021 11:00	0.1	12.7	1,941.2	0.2	0.6	1	1	1
08/29/2021 12:00	0.7	13.7	1,691.1	0.7	0.5	1	1	1
08/29/2021 13:00	0.7	13.8	1,676.6	0.7	0.5	1	1	1
08/29/2021 14:00	0.2	12.2	2,029.1	0.4	0.6	1	1	1
08/29/2021 15:00	0.7	11.9	2,090.9	0.7	0.6	1	1	1
08/29/2021 16:00	0.7	11.8	2,104.8	0.7	0.6	1	1	1
08/29/2021 17:00	0.7	11.7	2,135.4	0.7	0.6	1	1	1
08/29/2021 18:00	0.7	11.7	2,142.8	0.7	0.6	1	1	1
08/29/2021 19:00	0.7	11.6	2,153.2	0.7	0.6	1	1	1
08/29/2021 20:00	0.7	11.6	2,151.1	0.7	0.6	1	1	1
08/29/2021 21:00	0.7	11.7	2,152.1	0.7	0.6	1	1	1
08/29/2021 22:00	0.7	11.9	2,111.7	0.7	0.6	1	1	1
08/29/2021 23:00	0.5	12.4	1,995.4	0.5	0.6	1	1	1
Average/Sum#:	0.4	12.8	1,891.2	0.5	0.6	24 #	24 #	18 #
Minimum:	-2.6	11.6	1,459.3	-1.8	0.4	1	1	0
Maximum:	0.7	14.0	2,153.2	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/30/2021 00:00	0.6	13.9	1,606.5	0.6	0.5	1	1	0
08/30/2021 01:00	0.7	13.9	1,649.1	0.7	0.5	1	1	1
08/30/2021 02:00	-0.9	12.9	1,922.4	-0.5	0.6	1	1	1
08/30/2021 03:00	0.4	12.4	2,007.4	0.5	0.6	1	1	1
08/30/2021 04:00	0.6	13.9	1,614.9	0.6	0.5	1	1	0
08/30/2021 05:00	0.7	13.9	1,515.2	0.7	0.5	1	1	1
08/30/2021 06:00	0.2	12.6	1,998.3	0.4	0.6	1	1	1
08/30/2021 07:00	0.2	12.6	1,971.3	0.4	0.6	1	1	1
08/30/2021 08:00	0.6	13.9	1,653.8	0.6	0.5	1	1	0
08/30/2021 09:00	0.6	13.8	1,626.1	0.6	0.5	1	1	0
08/30/2021 10:00	-0.2	12.9	1,878.6	0.1	0.6	1	1	1
08/30/2021 11:00	0.5	12.2	2,025.1	0.5	0.6	1	1	1
08/30/2021 12:00	0.6	13.8	1,674.3	0.6	0.5	1	1	0
08/30/2021 13:00	0.7	13.8	1,660.1	0.7	0.5	1	1	1
08/30/2021 14:00	0.2	12.2	2,036.4	0.4	0.6	1	1	1
08/30/2021 15:00	0.7	11.9	2,102.3	0.7	0.6	1	1	1
08/30/2021 16:00	0.7	11.8	2,107.2	0.7	0.6	1	1	1
08/30/2021 17:00	0.7	11.7	2,130.7	0.7	0.6	1	1	1
08/30/2021 18:00	0.7	11.7	2,142.2	0.7	0.6	1	1	1
08/30/2021 19:00	0.7	11.7	2,156.9	0.7	0.6	1	1	1
08/30/2021 20:00	0.7	11.7	2,174.6	0.7	0.7	1	1	1
08/30/2021 21:00	0.7	11.8	2,160.1	0.7	0.6	1	1	1
08/30/2021 22:00	0.7	12.0	2,115.2	0.7	0.6	1	1	1
08/30/2021 23:00	0.5	12.3	2,018.7	0.5	0.6	1	1	1
Average/Sum#:	0.5	12.7	1,914.5	0.5	0.6	24 #	24 #	19 #
Minimum:	-0.9	11.7	1,515.2	-0.5	0.5	1	1	0
Maximum:	0.7	13.9	2,174.6	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/31/2021 00:00	0.6	13.9	1,636.0	0.6	0.5	1	1	0
08/31/2021 01:00	0.6	13.9	1,658.1	0.6	0.5	1	1	0
08/31/2021 02:00	0.6	14.0	1,300.0	0.6	0.4	1	1	0
08/31/2021 03:00	0.6	13.9	1,624.7	0.6	0.5	1	1	0
08/31/2021 04:00	-0.7	13.4	1,803.6	-0.4	0.5	1	1	1
08/31/2021 05:00	-0.9	13.1	1,865.3	-0.5	0.6	1	1	1
08/31/2021 06:00	0.6	13.7	1,754.2	0.6	0.5	1	1	0
08/31/2021 07:00	-0.7	12.9	1,955.2	-0.4	0.6	1	1	1
08/31/2021 08:00	0.5	12.4	2,032.1	0.5	0.6	1	1	1
08/31/2021 09:00	0.6	13.9	1,652.5	0.6	0.5	1	1	0
08/31/2021 10:00	0.6	13.8	1,668.9	0.6	0.5	1	1	0
08/31/2021 11:00	0.1	12.7	1,956.3	0.2	0.6	1	1	1
08/31/2021 12:00	0.5	12.3	2,026.7	0.5	0.6	1	1	1
08/31/2021 13:00	0.6	13.8	1,629.0	0.6	0.5	1	1	0
08/31/2021 14:00	0.6	13.8	1,684.7	0.6	0.5	1	1	0
08/31/2021 15:00	-0.1	12.6	1,961.7	0.1	0.6	1	1	1
08/31/2021 16:00	0.7	12.0	2,097.3	0.7	0.6	1	1	1
08/31/2021 17:00	0.7	11.9	2,110.4	0.7	0.6	1	1	1
08/31/2021 18:00	0.7	11.9	2,121.2	0.7	0.6	1	1	1
08/31/2021 19:00	0.7	12.0	2,055.1	0.7	0.6	1	1	1
08/31/2021 20:00	0.6	13.9	1,625.0	0.6	0.5	1	1	0
08/31/2021 21:00	0.7	13.8	1,679.2	0.7	0.5	1	1	1
08/31/2021 22:00	-0.7	12.7	1,983.2	-0.2	0.6	1	1	1
08/31/2021 23:00	0.7	12.4	2,052.6	0.7	0.6	1	1	1
Average/Sum#:	0.3	13.1	1,830.5	0.4	0.5	24 #	24 #	14 #
Minimum:	-0.9	11.9	1,300.0	-0.5	0.4	1	1	0
Maximum:	0.7	14.0	2,121.2	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/01/2021 00:00	0.7	12.3	2,081.8	0.7	0.6	1	1	1
09/01/2021 01:00	0.2	13.0	1,906.7	0.4	0.6	1	1	1
09/01/2021 02:00	0.6	13.9	1,576.1	0.6	0.5	1	1	0
09/01/2021 03:00	0.7	13.8	1,676.1	0.7	0.5	1	1	1
09/01/2021 04:00	-0.1	12.8	1,977.0	0.1	0.6	1	1	1
09/01/2021 05:00	0.7	12.4	2,078.6	0.7	0.6	1	1	1
09/01/2021 06:00	-0.1	12.9	1,966.2	0.1	0.6	1	1	1
09/01/2021 07:00	0.6	13.9	1,661.3	0.6	0.5	1	1	0
09/01/2021 08:00	0.6	13.9	1,597.6	0.6	0.5	1	1	0
09/01/2021 09:00	-1.1	13.2	1,854.8	-0.7	0.6	1	1	1
09/01/2021 10:00	-0.7	12.9	1,950.3	-0.4	0.6	1	1	1
09/01/2021 11:00	0.7	13.7	1,466.1	0.7	0.4	1	1	1
09/01/2021 12:00	0.7	13.9	1,524.8	0.7	0.5	1	1	1
09/01/2021 13:00	-0.2	12.8	1,946.4	0.1	0.6	1	1	1
09/01/2021 14:00	0.2	12.7	1,945.1	0.4	0.6	1	1	1
09/01/2021 15:00	0.7	13.6	1,661.0	0.7	0.5	1	1	1
09/01/2021 16:00	0.7	13.8	1,667.9	0.7	0.5	1	1	1
09/01/2021 17:00	0.1	12.5	2,009.8	0.2	0.6	1	1	1
09/01/2021 18:00	0.7	12.3	2,060.5	0.7	0.6	1	1	1
09/01/2021 19:00	0.7	12.3	2,048.1	0.7	0.6	1	1	1
09/01/2021 20:00	0.6	13.9	1,657.5	0.6	0.5	1	1	0
09/01/2021 21:00	0.6	14.0	1,370.0	0.6	0.4	1	1	0
09/01/2021 22:00	0.6	13.9	1,614.6	0.6	0.5	1	1	0
09/01/2021 23:00	0.6	13.9	1,680.2	0.6	0.5	1	1	0
Average/Sum#:	0.4	13.3	1,790.8	0.4	0.5	24 #	24 #	17 #
Minimum:	-1.1	12.3	1,370.0	-0.7	0.4	1	1	0
Maximum:	0.7	14.0	2,081.8	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/02/2021 00:00	0.2	13.3	1,820.1	0.4	0.5	1	1	1
09/02/2021 01:00	0.4	13.1	1,836.4	0.4	0.6	1	1	1
09/02/2021 02:00	0.6	14.0	1,349.8	0.6	0.4	1	1	0
09/02/2021 03:00	0.6	13.9	1,652.6	0.6	0.5	1	1	0
09/02/2021 04:00	0.6	14.0	1,379.3	0.6	0.4	1	1	0
09/02/2021 05:00	0.6	13.9	1,628.2	0.6	0.5	1	1	0
09/02/2021 06:00	-1.4	13.4	1,789.2	-0.9	0.5	1	1	1
09/02/2021 07:00	-0.4	13.3	1,819.9	-0.1	0.5	1	1	1
09/02/2021 08:00	0.6	14.0	1,345.5	0.6	0.4	1	1	0
09/02/2021 09:00	0.6	14.0	1,433.5	0.6	0.4	1	1	0
09/02/2021 10:00	0.6	14.0	1,488.2	0.6	0.4	1	1	0
09/02/2021 11:00	0.6	14.0	1,408.5	0.6	0.4	1	1	0
09/02/2021 12:00	0.7	13.9	1,663.3	0.7	0.5	1	1	1
09/02/2021 13:00	-0.1	12.7	1,986.4	0.1	0.6	1	1	1
09/02/2021 14:00	0.2	12.7	1,948.3	0.4	0.6	1	1	1
09/02/2021 15:00	0.6	13.9	1,644.9	0.6	0.5	1	1	0
09/02/2021 16:00	0.7	13.9	1,601.5	0.7	0.5	1	1	1
09/02/2021 17:00	0.1	12.5	2,010.0	0.2	0.6	1	1	1
09/02/2021 18:00	0.5	12.3	2,048.2	0.5	0.6	1	1	1
09/02/2021 19:00	0.5	12.4	2,013.3	0.5	0.6	1	1	1
09/02/2021 20:00	0.6	13.9	1,551.2	0.6	0.5	1	1	0
09/02/2021 21:00	0.6	14.0	1,377.3	0.6	0.4	1	1	0
09/02/2021 22:00	0.6	14.0	1,588.1	0.6	0.5	1	1	0
09/02/2021 23:00	-0.8	13.4	1,796.9	-0.5	0.5	1	1	1
Average/Sum#:	0.3	13.5	1,674.2	0.4	0.5	24 #	24 #	12 #
Minimum:	-1.4	12.3	1,345.5	-0.9	0.4	1	1	0
Maximum:	0.7	14.0	2,048.2	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/03/2021 00:00	0.1	13.0	1,859.7	0.2	0.6	1	1	1
09/03/2021 01:00	0.6	13.8	1,583.7	0.6	0.5	1	1	0
09/03/2021 02:00	0.7	13.8	1,753.5	0.7	0.5	1	1	1
09/03/2021 03:00	-3.5	13.2	1,905.9	-2.4	0.6	1	1	1
09/03/2021 04:00	0.6	13.9	1,555.9	0.6	0.5	1	1	0
09/03/2021 05:00	0.7	13.7	1,728.4	0.7	0.5	1	1	1
09/03/2021 06:00	0.5	12.8	1,994.8	0.5	0.6	1	1	1
09/03/2021 07:00	0.5	13.0	1,928.5	0.5	0.6	1	1	1
09/03/2021 08:00	0.6	13.9	1,684.3	0.6	0.5	1	1	0
09/03/2021 09:00	0.6	14.0	1,501.1	0.6	0.5	1	1	0
09/03/2021 10:00	0.6	14.0	1,586.8	0.6	0.5	1	1	0
09/03/2021 11:00	0.4	14.0	1,583.6	0.4	0.5	1	1	0
09/03/2021 12:00	0.6	14.0	1,592.1	0.6	0.5	1	1	0
09/03/2021 13:00	0.6	13.9	1,599.0	0.6	0.5	1	1	0
09/03/2021 14:00	0.7	14.0	1,522.3	0.7	0.5	1	1	1
09/03/2021 15:00	0.1	12.5	2,014.9	0.2	0.6	1	1	1
09/03/2021 16:00	0.5	12.2	2,079.3	0.5	0.6	1	1	1
09/03/2021 17:00	0.7	12.0	2,133.2	0.7	0.6	1	1	1
09/03/2021 18:00	0.7	12.0	2,133.0	0.7	0.6	1	1	1
09/03/2021 19:00	0.7	12.2	2,047.7	0.7	0.6	1	1	1
09/03/2021 20:00	0.6	13.9	1,664.3	0.6	0.5	1	1	0
09/03/2021 21:00	0.7	13.7	1,746.3	0.7	0.5	1	1	1
09/03/2021 22:00	-0.7	12.8	1,970.5	-0.4	0.6	1	1	1
09/03/2021 23:00	-0.7	13.0	1,919.6	-0.4	0.6	1	1	1
Average/Sum#:	0.3	13.3	1,795.4	0.4	0.5	24 #	24 #	15 #
Minimum:	-3.5	12.0	1,501.1	-2.4	0.5	1	1	0
Maximum:	0.7	14.0	2,133.2	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/04/2021 00:00	0.6	13.9	1,611.0	0.6	0.5	1	1	0
09/04/2021 01:00	0.7	13.8	1,630.6	0.7	0.5	1	1	1
09/04/2021 02:00	-0.9	12.8	1,976.7	-0.5	0.6	1	1	1
09/04/2021 03:00	0.0	14.1	1,256.5	0.0	0.4	1	0	1
09/04/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2021 13:00	0.0	17.9	342.7	0.0	0.1	1	0	0
09/04/2021 14:00	0.0	14.6	1,155.5	0.0	0.3	1	0	0
09/04/2021 15:00	0.6	13.9	1,692.1	0.6	0.5	1	1	0
09/04/2021 16:00	0.7	13.9	1,569.7	0.7	0.5	1	1	1
09/04/2021 17:00	0.4	12.3	2,053.5	0.5	0.6	1	1	1
09/04/2021 18:00	0.7	11.8	2,152.4	0.7	0.6	1	1	1
09/04/2021 19:00	0.7	11.8	2,165.8	0.7	0.6	1	1	1
09/04/2021 20:00	0.7	12.0	2,115.0	0.7	0.6	1	1	1
09/04/2021 21:00	0.7	12.2	2,078.6	0.7	0.6	1	1	1
09/04/2021 22:00	0.5	12.5	2,041.4	0.5	0.6	1	1	1
09/04/2021 23:00	0.4	12.5	2,032.9	0.5	0.6	1	1	1
Average/Sum#:	0.4	13.3	1,725.0	0.4	0.5	15 #	12 #	11 #
Minimum:	-0.9	11.8	342.7	-0.5	0.1	0	0	0
Maximum:	0.7	17.9	2,165.8	0.7	0.6	1	1	1
%SI	37.50	37.50	37.50	37.50	37.50	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/05/2021 00:00	-0.2	12.9	1,927.6	0.1	0.6	1	1	1
09/05/2021 01:00	0.6	13.9	1,620.3	0.6	0.5	1	1	0
09/05/2021 02:00	0.7	13.9	1,625.8	0.7	0.5	1	1	1
09/05/2021 03:00	-0.1	12.9	1,979.6	0.1	0.6	1	1	1
09/05/2021 04:00	-0.5	13.1	1,907.7	-0.2	0.6	1	1	1
09/05/2021 05:00	0.6	13.9	1,611.0	0.6	0.5	1	1	0
09/05/2021 06:00	0.6	13.9	1,600.6	0.6	0.5	1	1	0
09/05/2021 07:00	0.6	13.9	1,574.7	0.6	0.5	1	1	0
09/05/2021 08:00	0.6	13.9	1,605.3	0.6	0.5	1	1	0
09/05/2021 09:00	0.6	13.9	1,594.3	0.6	0.5	1	1	0
09/05/2021 10:00	0.6	13.9	1,662.0	0.6	0.5	1	1	0
09/05/2021 11:00	0.6	13.9	1,688.3	0.6	0.5	1	1	0
09/05/2021 12:00	0.6	13.9	1,678.0	0.6	0.5	1	1	0
09/05/2021 13:00	0.6	13.8	1,697.1	0.6	0.5	1	1	0
09/05/2021 14:00	0.1	12.6	1,961.0	0.2	0.6	1	1	1
09/05/2021 15:00	0.5	12.1	2,105.8	0.5	0.6	1	1	1
09/05/2021 16:00	0.7	11.9	2,123.3	0.7	0.6	1	1	1
09/05/2021 17:00	0.7	11.8	2,151.0	0.7	0.6	1	1	1
09/05/2021 18:00	0.7	11.9	2,144.8	0.7	0.6	1	1	1
09/05/2021 19:00	0.7	11.8	2,169.3	0.7	0.7	1	1	1
09/05/2021 20:00	0.7	12.0	2,115.9	0.7	0.6	1	1	1
09/05/2021 21:00	0.7	12.2	2,081.0	0.7	0.6	1	1	1
09/05/2021 22:00	0.5	12.3	2,064.4	0.5	0.6	1	1	1
09/05/2021 23:00	0.4	12.6	1,988.2	0.5	0.6	1	1	1
Average/Sum#:	0.5	13.0	1,861.5	0.5	0.6	24 #	24 #	14 #
Minimum:	-0.5	11.8	1,574.7	-0.2	0.5	1	1	0
Maximum:	0.7	13.9	2,169.3	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/06/2021 00:00	0.6	13.9	1,611.5	0.6	0.5	1	1	0
09/06/2021 01:00	0.7	13.9	1,602.2	0.7	0.5	1	1	1
09/06/2021 02:00	-0.4	12.9	1,951.6	-0.1	0.6	1	1	1
09/06/2021 03:00	0.1	12.8	1,936.4	0.2	0.6	1	1	1
09/06/2021 04:00	0.6	13.9	1,574.6	0.6	0.5	1	1	0
09/06/2021 05:00	0.6	13.9	1,640.8	0.6	0.5	1	1	0
09/06/2021 06:00	0.6	13.9	1,598.6	0.6	0.5	1	1	0
09/06/2021 07:00	0.6	14.0	1,607.7	0.6	0.5	1	1	0
09/06/2021 08:00	0.6	14.0	1,676.8	0.6	0.5	1	1	0
09/06/2021 09:00	0.6	14.0	1,541.7	0.6	0.5	1	1	0
09/06/2021 10:00	0.6	13.9	1,659.9	0.6	0.5	1	1	0
09/06/2021 11:00	0.7	13.9	1,649.8	0.7	0.5	1	1	1
09/06/2021 12:00	0.2	12.4	2,054.8	0.4	0.6	1	1	1
09/06/2021 13:00	0.7	11.9	2,138.3	0.7	0.6	1	1	1
09/06/2021 14:00	0.7	11.9	2,133.5	0.7	0.6	1	1	1
09/06/2021 15:00	0.7	11.9	2,138.4	0.7	0.6	1	1	1
09/06/2021 16:00	0.7	11.8	2,146.6	0.7	0.6	1	1	1
09/06/2021 17:00	0.7	11.7	2,160.6	0.7	0.6	1	1	1
09/06/2021 18:00	0.7	11.7	2,170.0	0.7	0.7	1	1	1
09/06/2021 19:00	0.7	11.7	2,174.2	0.7	0.7	1	1	1
09/06/2021 20:00	0.7	11.7	2,181.4	0.7	0.7	1	1	1
09/06/2021 21:00	0.7	11.9	2,157.0	0.7	0.6	1	1	1
09/06/2021 22:00	0.7	12.1	2,102.0	0.7	0.6	1	1	1
09/06/2021 23:00	0.5	12.5	2,005.8	0.5	0.6	1	1	1
Average/Sum#:	0.6	12.8	1,900.6	0.6	0.6	24 #	24 #	16 #
Minimum:	-0.4	11.7	1,541.7	-0.1	0.5	1	1	0
Maximum:	0.7	14.0	2,181.4	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/07/2021 00:00	0.6	13.9	1,672.9	0.6	0.5	1	1	0
09/07/2021 01:00	0.7	13.8	1,643.2	0.7	0.5	1	1	1
09/07/2021 02:00	0.1	12.6	2,000.5	0.2	0.6	1	1	1
09/07/2021 03:00	0.2	12.8	1,926.6	0.4	0.6	1	1	1
09/07/2021 04:00	0.6	13.9	1,674.9	0.6	0.5	1	1	0
09/07/2021 05:00	0.7	13.7	1,751.0	0.7	0.5	1	1	1
09/07/2021 06:00	-1.1	12.7	1,980.7	-0.7	0.6	1	1	1
09/07/2021 07:00	-0.1	12.8	1,949.2	0.1	0.6	1	1	1
09/07/2021 08:00	0.6	13.9	1,663.9	0.6	0.5	1	1	0
09/07/2021 09:00	0.6	13.8	1,704.1	0.6	0.5	1	1	0
09/07/2021 10:00	0.1	12.7	1,950.0	0.2	0.6	1	1	1
09/07/2021 11:00	0.7	11.9	2,116.0	0.7	0.6	1	1	1
09/07/2021 12:00	0.7	12.0	2,106.0	0.7	0.6	1	1	1
09/07/2021 13:00	0.7	12.0	2,086.1	0.7	0.6	1	1	1
09/07/2021 14:00	0.7	12.0	2,075.8	0.7	0.6	1	1	1
09/07/2021 15:00	0.7	11.9	2,084.2	0.7	0.6	1	1	1
09/07/2021 16:00	0.7	11.8	2,100.8	0.7	0.6	1	1	1
09/07/2021 17:00	0.7	11.9	2,098.9	0.7	0.6	1	1	1
09/07/2021 18:00	0.7	12.2	2,069.4	0.7	0.6	1	1	1
09/07/2021 19:00	0.7	12.3	2,054.6	0.7	0.6	1	1	1
09/07/2021 20:00	0.7	12.3	2,057.0	0.7	0.6	1	1	1
09/07/2021 21:00	0.7	11.9	2,144.3	0.7	0.6	1	1	1
09/07/2021 22:00	0.7	11.8	2,171.2	0.7	0.7	1	1	1
09/07/2021 23:00	0.7	11.8	2,171.2	0.7	0.7	1	1	1
Average/Sum#:	0.5	12.6	1,968.9	0.5	0.6	24 #	24 #	20 #
Minimum:	-1.1	11.8	1,643.2	-0.7	0.5	1	1	0
Maximum:	0.7	13.9	2,171.2	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/08/2021 00:00	0.7	11.9	2,156.8	0.7	0.6	1	1	1
09/08/2021 01:00	0.7	12.1	2,096.0	0.7	0.6	1	1	1
09/08/2021 02:00	0.7	12.3	2,050.5	0.7	0.6	1	1	1
09/08/2021 03:00	0.5	12.3	2,061.1	0.5	0.6	1	1	1
09/08/2021 04:00	0.7	11.9	2,148.5	0.7	0.6	1	1	1
09/08/2021 05:00	0.7	11.8	2,168.0	0.7	0.7	1	1	1
09/08/2021 06:00	0.7	12.0	2,142.3	0.7	0.6	1	1	1
09/08/2021 07:00	0.4	12.6	1,965.9	0.5	0.6	1	1	1
09/08/2021 08:00	0.6	13.9	1,676.1	0.6	0.5	1	1	0
09/08/2021 09:00	0.6	13.8	1,685.5	0.6	0.5	1	1	0
09/08/2021 10:00	0.2	12.6	1,964.2	0.4	0.6	1	1	1
09/08/2021 11:00	0.7	11.9	2,110.4	0.7	0.6	1	1	1
09/08/2021 12:00	0.7	12.0	2,093.6	0.7	0.6	1	1	1
09/08/2021 13:00	0.7	11.9	2,093.3	0.7	0.6	1	1	1
09/08/2021 14:00	0.7	11.8	2,094.3	0.7	0.6	1	1	1
09/08/2021 15:00	0.7	11.8	2,093.8	0.7	0.6	1	1	1
09/08/2021 16:00	0.7	11.7	2,112.4	0.7	0.6	1	1	1
09/08/2021 17:00	0.7	11.6	2,131.5	0.7	0.6	1	1	1
09/08/2021 18:00	0.7	11.7	2,133.7	0.7	0.6	1	1	1
09/08/2021 19:00	0.7	11.7	2,151.0	0.7	0.6	1	1	1
09/08/2021 20:00	0.7	11.8	2,141.7	0.7	0.6	1	1	1
09/08/2021 21:00	0.7	12.0	2,099.7	0.7	0.6	1	1	1
09/08/2021 22:00	0.7	12.1	2,074.7	0.7	0.6	1	1	1
09/08/2021 23:00	0.7	11.8	2,139.9	0.7	0.6	1	1	1
Average/Sum#:	0.7	12.1	2,066.0	0.7	0.6	24 #	24 #	22 #
Minimum:	0.2	11.6	1,676.1	0.4	0.5	1	1	0
Maximum:	0.7	13.9	2,168.0	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/09/2021 00:00	0.7	11.7	2,150.4	0.7	0.6	1	1	1
09/09/2021 01:00	0.7	11.7	2,162.9	0.7	0.6	1	1	1
09/09/2021 02:00	0.7	11.8	2,171.9	0.7	0.7	1	1	1
09/09/2021 03:00	0.7	11.8	2,166.9	0.7	0.7	1	1	1
09/09/2021 04:00	0.7	11.8	2,170.0	0.7	0.7	1	1	1
09/09/2021 05:00	0.7	11.8	2,168.6	0.7	0.7	1	1	1
09/09/2021 06:00	0.7	11.8	2,162.1	0.7	0.6	1	1	1
09/09/2021 07:00	0.7	12.0	2,120.0	0.7	0.6	1	1	1
09/09/2021 08:00	0.7	12.0	2,109.4	0.7	0.6	1	1	1
09/09/2021 09:00	0.7	12.0	2,111.2	0.7	0.6	1	1	1
09/09/2021 10:00	0.7	11.9	2,107.8	0.7	0.6	1	1	1
09/09/2021 11:00	0.7	11.9	2,095.8	0.7	0.6	1	1	1
09/09/2021 12:00	0.7	11.9	2,078.2	0.7	0.6	1	1	1
09/09/2021 13:00	0.7	11.8	2,088.3	0.7	0.6	1	1	1
09/09/2021 14:00	0.7	11.9	2,075.2	0.7	0.6	1	1	1
09/09/2021 15:00	0.7	11.9	2,068.6	0.7	0.6	1	1	1
09/09/2021 16:00	0.7	11.8	2,085.2	0.7	0.6	1	1	1
09/09/2021 17:00	0.7	11.8	2,095.3	0.7	0.6	1	1	1
09/09/2021 18:00	0.7	11.7	2,128.4	0.7	0.6	1	1	1
09/09/2021 19:00	0.7	11.7	2,136.7	0.7	0.6	1	1	1
09/09/2021 20:00	0.7	11.7	2,145.8	0.7	0.6	1	1	1
09/09/2021 21:00	0.7	11.7	2,152.6	0.7	0.6	1	1	1
09/09/2021 22:00	0.7	11.8	2,125.0	0.7	0.6	1	1	1
09/09/2021 23:00	0.7	11.8	2,138.2	0.7	0.6	1	1	1
Average/Sum#:	0.7	11.8	2,125.6	0.7	0.6	24 #	24 #	24 #
Minimum:	0.7	11.7	2,068.6	0.7	0.6	1	1	1
Maximum:	0.7	12.0	2,171.9	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/10/2021 00:00	0.7	12.1	2,054.4	0.7	0.6	1	1	1
09/10/2021 01:00	0.6	13.9	1,559.1	0.6	0.5	1	1	0
09/10/2021 02:00	0.7	13.7	1,715.5	0.7	0.5	1	1	1
09/10/2021 03:00	0.2	12.5	2,014.5	0.4	0.6	1	1	1
09/10/2021 04:00	0.7	11.8	2,142.7	0.7	0.6	1	1	1
09/10/2021 05:00	0.7	12.0	2,107.5	0.7	0.6	1	1	1
09/10/2021 06:00	0.7	11.8	2,151.7	0.7	0.6	1	1	1
09/10/2021 07:00	0.7	13.5	1,616.2	0.7	0.5	1	1	1
09/10/2021 08:00	0.6	13.9	1,489.7	0.6	0.4	1	1	0
09/10/2021 09:00	0.6	13.8	1,610.2	0.6	0.5	1	1	0
09/10/2021 10:00	0.7	13.8	1,581.7	0.7	0.5	1	1	1
09/10/2021 11:00	0.1	12.5	1,984.7	0.2	0.6	1	1	1
09/10/2021 12:00	0.7	12.4	1,966.8	0.7	0.6	1	1	1
09/10/2021 13:00	0.6	13.9	1,573.7	0.6	0.5	1	1	0
09/10/2021 14:00	0.7	13.8	1,687.7	0.7	0.5	1	1	1
09/10/2021 15:00	0.2	12.4	2,008.9	0.4	0.6	1	1	1
09/10/2021 16:00	0.7	12.1	2,063.9	0.7	0.6	1	1	1
09/10/2021 17:00	0.7	11.9	2,112.9	0.7	0.6	1	1	1
09/10/2021 18:00	0.7	11.8	2,129.9	0.7	0.6	1	1	1
09/10/2021 19:00	0.7	11.8	2,130.3	0.7	0.6	1	1	1
09/10/2021 20:00	0.7	11.8	2,129.3	0.7	0.6	1	1	1
09/10/2021 21:00	0.7	11.9	2,130.3	0.7	0.6	1	1	1
09/10/2021 22:00	0.7	12.1	2,074.7	0.7	0.6	1	1	1
09/10/2021 23:00	0.7	12.4	2,012.8	0.7	0.6	1	1	1
Average/Sum#:	0.6	12.7	1,918.7	0.6	0.6	24 #	24 #	20 #
Minimum:	0.1	11.8	1,489.7	0.2	0.4	1	1	0
Maximum:	0.7	13.9	2,151.7	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/11/2021 00:00	-0.2	12.9	1,893.7	0.1	0.6	1	1	1
09/11/2021 01:00	0.6	13.9	1,667.0	0.6	0.5	1	1	0
09/11/2021 02:00	0.6	13.9	1,652.8	0.6	0.5	1	1	0
09/11/2021 03:00	0.7	13.8	1,545.8	0.7	0.5	1	1	1
09/11/2021 04:00	-0.4	12.7	1,979.6	-0.1	0.6	1	1	1
09/11/2021 05:00	-0.5	12.9	1,909.7	-0.2	0.6	1	1	1
09/11/2021 06:00	0.6	13.9	1,632.8	0.6	0.5	1	1	0
09/11/2021 07:00	0.6	13.9	1,604.3	0.6	0.5	1	1	0
09/11/2021 08:00	0.6	13.9	1,499.9	0.6	0.4	1	1	0
09/11/2021 09:00	0.6	13.9	1,581.0	0.6	0.5	1	1	0
09/11/2021 10:00	0.6	13.8	1,663.1	0.6	0.5	1	1	0
09/11/2021 11:00	0.7	13.8	1,644.5	0.7	0.5	1	1	1
09/11/2021 12:00	0.5	12.6	2,005.0	0.5	0.6	1	1	1
09/11/2021 13:00	0.7	12.4	1,992.6	0.7	0.6	1	1	1
09/11/2021 14:00	0.6	13.9	1,656.8	0.6	0.5	1	1	0
09/11/2021 15:00	0.7	13.7	1,694.0	0.7	0.5	1	1	1
09/11/2021 16:00	0.1	12.5	2,007.0	0.2	0.6	1	1	1
09/11/2021 17:00	0.7	11.8	2,158.4	0.7	0.6	1	1	1
09/11/2021 18:00	0.7	11.8	2,135.8	0.7	0.6	1	1	1
09/11/2021 19:00	0.7	12.1	2,084.2	0.7	0.6	1	1	1
09/11/2021 20:00	0.7	11.9	2,125.6	0.7	0.6	1	1	1
09/11/2021 21:00	0.7	11.9	2,143.5	0.7	0.6	1	1	1
09/11/2021 22:00	0.7	12.1	2,102.3	0.7	0.6	1	1	1
09/11/2021 23:00	0.7	12.1	2,119.4	0.7	0.6	1	1	1
Average/Sum#:	0.5	13.0	1,854.1	0.5	0.6	24 #	24 #	16 #
Minimum:	-0.5	11.8	1,499.9	-0.2	0.4	1	1	0
Maximum:	0.7	13.9	2,158.4	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/12/2021 00:00	0.5	12.5	1,988.3	0.5	0.6	1	1	1
09/12/2021 01:00	0.6	13.9	1,666.9	0.6	0.5	1	1	0
09/12/2021 02:00	0.6	13.9	1,627.1	0.6	0.5	1	1	0
09/12/2021 03:00	-0.2	13.8	1,616.9	-0.1	0.5	1	1	1
09/12/2021 04:00	-0.2	12.8	1,972.6	0.1	0.6	1	1	1
09/12/2021 05:00	-0.5	13.0	1,909.9	-0.2	0.6	1	1	1
09/12/2021 06:00	0.1	13.8	1,520.2	0.2	0.5	1	1	1
09/12/2021 07:00	0.6	13.9	1,562.6	0.6	0.5	1	1	0
09/12/2021 08:00	0.6	14.0	1,340.4	0.6	0.4	1	1	0
09/12/2021 09:00	0.6	14.0	1,277.1	0.6	0.4	1	1	0
09/12/2021 10:00	0.6	13.8	1,634.2	0.6	0.5	1	1	0
09/12/2021 11:00	0.7	13.8	1,693.6	0.7	0.5	1	1	1
09/12/2021 12:00	0.1	12.5	2,001.0	0.2	0.6	1	1	1
09/12/2021 13:00	0.7	12.1	2,043.8	0.7	0.6	1	1	1
09/12/2021 14:00	0.6	13.9	1,631.2	0.6	0.5	1	1	0
09/12/2021 15:00	0.7	13.8	1,617.1	0.7	0.5	1	1	1
09/12/2021 16:00	0.4	12.3	2,024.9	0.5	0.6	1	1	1
09/12/2021 17:00	0.7	11.8	2,145.6	0.7	0.6	1	1	1
09/12/2021 18:00	0.7	11.9	2,119.4	0.7	0.6	1	1	1
09/12/2021 19:00	0.7	12.1	2,087.6	0.7	0.6	1	1	1
09/12/2021 20:00	0.7	12.2	2,061.4	0.7	0.6	1	1	1
09/12/2021 21:00	0.7	12.3	2,044.7	0.7	0.6	1	1	1
09/12/2021 22:00	0.7	12.4	2,036.7	0.7	0.6	1	1	1
09/12/2021 23:00	0.7	12.4	2,030.3	0.7	0.6	1	1	1
Average/Sum#:	0.5	13.0	1,818.9	0.5	0.5	24 #	24 #	17 #
Minimum:	-0.5	11.8	1,277.1	-0.2	0.4	1	1	0
Maximum:	0.7	14.0	2,145.6	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/13/2021 00:00	0.2	12.9	1,903.6	0.4	0.6	1	1	1
09/13/2021 01:00	0.6	13.9	1,565.5	0.6	0.5	1	1	0
09/13/2021 02:00	0.6	13.9	1,551.7	0.6	0.5	1	1	0
09/13/2021 03:00	0.6	13.9	1,624.8	0.6	0.5	1	1	0
09/13/2021 04:00	0.6	14.0	1,318.4	0.6	0.4	1	1	0
09/13/2021 05:00	0.6	14.0	1,653.7	0.6	0.5	1	1	0
09/13/2021 06:00	-0.7	13.2	1,765.5	-0.4	0.5	1	1	1
09/13/2021 07:00	0.2	13.0	1,821.6	0.4	0.5	1	1	1
09/13/2021 08:00	0.6	13.9	1,520.2	0.6	0.5	1	1	0
09/13/2021 09:00	-0.1	12.9	1,918.7	0.1	0.6	1	1	1
09/13/2021 10:00	0.2	12.7	1,921.0	0.4	0.6	1	1	1
09/13/2021 11:00	0.6	13.9	1,678.5	0.6	0.5	1	1	0
09/13/2021 12:00	0.6	13.8	1,655.2	0.6	0.5	1	1	0
09/13/2021 13:00	-0.1	12.6	1,976.1	0.1	0.6	1	1	1
09/13/2021 14:00	0.7	11.8	2,128.0	0.7	0.6	1	1	1
09/13/2021 15:00	0.7	11.8	2,115.6	0.7	0.6	1	1	1
09/13/2021 16:00	0.7	11.8	2,112.8	0.7	0.6	1	1	1
09/13/2021 17:00	0.7	11.7	2,138.4	0.7	0.6	1	1	1
09/13/2021 18:00	0.7	11.7	2,144.2	0.7	0.6	1	1	1
09/13/2021 19:00	0.7	11.7	2,144.5	0.7	0.6	1	1	1
09/13/2021 20:00	0.7	11.9	2,124.8	0.7	0.6	1	1	1
09/13/2021 21:00	0.7	12.1	2,081.4	0.7	0.6	1	1	1
09/13/2021 22:00	0.7	12.4	2,035.1	0.7	0.6	1	1	1
09/13/2021 23:00	0.4	12.8	1,926.9	0.5	0.6	1	1	1
Average/Sum#:	0.5	12.8	1,867.8	0.5	0.6	24 #	24 #	16 #
Minimum:	-0.7	11.7	1,318.4	-0.4	0.4	1	1	0
Maximum:	0.7	14.0	2,144.5	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/14/2021 00:00	0.1	12.9	1,905.8	0.2	0.6	1	1	1
09/14/2021 01:00	0.6	13.9	1,547.6	0.6	0.5	1	1	0
09/14/2021 02:00	0.6	13.9	1,527.3	0.6	0.5	1	1	0
09/14/2021 03:00	0.6	13.9	1,527.1	0.6	0.5	1	1	0
09/14/2021 04:00	0.6	13.9	1,482.2	0.6	0.4	1	1	0
09/14/2021 05:00	-1.1	12.9	1,957.4	-0.7	0.6	1	1	1
09/14/2021 06:00	-0.2	12.8	1,960.5	0.1	0.6	1	1	1
09/14/2021 07:00	0.6	13.9	1,624.6	0.6	0.5	1	1	0
09/14/2021 08:00	0.6	13.9	1,485.9	0.6	0.4	1	1	0
09/14/2021 09:00	0.6	13.9	1,457.4	0.6	0.4	1	1	0
09/14/2021 10:00	0.6	13.9	1,635.0	0.6	0.5	1	1	0
09/14/2021 11:00	0.6	13.9	1,681.5	0.6	0.5	1	1	0
09/14/2021 12:00	0.7	13.9	1,519.1	0.7	0.5	1	1	1
09/14/2021 13:00	-0.8	12.7	1,961.5	-0.4	0.6	1	1	1
09/14/2021 14:00	0.5	12.2	2,028.5	0.5	0.6	1	1	1
09/14/2021 15:00	0.6	13.8	1,661.0	0.6	0.5	1	1	0
09/14/2021 16:00	0.7	13.9	1,584.1	0.7	0.5	1	1	1
09/14/2021 17:00	0.2	12.3	2,024.0	0.4	0.6	1	1	1
09/14/2021 18:00	0.7	11.9	2,114.4	0.7	0.6	1	1	1
09/14/2021 19:00	0.7	12.4	1,977.1	0.7	0.6	1	1	1
09/14/2021 20:00	0.6	13.9	1,665.0	0.6	0.5	1	1	0
09/14/2021 21:00	0.7	13.8	1,712.3	0.7	0.5	1	1	1
09/14/2021 22:00	0.1	12.6	1,983.0	0.2	0.6	1	1	1
09/14/2021 23:00	0.2	12.8	1,911.2	0.4	0.6	1	1	1
Average/Sum#:	0.4	13.3	1,747.2	0.5	0.5	24 #	24 #	13 #
Minimum:	-1.1	11.9	1,457.4	-0.7	0.4	1	1	0
Maximum:	0.7	13.9	2,114.4	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/15/2021 00:00	0.6	13.9	1,520.9	0.6	0.5	1	1	0
09/15/2021 01:00	0.7	13.8	1,540.5	0.7	0.5	1	1	1
09/15/2021 02:00	-0.2	12.7	1,966.0	0.1	0.6	1	1	1
09/15/2021 03:00	-0.5	12.8	1,931.7	-0.2	0.6	1	1	1
09/15/2021 04:00	0.7	13.8	1,659.4	0.7	0.5	1	1	1
09/15/2021 05:00	0.7	13.8	1,568.4	0.7	0.5	1	1	1
09/15/2021 06:00	-0.7	12.8	1,952.9	-0.4	0.6	1	1	1
09/15/2021 07:00	-0.7	13.0	1,918.4	-0.4	0.6	1	1	1
09/15/2021 08:00	0.6	13.9	1,452.9	0.6	0.4	1	1	0
09/15/2021 09:00	0.6	14.0	1,396.5	0.6	0.4	1	1	0
09/15/2021 10:00	0.6	14.0	1,525.8	0.6	0.5	1	1	0
09/15/2021 11:00	0.6	13.9	1,581.9	0.6	0.5	1	1	0
09/15/2021 12:00	0.7	13.9	1,514.1	0.7	0.5	1	1	1
09/15/2021 13:00	0.1	12.5	2,012.2	0.2	0.6	1	1	1
09/15/2021 14:00	0.5	12.3	2,023.9	0.5	0.6	1	1	1
09/15/2021 15:00	0.7	13.8	1,542.4	0.7	0.5	1	1	1
09/15/2021 16:00	0.7	13.8	1,558.9	0.7	0.5	1	1	1
09/15/2021 17:00	0.4	12.4	2,004.3	0.5	0.6	1	1	1
09/15/2021 18:00	0.7	12.3	2,020.7	0.7	0.6	1	1	1
09/15/2021 19:00	0.4	12.7	1,938.3	0.5	0.6	1	1	1
09/15/2021 20:00	0.5	13.6	1,663.4	0.5	0.5	1	1	1
09/15/2021 21:00	0.7	13.9	1,587.6	0.7	0.5	1	1	1
09/15/2021 22:00	-1.5	13.0	1,907.1	-0.9	0.6	1	1	1
09/15/2021 23:00	-1.5	13.0	1,903.4	-0.9	0.6	1	1	1
Average/Sum#:	0.2	13.3	1,737.2	0.3	0.5	24 #	24 #	19 #
Minimum:	-1.5	12.3	1,396.5	-0.9	0.4	1	1	0
Maximum:	0.7	14.0	2,023.9	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/16/2021 00:00	-0.8	13.5	1,683.4	-0.5	0.5	1	1	1
09/16/2021 01:00	0.0	14.9	911.5	0.0	0.3	1	0	0
09/16/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2021 12:00	0.0	18.9	162.2	0.0	0.0	1	0	0
09/16/2021 13:00	0.0	15.8	794.0	0.0	0.2	1	0	0
09/16/2021 14:00	0.6	13.9	1,665.5	0.6	0.5	1	1	0
09/16/2021 15:00	0.6	13.9	1,614.5	0.6	0.5	1	1	0
09/16/2021 16:00	0.7	13.9	1,509.4	0.7	0.5	1	1	1
09/16/2021 17:00	-0.1	12.4	2,051.8	0.2	0.6	1	1	1
09/16/2021 18:00	0.7	12.1	2,071.2	0.7	0.6	1	1	1
09/16/2021 19:00	0.5	12.8	1,938.0	0.5	0.6	1	1	1
09/16/2021 20:00	0.7	13.6	1,685.0	0.7	0.5	1	1	1
09/16/2021 21:00	0.7	13.8	1,642.1	0.7	0.5	1	1	1
09/16/2021 22:00	0.1	12.6	1,994.2	0.2	0.6	1	1	1
09/16/2021 23:00	-0.1	12.9	1,927.6	0.1	0.6	1	1	1
Average/Sum#:	0.3	13.9	1,546.5	0.3	0.5	14 #	11 #	9 #
Minimum:	-0.8	12.1	162.2	-0.5	0.0	0	0	0
Maximum:	0.7	18.9	2,071.2	0.7	0.6	1	1	1
%SI	41.67	41.67	41.67	41.67	41.67	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/17/2021 00:00	-0.8	13.0	1,907.8	-0.4	0.6	1	1	1
09/17/2021 01:00	0.7	13.7	1,460.7	0.7	0.4	1	1	1
09/17/2021 02:00	0.0	16.6	304.7	0.0	0.1	1	0	0
09/17/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2021 13:00	0.0	18.0	292.3	0.0	0.1	1	0	0
09/17/2021 14:00	0.0	15.8	768.3	0.0	0.2	1	0	0
09/17/2021 15:00	0.6	14.0	1,474.6	0.6	0.4	1	1	0
09/17/2021 16:00	0.7	13.8	1,575.6	0.7	0.5	1	1	1
09/17/2021 17:00	0.4	12.4	2,025.4	0.5	0.6	1	1	1
09/17/2021 18:00	0.7	12.0	2,103.9	0.7	0.6	1	1	1
09/17/2021 19:00	0.5	12.6	1,969.4	0.5	0.6	1	1	1
09/17/2021 20:00	-0.4	13.0	1,899.6	-0.1	0.6	1	1	1
09/17/2021 21:00	-0.2	12.9	1,923.3	0.1	0.6	1	1	1
09/17/2021 22:00	-0.4	12.9	1,922.6	-0.1	0.6	1	1	1
09/17/2021 23:00	0.5	13.7	1,472.3	0.5	0.4	1	1	1
Average/Sum#:	0.2	13.9	1,507.2	0.3	0.5	14 #	11 #	10 #
Minimum:	-0.8	12.0	292.3	-0.4	0.1	0	0	0
Maximum:	0.7	18.0	2,103.9	0.7	0.6	1	1	1
%SI	41.67	41.67	41.67	41.67	41.67	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/18/2021 00:00	0.0	16.4	316.6	0.0	0.1	1	0	0
09/18/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/18/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/18/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/18/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/18/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/18/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/18/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/18/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/18/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/18/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/18/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/18/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/18/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/18/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/18/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/18/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/18/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/18/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/18/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/18/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/18/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/18/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/18/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	16.4	316.6	0.0	0.1	1 #	0 #	0 #
Minimum:	0.0	16.4	316.6	0.0	0.1	0	0	0
Maximum:	0.0	16.4	316.6	0.0	0.1	1	0	0
%SI	95.83	95.83	95.83	95.83	95.83	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/19/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/20/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2021 01:00	0.0	18.3	245.1	0.0	0.1	1	0	0
09/20/2021 02:00	0.0	16.9	479.2	0.0	0.1	1	0	0
09/20/2021 03:00	0.0	14.1	1,283.8	0.0	0.4	1	0	0
09/20/2021 04:00	0.6	14.0	1,432.1	0.6	0.4	1	1	0
09/20/2021 05:00	-1.8	13.3	1,852.9	-1.2	0.6	1	1	1
09/20/2021 06:00	-1.2	13.0	1,960.2	-0.8	0.6	1	1	1
09/20/2021 07:00	0.4	13.8	1,486.8	0.4	0.4	1	1	1
09/20/2021 08:00	0.6	14.1	1,284.3	0.6	0.4	1	1	0
09/20/2021 09:00	0.6	14.1	1,286.6	0.6	0.4	1	1	0
09/20/2021 10:00	0.6	14.1	1,289.3	0.6	0.4	1	1	0
09/20/2021 11:00	0.7	13.9	1,571.0	0.7	0.5	1	1	1
09/20/2021 12:00	-0.1	12.9	1,953.3	0.1	0.6	1	1	1
09/20/2021 13:00	0.4	12.8	1,965.1	0.5	0.6	1	1	1
09/20/2021 14:00	0.7	13.7	1,562.4	0.7	0.5	1	1	1
09/20/2021 15:00	0.7	13.9	1,527.7	0.7	0.5	1	1	1
09/20/2021 16:00	-0.1	12.5	2,021.7	0.1	0.6	1	1	1
09/20/2021 17:00	0.7	11.8	2,174.0	0.7	0.7	1	1	1
09/20/2021 18:00	0.7	11.9	2,170.9	0.7	0.7	1	1	1
09/20/2021 19:00	0.7	12.0	2,142.6	0.7	0.6	1	1	1
09/20/2021 20:00	0.7	12.1	2,110.3	0.7	0.6	1	1	1
09/20/2021 21:00	0.7	12.4	2,061.6	0.7	0.6	1	1	1
09/20/2021 22:00	-0.1	13.0	1,935.9	0.1	0.6	1	1	1
09/20/2021 23:00	-0.8	13.1	1,893.7	-0.5	0.6	1	1	1
Average/Sum#:	0.2	13.6	1,638.7	0.3	0.5	23 #	20 #	16 #
Minimum:	-1.8	11.8	245.1	-1.2	0.1	0	0	0
Maximum:	0.7	18.3	2,174.0	0.7	0.7	1	1	1
%SI	4.17	4.17	4.17	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/21/2021 00:00	0.6	13.9	1,661.9	0.6	0.5	1	1	0
09/21/2021 01:00	0.7	13.9	1,565.4	0.7	0.5	1	1	1
09/21/2021 02:00	-3.3	13.2	1,910.5	-2.4	0.6	1	1	1
09/21/2021 03:00	-2.3	13.2	1,902.3	-1.5	0.6	1	1	1
09/21/2021 04:00	-2.6	13.2	1,900.9	-1.8	0.6	1	1	1
09/21/2021 05:00	-2.0	13.2	1,916.2	-1.4	0.6	1	1	1
09/21/2021 06:00	0.5	12.7	2,041.5	0.5	0.6	1	1	1
09/21/2021 07:00	-1.8	13.1	1,901.9	-1.2	0.6	1	1	1
09/21/2021 08:00	0.6	14.0	1,464.5	0.6	0.4	1	1	0
09/21/2021 09:00	0.6	14.0	1,523.5	0.6	0.5	1	1	0
09/21/2021 10:00	0.6	13.9	1,651.5	0.6	0.5	1	1	0
09/21/2021 11:00	0.7	14.0	1,619.2	0.7	0.5	1	1	1
09/21/2021 12:00	-0.4	12.7	1,993.4	-0.1	0.6	1	1	1
09/21/2021 13:00	0.7	12.0	2,123.1	0.7	0.6	1	1	1
09/21/2021 14:00	0.7	12.0	2,123.2	0.7	0.6	1	1	1
09/21/2021 15:00	0.7	11.9	2,137.2	0.7	0.6	1	1	1
09/21/2021 16:00	0.7	11.9	2,148.8	0.7	0.6	1	1	1
09/21/2021 17:00	0.7	11.8	2,160.3	0.7	0.6	1	1	1
09/21/2021 18:00	0.7	11.8	2,172.6	0.7	0.7	1	1	1
09/21/2021 19:00	0.7	11.9	2,139.9	0.7	0.6	1	1	1
09/21/2021 20:00	0.7	12.0	2,144.1	0.7	0.6	1	1	1
09/21/2021 21:00	0.7	12.2	2,106.0	0.7	0.6	1	1	1
09/21/2021 22:00	0.7	12.3	2,071.9	0.7	0.6	1	1	1
09/21/2021 23:00	0.4	12.6	2,002.4	0.5	0.6	1	1	1
Average/Sum#:	0.0	12.8	1,932.6	0.1	0.6	24 #	24 #	20 #
Minimum:	-3.3	11.8	1,464.5	-2.4	0.4	1	1	0
Maximum:	0.7	14.0	2,172.6	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/22/2021 00:00	0.7	13.8	1,607.2	0.7	0.5	1	1	1
09/22/2021 01:00	0.7	13.8	1,638.3	0.7	0.5	1	1	1
09/22/2021 02:00	-2.3	13.1	1,898.6	-1.5	0.6	1	1	1
09/22/2021 03:00	-2.4	13.1	1,895.0	-1.7	0.6	1	1	1
09/22/2021 04:00	-0.5	12.8	2,002.8	-0.2	0.6	1	1	1
09/22/2021 05:00	0.7	12.2	2,114.0	0.7	0.6	1	1	1
09/22/2021 06:00	0.5	12.6	2,046.4	0.5	0.6	1	1	1
09/22/2021 07:00	-1.4	13.1	1,896.4	-0.9	0.6	1	1	1
09/22/2021 08:00	0.6	13.9	1,618.8	0.6	0.5	1	1	0
09/22/2021 09:00	0.6	13.8	1,712.7	0.6	0.5	1	1	0
09/22/2021 10:00	-0.1	13.0	1,902.3	0.1	0.6	1	1	1
09/22/2021 11:00	0.5	12.5	2,003.1	0.5	0.6	1	1	1
09/22/2021 12:00	0.6	13.9	1,603.8	0.6	0.5	1	1	0
09/22/2021 13:00	0.7	13.8	1,698.8	0.7	0.5	1	1	1
09/22/2021 14:00	0.2	12.4	2,034.0	0.4	0.6	1	1	1
09/22/2021 15:00	0.7	11.9	2,132.1	0.7	0.6	1	1	1
09/22/2021 16:00	0.7	11.8	2,154.4	0.7	0.6	1	1	1
09/22/2021 17:00	0.7	11.8	2,147.2	0.7	0.6	1	1	1
09/22/2021 18:00	0.7	11.9	2,154.4	0.7	0.6	1	1	1
09/22/2021 19:00	0.7	12.3	2,035.1	0.7	0.6	1	1	1
09/22/2021 20:00	0.6	13.9	1,629.9	0.6	0.5	1	1	0
09/22/2021 21:00	0.7	13.7	1,741.8	0.7	0.5	1	1	1
09/22/2021 22:00	-0.1	12.7	1,973.4	0.1	0.6	1	1	1
09/22/2021 23:00	0.7	12.5	2,030.0	0.7	0.6	1	1	1
Average/Sum#:	0.2	12.9	1,902.9	0.3	0.6	24 #	24 #	20 #
Minimum:	-2.4	11.8	1,603.8	-1.7	0.5	1	1	0
Maximum:	0.7	13.9	2,154.4	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/23/2021 00:00	0.2	12.9	1,915.3	0.4	0.6	1	1	1
09/23/2021 01:00	0.6	13.9	1,544.6	0.6	0.5	1	1	0
09/23/2021 02:00	0.6	14.0	1,523.2	0.6	0.5	1	1	0
09/23/2021 03:00	0.6	14.0	1,623.4	0.6	0.5	1	1	0
09/23/2021 04:00	0.7	13.9	1,567.3	0.7	0.5	1	1	1
09/23/2021 05:00	0.2	12.7	2,000.5	0.4	0.6	1	1	1
09/23/2021 06:00	0.1	12.8	1,961.4	0.2	0.6	1	1	1
09/23/2021 07:00	0.6	13.9	1,644.7	0.6	0.5	1	1	0
09/23/2021 08:00	0.6	14.0	1,392.5	0.6	0.4	1	1	0
09/23/2021 09:00	0.6	13.7	1,736.5	0.6	0.5	1	1	0
09/23/2021 10:00	0.6	13.7	1,735.1	0.6	0.5	1	1	0
09/23/2021 11:00	0.6	13.7	1,729.2	0.6	0.5	1	1	0
09/23/2021 12:00	0.6	13.7	1,726.4	0.6	0.5	1	1	0
09/23/2021 13:00	0.6	13.7	1,724.7	0.6	0.5	1	1	0
09/23/2021 14:00	0.6	13.7	1,725.2	0.6	0.5	1	1	0
09/23/2021 15:00	0.6	13.7	1,724.3	0.6	0.5	1	1	0
09/23/2021 16:00	0.6	13.7	1,722.4	0.6	0.5	1	1	0
09/23/2021 17:00	0.6	13.7	1,724.6	0.6	0.5	1	1	0
09/23/2021 18:00	0.6	13.8	1,730.3	0.6	0.5	1	1	0
09/23/2021 19:00	0.6	13.8	1,732.8	0.6	0.5	1	1	0
09/23/2021 20:00	0.6	13.7	1,732.7	0.6	0.5	1	1	0
09/23/2021 21:00	0.6	13.8	1,732.8	0.6	0.5	1	1	0
09/23/2021 22:00	0.6	13.7	1,732.8	0.6	0.5	1	1	0
09/23/2021 23:00	0.6	13.7	1,736.0	0.6	0.5	1	1	0
Average/Sum#:	0.6	13.7	1,713.3	0.6	0.5	24 #	24 #	4 #
Minimum:	0.1	12.7	1,392.5	0.2	0.4	1	1	0
Maximum:	0.7	14.0	2,000.5	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/24/2021 00:00	0.6	13.7	1,736.8	0.6	0.5	1	1	0
09/24/2021 01:00	0.6	13.7	1,737.3	0.6	0.5	1	1	0
09/24/2021 02:00	0.6	13.7	1,738.3	0.6	0.5	1	1	0
09/24/2021 03:00	0.6	13.7	1,738.6	0.6	0.5	1	1	0
09/24/2021 04:00	0.6	13.7	1,745.1	0.6	0.5	1	1	0
09/24/2021 05:00	0.6	13.7	1,751.2	0.6	0.5	1	1	0
09/24/2021 06:00	0.6	13.7	1,751.5	0.6	0.5	1	1	0
09/24/2021 07:00	0.6	13.7	1,748.1	0.6	0.5	1	1	0
09/24/2021 08:00	0.6	13.7	1,742.3	0.6	0.5	1	1	0
09/24/2021 09:00	0.6	13.9	1,636.2	0.6	0.5	1	1	0
09/24/2021 10:00	0.6	13.9	1,515.9	0.6	0.5	1	1	0
09/24/2021 11:00	0.6	14.0	1,584.2	0.6	0.5	1	1	0
09/24/2021 12:00	0.6	14.0	1,579.0	0.6	0.5	1	1	0
09/24/2021 13:00	0.6	13.9	1,640.9	0.6	0.5	1	1	0
09/24/2021 14:00	0.6	13.8	1,678.6	0.6	0.5	1	1	0
09/24/2021 15:00	0.6	13.8	1,670.9	0.6	0.5	1	1	0
09/24/2021 16:00	0.6	13.8	1,657.4	0.6	0.5	1	1	0
09/24/2021 17:00	0.6	13.8	1,695.7	0.6	0.5	1	1	0
09/24/2021 18:00	0.6	13.9	1,637.3	0.6	0.5	1	1	0
09/24/2021 19:00	0.6	13.9	1,671.8	0.6	0.5	1	1	0
09/24/2021 20:00	0.6	13.9	1,615.8	0.6	0.5	1	1	0
09/24/2021 21:00	0.6	13.9	1,592.7	0.6	0.5	1	1	0
09/24/2021 22:00	0.6	13.9	1,627.7	0.6	0.5	1	1	0
09/24/2021 23:00	0.6	13.9	1,623.4	0.6	0.5	1	1	0
Average/Sum#:	0.6	13.8	1,671.5	0.6	0.5	24 #	24 #	0 #
Minimum:	0.6	13.7	1,515.9	0.6	0.5	1	1	0
Maximum:	0.6	14.0	1,751.5	0.6	0.5	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/25/2021 00:00	0.6	13.9	1,552.3	0.6	0.5	1	1	0
09/25/2021 01:00	0.6	13.9	1,618.0	0.6	0.5	1	1	0
09/25/2021 02:00	0.6	13.9	1,646.8	0.6	0.5	1	1	0
09/25/2021 03:00	0.6	13.9	1,645.9	0.6	0.5	1	1	0
09/25/2021 04:00	0.6	13.9	1,601.4	0.6	0.5	1	1	0
09/25/2021 05:00	0.6	13.9	1,581.9	0.6	0.5	1	1	0
09/25/2021 06:00	0.6	13.9	1,636.0	0.6	0.5	1	1	0
09/25/2021 07:00	0.6	13.9	1,623.5	0.6	0.5	1	1	0
09/25/2021 08:00	0.6	13.9	1,521.2	0.6	0.5	1	1	0
09/25/2021 09:00	0.6	14.0	1,328.5	0.6	0.4	1	1	0
09/25/2021 10:00	0.6	14.0	1,508.5	0.6	0.5	1	1	0
09/25/2021 11:00	0.6	13.9	1,637.1	0.6	0.5	1	1	0
09/25/2021 12:00	0.6	13.9	1,644.7	0.6	0.5	1	1	0
09/25/2021 13:00	0.6	13.9	1,638.9	0.6	0.5	1	1	0
09/25/2021 14:00	0.6	13.9	1,667.3	0.6	0.5	1	1	0
09/25/2021 15:00	0.6	13.8	1,662.9	0.6	0.5	1	1	0
09/25/2021 16:00	0.6	13.9	1,613.2	0.6	0.5	1	1	0
09/25/2021 17:00	0.6	14.0	1,316.6	0.6	0.4	1	1	0
09/25/2021 18:00	0.6	13.9	1,602.4	0.6	0.5	1	1	0
09/25/2021 19:00	0.6	13.9	1,664.1	0.6	0.5	1	1	0
09/25/2021 20:00	0.6	13.9	1,640.2	0.6	0.5	1	1	0
09/25/2021 21:00	0.6	13.9	1,548.2	0.6	0.5	1	1	0
09/25/2021 22:00	0.6	14.0	1,344.3	0.6	0.4	1	1	0
09/25/2021 23:00	0.6	14.0	1,310.5	0.6	0.4	1	1	0
Average/Sum#:	0.6	13.9	1,564.8	0.6	0.5	24 #	24 #	0 #
Minimum:	0.6	13.8	1,310.5	0.6	0.4	1	1	0
Maximum:	0.6	14.0	1,667.3	0.6	0.5	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/26/2021 00:00	0.6	14.0	1,313.2	0.6	0.4	1	1	0
09/26/2021 01:00	0.6	14.0	1,318.1	0.6	0.4	1	1	0
09/26/2021 02:00	0.6	14.0	1,323.5	0.6	0.4	1	1	0
09/26/2021 03:00	0.6	14.0	1,322.0	0.6	0.4	1	1	0
09/26/2021 04:00	0.6	14.0	1,323.2	0.6	0.4	1	1	0
09/26/2021 05:00	0.6	14.0	1,330.2	0.6	0.4	1	1	0
09/26/2021 06:00	0.6	14.0	1,372.8	0.6	0.4	1	1	0
09/26/2021 07:00	0.6	14.0	1,367.0	0.6	0.4	1	1	0
09/26/2021 08:00	0.6	14.0	1,326.1	0.6	0.4	1	1	0
09/26/2021 09:00	0.6	14.0	1,329.0	0.6	0.4	1	1	0
09/26/2021 10:00	0.6	14.0	1,356.2	0.6	0.4	1	1	0
09/26/2021 11:00	0.6	14.0	1,434.8	0.6	0.4	1	1	0
09/26/2021 12:00	0.6	14.0	1,329.5	0.6	0.4	1	1	0
09/26/2021 13:00	0.6	14.0	1,359.4	0.6	0.4	1	1	0
09/26/2021 14:00	0.6	14.0	1,362.0	0.6	0.4	1	1	0
09/26/2021 15:00	0.6	14.0	1,433.4	0.6	0.4	1	1	0
09/26/2021 16:00	0.6	14.0	1,415.0	0.6	0.4	1	1	0
09/26/2021 17:00	0.6	14.0	1,334.4	0.6	0.4	1	1	0
09/26/2021 18:00	0.6	14.0	1,323.7	0.6	0.4	1	1	0
09/26/2021 19:00	0.6	14.0	1,315.2	0.6	0.4	1	1	0
09/26/2021 20:00	0.6	14.0	1,316.4	0.6	0.4	1	1	0
09/26/2021 21:00	0.6	14.0	1,316.8	0.6	0.4	1	1	0
09/26/2021 22:00	0.6	14.0	1,317.8	0.6	0.4	1	1	0
09/26/2021 23:00	0.6	14.0	1,319.9	0.6	0.4	1	1	0
Average/Sum#:	0.6	14.0	1,344.2	0.6	0.4	24 #	24 #	0 #
Minimum:	0.6	14.0	1,313.2	0.6	0.4	1	1	0
Maximum:	0.6	14.0	1,434.8	0.6	0.4	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/27/2021 00:00	0.6	14.0	1,319.1	0.6	0.4	1	1	0
09/27/2021 01:00	0.6	14.0	1,318.1	0.6	0.4	1	1	0
09/27/2021 02:00	0.6	14.0	1,320.2	0.6	0.4	1	1	0
09/27/2021 03:00	0.6	14.0	1,320.1	0.6	0.4	1	1	0
09/27/2021 04:00	0.6	13.9	1,401.6	0.6	0.4	1	1	0
09/27/2021 05:00	0.6	13.8	1,659.9	0.6	0.5	1	1	0
09/27/2021 06:00	0.6	13.9	1,610.2	0.6	0.5	1	1	0
09/27/2021 07:00	0.6	13.9	1,472.0	0.6	0.4	1	1	0
09/27/2021 08:00	0.6	14.0	1,319.9	0.6	0.4	1	1	0
09/27/2021 09:00	0.6	14.0	1,319.3	0.6	0.4	1	1	0
09/27/2021 10:00	0.6	14.0	1,328.2	0.6	0.4	1	1	0
09/27/2021 11:00	0.6	14.0	1,332.5	0.6	0.4	1	1	0
09/27/2021 12:00	0.6	14.0	1,333.2	0.6	0.4	1	1	0
09/27/2021 13:00	0.6	14.0	1,329.4	0.6	0.4	1	1	0
09/27/2021 14:00	0.6	14.0	1,331.6	0.6	0.4	1	1	0
09/27/2021 15:00	0.6	14.0	1,325.6	0.6	0.4	1	1	0
09/27/2021 16:00	0.6	13.9	1,453.7	0.6	0.4	1	1	0
09/27/2021 17:00	0.6	14.0	1,364.5	0.6	0.4	1	1	0
09/27/2021 18:00	0.6	14.0	1,456.9	0.6	0.4	1	1	0
09/27/2021 19:00	0.6	14.0	1,462.7	0.6	0.4	1	1	0
09/27/2021 20:00	0.6	13.9	1,571.5	0.6	0.5	1	1	0
09/27/2021 21:00	0.6	14.0	1,415.2	0.6	0.4	1	1	0
09/27/2021 22:00	0.6	14.0	1,379.9	0.6	0.4	1	1	0
09/27/2021 23:00	0.6	14.0	1,320.0	0.6	0.4	1	1	0
Average/Sum#:	0.6	14.0	1,394.4	0.6	0.4	24 #	24 #	0 #
Minimum:	0.6	13.8	1,318.1	0.6	0.4	1	1	0
Maximum:	0.6	14.0	1,659.9	0.6	0.5	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/28/2021 00:00	0.6	14.0	1,321.8	0.6	0.4	1	1	0
09/28/2021 01:00	0.6	14.0	1,321.4	0.6	0.4	1	1	0
09/28/2021 02:00	0.6	14.0	1,319.6	0.6	0.4	1	1	0
09/28/2021 03:00	0.6	14.0	1,318.0	0.6	0.4	1	1	0
09/28/2021 04:00	0.6	14.0	1,421.4	0.6	0.4	1	1	0
09/28/2021 05:00	0.6	14.0	1,341.8	0.6	0.4	1	1	0
09/28/2021 06:00	0.6	14.0	1,504.3	0.6	0.5	1	1	0
09/28/2021 07:00	0.6	14.0	1,420.7	0.6	0.4	1	1	0
09/28/2021 08:00	0.6	14.0	1,438.2	0.6	0.4	1	1	0
09/28/2021 09:00	0.6	14.0	1,336.7	0.6	0.4	1	1	0
09/28/2021 10:00	0.6	14.1	1,340.8	0.6	0.4	1	1	0
09/28/2021 11:00	0.6	14.1	1,344.3	0.6	0.4	1	1	0
09/28/2021 12:00	0.6	14.1	1,344.2	0.6	0.4	1	1	0
09/28/2021 13:00	0.6	14.1	1,344.9	0.6	0.4	1	1	0
09/28/2021 14:00	0.6	14.1	1,344.7	0.6	0.4	1	1	0
09/28/2021 15:00	0.6	14.1	1,343.2	0.6	0.4	1	1	0
09/28/2021 16:00	0.7	14.0	1,461.7	0.7	0.4	1	1	1
09/28/2021 17:00	-1.2	12.7	2,020.9	-0.7	0.6	1	1	1
09/28/2021 18:00	0.4	12.1	2,133.9	0.5	0.6	1	1	1
09/28/2021 19:00	-1.1	13.0	1,927.9	-0.7	0.6	1	1	1
09/28/2021 20:00	-2.3	13.1	1,907.3	-1.5	0.6	1	1	1
09/28/2021 21:00	-2.4	13.1	1,888.7	-1.7	0.6	1	1	1
09/28/2021 22:00	0.6	14.0	1,353.7	0.6	0.4	1	1	0
09/28/2021 23:00	0.6	14.1	1,324.7	0.6	0.4	1	1	0
Average/Sum#:	0.2	13.8	1,492.7	0.3	0.4	24 #	24 #	6 #
Minimum:	-2.4	12.1	1,318.0	-1.7	0.4	1	1	0
Maximum:	0.7	14.1	2,133.9	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/29/2021 00:00	0.6	14.1	1,324.8	0.6	0.4	1	1	0
09/29/2021 01:00	0.6	14.0	1,324.9	0.6	0.4	1	1	0
09/29/2021 02:00	0.6	14.0	1,323.8	0.6	0.4	1	1	0
09/29/2021 03:00	0.6	13.9	1,611.5	0.6	0.5	1	1	0
09/29/2021 04:00	0.6	13.9	1,616.2	0.6	0.5	1	1	0
09/29/2021 05:00	0.6	13.8	1,733.8	0.6	0.5	1	1	0
09/29/2021 06:00	0.6	13.7	1,773.0	0.6	0.5	1	1	0
09/29/2021 07:00	0.6	13.7	1,768.9	0.6	0.5	1	1	0
09/29/2021 08:00	0.6	13.7	1,759.0	0.6	0.5	1	1	0
09/29/2021 09:00	0.6	13.9	1,493.7	0.6	0.4	1	1	0
09/29/2021 10:00	0.6	14.0	1,537.1	0.6	0.5	1	1	0
09/29/2021 11:00	0.6	13.9	1,463.8	0.6	0.4	1	1	0
09/29/2021 12:00	0.6	14.1	1,462.1	0.6	0.4	1	1	0
09/29/2021 13:00	0.6	14.0	1,619.6	0.6	0.5	1	1	0
09/29/2021 14:00	0.6	13.9	1,650.9	0.6	0.5	1	1	0
09/29/2021 15:00	0.6	13.9	1,658.9	0.6	0.5	1	1	0
09/29/2021 16:00	0.6	13.9	1,645.7	0.6	0.5	1	1	0
09/29/2021 17:00	0.6	14.0	1,415.3	0.6	0.4	1	1	0
09/29/2021 18:00	0.6	14.1	1,373.6	0.6	0.4	1	1	0
09/29/2021 19:00	0.6	13.9	1,628.7	0.6	0.5	1	1	0
09/29/2021 20:00	0.6	13.9	1,644.4	0.6	0.5	1	1	0
09/29/2021 21:00	0.6	13.9	1,608.9	0.6	0.5	1	1	0
09/29/2021 22:00	0.6	13.9	1,637.4	0.6	0.5	1	1	0
09/29/2021 23:00	0.6	13.9	1,514.1	0.6	0.5	1	1	0
Average/Sum#:	0.6	13.9	1,566.3	0.6	0.5	24 #	24 #	0 #
Minimum:	0.6	13.7	1,323.8	0.6	0.4	1	1	0
Maximum:	0.6	14.1	1,773.0	0.6	0.5	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/30/2021 00:00	0.6	14.0	1,492.1	0.6	0.4	1	1	0
09/30/2021 01:00	0.6	14.1	1,306.7	0.6	0.4	1	1	0
09/30/2021 02:00	0.6	14.1	1,281.8	0.6	0.4	1	1	0
09/30/2021 03:00	0.6	14.0	1,534.4	0.6	0.5	1	1	0
09/30/2021 04:00	0.6	14.0	1,594.3	0.6	0.5	1	1	0
09/30/2021 05:00	0.6	14.1	1,319.4	0.6	0.4	1	1	0
09/30/2021 06:00	0.0	16.2	349.6	0.0	0.1	1	0	0
09/30/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/30/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/30/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/30/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/30/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/30/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/30/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/30/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/30/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/30/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/30/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/30/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/30/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/30/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/30/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/30/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/30/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.5	14.4	1,268.3	0.5	0.4	7 #	6 #	0 #
Minimum:	0.0	14.0	349.6	0.0	0.1	0	0	0
Maximum:	0.6	16.2	1,594.3	0.6	0.5	1	1	0
%SI	70.83	70.83	70.83	70.83	70.83	0.00	0.00	0.00

Excess Emission Report

CT2 -VOC Lb 1-Day Block Average

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/04/2021 10:27 **Location:** Maxwell, CA

Tag Name: CT2_VOC_Lb_1D
Total Operating Time: 80.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 12.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**80.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 - VOC LbPerHr 1-Hour Block Average

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/04/2021 10:28 **Location:** Maxwell, CA

Tag Name: CT1_VOC_LbPerHr_1H
Total Operating Time: 1,737.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 471.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,737.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 - VOC Ppmvdc 1-Hour Block Average

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/04/2021 10:29 **Location:** Maxwell, CA

Tag Name: CT1_VOC_Ppmvdc_1H
Total Operating Time: 1,737.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 471.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,737.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 - VOC Lb 1-Day Block Average

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/04/2021 10:30 **Location:** Maxwell, CA

Tag Name: CT1_VOC_Lb_1D
Total Operating Time: 79.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 13.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**79.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - VOC LbPerHr 1-Hour Block Average

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/04/2021 10:30 **Location:** Maxwell, CA

Tag Name: CT2_VOC_LbPerHr_1H
Total Operating Time: 1,739.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 469.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,739.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - NOx Ppmvdc 1-Hour Block Average

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/04/2021 10:31 **Location:** Maxwell, CA

Tag Name: CT2_NOx_Ppmvdc_1H
Total Operating Time: 1,779.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 429.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,779.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

ATTACHMENT 6
Hourly Emissions – NOx

FCD: AQ-15
Title V: #6

Excess Emission Report

CT1 - NOx Lb 1-Day Block Average

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/04/2021 10:33 **Location:** Maxwell, CA

Tag Name: CT1_NOx_Lb_1D
Total Operating Time: 1,776.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 432.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,776.00 Hour(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - NOx Lb 1-Day Block Average

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/04/2021 10:33 **Location:** Maxwell, CA

Tag Name: CT2_NOx_Lb_1D
Total Operating Time: 1,779.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 429.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,779.00 Hour(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Daily Summary Report

CT1 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/01/2021 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2021 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2021 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2021 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2021 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2021 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2021 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2021 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2021 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2021 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2021 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2021 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2021 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2021 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2021 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2021 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/02/2021 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2021 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2021 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2021 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2021 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2021 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2021 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2021 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2021 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2021 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2021 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2021 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2021 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2021 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2021 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2021 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/03/2021 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/03/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/03/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/03/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/03/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/03/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/03/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/03/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/03/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/03/2021 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/03/2021 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/03/2021 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/03/2021 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/03/2021 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/03/2021 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/03/2021 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/03/2021 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/03/2021 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/03/2021 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/03/2021 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/03/2021 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/03/2021 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/03/2021 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/03/2021 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/04/2021 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2021 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2021 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2021 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2021 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2021 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2021 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2021 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2021 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2021 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2021 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2021 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2021 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2021 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2021 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2021 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/05/2021 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/05/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/05/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/05/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/05/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/05/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/05/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/05/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/05/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/05/2021 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/05/2021 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/05/2021 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/05/2021 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/05/2021 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/05/2021 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/05/2021 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/05/2021 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/05/2021 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/05/2021 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/05/2021 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/05/2021 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/05/2021 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/05/2021 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/05/2021 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/06/2021 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/06/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/06/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/06/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/06/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/06/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/06/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/06/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/06/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/06/2021 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/06/2021 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/06/2021 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/06/2021 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/06/2021 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/06/2021 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/06/2021 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/06/2021 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/06/2021 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/06/2021 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/06/2021 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/06/2021 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/06/2021 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/06/2021 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/06/2021 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/07/2021 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/07/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/07/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/07/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/07/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/07/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/07/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/07/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/07/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/07/2021 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/07/2021 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/07/2021 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/07/2021 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/07/2021 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/07/2021 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/07/2021 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/07/2021 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/07/2021 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/07/2021 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/07/2021 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/07/2021 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/07/2021 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/07/2021 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/07/2021 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/08/2021 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/08/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/08/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/08/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/08/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/08/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/08/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/08/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/08/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/08/2021 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/08/2021 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/08/2021 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/08/2021 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/08/2021 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/08/2021 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/08/2021 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/08/2021 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/08/2021 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/08/2021 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/08/2021 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/08/2021 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/08/2021 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/08/2021 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/08/2021 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/09/2021 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/09/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/09/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/09/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/09/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/09/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/09/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/09/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/09/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/09/2021 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/09/2021 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/09/2021 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/09/2021 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/09/2021 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/09/2021 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/09/2021 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/09/2021 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/09/2021 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/09/2021 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/09/2021 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/09/2021 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/09/2021 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/09/2021 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/09/2021 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/10/2021 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/10/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/10/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/10/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/10/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/10/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/10/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/10/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/10/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/10/2021 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/10/2021 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/10/2021 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/10/2021 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/10/2021 13:00	29.2	17.5	277.5	50.7	27.51	1	0	0
07/10/2021 14:00	25.5	16.9	364.5	37.6	50.70	1	0	0
07/10/2021 15:00	9.1	15.6	636.7	10.1	23.60	1	0	0
07/10/2021 16:00	3.1	14.0	1,294.4	2.7	12.90	1	0	0
07/10/2021 17:00	1.2	13.5	1,643.7	1.0	6.60	1	1	0
07/10/2021 18:00	1.2	13.4	1,705.4	0.9	5.10	1	1	0
07/10/2021 19:00	1.2	13.4	1,711.6	0.9	5.10	1	1	0
07/10/2021 20:00	1.2	13.4	1,730.2	0.9	5.20	1	1	0
07/10/2021 21:00	1.2	13.4	1,742.3	0.9	5.20	1	1	0
07/10/2021 22:00	1.2	13.4	1,743.5	0.9	5.20	1	1	0
07/10/2021 23:00	1.5	14.1	1,326.0	1.3	4.62	1	0	0
Average/Sum#:	6.9	14.4	1,288.7	9.8	151.73 #	11 #	6 #	0 #
Minimum:	1.2	13.4	277.5	0.9	4.62	0	0	0
Maximum:	29.2	17.5	1,743.5	50.7	50.70	1	1	0
%SI	54.17	54.17	54.17	54.17	54.17	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/11/2021 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/11/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/11/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/11/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/11/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/11/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/11/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/11/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/11/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/11/2021 09:00	26.4	17.5	319.9	45.8	35.17	1	0	0
07/11/2021 10:00	8.1	16.9	408.6	11.9	18.00	1	0	0
07/11/2021 11:00	5.4	14.4	1,082.8	4.9	19.50	1	0	0
07/11/2021 12:00	1.2	13.8	1,380.4	1.0	5.50	1	1	0
07/11/2021 13:00	1.7	13.7	1,485.8	1.4	7.40	1	1	0
07/11/2021 14:00	1.2	13.5	1,680.2	1.0	6.70	1	1	0
07/11/2021 15:00	1.8	13.5	1,625.7	1.4	8.10	1	1	0
07/11/2021 16:00	1.9	13.3	1,704.5	1.5	8.50	1	1	0
07/11/2021 17:00	1.2	13.4	1,707.9	0.9	5.10	1	1	0
07/11/2021 18:00	1.2	13.4	1,715.3	0.9	5.10	1	1	0
07/11/2021 19:00	1.2	13.4	1,723.8	0.9	5.20	1	1	0
07/11/2021 20:00	1.2	13.4	1,722.9	0.9	5.20	1	1	0
07/11/2021 21:00	1.2	13.5	1,709.5	1.0	6.80	1	1	0
07/11/2021 22:00	1.2	13.6	1,704.6	1.0	6.80	1	1	0
07/11/2021 23:00	1.1	13.5	1,673.2	0.9	5.00	1	1	0
Average/Sum#:	3.7	14.1	1,443.0	5.0	148.07 #	15 #	12 #	0 #
Minimum:	1.1	13.3	319.9	0.9	5.00	0	0	0
Maximum:	26.4	17.5	1,723.8	45.8	35.17	1	1	0
%SI	37.50	37.50	37.50	37.50	37.50	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/12/2021 00:00	1.2	13.5	1,705.3	1.0	6.80	1	1	0
07/12/2021 01:00	2.3	15.6	501.7	2.6	0.90	1	0	0
07/12/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/12/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/12/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/12/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/12/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/12/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/12/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/12/2021 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/12/2021 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/12/2021 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/12/2021 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/12/2021 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/12/2021 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/12/2021 15:00	15.3	17.9	277.5	30.1	11.40	1	0	0
07/12/2021 16:00	14.2	14.9	1,085.2	14.0	55.30	1	0	0
07/12/2021 17:00	1.2	13.4	1,748.9	0.9	5.20	1	1	0
07/12/2021 18:00	1.2	13.5	1,731.1	1.0	6.90	1	1	0
07/12/2021 19:00	1.2	13.5	1,735.7	1.0	6.90	1	1	0
07/12/2021 20:00	1.2	13.4	1,771.0	0.9	5.30	1	1	0
07/12/2021 21:00	1.2	13.4	1,756.0	0.9	5.30	1	1	0
07/12/2021 22:00	1.4	14.1	1,360.8	1.2	4.86	1	0	0
07/12/2021 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	4.0	14.3	1,367.3	5.4	108.86 #	10 #	6 #	0 #
Minimum:	1.2	13.4	277.5	0.9	0.90	0	0	0
Maximum:	15.3	17.9	1,771.0	30.1	55.30	1	1	0
%SI	58.33	58.33	58.33	58.33	58.33	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/13/2021 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/13/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/13/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/13/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/13/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/13/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/13/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/13/2021 07:00	16.2	17.6	333.6	29.0	22.13	1	0	0
07/13/2021 08:00	3.7	17.0	390.2	5.6	8.20	1	0	0
07/13/2021 09:00	3.0	17.1	345.5	4.7	5.72	1	0	0
07/13/2021 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/13/2021 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/13/2021 12:00	3.5	17.2	390.1	5.6	7.63	1	0	0
07/13/2021 13:00	9.4	15.8	618.9	10.9	18.60	1	0	0
07/13/2021 14:00	0.2	18.3	220.8	0.5	0.10	1	0	0
07/13/2021 15:00	6.4	15.9	661.2	7.6	18.50	1	0	0
07/13/2021 16:00	4.9	14.4	1,270.7	4.4	20.30	1	0	0
07/13/2021 17:00	1.2	13.4	1,757.7	0.9	5.30	1	1	0
07/13/2021 18:00	1.1	13.5	1,553.6	0.9	4.70	1	1	0
07/13/2021 19:00	1.2	13.4	1,726.7	0.9	5.20	1	1	0
07/13/2021 20:00	1.1	13.4	1,774.9	0.9	5.30	1	1	0
07/13/2021 21:00	1.4	14.0	1,397.2	1.2	5.32	1	0	0
07/13/2021 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/13/2021 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	4.1	15.5	957.0	5.6	127.00 #	13 #	4 #	0 #
Minimum:	0.2	13.4	220.8	0.5	0.10	0	0	0
Maximum:	16.2	18.3	1,774.9	29.0	22.13	1	1	0
%SI	45.83	45.83	45.83	45.83	45.83	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/14/2021 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/14/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/14/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/14/2021 03:00	4.2	16.5	562.5	5.6	6.84	1	0	0
07/14/2021 04:00	2.5	13.9	1,425.1	2.1	11.40	1	0	0
07/14/2021 05:00	1.3	13.6	1,702.9	1.1	6.80	1	1	0
07/14/2021 06:00	1.5	13.6	1,641.4	1.2	6.60	1	1	0
07/14/2021 07:00	1.4	13.6	1,679.9	1.1	6.70	1	1	1
07/14/2021 08:00	1.3	12.3	1,910.2	0.9	5.70	1	1	1
07/14/2021 09:00	1.3	12.4	1,992.3	0.9	6.00	1	1	1
07/14/2021 10:00	1.1	13.6	1,664.5	0.9	5.00	1	1	0
07/14/2021 11:00	1.1	13.6	1,595.0	0.9	4.80	1	1	1
07/14/2021 12:00	1.4	12.0	2,096.4	0.9	6.30	1	1	1
07/14/2021 13:00	1.5	11.2	2,237.6	0.9	6.70	1	1	1
07/14/2021 14:00	1.5	11.2	2,233.0	0.9	6.70	1	1	1
07/14/2021 15:00	1.5	11.3	2,218.1	0.9	6.70	1	1	1
07/14/2021 16:00	1.5	11.2	2,235.0	0.9	6.70	1	1	1
07/14/2021 17:00	1.5	11.2	2,238.8	0.9	6.70	1	1	1
07/14/2021 18:00	1.5	11.3	2,222.0	0.9	6.70	1	1	1
07/14/2021 19:00	1.5	11.6	2,174.9	1.0	8.70	1	1	1
07/14/2021 20:00	1.4	11.6	2,159.8	0.9	6.50	1	1	1
07/14/2021 21:00	1.4	11.9	2,112.7	0.9	6.30	1	1	1
07/14/2021 22:00	1.4	11.9	2,111.8	0.9	6.30	1	1	1
07/14/2021 23:00	1.4	12.0	2,105.2	0.9	6.30	1	1	1
Average/Sum#:	1.6	12.5	1,920.0	1.2	140.44 #	21 #	19 #	16 #
Minimum:	1.1	11.2	562.5	0.9	4.80	0	0	0
Maximum:	4.2	16.5	2,238.8	5.6	11.40	1	1	1
%SI	12.50	12.50	12.50	12.50	12.50	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/15/2021 00:00	1.3	12.3	2,016.4	0.9	6.00	1	1	1
07/15/2021 01:00	1.1	13.6	1,562.9	0.9	4.70	1	1	0
07/15/2021 02:00	1.2	13.7	1,509.7	1.0	6.00	1	1	0
07/15/2021 03:00	1.1	13.7	1,490.1	0.9	4.50	1	1	0
07/15/2021 04:00	1.2	13.6	1,712.7	1.0	6.90	1	1	0
07/15/2021 05:00	1.4	12.4	1,975.5	1.0	7.90	1	1	1
07/15/2021 06:00	1.3	12.3	2,039.9	0.9	6.10	1	1	1
07/15/2021 07:00	1.1	13.6	1,646.3	0.9	4.90	1	1	1
07/15/2021 08:00	1.2	13.6	1,646.6	1.0	6.60	1	1	0
07/15/2021 09:00	1.1	13.7	1,574.1	0.9	4.70	1	1	0
07/15/2021 10:00	1.1	13.7	1,677.1	0.9	5.00	1	1	0
07/15/2021 11:00	1.1	13.7	1,575.4	0.9	4.70	1	1	1
07/15/2021 12:00	1.4	12.0	2,105.0	0.9	6.30	1	1	1
07/15/2021 13:00	1.4	11.7	2,152.1	0.9	6.50	1	1	1
07/15/2021 14:00	1.4	11.6	2,176.0	0.9	6.50	1	1	1
07/15/2021 15:00	1.4	11.6	2,180.0	0.9	6.50	1	1	1
07/15/2021 16:00	1.4	11.5	2,189.0	0.9	6.60	1	1	1
07/15/2021 17:00	1.5	11.5	2,181.1	0.9	6.50	1	1	1
07/15/2021 18:00	1.5	11.4	2,216.8	0.9	6.70	1	1	1
07/15/2021 19:00	1.5	11.3	2,224.1	0.9	6.70	1	1	1
07/15/2021 20:00	1.5	11.4	2,234.4	0.9	6.70	1	1	1
07/15/2021 21:00	1.4	11.7	2,169.3	0.9	6.50	1	1	1
07/15/2021 22:00	1.4	12.0	2,110.6	0.9	6.30	1	1	1
07/15/2021 23:00	1.4	12.0	2,120.0	0.9	6.40	1	1	1
Average/Sum#:	1.3	12.5	1,936.9	0.9	146.20 #	24 #	24 #	17 #
Minimum:	1.1	11.3	1,490.1	0.9	4.50	1	1	0
Maximum:	1.5	13.7	2,234.4	1.0	7.90	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/16/2021 00:00	1.4	12.1	2,113.2	0.9	6.30	1	1	1
07/16/2021 01:00	1.3	12.5	1,998.9	0.9	6.00	1	1	1
07/16/2021 02:00	1.1	13.6	1,639.8	0.9	4.90	1	1	0
07/16/2021 03:00	1.1	13.6	1,483.0	0.9	4.40	1	1	0
07/16/2021 04:00	1.2	13.6	1,636.0	1.0	6.50	1	1	0
07/16/2021 05:00	1.3	12.9	1,820.7	1.0	7.30	1	1	1
07/16/2021 06:00	1.3	12.7	1,887.8	0.9	5.70	1	1	1
07/16/2021 07:00	1.2	13.6	1,686.1	1.0	6.70	1	1	0
07/16/2021 08:00	1.2	13.6	1,688.3	1.0	6.80	1	1	0
07/16/2021 09:00	1.1	13.6	1,657.6	0.9	5.00	1	1	0
07/16/2021 10:00	1.2	13.6	1,705.4	1.0	6.80	1	1	0
07/16/2021 11:00	1.1	13.6	1,530.9	0.9	4.60	1	1	0
07/16/2021 12:00	1.4	12.3	2,041.8	1.0	8.20	1	1	1
07/16/2021 13:00	1.3	12.2	2,025.2	0.9	6.10	1	1	1
07/16/2021 14:00	1.1	13.6	1,667.1	0.9	5.00	1	1	0
07/16/2021 15:00	1.1	13.6	1,614.4	0.9	4.80	1	1	1
07/16/2021 16:00	1.4	12.0	2,126.2	0.9	6.40	1	1	1
07/16/2021 17:00	1.5	11.2	2,262.6	0.9	6.80	1	1	1
07/16/2021 18:00	1.5	11.1	2,284.9	0.9	6.90	1	1	1
07/16/2021 19:00	1.5	11.1	2,280.3	0.9	6.80	1	1	1
07/16/2021 20:00	1.5	11.3	2,263.6	0.9	6.80	1	1	1
07/16/2021 21:00	1.4	11.5	2,207.6	0.9	6.60	1	1	1
07/16/2021 22:00	1.4	11.7	2,174.9	0.9	6.50	1	1	1
07/16/2021 23:00	1.4	11.9	2,129.1	0.9	6.40	1	1	1
Average/Sum#:	1.3	12.6	1,913.6	0.9	148.30 #	24 #	24 #	15 #
Minimum:	1.1	11.1	1,483.0	0.9	4.40	1	1	0
Maximum:	1.5	13.6	2,284.9	1.0	8.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/17/2021 00:00	1.3	12.5	1,972.6	0.9	5.90	1	1	1
07/17/2021 01:00	1.2	13.6	1,666.8	1.0	6.70	1	1	0
07/17/2021 02:00	1.2	13.7	1,328.0	1.0	5.30	1	1	0
07/17/2021 03:00	1.1	13.7	1,634.2	0.9	4.90	1	1	0
07/17/2021 04:00	1.2	13.1	1,844.6	0.9	5.50	1	1	1
07/17/2021 05:00	1.1	12.9	1,879.3	0.8	5.60	1	1	1
07/17/2021 06:00	1.2	13.6	1,645.7	1.0	6.60	1	1	0
07/17/2021 07:00	1.1	13.7	1,649.0	0.9	4.90	1	1	0
07/17/2021 08:00	1.1	13.7	1,609.6	0.9	4.80	1	1	0
07/17/2021 09:00	1.2	13.6	1,703.5	1.0	6.80	1	1	0
07/17/2021 10:00	1.1	13.7	1,622.1	0.9	4.90	1	1	0
07/17/2021 11:00	1.1	13.7	1,538.1	0.9	4.60	1	1	0
07/17/2021 12:00	1.2	13.6	1,639.8	1.0	6.60	1	1	1
07/17/2021 13:00	1.4	11.9	2,136.6	0.9	6.40	1	1	1
07/17/2021 14:00	1.5	11.3	2,246.5	0.9	6.70	1	1	1
07/17/2021 15:00	1.5	11.3	2,243.6	0.9	6.70	1	1	1
07/17/2021 16:00	1.5	11.2	2,262.7	0.9	6.80	1	1	1
07/17/2021 17:00	1.5	11.1	2,283.0	0.9	6.80	1	1	1
07/17/2021 18:00	1.5	11.1	2,286.9	0.9	6.90	1	1	1
07/17/2021 19:00	1.5	11.0	2,279.2	0.9	6.80	1	1	1
07/17/2021 20:00	1.5	11.2	2,258.8	0.9	6.80	1	1	1
07/17/2021 21:00	1.5	11.3	2,224.9	0.9	6.70	1	1	1
07/17/2021 22:00	1.4	11.7	2,172.0	0.9	6.50	1	1	1
07/17/2021 23:00	1.4	11.7	2,167.3	0.9	6.50	1	1	1
Average/Sum#:	1.3	12.5	1,929.0	0.9	146.70 #	24 #	24 #	15 #
Minimum:	1.1	11.0	1,328.0	0.8	4.60	1	1	0
Maximum:	1.5	13.7	2,286.9	1.0	6.90	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/18/2021 00:00	1.4	12.2	2,036.6	0.9	6.10	1	1	1
07/18/2021 01:00	1.1	13.6	1,668.4	0.9	5.00	1	1	0
07/18/2021 02:00	1.2	13.6	1,587.1	1.0	6.30	1	1	1
07/18/2021 03:00	1.4	12.3	2,060.2	1.0	8.20	1	1	1
07/18/2021 04:00	1.3	12.4	2,004.2	0.9	6.00	1	1	1
07/18/2021 05:00	1.1	13.6	1,675.6	0.9	5.00	1	1	0
07/18/2021 06:00	1.1	13.6	1,676.3	0.9	5.00	1	1	0
07/18/2021 07:00	1.1	13.7	1,669.6	0.9	5.00	1	1	0
07/18/2021 08:00	1.1	13.6	1,691.3	0.9	5.10	1	1	0
07/18/2021 09:00	1.1	13.7	1,665.4	0.9	5.00	1	1	0
07/18/2021 10:00	1.1	13.7	1,606.5	0.9	4.80	1	1	0
07/18/2021 11:00	1.2	13.6	1,723.2	1.0	6.90	1	1	1
07/18/2021 12:00	1.4	11.9	2,125.3	0.9	6.40	1	1	1
07/18/2021 13:00	1.5	11.1	2,274.2	0.9	6.80	1	1	1
07/18/2021 14:00	1.5	11.1	2,280.6	0.9	6.80	1	1	1
07/18/2021 15:00	1.5	11.1	2,277.0	0.9	6.80	1	1	1
07/18/2021 16:00	1.5	11.0	2,268.0	0.9	6.80	1	1	1
07/18/2021 17:00	1.5	11.0	2,262.4	0.9	6.80	1	1	1
07/18/2021 18:00	1.5	11.2	2,228.6	0.9	6.70	1	1	1
07/18/2021 19:00	1.4	11.4	2,208.5	0.9	6.60	1	1	1
07/18/2021 20:00	1.4	11.5	2,203.7	0.9	6.60	1	1	1
07/18/2021 21:00	1.5	11.3	2,246.1	0.9	6.70	1	1	1
07/18/2021 22:00	1.5	11.4	2,236.8	0.9	6.70	1	1	1
07/18/2021 23:00	1.4	11.4	2,233.9	0.9	6.70	1	1	1
Average/Sum#:	1.3	12.3	1,996.2	0.9	148.80 #	24 #	24 #	17 #
Minimum:	1.1	11.0	1,587.1	0.9	4.80	1	1	0
Maximum:	1.5	13.7	2,280.6	1.0	8.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/19/2021 00:00	1.5	11.5	2,213.9	0.9	6.60	1	1	1
07/19/2021 01:00	1.2	13.3	1,723.8	0.9	5.20	1	1	1
07/19/2021 02:00	1.2	13.6	1,698.0	1.0	6.80	1	1	0
07/19/2021 03:00	1.2	13.6	1,645.9	1.0	6.60	1	1	0
07/19/2021 04:00	1.2	13.6	1,714.6	1.0	6.90	1	1	1
07/19/2021 05:00	1.5	11.9	2,086.0	1.0	8.30	1	1	1
07/19/2021 06:00	1.4	11.8	2,125.0	0.9	6.40	1	1	1
07/19/2021 07:00	1.1	13.6	1,614.4	0.9	4.80	1	1	0
07/19/2021 08:00	1.2	13.6	1,636.5	1.0	6.50	1	1	0
07/19/2021 09:00	1.1	13.6	1,598.9	0.9	4.80	1	1	0
07/19/2021 10:00	1.4	12.0	2,098.5	0.9	6.30	1	1	1
07/19/2021 11:00	1.5	11.2	2,247.4	0.9	6.70	1	1	1
07/19/2021 12:00	1.5	11.1	2,271.4	0.9	6.80	1	1	1
07/19/2021 13:00	1.5	11.1	2,271.8	0.9	6.80	1	1	1
07/19/2021 14:00	1.5	11.1	2,276.4	0.9	6.80	1	1	1
07/19/2021 15:00	1.5	11.0	2,265.0	0.9	6.80	1	1	1
07/19/2021 16:00	1.5	11.0	2,276.1	0.9	6.80	1	1	1
07/19/2021 17:00	1.5	11.1	2,275.8	0.9	6.80	1	1	1
07/19/2021 18:00	1.5	11.1	2,278.6	0.9	6.80	1	1	1
07/19/2021 19:00	1.5	11.1	2,290.5	0.9	6.90	1	1	1
07/19/2021 20:00	1.5	11.1	2,284.8	0.9	6.90	1	1	1
07/19/2021 21:00	1.5	11.2	2,252.2	0.9	6.80	1	1	1
07/19/2021 22:00	1.4	11.8	2,141.8	0.9	6.40	1	1	1
07/19/2021 23:00	1.4	11.9	2,128.5	0.9	6.40	1	1	1
Average/Sum#:	1.4	12.0	2,059.0	0.9	156.90 #	24 #	24 #	19 #
Minimum:	1.1	11.0	1,598.9	0.9	4.80	1	1	0
Maximum:	1.5	13.6	2,290.5	1.0	8.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/20/2021 00:00	1.4	12.0	2,099.3	0.9	6.30	1	1	1
07/20/2021 01:00	1.2	13.5	1,690.0	1.0	6.80	1	1	1
07/20/2021 02:00	1.2	13.6	1,700.2	1.0	6.80	1	1	0
07/20/2021 03:00	1.2	13.6	1,701.4	1.0	6.80	1	1	1
07/20/2021 04:00	1.3	12.3	2,073.1	0.9	6.20	1	1	1
07/20/2021 05:00	1.5	11.7	2,204.6	1.0	8.80	1	1	1
07/20/2021 06:00	1.1	13.3	1,694.2	0.9	5.10	1	1	1
07/20/2021 07:00	1.2	13.6	1,657.8	1.0	6.60	1	1	0
07/20/2021 08:00	1.2	13.6	1,606.9	1.0	6.40	1	1	0
07/20/2021 09:00	1.2	13.6	1,643.0	1.0	6.60	1	1	0
07/20/2021 10:00	1.2	13.6	1,677.9	1.0	6.70	1	1	0
07/20/2021 11:00	1.2	13.6	1,603.9	1.0	6.40	1	1	0
07/20/2021 12:00	1.1	13.6	1,675.6	0.9	5.00	1	1	1
07/20/2021 13:00	1.4	12.0	2,089.1	0.9	6.30	1	1	1
07/20/2021 14:00	1.5	11.3	2,204.6	0.9	6.60	1	1	1
07/20/2021 15:00	1.5	11.2	2,237.2	0.9	6.70	1	1	1
07/20/2021 16:00	1.5	11.0	2,268.2	0.9	6.80	1	1	1
07/20/2021 17:00	1.5	11.0	2,269.9	0.9	6.80	1	1	1
07/20/2021 18:00	1.5	11.0	2,272.6	0.9	6.80	1	1	1
07/20/2021 19:00	1.7	11.0	2,266.0	1.0	9.10	1	1	1
07/20/2021 20:00	2.9	11.0	2,288.8	1.7	13.70	1	1	1
07/20/2021 21:00	2.7	11.3	2,224.6	1.7	13.30	1	1	1
07/20/2021 22:00	2.5	11.5	2,198.7	1.6	13.20	1	1	1
07/20/2021 23:00	2.4	11.7	2,174.3	1.5	13.00	1	1	1
Average/Sum#:	1.5	12.3	1,980.1	1.1	186.80 #	24 #	24 #	18 #
Minimum:	1.1	11.0	1,603.9	0.9	5.00	1	1	0
Maximum:	2.9	13.6	2,288.8	1.7	13.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/21/2021 00:00	2.1	12.2	2,055.4	1.4	10.30	1	1	1
07/21/2021 01:00	1.6	13.6	1,647.8	1.3	8.20	1	1	0
07/21/2021 02:00	1.4	13.6	1,669.5	1.1	6.70	1	1	0
07/21/2021 03:00	1.6	12.9	1,864.7	1.2	7.50	1	1	1
07/21/2021 04:00	2.1	12.1	2,071.1	1.4	10.40	1	1	1
07/21/2021 05:00	1.0	13.6	1,635.7	0.8	4.90	1	1	0
07/21/2021 06:00	1.1	13.6	1,593.0	0.9	4.80	1	1	1
07/21/2021 07:00	1.4	12.3	2,065.1	1.0	8.30	1	1	1
07/21/2021 08:00	1.3	12.5	1,992.1	0.9	6.00	1	1	1
07/21/2021 09:00	1.1	13.6	1,705.7	0.9	5.10	1	1	0
07/21/2021 10:00	1.2	13.6	1,619.9	1.0	6.50	1	1	1
07/21/2021 11:00	1.4	12.0	2,109.5	0.9	6.30	1	1	1
07/21/2021 12:00	1.4	11.7	2,154.6	0.9	6.50	1	1	1
07/21/2021 13:00	1.4	11.7	2,175.1	0.9	6.50	1	1	1
07/21/2021 14:00	1.4	11.5	2,188.9	0.9	6.60	1	1	1
07/21/2021 15:00	1.5	11.4	2,210.2	0.9	6.60	1	1	1
07/21/2021 16:00	1.5	11.4	2,206.1	0.9	6.60	1	1	1
07/21/2021 17:00	1.5	11.3	2,229.6	0.9	6.70	1	1	1
07/21/2021 18:00	1.5	11.0	2,270.4	0.9	6.80	1	1	1
07/21/2021 19:00	1.5	11.0	2,270.4	0.9	6.80	1	1	1
07/21/2021 20:00	1.5	11.0	2,281.4	0.9	6.80	1	1	1
07/21/2021 21:00	1.5	11.3	2,240.9	0.9	6.70	1	1	1
07/21/2021 22:00	1.4	11.5	2,206.0	0.9	6.60	1	1	1
07/21/2021 23:00	1.4	11.8	2,143.1	0.9	6.40	1	1	1
Average/Sum#:	1.5	12.2	2,025.3	1.0	164.60 #	24 #	24 #	20 #
Minimum:	1.0	11.0	1,593.0	0.8	4.80	1	1	0
Maximum:	2.1	13.6	2,281.4	1.4	10.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/22/2021 00:00	1.4	12.2	2,045.5	0.9	6.10	1	1	1
07/22/2021 01:00	1.1	13.6	1,676.7	0.9	5.00	1	1	0
07/22/2021 02:00	1.1	13.5	1,576.1	0.9	4.70	1	1	1
07/22/2021 03:00	1.4	12.2	2,056.5	0.9	6.20	1	1	1
07/22/2021 04:00	1.3	12.4	1,998.4	0.9	6.00	1	1	1
07/22/2021 05:00	1.1	13.6	1,615.0	0.9	4.80	1	1	0
07/22/2021 06:00	1.1	13.5	1,705.5	0.9	5.10	1	1	1
07/22/2021 07:00	1.4	12.2	2,067.2	0.9	6.20	1	1	1
07/22/2021 08:00	1.3	12.5	2,005.3	0.9	6.00	1	1	1
07/22/2021 09:00	1.1	13.5	1,627.9	0.9	4.90	1	1	1
07/22/2021 10:00	1.2	13.6	1,651.1	1.0	6.60	1	1	0
07/22/2021 11:00	1.2	13.5	1,770.1	1.0	7.10	1	1	1
07/22/2021 12:00	1.4	11.9	2,135.0	0.9	6.40	1	1	1
07/22/2021 13:00	1.5	11.3	2,257.4	0.9	6.80	1	1	1
07/22/2021 14:00	1.5	11.4	2,230.9	0.9	6.70	1	1	1
07/22/2021 15:00	1.5	11.4	2,225.0	0.9	6.70	1	1	1
07/22/2021 16:00	1.5	11.2	2,264.5	0.9	6.80	1	1	1
07/22/2021 17:00	1.5	11.3	2,246.1	0.9	6.70	1	1	1
07/22/2021 18:00	1.5	11.1	2,284.5	0.9	6.90	1	1	1
07/22/2021 19:00	1.5	11.1	2,277.1	0.9	6.80	1	1	1
07/22/2021 20:00	1.5	11.2	2,257.8	0.9	6.80	1	1	1
07/22/2021 21:00	1.4	11.6	2,172.3	0.9	6.50	1	1	1
07/22/2021 22:00	1.4	11.7	2,155.3	0.9	6.50	1	1	1
07/22/2021 23:00	1.4	12.0	2,074.1	0.9	6.20	1	1	1
Average/Sum#:	1.3	12.2	2,015.6	0.9	148.50 #	24 #	24 #	21 #
Minimum:	1.1	11.1	1,576.1	0.9	4.70	1	1	0
Maximum:	1.5	13.6	2,284.5	1.0	7.10	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/23/2021 00:00	1.1	13.6	1,691.2	0.9	5.10	1	1	0
07/23/2021 01:00	1.2	13.6	1,662.7	1.0	6.70	1	1	1
07/23/2021 02:00	1.4	12.2	2,074.7	0.9	6.20	1	1	1
07/23/2021 03:00	1.3	12.5	1,976.9	0.9	5.90	1	1	1
07/23/2021 04:00	1.1	13.6	1,696.4	0.9	5.10	1	1	0
07/23/2021 05:00	1.1	13.6	1,664.0	0.9	5.00	1	1	0
07/23/2021 06:00	1.2	13.6	1,678.0	1.0	6.70	1	1	0
07/23/2021 07:00	1.2	13.6	1,651.9	1.0	6.60	1	1	0
07/23/2021 08:00	1.2	13.6	1,690.7	1.0	6.80	1	1	0
07/23/2021 09:00	1.2	13.6	1,674.8	1.0	6.70	1	1	0
07/23/2021 10:00	1.2	13.6	1,713.8	1.0	6.90	1	1	0
07/23/2021 11:00	1.2	13.5	1,725.3	1.0	6.90	1	1	1
07/23/2021 12:00	1.5	11.7	2,166.0	1.0	8.70	1	1	1
07/23/2021 13:00	1.5	11.1	2,284.6	0.9	6.90	1	1	1
07/23/2021 14:00	1.5	11.1	2,290.7	0.9	6.90	1	1	1
07/23/2021 15:00	1.5	11.1	2,287.8	0.9	6.90	1	1	1
07/23/2021 16:00	1.5	11.1	2,284.9	0.9	6.90	1	1	1
07/23/2021 17:00	1.5	11.1	2,289.6	0.9	6.90	1	1	1
07/23/2021 18:00	1.5	11.0	2,287.2	0.9	6.90	1	1	1
07/23/2021 19:00	1.5	11.0	2,294.7	0.9	6.90	1	1	1
07/23/2021 20:00	1.5	11.1	2,284.1	0.9	6.90	1	1	1
07/23/2021 21:00	1.4	11.5	2,224.0	0.9	6.70	1	1	1
07/23/2021 22:00	1.4	11.8	2,143.6	0.9	6.40	1	1	1
07/23/2021 23:00	1.4	11.9	2,134.5	0.9	6.40	1	1	1
Average/Sum#:	1.3	12.3	1,994.7	0.9	158.00 #	24 #	24 #	16 #
Minimum:	1.1	11.0	1,651.9	0.9	5.00	1	1	0
Maximum:	1.5	13.6	2,294.7	1.0	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/24/2021 00:00	1.4	12.0	2,122.2	0.9	6.40	1	1	1
07/24/2021 01:00	1.3	12.5	1,978.3	0.9	5.90	1	1	1
07/24/2021 02:00	1.2	13.6	1,669.3	1.0	6.70	1	1	0
07/24/2021 03:00	1.1	13.6	1,738.0	0.9	5.20	1	1	1
07/24/2021 04:00	1.4	12.3	2,058.4	1.0	8.20	1	1	1
07/24/2021 05:00	1.3	12.6	1,980.7	0.9	5.90	1	1	1
07/24/2021 06:00	1.1	13.6	1,663.6	0.9	5.00	1	1	0
07/24/2021 07:00	1.1	13.6	1,622.5	0.9	4.90	1	1	0
07/24/2021 08:00	1.2	13.6	1,633.2	1.0	6.50	1	1	0
07/24/2021 09:00	1.2	13.6	1,662.8	1.0	6.70	1	1	0
07/24/2021 10:00	1.2	13.6	1,624.6	1.0	6.50	1	1	0
07/24/2021 11:00	1.1	13.6	1,664.4	0.9	5.00	1	1	0
07/24/2021 12:00	1.4	12.0	2,089.7	0.9	6.30	1	1	1
07/24/2021 13:00	1.5	11.4	2,191.7	0.9	6.60	1	1	1
07/24/2021 14:00	1.4	11.6	2,142.8	0.9	6.40	1	1	1
07/24/2021 15:00	1.1	13.6	1,687.8	0.9	5.10	1	1	0
07/24/2021 16:00	1.2	13.6	1,711.0	1.0	6.80	1	1	1
07/24/2021 17:00	1.4	11.9	2,094.4	0.9	6.30	1	1	1
07/24/2021 18:00	1.5	11.3	2,201.5	0.9	6.60	1	1	1
07/24/2021 19:00	1.5	11.0	2,273.6	0.9	6.80	1	1	1
07/24/2021 20:00	1.5	11.0	2,282.5	0.9	6.80	1	1	1
07/24/2021 21:00	1.5	11.2	2,252.2	0.9	6.80	1	1	1
07/24/2021 22:00	1.4	11.6	2,176.1	0.9	6.50	1	1	1
07/24/2021 23:00	1.4	11.5	2,189.6	0.9	6.60	1	1	1
Average/Sum#:	1.3	12.5	1,946.3	0.9	150.50 #	24 #	24 #	16 #
Minimum:	1.1	11.0	1,622.5	0.9	4.90	1	1	0
Maximum:	1.5	13.6	2,282.5	1.0	8.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/25/2021 00:00	1.3	12.3	2,006.6	0.9	6.00	1	1	1
07/25/2021 01:00	1.1	13.6	1,660.5	0.9	5.00	1	1	0
07/25/2021 02:00	1.1	13.6	1,601.6	0.9	4.80	1	1	1
07/25/2021 03:00	1.4	12.1	2,080.6	0.9	6.20	1	1	1
07/25/2021 04:00	1.3	12.4	1,978.5	0.9	5.90	1	1	1
07/25/2021 05:00	1.1	13.6	1,686.6	0.9	5.10	1	1	0
07/25/2021 06:00	1.2	13.6	1,676.1	1.0	6.70	1	1	0
07/25/2021 07:00	1.2	13.6	1,686.1	1.0	6.70	1	1	0
07/25/2021 08:00	1.2	13.6	1,697.9	1.0	6.80	1	1	0
07/25/2021 09:00	1.2	13.6	1,692.5	1.0	6.80	1	1	0
07/25/2021 10:00	1.2	13.6	1,688.9	1.0	6.80	1	1	0
07/25/2021 11:00	1.1	13.6	1,538.8	0.9	4.60	1	1	1
07/25/2021 12:00	1.4	11.8	2,117.2	0.9	6.40	1	1	1
07/25/2021 13:00	1.4	11.6	2,129.1	0.9	6.40	1	1	1
07/25/2021 14:00	1.2	13.6	1,683.6	1.0	6.70	1	1	0
07/25/2021 15:00	1.2	13.5	1,719.6	1.0	6.90	1	1	0
07/25/2021 16:00	1.2	13.4	1,730.4	0.9	5.20	1	1	1
07/25/2021 17:00	1.5	11.5	2,141.1	0.9	6.40	1	1	1
07/25/2021 18:00	1.5	11.0	2,253.0	0.9	6.80	1	1	1
07/25/2021 19:00	1.5	11.3	2,206.5	0.9	6.60	1	1	1
07/25/2021 20:00	1.4	11.5	2,160.7	0.9	6.50	1	1	1
07/25/2021 21:00	1.4	11.8	2,123.6	0.9	6.40	1	1	1
07/25/2021 22:00	1.4	11.9	2,108.7	0.9	6.30	1	1	1
07/25/2021 23:00	1.4	11.8	2,133.2	0.9	6.40	1	1	1
Average/Sum#:	1.3	12.7	1,895.9	0.9	148.40 #	24 #	24 #	15 #
Minimum:	1.1	11.0	1,538.8	0.9	4.60	1	1	0
Maximum:	1.5	13.6	2,253.0	1.0	6.90	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/26/2021 00:00	1.3	12.4	2,001.4	0.9	6.00	1	1	1
07/26/2021 01:00	1.2	13.6	1,617.4	1.0	6.50	1	1	0
07/26/2021 02:00	1.2	13.6	1,646.6	1.0	6.60	1	1	1
07/26/2021 03:00	1.4	12.2	2,062.3	0.9	6.20	1	1	1
07/26/2021 04:00	1.4	12.0	2,085.0	0.9	6.30	1	1	1
07/26/2021 05:00	1.0	13.6	1,698.6	0.8	5.10	1	1	1
07/26/2021 06:00	1.2	13.6	1,624.4	1.0	6.50	1	1	0
07/26/2021 07:00	1.1	13.6	1,538.3	0.9	4.60	1	1	0
07/26/2021 08:00	1.1	13.6	1,683.2	0.9	5.00	1	1	0
07/26/2021 09:00	1.1	13.6	1,565.3	0.9	4.70	1	1	0
07/26/2021 10:00	1.2	13.6	1,679.6	1.0	6.70	1	1	1
07/26/2021 11:00	1.4	12.0	2,101.0	0.9	6.30	1	1	1
07/26/2021 12:00	1.5	11.2	2,245.3	0.9	6.70	1	1	1
07/26/2021 13:00	1.5	11.2	2,241.8	0.9	6.70	1	1	1
07/26/2021 14:00	1.5	11.4	2,207.6	0.9	6.60	1	1	1
07/26/2021 15:00	1.5	11.1	2,268.8	0.9	6.80	1	1	1
07/26/2021 16:00	1.5	11.0	2,267.0	0.9	6.80	1	1	1
07/26/2021 17:00	1.5	11.2	2,234.1	0.9	6.70	1	1	1
07/26/2021 18:00	1.5	11.2	2,247.4	0.9	6.70	1	1	1
07/26/2021 19:00	1.5	11.2	2,243.5	0.9	6.70	1	1	1
07/26/2021 20:00	1.5	11.3	2,234.6	0.9	6.70	1	1	1
07/26/2021 21:00	1.5	11.2	2,281.9	0.9	6.80	1	1	1
07/26/2021 22:00	1.4	11.5	2,214.6	0.9	6.60	1	1	1
07/26/2021 23:00	1.4	12.2	2,057.6	0.9	6.20	1	1	1
Average/Sum#:	1.4	12.2	2,002.0	0.9	150.50 #	24 #	24 #	19 #
Minimum:	1.0	11.0	1,538.3	0.8	4.60	1	1	0
Maximum:	1.5	13.6	2,281.9	1.0	6.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/27/2021 00:00	1.2	13.6	1,632.3	1.0	6.50	1	1	0
07/27/2021 01:00	1.1	13.6	1,700.7	0.9	5.10	1	1	1
07/27/2021 02:00	1.3	12.6	1,981.7	0.9	5.90	1	1	1
07/27/2021 03:00	1.3	12.6	1,950.6	0.9	5.90	1	1	1
07/27/2021 04:00	1.1	13.6	1,654.6	0.9	5.00	1	1	0
07/27/2021 05:00	1.2	13.6	1,738.1	1.0	7.00	1	1	1
07/27/2021 06:00	1.3	12.3	2,067.6	0.9	6.20	1	1	1
07/27/2021 07:00	1.3	12.6	1,958.7	0.9	5.90	1	1	1
07/27/2021 08:00	1.2	13.7	1,686.7	1.0	6.70	1	1	0
07/27/2021 09:00	1.1	13.7	1,700.5	0.9	5.10	1	1	0
07/27/2021 10:00	1.1	13.6	1,701.0	0.9	5.10	1	1	0
07/27/2021 11:00	1.2	13.6	1,710.7	1.0	6.80	1	1	0
07/27/2021 12:00	1.4	12.1	2,118.3	0.9	6.40	1	1	1
07/27/2021 13:00	1.5	11.3	2,264.0	0.9	6.80	1	1	1
07/27/2021 14:00	1.5	11.4	2,257.6	0.9	6.80	1	1	1
07/27/2021 15:00	1.5	11.4	2,252.5	0.9	6.80	1	1	1
07/27/2021 16:00	1.4	11.6	2,215.2	0.9	6.60	1	1	1
07/27/2021 17:00	1.5	11.3	2,263.8	0.9	6.80	1	1	1
07/27/2021 18:00	1.5	11.3	2,273.8	0.9	6.80	1	1	1
07/27/2021 19:00	1.4	11.3	2,274.4	0.9	6.80	1	1	1
07/27/2021 20:00	1.5	11.3	2,269.4	0.9	6.80	1	1	1
07/27/2021 21:00	1.4	11.4	2,267.5	0.9	6.80	1	1	1
07/27/2021 22:00	1.4	11.5	2,240.1	0.9	6.70	1	1	1
07/27/2021 23:00	1.4	11.5	2,227.1	0.9	6.70	1	1	1
Average/Sum#:	1.3	12.4	2,017.0	0.9	152.00 #	24 #	24 #	18 #
Minimum:	1.1	11.3	1,632.3	0.9	5.00	1	1	0
Maximum:	1.5	13.7	2,274.4	1.0	7.00	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/28/2021 00:00	1.4	11.8	2,180.2	0.9	6.50	1	1	1
07/28/2021 01:00	1.3	12.5	1,979.6	0.9	5.90	1	1	1
07/28/2021 02:00	1.1	13.6	1,690.5	0.9	5.10	1	1	0
07/28/2021 03:00	1.2	13.6	1,679.4	1.0	6.70	1	1	1
07/28/2021 04:00	1.4	12.2	2,087.5	0.9	6.30	1	1	1
07/28/2021 05:00	1.5	11.5	2,230.0	0.9	6.70	1	1	1
07/28/2021 06:00	1.4	11.7	2,149.9	0.9	6.40	1	1	1
07/28/2021 07:00	1.1	13.6	1,669.3	0.9	5.00	1	1	0
07/28/2021 08:00	1.2	13.5	1,712.9	1.0	6.90	1	1	1
07/28/2021 09:00	1.4	11.8	2,093.3	0.9	6.30	1	1	1
07/28/2021 10:00	1.5	11.1	2,252.5	0.9	6.80	1	1	1
07/28/2021 11:00	1.5	11.1	2,248.6	0.9	6.70	1	1	1
07/28/2021 12:00	1.5	11.2	2,237.6	0.9	6.70	1	1	1
07/28/2021 13:00	1.5	11.1	2,239.8	0.9	6.70	1	1	1
07/28/2021 14:00	1.5	11.2	2,236.4	0.9	6.70	1	1	1
07/28/2021 15:00	1.5	11.1	2,227.9	0.9	6.70	1	1	1
07/28/2021 16:00	1.5	11.1	2,228.3	0.9	6.70	1	1	1
07/28/2021 17:00	1.5	11.1	2,224.5	0.9	6.70	1	1	1
07/28/2021 18:00	1.5	11.2	2,209.0	0.9	6.60	1	1	1
07/28/2021 19:00	1.4	11.4	2,182.4	0.9	6.50	1	1	1
07/28/2021 20:00	1.4	11.5	2,166.0	0.9	6.50	1	1	1
07/28/2021 21:00	1.5	11.2	2,228.9	0.9	6.70	1	1	1
07/28/2021 22:00	1.4	11.4	2,202.9	0.9	6.60	1	1	1
07/28/2021 23:00	1.5	11.3	2,217.5	0.9	6.70	1	1	1
Average/Sum#:	1.4	11.8	2,107.3	0.9	155.10 #	24 #	24 #	22 #
Minimum:	1.1	11.1	1,669.3	0.9	5.00	1	1	0
Maximum:	1.5	13.6	2,252.5	1.0	6.90	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/29/2021 00:00	1.5	11.2	2,249.3	0.9	6.70	1	1	1
07/29/2021 01:00	1.5	11.4	2,211.3	0.9	6.60	1	1	1
07/29/2021 02:00	1.2	13.2	1,628.3	0.9	4.90	1	1	1
07/29/2021 03:00	1.2	13.6	1,728.2	1.0	6.90	1	1	1
07/29/2021 04:00	1.4	12.0	2,104.2	0.9	6.30	1	1	1
07/29/2021 05:00	1.3	11.4	2,237.5	0.8	6.70	1	1	1
07/29/2021 06:00	1.4	11.8	2,127.8	0.9	6.40	1	1	1
07/29/2021 07:00	1.1	13.6	1,658.6	0.9	5.00	1	1	0
07/29/2021 08:00	1.2	13.6	1,688.4	1.0	6.80	1	1	1
07/29/2021 09:00	1.4	12.1	2,056.7	0.9	6.20	1	1	1
07/29/2021 10:00	1.5	11.0	2,272.3	0.9	6.80	1	1	1
07/29/2021 11:00	1.5	11.0	2,271.4	0.9	6.80	1	1	1
07/29/2021 12:00	1.5	11.0	2,262.6	0.9	6.80	1	1	1
07/29/2021 13:00	1.5	11.0	2,258.5	0.9	6.80	1	1	1
07/29/2021 14:00	1.5	11.0	2,250.1	0.9	6.80	1	1	1
07/29/2021 15:00	1.5	11.0	2,246.5	0.9	6.70	1	1	1
07/29/2021 16:00	1.5	11.0	2,241.6	0.9	6.70	1	1	1
07/29/2021 17:00	1.5	11.0	2,241.8	0.9	6.70	1	1	1
07/29/2021 18:00	1.5	11.0	2,240.1	0.9	6.70	1	1	1
07/29/2021 19:00	1.5	11.0	2,241.8	0.9	6.70	1	1	1
07/29/2021 20:00	1.5	11.1	2,218.7	0.9	6.70	1	1	1
07/29/2021 21:00	1.5	11.1	2,246.9	0.9	6.70	1	1	1
07/29/2021 22:00	1.5	11.2	2,240.0	0.9	6.70	1	1	1
07/29/2021 23:00	1.5	11.2	2,229.3	0.9	6.70	1	1	1
Average/Sum#:	1.4	11.6	2,131.3	0.9	156.80 #	24 #	24 #	23 #
Minimum:	1.1	11.0	1,628.3	0.8	4.90	1	1	0
Maximum:	1.5	13.6	2,272.3	1.0	6.90	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/30/2021 00:00	1.5	11.4	2,209.5	0.9	6.60	1	1	1
07/30/2021 01:00	1.4	11.6	2,137.2	0.9	6.40	1	1	1
07/30/2021 02:00	1.2	13.5	1,702.8	1.0	6.80	1	1	1
07/30/2021 03:00	1.2	13.6	1,742.5	1.0	7.00	1	1	1
07/30/2021 04:00	1.4	11.8	2,141.4	0.9	6.40	1	1	1
07/30/2021 05:00	1.3	11.1	2,285.8	0.8	6.90	1	1	1
07/30/2021 06:00	1.5	11.3	2,246.4	0.9	6.70	1	1	1
07/30/2021 07:00	1.5	11.3	2,237.5	0.9	6.70	1	1	1
07/30/2021 08:00	1.5	11.3	2,217.5	0.9	6.70	1	1	1
07/30/2021 09:00	1.5	11.2	2,240.6	0.9	6.70	1	1	1
07/30/2021 10:00	1.5	11.1	2,244.0	0.9	6.70	1	1	1
07/30/2021 11:00	1.5	11.0	2,257.2	0.9	6.80	1	1	1
07/30/2021 12:00	1.5	11.0	2,250.5	0.9	6.80	1	1	1
07/30/2021 13:00	1.5	11.0	2,247.3	0.9	6.70	1	1	1
07/30/2021 14:00	1.5	11.0	2,241.3	0.9	6.70	1	1	1
07/30/2021 15:00	1.5	11.0	2,235.8	0.9	6.70	1	1	1
07/30/2021 16:00	1.5	11.1	2,228.6	0.9	6.70	1	1	1
07/30/2021 17:00	1.5	11.1	2,227.9	0.9	6.70	1	1	1
07/30/2021 18:00	1.5	11.1	2,219.0	0.9	6.70	1	1	1
07/30/2021 19:00	1.5	11.0	2,238.0	0.9	6.70	1	1	1
07/30/2021 20:00	1.5	11.0	2,246.4	0.9	6.70	1	1	1
07/30/2021 21:00	1.5	11.1	2,226.5	0.9	6.70	1	1	1
07/30/2021 22:00	1.5	11.1	2,236.3	0.9	6.70	1	1	1
07/30/2021 23:00	1.5	11.1	2,250.8	0.9	6.80	1	1	1
Average/Sum#:	1.5	11.4	2,188.0	0.9	161.00 #	24 #	24 #	24 #
Minimum:	1.2	11.0	1,702.8	0.8	6.40	1	1	1
Maximum:	1.5	13.6	2,285.8	1.0	7.00	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/31/2021 00:00	1.5	11.1	2,278.6	0.9	6.80	1	1	1
07/31/2021 01:00	1.5	11.3	2,268.1	0.9	6.80	1	1	1
07/31/2021 02:00	1.4	11.5	2,221.4	0.9	6.70	1	1	1
07/31/2021 03:00	1.2	13.3	1,705.9	0.9	5.10	1	1	1
07/31/2021 04:00	1.2	13.5	1,783.4	1.0	7.10	1	1	0
07/31/2021 05:00	1.4	12.5	1,944.3	1.0	7.80	1	1	1
07/31/2021 06:00	1.4	11.8	2,128.1	0.9	6.40	1	1	1
07/31/2021 07:00	1.2	13.6	1,692.5	1.0	6.80	1	1	0
07/31/2021 08:00	1.2	13.6	1,592.9	1.0	6.40	1	1	1
07/31/2021 09:00	1.4	12.2	2,072.5	0.9	6.20	1	1	1
07/31/2021 10:00	1.4	11.9	2,124.4	0.9	6.40	1	1	1
07/31/2021 11:00	1.4	11.8	2,137.8	0.9	6.40	1	1	1
07/31/2021 12:00	1.4	11.7	2,147.2	0.9	6.40	1	1	1
07/31/2021 13:00	1.4	11.7	2,140.4	0.9	6.40	1	1	1
07/31/2021 14:00	1.4	11.7	2,146.8	0.9	6.40	1	1	1
07/31/2021 15:00	1.4	11.6	2,155.2	0.9	6.50	1	1	1
07/31/2021 16:00	1.5	11.5	2,161.5	0.9	6.50	1	1	1
07/31/2021 17:00	1.5	11.4	2,195.2	0.9	6.60	1	1	1
07/31/2021 18:00	1.5	11.3	2,221.4	0.9	6.70	1	1	1
07/31/2021 19:00	1.5	11.4	2,218.5	0.9	6.70	1	1	1
07/31/2021 20:00	1.5	11.2	2,264.0	0.9	6.80	1	1	1
07/31/2021 21:00	1.5	11.3	2,237.7	0.9	6.70	1	1	1
07/31/2021 22:00	1.4	11.5	2,210.9	0.9	6.60	1	1	1
07/31/2021 23:00	1.4	11.9	2,144.6	0.9	6.40	1	1	1
Average/Sum#:	1.4	11.9	2,091.4	0.9	157.60 #	24 #	24 #	22 #
Minimum:	1.2	11.1	1,592.9	0.9	5.10	1	1	0
Maximum:	1.5	13.6	2,278.6	1.0	7.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/01/2021 00:00	1.3	12.5	1,998.4	0.9	6.00	1	1	1
08/01/2021 01:00	1.2	13.6	1,662.9	1.0	6.70	1	1	0
08/01/2021 02:00	1.1	13.6	1,707.2	0.9	5.10	1	1	1
08/01/2021 03:00	1.3	12.3	2,048.0	0.9	6.10	1	1	1
08/01/2021 04:00	1.3	12.4	2,006.0	0.9	6.00	1	1	1
08/01/2021 05:00	1.2	13.6	1,692.6	1.0	6.80	1	1	0
08/01/2021 06:00	1.1	13.6	1,641.8	0.9	4.90	1	1	0
08/01/2021 07:00	1.1	13.6	1,623.5	0.9	4.90	1	1	0
08/01/2021 08:00	1.1	13.7	1,418.4	0.9	4.30	1	1	0
08/01/2021 09:00	1.1	13.6	1,582.5	0.9	4.70	1	1	1
08/01/2021 10:00	1.4	12.1	2,082.3	0.9	6.20	1	1	1
08/01/2021 11:00	1.4	12.1	2,028.7	0.9	6.10	1	1	1
08/01/2021 12:00	1.1	13.6	1,635.4	0.9	4.90	1	1	0
08/01/2021 13:00	1.2	13.6	1,680.1	1.0	6.70	1	1	0
08/01/2021 14:00	1.2	13.6	1,693.6	1.0	6.80	1	1	0
08/01/2021 15:00	1.2	13.6	1,713.5	1.0	6.90	1	1	0
08/01/2021 16:00	1.3	12.9	1,838.5	1.0	7.40	1	1	1
08/01/2021 17:00	1.5	11.2	2,247.6	0.9	6.70	1	1	1
08/01/2021 18:00	1.5	11.0	2,288.1	0.9	6.90	1	1	1
08/01/2021 19:00	1.5	11.1	2,280.7	0.9	6.80	1	1	1
08/01/2021 20:00	1.5	11.0	2,299.7	0.9	6.90	1	1	1
08/01/2021 21:00	1.5	11.1	2,297.8	0.9	6.90	1	1	1
08/01/2021 22:00	1.5	11.2	2,274.7	0.9	6.80	1	1	1
08/01/2021 23:00	1.5	11.4	2,243.3	0.9	6.70	1	1	1
Average/Sum#:	1.3	12.6	1,916.1	0.9	148.20 #	24 #	24 #	15 #
Minimum:	1.1	11.0	1,418.4	0.9	4.30	1	1	0
Maximum:	1.5	13.7	2,299.7	1.0	7.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/02/2021 00:00	1.5	11.4	2,258.7	0.9	6.80	1	1	1
08/02/2021 01:00	1.4	11.6	2,221.7	0.9	6.70	1	1	1
08/02/2021 02:00	1.2	13.4	1,665.6	0.9	5.00	1	1	1
08/02/2021 03:00	1.2	13.6	1,701.4	1.0	6.80	1	1	1
08/02/2021 04:00	1.4	12.3	2,093.8	1.0	8.40	1	1	1
08/02/2021 05:00	1.5	11.5	2,260.2	0.9	6.80	1	1	1
08/02/2021 06:00	1.3	11.8	2,177.6	0.8	6.50	1	1	1
08/02/2021 07:00	1.2	13.3	1,710.0	0.9	5.10	1	1	1
08/02/2021 08:00	1.1	13.6	1,606.7	0.9	4.80	1	1	1
08/02/2021 09:00	1.4	12.2	2,095.5	0.9	6.30	1	1	1
08/02/2021 10:00	1.4	11.6	2,204.1	0.9	6.60	1	1	1
08/02/2021 11:00	1.4	11.5	2,224.2	0.9	6.70	1	1	1
08/02/2021 12:00	1.4	11.6	2,202.4	0.9	6.60	1	1	1
08/02/2021 13:00	1.4	11.6	2,197.5	0.9	6.60	1	1	1
08/02/2021 14:00	1.4	11.6	2,192.2	0.9	6.60	1	1	1
08/02/2021 15:00	1.4	11.6	2,194.6	0.9	6.60	1	1	1
08/02/2021 16:00	1.4	11.6	2,195.5	0.9	6.60	1	1	1
08/02/2021 17:00	1.5	11.5	2,217.6	0.9	6.70	1	1	1
08/02/2021 18:00	1.5	11.2	2,277.9	0.9	6.80	1	1	1
08/02/2021 19:00	1.5	11.1	2,289.2	0.9	6.90	1	1	1
08/02/2021 20:00	1.5	11.1	2,302.7	0.9	6.90	1	1	1
08/02/2021 21:00	1.5	11.2	2,302.3	0.9	6.90	1	1	1
08/02/2021 22:00	1.5	11.2	2,300.8	0.9	6.90	1	1	1
08/02/2021 23:00	1.5	11.2	2,302.2	0.9	6.90	1	1	1
Average/Sum#:	1.4	11.8	2,133.1	0.9	157.50 #	24 #	24 #	24 #
Minimum:	1.1	11.1	1,606.7	0.8	4.80	1	1	1
Maximum:	1.5	13.6	2,302.7	1.0	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/03/2021 00:00	1.4	11.5	2,242.8	0.9	6.70	1	1	1
08/03/2021 01:00	1.4	11.5	2,238.0	0.9	6.70	1	1	1
08/03/2021 02:00	1.2	13.3	1,752.8	0.9	5.30	1	1	1
08/03/2021 03:00	1.2	13.5	1,785.3	1.0	7.10	1	1	1
08/03/2021 04:00	1.3	12.2	2,099.5	0.9	6.30	1	1	1
08/03/2021 05:00	1.4	11.8	2,204.3	0.9	6.60	1	1	1
08/03/2021 06:00	1.5	11.8	2,170.9	1.0	8.70	1	1	1
08/03/2021 07:00	1.5	11.7	2,187.0	1.0	8.70	1	1	1
08/03/2021 08:00	1.5	11.6	2,210.3	1.0	8.80	1	1	1
08/03/2021 09:00	1.5	11.5	2,231.7	0.9	6.70	1	1	1
08/03/2021 10:00	1.5	11.3	2,271.6	0.9	6.80	1	1	1
08/03/2021 11:00	1.4	12.0	1,974.7	0.9	5.90	1	1	1
08/03/2021 12:00	1.1	13.8	1,332.6	0.9	4.00	1	1	0
08/03/2021 13:00	1.1	13.6	1,718.2	0.9	5.20	1	1	1
08/03/2021 14:00	1.4	11.9	2,133.2	0.9	6.40	1	1	1
08/03/2021 15:00	1.4	11.6	2,189.3	0.9	6.60	1	1	1
08/03/2021 16:00	1.4	11.5	2,195.3	0.9	6.60	1	1	1
08/03/2021 17:00	1.5	11.4	2,208.6	0.9	6.60	1	1	1
08/03/2021 18:00	1.5	11.2	2,267.7	0.9	6.80	1	1	1
08/03/2021 19:00	1.5	11.1	2,280.8	0.9	6.80	1	1	1
08/03/2021 20:00	1.5	11.1	2,294.7	0.9	6.90	1	1	1
08/03/2021 21:00	1.5	11.1	2,288.8	0.9	6.90	1	1	1
08/03/2021 22:00	1.5	11.2	2,276.6	0.9	6.80	1	1	1
08/03/2021 23:00	1.4	11.4	2,258.9	0.9	6.80	1	1	1
Average/Sum#:	1.4	11.9	2,117.2	0.9	160.70 #	24 #	24 #	23 #
Minimum:	1.1	11.1	1,332.6	0.9	4.00	1	1	0
Maximum:	1.5	13.8	2,294.7	1.0	8.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/04/2021 00:00	1.4	11.9	2,097.3	0.9	6.30	1	1	1
08/04/2021 01:00	1.2	13.6	1,678.6	1.0	6.70	1	1	0
08/04/2021 02:00	1.2	13.5	1,780.1	1.0	7.10	1	1	1
08/04/2021 03:00	1.4	12.3	2,071.5	1.0	8.30	1	1	1
08/04/2021 04:00	1.4	11.5	2,242.4	0.9	6.70	1	1	1
08/04/2021 05:00	1.4	11.3	2,265.6	0.9	6.80	1	1	1
08/04/2021 06:00	1.4	11.9	2,127.2	0.9	6.40	1	1	1
08/04/2021 07:00	1.3	12.5	1,984.9	0.9	6.00	1	1	1
08/04/2021 08:00	1.1	13.6	1,645.9	0.9	4.90	1	1	0
08/04/2021 09:00	1.2	13.5	1,717.4	1.0	6.90	1	1	0
08/04/2021 10:00	1.4	12.1	2,079.9	0.9	6.20	1	1	1
08/04/2021 11:00	1.4	11.4	2,222.3	0.9	6.70	1	1	1
08/04/2021 12:00	1.4	11.5	2,189.0	0.9	6.60	1	1	1
08/04/2021 13:00	1.4	11.5	2,176.6	0.9	6.50	1	1	1
08/04/2021 14:00	1.5	11.5	2,176.9	0.9	6.50	1	1	1
08/04/2021 15:00	1.5	11.4	2,183.3	0.9	6.50	1	1	1
08/04/2021 16:00	1.5	11.2	2,213.6	0.9	6.60	1	1	1
08/04/2021 17:00	1.5	11.2	2,226.0	0.9	6.70	1	1	1
08/04/2021 18:00	1.5	11.2	2,240.1	0.9	6.70	1	1	1
08/04/2021 19:00	1.5	11.1	2,262.3	0.9	6.80	1	1	1
08/04/2021 20:00	1.5	11.1	2,280.6	0.9	6.80	1	1	1
08/04/2021 21:00	1.5	11.1	2,289.4	0.9	6.90	1	1	1
08/04/2021 22:00	1.5	11.2	2,285.8	0.9	6.90	1	1	1
08/04/2021 23:00	1.4	11.6	2,192.1	0.9	6.60	1	1	1
Average/Sum#:	1.4	11.9	2,109.5	0.9	159.10 #	24 #	24 #	21 #
Minimum:	1.1	11.1	1,645.9	0.9	4.90	1	1	0
Maximum:	1.5	13.6	2,289.4	1.0	8.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/05/2021 00:00	1.4	11.8	2,174.5	0.9	6.50	1	1	1
08/05/2021 01:00	1.4	11.7	2,188.6	0.9	6.60	1	1	1
08/05/2021 02:00	1.4	11.7	2,182.7	0.9	6.50	1	1	1
08/05/2021 03:00	1.4	11.5	2,230.8	0.9	6.70	1	1	1
08/05/2021 04:00	1.4	11.4	2,253.0	0.9	6.80	1	1	1
08/05/2021 05:00	1.3	11.5	2,245.7	0.8	6.70	1	1	1
08/05/2021 06:00	1.3	12.3	2,038.3	0.9	6.10	1	1	1
08/05/2021 07:00	1.1	13.6	1,662.7	0.9	5.00	1	1	0
08/05/2021 08:00	1.1	13.6	1,644.7	0.9	4.90	1	1	1
08/05/2021 09:00	1.3	12.6	1,997.8	0.9	6.00	1	1	1
08/05/2021 10:00	1.4	12.1	2,080.9	0.9	6.20	1	1	1
08/05/2021 11:00	1.1	13.6	1,690.5	0.9	5.10	1	1	0
08/05/2021 12:00	1.2	13.6	1,759.6	1.0	7.00	1	1	1
08/05/2021 13:00	1.4	12.1	2,087.9	0.9	6.30	1	1	1
08/05/2021 14:00	1.4	11.8	2,141.6	0.9	6.40	1	1	1
08/05/2021 15:00	1.4	11.8	2,152.2	0.9	6.50	1	1	1
08/05/2021 16:00	1.4	11.6	2,184.5	0.9	6.60	1	1	1
08/05/2021 17:00	1.4	11.7	2,164.5	0.9	6.50	1	1	1
08/05/2021 18:00	1.5	11.3	2,259.7	0.9	6.80	1	1	1
08/05/2021 19:00	1.5	11.2	2,278.3	0.9	6.80	1	1	1
08/05/2021 20:00	1.5	11.2	2,282.9	0.9	6.80	1	1	1
08/05/2021 21:00	1.5	11.4	2,236.3	0.9	6.70	1	1	1
08/05/2021 22:00	1.4	11.7	2,165.0	0.9	6.50	1	1	1
08/05/2021 23:00	1.4	11.9	2,137.0	0.9	6.40	1	1	1
Average/Sum#:	1.4	12.0	2,093.3	0.9	152.40 #	24 #	24 #	22 #
Minimum:	1.1	11.2	1,644.7	0.8	4.90	1	1	0
Maximum:	1.5	13.6	2,282.9	1.0	7.00	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/06/2021 00:00	1.4	12.0	2,076.7	0.9	6.20	1	1	1
08/06/2021 01:00	1.2	13.6	1,695.4	1.0	6.80	1	1	0
08/06/2021 02:00	1.2	13.6	1,691.4	1.0	6.80	1	1	0
08/06/2021 03:00	1.2	13.6	1,639.6	1.0	6.60	1	1	1
08/06/2021 04:00	1.3	12.3	2,055.5	0.9	6.20	1	1	1
08/06/2021 05:00	1.2	12.3	2,077.3	0.8	6.20	1	1	1
08/06/2021 06:00	1.1	13.7	1,600.7	0.9	4.80	1	1	0
08/06/2021 07:00	1.1	13.7	1,665.4	0.9	5.00	1	1	0
08/06/2021 08:00	1.2	13.6	1,667.2	1.0	6.70	1	1	0
08/06/2021 09:00	1.3	12.4	2,007.8	0.9	6.00	1	1	1
08/06/2021 10:00	1.3	12.4	1,995.8	0.9	6.00	1	1	1
08/06/2021 11:00	1.2	13.6	1,660.3	1.0	6.60	1	1	0
08/06/2021 12:00	1.1	13.7	1,530.6	0.9	4.60	1	1	0
08/06/2021 13:00	1.3	12.3	2,034.7	0.9	6.10	1	1	1
08/06/2021 14:00	1.4	11.8	2,128.3	0.9	6.40	1	1	1
08/06/2021 15:00	1.4	11.8	2,112.5	0.9	6.30	1	1	1
08/06/2021 16:00	1.4	11.5	2,166.2	0.9	6.50	1	1	1
08/06/2021 17:00	1.4	11.4	2,170.9	0.9	6.50	1	1	1
08/06/2021 18:00	1.4	11.2	2,221.4	0.9	6.70	1	1	1
08/06/2021 19:00	1.4	11.5	2,173.4	0.9	6.50	1	1	1
08/06/2021 20:00	1.4	11.5	2,141.6	0.9	6.40	1	1	1
08/06/2021 21:00	1.4	11.7	2,111.7	0.9	6.30	1	1	1
08/06/2021 22:00	1.4	11.9	2,096.0	0.9	6.30	1	1	1
08/06/2021 23:00	1.3	12.4	1,955.7	0.9	5.90	1	1	1
Average/Sum#:	1.3	12.5	1,944.8	0.9	148.40 #	24 #	24 #	17 #
Minimum:	1.1	11.2	1,530.6	0.8	4.60	1	1	0
Maximum:	1.4	13.7	2,221.4	1.0	6.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/07/2021 00:00	1.2	13.6	1,703.0	1.0	6.80	1	1	0
08/07/2021 01:00	1.2	13.5	1,630.7	1.0	6.50	1	1	1
08/07/2021 02:00	1.4	12.4	1,991.3	1.0	8.00	1	1	1
08/07/2021 03:00	2.3	13.9	1,196.2	1.9	4.03	1	0	1
08/07/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/07/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/07/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/07/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/07/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/07/2021 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/07/2021 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/07/2021 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/07/2021 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/07/2021 13:00	6.6	18.5	172.7	16.2	2.08	1	0	0
08/07/2021 14:00	15.7	15.4	813.4	16.8	50.40	1	0	0
08/07/2021 15:00	1.3	13.6	1,657.0	1.1	6.60	1	1	0
08/07/2021 16:00	1.2	13.6	1,536.5	1.0	6.10	1	1	1
08/07/2021 17:00	1.4	11.9	2,068.8	0.9	6.20	1	1	1
08/07/2021 18:00	1.5	11.6	2,140.2	1.0	8.60	1	1	1
08/07/2021 19:00	1.4	11.9	2,049.0	0.9	6.10	1	1	1
08/07/2021 20:00	1.2	13.5	1,687.8	1.0	6.80	1	1	0
08/07/2021 21:00	1.2	13.5	1,656.9	1.0	6.60	1	1	1
08/07/2021 22:00	1.3	12.4	1,999.2	0.9	6.00	1	1	1
08/07/2021 23:00	1.4	11.9	2,078.2	0.9	6.20	1	1	1
Average/Sum#:	2.7	13.4	1,625.4	3.1	137.01 #	15 #	12 #	10 #
Minimum:	1.2	11.6	172.7	0.9	2.08	0	0	0
Maximum:	15.7	18.5	2,140.2	16.8	50.40	1	1	1
%SI	37.50	37.50	37.50	37.50	37.50	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/08/2021 00:00	1.2	13.6	1,601.3	1.0	6.40	1	1	0
08/08/2021 01:00	1.1	13.5	1,571.0	0.9	4.70	1	1	1
08/08/2021 02:00	1.3	12.5	1,979.4	0.9	5.90	1	1	1
08/08/2021 03:00	1.2	13.4	1,496.5	0.9	4.50	1	1	1
08/08/2021 04:00	3.8	16.3	332.8	4.9	1.08	1	0	0
08/08/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/08/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/08/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/08/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/08/2021 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/08/2021 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/08/2021 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/08/2021 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/08/2021 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/08/2021 14:00	5.1	18.6	165.6	13.1	1.74	1	0	0
08/08/2021 15:00	18.1	15.4	815.0	19.4	58.70	1	0	0
08/08/2021 16:00	1.1	13.6	1,604.6	0.9	4.80	1	1	0
08/08/2021 17:00	1.3	12.8	1,811.1	0.9	5.40	1	1	1
08/08/2021 18:00	1.5	11.5	2,154.8	0.9	6.50	1	1	1
08/08/2021 19:00	1.4	11.4	2,181.1	0.9	6.50	1	1	1
08/08/2021 20:00	1.5	11.3	2,225.9	0.9	6.70	1	1	1
08/08/2021 21:00	1.4	11.5	2,174.0	0.9	6.50	1	1	1
08/08/2021 22:00	1.4	11.9	2,090.8	0.9	6.30	1	1	1
08/08/2021 23:00	1.3	12.4	1,968.1	0.9	5.90	1	1	1
Average/Sum#:	2.8	13.3	1,611.5	3.2	131.62 #	15 #	12 #	10 #
Minimum:	1.1	11.3	165.6	0.9	1.08	0	0	0
Maximum:	18.1	18.6	2,225.9	19.4	58.70	1	1	1
%SI	37.50	37.50	37.50	37.50	37.50	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/09/2021 00:00	1.2	13.6	1,595.0	1.0	6.40	1	1	0
08/09/2021 01:00	1.2	13.5	1,755.9	1.0	7.00	1	1	1
08/09/2021 02:00	1.4	12.3	2,038.3	1.0	8.20	1	1	1
08/09/2021 03:00	1.3	12.5	1,963.2	0.9	5.90	1	1	1
08/09/2021 04:00	1.2	13.6	1,692.9	1.0	6.80	1	1	0
08/09/2021 05:00	1.2	13.4	1,767.7	0.9	5.30	1	1	1
08/09/2021 06:00	1.4	12.4	2,019.5	1.0	8.10	1	1	1
08/09/2021 07:00	1.3	12.2	2,022.1	0.9	6.10	1	1	1
08/09/2021 08:00	1.2	13.6	1,592.2	1.0	6.40	1	1	0
08/09/2021 09:00	1.1	13.6	1,650.0	0.9	5.00	1	1	0
08/09/2021 10:00	1.1	13.5	1,682.3	0.9	5.00	1	1	0
08/09/2021 11:00	1.4	12.2	2,001.9	0.9	6.00	1	1	1
08/09/2021 12:00	1.4	11.6	2,089.2	0.9	6.30	1	1	1
08/09/2021 13:00	1.1	13.6	1,718.3	0.9	5.20	1	1	0
08/09/2021 14:00	1.3	12.8	1,829.5	0.9	5.50	1	1	1
08/09/2021 15:00	1.5	11.4	2,178.7	0.9	6.50	1	1	1
08/09/2021 16:00	1.5	11.3	2,187.8	0.9	6.60	1	1	1
08/09/2021 17:00	1.5	11.3	2,189.8	0.9	6.60	1	1	1
08/09/2021 18:00	1.5	11.3	2,191.4	0.9	6.60	1	1	1
08/09/2021 19:00	1.5	11.1	2,246.4	0.9	6.70	1	1	1
08/09/2021 20:00	1.5	11.0	2,265.8	0.9	6.80	1	1	1
08/09/2021 21:00	1.5	11.2	2,231.9	0.9	6.70	1	1	1
08/09/2021 22:00	1.4	11.8	2,133.8	0.9	6.40	1	1	1
08/09/2021 23:00	1.4	11.8	2,139.5	0.9	6.40	1	1	1
Average/Sum#:	1.3	12.4	1,966.0	0.9	152.50 #	24 #	24 #	18 #
Minimum:	1.1	11.0	1,592.2	0.9	5.00	1	1	0
Maximum:	1.5	13.6	2,265.8	1.0	8.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/10/2021 00:00	1.3	12.2	2,030.6	0.9	6.10	1	1	1
08/10/2021 01:00	1.2	13.6	1,631.7	1.0	6.50	1	1	0
08/10/2021 02:00	1.1	13.6	1,637.3	0.9	4.90	1	1	0
08/10/2021 03:00	1.2	13.5	1,746.1	1.0	7.00	1	1	1
08/10/2021 04:00	1.4	12.2	2,079.9	0.9	6.20	1	1	1
08/10/2021 05:00	1.2	12.2	2,086.2	0.8	6.30	1	1	1
08/10/2021 06:00	1.1	13.6	1,661.3	0.9	5.00	1	1	0
08/10/2021 07:00	1.1	13.5	1,633.4	0.9	4.90	1	1	1
08/10/2021 08:00	1.4	12.3	2,050.1	1.0	8.20	1	1	1
08/10/2021 09:00	1.3	12.5	1,978.1	0.9	5.90	1	1	1
08/10/2021 10:00	1.1	13.6	1,703.6	0.9	5.10	1	1	0
08/10/2021 11:00	1.2	13.6	1,715.4	1.0	6.90	1	1	1
08/10/2021 12:00	1.4	12.0	2,086.5	0.9	6.30	1	1	1
08/10/2021 13:00	1.4	11.5	2,182.7	0.9	6.50	1	1	1
08/10/2021 14:00	1.4	11.4	2,177.7	0.9	6.50	1	1	1
08/10/2021 15:00	1.4	11.4	2,181.0	0.9	6.50	1	1	1
08/10/2021 16:00	1.5	11.3	2,202.8	0.9	6.60	1	1	1
08/10/2021 17:00	1.5	11.3	2,207.7	0.9	6.60	1	1	1
08/10/2021 18:00	1.5	11.1	2,250.4	0.9	6.80	1	1	1
08/10/2021 19:00	1.5	11.0	2,266.3	0.9	6.80	1	1	1
08/10/2021 20:00	1.5	11.0	2,267.5	0.9	6.80	1	1	1
08/10/2021 21:00	1.5	11.1	2,258.8	0.9	6.80	1	1	1
08/10/2021 22:00	1.4	11.5	2,180.8	0.9	6.50	1	1	1
08/10/2021 23:00	1.4	11.7	2,157.9	0.9	6.50	1	1	1
Average/Sum#:	1.3	12.2	2,015.6	0.9	152.20 #	24 #	24 #	20 #
Minimum:	1.1	11.0	1,631.7	0.8	4.90	1	1	0
Maximum:	1.5	13.6	2,267.5	1.0	8.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/11/2021 00:00	1.4	11.9	2,094.7	0.9	6.30	1	1	1
08/11/2021 01:00	1.1	13.5	1,699.9	0.9	5.10	1	1	0
08/11/2021 02:00	1.2	13.6	1,633.8	1.0	6.50	1	1	0
08/11/2021 03:00	1.2	13.6	1,622.4	1.0	6.50	1	1	0
08/11/2021 04:00	1.1	13.5	1,644.3	0.9	4.90	1	1	1
08/11/2021 05:00	1.3	12.1	2,066.9	0.9	6.20	1	1	1
08/11/2021 06:00	1.4	12.1	2,092.2	0.9	6.30	1	1	1
08/11/2021 07:00	1.2	13.6	1,664.7	1.0	6.70	1	1	0
08/11/2021 08:00	1.2	13.5	1,764.9	1.0	7.10	1	1	0
08/11/2021 09:00	1.4	12.0	2,101.4	0.9	6.30	1	1	1
08/11/2021 10:00	1.5	11.4	2,206.8	0.9	6.60	1	1	1
08/11/2021 11:00	1.5	11.4	2,194.0	0.9	6.60	1	1	1
08/11/2021 12:00	1.4	11.6	2,149.1	0.9	6.40	1	1	1
08/11/2021 13:00	1.4	11.5	2,149.9	0.9	6.40	1	1	1
08/11/2021 14:00	1.5	11.5	2,137.2	0.9	6.40	1	1	1
08/11/2021 15:00	1.6	11.9	2,002.5	1.0	8.00	1	1	1
08/11/2021 16:00	1.8	11.5	2,157.0	1.1	8.60	1	1	1
08/11/2021 17:00	1.8	11.4	2,171.9	1.1	8.70	1	1	1
08/11/2021 18:00	2.0	11.1	2,230.3	1.2	8.90	1	1	1
08/11/2021 19:00	2.1	11.0	2,244.4	1.3	11.20	1	1	1
08/11/2021 20:00	2.1	11.0	2,252.9	1.3	11.30	1	1	1
08/11/2021 21:00	2.0	11.3	2,219.2	1.2	11.10	1	1	1
08/11/2021 22:00	1.8	11.6	2,161.8	1.1	8.60	1	1	1
08/11/2021 23:00	1.7	11.7	2,164.1	1.1	8.70	1	1	1
Average/Sum#:	1.5	12.1	2,034.4	1.0	179.40 #	24 #	24 #	19 #
Minimum:	1.1	11.0	1,622.4	0.9	4.90	1	1	0
Maximum:	2.1	13.6	2,252.9	1.3	11.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/12/2021 00:00	1.6	11.9	2,120.6	1.0	8.50	1	1	1
08/12/2021 01:00	1.3	13.6	1,693.4	1.1	6.80	1	1	1
08/12/2021 02:00	1.2	13.5	1,651.0	1.0	6.60	1	1	1
08/12/2021 03:00	1.3	12.2	2,052.6	0.9	6.20	1	1	1
08/12/2021 04:00	1.5	12.2	2,033.5	1.0	8.10	1	1	1
08/12/2021 05:00	1.1	13.6	1,699.4	0.9	5.10	1	1	0
08/12/2021 06:00	1.2	13.5	1,780.9	1.0	7.10	1	1	1
08/12/2021 07:00	1.4	12.3	2,048.0	1.0	8.20	1	1	1
08/12/2021 08:00	1.3	12.4	1,978.2	0.9	5.90	1	1	1
08/12/2021 09:00	1.2	13.6	1,709.6	1.0	6.80	1	1	0
08/12/2021 10:00	1.2	13.6	1,722.3	1.0	6.90	1	1	1
08/12/2021 11:00	1.4	12.0	2,091.6	0.9	6.30	1	1	1
08/12/2021 12:00	1.4	11.6	2,141.2	0.9	6.40	1	1	1
08/12/2021 13:00	1.4	11.7	2,124.6	0.9	6.40	1	1	1
08/12/2021 14:00	1.4	11.7	2,111.7	0.9	6.30	1	1	1
08/12/2021 15:00	1.4	11.6	2,119.3	0.9	6.40	1	1	1
08/12/2021 16:00	1.4	11.6	2,133.9	0.9	6.40	1	1	1
08/12/2021 17:00	1.4	11.5	2,145.0	0.9	6.40	1	1	1
08/12/2021 18:00	1.5	11.3	2,196.1	0.9	6.60	1	1	1
08/12/2021 19:00	1.5	11.2	2,203.9	0.9	6.60	1	1	1
08/12/2021 20:00	1.5	11.2	2,239.6	0.9	6.70	1	1	1
08/12/2021 21:00	1.4	11.4	2,201.1	0.9	6.60	1	1	1
08/12/2021 22:00	1.4	11.8	2,145.5	0.9	6.40	1	1	1
08/12/2021 23:00	1.4	12.1	2,082.4	0.9	6.20	1	1	1
Average/Sum#:	1.4	12.2	2,017.7	0.9	159.90 #	24 #	24 #	22 #
Minimum:	1.1	11.2	1,651.0	0.9	5.10	1	1	0
Maximum:	1.6	13.6	2,239.6	1.1	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/13/2021 00:00	1.3	12.5	1,980.3	0.9	5.90	1	1	1
08/13/2021 01:00	1.2	13.5	1,655.2	1.0	6.60	1	1	1
08/13/2021 02:00	1.1	13.6	1,502.2	0.9	4.50	1	1	1
08/13/2021 03:00	1.3	12.3	2,040.5	0.9	6.10	1	1	1
08/13/2021 04:00	1.3	12.6	1,963.8	0.9	5.90	1	1	1
08/13/2021 05:00	1.2	13.6	1,684.7	1.0	6.70	1	1	0
08/13/2021 06:00	1.1	13.6	1,652.6	0.9	5.00	1	1	0
08/13/2021 07:00	1.2	13.6	1,568.8	1.0	6.30	1	1	1
08/13/2021 08:00	1.4	12.3	2,033.2	1.0	8.10	1	1	1
08/13/2021 09:00	1.3	12.4	1,989.1	0.9	6.00	1	1	1
08/13/2021 10:00	1.1	13.6	1,599.3	0.9	4.80	1	1	0
08/13/2021 11:00	1.2	13.6	1,600.0	1.0	6.40	1	1	1
08/13/2021 12:00	1.3	12.1	2,076.3	0.9	6.20	1	1	1
08/13/2021 13:00	1.4	11.9	2,112.6	0.9	6.30	1	1	1
08/13/2021 14:00	1.4	11.9	2,105.4	0.9	6.30	1	1	1
08/13/2021 15:00	1.4	11.8	2,102.1	0.9	6.30	1	1	1
08/13/2021 16:00	1.4	11.7	2,109.3	0.9	6.30	1	1	1
08/13/2021 17:00	1.4	11.6	2,129.1	0.9	6.40	1	1	1
08/13/2021 18:00	1.4	11.4	2,179.8	0.9	6.50	1	1	1
08/13/2021 19:00	1.5	11.3	2,221.0	0.9	6.70	1	1	1
08/13/2021 20:00	1.4	11.4	2,199.3	0.9	6.60	1	1	1
08/13/2021 21:00	1.4	11.7	2,129.2	0.9	6.40	1	1	1
08/13/2021 22:00	1.4	11.8	2,126.3	0.9	6.40	1	1	1
08/13/2021 23:00	1.4	11.8	2,125.0	0.9	6.40	1	1	1
Average/Sum#:	1.3	12.4	1,953.5	0.9	149.10 #	24 #	24 #	21 #
Minimum:	1.1	11.3	1,502.2	0.9	4.50	1	1	0
Maximum:	1.5	13.6	2,221.0	1.0	8.10	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/14/2021 00:00	1.3	12.2	2,009.9	0.9	6.00	1	1	1
08/14/2021 01:00	1.2	13.6	1,710.5	1.0	6.80	1	1	0
08/14/2021 02:00	1.2	13.5	1,751.2	1.0	7.00	1	1	1
08/14/2021 03:00	1.4	12.2	2,055.0	0.9	6.20	1	1	1
08/14/2021 04:00	1.3	12.4	1,975.7	0.9	5.90	1	1	1
08/14/2021 05:00	1.1	13.6	1,717.7	0.9	5.20	1	1	0
08/14/2021 06:00	1.2	13.6	1,630.6	1.0	6.50	1	1	0
08/14/2021 07:00	1.1	13.6	1,519.8	0.9	4.60	1	1	0
08/14/2021 08:00	1.1	13.7	1,317.3	0.9	4.00	1	1	0
08/14/2021 09:00	1.2	13.6	1,594.8	1.0	6.40	1	1	0
08/14/2021 10:00	1.1	13.6	1,665.3	0.9	5.00	1	1	0
08/14/2021 11:00	1.2	13.6	1,689.3	1.0	6.80	1	1	0
08/14/2021 12:00	1.2	13.6	1,693.4	1.0	6.80	1	1	1
08/14/2021 13:00	1.4	12.0	2,046.4	0.9	6.10	1	1	1
08/14/2021 14:00	1.4	11.6	2,090.5	0.9	6.30	1	1	1
08/14/2021 15:00	1.1	13.6	1,592.7	0.9	4.80	1	1	0
08/14/2021 16:00	1.1	13.7	1,510.0	0.9	4.50	1	1	0
08/14/2021 17:00	1.4	11.8	2,075.0	0.9	6.20	1	1	1
08/14/2021 18:00	1.5	11.1	2,194.8	0.9	6.60	1	1	1
08/14/2021 19:00	1.5	11.0	2,210.3	0.9	6.60	1	1	1
08/14/2021 20:00	1.5	11.2	2,201.9	0.9	6.60	1	1	1
08/14/2021 21:00	1.4	11.4	2,179.8	0.9	6.50	1	1	1
08/14/2021 22:00	1.4	11.6	2,145.3	0.9	6.40	1	1	1
08/14/2021 23:00	1.4	11.8	2,121.5	0.9	6.40	1	1	1
Average/Sum#:	1.3	12.7	1,862.4	0.9	144.20 #	24 #	24 #	14 #
Minimum:	1.1	11.0	1,317.3	0.9	4.00	1	1	0
Maximum:	1.5	13.7	2,210.3	1.0	7.00	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/15/2021 00:00	1.3	12.4	1,993.4	0.9	6.00	1	1	1
08/15/2021 01:00	1.2	13.6	1,707.4	1.0	6.80	1	1	0
08/15/2021 02:00	1.1	13.5	1,645.3	0.9	4.90	1	1	1
08/15/2021 03:00	1.4	12.2	2,057.7	0.9	6.20	1	1	1
08/15/2021 04:00	1.3	12.5	1,972.3	0.9	5.90	1	1	1
08/15/2021 05:00	1.1	13.6	1,687.4	0.9	5.10	1	1	0
08/15/2021 06:00	1.2	13.6	1,606.4	1.0	6.40	1	1	0
08/15/2021 07:00	1.2	13.6	1,684.1	1.0	6.70	1	1	0
08/15/2021 08:00	1.2	13.6	1,513.1	1.0	6.10	1	1	0
08/15/2021 09:00	1.2	13.6	1,638.4	1.0	6.60	1	1	0
08/15/2021 10:00	1.2	13.6	1,697.0	1.0	6.80	1	1	0
08/15/2021 11:00	1.1	13.6	1,523.7	0.9	4.60	1	1	0
08/15/2021 12:00	1.3	12.8	1,761.4	0.9	5.30	1	1	1
08/15/2021 13:00	1.4	11.6	2,076.9	0.9	6.20	1	1	1
08/15/2021 14:00	1.1	13.5	1,644.2	0.9	4.90	1	1	0
08/15/2021 15:00	1.2	13.5	1,654.9	1.0	6.60	1	1	1
08/15/2021 16:00	1.4	11.7	2,090.7	0.9	6.30	1	1	1
08/15/2021 17:00	1.5	11.3	2,146.6	0.9	6.40	1	1	1
08/15/2021 18:00	1.5	11.1	2,191.1	0.9	6.60	1	1	1
08/15/2021 19:00	1.5	11.3	2,180.2	0.9	6.50	1	1	1
08/15/2021 20:00	1.4	11.4	2,163.3	0.9	6.50	1	1	1
08/15/2021 21:00	1.4	11.5	2,159.1	0.9	6.50	1	1	1
08/15/2021 22:00	1.4	11.6	2,135.4	0.9	6.40	1	1	1
08/15/2021 23:00	1.4	11.7	2,126.5	0.9	6.40	1	1	1
Average/Sum#:	1.3	12.6	1,877.4	0.9	146.70 #	24 #	24 #	15 #
Minimum:	1.1	11.1	1,513.1	0.9	4.60	1	1	0
Maximum:	1.5	13.6	2,191.1	1.0	6.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/16/2021 00:00	1.3	12.2	1,998.1	0.9	6.00	1	1	1
08/16/2021 01:00	1.2	13.6	1,707.9	1.0	6.80	1	1	0
08/16/2021 02:00	1.2	13.5	1,542.2	1.0	6.20	1	1	1
08/16/2021 03:00	1.4	12.2	2,031.8	0.9	6.10	1	1	1
08/16/2021 04:00	1.3	12.3	2,002.7	0.9	6.00	1	1	1
08/16/2021 05:00	1.2	13.6	1,715.7	1.0	6.90	1	1	1
08/16/2021 06:00	1.2	13.5	1,750.3	1.0	7.00	1	1	1
08/16/2021 07:00	1.4	12.1	2,031.2	0.9	6.10	1	1	1
08/16/2021 08:00	1.4	12.0	2,035.4	0.9	6.10	1	1	1
08/16/2021 09:00	1.1	13.5	1,685.7	0.9	5.10	1	1	0
08/16/2021 10:00	1.2	13.6	1,631.4	1.0	6.50	1	1	1
08/16/2021 11:00	1.4	11.8	2,088.4	0.9	6.30	1	1	1
08/16/2021 12:00	1.5	11.5	2,130.0	0.9	6.40	1	1	1
08/16/2021 13:00	1.4	11.5	2,123.1	0.9	6.40	1	1	1
08/16/2021 14:00	1.4	11.7	2,083.8	0.9	6.30	1	1	1
08/16/2021 15:00	1.5	11.3	2,157.0	0.9	6.50	1	1	1
08/16/2021 16:00	1.5	11.2	2,178.3	0.9	6.50	1	1	1
08/16/2021 17:00	1.5	11.0	2,211.6	0.9	6.60	1	1	1
08/16/2021 18:00	1.5	10.9	2,241.1	0.9	6.70	1	1	1
08/16/2021 19:00	1.5	11.0	2,228.5	0.9	6.70	1	1	1
08/16/2021 20:00	1.5	11.2	2,201.6	0.9	6.60	1	1	1
08/16/2021 21:00	1.5	11.1	2,210.1	0.9	6.60	1	1	1
08/16/2021 22:00	1.4	11.6	2,144.2	0.9	6.40	1	1	1
08/16/2021 23:00	1.4	11.7	2,138.5	0.9	6.40	1	1	1
Average/Sum#:	1.4	12.1	2,011.2	0.9	153.20 #	24 #	24 #	22 #
Minimum:	1.1	10.9	1,542.2	0.9	5.10	1	1	0
Maximum:	1.5	13.6	2,241.1	1.0	7.00	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/17/2021 00:00	1.4	11.9	2,101.8	0.9	6.30	1	1	1
08/17/2021 01:00	1.2	13.5	1,690.4	1.0	6.80	1	1	1
08/17/2021 02:00	1.2	13.5	1,651.6	1.0	6.60	1	1	1
08/17/2021 03:00	1.4	12.0	2,088.3	0.9	6.30	1	1	1
08/17/2021 04:00	1.4	11.6	2,168.9	0.9	6.50	1	1	1
08/17/2021 05:00	1.2	11.3	2,217.7	0.7	6.70	1	1	1
08/17/2021 06:00	1.4	11.8	2,104.1	0.9	6.30	1	1	1
08/17/2021 07:00	1.1	13.6	1,663.8	0.9	5.00	1	1	0
08/17/2021 08:00	1.1	13.6	1,607.8	0.9	4.80	1	1	1
08/17/2021 09:00	1.3	12.3	2,044.4	0.9	6.10	1	1	1
08/17/2021 10:00	1.3	12.5	1,970.1	0.9	5.90	1	1	1
08/17/2021 11:00	1.1	13.6	1,663.1	0.9	5.00	1	1	0
08/17/2021 12:00	1.1	13.6	1,486.4	0.9	4.50	1	1	0
08/17/2021 13:00	1.1	13.5	1,761.0	0.9	5.30	1	1	0
08/17/2021 14:00	1.3	12.9	1,849.5	1.0	7.40	1	1	1
08/17/2021 15:00	1.3	12.6	1,872.6	0.9	5.60	1	1	1
08/17/2021 16:00	1.2	13.6	1,565.3	1.0	6.30	1	1	1
08/17/2021 17:00	1.4	12.0	2,077.4	0.9	6.20	1	1	1
08/17/2021 18:00	1.5	11.4	2,192.1	0.9	6.60	1	1	1
08/17/2021 19:00	1.5	11.2	2,237.3	0.9	6.70	1	1	1
08/17/2021 20:00	1.5	11.1	2,258.0	0.9	6.80	1	1	1
08/17/2021 21:00	1.5	11.3	2,221.8	0.9	6.70	1	1	1
08/17/2021 22:00	1.4	11.7	2,170.8	0.9	6.50	1	1	1
08/17/2021 23:00	1.3	12.4	2,032.3	0.9	6.10	1	1	1
Average/Sum#:	1.3	12.4	1,945.7	0.9	147.00 #	24 #	24 #	20 #
Minimum:	1.1	11.1	1,486.4	0.7	4.50	1	1	0
Maximum:	1.5	13.6	2,258.0	1.0	7.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/18/2021 00:00	1.1	13.6	1,649.7	0.9	4.90	1	1	0
08/18/2021 01:00	1.1	13.7	1,562.7	0.9	4.70	1	1	1
08/18/2021 02:00	1.3	12.7	1,985.3	0.9	6.00	1	1	1
08/18/2021 03:00	1.3	12.7	1,965.1	0.9	5.90	1	1	1
08/18/2021 04:00	1.2	13.6	1,715.8	1.0	6.90	1	1	0
08/18/2021 05:00	1.0	13.5	1,694.9	0.8	5.10	1	1	1
08/18/2021 06:00	1.3	12.5	2,032.6	0.9	6.10	1	1	1
08/18/2021 07:00	1.3	12.6	1,982.0	0.9	5.90	1	1	1
08/18/2021 08:00	1.2	13.7	1,458.9	1.0	5.80	1	1	0
08/18/2021 09:00	0.0	0.0	1,569.1	0.0	0.00	1	1	0
08/18/2021 10:00	0.9	14.0	1,541.4	0.8	4.60	1	1	0
08/18/2021 11:00	1.1	14.0	1,482.0	0.9	4.40	1	1	0
08/18/2021 12:00	1.1	13.9	1,527.9	0.9	4.60	1	1	1
08/18/2021 13:00	1.3	12.4	2,102.0	0.9	6.30	1	1	1
08/18/2021 14:00	1.3	12.1	2,088.5	0.9	6.30	1	1	1
08/18/2021 15:00	1.0	13.8	1,692.3	0.8	5.10	1	1	0
08/18/2021 16:00	1.0	13.9	1,547.5	0.8	4.60	1	1	0
08/18/2021 17:00	1.3	12.4	2,040.2	0.9	6.10	1	1	1
08/18/2021 18:00	1.4	11.8	2,188.5	0.9	6.60	1	1	1
08/18/2021 19:00	1.3	12.4	2,028.9	0.9	6.10	1	1	1
08/18/2021 20:00	1.1	13.8	1,724.9	0.9	5.20	1	1	0
08/18/2021 21:00	1.1	13.7	1,749.7	0.9	5.20	1	1	1
08/18/2021 22:00	1.3	12.4	2,079.3	0.9	6.20	1	1	1
08/18/2021 23:00	1.3	12.7	1,968.6	0.9	5.90	1	1	1
Average/Sum#:	1.2	13.1	1,807.4	0.9	128.50 #	24 #	24 #	15 #
Minimum:	0.9	11.8	1,458.9	0.8	4.40	1	1	0
Maximum:	1.4	14.0	2,188.5	1.0	6.90	1	1	1
%SI	4.17	4.17	0.00	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/19/2021 00:00	1.1	13.8	1,628.3	0.9	4.90	1	1	0
08/19/2021 01:00	1.1	13.8	1,660.5	0.9	5.00	1	1	0
08/19/2021 02:00	1.1	13.8	1,522.6	0.9	4.60	1	1	0
08/19/2021 03:00	1.1	13.8	1,557.9	0.9	4.70	1	1	1
08/19/2021 04:00	1.3	12.4	2,070.5	0.9	6.20	1	1	1
08/19/2021 05:00	1.2	12.8	1,990.8	0.9	6.00	1	1	1
08/19/2021 06:00	1.1	13.8	1,670.2	0.9	5.00	1	1	0
08/19/2021 07:00	1.1	13.8	1,701.0	0.9	5.10	1	1	0
08/19/2021 08:00	1.1	13.9	1,364.1	0.9	4.10	1	1	0
08/19/2021 09:00	0.0	0.0	1,688.3	0.0	0.00	1	1	0
08/19/2021 10:00	0.0	14.0	1,654.6	0.0	0.00	1	1	0
08/19/2021 11:00	0.1	13.9	1,623.7	0.1	0.00	1	1	0
08/19/2021 12:00	0.4	13.9	1,708.0	0.3	1.70	1	1	1
08/19/2021 13:00	0.0	0.0	2,118.7	0.0	0.00	1	1	1
08/19/2021 14:00	1.1	12.5	2,052.8	0.8	6.20	1	1	1
08/19/2021 15:00	1.0	13.9	1,586.0	0.8	4.80	1	1	0
08/19/2021 16:00	0.9	13.9	1,669.5	0.8	5.00	1	1	1
08/19/2021 17:00	1.3	12.3	2,091.5	0.9	6.30	1	1	1
08/19/2021 18:00	1.4	11.9	2,168.3	0.9	6.50	1	1	1
08/19/2021 19:00	1.4	12.2	2,081.9	0.9	6.20	1	1	1
08/19/2021 20:00	0.9	13.9	1,714.6	0.8	5.10	1	1	0
08/19/2021 21:00	0.9	13.8	1,621.2	0.7	4.90	1	1	1
08/19/2021 22:00	1.2	12.5	2,043.6	0.8	6.10	1	1	1
08/19/2021 23:00	1.3	12.8	1,963.7	0.9	5.90	1	1	1
Average/Sum#:	1.0	13.3	1,789.7	0.8	104.30 #	24 #	24 #	13 #
Minimum:	0.0	11.9	1,364.1	0.0	0.00	1	1	0
Maximum:	1.4	14.0	2,168.3	0.9	6.50	1	1	1
%SI	8.33	8.33	0.00	8.33	8.33	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/20/2021 00:00	1.0	13.9	1,690.4	0.8	5.10	1	1	0
08/20/2021 01:00	1.1	13.9	1,688.0	0.9	5.10	1	1	0
08/20/2021 02:00	0.9	13.9	1,546.8	0.8	4.60	1	1	0
08/20/2021 03:00	0.9	13.9	1,355.8	0.8	4.10	1	1	0
08/20/2021 04:00	1.0	13.9	1,652.9	0.8	5.00	1	1	0
08/20/2021 05:00	1.0	13.4	1,729.8	0.8	5.20	1	1	1
08/20/2021 06:00	1.0	13.1	1,865.4	0.8	5.60	1	1	1
08/20/2021 07:00	1.1	13.9	1,660.7	0.9	5.00	1	1	0
08/20/2021 08:00	0.9	13.9	1,526.6	0.8	4.60	1	1	0
08/20/2021 09:00	0.8	14.0	1,320.0	0.7	4.00	1	1	0
08/20/2021 10:00	0.8	14.0	1,308.3	0.7	3.90	1	1	0
08/20/2021 11:00	0.8	14.0	1,310.3	0.7	3.90	1	1	0
08/20/2021 12:00	0.8	13.9	1,524.4	0.7	3.00	1	1	1
08/20/2021 13:00	1.2	12.3	2,070.7	0.8	6.20	1	1	1
08/20/2021 14:00	1.3	12.5	2,004.6	0.9	6.00	1	1	1
08/20/2021 15:00	0.9	13.9	1,544.0	0.8	4.60	1	1	0
08/20/2021 16:00	0.9	13.8	1,552.9	0.7	4.70	1	1	0
08/20/2021 17:00	1.3	12.2	2,093.1	0.9	6.30	1	1	1
08/20/2021 18:00	1.4	11.9	2,156.3	0.9	6.50	1	1	1
08/20/2021 19:00	1.3	12.1	2,093.0	0.9	6.30	1	1	1
08/20/2021 20:00	1.1	13.9	1,676.8	0.9	5.00	1	1	0
08/20/2021 21:00	1.0	13.7	1,722.8	0.8	5.20	1	1	1
08/20/2021 22:00	1.3	12.4	2,063.8	0.9	6.20	1	1	1
08/20/2021 23:00	1.3	12.8	1,944.1	0.9	5.80	1	1	1
Average/Sum#:	1.0	13.4	1,712.6	0.8	121.90 #	24 #	24 #	11 #
Minimum:	0.8	11.9	1,308.3	0.7	3.00	1	1	0
Maximum:	1.4	14.0	2,156.3	0.9	6.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/21/2021 00:00	4.2	15.7	595.3	4.8	2.46	1	0	0
08/21/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/21/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/21/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/21/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/21/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/21/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/21/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/21/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/21/2021 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/21/2021 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/21/2021 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/21/2021 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/21/2021 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/21/2021 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/21/2021 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/21/2021 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/21/2021 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/21/2021 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/21/2021 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/21/2021 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/21/2021 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/21/2021 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/21/2021 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	4.2	15.7	595.3	4.8	2.46 #	1 #	0 #	0 #
Minimum:	4.2	15.7	595.3	4.8	2.46	0	0	0
Maximum:	4.2	15.7	595.3	4.8	2.46	1	0	0
%SI	95.83	95.83	95.83	95.83	95.83	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/22/2021 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2021 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2021 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2021 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2021 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2021 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2021 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2021 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2021 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2021 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2021 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2021 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2021 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2021 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2021 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2021 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/23/2021 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2021 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2021 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2021 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2021 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2021 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2021 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2021 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2021 16:00	31.5	17.8	320.6	60.0	63.81	1	0	0
08/23/2021 17:00	15.1	15.9	783.7	17.8	51.70	1	0	0
08/23/2021 18:00	0.3	14.1	1,703.5	0.3	1.70	1	1	0
08/23/2021 19:00	0.8	13.6	1,820.0	0.6	3.60	1	1	1
08/23/2021 20:00	1.1	13.1	1,884.9	0.8	5.70	1	1	1
08/23/2021 21:00	0.8	14.0	1,788.3	0.7	5.40	1	1	1
08/23/2021 22:00	1.1	13.0	2,028.3	0.8	6.10	1	1	1
08/23/2021 23:00	1.1	13.2	1,964.9	0.8	5.90	1	1	1
Average/Sum#:	6.5	14.3	1,536.8	10.2	143.91 #	8 #	6 #	5 #
Minimum:	0.3	13.0	320.6	0.3	1.70	0	0	0
Maximum:	31.5	17.8	2,028.3	60.0	63.81	1	1	1
%SI	66.67	66.67	66.67	66.67	66.67	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/24/2021 00:00	0.9	14.2	1,562.4	0.8	4.70	1	1	0
08/24/2021 01:00	0.8	14.2	1,629.4	0.7	4.90	1	1	0
08/24/2021 02:00	0.7	14.1	1,680.4	0.6	3.40	1	1	1
08/24/2021 03:00	0.9	13.4	1,948.6	0.7	5.80	1	1	1
08/24/2021 04:00	1.0	13.4	1,926.1	0.8	5.80	1	1	1
08/24/2021 05:00	0.8	14.2	1,667.1	0.7	5.00	1	1	0
08/24/2021 06:00	0.8	14.2	1,616.4	0.7	4.80	1	1	0
08/24/2021 07:00	0.8	14.2	1,658.7	0.7	5.00	1	1	0
08/24/2021 08:00	0.7	14.2	1,544.5	0.6	3.10	1	1	0
08/24/2021 09:00	0.7	14.2	1,704.8	0.6	3.40	1	1	0
08/24/2021 10:00	0.6	14.2	1,687.9	0.5	3.40	1	1	0
08/24/2021 11:00	0.5	14.2	1,652.2	0.4	3.30	1	1	0
08/24/2021 12:00	0.5	14.3	1,580.3	0.4	3.20	1	1	0
08/24/2021 13:00	0.6	14.2	1,661.3	0.5	3.30	1	1	1
08/24/2021 14:00	1.1	12.7	2,084.6	0.8	6.30	1	1	1
08/24/2021 15:00	1.3	12.7	2,079.1	0.9	6.20	1	1	1
08/24/2021 16:00	0.8	14.2	1,719.6	0.7	5.20	1	1	0
08/24/2021 17:00	0.7	14.0	1,770.8	0.6	3.50	1	1	1
08/24/2021 18:00	1.1	12.6	2,098.5	0.8	6.30	1	1	1
08/24/2021 19:00	1.3	12.2	2,154.7	0.9	6.50	1	1	1
08/24/2021 20:00	0.9	14.1	1,674.7	0.8	5.00	1	1	0
08/24/2021 21:00	0.8	14.0	1,798.3	0.7	5.40	1	1	1
08/24/2021 22:00	1.1	12.9	2,066.9	0.8	6.20	1	1	1
08/24/2021 23:00	1.3	12.5	2,164.1	0.9	6.50	1	1	1
Average/Sum#:	0.9	13.7	1,797.1	0.7	116.20 #	24 #	24 #	12 #
Minimum:	0.5	12.2	1,544.5	0.4	3.10	1	1	0
Maximum:	1.3	14.3	2,164.1	0.9	6.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/25/2021 00:00	0.9	13.9	1,651.0	0.8	5.00	1	1	1
08/25/2021 01:00	0.9	14.1	1,639.7	0.8	4.90	1	1	0
08/25/2021 02:00	0.8	14.1	1,590.9	0.7	4.80	1	1	1
08/25/2021 03:00	1.0	13.1	2,017.4	0.8	6.10	1	1	1
08/25/2021 04:00	1.1	12.8	2,088.8	0.8	6.30	1	1	1
08/25/2021 05:00	0.8	13.4	1,955.8	0.6	3.90	1	1	1
08/25/2021 06:00	0.6	14.2	1,607.1	0.5	3.20	1	1	0
08/25/2021 07:00	0.6	14.2	1,567.2	0.5	3.10	1	1	0
08/25/2021 08:00	0.7	14.1	1,642.5	0.6	3.30	1	1	1
08/25/2021 09:00	1.1	13.1	2,033.4	0.8	6.10	1	1	1
08/25/2021 10:00	1.2	13.3	1,972.7	0.9	5.90	1	1	1
08/25/2021 11:00	0.8	14.1	1,683.0	0.7	5.00	1	1	1
08/25/2021 12:00	0.8	14.1	1,650.6	0.7	5.00	1	1	1
08/25/2021 13:00	1.2	12.7	2,087.9	0.9	6.30	1	1	1
08/25/2021 14:00	1.3	12.6	2,077.7	0.9	6.20	1	1	1
08/25/2021 15:00	0.8	14.2	1,625.2	0.7	4.90	1	1	0
08/25/2021 16:00	0.7	14.2	1,482.5	0.6	3.00	1	1	1
08/25/2021 17:00	1.2	12.7	2,080.3	0.9	6.20	1	1	1
08/25/2021 18:00	1.3	12.2	2,175.5	0.9	6.50	1	1	1
08/25/2021 19:00	1.3	12.6	2,078.9	0.9	6.20	1	1	1
08/25/2021 20:00	0.9	14.1	1,666.9	0.8	5.00	1	1	0
08/25/2021 21:00	0.8	14.0	1,713.5	0.7	5.10	1	1	1
08/25/2021 22:00	1.2	12.9	2,057.5	0.9	6.20	1	1	1
08/25/2021 23:00	1.2	13.2	1,975.4	0.9	5.90	1	1	1
Average/Sum#:	1.0	13.5	1,838.4	0.8	124.10 #	24 #	24 #	19 #
Minimum:	0.6	12.2	1,482.5	0.5	3.00	1	1	0
Maximum:	1.3	14.2	2,175.5	0.9	6.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/26/2021 00:00	0.9	14.1	1,670.7	0.8	5.00	1	1	0
08/26/2021 01:00	0.9	14.1	1,636.5	0.8	4.90	1	1	0
08/26/2021 02:00	0.8	14.2	1,426.6	0.7	4.30	1	1	0
08/26/2021 03:00	0.8	14.1	1,591.5	0.7	4.80	1	1	1
08/26/2021 04:00	1.1	12.9	2,071.1	0.8	6.20	1	1	1
08/26/2021 05:00	1.2	12.8	2,103.5	0.9	6.30	1	1	1
08/26/2021 06:00	1.1	13.2	1,981.1	0.8	5.90	1	1	1
08/26/2021 07:00	0.8	14.1	1,698.6	0.7	5.10	1	1	1
08/26/2021 08:00	0.7	14.1	1,569.6	0.6	3.10	1	1	0
08/26/2021 09:00	1.0	13.5	1,865.4	0.8	5.60	1	1	1
08/26/2021 10:00	1.2	13.1	1,987.7	0.9	6.00	1	1	1
08/26/2021 11:00	0.8	14.1	1,726.8	0.7	5.20	1	1	0
08/26/2021 12:00	0.8	14.1	1,708.9	0.7	5.10	1	1	0
08/26/2021 13:00	1.2	12.8	2,066.9	0.9	6.20	1	1	1
08/26/2021 14:00	1.3	12.7	2,033.7	0.9	6.10	1	1	1
08/26/2021 15:00	0.8	14.1	1,725.7	0.7	5.20	1	1	0
08/26/2021 16:00	0.8	14.0	1,659.2	0.7	5.00	1	1	1
08/26/2021 17:00	1.3	12.3	2,150.8	0.9	6.50	1	1	1
08/26/2021 18:00	1.3	11.6	2,282.5	0.8	6.80	1	1	1
08/26/2021 19:00	1.3	11.6	2,300.4	0.8	6.90	1	1	1
08/26/2021 20:00	1.3	11.8	2,249.0	0.8	6.70	1	1	1
08/26/2021 21:00	1.3	11.9	2,232.7	0.9	6.70	1	1	1
08/26/2021 22:00	1.3	12.0	2,215.2	0.9	6.60	1	1	1
08/26/2021 23:00	1.3	12.4	2,112.7	0.9	6.30	1	1	1
Average/Sum#:	1.1	13.2	1,919.5	0.8	136.50 #	24 #	24 #	17 #
Minimum:	0.7	11.6	1,426.6	0.6	3.10	1	1	0
Maximum:	1.3	14.2	2,300.4	0.9	6.90	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/27/2021 00:00	0.9	14.0	1,712.6	0.8	5.10	1	1	0
08/27/2021 01:00	0.7	14.1	1,676.9	0.6	3.40	1	1	0
08/27/2021 02:00	0.7	14.0	1,708.6	0.6	3.40	1	1	0
08/27/2021 03:00	0.8	13.9	1,757.8	0.7	3.50	1	1	1
08/27/2021 04:00	1.2	12.6	2,098.9	0.9	6.30	1	1	1
08/27/2021 05:00	1.2	12.5	2,116.0	0.8	6.30	1	1	1
08/27/2021 06:00	0.8	14.0	1,610.2	0.7	4.80	1	1	0
08/27/2021 07:00	0.7	14.0	1,698.6	0.6	3.40	1	1	0
08/27/2021 08:00	0.7	14.0	1,554.4	0.6	3.10	1	1	0
08/27/2021 09:00	1.2	12.9	1,988.1	0.9	6.00	1	1	1
08/27/2021 10:00	1.3	12.7	2,014.5	0.9	6.00	1	1	1
08/27/2021 11:00	0.8	14.0	1,740.0	0.7	5.20	1	1	0
08/27/2021 12:00	0.7	14.0	1,736.3	0.6	3.50	1	1	1
08/27/2021 13:00	1.3	12.4	2,096.7	0.9	6.30	1	1	1
08/27/2021 14:00	1.4	11.8	2,210.8	0.9	6.60	1	1	1
08/27/2021 15:00	1.3	11.7	2,202.0	0.8	6.60	1	1	1
08/27/2021 16:00	1.3	11.7	2,198.8	0.8	6.60	1	1	1
08/27/2021 17:00	1.3	11.6	2,220.2	0.8	6.70	1	1	1
08/27/2021 18:00	1.3	11.6	2,231.5	0.8	6.70	1	1	1
08/27/2021 19:00	1.3	11.6	2,230.2	0.8	6.70	1	1	1
08/27/2021 20:00	1.3	11.6	2,235.5	0.8	6.70	1	1	1
08/27/2021 21:00	1.4	11.6	2,256.9	0.9	6.80	1	1	1
08/27/2021 22:00	1.3	11.9	2,210.2	0.9	6.60	1	1	1
08/27/2021 23:00	1.3	12.2	2,118.0	0.9	6.40	1	1	1
Average/Sum#:	1.1	12.8	1,984.3	0.8	132.70 #	24 #	24 #	17 #
Minimum:	0.7	11.6	1,554.4	0.6	3.10	1	1	0
Maximum:	1.4	14.1	2,256.9	0.9	6.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/28/2021 00:00	0.9	14.0	1,703.5	0.8	5.10	1	1	0
08/28/2021 01:00	0.8	13.8	1,792.7	0.7	3.60	1	1	1
08/28/2021 02:00	1.2	12.6	2,069.5	0.9	6.20	1	1	1
08/28/2021 03:00	1.2	13.0	1,965.6	0.9	5.90	1	1	1
08/28/2021 04:00	0.9	14.0	1,670.8	0.8	5.00	1	1	0
08/28/2021 05:00	0.5	14.1	1,666.0	0.4	3.30	1	1	0
08/28/2021 06:00	0.5	14.1	1,655.6	0.4	3.30	1	1	0
08/28/2021 07:00	0.6	14.0	1,692.8	0.5	3.40	1	1	0
08/28/2021 08:00	0.5	14.1	1,655.0	0.4	3.30	1	1	0
08/28/2021 09:00	0.7	13.9	1,694.6	0.6	3.40	1	1	0
08/28/2021 10:00	0.6	14.0	1,653.6	0.5	3.30	1	1	1
08/28/2021 11:00	1.3	12.3	2,114.8	0.9	6.30	1	1	1
08/28/2021 12:00	1.3	12.0	2,120.6	0.9	6.40	1	1	1
08/28/2021 13:00	0.7	14.0	1,704.8	0.6	3.40	1	1	0
08/28/2021 14:00	0.7	14.0	1,723.2	0.6	3.40	1	1	1
08/28/2021 15:00	1.2	12.4	2,080.0	0.8	6.20	1	1	1
08/28/2021 16:00	1.4	11.8	2,195.1	0.9	6.60	1	1	1
08/28/2021 17:00	1.3	11.6	2,230.8	0.8	6.70	1	1	1
08/28/2021 18:00	1.3	11.5	2,270.2	0.8	6.80	1	1	1
08/28/2021 19:00	1.3	11.4	2,290.7	0.8	6.90	1	1	1
08/28/2021 20:00	1.4	11.4	2,294.1	0.9	6.90	1	1	1
08/28/2021 21:00	1.3	11.5	2,276.2	0.8	6.80	1	1	1
08/28/2021 22:00	1.3	11.9	2,210.2	0.9	6.60	1	1	1
08/28/2021 23:00	1.3	12.2	2,147.8	0.9	6.40	1	1	1
Average/Sum#:	1.0	12.9	1,953.3	0.7	125.20 #	24 #	24 #	16 #
Minimum:	0.5	11.4	1,653.6	0.4	3.30	1	1	0
Maximum:	1.4	14.1	2,294.1	0.9	6.90	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/29/2021 00:00	1.3	12.7	2,008.0	0.9	6.00	1	1	1
08/29/2021 01:00	0.9	13.9	1,713.5	0.8	5.10	1	1	0
08/29/2021 02:00	0.8	13.7	1,797.6	0.7	3.60	1	1	1
08/29/2021 03:00	1.2	12.5	2,077.9	0.8	6.20	1	1	1
08/29/2021 04:00	1.3	12.3	2,082.6	0.9	6.20	1	1	1
08/29/2021 05:00	0.4	14.0	1,715.6	0.3	1.70	1	1	0
08/29/2021 06:00	0.4	14.0	1,647.3	0.3	1.60	1	1	0
08/29/2021 07:00	0.4	14.0	1,621.7	0.3	1.60	1	1	0
08/29/2021 08:00	0.5	14.1	1,544.6	0.4	3.10	1	1	0
08/29/2021 09:00	0.6	14.1	1,495.7	0.5	3.00	1	1	0
08/29/2021 10:00	1.0	13.3	1,824.9	0.8	5.50	1	1	1
08/29/2021 11:00	1.3	12.6	2,022.3	0.9	6.10	1	1	1
08/29/2021 12:00	1.0	13.8	1,734.4	0.8	5.20	1	1	1
08/29/2021 13:00	0.9	13.9	1,715.0	0.8	5.10	1	1	1
08/29/2021 14:00	1.3	12.1	2,115.5	0.9	6.30	1	1	1
08/29/2021 15:00	1.4	11.7	2,187.1	0.9	6.60	1	1	1
08/29/2021 16:00	1.4	11.6	2,203.9	0.9	6.60	1	1	1
08/29/2021 17:00	1.4	11.4	2,248.6	0.9	6.70	1	1	1
08/29/2021 18:00	1.3	11.4	2,257.6	0.8	6.80	1	1	1
08/29/2021 19:00	1.3	11.3	2,267.8	0.8	6.80	1	1	1
08/29/2021 20:00	1.4	11.3	2,265.7	0.9	6.80	1	1	1
08/29/2021 21:00	1.3	11.3	2,266.7	0.8	6.80	1	1	1
08/29/2021 22:00	1.4	11.6	2,216.8	0.9	6.70	1	1	1
08/29/2021 23:00	1.3	12.2	2,074.9	0.9	6.20	1	1	1
Average/Sum#:	1.1	12.7	1,962.7	0.7	126.30 #	24 #	24 #	18 #
Minimum:	0.4	11.3	1,495.7	0.3	1.60	1	1	0
Maximum:	1.4	14.1	2,267.8	0.9	6.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/30/2021 00:00	1.0	13.9	1,651.0	0.8	5.00	1	1	0
08/30/2021 01:00	1.0	13.9	1,696.1	0.8	5.10	1	1	1
08/30/2021 02:00	1.2	12.8	1,985.9	0.9	6.00	1	1	1
08/30/2021 03:00	1.3	12.3	2,078.8	0.9	6.20	1	1	1
08/30/2021 04:00	1.0	13.9	1,656.6	0.8	5.00	1	1	0
08/30/2021 05:00	0.9	13.9	1,556.2	0.8	4.70	1	1	1
08/30/2021 06:00	1.2	12.5	2,066.0	0.8	6.20	1	1	1
08/30/2021 07:00	1.3	12.5	2,034.9	0.9	6.10	1	1	1
08/30/2021 08:00	1.0	13.9	1,695.3	0.8	5.10	1	1	0
08/30/2021 09:00	1.0	13.8	1,666.0	0.8	5.00	1	1	0
08/30/2021 10:00	1.2	12.8	1,959.6	0.9	5.90	1	1	1
08/30/2021 11:00	1.3	12.1	2,092.0	0.9	6.30	1	1	1
08/30/2021 12:00	0.9	13.9	1,714.4	0.8	5.10	1	1	0
08/30/2021 13:00	0.8	13.9	1,700.3	0.7	3.40	1	1	1
08/30/2021 14:00	1.3	12.1	2,122.8	0.9	6.40	1	1	1
08/30/2021 15:00	1.4	11.6	2,198.3	0.9	6.60	1	1	1
08/30/2021 16:00	1.4	11.6	2,206.6	0.9	6.60	1	1	1
08/30/2021 17:00	1.4	11.4	2,239.3	0.9	6.70	1	1	1
08/30/2021 18:00	1.4	11.3	2,256.6	0.9	6.80	1	1	1
08/30/2021 19:00	1.3	11.3	2,272.2	0.8	6.80	1	1	1
08/30/2021 20:00	1.4	11.4	2,298.6	0.9	6.90	1	1	1
08/30/2021 21:00	1.3	11.5	2,279.5	0.8	6.80	1	1	1
08/30/2021 22:00	1.4	11.8	2,219.8	0.9	6.70	1	1	1
08/30/2021 23:00	1.3	12.2	2,099.9	0.9	6.30	1	1	1
Average/Sum#:	1.2	12.6	1,989.4	0.9	141.70 #	24 #	24 #	19 #
Minimum:	0.8	11.3	1,556.2	0.7	3.40	1	1	0
Maximum:	1.4	13.9	2,298.6	0.9	6.90	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/31/2021 00:00	1.0	13.9	1,680.9	0.8	5.00	1	1	0
08/31/2021 01:00	0.9	13.9	1,701.9	0.8	5.10	1	1	0
08/31/2021 02:00	0.9	14.0	1,331.1	0.8	4.00	1	1	0
08/31/2021 03:00	0.8	13.9	1,669.0	0.7	3.30	1	1	0
08/31/2021 04:00	0.8	13.4	1,835.1	0.6	3.70	1	1	1
08/31/2021 05:00	1.1	13.1	1,913.5	0.8	5.70	1	1	1
08/31/2021 06:00	0.8	13.7	1,797.8	0.7	3.60	1	1	0
08/31/2021 07:00	1.1	12.8	2,017.4	0.8	6.10	1	1	1
08/31/2021 08:00	1.3	12.3	2,098.8	0.9	6.30	1	1	1
08/31/2021 09:00	1.0	13.9	1,694.7	0.8	5.10	1	1	0
08/31/2021 10:00	0.8	13.8	1,710.3	0.7	3.40	1	1	0
08/31/2021 11:00	1.2	12.6	2,040.7	0.9	6.10	1	1	1
08/31/2021 12:00	1.4	12.1	2,106.5	0.9	6.30	1	1	1
08/31/2021 13:00	0.8	13.9	1,666.0	0.7	3.30	1	1	0
08/31/2021 14:00	0.8	13.8	1,726.0	0.7	3.50	1	1	0
08/31/2021 15:00	1.2	12.5	2,037.7	0.8	6.10	1	1	1
08/31/2021 16:00	1.4	11.7	2,188.2	0.9	6.60	1	1	1
08/31/2021 17:00	1.4	11.6	2,213.8	0.9	6.60	1	1	1
08/31/2021 18:00	1.3	11.6	2,221.7	0.8	6.70	1	1	1
08/31/2021 19:00	1.4	11.8	2,142.2	0.9	6.40	1	1	1
08/31/2021 20:00	0.9	13.9	1,665.8	0.8	5.00	1	1	0
08/31/2021 21:00	0.9	13.8	1,727.7	0.7	5.20	1	1	1
08/31/2021 22:00	1.2	12.6	2,039.4	0.9	6.10	1	1	1
08/31/2021 23:00	1.3	12.3	2,104.3	0.9	6.30	1	1	1
Average/Sum#:	1.1	13.0	1,888.8	0.8	125.50 #	24 #	24 #	14 #
Minimum:	0.8	11.6	1,331.1	0.6	3.30	1	1	0
Maximum:	1.4	14.0	2,221.7	0.9	6.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/01/2021 00:00	1.4	12.2	2,119.6	0.9	6.40	1	1	1
09/01/2021 01:00	1.1	12.9	1,948.2	0.8	5.80	1	1	1
09/01/2021 02:00	0.8	13.9	1,611.5	0.7	3.20	1	1	0
09/01/2021 03:00	0.8	13.8	1,708.0	0.7	3.40	1	1	1
09/01/2021 04:00	1.0	12.7	2,026.0	0.7	6.10	1	1	1
09/01/2021 05:00	1.3	12.2	2,137.0	0.9	6.40	1	1	1
09/01/2021 06:00	1.1	12.7	2,014.6	0.8	6.00	1	1	1
09/01/2021 07:00	0.7	13.9	1,688.3	0.6	3.40	1	1	0
09/01/2021 08:00	0.8	13.9	1,627.2	0.7	3.30	1	1	0
09/01/2021 09:00	1.0	13.2	1,903.9	0.8	5.70	1	1	1
09/01/2021 10:00	1.2	12.8	2,008.3	0.9	6.00	1	1	1
09/01/2021 11:00	1.0	13.7	1,502.1	0.8	4.50	1	1	1
09/01/2021 12:00	0.9	13.9	1,567.5	0.8	4.70	1	1	1
09/01/2021 13:00	1.2	12.6	2,028.4	0.9	6.10	1	1	1
09/01/2021 14:00	1.3	12.6	2,015.2	0.9	6.00	1	1	1
09/01/2021 15:00	1.1	13.6	1,702.8	0.9	5.10	1	1	1
09/01/2021 16:00	0.9	13.8	1,707.8	0.7	5.10	1	1	1
09/01/2021 17:00	1.3	12.4	2,082.1	0.9	6.20	1	1	1
09/01/2021 18:00	1.4	12.1	2,135.8	0.9	6.40	1	1	1
09/01/2021 19:00	1.4	12.1	2,131.5	0.9	6.40	1	1	1
09/01/2021 20:00	0.9	13.9	1,700.1	0.8	5.10	1	1	0
09/01/2021 21:00	0.9	14.0	1,393.2	0.8	4.20	1	1	0
09/01/2021 22:00	0.8	13.9	1,652.8	0.7	3.30	1	1	0
09/01/2021 23:00	0.7	13.9	1,715.5	0.6	3.40	1	1	0
Average/Sum#:	1.0	13.2	1,838.6	0.8	122.20 #	24 #	24 #	17 #
Minimum:	0.7	12.1	1,393.2	0.6	3.20	1	1	0
Maximum:	1.4	14.0	2,137.0	0.9	6.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/02/2021 00:00	0.8	13.3	1,857.1	0.6	3.70	1	1	1
09/02/2021 01:00	1.0	13.1	1,876.2	0.8	5.60	1	1	1
09/02/2021 02:00	1.0	14.0	1,370.3	0.9	4.10	1	1	0
09/02/2021 03:00	0.8	13.9	1,683.9	0.7	3.40	1	1	0
09/02/2021 04:00	0.9	14.0	1,400.5	0.8	4.20	1	1	0
09/02/2021 05:00	0.9	13.9	1,663.2	0.8	5.00	1	1	0
09/02/2021 06:00	0.8	13.5	1,825.7	0.6	3.70	1	1	1
09/02/2021 07:00	0.9	13.4	1,846.9	0.7	5.50	1	1	1
09/02/2021 08:00	0.9	14.0	1,369.4	0.8	4.10	1	1	0
09/02/2021 09:00	1.0	14.0	1,457.6	0.9	4.40	1	1	0
09/02/2021 10:00	0.8	14.0	1,514.8	0.7	4.50	1	1	0
09/02/2021 11:00	0.9	14.0	1,439.1	0.8	4.30	1	1	0
09/02/2021 12:00	0.8	13.9	1,706.5	0.7	3.40	1	1	1
09/02/2021 13:00	1.2	12.6	2,063.2	0.9	6.20	1	1	1
09/02/2021 14:00	1.4	12.6	2,016.1	1.0	8.10	1	1	1
09/02/2021 15:00	0.9	13.9	1,683.5	0.8	5.10	1	1	0
09/02/2021 16:00	0.8	13.9	1,647.4	0.7	3.30	1	1	1
09/02/2021 17:00	1.4	12.4	2,091.0	1.0	8.40	1	1	1
09/02/2021 18:00	1.6	12.2	2,123.3	1.1	8.50	1	1	1
09/02/2021 19:00	1.6	12.3	2,091.3	1.1	8.40	1	1	1
09/02/2021 20:00	1.0	13.9	1,588.0	0.8	4.80	1	1	0
09/02/2021 21:00	0.8	14.0	1,400.2	0.7	4.20	1	1	0
09/02/2021 22:00	0.7	14.0	1,624.0	0.6	3.20	1	1	0
09/02/2021 23:00	0.9	13.4	1,853.7	0.7	5.60	1	1	1
Average/Sum#:	1.0	13.5	1,716.4	0.8	121.70 #	24 #	24 #	12 #
Minimum:	0.7	12.2	1,369.4	0.6	3.20	1	1	0
Maximum:	1.6	14.0	2,123.3	1.1	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/03/2021 00:00	1.2	13.0	1,910.7	0.9	5.70	1	1	1
09/03/2021 01:00	0.9	13.8	1,617.8	0.7	4.90	1	1	0
09/03/2021 02:00	0.7	13.7	1,793.5	0.6	3.60	1	1	1
09/03/2021 03:00	1.0	13.1	1,925.9	0.8	5.80	1	1	1
09/03/2021 04:00	0.8	13.9	1,590.6	0.7	3.20	1	1	0
09/03/2021 05:00	0.7	13.7	1,755.9	0.6	3.50	1	1	1
09/03/2021 06:00	1.0	12.7	2,045.0	0.7	6.10	1	1	1
09/03/2021 07:00	1.1	12.9	1,969.9	0.8	5.90	1	1	1
09/03/2021 08:00	0.7	13.9	1,715.3	0.6	3.40	1	1	0
09/03/2021 09:00	0.7	14.0	1,526.3	0.6	3.10	1	1	0
09/03/2021 10:00	0.8	14.0	1,614.6	0.7	4.80	1	1	0
09/03/2021 11:00	0.7	14.0	1,620.6	0.6	3.20	1	1	0
09/03/2021 12:00	0.6	14.0	1,628.9	0.5	3.30	1	1	0
09/03/2021 13:00	0.7	14.0	1,643.2	0.6	3.30	1	1	0
09/03/2021 14:00	0.7	14.0	1,562.2	0.6	3.10	1	1	1
09/03/2021 15:00	1.3	12.3	2,094.4	0.9	6.30	1	1	1
09/03/2021 16:00	1.4	12.0	2,163.6	0.9	6.50	1	1	1
09/03/2021 17:00	1.4	11.7	2,230.1	0.9	6.70	1	1	1
09/03/2021 18:00	1.3	11.7	2,225.2	0.8	6.70	1	1	1
09/03/2021 19:00	1.3	12.0	2,132.1	0.9	6.40	1	1	1
09/03/2021 20:00	0.9	13.9	1,709.0	0.8	5.10	1	1	0
09/03/2021 21:00	0.9	13.7	1,806.1	0.7	5.40	1	1	1
09/03/2021 22:00	1.2	12.7	2,041.0	0.9	6.10	1	1	1
09/03/2021 23:00	1.3	12.9	1,978.4	1.0	7.90	1	1	1
Average/Sum#:	1.0	13.2	1,845.8	0.7	120.00 #	24 #	24 #	15 #
Minimum:	0.6	11.7	1,526.3	0.5	3.10	1	1	0
Maximum:	1.4	14.0	2,230.1	1.0	7.90	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/04/2021 00:00	1.0	13.9	1,650.1	0.8	5.00	1	1	0
09/04/2021 01:00	1.0	13.8	1,674.7	0.8	5.00	1	1	1
09/04/2021 02:00	1.2	12.7	2,039.5	0.9	6.10	1	1	1
09/04/2021 03:00	2.9	14.0	1,289.6	2.5	5.80	1	0	1
09/04/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/04/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/04/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/04/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/04/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/04/2021 09:00	1.4	18.5	252.8	3.4	0.92	1	0	0
09/04/2021 10:00	9.1	15.6	860.7	10.1	31.80	1	0	0
09/04/2021 11:00	0.3	14.1	1,392.6	0.3	1.40	1	1	0
09/04/2021 12:00	0.7	14.1	1,380.3	0.6	2.80	1	1	0
09/04/2021 13:00	0.9	13.9	1,672.0	0.8	5.00	1	1	0
09/04/2021 14:00	0.7	14.0	1,458.3	0.6	2.90	1	1	0
09/04/2021 15:00	0.8	13.9	1,725.1	0.7	3.50	1	1	0
09/04/2021 16:00	0.9	13.9	1,622.1	0.8	4.90	1	1	1
09/04/2021 17:00	1.3	12.1	2,143.0	0.9	6.40	1	1	1
09/04/2021 18:00	1.4	11.5	2,257.2	0.9	6.80	1	1	1
09/04/2021 19:00	1.3	11.5	2,278.9	0.8	6.80	1	1	1
09/04/2021 20:00	1.3	11.8	2,210.2	0.8	6.60	1	1	1
09/04/2021 21:00	1.3	12.1	2,164.2	0.9	6.50	1	1	1
09/04/2021 22:00	1.3	12.3	2,115.0	0.9	6.30	1	1	1
09/04/2021 23:00	1.3	12.4	2,102.2	0.9	6.30	1	1	1
Average/Sum#:	1.6	13.5	1,699.4	1.5	120.82 #	19 #	16 #	11 #
Minimum:	0.3	11.5	252.8	0.3	0.92	0	0	0
Maximum:	9.1	18.5	2,278.9	10.1	31.80	1	1	1
%SI	20.83	20.83	20.83	20.83	20.83	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/05/2021 00:00	1.2	12.8	1,980.3	0.9	5.90	1	1	1
09/05/2021 01:00	1.0	13.9	1,662.6	0.8	5.00	1	1	0
09/05/2021 02:00	0.9	13.9	1,674.5	0.8	5.00	1	1	1
09/05/2021 03:00	1.3	12.7	2,044.6	0.9	6.10	1	1	1
09/05/2021 04:00	1.3	13.0	1,964.0	1.0	7.90	1	1	1
09/05/2021 05:00	1.0	13.9	1,654.9	0.8	5.00	1	1	0
09/05/2021 06:00	1.1	13.9	1,643.1	0.9	4.90	1	1	0
09/05/2021 07:00	1.1	13.9	1,615.9	0.9	4.80	1	1	0
09/05/2021 08:00	1.1	13.9	1,646.7	0.9	4.90	1	1	0
09/05/2021 09:00	1.1	13.9	1,636.0	0.9	4.90	1	1	0
09/05/2021 10:00	1.0	13.9	1,704.5	0.8	5.10	1	1	0
09/05/2021 11:00	0.9	13.9	1,730.3	0.8	5.20	1	1	0
09/05/2021 12:00	0.8	13.9	1,717.8	0.7	3.40	1	1	0
09/05/2021 13:00	0.7	13.9	1,734.3	0.6	3.50	1	1	0
09/05/2021 14:00	1.2	12.5	2,046.7	0.8	6.10	1	1	1
09/05/2021 15:00	1.4	11.9	2,203.4	0.9	6.60	1	1	1
09/05/2021 16:00	1.4	11.7	2,225.0	0.9	6.70	1	1	1
09/05/2021 17:00	1.4	11.5	2,263.7	0.9	6.80	1	1	1
09/05/2021 18:00	1.3	11.6	2,250.1	0.8	6.80	1	1	1
09/05/2021 19:00	1.3	11.5	2,281.4	0.8	6.80	1	1	1
09/05/2021 20:00	1.3	11.8	2,210.7	0.8	6.60	1	1	1
09/05/2021 21:00	1.3	12.1	2,164.2	0.9	6.50	1	1	1
09/05/2021 22:00	1.3	12.2	2,142.8	0.9	6.40	1	1	1
09/05/2021 23:00	1.3	12.5	2,050.0	0.9	6.20	1	1	1
Average/Sum#:	1.2	12.9	1,927.0	0.8	137.10 #	24 #	24 #	14 #
Minimum:	0.7	11.5	1,615.9	0.6	3.40	1	1	0
Maximum:	1.4	13.9	2,281.4	1.0	7.90	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/06/2021 00:00	1.0	13.9	1,652.7	0.8	5.00	1	1	0
09/06/2021 01:00	0.9	13.9	1,625.0	0.8	4.90	1	1	1
09/06/2021 02:00	1.2	12.8	1,957.6	0.9	5.90	1	1	1
09/06/2021 03:00	1.2	12.8	1,935.8	0.9	5.80	1	1	1
09/06/2021 04:00	0.7	14.0	1,604.9	0.6	3.20	1	1	0
09/06/2021 05:00	1.1	13.9	1,680.6	0.9	5.00	1	1	0
09/06/2021 06:00	1.0	13.9	1,635.7	0.8	4.90	1	1	0
09/06/2021 07:00	0.8	14.0	1,635.3	0.7	4.90	1	1	0
09/06/2021 08:00	0.5	14.0	1,706.4	0.4	3.40	1	1	0
09/06/2021 09:00	0.7	14.0	1,567.3	0.6	3.10	1	1	0
09/06/2021 10:00	0.8	13.9	1,706.1	0.7	3.40	1	1	0
09/06/2021 11:00	0.8	13.9	1,699.3	0.7	3.40	1	1	1
09/06/2021 12:00	1.3	12.2	2,137.3	0.9	6.40	1	1	1
09/06/2021 13:00	1.4	11.7	2,221.8	0.9	6.70	1	1	1
09/06/2021 14:00	1.4	11.7	2,213.1	0.9	6.60	1	1	1
09/06/2021 15:00	1.3	11.6	2,219.5	0.8	6.70	1	1	1
09/06/2021 16:00	1.4	11.6	2,226.8	0.9	6.70	1	1	1
09/06/2021 17:00	1.3	11.5	2,239.8	0.8	6.70	1	1	1
09/06/2021 18:00	1.3	11.4	2,242.5	0.8	6.70	1	1	1
09/06/2021 19:00	1.4	11.5	2,252.5	0.9	6.80	1	1	1
09/06/2021 20:00	1.3	11.5	2,261.6	0.8	6.80	1	1	1
09/06/2021 21:00	1.3	11.6	2,238.3	0.8	6.70	1	1	1
09/06/2021 22:00	1.3	11.9	2,174.2	0.9	6.50	1	1	1
09/06/2021 23:00	1.3	12.4	2,074.3	0.9	6.20	1	1	1
Average/Sum#:	1.1	12.7	1,954.5	0.8	132.40 #	24 #	24 #	16 #
Minimum:	0.5	11.4	1,567.3	0.4	3.10	1	1	0
Maximum:	1.4	14.0	2,261.6	0.9	6.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/07/2021 00:00	0.8	13.9	1,717.1	0.7	3.40	1	1	0
09/07/2021 01:00	0.8	13.8	1,693.8	0.7	3.40	1	1	1
09/07/2021 02:00	1.1	12.8	2,023.7	0.8	6.10	1	1	1
09/07/2021 03:00	1.3	13.0	1,958.1	1.0	7.80	1	1	1
09/07/2021 04:00	1.1	13.9	1,720.2	0.9	5.20	1	1	0
09/07/2021 05:00	0.9	13.7	1,806.0	0.7	5.40	1	1	1
09/07/2021 06:00	1.2	12.7	2,046.2	0.9	6.10	1	1	1
09/07/2021 07:00	1.3	12.7	2,011.4	0.9	6.00	1	1	1
09/07/2021 08:00	1.1	13.9	1,708.1	0.9	5.10	1	1	0
09/07/2021 09:00	0.9	13.8	1,750.7	0.7	5.30	1	1	0
09/07/2021 10:00	1.3	12.6	2,039.3	0.9	6.10	1	1	1
09/07/2021 11:00	1.4	11.7	2,224.5	0.9	6.70	1	1	1
09/07/2021 12:00	1.3	11.7	2,207.4	0.8	6.60	1	1	1
09/07/2021 13:00	1.3	11.8	2,182.0	0.8	6.50	1	1	1
09/07/2021 14:00	1.3	11.8	2,170.1	0.8	6.50	1	1	1
09/07/2021 15:00	1.4	11.7	2,180.3	0.9	6.50	1	1	1
09/07/2021 16:00	1.4	11.6	2,201.9	0.9	6.60	1	1	1
09/07/2021 17:00	1.3	11.7	2,194.2	0.8	6.60	1	1	1
09/07/2021 18:00	1.3	12.0	2,154.8	0.9	6.50	1	1	1
09/07/2021 19:00	1.3	12.1	2,140.7	0.9	6.40	1	1	1
09/07/2021 20:00	1.3	12.1	2,150.4	0.9	6.50	1	1	1
09/07/2021 21:00	1.3	11.7	2,252.7	0.8	6.80	1	1	1
09/07/2021 22:00	1.3	11.4	2,283.7	0.8	6.90	1	1	1
09/07/2021 23:00	1.3	11.5	2,284.5	0.8	6.90	1	1	1
Average/Sum#:	1.2	12.5	2,045.9	0.8	145.90 #	24 #	24 #	20 #
Minimum:	0.8	11.4	1,693.8	0.7	3.40	1	1	0
Maximum:	1.4	13.9	2,284.5	1.0	7.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/08/2021 00:00	1.3	11.6	2,263.8	0.8	6.80	1	1	1
09/08/2021 01:00	1.3	11.9	2,186.0	0.9	6.60	1	1	1
09/08/2021 02:00	1.3	12.2	2,133.6	0.9	6.40	1	1	1
09/08/2021 03:00	1.3	12.2	2,144.7	0.9	6.40	1	1	1
09/08/2021 04:00	1.4	11.7	2,254.9	0.9	6.80	1	1	1
09/08/2021 05:00	0.9	11.6	2,279.4	0.6	4.60	1	1	1
09/08/2021 06:00	1.3	11.7	2,238.7	0.8	6.70	1	1	1
09/08/2021 07:00	1.3	12.5	2,044.9	0.9	6.10	1	1	1
09/08/2021 08:00	0.9	13.9	1,716.5	0.8	5.10	1	1	0
09/08/2021 09:00	0.9	13.8	1,728.7	0.7	5.20	1	1	1
09/08/2021 10:00	1.3	12.4	2,089.6	0.9	6.30	1	1	1
09/08/2021 11:00	1.3	11.7	2,191.9	0.8	6.60	1	1	1
09/08/2021 12:00	1.4	11.8	2,166.9	0.9	6.50	1	1	1
09/08/2021 13:00	1.3	11.7	2,166.2	0.8	6.50	1	1	1
09/08/2021 14:00	1.4	11.6	2,167.2	0.9	6.50	1	1	1
09/08/2021 15:00	1.3	11.6	2,165.3	0.8	6.50	1	1	1
09/08/2021 16:00	1.3	11.5	2,186.0	0.8	6.60	1	1	1
09/08/2021 17:00	1.4	11.4	2,203.1	0.9	6.60	1	1	1
09/08/2021 18:00	1.3	11.5	2,204.6	0.8	6.60	1	1	1
09/08/2021 19:00	1.4	11.5	2,220.7	0.9	6.70	1	1	1
09/08/2021 20:00	1.3	11.6	2,210.2	0.8	6.60	1	1	1
09/08/2021 21:00	1.3	11.8	2,171.2	0.8	6.50	1	1	1
09/08/2021 22:00	1.3	11.9	2,146.3	0.9	6.40	1	1	1
09/08/2021 23:00	1.4	11.6	2,213.3	0.9	6.60	1	1	1
Average/Sum#:	1.3	11.9	2,145.6	0.8	152.20 #	24 #	24 #	23 #
Minimum:	0.9	11.4	1,716.5	0.6	4.60	1	1	0
Maximum:	1.4	13.9	2,279.4	0.9	6.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/09/2021 00:00	1.3	11.5	2,226.4	0.8	6.70	1	1	1
09/09/2021 01:00	1.4	11.5	2,235.7	0.9	6.70	1	1	1
09/09/2021 02:00	1.3	11.6	2,241.1	0.8	6.70	1	1	1
09/09/2021 03:00	1.3	11.6	2,238.9	0.8	6.70	1	1	1
09/09/2021 04:00	1.4	11.5	2,242.2	0.9	6.70	1	1	1
09/09/2021 05:00	1.4	11.5	2,245.9	0.9	6.70	1	1	1
09/09/2021 06:00	1.3	11.6	2,235.2	0.8	6.70	1	1	1
09/09/2021 07:00	1.3	11.8	2,188.7	0.8	6.60	1	1	1
09/09/2021 08:00	1.4	11.8	2,180.0	0.9	6.50	1	1	1
09/09/2021 09:00	1.4	11.7	2,181.9	0.9	6.50	1	1	1
09/09/2021 10:00	1.4	11.7	2,180.9	0.9	6.50	1	1	1
09/09/2021 11:00	1.4	11.7	2,165.1	0.9	6.50	1	1	1
09/09/2021 12:00	1.3	11.8	2,145.6	0.8	6.40	1	1	1
09/09/2021 13:00	1.3	11.6	2,155.1	0.8	6.50	1	1	1
09/09/2021 14:00	1.4	11.7	2,142.4	0.9	6.40	1	1	1
09/09/2021 15:00	1.4	11.7	2,137.4	0.9	6.40	1	1	1
09/09/2021 16:00	1.4	11.6	2,152.0	0.9	6.50	1	1	1
09/09/2021 17:00	1.4	11.6	2,162.8	0.9	6.50	1	1	1
09/09/2021 18:00	1.4	11.4	2,199.0	0.9	6.60	1	1	1
09/09/2021 19:00	1.4	11.4	2,204.7	0.9	6.60	1	1	1
09/09/2021 20:00	1.4	11.5	2,219.3	0.9	6.70	1	1	1
09/09/2021 21:00	1.3	11.5	2,220.9	0.8	6.70	1	1	1
09/09/2021 22:00	1.3	11.6	2,192.1	0.8	6.60	1	1	1
09/09/2021 23:00	1.3	11.6	2,206.7	0.8	6.60	1	1	1
Average/Sum#:	1.4	11.6	2,195.8	0.9	158.00 #	24 #	24 #	24 #
Minimum:	1.3	11.4	2,137.4	0.8	6.40	1	1	1
Maximum:	1.4	11.8	2,245.9	0.9	6.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/10/2021 00:00	1.3	11.9	2,121.5	0.9	6.40	1	1	1
09/10/2021 01:00	1.0	13.9	1,595.7	0.8	4.80	1	1	0
09/10/2021 02:00	0.9	13.7	1,762.7	0.7	5.30	1	1	1
09/10/2021 03:00	1.3	12.4	2,082.3	0.9	6.20	1	1	1
09/10/2021 04:00	1.4	11.8	2,203.4	0.9	6.60	1	1	1
09/10/2021 05:00	1.4	11.9	2,162.2	0.9	6.50	1	1	1
09/10/2021 06:00	1.4	11.8	2,217.1	0.9	6.70	1	1	1
09/10/2021 07:00	1.1	13.5	1,658.1	0.9	5.00	1	1	1
09/10/2021 08:00	1.0	13.9	1,527.7	0.8	4.60	1	1	0
09/10/2021 09:00	0.9	13.9	1,649.6	0.8	4.90	1	1	0
09/10/2021 10:00	0.9	13.8	1,627.3	0.7	4.90	1	1	1
09/10/2021 11:00	1.3	12.4	2,066.7	0.9	6.20	1	1	1
09/10/2021 12:00	1.3	12.3	2,038.6	0.9	6.10	1	1	1
09/10/2021 13:00	0.9	13.9	1,607.4	0.8	4.80	1	1	0
09/10/2021 14:00	0.8	13.8	1,726.8	0.7	3.50	1	1	1
09/10/2021 15:00	1.3	12.2	2,089.8	0.9	6.30	1	1	1
09/10/2021 16:00	1.4	11.9	2,151.3	0.9	6.50	1	1	1
09/10/2021 17:00	1.4	11.6	2,212.6	0.9	6.60	1	1	1
09/10/2021 18:00	1.4	11.5	2,232.2	0.9	6.70	1	1	1
09/10/2021 19:00	1.3	11.5	2,232.9	0.8	6.70	1	1	1
09/10/2021 20:00	1.4	11.6	2,229.3	0.9	6.70	1	1	1
09/10/2021 21:00	1.3	11.6	2,229.1	0.8	6.70	1	1	1
09/10/2021 22:00	1.3	11.9	2,159.0	0.9	6.50	1	1	1
09/10/2021 23:00	1.3	12.3	2,087.1	0.9	6.30	1	1	1
Average/Sum#:	1.2	12.5	1,986.3	0.9	141.50 #	24 #	24 #	20 #
Minimum:	0.8	11.5	1,527.7	0.7	3.50	1	1	0
Maximum:	1.4	13.9	2,232.9	0.9	6.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/11/2021 00:00	1.3	12.8	1,952.2	0.9	5.90	1	1	1
09/11/2021 01:00	1.0	13.9	1,709.2	0.8	5.10	1	1	0
09/11/2021 02:00	1.0	13.9	1,694.1	0.8	5.10	1	1	0
09/11/2021 03:00	0.9	13.8	1,583.2	0.7	4.70	1	1	1
09/11/2021 04:00	1.3	12.6	2,039.4	0.9	6.10	1	1	1
09/11/2021 05:00	1.2	13.0	1,962.4	0.9	5.90	1	1	1
09/11/2021 06:00	1.1	13.9	1,672.1	0.9	5.00	1	1	0
09/11/2021 07:00	1.1	13.8	1,644.5	0.9	4.90	1	1	0
09/11/2021 08:00	1.0	13.9	1,525.9	0.8	4.60	1	1	0
09/11/2021 09:00	1.0	13.9	1,608.1	0.8	4.80	1	1	0
09/11/2021 10:00	0.8	13.9	1,703.1	0.7	3.40	1	1	0
09/11/2021 11:00	1.0	13.8	1,688.8	0.8	5.10	1	1	1
09/11/2021 12:00	1.3	12.2	2,095.8	0.9	6.30	1	1	1
09/11/2021 13:00	1.3	12.1	2,076.8	0.9	6.20	1	1	1
09/11/2021 14:00	0.9	13.9	1,695.9	0.8	5.10	1	1	0
09/11/2021 15:00	0.9	13.7	1,735.3	0.7	5.20	1	1	1
09/11/2021 16:00	1.3	12.3	2,087.0	0.9	6.30	1	1	1
09/11/2021 17:00	1.4	11.4	2,270.9	0.9	6.80	1	1	1
09/11/2021 18:00	1.3	11.5	2,236.7	0.8	6.70	1	1	1
09/11/2021 19:00	1.3	11.9	2,176.8	0.9	6.50	1	1	1
09/11/2021 20:00	1.3	11.7	2,220.5	0.8	6.70	1	1	1
09/11/2021 21:00	1.4	11.6	2,242.3	0.9	6.70	1	1	1
09/11/2021 22:00	1.3	11.9	2,189.2	0.9	6.60	1	1	1
09/11/2021 23:00	1.3	11.8	2,202.1	0.8	6.60	1	1	1
Average/Sum#:	1.2	12.9	1,917.2	0.8	136.30 #	24 #	24 #	16 #
Minimum:	0.8	11.4	1,525.9	0.7	3.40	1	1	0
Maximum:	1.4	13.9	2,270.9	0.9	6.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/12/2021 00:00	1.3	12.4	2,055.2	0.9	6.20	1	1	1
09/12/2021 01:00	0.8	13.9	1,710.0	0.7	3.40	1	1	0
09/12/2021 02:00	0.5	14.0	1,667.0	0.4	3.30	1	1	0
09/12/2021 03:00	0.7	13.7	1,666.4	0.6	3.30	1	1	1
09/12/2021 04:00	1.3	12.7	2,028.8	0.9	6.10	1	1	1
09/12/2021 05:00	1.3	13.0	1,969.1	1.0	7.90	1	1	1
09/12/2021 06:00	1.0	13.8	1,557.1	0.8	4.70	1	1	1
09/12/2021 07:00	0.9	13.9	1,601.5	0.8	4.80	1	1	0
09/12/2021 08:00	0.8	14.0	1,367.1	0.7	4.10	1	1	0
09/12/2021 09:00	0.9	14.0	1,298.1	0.8	3.90	1	1	0
09/12/2021 10:00	0.8	13.9	1,676.8	0.7	3.40	1	1	0
09/12/2021 11:00	0.9	13.8	1,746.7	0.7	5.20	1	1	1
09/12/2021 12:00	1.3	12.3	2,083.6	0.9	6.30	1	1	1
09/12/2021 13:00	1.3	11.9	2,115.0	0.9	6.30	1	1	1
09/12/2021 14:00	1.0	13.9	1,670.3	0.8	5.00	1	1	0
09/12/2021 15:00	1.0	13.8	1,657.2	0.8	5.00	1	1	1
09/12/2021 16:00	1.3	12.1	2,116.2	0.9	6.30	1	1	1
09/12/2021 17:00	1.3	11.4	2,257.9	0.8	6.80	1	1	1
09/12/2021 18:00	1.3	11.6	2,220.7	0.8	6.70	1	1	1
09/12/2021 19:00	1.3	11.8	2,183.1	0.8	6.50	1	1	1
09/12/2021 20:00	1.4	12.0	2,151.7	0.9	6.50	1	1	1
09/12/2021 21:00	1.3	12.1	2,128.6	0.9	6.40	1	1	1
09/12/2021 22:00	1.3	12.2	2,114.7	0.9	6.30	1	1	1
09/12/2021 23:00	1.3	12.3	2,107.9	0.9	6.30	1	1	1
Average/Sum#:	1.1	12.9	1,881.3	0.8	130.70 #	24 #	24 #	17 #
Minimum:	0.5	11.4	1,298.1	0.4	3.30	1	1	0
Maximum:	1.4	14.0	2,257.9	1.0	7.90	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/13/2021 00:00	1.2	12.8	1,967.5	0.9	5.90	1	1	1
09/13/2021 01:00	1.1	13.9	1,606.9	0.9	4.80	1	1	0
09/13/2021 02:00	1.0	13.9	1,592.6	0.8	4.80	1	1	0
09/13/2021 03:00	0.9	13.9	1,667.3	0.8	5.00	1	1	0
09/13/2021 04:00	0.7	14.0	1,347.6	0.6	2.70	1	1	0
09/13/2021 05:00	0.6	14.0	1,695.4	0.5	3.40	1	1	0
09/13/2021 06:00	0.8	13.4	1,826.7	0.6	3.70	1	1	1
09/13/2021 07:00	1.1	13.0	1,875.7	0.8	5.60	1	1	1
09/13/2021 08:00	0.9	13.9	1,544.6	0.8	4.60	1	1	0
09/13/2021 09:00	1.2	12.7	1,991.2	0.9	6.00	1	1	1
09/13/2021 10:00	1.3	12.6	1,997.8	0.9	6.00	1	1	1
09/13/2021 11:00	0.8	13.9	1,724.6	0.7	3.40	1	1	0
09/13/2021 12:00	0.8	13.8	1,697.5	0.7	3.40	1	1	0
09/13/2021 13:00	1.2	12.4	2,062.3	0.8	6.20	1	1	1
09/13/2021 14:00	1.4	11.5	2,232.7	0.9	6.70	1	1	1
09/13/2021 15:00	1.4	11.6	2,216.2	0.9	6.60	1	1	1
09/13/2021 16:00	1.4	11.5	2,210.5	0.9	6.60	1	1	1
09/13/2021 17:00	1.4	11.4	2,243.4	0.9	6.70	1	1	1
09/13/2021 18:00	1.4	11.4	2,248.1	0.9	6.70	1	1	1
09/13/2021 19:00	1.4	11.4	2,243.6	0.9	6.70	1	1	1
09/13/2021 20:00	1.4	11.6	2,222.3	0.9	6.70	1	1	1
09/13/2021 21:00	1.4	11.9	2,166.7	0.9	6.50	1	1	1
09/13/2021 22:00	1.4	12.2	2,106.5	0.9	6.30	1	1	1
09/13/2021 23:00	1.3	12.7	1,990.8	0.9	6.00	1	1	1
Average/Sum#:	1.1	12.7	1,936.6	0.8	131.00 #	24 #	24 #	16 #
Minimum:	0.6	11.4	1,347.6	0.5	2.70	1	1	0
Maximum:	1.4	14.0	2,248.1	0.9	6.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/14/2021 00:00	1.3	12.8	1,965.4	0.9	5.90	1	1	1
09/14/2021 01:00	0.9	13.9	1,588.9	0.8	4.80	1	1	0
09/14/2021 02:00	0.9	13.9	1,566.1	0.8	4.70	1	1	0
09/14/2021 03:00	0.9	13.9	1,565.7	0.8	4.70	1	1	0
09/14/2021 04:00	0.9	13.9	1,509.7	0.8	4.50	1	1	0
09/14/2021 05:00	1.3	12.5	2,022.2	0.9	6.10	1	1	1
09/14/2021 06:00	1.3	12.6	2,022.1	0.9	6.10	1	1	1
09/14/2021 07:00	0.9	13.9	1,665.4	0.8	5.00	1	1	0
09/14/2021 08:00	0.9	13.9	1,523.2	0.8	4.60	1	1	0
09/14/2021 09:00	0.9	13.9	1,489.7	0.8	4.50	1	1	0
09/14/2021 10:00	0.9	13.9	1,664.4	0.8	5.00	1	1	0
09/14/2021 11:00	0.7	13.9	1,712.1	0.6	3.40	1	1	0
09/14/2021 12:00	0.7	13.9	1,557.2	0.6	3.10	1	1	1
09/14/2021 13:00	1.3	12.5	2,045.9	0.9	6.10	1	1	1
09/14/2021 14:00	1.4	12.0	2,114.7	0.9	6.30	1	1	1
09/14/2021 15:00	0.9	13.8	1,698.1	0.7	5.10	1	1	0
09/14/2021 16:00	0.9	13.8	1,625.0	0.7	4.90	1	1	1
09/14/2021 17:00	1.3	12.1	2,108.7	0.9	6.30	1	1	1
09/14/2021 18:00	1.4	11.5	2,212.1	0.9	6.60	1	1	1
09/14/2021 19:00	1.3	12.2	2,057.0	0.9	6.20	1	1	1
09/14/2021 20:00	0.9	13.8	1,711.4	0.7	5.10	1	1	0
09/14/2021 21:00	0.9	13.7	1,772.0	0.7	5.30	1	1	1
09/14/2021 22:00	1.3	12.5	2,062.5	0.9	6.20	1	1	1
09/14/2021 23:00	1.3	12.7	1,979.7	0.9	5.90	1	1	1
Average/Sum#:	1.1	13.2	1,801.6	0.8	126.40 #	24 #	24 #	13 #
Minimum:	0.7	11.5	1,489.7	0.6	3.10	1	1	0
Maximum:	1.4	13.9	2,212.1	0.9	6.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/15/2021 00:00	1.0	13.9	1,558.6	0.8	4.70	1	1	0
09/15/2021 01:00	1.0	13.8	1,587.9	0.8	4.80	1	1	1
09/15/2021 02:00	1.3	12.6	2,035.2	0.9	6.10	1	1	1
09/15/2021 03:00	1.3	12.8	1,989.8	0.9	6.00	1	1	1
09/15/2021 04:00	0.9	13.8	1,697.9	0.7	5.10	1	1	1
09/15/2021 05:00	0.7	13.7	1,608.1	0.6	3.20	1	1	1
09/15/2021 06:00	1.0	12.8	2,006.8	0.7	6.00	1	1	1
09/15/2021 07:00	1.2	12.9	1,957.5	0.9	5.90	1	1	1
09/15/2021 08:00	0.9	13.9	1,483.0	0.8	4.40	1	1	0
09/15/2021 09:00	0.9	14.0	1,420.2	0.8	4.30	1	1	0
09/15/2021 10:00	0.8	14.0	1,552.3	0.7	4.70	1	1	0
09/15/2021 11:00	0.9	13.9	1,619.9	0.8	4.90	1	1	0
09/15/2021 12:00	0.8	13.9	1,547.8	0.7	3.10	1	1	1
09/15/2021 13:00	1.2	12.3	2,080.9	0.8	6.20	1	1	1
09/15/2021 14:00	1.4	12.1	2,096.8	0.9	6.30	1	1	1
09/15/2021 15:00	1.0	13.8	1,576.0	0.8	4.70	1	1	1
09/15/2021 16:00	0.8	13.8	1,587.1	0.7	3.20	1	1	1
09/15/2021 17:00	1.3	12.2	2,081.4	0.9	6.20	1	1	1
09/15/2021 18:00	1.4	12.1	2,092.8	0.9	6.30	1	1	1
09/15/2021 19:00	1.3	12.6	1,995.0	0.9	6.00	1	1	1
09/15/2021 20:00	1.1	13.6	1,706.4	0.9	5.10	1	1	1
09/15/2021 21:00	0.8	13.9	1,628.6	0.7	3.30	1	1	1
09/15/2021 22:00	1.1	12.9	1,959.9	0.8	5.90	1	1	1
09/15/2021 23:00	1.2	13.0	1,951.9	0.9	5.90	1	1	1
Average/Sum#:	1.1	13.3	1,784.2	0.8	122.30 #	24 #	24 #	19 #
Minimum:	0.7	12.1	1,420.2	0.6	3.10	1	1	0
Maximum:	1.4	14.0	2,096.8	0.9	6.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/16/2021 00:00	1.0	13.5	1,720.7	0.8	5.20	1	1	1
09/16/2021 01:00	0.7	13.9	1,542.6	0.6	3.10	1	1	0
09/16/2021 02:00	0.6	13.8	1,778.0	0.5	3.60	1	1	0
09/16/2021 03:00	0.6	13.8	1,780.3	0.5	3.60	1	1	0
09/16/2021 04:00	0.6	14.0	1,407.5	0.5	2.80	1	1	0
09/16/2021 05:00	0.9	14.0	1,331.1	0.8	4.00	1	1	0
09/16/2021 06:00	0.8	13.9	1,385.8	0.7	2.80	1	1	0
09/16/2021 07:00	0.9	13.9	1,359.7	0.8	4.10	1	1	0
09/16/2021 08:00	0.9	13.9	1,364.4	0.8	4.10	1	1	0
09/16/2021 09:00	1.0	13.9	1,368.0	0.8	4.10	1	1	0
09/16/2021 10:00	1.0	14.0	1,375.5	0.9	4.10	1	1	0
09/16/2021 11:00	1.0	14.0	1,376.0	0.9	4.10	1	1	0
09/16/2021 12:00	1.0	13.9	1,607.3	0.8	4.80	1	1	0
09/16/2021 13:00	0.8	13.9	1,543.6	0.7	3.10	1	1	0
09/16/2021 14:00	0.8	13.9	1,709.6	0.7	3.40	1	1	0
09/16/2021 15:00	0.8	13.9	1,651.1	0.7	3.30	1	1	0
09/16/2021 16:00	0.8	13.9	1,547.5	0.7	3.10	1	1	1
09/16/2021 17:00	1.2	12.1	2,136.0	0.8	6.40	1	1	1
09/16/2021 18:00	1.4	11.9	2,149.0	0.9	6.40	1	1	1
09/16/2021 19:00	1.3	12.6	1,998.5	0.9	6.00	1	1	1
09/16/2021 20:00	1.0	13.6	1,730.7	0.8	5.20	1	1	1
09/16/2021 21:00	0.9	13.7	1,691.7	0.7	5.10	1	1	1
09/16/2021 22:00	1.2	12.5	2,056.9	0.8	6.20	1	1	1
09/16/2021 23:00	1.3	12.8	1,977.6	0.9	5.90	1	1	1
Average/Sum#:	0.9	13.6	1,649.5	0.8	104.50 #	24 #	24 #	9 #
Minimum:	0.6	11.9	1,331.1	0.5	2.80	1	1	0
Maximum:	1.4	14.0	2,149.0	0.9	6.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/17/2021 00:00	1.2	12.9	1,950.3	0.9	5.90	1	1	1
09/17/2021 01:00	0.9	13.7	1,501.4	0.7	4.50	1	1	1
09/17/2021 02:00	0.8	13.9	1,529.8	0.7	3.10	1	1	0
09/17/2021 03:00	0.8	13.9	1,529.3	0.7	3.10	1	1	0
09/17/2021 04:00	0.8	13.9	1,510.5	0.7	3.00	1	1	0
09/17/2021 05:00	0.8	13.9	1,541.5	0.7	3.10	1	1	0
09/17/2021 06:00	0.8	13.9	1,479.7	0.7	3.00	1	1	0
09/17/2021 07:00	0.9	13.9	1,439.4	0.8	4.30	1	1	0
09/17/2021 08:00	1.0	13.9	1,355.1	0.8	4.10	1	1	0
09/17/2021 09:00	1.0	14.0	1,358.1	0.9	4.10	1	1	0
09/17/2021 10:00	0.9	14.0	1,359.8	0.8	4.10	1	1	0
09/17/2021 11:00	0.9	14.0	1,368.7	0.8	4.10	1	1	0
09/17/2021 12:00	0.8	14.0	1,368.2	0.7	4.10	1	1	0
09/17/2021 13:00	0.8	13.9	1,607.2	0.7	3.20	1	1	0
09/17/2021 14:00	0.6	13.9	1,491.4	0.5	3.00	1	1	0
09/17/2021 15:00	0.7	13.9	1,504.1	0.6	3.00	1	1	0
09/17/2021 16:00	0.8	13.8	1,606.3	0.7	3.20	1	1	1
09/17/2021 17:00	1.3	12.1	2,109.7	0.9	6.30	1	1	1
09/17/2021 18:00	1.4	11.8	2,191.9	0.9	6.60	1	1	1
09/17/2021 19:00	1.3	12.5	2,036.8	0.9	6.10	1	1	1
09/17/2021 20:00	1.2	12.9	1,957.5	0.9	5.90	1	1	1
09/17/2021 21:00	1.3	12.8	1,977.9	0.9	5.90	1	1	1
09/17/2021 22:00	1.2	12.8	1,973.1	0.9	5.90	1	1	1
09/17/2021 23:00	0.9	13.7	1,516.1	0.7	4.50	1	1	1
Average/Sum#:	1.0	13.5	1,636.0	0.8	104.10 #	24 #	24 #	10 #
Minimum:	0.6	11.8	1,355.1	0.5	3.00	1	1	0
Maximum:	1.4	14.0	2,191.9	0.9	6.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/18/2021 00:00	0.8	14.0	1,371.7	0.7	4.10	1	1	0
09/18/2021 01:00	0.9	14.0	1,347.8	0.8	4.00	1	1	0
09/18/2021 02:00	0.9	14.0	1,350.6	0.8	4.10	1	1	0
09/18/2021 03:00	0.9	14.0	1,356.0	0.8	4.10	1	1	0
09/18/2021 04:00	0.9	13.9	1,430.5	0.8	4.30	1	1	0
09/18/2021 05:00	0.9	13.9	1,380.1	0.8	4.10	1	1	0
09/18/2021 06:00	0.9	13.9	1,391.4	0.8	4.20	1	1	0
09/18/2021 07:00	0.9	13.9	1,368.4	0.8	4.10	1	1	0
09/18/2021 08:00	0.9	13.9	1,370.3	0.8	4.10	1	1	0
09/18/2021 09:00	1.0	13.9	1,371.9	0.8	4.10	1	1	0
09/18/2021 10:00	1.0	14.0	1,376.0	0.9	4.10	1	1	0
09/18/2021 11:00	0.9	14.0	1,374.9	0.8	4.10	1	1	0
09/18/2021 12:00	0.9	14.0	1,371.2	0.8	4.10	1	1	0
09/18/2021 13:00	0.9	14.0	1,369.9	0.8	4.10	1	1	0
09/18/2021 14:00	0.9	14.0	1,366.4	0.8	4.10	1	1	0
09/18/2021 15:00	0.9	14.0	1,363.9	0.8	4.10	1	1	0
09/18/2021 16:00	0.9	14.0	1,402.4	0.8	4.20	1	1	0
09/18/2021 17:00	0.8	14.0	1,414.2	0.7	4.20	1	1	0
09/18/2021 18:00	0.8	14.0	1,397.7	0.7	4.20	1	1	0
09/18/2021 19:00	0.9	14.0	1,364.0	0.8	4.10	1	1	0
09/18/2021 20:00	0.8	13.9	1,566.9	0.7	3.10	1	1	0
09/18/2021 21:00	0.7	13.9	1,489.9	0.6	3.00	1	1	0
09/18/2021 22:00	0.7	13.9	1,526.8	0.6	3.10	1	1	0
09/18/2021 23:00	0.8	13.9	1,355.6	0.7	2.70	1	1	0
Average/Sum#:	0.9	14.0	1,394.9	0.8	94.40 #	24 #	24 #	0 #
Minimum:	0.7	13.9	1,347.8	0.6	2.70	1	1	0
Maximum:	1.0	14.0	1,566.9	0.9	4.30	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/19/2021 00:00	0.9	13.9	1,357.3	0.8	4.10	1	1	0
09/19/2021 01:00	0.9	13.9	1,356.0	0.8	4.10	1	1	0
09/19/2021 02:00	0.9	13.9	1,353.3	0.8	4.10	1	1	0
09/19/2021 03:00	0.9	13.9	1,358.9	0.8	4.10	1	1	0
09/19/2021 04:00	0.9	13.9	1,409.4	0.8	4.20	1	1	0
09/19/2021 05:00	0.9	13.9	1,420.9	0.8	4.30	1	1	0
09/19/2021 06:00	0.9	13.9	1,358.3	0.8	4.10	1	1	0
09/19/2021 07:00	1.0	13.9	1,359.8	0.8	4.10	1	1	0
09/19/2021 08:00	1.0	13.9	1,356.8	0.8	4.10	1	1	0
09/19/2021 09:00	1.0	13.9	1,360.6	0.8	4.10	1	1	0
09/19/2021 10:00	0.9	14.0	1,387.7	0.8	4.20	1	1	0
09/19/2021 11:00	0.9	14.0	1,372.1	0.8	4.10	1	1	0
09/19/2021 12:00	0.8	14.0	1,372.9	0.7	4.10	1	1	0
09/19/2021 13:00	0.8	14.0	1,369.1	0.7	4.10	1	1	0
09/19/2021 14:00	0.7	14.0	1,400.8	0.6	2.80	1	1	0
09/19/2021 15:00	0.7	14.0	1,369.5	0.6	2.70	1	1	0
09/19/2021 16:00	0.8	14.0	1,551.9	0.7	4.70	1	1	0
09/19/2021 17:00	0.8	13.9	1,729.4	0.7	3.50	1	1	0
09/19/2021 18:00	0.6	13.9	1,563.0	0.5	3.10	1	1	0
09/19/2021 19:00	0.6	14.0	1,424.6	0.5	2.80	1	1	0
09/19/2021 20:00	0.6	14.0	1,559.1	0.5	3.10	1	1	0
09/19/2021 21:00	0.6	14.0	1,400.9	0.5	2.80	1	1	0
09/19/2021 22:00	0.7	14.0	1,364.0	0.6	2.70	1	1	0
09/19/2021 23:00	0.7	14.0	1,363.1	0.6	2.70	1	1	0
Average/Sum#:	0.8	14.0	1,413.3	0.7	88.70 #	24 #	24 #	0 #
Minimum:	0.6	13.9	1,353.3	0.5	2.70	1	1	0
Maximum:	1.0	14.0	1,729.4	0.8	4.70	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/20/2021 00:00	0.7	14.0	1,361.9	0.6	2.70	1	1	0
09/20/2021 01:00	0.8	13.9	1,520.4	0.7	3.00	1	1	0
09/20/2021 02:00	0.8	13.9	1,724.2	0.7	3.40	1	1	0
09/20/2021 03:00	0.5	14.0	1,304.8	0.4	2.60	1	1	0
09/20/2021 04:00	0.8	14.0	1,469.6	0.7	4.40	1	1	0
09/20/2021 05:00	1.0	13.1	1,899.9	0.8	5.70	1	1	1
09/20/2021 06:00	1.2	12.8	2,007.4	0.9	6.00	1	1	1
09/20/2021 07:00	0.9	13.8	1,514.1	0.7	4.50	1	1	1
09/20/2021 08:00	0.7	14.1	1,307.3	0.6	2.60	1	1	0
09/20/2021 09:00	0.6	14.1	1,310.2	0.5	2.60	1	1	0
09/20/2021 10:00	0.6	14.1	1,312.2	0.5	2.60	1	1	0
09/20/2021 11:00	0.7	13.9	1,605.4	0.6	3.20	1	1	1
09/20/2021 12:00	1.2	12.7	2,034.5	0.9	6.10	1	1	1
09/20/2021 13:00	1.3	12.7	2,034.2	0.9	6.10	1	1	1
09/20/2021 14:00	0.8	13.7	1,596.8	0.7	3.20	1	1	1
09/20/2021 15:00	0.6	13.9	1,562.1	0.5	3.10	1	1	1
09/20/2021 16:00	1.2	12.4	2,103.8	0.8	6.30	1	1	1
09/20/2021 17:00	1.3	11.5	2,286.4	0.8	6.90	1	1	1
09/20/2021 18:00	1.4	11.5	2,280.4	0.9	6.80	1	1	1
09/20/2021 19:00	1.4	11.7	2,243.1	0.9	6.70	1	1	1
09/20/2021 20:00	1.3	11.9	2,203.6	0.9	6.60	1	1	1
09/20/2021 21:00	1.3	12.2	2,143.5	0.9	6.40	1	1	1
09/20/2021 22:00	1.3	12.9	1,994.7	1.0	8.00	1	1	1
09/20/2021 23:00	1.2	13.0	1,945.9	0.9	5.80	1	1	1
Average/Sum#:	1.0	13.2	1,781.9	0.7	115.30 #	24 #	24 #	16 #
Minimum:	0.5	11.5	1,304.8	0.4	2.60	1	1	0
Maximum:	1.4	14.1	2,286.4	1.0	8.00	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/21/2021 00:00	0.9	13.9	1,703.3	0.8	5.10	1	1	0
09/21/2021 01:00	0.9	13.9	1,604.3	0.8	4.80	1	1	1
09/21/2021 02:00	1.1	13.1	1,966.7	0.8	5.90	1	1	1
09/21/2021 03:00	1.2	13.1	1,958.2	0.9	5.90	1	1	1
09/21/2021 04:00	1.2	13.1	1,954.7	0.9	5.90	1	1	1
09/21/2021 05:00	1.2	13.0	1,969.9	0.9	5.90	1	1	1
09/21/2021 06:00	1.3	12.5	2,101.0	0.9	6.30	1	1	1
09/21/2021 07:00	1.2	13.1	1,949.9	0.9	5.80	1	1	1
09/21/2021 08:00	0.9	13.9	1,493.1	0.8	4.50	1	1	0
09/21/2021 09:00	0.6	14.0	1,549.6	0.5	3.10	1	1	0
09/21/2021 10:00	0.7	13.9	1,682.3	0.6	3.40	1	1	0
09/21/2021 11:00	0.6	14.0	1,653.4	0.5	3.30	1	1	1
09/21/2021 12:00	1.2	12.5	2,070.7	0.8	6.20	1	1	1
09/21/2021 13:00	1.3	11.8	2,198.1	0.8	6.60	1	1	1
09/21/2021 14:00	1.4	11.8	2,201.4	0.9	6.60	1	1	1
09/21/2021 15:00	1.3	11.7	2,212.8	0.8	6.60	1	1	1
09/21/2021 16:00	1.3	11.6	2,228.5	0.8	6.70	1	1	1
09/21/2021 17:00	1.3	11.6	2,235.1	0.8	6.70	1	1	1
09/21/2021 18:00	1.3	11.5	2,251.1	0.8	6.80	1	1	1
09/21/2021 19:00	1.3	11.7	2,218.9	0.8	6.70	1	1	1
09/21/2021 20:00	1.4	11.7	2,237.7	0.9	6.70	1	1	1
09/21/2021 21:00	1.4	11.9	2,184.0	0.9	6.60	1	1	1
09/21/2021 22:00	1.3	12.2	2,143.1	0.9	6.40	1	1	1
09/21/2021 23:00	1.3	12.5	2,064.6	0.9	6.20	1	1	1
Average/Sum#:	1.2	12.7	1,993.0	0.8	138.70 #	24 #	24 #	20 #
Minimum:	0.6	11.5	1,493.1	0.5	3.10	1	1	0
Maximum:	1.4	14.0	2,251.1	0.9	6.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/22/2021 00:00	0.9	13.8	1,648.7	0.7	4.90	1	1	1
09/22/2021 01:00	0.9	13.8	1,682.3	0.7	5.00	1	1	1
09/22/2021 02:00	1.1	13.0	1,957.6	0.8	5.90	1	1	1
09/22/2021 03:00	1.2	13.1	1,955.1	0.9	5.90	1	1	1
09/22/2021 04:00	1.3	12.7	2,066.4	0.9	6.20	1	1	1
09/22/2021 05:00	1.3	12.0	2,188.9	0.9	6.60	1	1	1
09/22/2021 06:00	1.3	12.3	2,111.4	0.9	6.30	1	1	1
09/22/2021 07:00	1.2	13.0	1,948.2	0.9	5.80	1	1	1
09/22/2021 08:00	0.9	13.9	1,657.2	0.8	5.00	1	1	0
09/22/2021 09:00	0.8	13.8	1,755.2	0.7	3.50	1	1	0
09/22/2021 10:00	1.2	12.9	1,972.5	0.9	5.90	1	1	1
09/22/2021 11:00	1.3	12.3	2,083.3	0.9	6.20	1	1	1
09/22/2021 12:00	1.0	13.9	1,639.6	0.8	4.90	1	1	0
09/22/2021 13:00	0.8	13.8	1,735.7	0.7	3.50	1	1	1
09/22/2021 14:00	1.3	12.2	2,113.9	0.9	6.30	1	1	1
09/22/2021 15:00	1.4	11.6	2,224.9	0.9	6.70	1	1	1
09/22/2021 16:00	1.4	11.5	2,252.4	0.9	6.80	1	1	1
09/22/2021 17:00	1.4	11.5	2,241.3	0.9	6.70	1	1	1
09/22/2021 18:00	1.4	11.6	2,247.3	0.9	6.70	1	1	1
09/22/2021 19:00	1.4	12.1	2,112.8	0.9	6.30	1	1	1
09/22/2021 20:00	0.9	13.9	1,674.1	0.8	5.00	1	1	0
09/22/2021 21:00	0.8	13.7	1,798.4	0.7	3.60	1	1	1
09/22/2021 22:00	1.2	12.6	2,042.1	0.9	6.10	1	1	1
09/22/2021 23:00	1.4	12.3	2,097.0	1.0	8.40	1	1	1
Average/Sum#:	1.2	12.8	1,966.9	0.8	138.20 #	24 #	24 #	20 #
Minimum:	0.8	11.5	1,639.6	0.7	3.50	1	1	0
Maximum:	1.4	13.9	2,252.4	1.0	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/23/2021 00:00	1.3	12.8	1,975.9	0.9	5.90	1	1	1
09/23/2021 01:00	0.9	13.9	1,584.6	0.8	4.80	1	1	0
09/23/2021 02:00	0.7	14.0	1,549.0	0.6	3.10	1	1	0
09/23/2021 03:00	0.4	14.0	1,658.9	0.3	1.70	1	1	0
09/23/2021 04:00	0.6	13.9	1,608.1	0.5	3.20	1	1	1
09/23/2021 05:00	1.2	12.4	2,061.1	0.8	6.20	1	1	1
09/23/2021 06:00	1.3	12.6	2,023.1	0.9	6.10	1	1	1
09/23/2021 07:00	0.8	13.9	1,684.9	0.7	3.40	1	1	0
09/23/2021 08:00	0.7	14.0	1,419.6	0.6	2.80	1	1	0
09/23/2021 09:00	0.8	13.8	1,783.4	0.7	3.60	1	1	0
09/23/2021 10:00	0.7	13.7	1,784.9	0.6	3.60	1	1	0
09/23/2021 11:00	0.8	13.7	1,787.1	0.7	3.60	1	1	0
09/23/2021 12:00	0.8	13.7	1,781.7	0.7	3.60	1	1	0
09/23/2021 13:00	0.8	13.7	1,779.9	0.7	3.60	1	1	0
09/23/2021 14:00	0.7	13.7	1,779.4	0.6	3.60	1	1	0
09/23/2021 15:00	0.7	13.7	1,779.1	0.6	3.60	1	1	0
09/23/2021 16:00	0.7	13.7	1,778.1	0.6	3.60	1	1	0
09/23/2021 17:00	0.7	13.7	1,781.0	0.6	3.60	1	1	0
09/23/2021 18:00	0.7	13.7	1,788.5	0.6	3.60	1	1	0
09/23/2021 19:00	0.7	13.7	1,794.0	0.6	3.60	1	1	0
09/23/2021 20:00	0.7	13.7	1,801.3	0.6	3.60	1	1	0
09/23/2021 21:00	0.8	13.7	1,801.3	0.7	3.60	1	1	0
09/23/2021 22:00	0.8	13.7	1,799.1	0.7	3.60	1	1	0
09/23/2021 23:00	0.7	13.7	1,796.4	0.6	3.60	1	1	0
Average/Sum#:	0.8	13.6	1,765.9	0.7	91.20 #	24 #	24 #	4 #
Minimum:	0.4	12.4	1,419.6	0.3	1.70	1	1	0
Maximum:	1.3	14.0	2,061.1	0.9	6.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/24/2021 00:00	0.7	13.7	1,797.5	0.6	3.60	1	1	0
09/24/2021 01:00	0.7	13.7	1,797.8	0.6	3.60	1	1	0
09/24/2021 02:00	0.7	13.7	1,798.8	0.6	3.60	1	1	0
09/24/2021 03:00	0.7	13.7	1,799.7	0.6	3.60	1	1	0
09/24/2021 04:00	0.7	13.7	1,803.6	0.6	3.60	1	1	0
09/24/2021 05:00	0.7	13.7	1,799.4	0.6	3.60	1	1	0
09/24/2021 06:00	0.7	13.7	1,802.9	0.6	3.60	1	1	0
09/24/2021 07:00	0.8	13.7	1,805.4	0.7	3.60	1	1	0
09/24/2021 08:00	0.8	13.7	1,802.4	0.7	3.60	1	1	0
09/24/2021 09:00	0.8	13.9	1,677.0	0.7	3.40	1	1	0
09/24/2021 10:00	0.7	13.9	1,557.3	0.6	3.10	1	1	0
09/24/2021 11:00	0.7	14.0	1,630.3	0.6	3.30	1	1	0
09/24/2021 12:00	0.7	13.9	1,630.4	0.6	3.30	1	1	0
09/24/2021 13:00	0.8	13.9	1,683.8	0.7	3.40	1	1	0
09/24/2021 14:00	0.7	13.9	1,722.1	0.6	3.40	1	1	0
09/24/2021 15:00	0.8	13.8	1,713.7	0.7	3.40	1	1	0
09/24/2021 16:00	0.8	13.9	1,698.6	0.7	3.40	1	1	0
09/24/2021 17:00	0.9	13.7	1,741.7	0.7	5.20	1	1	0
09/24/2021 18:00	0.8	13.9	1,678.0	0.7	3.40	1	1	0
09/24/2021 19:00	0.7	13.9	1,712.1	0.6	3.40	1	1	0
09/24/2021 20:00	0.9	13.9	1,655.7	0.8	5.00	1	1	0
09/24/2021 21:00	1.0	13.9	1,633.4	0.8	4.90	1	1	0
09/24/2021 22:00	1.1	13.8	1,669.3	0.9	5.00	1	1	0
09/24/2021 23:00	1.1	13.9	1,665.3	0.9	5.00	1	1	0
Average/Sum#:	0.8	13.8	1,719.8	0.7	91.00 #	24 #	24 #	0 #
Minimum:	0.7	13.7	1,557.3	0.6	3.10	1	1	0
Maximum:	1.1	14.0	1,805.4	0.9	5.20	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/25/2021 00:00	1.1	13.9	1,591.8	0.9	4.80	1	1	0
09/25/2021 01:00	1.1	13.8	1,658.5	0.9	5.00	1	1	0
09/25/2021 02:00	1.1	13.8	1,686.9	0.9	5.10	1	1	0
09/25/2021 03:00	1.0	13.8	1,685.7	0.8	5.10	1	1	0
09/25/2021 04:00	0.9	13.9	1,639.5	0.8	4.90	1	1	0
09/25/2021 05:00	0.8	13.9	1,620.9	0.7	3.20	1	1	0
09/25/2021 06:00	0.8	13.9	1,665.6	0.7	3.30	1	1	0
09/25/2021 07:00	0.9	13.9	1,660.0	0.8	5.00	1	1	0
09/25/2021 08:00	0.9	13.9	1,553.0	0.8	4.70	1	1	0
09/25/2021 09:00	0.9	14.0	1,356.2	0.8	4.10	1	1	0
09/25/2021 10:00	0.8	13.9	1,545.0	0.7	3.10	1	1	0
09/25/2021 11:00	0.7	13.9	1,675.0	0.6	3.40	1	1	0
09/25/2021 12:00	0.9	13.9	1,685.3	0.8	5.10	1	1	0
09/25/2021 13:00	0.9	13.9	1,672.1	0.8	5.00	1	1	0
09/25/2021 14:00	0.8	13.9	1,704.6	0.7	3.40	1	1	0
09/25/2021 15:00	0.8	13.8	1,701.0	0.7	3.40	1	1	0
09/25/2021 16:00	0.9	13.8	1,650.4	0.7	5.00	1	1	0
09/25/2021 17:00	0.8	14.0	1,344.2	0.7	4.00	1	1	0
09/25/2021 18:00	0.6	13.9	1,643.0	0.5	3.30	1	1	0
09/25/2021 19:00	0.8	13.9	1,701.4	0.7	3.40	1	1	0
09/25/2021 20:00	0.9	13.9	1,664.9	0.8	5.00	1	1	0
09/25/2021 21:00	0.8	13.9	1,575.6	0.7	3.20	1	1	0
09/25/2021 22:00	2.7	15.0	907.9	2.7	4.10	1	0	0
09/25/2021 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	1.0	13.9	1,590.8	0.8	96.60 #	23 #	22 #	0 #
Minimum:	0.6	13.8	907.9	0.5	3.10	0	0	0
Maximum:	2.7	15.0	1,704.6	2.7	5.10	1	1	0
%SI	4.17	4.17	4.17	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/26/2021 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/26/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/26/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/26/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/26/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/26/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/26/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/26/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/26/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/26/2021 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/26/2021 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/26/2021 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/26/2021 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/26/2021 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/26/2021 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/26/2021 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/26/2021 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/26/2021 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/26/2021 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/26/2021 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/26/2021 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/26/2021 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/26/2021 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/26/2021 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/27/2021 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/27/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/27/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/27/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/27/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/27/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/27/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/27/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/27/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/27/2021 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/27/2021 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/27/2021 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/27/2021 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/27/2021 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/27/2021 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/27/2021 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/27/2021 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/27/2021 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/27/2021 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/27/2021 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/27/2021 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/27/2021 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/27/2021 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/27/2021 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/28/2021 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/28/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/28/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/28/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/28/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/28/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/28/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/28/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/28/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/28/2021 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/28/2021 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/28/2021 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/28/2021 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/28/2021 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/28/2021 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/28/2021 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/28/2021 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/28/2021 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/28/2021 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/28/2021 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/28/2021 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/28/2021 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/28/2021 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/28/2021 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/29/2021 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/29/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/29/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/29/2021 03:00	31.6	17.9	263.9	62.1	42.28	1	0	0
09/29/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/29/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/29/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/29/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/29/2021 08:00	15.0	18.1	223.9	31.6	14.30	1	0	0
09/29/2021 09:00	15.3	15.4	866.8	16.4	52.00	1	0	0
09/29/2021 10:00	0.5	14.0	1,574.3	0.4	3.10	1	1	0
09/29/2021 11:00	0.0	0.0	1,499.4	0.0	0.00	1	1	0
09/29/2021 12:00	0.0	0.0	1,487.6	0.0	0.00	1	1	0
09/29/2021 13:00	0.8	14.0	1,660.5	0.7	5.00	1	1	0
09/29/2021 14:00	1.0	13.9	1,691.4	0.8	5.10	1	1	0
09/29/2021 15:00	1.0	13.9	1,700.0	0.8	5.10	1	1	0
09/29/2021 16:00	1.0	13.9	1,687.6	0.8	5.10	1	1	0
09/29/2021 17:00	0.9	14.0	1,449.6	0.8	4.30	1	1	0
09/29/2021 18:00	0.7	14.1	1,406.0	0.6	2.80	1	1	0
09/29/2021 19:00	1.0	13.9	1,663.2	0.8	5.00	1	1	0
09/29/2021 20:00	1.1	13.9	1,672.2	0.9	5.00	1	1	0
09/29/2021 21:00	1.1	13.9	1,642.1	0.9	4.90	1	1	0
09/29/2021 22:00	1.1	13.9	1,677.9	0.9	5.00	1	1	0
09/29/2021 23:00	1.0	13.9	1,549.8	0.8	4.60	1	1	0
Average/Sum#:	4.9	14.6	1,395.1	8.0	163.58 #	17 #	14 #	0 #
Minimum:	0.5	13.9	223.9	0.4	2.80	0	0	0
Maximum:	31.6	18.1	1,700.0	62.1	52.00	1	1	0
%SI	37.50	37.50	29.17	37.50	37.50	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/30/2021 00:00	0.7	14.0	1,520.5	0.6	3.00	1	1	0
09/30/2021 01:00	0.7	14.1	1,336.6	0.6	2.70	1	1	0
09/30/2021 02:00	0.8	14.1	1,310.2	0.7	3.90	1	1	0
09/30/2021 03:00	0.7	14.0	1,569.4	0.6	3.10	1	1	0
09/30/2021 04:00	0.6	14.0	1,630.0	0.5	3.30	1	1	0
09/30/2021 05:00	0.5	14.1	1,357.1	0.4	2.70	1	1	0
09/30/2021 06:00	0.8	14.0	1,460.2	0.7	4.40	1	1	0
09/30/2021 07:00	0.8	14.1	1,350.2	0.7	4.10	1	1	0
09/30/2021 08:00	0.8	14.1	1,348.2	0.7	4.00	1	1	0
09/30/2021 09:00	0.8	14.1	1,362.1	0.7	4.10	1	1	0
09/30/2021 10:00	0.7	14.1	1,366.0	0.6	2.70	1	1	0
09/30/2021 11:00	0.7	14.1	1,366.5	0.6	2.70	1	1	0
09/30/2021 12:00	0.6	14.1	1,367.6	0.5	2.70	1	1	0
09/30/2021 13:00	0.5	14.1	1,362.4	0.4	2.70	1	1	0
09/30/2021 14:00	0.5	14.1	1,386.1	0.4	2.80	1	1	1
09/30/2021 15:00	1.2	13.0	1,970.2	0.9	5.90	1	1	1
09/30/2021 16:00	1.3	12.7	2,026.7	0.9	6.10	1	1	1
09/30/2021 17:00	1.3	12.8	1,997.0	0.9	6.00	1	1	1
09/30/2021 18:00	1.2	13.0	1,967.0	0.9	5.90	1	1	1
09/30/2021 19:00	1.2	13.0	1,965.3	0.9	5.90	1	1	1
09/30/2021 20:00	1.2	13.0	1,950.1	0.9	5.90	1	1	1
09/30/2021 21:00	1.2	13.0	1,953.0	0.9	5.90	1	1	1
09/30/2021 22:00	1.2	13.2	1,921.7	0.9	5.80	1	1	1
09/30/2021 23:00	0.9	14.0	1,410.1	0.8	4.20	1	1	0
Average/Sum#:	0.9	13.7	1,593.9	0.7	100.50 #	24 #	24 #	9 #
Minimum:	0.5	12.7	1,310.2	0.4	2.70	1	1	0
Maximum:	1.3	14.1	2,026.7	0.9	6.10	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/01/2021 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2021 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2021 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2021 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2021 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2021 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2021 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2021 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2021 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2021 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2021 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2021 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2021 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2021 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2021 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/01/2021 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/02/2021 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2021 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2021 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2021 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2021 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2021 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2021 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2021 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2021 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2021 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2021 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2021 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2021 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2021 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2021 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/02/2021 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/03/2021 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/03/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/03/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/03/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/03/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/03/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/03/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/03/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/03/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/03/2021 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/03/2021 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/03/2021 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/03/2021 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/03/2021 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/03/2021 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/03/2021 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/03/2021 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/03/2021 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/03/2021 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/03/2021 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/03/2021 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/03/2021 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/03/2021 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/03/2021 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/04/2021 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2021 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2021 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2021 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2021 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2021 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2021 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2021 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2021 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2021 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2021 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2021 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2021 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2021 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2021 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2021 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/05/2021 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/05/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/05/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/05/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/05/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/05/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/05/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/05/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/05/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/05/2021 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/05/2021 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/05/2021 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/05/2021 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/05/2021 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/05/2021 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/05/2021 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/05/2021 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/05/2021 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/05/2021 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/05/2021 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/05/2021 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/05/2021 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/05/2021 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/05/2021 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/06/2021 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/06/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/06/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/06/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/06/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/06/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/06/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/06/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/06/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/06/2021 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/06/2021 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/06/2021 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/06/2021 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/06/2021 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/06/2021 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/06/2021 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/06/2021 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/06/2021 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/06/2021 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/06/2021 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/06/2021 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/06/2021 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/06/2021 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/06/2021 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/07/2021 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/07/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/07/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/07/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/07/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/07/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/07/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/07/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/07/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/07/2021 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/07/2021 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/07/2021 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/07/2021 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/07/2021 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/07/2021 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/07/2021 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/07/2021 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/07/2021 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/07/2021 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/07/2021 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/07/2021 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/07/2021 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/07/2021 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/07/2021 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/08/2021 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/08/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/08/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/08/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/08/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/08/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/08/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/08/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/08/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/08/2021 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/08/2021 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/08/2021 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/08/2021 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/08/2021 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/08/2021 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/08/2021 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/08/2021 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/08/2021 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/08/2021 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/08/2021 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/08/2021 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/08/2021 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/08/2021 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/08/2021 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/09/2021 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/09/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/09/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/09/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/09/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/09/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/09/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/09/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/09/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/09/2021 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/09/2021 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/09/2021 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/09/2021 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/09/2021 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/09/2021 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/09/2021 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/09/2021 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/09/2021 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/09/2021 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/09/2021 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/09/2021 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/09/2021 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/09/2021 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/09/2021 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/10/2021 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/10/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/10/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/10/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/10/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/10/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/10/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/10/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/10/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/10/2021 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/10/2021 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/10/2021 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/10/2021 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/10/2021 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/10/2021 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/10/2021 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/10/2021 16:00	15.7	18.1	174.5	33.1	7.46	1	0	0
07/10/2021 17:00	27.6	17.6	205.2	49.3	17.53	1	0	0
07/10/2021 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/10/2021 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/10/2021 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/10/2021 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/10/2021 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/10/2021 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	21.7	17.9	189.9	41.2	24.99 #	2 #	0 #	0 #
Minimum:	15.7	17.6	174.5	33.1	7.46	0	0	0
Maximum:	27.6	18.1	205.2	49.3	17.53	1	0	0
%SI	91.67	91.67	91.67	91.67	91.67	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/11/2021 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/11/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/11/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/11/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/11/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/11/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/11/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/11/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/11/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/11/2021 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/11/2021 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/11/2021 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/11/2021 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/11/2021 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/11/2021 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/11/2021 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/11/2021 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/11/2021 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/11/2021 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/11/2021 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/11/2021 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/11/2021 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/11/2021 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/11/2021 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/12/2021 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/12/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/12/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/12/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/12/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/12/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/12/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/12/2021 07:00	0.0	0.0	307.2	0.0	0.00	1	0	0
07/12/2021 08:00	0.0	0.0	373.7	0.0	0.00	1	0	0
07/12/2021 09:00	0.0	0.0	649.9	0.0	0.00	1	0	0
07/12/2021 10:00	0.6	13.9	1,339.1	0.5	2.70	1	1	0
07/12/2021 11:00	1.2	13.7	1,666.6	1.0	6.70	1	1	0
07/12/2021 12:00	1.3	13.6	1,721.4	1.1	6.90	1	1	0
07/12/2021 13:00	1.3	13.6	1,719.6	1.1	6.90	1	1	0
07/12/2021 14:00	1.2	13.6	1,715.2	1.0	6.90	1	1	0
07/12/2021 15:00	1.2	13.6	1,707.5	1.0	6.80	1	1	0
07/12/2021 16:00	1.0	13.8	1,546.3	0.8	4.60	1	1	0
07/12/2021 17:00	1.3	13.6	1,697.5	1.1	6.80	1	1	0
07/12/2021 18:00	1.2	13.6	1,692.4	1.0	6.80	1	1	0
07/12/2021 19:00	1.1	13.7	1,692.1	0.9	5.10	1	1	0
07/12/2021 20:00	1.2	13.6	1,716.2	1.0	6.90	1	1	0
07/12/2021 21:00	1.2	13.6	1,715.7	1.0	6.90	1	1	0
07/12/2021 22:00	1.1	13.7	1,684.2	0.9	5.10	1	1	0
07/12/2021 23:00	1.3	13.6	1,741.8	1.1	7.00	1	1	0
Average/Sum#:	1.2	13.7	1,452.1	1.0	86.10 #	17 #	14 #	0 #
Minimum:	0.6	13.6	307.2	0.5	2.70	0	0	0
Maximum:	1.3	13.9	1,741.8	1.1	7.00	1	1	0
%SI	41.67	41.67	29.17	41.67	41.67	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/13/2021 00:00	1.3	13.6	1,747.3	1.1	7.00	1	1	0
07/13/2021 01:00	1.3	13.6	1,751.2	1.1	7.00	1	1	0
07/13/2021 02:00	2.1	14.8	1,048.1	2.0	3.14	1	0	0
07/13/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/13/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/13/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/13/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/13/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/13/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/13/2021 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/13/2021 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/13/2021 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/13/2021 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/13/2021 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/13/2021 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/13/2021 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/13/2021 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/13/2021 17:00	21.5	17.7	326.6	39.6	30.05	1	0	0
07/13/2021 18:00	10.8	14.9	990.6	10.6	38.60	1	0	0
07/13/2021 19:00	1.1	13.7	1,674.6	0.9	5.00	1	1	0
07/13/2021 20:00	1.6	12.8	1,882.4	1.2	7.50	1	1	1
07/13/2021 21:00	1.3	13.5	1,539.9	1.0	6.20	1	1	1
07/13/2021 22:00	0.7	14.0	1,292.6	0.6	2.60	1	1	0
07/13/2021 23:00	1.2	13.8	1,692.2	1.0	6.80	1	1	0
Average/Sum#:	4.3	14.2	1,394.6	5.9	113.89 #	10 #	7 #	2 #
Minimum:	0.7	12.8	326.6	0.6	2.60	0	0	0
Maximum:	21.5	17.7	1,882.4	39.6	38.60	1	1	1
%SI	58.33	58.33	58.33	58.33	58.33	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/14/2021 00:00	1.0	13.9	1,549.0	0.8	4.60	1	1	0
07/14/2021 01:00	1.0	13.9	1,513.0	0.8	4.50	1	1	0
07/14/2021 02:00	1.0	13.9	1,523.5	0.8	4.60	1	1	0
07/14/2021 03:00	1.0	13.9	1,608.3	0.8	4.80	1	1	0
07/14/2021 04:00	0.9	13.9	1,484.0	0.8	4.50	1	1	0
07/14/2021 05:00	1.0	13.9	1,671.9	0.8	5.00	1	1	0
07/14/2021 06:00	1.0	13.9	1,601.0	0.8	4.80	1	1	0
07/14/2021 07:00	1.0	13.8	1,643.1	0.8	4.90	1	1	1
07/14/2021 08:00	1.6	12.7	1,971.0	1.2	7.90	1	1	1
07/14/2021 09:00	1.6	12.8	1,909.3	1.2	7.60	1	1	1
07/14/2021 10:00	1.1	13.9	1,625.4	0.9	4.90	1	1	0
07/14/2021 11:00	1.0	13.9	1,561.8	0.8	4.70	1	1	1
07/14/2021 12:00	1.5	12.6	1,971.1	1.1	7.90	1	1	1
07/14/2021 13:00	1.6	12.1	2,046.9	1.1	8.20	1	1	1
07/14/2021 14:00	1.6	12.1	2,041.2	1.1	8.20	1	1	1
07/14/2021 15:00	1.6	12.2	2,032.1	1.1	8.10	1	1	1
07/14/2021 16:00	1.6	12.1	2,034.4	1.1	8.10	1	1	1
07/14/2021 17:00	1.7	12.1	2,044.1	1.1	8.20	1	1	1
07/14/2021 18:00	1.7	12.2	2,039.3	1.2	8.20	1	1	1
07/14/2021 19:00	1.7	12.3	2,021.2	1.2	8.10	1	1	1
07/14/2021 20:00	1.7	12.3	2,015.5	1.2	8.10	1	1	1
07/14/2021 21:00	1.7	12.5	1,990.7	1.2	8.00	1	1	1
07/14/2021 22:00	1.7	12.5	1,992.9	1.2	8.00	1	1	1
07/14/2021 23:00	1.7	12.6	1,990.3	1.2	8.00	1	1	1
Average/Sum#:	1.4	13.0	1,828.4	1.0	159.90 #	24 #	24 #	16 #
Minimum:	0.9	12.1	1,484.0	0.8	4.50	1	1	0
Maximum:	1.7	13.9	2,046.9	1.2	8.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/15/2021 00:00	1.6	12.8	1,929.1	1.2	7.70	1	1	1
07/15/2021 01:00	1.0	13.9	1,534.2	0.8	4.60	1	1	0
07/15/2021 02:00	0.9	13.9	1,485.1	0.8	4.50	1	1	0
07/15/2021 03:00	0.9	13.9	1,466.4	0.8	4.40	1	1	0
07/15/2021 04:00	1.0	13.9	1,674.5	0.8	5.00	1	1	0
07/15/2021 05:00	1.6	13.0	1,913.8	1.2	7.70	1	1	1
07/15/2021 06:00	1.6	12.8	1,950.4	1.2	7.80	1	1	1
07/15/2021 07:00	0.9	13.9	1,607.5	0.8	4.80	1	1	1
07/15/2021 08:00	0.9	13.9	1,606.7	0.8	4.80	1	1	0
07/15/2021 09:00	0.9	13.9	1,535.6	0.8	4.60	1	1	0
07/15/2021 10:00	1.0	13.9	1,636.1	0.8	4.90	1	1	0
07/15/2021 11:00	1.0	14.0	1,533.8	0.9	4.60	1	1	1
07/15/2021 12:00	1.6	12.6	2,000.2	1.1	8.00	1	1	1
07/15/2021 13:00	1.7	12.3	2,048.0	1.2	8.20	1	1	1
07/15/2021 14:00	1.7	12.2	2,064.3	1.2	8.30	1	1	1
07/15/2021 15:00	1.7	12.2	2,065.4	1.2	8.30	1	1	1
07/15/2021 16:00	1.7	12.1	2,069.6	1.1	8.30	1	1	1
07/15/2021 17:00	1.8	12.2	2,071.0	1.2	8.30	1	1	1
07/15/2021 18:00	1.8	12.1	2,096.3	1.2	8.40	1	1	1
07/15/2021 19:00	1.8	12.0	2,101.8	1.2	8.40	1	1	1
07/15/2021 20:00	1.8	12.0	2,104.1	1.2	8.40	1	1	1
07/15/2021 21:00	1.7	12.3	2,058.4	1.2	8.20	1	1	1
07/15/2021 22:00	1.7	12.5	2,015.7	1.2	8.10	1	1	1
07/15/2021 23:00	1.7	12.5	2,027.7	1.2	8.10	1	1	1
Average/Sum#:	1.4	13.0	1,858.2	1.0	164.40 #	24 #	24 #	17 #
Minimum:	0.9	12.0	1,466.4	0.8	4.40	1	1	0
Maximum:	1.8	14.0	2,104.1	1.2	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/16/2021 00:00	1.7	12.6	2,030.5	1.2	8.10	1	1	1
07/16/2021 01:00	1.6	12.9	1,931.7	1.2	7.70	1	1	1
07/16/2021 02:00	1.0	13.9	1,601.5	0.8	4.80	1	1	0
07/16/2021 03:00	0.9	13.9	1,447.7	0.8	4.30	1	1	0
07/16/2021 04:00	1.0	13.9	1,595.9	0.8	4.80	1	1	0
07/16/2021 05:00	1.2	13.5	1,777.5	1.0	7.10	1	1	1
07/16/2021 06:00	1.4	13.3	1,839.7	1.1	7.40	1	1	1
07/16/2021 07:00	1.0	13.9	1,650.3	0.8	5.00	1	1	0
07/16/2021 08:00	1.0	13.9	1,646.5	0.8	4.90	1	1	0
07/16/2021 09:00	1.0	13.9	1,615.7	0.8	4.80	1	1	0
07/16/2021 10:00	1.0	13.9	1,662.6	0.8	5.00	1	1	0
07/16/2021 11:00	1.0	13.9	1,491.7	0.8	4.50	1	1	0
07/16/2021 12:00	1.5	12.8	1,949.3	1.1	7.80	1	1	1
07/16/2021 13:00	1.6	12.7	1,941.8	1.2	7.80	1	1	1
07/16/2021 14:00	1.1	13.9	1,627.9	0.9	4.90	1	1	0
07/16/2021 15:00	1.1	13.9	1,565.9	0.9	4.70	1	1	1
07/16/2021 16:00	1.5	12.6	2,009.2	1.1	8.00	1	1	1
07/16/2021 17:00	1.8	12.0	2,122.2	1.2	8.50	1	1	1
07/16/2021 18:00	1.8	11.9	2,140.2	1.2	8.60	1	1	1
07/16/2021 19:00	1.8	11.9	2,141.8	1.2	8.60	1	1	1
07/16/2021 20:00	1.8	12.0	2,127.2	1.2	8.50	1	1	1
07/16/2021 21:00	1.7	12.1	2,089.3	1.1	8.40	1	1	1
07/16/2021 22:00	1.7	12.3	2,060.5	1.2	8.20	1	1	1
07/16/2021 23:00	1.7	12.4	2,028.6	1.2	8.10	1	1	1
Average/Sum#:	1.4	13.1	1,837.3	1.0	160.50 #	24 #	24 #	15 #
Minimum:	0.9	11.9	1,447.7	0.8	4.30	1	1	0
Maximum:	1.8	13.9	2,141.8	1.2	8.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/17/2021 00:00	1.6	12.9	1,901.5	1.2	7.60	1	1	1
07/17/2021 01:00	1.1	13.9	1,626.2	0.9	4.90	1	1	0
07/17/2021 02:00	0.8	14.0	1,296.9	0.7	3.90	1	1	0
07/17/2021 03:00	1.0	13.9	1,595.3	0.8	4.80	1	1	0
07/17/2021 04:00	1.3	13.4	1,785.2	1.0	7.10	1	1	1
07/17/2021 05:00	1.5	13.1	1,811.7	1.1	7.20	1	1	1
07/17/2021 06:00	1.1	13.9	1,606.1	0.9	4.80	1	1	0
07/17/2021 07:00	1.0	13.9	1,609.3	0.8	4.80	1	1	0
07/17/2021 08:00	1.0	14.0	1,571.3	0.9	4.70	1	1	0
07/17/2021 09:00	1.4	13.8	1,664.0	1.2	6.70	1	1	0
07/17/2021 10:00	1.2	13.9	1,587.3	1.0	6.30	1	1	0
07/17/2021 11:00	1.1	14.0	1,512.4	0.9	4.50	1	1	0
07/17/2021 12:00	1.1	13.9	1,599.6	0.9	4.80	1	1	1
07/17/2021 13:00	1.5	12.4	2,023.8	1.0	8.10	1	1	1
07/17/2021 14:00	1.8	12.0	2,111.8	1.2	8.40	1	1	1
07/17/2021 15:00	1.8	12.0	2,109.8	1.2	8.40	1	1	1
07/17/2021 16:00	1.8	11.9	2,119.4	1.2	8.50	1	1	1
07/17/2021 17:00	1.8	11.8	2,137.7	1.2	8.60	1	1	1
07/17/2021 18:00	1.8	11.8	2,141.2	1.2	8.60	1	1	1
07/17/2021 19:00	1.8	11.8	2,140.3	1.2	8.60	1	1	1
07/17/2021 20:00	1.7	11.9	2,123.7	1.1	8.50	1	1	1
07/17/2021 21:00	1.8	12.0	2,100.9	1.2	8.40	1	1	1
07/17/2021 22:00	1.7	12.3	2,052.5	1.2	8.20	1	1	1
07/17/2021 23:00	1.7	12.3	2,057.4	1.2	8.20	1	1	1
Average/Sum#:	1.4	13.0	1,845.2	1.1	164.60 #	24 #	24 #	15 #
Minimum:	0.8	11.8	1,296.9	0.7	3.90	1	1	0
Maximum:	1.8	14.0	2,141.2	1.2	8.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/18/2021 00:00	1.6	12.7	1,954.7	1.2	7.80	1	1	1
07/18/2021 01:00	1.1	13.9	1,627.7	0.9	4.90	1	1	0
07/18/2021 02:00	1.1	13.9	1,551.8	0.9	4.70	1	1	1
07/18/2021 03:00	1.6	12.7	1,978.9	1.2	7.90	1	1	1
07/18/2021 04:00	1.6	12.8	1,946.2	1.2	7.80	1	1	1
07/18/2021 05:00	1.1	13.9	1,635.2	0.9	4.90	1	1	0
07/18/2021 06:00	1.1	13.9	1,635.6	0.9	4.90	1	1	0
07/18/2021 07:00	1.1	13.9	1,629.0	0.9	4.90	1	1	0
07/18/2021 08:00	1.2	13.8	1,651.5	1.0	6.60	1	1	0
07/18/2021 09:00	1.2	13.9	1,620.6	1.0	6.50	1	1	0
07/18/2021 10:00	1.1	14.0	1,568.9	0.9	4.70	1	1	0
07/18/2021 11:00	1.1	13.9	1,682.7	0.9	5.00	1	1	1
07/18/2021 12:00	1.5	12.5	2,012.7	1.1	8.10	1	1	1
07/18/2021 13:00	1.8	11.9	2,130.5	1.2	8.50	1	1	1
07/18/2021 14:00	1.8	11.8	2,133.9	1.2	8.50	1	1	1
07/18/2021 15:00	1.8	11.8	2,132.0	1.2	8.50	1	1	1
07/18/2021 16:00	1.8	11.8	2,124.8	1.2	8.50	1	1	1
07/18/2021 17:00	1.8	11.8	2,123.5	1.2	8.50	1	1	1
07/18/2021 18:00	1.8	11.9	2,103.3	1.2	8.40	1	1	1
07/18/2021 19:00	1.7	12.1	2,087.1	1.1	8.30	1	1	1
07/18/2021 20:00	1.7	12.1	2,085.7	1.1	8.30	1	1	1
07/18/2021 21:00	1.8	12.0	2,119.4	1.2	8.50	1	1	1
07/18/2021 22:00	1.8	12.0	2,114.2	1.2	8.50	1	1	1
07/18/2021 23:00	1.7	12.0	2,113.9	1.1	8.50	1	1	1
Average/Sum#:	1.5	12.8	1,906.8	1.1	171.70 #	24 #	24 #	17 #
Minimum:	1.1	11.8	1,551.8	0.9	4.70	1	1	0
Maximum:	1.8	14.0	2,133.9	1.2	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/19/2021 00:00	1.7	12.1	2,099.9	1.1	8.40	1	1	1
07/19/2021 01:00	1.3	13.6	1,678.5	1.1	6.70	1	1	1
07/19/2021 02:00	1.1	13.9	1,655.1	0.9	5.00	1	1	0
07/19/2021 03:00	1.1	13.9	1,603.6	0.9	4.80	1	1	0
07/19/2021 04:00	1.1	13.9	1,672.3	0.9	5.00	1	1	1
07/19/2021 05:00	1.6	12.7	2,010.3	1.2	8.00	1	1	1
07/19/2021 06:00	1.6	12.6	2,020.6	1.1	8.10	1	1	1
07/19/2021 07:00	1.0	13.9	1,574.5	0.8	4.70	1	1	0
07/19/2021 08:00	1.1	13.9	1,595.5	0.9	4.80	1	1	0
07/19/2021 09:00	1.1	13.9	1,560.4	0.9	4.70	1	1	1
07/19/2021 10:00	1.6	12.6	2,007.6	1.1	8.00	1	1	1
07/19/2021 11:00	1.8	11.8	2,143.7	1.2	8.60	1	1	1
07/19/2021 12:00	1.8	11.8	2,141.9	1.2	8.60	1	1	1
07/19/2021 13:00	1.8	11.8	2,132.7	1.2	8.50	1	1	1
07/19/2021 14:00	1.8	11.8	2,137.1	1.2	8.50	1	1	1
07/19/2021 15:00	1.8	11.8	2,129.4	1.2	8.50	1	1	1
07/19/2021 16:00	1.8	11.8	2,138.3	1.2	8.60	1	1	1
07/19/2021 17:00	1.8	11.9	2,136.9	1.2	8.50	1	1	1
07/19/2021 18:00	1.7	11.9	2,140.8	1.1	8.60	1	1	1
07/19/2021 19:00	1.8	11.9	2,142.5	1.2	8.60	1	1	1
07/19/2021 20:00	1.8	11.9	2,140.0	1.2	8.60	1	1	1
07/19/2021 21:00	1.8	11.9	2,122.1	1.2	8.50	1	1	1
07/19/2021 22:00	1.7	12.4	2,038.8	1.2	8.20	1	1	1
07/19/2021 23:00	1.7	12.4	2,026.9	1.2	8.10	1	1	1
Average/Sum#:	1.6	12.6	1,960.4	1.1	178.60 #	24 #	24 #	20 #
Minimum:	1.0	11.8	1,560.4	0.8	4.70	1	1	0
Maximum:	1.8	13.9	2,143.7	1.2	8.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/20/2021 00:00	1.7	12.5	2,010.8	1.2	8.00	1	1	1
07/20/2021 01:00	1.2	13.8	1,650.2	1.0	6.60	1	1	1
07/20/2021 02:00	1.1	13.9	1,659.6	0.9	5.00	1	1	0
07/20/2021 03:00	1.1	13.9	1,661.2	0.9	5.00	1	1	1
07/20/2021 04:00	1.6	12.7	2,001.4	1.2	8.00	1	1	1
07/20/2021 05:00	1.7	12.3	2,100.5	1.2	8.40	1	1	1
07/20/2021 06:00	1.1	13.6	1,651.5	0.9	5.00	1	1	1
07/20/2021 07:00	1.0	13.9	1,618.2	0.8	4.90	1	1	0
07/20/2021 08:00	1.0	13.9	1,568.9	0.8	4.70	1	1	0
07/20/2021 09:00	1.1	13.9	1,603.5	0.9	4.80	1	1	0
07/20/2021 10:00	1.1	13.9	1,639.1	0.9	4.90	1	1	0
07/20/2021 11:00	1.1	13.9	1,568.7	0.9	4.70	1	1	0
07/20/2021 12:00	1.1	13.9	1,636.5	0.9	4.90	1	1	1
07/20/2021 13:00	1.5	12.7	1,978.7	1.1	7.90	1	1	1
07/20/2021 14:00	1.7	12.0	2,080.2	1.1	8.30	1	1	1
07/20/2021 15:00	1.8	11.9	2,104.9	1.2	8.40	1	1	1
07/20/2021 16:00	1.8	11.8	2,128.0	1.2	8.50	1	1	1
07/20/2021 17:00	1.8	11.8	2,130.3	1.2	8.50	1	1	1
07/20/2021 18:00	1.8	11.8	2,132.8	1.2	8.50	1	1	1
07/20/2021 19:00	1.8	11.8	2,129.0	1.2	8.50	1	1	1
07/20/2021 20:00	1.8	11.8	2,144.6	1.2	8.60	1	1	1
07/20/2021 21:00	1.8	12.0	2,103.2	1.2	8.40	1	1	1
07/20/2021 22:00	1.7	12.2	2,087.1	1.2	8.30	1	1	1
07/20/2021 23:00	1.7	12.2	2,071.3	1.2	8.30	1	1	1
Average/Sum#:	1.5	12.8	1,894.2	1.1	167.10 #	24 #	24 #	18 #
Minimum:	1.0	11.8	1,568.7	0.8	4.70	1	1	0
Maximum:	1.8	13.9	2,144.6	1.2	8.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/21/2021 00:00	1.6	12.7	1,969.4	1.2	7.90	1	1	1
07/21/2021 01:00	1.1	13.9	1,609.0	0.9	4.80	1	1	0
07/21/2021 02:00	1.1	13.9	1,635.6	0.9	4.90	1	1	0
07/21/2021 03:00	1.4	13.3	1,809.6	1.1	7.20	1	1	1
07/21/2021 04:00	1.6	12.6	1,986.5	1.1	7.90	1	1	1
07/21/2021 05:00	1.0	13.9	1,596.8	0.8	4.80	1	1	0
07/21/2021 06:00	1.0	13.9	1,556.5	0.8	4.70	1	1	1
07/21/2021 07:00	1.6	12.8	1,978.9	1.2	7.90	1	1	1
07/21/2021 08:00	1.6	12.9	1,918.1	1.2	7.70	1	1	1
07/21/2021 09:00	1.1	13.9	1,664.0	0.9	5.00	1	1	0
07/21/2021 10:00	1.1	13.9	1,577.3	0.9	4.70	1	1	1
07/21/2021 11:00	1.6	12.6	2,003.1	1.1	8.00	1	1	1
07/21/2021 12:00	1.7	12.3	2,052.4	1.2	8.20	1	1	1
07/21/2021 13:00	1.7	12.3	2,060.2	1.2	8.20	1	1	1
07/21/2021 14:00	1.7	12.1	2,070.6	1.1	8.30	1	1	1
07/21/2021 15:00	1.7	12.1	2,087.0	1.1	8.30	1	1	1
07/21/2021 16:00	1.8	12.0	2,085.8	1.2	8.30	1	1	1
07/21/2021 17:00	1.8	12.0	2,102.3	1.2	8.40	1	1	1
07/21/2021 18:00	1.8	11.8	2,131.7	1.2	8.50	1	1	1
07/21/2021 19:00	1.8	11.8	2,133.7	1.2	8.50	1	1	1
07/21/2021 20:00	1.8	11.8	2,141.9	1.2	8.60	1	1	1
07/21/2021 21:00	1.8	12.0	2,116.8	1.2	8.50	1	1	1
07/21/2021 22:00	1.7	12.1	2,093.2	1.1	8.40	1	1	1
07/21/2021 23:00	1.7	12.4	2,045.1	1.2	8.20	1	1	1
Average/Sum#:	1.5	12.7	1,934.4	1.1	175.90 #	24 #	24 #	20 #
Minimum:	1.0	11.8	1,556.5	0.8	4.70	1	1	0
Maximum:	1.8	13.9	2,141.9	1.2	8.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/22/2021 00:00	1.6	12.7	1,966.0	1.2	7.90	1	1	1
07/22/2021 01:00	1.2	13.9	1,636.5	1.0	6.50	1	1	0
07/22/2021 02:00	1.1	13.8	1,535.6	0.9	4.60	1	1	1
07/22/2021 03:00	1.6	12.7	1,977.8	1.2	7.90	1	1	1
07/22/2021 04:00	1.6	12.9	1,923.0	1.2	7.70	1	1	1
07/22/2021 05:00	1.0	13.9	1,577.5	0.8	4.70	1	1	0
07/22/2021 06:00	1.1	13.8	1,665.6	0.9	5.00	1	1	1
07/22/2021 07:00	1.6	12.7	1,979.6	1.2	7.90	1	1	1
07/22/2021 08:00	1.6	12.9	1,928.8	1.2	7.70	1	1	1
07/22/2021 09:00	1.2	13.8	1,590.3	1.0	6.40	1	1	1
07/22/2021 10:00	1.1	13.9	1,613.2	0.9	4.80	1	1	0
07/22/2021 11:00	1.2	13.7	1,730.7	1.0	6.90	1	1	1
07/22/2021 12:00	1.6	12.5	2,028.7	1.1	8.10	1	1	1
07/22/2021 13:00	1.8	12.0	2,128.6	1.2	8.50	1	1	1
07/22/2021 14:00	1.7	12.1	2,104.7	1.1	8.40	1	1	1
07/22/2021 15:00	1.7	12.1	2,100.7	1.1	8.40	1	1	1
07/22/2021 16:00	1.8	11.9	2,130.2	1.2	8.50	1	1	1
07/22/2021 17:00	1.8	12.0	2,115.4	1.2	8.50	1	1	1
07/22/2021 18:00	1.8	11.9	2,140.1	1.2	8.60	1	1	1
07/22/2021 19:00	1.8	11.9	2,133.9	1.2	8.50	1	1	1
07/22/2021 20:00	1.8	11.9	2,127.4	1.2	8.50	1	1	1
07/22/2021 21:00	1.7	12.2	2,065.2	1.2	8.30	1	1	1
07/22/2021 22:00	1.7	12.3	2,054.6	1.2	8.20	1	1	1
07/22/2021 23:00	1.7	12.5	1,986.9	1.2	7.90	1	1	1
Average/Sum#:	1.5	12.8	1,926.7	1.1	178.40 #	24 #	24 #	21 #
Minimum:	1.0	11.9	1,535.6	0.8	4.60	1	1	0
Maximum:	1.8	13.9	2,140.1	1.2	8.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/23/2021 00:00	1.1	13.9	1,649.8	0.9	4.90	1	1	0
07/23/2021 01:00	1.1	13.9	1,621.3	0.9	4.90	1	1	1
07/23/2021 02:00	1.6	12.8	1,980.5	1.2	7.90	1	1	1
07/23/2021 03:00	1.6	13.0	1,904.4	1.2	7.60	1	1	1
07/23/2021 04:00	1.1	13.9	1,655.8	0.9	5.00	1	1	0
07/23/2021 05:00	1.0	13.9	1,623.0	0.8	4.90	1	1	0
07/23/2021 06:00	1.0	13.9	1,634.9	0.8	4.90	1	1	0
07/23/2021 07:00	1.0	13.9	1,610.7	0.8	4.80	1	1	0
07/23/2021 08:00	1.0	13.9	1,648.3	0.8	4.90	1	1	0
07/23/2021 09:00	1.0	13.9	1,632.5	0.8	4.90	1	1	0
07/23/2021 10:00	1.1	13.9	1,672.3	0.9	5.00	1	1	0
07/23/2021 11:00	1.1	13.8	1,683.2	0.9	5.00	1	1	1
07/23/2021 12:00	1.6	12.3	2,057.3	1.1	8.20	1	1	1
07/23/2021 13:00	1.8	11.8	2,147.1	1.2	8.60	1	1	1
07/23/2021 14:00	1.8	11.8	2,144.2	1.2	8.60	1	1	1
07/23/2021 15:00	1.8	11.8	2,147.1	1.2	8.60	1	1	1
07/23/2021 16:00	1.7	11.8	2,147.4	1.1	8.60	1	1	1
07/23/2021 17:00	1.8	11.8	2,150.6	1.2	8.60	1	1	1
07/23/2021 18:00	1.8	11.8	2,149.6	1.2	8.60	1	1	1
07/23/2021 19:00	1.8	11.8	2,150.1	1.2	8.60	1	1	1
07/23/2021 20:00	1.8	11.9	2,142.8	1.2	8.60	1	1	1
07/23/2021 21:00	1.7	12.1	2,098.2	1.1	8.40	1	1	1
07/23/2021 22:00	1.7	12.4	2,041.0	1.2	8.20	1	1	1
07/23/2021 23:00	1.7	12.4	2,037.4	1.2	8.10	1	1	1
Average/Sum#:	1.4	12.9	1,905.4	1.0	166.40 #	24 #	24 #	16 #
Minimum:	1.0	11.8	1,610.7	0.8	4.80	1	1	0
Maximum:	1.8	13.9	2,150.6	1.2	8.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/24/2021 00:00	1.7	12.5	2,024.5	1.2	8.10	1	1	1
07/24/2021 01:00	1.6	12.9	1,904.0	1.2	7.60	1	1	1
07/24/2021 02:00	1.1	13.9	1,628.7	0.9	4.90	1	1	0
07/24/2021 03:00	1.2	13.9	1,695.4	1.0	6.80	1	1	1
07/24/2021 04:00	1.6	12.8	1,975.1	1.2	7.90	1	1	1
07/24/2021 05:00	1.6	13.0	1,916.7	1.2	7.70	1	1	1
07/24/2021 06:00	1.0	13.9	1,622.6	0.8	4.90	1	1	0
07/24/2021 07:00	1.0	13.9	1,582.5	0.8	4.70	1	1	0
07/24/2021 08:00	1.0	13.9	1,593.8	0.8	4.80	1	1	0
07/24/2021 09:00	1.0	13.9	1,622.7	0.8	4.90	1	1	0
07/24/2021 10:00	1.1	13.9	1,587.8	0.9	4.80	1	1	0
07/24/2021 11:00	1.2	13.9	1,613.8	1.0	6.50	1	1	1
07/24/2021 12:00	1.5	12.6	1,995.9	1.1	8.00	1	1	1
07/24/2021 13:00	1.7	12.1	2,074.0	1.1	8.30	1	1	1
07/24/2021 14:00	1.7	12.2	2,033.6	1.2	8.10	1	1	1
07/24/2021 15:00	1.2	13.9	1,648.3	1.0	6.60	1	1	0
07/24/2021 16:00	1.2	13.9	1,670.3	1.0	6.70	1	1	1
07/24/2021 17:00	1.5	12.5	1,995.3	1.1	8.00	1	1	1
07/24/2021 18:00	1.7	12.0	2,084.0	1.1	8.30	1	1	1
07/24/2021 19:00	1.8	11.8	2,137.7	1.2	8.60	1	1	1
07/24/2021 20:00	1.8	11.8	2,142.0	1.2	8.60	1	1	1
07/24/2021 21:00	1.8	11.9	2,113.9	1.2	8.50	1	1	1
07/24/2021 22:00	1.7	12.2	2,060.9	1.2	8.20	1	1	1
07/24/2021 23:00	1.7	12.2	2,073.4	1.2	8.30	1	1	1
Average/Sum#:	1.4	13.0	1,866.5	1.1	169.80 #	24 #	24 #	17 #
Minimum:	1.0	11.8	1,582.5	0.8	4.70	1	1	0
Maximum:	1.8	13.9	2,142.0	1.2	8.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/25/2021 00:00	1.6	12.8	1,921.7	1.2	7.70	1	1	1
07/25/2021 01:00	1.1	13.9	1,618.3	0.9	4.90	1	1	0
07/25/2021 02:00	1.0	13.9	1,569.9	0.8	4.70	1	1	1
07/25/2021 03:00	1.6	12.6	1,986.5	1.1	7.90	1	1	1
07/25/2021 04:00	1.6	12.9	1,906.0	1.2	7.60	1	1	1
07/25/2021 05:00	1.1	13.9	1,646.6	0.9	4.90	1	1	0
07/25/2021 06:00	1.1	13.9	1,635.3	0.9	4.90	1	1	0
07/25/2021 07:00	1.1	13.9	1,645.9	0.9	4.90	1	1	0
07/25/2021 08:00	1.1	13.9	1,658.8	0.9	5.00	1	1	0
07/25/2021 09:00	1.1	13.9	1,652.5	0.9	5.00	1	1	0
07/25/2021 10:00	1.1	13.9	1,651.5	0.9	5.00	1	1	0
07/25/2021 11:00	1.0	13.9	1,508.0	0.8	4.50	1	1	1
07/25/2021 12:00	1.6	12.4	2,032.8	1.1	8.10	1	1	1
07/25/2021 13:00	1.8	12.1	2,043.7	1.2	8.20	1	1	1
07/25/2021 14:00	1.2	13.8	1,646.0	1.0	6.60	1	1	0
07/25/2021 15:00	1.2	13.7	1,678.7	1.0	6.70	1	1	0
07/25/2021 16:00	1.2	13.7	1,679.0	1.0	6.70	1	1	1
07/25/2021 17:00	1.5	12.2	2,023.5	1.0	8.10	1	1	1
07/25/2021 18:00	1.8	11.8	2,113.1	1.2	8.50	1	1	1
07/25/2021 19:00	1.8	12.0	2,085.4	1.2	8.30	1	1	1
07/25/2021 20:00	1.7	12.2	2,052.2	1.2	8.20	1	1	1
07/25/2021 21:00	1.7	12.3	2,018.7	1.2	8.10	1	1	1
07/25/2021 22:00	1.7	12.4	2,007.0	1.2	8.00	1	1	1
07/25/2021 23:00	1.7	12.4	2,027.4	1.2	8.10	1	1	1
Average/Sum#:	1.4	13.1	1,825.4	1.0	160.60 #	24 #	24 #	15 #
Minimum:	1.0	11.8	1,508.0	0.8	4.50	1	1	0
Maximum:	1.8	13.9	2,113.1	1.2	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/26/2021 00:00	1.6	12.8	1,917.7	1.2	7.70	1	1	1
07/26/2021 01:00	1.1	13.9	1,586.0	0.9	4.80	1	1	0
07/26/2021 02:00	1.1	13.9	1,608.8	0.9	4.80	1	1	1
07/26/2021 03:00	1.6	12.7	1,972.0	1.2	7.90	1	1	1
07/26/2021 04:00	1.6	12.5	1,993.3	1.1	8.00	1	1	1
07/26/2021 05:00	1.1	13.8	1,659.8	0.9	5.00	1	1	1
07/26/2021 06:00	1.0	13.9	1,587.1	0.8	4.80	1	1	0
07/26/2021 07:00	1.0	13.9	1,504.7	0.8	4.50	1	1	0
07/26/2021 08:00	1.0	13.9	1,650.7	0.8	5.00	1	1	0
07/26/2021 09:00	1.0	13.9	1,533.4	0.8	4.60	1	1	0
07/26/2021 10:00	1.1	13.8	1,642.4	0.9	4.90	1	1	1
07/26/2021 11:00	1.6	12.6	2,000.8	1.1	8.00	1	1	1
07/26/2021 12:00	1.8	11.9	2,121.8	1.2	8.50	1	1	1
07/26/2021 13:00	1.8	12.0	2,119.2	1.2	8.50	1	1	1
07/26/2021 14:00	1.8	12.1	2,095.6	1.2	8.40	1	1	1
07/26/2021 15:00	1.8	11.8	2,140.9	1.2	8.60	1	1	1
07/26/2021 16:00	1.8	11.8	2,142.0	1.2	8.60	1	1	1
07/26/2021 17:00	1.8	11.9	2,124.4	1.2	8.50	1	1	1
07/26/2021 18:00	1.8	11.9	2,127.0	1.2	8.50	1	1	1
07/26/2021 19:00	1.8	11.9	2,126.3	1.2	8.50	1	1	1
07/26/2021 20:00	1.8	11.9	2,126.3	1.2	8.50	1	1	1
07/26/2021 21:00	1.8	11.9	2,152.1	1.2	8.60	1	1	1
07/26/2021 22:00	1.7	12.1	2,105.2	1.1	8.40	1	1	1
07/26/2021 23:00	1.6	12.6	1,976.6	1.1	7.90	1	1	1
Average/Sum#:	1.5	12.7	1,917.3	1.1	171.50 #	24 #	24 #	19 #
Minimum:	1.0	11.8	1,504.7	0.8	4.50	1	1	0
Maximum:	1.8	13.9	2,152.1	1.2	8.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/27/2021 00:00	1.2	13.9	1,591.4	1.0	6.40	1	1	0
07/27/2021 01:00	1.2	13.9	1,659.8	1.0	6.60	1	1	1
07/27/2021 02:00	1.5	13.0	1,912.0	1.1	7.60	1	1	1
07/27/2021 03:00	1.6	13.0	1,884.5	1.2	7.50	1	1	1
07/27/2021 04:00	1.1	13.9	1,614.5	0.9	4.80	1	1	0
07/27/2021 05:00	1.2	13.9	1,696.3	1.0	6.80	1	1	1
07/27/2021 06:00	1.3	12.7	1,994.8	0.9	6.00	1	1	1
07/27/2021 07:00	1.6	12.9	1,934.5	1.2	7.70	1	1	1
07/27/2021 08:00	1.1	13.9	1,639.3	0.9	4.90	1	1	0
07/27/2021 09:00	1.1	13.9	1,653.7	0.9	5.00	1	1	0
07/27/2021 10:00	1.1	13.9	1,657.0	0.9	5.00	1	1	0
07/27/2021 11:00	1.1	13.9	1,668.3	0.9	5.00	1	1	0
07/27/2021 12:00	1.6	12.6	2,016.6	1.1	8.10	1	1	1
07/27/2021 13:00	1.7	12.0	2,135.2	1.1	8.50	1	1	1
07/27/2021 14:00	1.7	12.1	2,134.1	1.1	8.50	1	1	1
07/27/2021 15:00	1.7	12.1	2,129.9	1.1	8.50	1	1	1
07/27/2021 16:00	1.7	12.2	2,097.5	1.2	8.40	1	1	1
07/27/2021 17:00	1.7	12.0	2,133.9	1.1	8.50	1	1	1
07/27/2021 18:00	1.7	12.0	2,143.9	1.1	8.60	1	1	1
07/27/2021 19:00	1.7	12.0	2,146.6	1.1	8.60	1	1	1
07/27/2021 20:00	1.7	12.0	2,147.9	1.1	8.60	1	1	1
07/27/2021 21:00	1.7	12.0	2,146.4	1.1	8.60	1	1	1
07/27/2021 22:00	1.7	12.1	2,128.4	1.1	8.50	1	1	1
07/27/2021 23:00	1.7	12.2	2,119.7	1.2	8.50	1	1	1
Average/Sum#:	1.5	12.8	1,932.8	1.1	175.20 #	24 #	24 #	18 #
Minimum:	1.1	12.0	1,591.4	0.9	4.80	1	1	0
Maximum:	1.7	13.9	2,147.9	1.2	8.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/28/2021 00:00	1.7	12.3	2,084.0	1.2	8.30	1	1	1
07/28/2021 01:00	1.6	13.0	1,910.8	1.2	7.60	1	1	1
07/28/2021 02:00	1.2	13.9	1,648.8	1.0	6.60	1	1	0
07/28/2021 03:00	1.1	13.9	1,638.9	0.9	4.90	1	1	1
07/28/2021 04:00	1.6	12.7	2,001.1	1.2	8.00	1	1	1
07/28/2021 05:00	1.7	12.2	2,119.3	1.2	8.50	1	1	1
07/28/2021 06:00	1.6	12.4	2,051.9	1.1	8.20	1	1	1
07/28/2021 07:00	1.1	13.9	1,625.2	0.9	4.90	1	1	0
07/28/2021 08:00	1.1	13.9	1,665.1	0.9	5.00	1	1	1
07/28/2021 09:00	1.6	12.3	2,042.5	1.1	8.20	1	1	1
07/28/2021 10:00	1.8	11.8	2,134.9	1.2	8.50	1	1	1
07/28/2021 11:00	1.8	11.8	2,139.3	1.2	8.60	1	1	1
07/28/2021 12:00	1.8	11.8	2,134.6	1.2	8.50	1	1	1
07/28/2021 13:00	1.8	11.8	2,138.0	1.2	8.60	1	1	1
07/28/2021 14:00	1.8	11.8	2,136.4	1.2	8.50	1	1	1
07/28/2021 15:00	1.8	11.8	2,121.5	1.2	8.50	1	1	1
07/28/2021 16:00	1.8	11.8	2,129.0	1.2	8.50	1	1	1
07/28/2021 17:00	1.8	11.8	2,125.0	1.2	8.50	1	1	1
07/28/2021 18:00	1.8	11.8	2,114.1	1.2	8.50	1	1	1
07/28/2021 19:00	1.8	11.9	2,096.7	1.2	8.40	1	1	1
07/28/2021 20:00	1.8	12.0	2,082.4	1.2	8.30	1	1	1
07/28/2021 21:00	1.8	11.8	2,131.3	1.2	8.50	1	1	1
07/28/2021 22:00	1.7	12.0	2,109.8	1.1	8.40	1	1	1
07/28/2021 23:00	1.8	11.9	2,120.6	1.2	8.50	1	1	1
Average/Sum#:	1.6	12.3	2,020.9	1.1	189.00 #	24 #	24 #	22 #
Minimum:	1.1	11.8	1,625.2	0.9	4.90	1	1	0
Maximum:	1.8	13.9	2,139.3	1.2	8.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/29/2021 00:00	1.8	11.8	2,147.7	1.2	8.60	1	1	1
07/29/2021 01:00	1.8	11.9	2,121.2	1.2	8.50	1	1	1
07/29/2021 02:00	1.3	13.6	1,583.8	1.1	6.30	1	1	1
07/29/2021 03:00	1.1	13.9	1,688.6	0.9	5.10	1	1	1
07/29/2021 04:00	1.6	12.6	2,008.6	1.1	8.00	1	1	1
07/29/2021 05:00	1.8	12.1	2,117.5	1.2	8.50	1	1	1
07/29/2021 06:00	1.7	12.5	2,026.8	1.2	8.10	1	1	1
07/29/2021 07:00	1.1	13.9	1,617.3	0.9	4.90	1	1	0
07/29/2021 08:00	1.1	13.8	1,645.9	0.9	4.90	1	1	1
07/29/2021 09:00	1.5	12.6	1,965.2	1.1	7.90	1	1	1
07/29/2021 10:00	1.8	11.8	2,131.6	1.2	8.50	1	1	1
07/29/2021 11:00	1.8	11.8	2,132.3	1.2	8.50	1	1	1
07/29/2021 12:00	1.8	11.8	2,130.5	1.2	8.50	1	1	1
07/29/2021 13:00	1.8	11.7	2,127.4	1.2	8.50	1	1	1
07/29/2021 14:00	1.8	11.7	2,117.5	1.2	8.50	1	1	1
07/29/2021 15:00	1.8	11.7	2,110.6	1.2	8.40	1	1	1
07/29/2021 16:00	1.8	11.7	2,107.1	1.2	8.40	1	1	1
07/29/2021 17:00	1.8	11.7	2,109.8	1.2	8.40	1	1	1
07/29/2021 18:00	1.8	11.7	2,110.3	1.2	8.40	1	1	1
07/29/2021 19:00	1.9	11.7	2,112.1	1.2	8.40	1	1	1
07/29/2021 20:00	1.8	11.8	2,102.6	1.2	8.40	1	1	1
07/29/2021 21:00	1.8	11.8	2,119.3	1.2	8.50	1	1	1
07/29/2021 22:00	1.8	11.9	2,117.9	1.2	8.50	1	1	1
07/29/2021 23:00	1.8	11.9	2,112.8	1.2	8.50	1	1	1
Average/Sum#:	1.7	12.2	2,023.5	1.2	189.20 #	24 #	24 #	23 #
Minimum:	1.1	11.7	1,583.8	0.9	4.90	1	1	0
Maximum:	1.9	13.9	2,147.7	1.2	8.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/30/2021 00:00	1.8	12.0	2,101.0	1.2	8.40	1	1	1
07/30/2021 01:00	1.7	12.2	2,044.9	1.2	8.20	1	1	1
07/30/2021 02:00	1.2	13.8	1,657.9	1.0	6.60	1	1	1
07/30/2021 03:00	1.2	13.8	1,698.6	1.0	6.80	1	1	1
07/30/2021 04:00	1.6	12.4	2,027.8	1.1	8.10	1	1	1
07/30/2021 05:00	1.8	11.9	2,145.3	1.2	8.60	1	1	1
07/30/2021 06:00	1.7	11.9	2,127.9	1.1	8.50	1	1	1
07/30/2021 07:00	1.7	11.9	2,135.8	1.1	8.50	1	1	1
07/30/2021 08:00	1.8	11.9	2,119.7	1.2	8.50	1	1	1
07/30/2021 09:00	1.8	11.8	2,141.0	1.2	8.60	1	1	1
07/30/2021 10:00	1.8	11.8	2,137.2	1.2	8.50	1	1	1
07/30/2021 11:00	1.8	11.7	2,143.6	1.2	8.60	1	1	1
07/30/2021 12:00	1.8	11.7	2,141.3	1.2	8.60	1	1	1
07/30/2021 13:00	1.8	11.6	2,136.5	1.1	8.50	1	1	1
07/30/2021 14:00	1.8	11.6	2,129.0	1.1	8.50	1	1	1
07/30/2021 15:00	1.8	11.7	2,124.5	1.2	8.50	1	1	1
07/30/2021 16:00	1.8	11.7	2,120.2	1.2	8.50	1	1	1
07/30/2021 17:00	1.8	11.7	2,118.8	1.2	8.50	1	1	1
07/30/2021 18:00	1.8	11.7	2,117.4	1.2	8.50	1	1	1
07/30/2021 19:00	1.8	11.6	2,130.8	1.1	8.50	1	1	1
07/30/2021 20:00	1.8	11.6	2,138.7	1.1	8.60	1	1	1
07/30/2021 21:00	1.8	11.7	2,127.4	1.2	8.50	1	1	1
07/30/2021 22:00	1.8	11.7	2,133.5	1.2	8.50	1	1	1
07/30/2021 23:00	1.8	11.7	2,145.3	1.2	8.60	1	1	1
Average/Sum#:	1.7	12.0	2,085.2	1.2	200.20 #	24 #	24 #	24 #
Minimum:	1.2	11.6	1,657.9	1.0	6.60	1	1	1
Maximum:	1.8	13.8	2,145.3	1.2	8.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/31/2021 00:00	1.8	11.7	2,171.5	1.2	8.70	1	1	1
07/31/2021 01:00	1.7	11.8	2,167.1	1.1	8.70	1	1	1
07/31/2021 02:00	1.7	12.0	2,135.1	1.1	8.50	1	1	1
07/31/2021 03:00	1.3	13.6	1,662.2	1.1	6.60	1	1	1
07/31/2021 04:00	1.2	13.7	1,738.8	1.0	7.00	1	1	0
07/31/2021 05:00	1.5	13.1	1,885.5	1.1	7.50	1	1	1
07/31/2021 06:00	1.6	12.4	2,050.9	1.1	8.20	1	1	1
07/31/2021 07:00	1.1	13.9	1,653.5	0.9	5.00	1	1	0
07/31/2021 08:00	1.0	13.9	1,556.8	0.8	4.70	1	1	1
07/31/2021 09:00	1.6	12.6	1,991.9	1.1	8.00	1	1	1
07/31/2021 10:00	1.7	12.3	2,042.1	1.2	8.20	1	1	1
07/31/2021 11:00	1.7	12.3	2,052.9	1.2	8.20	1	1	1
07/31/2021 12:00	1.7	12.2	2,063.6	1.2	8.30	1	1	1
07/31/2021 13:00	1.7	12.2	2,055.3	1.2	8.20	1	1	1
07/31/2021 14:00	1.7	12.2	2,059.5	1.2	8.20	1	1	1
07/31/2021 15:00	1.7	12.1	2,067.7	1.1	8.30	1	1	1
07/31/2021 16:00	1.8	12.0	2,071.5	1.2	8.30	1	1	1
07/31/2021 17:00	1.8	11.9	2,101.0	1.2	8.40	1	1	1
07/31/2021 18:00	1.8	11.9	2,120.4	1.2	8.50	1	1	1
07/31/2021 19:00	1.8	11.9	2,113.7	1.2	8.50	1	1	1
07/31/2021 20:00	1.8	11.8	2,148.5	1.2	8.60	1	1	1
07/31/2021 21:00	1.8	11.9	2,139.0	1.2	8.60	1	1	1
07/31/2021 22:00	1.8	12.0	2,113.7	1.2	8.50	1	1	1
07/31/2021 23:00	1.7	12.3	2,057.7	1.2	8.20	1	1	1
Average/Sum#:	1.6	12.4	2,009.2	1.1	189.90 #	24 #	24 #	22 #
Minimum:	1.0	11.7	1,556.8	0.8	4.70	1	1	0
Maximum:	1.8	13.9	2,171.5	1.2	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/01/2021 00:00	1.6	12.8	1,926.0	1.2	7.70	1	1	1
08/01/2021 01:00	1.2	13.9	1,622.4	1.0	6.50	1	1	0
08/01/2021 02:00	1.2	13.8	1,665.8	1.0	6.70	1	1	1
08/01/2021 03:00	1.6	12.7	1,987.6	1.2	8.00	1	1	1
08/01/2021 04:00	1.6	12.8	1,950.4	1.2	7.80	1	1	1
08/01/2021 05:00	1.2	13.9	1,652.6	1.0	6.60	1	1	0
08/01/2021 06:00	1.1	13.9	1,602.6	0.9	4.80	1	1	0
08/01/2021 07:00	1.0	13.9	1,593.7	0.8	4.80	1	1	0
08/01/2021 08:00	0.9	13.9	1,393.0	0.8	4.20	1	1	0
08/01/2021 09:00	1.1	13.9	1,539.5	0.9	4.60	1	1	1
08/01/2021 10:00	1.6	12.6	2,000.8	1.1	8.00	1	1	1
08/01/2021 11:00	1.6	12.6	1,965.6	1.1	7.90	1	1	1
08/01/2021 12:00	1.2	13.9	1,598.3	1.0	6.40	1	1	0
08/01/2021 13:00	1.2	13.8	1,643.0	1.0	6.60	1	1	0
08/01/2021 14:00	1.2	13.8	1,654.7	1.0	6.60	1	1	0
08/01/2021 15:00	1.2	13.8	1,673.6	1.0	6.70	1	1	0
08/01/2021 16:00	1.3	13.2	1,782.2	1.0	7.10	1	1	1
08/01/2021 17:00	1.8	11.8	2,137.7	1.2	8.60	1	1	1
08/01/2021 18:00	1.8	11.7	2,170.2	1.2	8.70	1	1	1
08/01/2021 19:00	1.8	11.8	2,161.9	1.2	8.60	1	1	1
08/01/2021 20:00	1.8	11.7	2,178.7	1.2	8.70	1	1	1
08/01/2021 21:00	1.8	11.7	2,185.4	1.2	8.70	1	1	1
08/01/2021 22:00	1.7	11.8	2,171.6	1.1	8.70	1	1	1
08/01/2021 23:00	1.7	11.9	2,148.3	1.1	8.60	1	1	1
Average/Sum#:	1.4	13.0	1,850.2	1.1	171.60 #	24 #	24 #	15 #
Minimum:	0.9	11.7	1,393.0	0.8	4.20	1	1	0
Maximum:	1.8	13.9	2,185.4	1.2	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/02/2021 00:00	1.7	11.9	2,165.2	1.1	8.70	1	1	1
08/02/2021 01:00	1.7	12.1	2,135.9	1.1	8.50	1	1	1
08/02/2021 02:00	1.2	13.7	1,624.9	1.0	6.50	1	1	1
08/02/2021 03:00	1.2	13.8	1,665.0	1.0	6.70	1	1	1
08/02/2021 04:00	1.6	12.6	2,031.6	1.1	8.10	1	1	1
08/02/2021 05:00	1.7	12.0	2,170.4	1.1	8.70	1	1	1
08/02/2021 06:00	1.7	12.4	2,104.8	1.2	8.40	1	1	1
08/02/2021 07:00	1.3	13.6	1,666.9	1.1	6.70	1	1	1
08/02/2021 08:00	1.0	13.8	1,570.7	0.8	4.70	1	1	0
08/02/2021 09:00	1.6	12.7	2,013.4	1.2	8.10	1	1	1
08/02/2021 10:00	1.7	12.1	2,112.0	1.1	8.40	1	1	1
08/02/2021 11:00	1.7	12.0	2,126.2	1.1	8.50	1	1	1
08/02/2021 12:00	1.7	12.1	2,111.3	1.1	8.40	1	1	1
08/02/2021 13:00	1.7	12.1	2,109.2	1.1	8.40	1	1	1
08/02/2021 14:00	1.7	12.1	2,102.4	1.1	8.40	1	1	1
08/02/2021 15:00	1.7	12.1	2,100.4	1.1	8.40	1	1	1
08/02/2021 16:00	1.7	12.1	2,100.3	1.1	8.40	1	1	1
08/02/2021 17:00	1.7	12.0	2,115.4	1.1	8.50	1	1	1
08/02/2021 18:00	1.8	11.8	2,163.2	1.2	8.70	1	1	1
08/02/2021 19:00	1.8	11.7	2,174.9	1.2	8.70	1	1	1
08/02/2021 20:00	1.7	11.8	2,182.3	1.1	8.70	1	1	1
08/02/2021 21:00	1.8	11.8	2,187.4	1.2	8.70	1	1	1
08/02/2021 22:00	1.7	11.8	2,189.6	1.1	8.80	1	1	1
08/02/2021 23:00	1.7	11.8	2,192.8	1.1	8.80	1	1	1
Average/Sum#:	1.6	12.3	2,046.5	1.1	194.90 #	24 #	24 #	23 #
Minimum:	1.0	11.7	1,570.7	0.8	4.70	1	1	0
Maximum:	1.8	13.8	2,192.8	1.2	8.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/03/2021 00:00	1.7	12.0	2,150.5	1.1	8.60	1	1	1
08/03/2021 01:00	1.7	12.0	2,142.2	1.1	8.60	1	1	1
08/03/2021 02:00	1.3	13.6	1,706.1	1.1	6.80	1	1	1
08/03/2021 03:00	1.2	13.8	1,743.4	1.0	7.00	1	1	1
08/03/2021 04:00	1.5	13.0	1,929.7	1.1	5.24	1	0	1
08/03/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/03/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/03/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/03/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/03/2021 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/03/2021 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/03/2021 11:00	18.2	16.6	578.5	25.0	44.16	1	0	0
08/03/2021 12:00	0.6	14.1	1,305.3	0.5	2.60	1	0	0
08/03/2021 13:00	1.1	13.8	1,681.1	0.9	5.00	1	1	1
08/03/2021 14:00	1.6	12.3	2,042.2	1.1	8.20	1	1	1
08/03/2021 15:00	1.7	12.1	2,097.4	1.1	8.40	1	1	1
08/03/2021 16:00	1.7	12.0	2,102.5	1.1	8.40	1	1	1
08/03/2021 17:00	1.8	12.0	2,114.9	1.2	8.50	1	1	1
08/03/2021 18:00	1.7	11.8	2,157.6	1.1	8.60	1	1	1
08/03/2021 19:00	1.8	11.7	2,165.7	1.2	8.70	1	1	1
08/03/2021 20:00	1.7	11.7	2,174.2	1.1	8.70	1	1	1
08/03/2021 21:00	1.7	11.7	2,172.4	1.1	8.70	1	1	1
08/03/2021 22:00	1.7	11.8	2,167.7	1.1	8.70	1	1	1
08/03/2021 23:00	1.7	11.9	2,151.9	1.1	8.60	1	1	1
Average/Sum#:	2.5	12.7	1,921.3	2.4	173.50 #	18 #	15 #	16 #
Minimum:	0.6	11.7	578.5	0.5	2.60	0	0	0
Maximum:	18.2	16.6	2,174.2	25.0	44.16	1	1	1
%SI	25.00	25.00	25.00	25.00	25.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/04/2021 00:00	1.6	12.4	2,031.1	1.1	8.10	1	1	1
08/04/2021 01:00	1.1	13.9	1,635.9	0.9	4.90	1	1	0
08/04/2021 02:00	1.4	13.7	1,741.2	1.1	7.00	1	1	1
08/04/2021 03:00	1.6	12.7	2,000.0	1.2	8.00	1	1	1
08/04/2021 04:00	1.7	12.0	2,147.6	1.1	8.60	1	1	1
08/04/2021 05:00	1.7	11.9	2,169.2	1.1	8.70	1	1	1
08/04/2021 06:00	1.7	12.4	2,053.5	1.2	8.20	1	1	1
08/04/2021 07:00	1.6	12.8	1,920.2	1.2	7.70	1	1	1
08/04/2021 08:00	1.1	13.9	1,608.0	0.9	4.80	1	1	0
08/04/2021 09:00	1.2	13.8	1,679.0	1.0	6.70	1	1	0
08/04/2021 10:00	1.6	12.6	2,001.1	1.1	8.00	1	1	1
08/04/2021 11:00	1.7	11.9	2,120.9	1.1	8.50	1	1	1
08/04/2021 12:00	1.8	12.0	2,095.2	1.2	8.40	1	1	1
08/04/2021 13:00	1.7	12.0	2,089.5	1.1	8.40	1	1	1
08/04/2021 14:00	1.7	12.0	2,088.2	1.1	8.40	1	1	1
08/04/2021 15:00	1.8	11.9	2,091.3	1.2	8.40	1	1	1
08/04/2021 16:00	1.8	11.8	2,112.6	1.2	8.50	1	1	1
08/04/2021 17:00	1.8	11.8	2,122.7	1.2	8.50	1	1	1
08/04/2021 18:00	1.8	11.8	2,136.8	1.2	8.50	1	1	1
08/04/2021 19:00	1.8	11.7	2,149.2	1.2	8.60	1	1	1
08/04/2021 20:00	1.8	11.7	2,162.6	1.2	8.70	1	1	1
08/04/2021 21:00	1.8	11.7	2,174.4	1.2	8.70	1	1	1
08/04/2021 22:00	1.8	11.8	2,177.9	1.2	8.70	1	1	1
08/04/2021 23:00	1.7	12.1	2,112.1	1.1	8.40	1	1	1
Average/Sum#:	1.6	12.3	2,025.8	1.1	191.40 #	24 #	24 #	21 #
Minimum:	1.1	11.7	1,608.0	0.9	4.80	1	1	0
Maximum:	1.8	13.9	2,177.9	1.2	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/05/2021 00:00	1.7	12.2	2,100.7	1.2	8.40	1	1	1
08/05/2021 01:00	1.7	12.2	2,120.0	1.2	8.50	1	1	1
08/05/2021 02:00	1.7	12.2	2,118.7	1.2	8.50	1	1	1
08/05/2021 03:00	1.7	12.0	2,162.2	1.1	8.60	1	1	1
08/05/2021 04:00	1.8	12.0	2,170.9	1.2	8.70	1	1	1
08/05/2021 05:00	1.7	12.0	2,165.4	1.1	8.70	1	1	1
08/05/2021 06:00	1.5	12.8	1,990.6	1.1	8.00	1	1	1
08/05/2021 07:00	1.0	13.9	1,630.9	0.8	4.90	1	1	0
08/05/2021 08:00	1.0	13.9	1,609.8	0.8	4.80	1	1	1
08/05/2021 09:00	1.5	13.0	1,939.5	1.1	7.80	1	1	1
08/05/2021 10:00	1.6	12.5	2,007.0	1.1	8.00	1	1	1
08/05/2021 11:00	1.2	13.8	1,652.7	1.0	6.60	1	1	0
08/05/2021 12:00	1.1	13.8	1,720.3	0.9	5.20	1	1	1
08/05/2021 13:00	1.6	12.5	2,007.3	1.1	8.00	1	1	1
08/05/2021 14:00	1.7	12.3	2,054.8	1.2	8.20	1	1	1
08/05/2021 15:00	1.7	12.2	2,064.2	1.2	8.30	1	1	1
08/05/2021 16:00	1.7	12.1	2,093.1	1.1	8.40	1	1	1
08/05/2021 17:00	1.7	12.2	2,071.3	1.2	8.30	1	1	1
08/05/2021 18:00	1.7	11.9	2,148.0	1.1	8.60	1	1	1
08/05/2021 19:00	1.8	11.8	2,162.0	1.2	8.60	1	1	1
08/05/2021 20:00	1.7	11.7	2,167.7	1.1	8.70	1	1	1
08/05/2021 21:00	1.7	11.9	2,137.4	1.1	8.50	1	1	1
08/05/2021 22:00	1.7	12.1	2,084.5	1.1	8.30	1	1	1
08/05/2021 23:00	1.7	12.3	2,061.4	1.2	8.20	1	1	1
Average/Sum#:	1.6	12.5	2,018.4	1.1	188.80 #	24 #	24 #	22 #
Minimum:	1.0	11.7	1,609.8	0.8	4.80	1	1	0
Maximum:	1.8	13.9	2,170.9	1.2	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/06/2021 00:00	1.7	12.4	2,006.9	1.2	8.00	1	1	1
08/06/2021 01:00	1.1	13.9	1,655.7	0.9	5.00	1	1	0
08/06/2021 02:00	1.1	13.9	1,650.5	0.9	5.00	1	1	0
08/06/2021 03:00	1.1	13.8	1,596.5	0.9	4.80	1	1	1
08/06/2021 04:00	1.6	12.7	1,985.9	1.2	7.90	1	1	1
08/06/2021 05:00	1.7	12.5	2,005.7	1.2	8.00	1	1	1
08/06/2021 06:00	1.0	13.9	1,572.2	0.8	4.70	1	1	0
08/06/2021 07:00	1.0	13.9	1,638.9	0.8	4.90	1	1	0
08/06/2021 08:00	1.0	13.9	1,634.5	0.8	4.90	1	1	0
08/06/2021 09:00	1.6	12.8	1,960.6	1.2	7.80	1	1	1
08/06/2021 10:00	1.6	12.8	1,933.7	1.2	7.70	1	1	1
08/06/2021 11:00	1.2	13.9	1,630.7	1.0	6.50	1	1	0
08/06/2021 12:00	1.0	14.0	1,504.0	0.9	4.50	1	1	0
08/06/2021 13:00	1.6	12.8	1,960.0	1.2	7.80	1	1	1
08/06/2021 14:00	1.7	12.3	2,050.8	1.2	8.20	1	1	1
08/06/2021 15:00	1.7	12.3	2,039.2	1.2	8.20	1	1	1
08/06/2021 16:00	1.7	12.1	2,083.3	1.1	8.30	1	1	1
08/06/2021 17:00	1.8	12.0	2,094.5	1.2	8.40	1	1	1
08/06/2021 18:00	1.8	11.8	2,140.5	1.2	8.60	1	1	1
08/06/2021 19:00	1.7	12.0	2,093.1	1.1	8.40	1	1	1
08/06/2021 20:00	1.7	12.0	2,087.9	1.1	8.40	1	1	1
08/06/2021 21:00	1.7	12.1	2,063.0	1.1	8.30	1	1	1
08/06/2021 22:00	1.7	12.3	2,027.9	1.2	8.10	1	1	1
08/06/2021 23:00	1.6	12.7	1,916.9	1.2	7.70	1	1	1
Average/Sum#:	1.5	12.9	1,888.9	1.1	170.10 #	24 #	24 #	17 #
Minimum:	1.0	11.8	1,504.0	0.8	4.50	1	1	0
Maximum:	1.8	14.0	2,140.5	1.2	8.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/07/2021 00:00	1.2	13.9	1,660.6	1.0	6.60	1	1	0
08/07/2021 01:00	1.2	13.8	1,585.9	1.0	6.30	1	1	1
08/07/2021 02:00	1.6	12.8	1,919.9	1.2	7.70	1	1	1
08/07/2021 03:00	3.0	14.3	1,164.1	2.7	5.57	1	0	1
08/07/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/07/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/07/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/07/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/07/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/07/2021 09:00	0.7	18.7	181.5	1.9	0.29	1	0	0
08/07/2021 10:00	9.4	16.4	552.2	12.3	24.80	1	0	0
08/07/2021 11:00	13.2	15.9	597.4	15.6	15.35	1	0	0
08/07/2021 12:00	6.4	16.0	737.1	7.7	19.16	1	0	0
08/07/2021 13:00	1.0	13.9	1,548.6	0.8	4.60	1	1	0
08/07/2021 14:00	1.0	13.9	1,453.5	0.8	4.40	1	1	0
08/07/2021 15:00	1.2	13.9	1,620.2	1.0	6.50	1	1	0
08/07/2021 16:00	1.0	14.0	1,498.8	0.9	4.50	1	1	1
08/07/2021 17:00	1.6	12.5	1,986.9	1.1	7.90	1	1	1
08/07/2021 18:00	1.7	12.1	2,049.2	1.1	8.20	1	1	1
08/07/2021 19:00	1.7	12.4	1,973.2	1.2	7.90	1	1	1
08/07/2021 20:00	1.3	13.8	1,646.0	1.1	6.60	1	1	0
08/07/2021 21:00	1.2	13.8	1,613.3	1.0	6.50	1	1	1
08/07/2021 22:00	1.6	12.9	1,928.0	1.2	7.70	1	1	1
08/07/2021 23:00	1.7	12.4	2,004.3	1.2	8.00	1	1	1
Average/Sum#:	2.7	14.1	1,459.0	2.9	158.57 #	19 #	14 #	10 #
Minimum:	0.7	12.1	181.5	0.8	0.29	0	0	0
Maximum:	13.2	18.7	2,049.2	15.6	24.80	1	1	1
%SI	20.83	20.83	20.83	20.83	20.83	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/08/2021 00:00	1.2	13.9	1,561.0	1.0	6.20	1	1	0
08/08/2021 01:00	1.1	13.8	1,529.1	0.9	4.60	1	1	1
08/08/2021 02:00	1.6	13.0	1,908.5	1.2	7.60	1	1	1
08/08/2021 03:00	1.1	13.7	1,462.5	0.9	4.40	1	1	1
08/08/2021 04:00	0.9	14.0	1,363.8	0.8	4.10	1	1	0
08/08/2021 05:00	1.0	14.0	1,350.3	0.9	4.10	1	1	0
08/08/2021 06:00	1.0	14.0	1,352.9	0.9	4.10	1	1	0
08/08/2021 07:00	0.9	14.0	1,357.3	0.8	4.10	1	1	0
08/08/2021 08:00	1.0	14.0	1,361.9	0.9	4.10	1	1	0
08/08/2021 09:00	1.0	14.0	1,362.8	0.9	4.10	1	1	0
08/08/2021 10:00	1.0	14.0	1,363.1	0.9	4.10	1	1	0
08/08/2021 11:00	1.0	14.0	1,367.2	0.9	4.10	1	1	0
08/08/2021 12:00	1.0	14.0	1,370.8	0.9	4.10	1	1	0
08/08/2021 13:00	1.1	14.0	1,438.0	0.9	4.30	1	1	0
08/08/2021 14:00	1.1	13.9	1,563.7	0.9	4.70	1	1	0
08/08/2021 15:00	1.0	13.9	1,469.3	0.8	4.40	1	1	0
08/08/2021 16:00	1.2	13.9	1,568.8	1.0	6.30	1	1	0
08/08/2021 17:00	1.4	13.2	1,745.4	1.1	7.00	1	1	1
08/08/2021 18:00	1.8	12.1	2,066.5	1.2	8.30	1	1	1
08/08/2021 19:00	1.8	12.0	2,088.5	1.2	8.40	1	1	1
08/08/2021 20:00	1.8	11.9	2,123.8	1.2	8.50	1	1	1
08/08/2021 21:00	1.8	12.0	2,085.2	1.2	8.30	1	1	1
08/08/2021 22:00	1.7	12.4	2,013.0	1.2	8.10	1	1	1
08/08/2021 23:00	1.6	12.8	1,904.5	1.2	7.60	1	1	1
Average/Sum#:	1.3	13.4	1,615.7	1.0	135.60 #	24 #	24 #	10 #
Minimum:	0.9	11.9	1,350.3	0.8	4.10	1	1	0
Maximum:	1.8	14.0	2,123.8	1.2	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/09/2021 00:00	1.2	13.9	1,554.3	1.0	6.20	1	1	0
08/09/2021 01:00	1.4	13.8	1,703.8	1.2	6.80	1	1	1
08/09/2021 02:00	1.6	12.7	1,963.1	1.2	7.90	1	1	1
08/09/2021 03:00	1.6	12.9	1,906.6	1.2	7.60	1	1	1
08/09/2021 04:00	1.2	13.9	1,652.3	1.0	6.60	1	1	0
08/09/2021 05:00	1.4	13.7	1,731.1	1.1	6.90	1	1	1
08/09/2021 06:00	1.4	12.8	1,962.9	1.0	7.90	1	1	1
08/09/2021 07:00	1.6	12.6	1,959.9	1.1	7.80	1	1	1
08/09/2021 08:00	1.2	13.9	1,553.5	1.0	6.20	1	1	0
08/09/2021 09:00	1.2	13.9	1,608.7	1.0	6.40	1	1	0
08/09/2021 10:00	1.3	13.8	1,641.4	1.1	6.60	1	1	0
08/09/2021 11:00	1.6	12.7	1,955.3	1.2	7.80	1	1	1
08/09/2021 12:00	1.7	12.1	2,018.6	1.1	8.10	1	1	1
08/09/2021 13:00	1.3	13.8	1,679.6	1.1	6.70	1	1	0
08/09/2021 14:00	1.4	13.2	1,773.7	1.1	7.10	1	1	1
08/09/2021 15:00	1.8	12.0	2,085.0	1.2	8.30	1	1	1
08/09/2021 16:00	1.7	11.9	2,093.5	1.1	8.40	1	1	1
08/09/2021 17:00	1.8	11.9	2,097.0	1.2	8.40	1	1	1
08/09/2021 18:00	1.7	11.9	2,099.9	1.1	8.40	1	1	1
08/09/2021 19:00	1.8	11.7	2,137.6	1.2	8.60	1	1	1
08/09/2021 20:00	1.8	11.7	2,149.8	1.2	8.60	1	1	1
08/09/2021 21:00	1.7	11.9	2,127.8	1.1	8.50	1	1	1
08/09/2021 22:00	1.7	12.3	2,048.8	1.2	8.20	1	1	1
08/09/2021 23:00	1.7	12.3	2,056.0	1.2	8.20	1	1	1
Average/Sum#:	1.5	12.8	1,898.3	1.1	182.20 #	24 #	24 #	18 #
Minimum:	1.2	11.7	1,553.5	1.0	6.20	1	1	0
Maximum:	1.8	13.9	2,149.8	1.2	8.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/10/2021 00:00	1.6	12.6	1,960.3	1.1	7.80	1	1	1
08/10/2021 01:00	1.2	13.9	1,593.3	1.0	6.40	1	1	0
08/10/2021 02:00	1.2	13.9	1,596.1	1.0	6.40	1	1	0
08/10/2021 03:00	1.3	13.8	1,698.6	1.1	6.80	1	1	1
08/10/2021 04:00	1.6	12.6	2,014.3	1.1	8.10	1	1	1
08/10/2021 05:00	1.6	12.4	2,021.4	1.1	8.10	1	1	1
08/10/2021 06:00	1.2	13.9	1,620.6	1.0	6.50	1	1	0
08/10/2021 07:00	1.1	13.8	1,590.5	0.9	4.80	1	1	1
08/10/2021 08:00	1.6	12.7	1,975.6	1.2	7.90	1	1	1
08/10/2021 09:00	1.5	12.9	1,909.7	1.1	7.60	1	1	1
08/10/2021 10:00	1.3	13.9	1,660.0	1.1	6.60	1	1	0
08/10/2021 11:00	1.3	13.8	1,675.5	1.1	6.70	1	1	1
08/10/2021 12:00	1.6	12.5	2,008.1	1.1	8.00	1	1	1
08/10/2021 13:00	1.7	12.0	2,102.4	1.1	8.40	1	1	1
08/10/2021 14:00	1.8	11.9	2,102.6	1.2	8.40	1	1	1
08/10/2021 15:00	1.7	11.9	2,097.3	1.1	8.40	1	1	1
08/10/2021 16:00	1.7	11.9	2,107.9	1.1	8.40	1	1	1
08/10/2021 17:00	1.8	11.8	2,112.5	1.2	8.50	1	1	1
08/10/2021 18:00	1.8	11.7	2,145.2	1.2	8.60	1	1	1
08/10/2021 19:00	1.8	11.7	2,157.2	1.2	8.60	1	1	1
08/10/2021 20:00	1.7	11.7	2,159.3	1.1	8.60	1	1	1
08/10/2021 21:00	1.8	11.7	2,157.0	1.2	8.60	1	1	1
08/10/2021 22:00	1.7	12.0	2,100.8	1.1	8.40	1	1	1
08/10/2021 23:00	1.7	12.1	2,086.9	1.1	8.30	1	1	1
Average/Sum#:	1.6	12.6	1,943.9	1.1	184.90 #	24 #	24 #	20 #
Minimum:	1.1	11.7	1,590.5	0.9	4.80	1	1	0
Maximum:	1.8	13.9	2,159.3	1.2	8.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/11/2021 00:00	1.7	12.3	2,032.6	1.2	8.10	1	1	1
08/11/2021 01:00	1.3	13.8	1,656.6	1.1	6.60	1	1	0
08/11/2021 02:00	1.2	13.9	1,592.8	1.0	6.40	1	1	0
08/11/2021 03:00	1.2	13.9	1,581.0	1.0	6.30	1	1	0
08/11/2021 04:00	1.2	13.8	1,606.8	1.0	6.40	1	1	1
08/11/2021 05:00	1.6	12.6	2,023.6	1.1	8.10	1	1	1
08/11/2021 06:00	1.5	12.5	2,037.3	1.1	8.10	1	1	1
08/11/2021 07:00	1.2	13.9	1,622.1	1.0	6.50	1	1	0
08/11/2021 08:00	1.3	13.7	1,716.3	1.1	6.90	1	1	1
08/11/2021 09:00	1.6	12.5	2,008.6	1.1	8.00	1	1	1
08/11/2021 10:00	1.7	12.0	2,106.4	1.1	8.40	1	1	1
08/11/2021 11:00	1.7	12.0	2,108.9	1.1	8.40	1	1	1
08/11/2021 12:00	1.7	12.1	2,074.1	1.1	8.30	1	1	1
08/11/2021 13:00	1.7	12.1	2,078.0	1.1	8.30	1	1	1
08/11/2021 14:00	1.7	11.9	2,095.8	1.1	8.40	1	1	1
08/11/2021 15:00	1.7	12.1	2,037.4	1.1	8.10	1	1	1
08/11/2021 16:00	1.7	12.0	2,067.6	1.1	8.30	1	1	1
08/11/2021 17:00	1.7	11.9	2,091.5	1.1	8.40	1	1	1
08/11/2021 18:00	1.8	11.7	2,134.0	1.2	8.50	1	1	1
08/11/2021 19:00	1.8	11.7	2,137.5	1.2	8.60	1	1	1
08/11/2021 20:00	1.8	11.7	2,144.0	1.2	8.60	1	1	1
08/11/2021 21:00	1.7	11.8	2,117.6	1.1	8.50	1	1	1
08/11/2021 22:00	1.7	12.1	2,078.6	1.1	8.30	1	1	1
08/11/2021 23:00	1.7	12.2	2,083.5	1.2	8.30	1	1	1
Average/Sum#:	1.6	12.5	1,968.0	1.1	188.80 #	24 #	24 #	20 #
Minimum:	1.2	11.7	1,581.0	1.0	6.30	1	1	0
Maximum:	1.8	13.9	2,144.0	1.2	8.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/12/2021 00:00	1.7	12.3	2,043.0	1.2	8.20	1	1	1
08/12/2021 01:00	1.2	13.9	1,652.2	1.0	6.60	1	1	0
08/12/2021 02:00	1.3	13.8	1,606.3	1.1	6.40	1	1	1
08/12/2021 03:00	1.6	12.7	1,974.9	1.2	7.90	1	1	1
08/12/2021 04:00	1.6	12.6	1,974.7	1.1	7.90	1	1	1
08/12/2021 05:00	1.2	13.9	1,657.7	1.0	6.60	1	1	0
08/12/2021 06:00	1.3	13.8	1,736.6	1.1	6.90	1	1	1
08/12/2021 07:00	1.6	12.7	1,981.0	1.2	7.90	1	1	1
08/12/2021 08:00	1.6	12.8	1,915.9	1.2	7.70	1	1	1
08/12/2021 09:00	1.3	13.9	1,668.4	1.1	6.70	1	1	0
08/12/2021 10:00	1.3	13.9	1,680.0	1.1	6.70	1	1	1
08/12/2021 11:00	1.6	12.5	2,006.9	1.1	8.00	1	1	1
08/12/2021 12:00	1.7	12.1	2,053.9	1.1	8.20	1	1	1
08/12/2021 13:00	1.7	12.2	2,043.5	1.2	8.20	1	1	1
08/12/2021 14:00	1.7	12.2	2,034.6	1.2	8.10	1	1	1
08/12/2021 15:00	1.7	12.1	2,039.2	1.1	8.20	1	1	1
08/12/2021 16:00	1.7	12.1	2,054.7	1.1	8.20	1	1	1
08/12/2021 17:00	1.7	12.0	2,064.9	1.1	8.30	1	1	1
08/12/2021 18:00	1.8	11.9	2,108.2	1.2	8.40	1	1	1
08/12/2021 19:00	1.8	11.8	2,117.5	1.2	8.50	1	1	1
08/12/2021 20:00	1.7	11.8	2,137.9	1.1	8.60	1	1	1
08/12/2021 21:00	1.7	12.0	2,110.9	1.1	8.40	1	1	1
08/12/2021 22:00	1.7	12.2	2,062.5	1.2	8.30	1	1	1
08/12/2021 23:00	1.6	12.5	2,016.3	1.1	8.10	1	1	1
Average/Sum#:	1.6	12.7	1,947.6	1.1	187.00 #	24 #	24 #	21 #
Minimum:	1.2	11.8	1,606.3	1.0	6.40	1	1	0
Maximum:	1.8	13.9	2,137.9	1.2	8.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/13/2021 00:00	1.6	12.9	1,922.2	1.2	7.70	1	1	1
08/13/2021 01:00	1.2	13.8	1,613.8	1.0	6.50	1	1	1
08/13/2021 02:00	1.0	13.9	1,468.4	0.8	4.40	1	1	1
08/13/2021 03:00	1.6	12.7	1,977.5	1.2	7.90	1	1	1
08/13/2021 04:00	1.6	13.0	1,908.9	1.2	7.60	1	1	1
08/13/2021 05:00	1.1	13.9	1,643.1	0.9	4.90	1	1	0
08/13/2021 06:00	1.1	13.9	1,611.3	0.9	4.80	1	1	0
08/13/2021 07:00	1.0	13.9	1,536.4	0.8	4.60	1	1	1
08/13/2021 08:00	1.6	12.8	1,965.9	1.2	7.90	1	1	1
08/13/2021 09:00	1.6	12.7	1,927.0	1.2	7.70	1	1	1
08/13/2021 10:00	1.2	13.9	1,564.2	1.0	6.30	1	1	0
08/13/2021 11:00	1.1	13.9	1,564.0	0.9	4.70	1	1	1
08/13/2021 12:00	1.6	12.5	1,989.4	1.1	8.00	1	1	1
08/13/2021 13:00	1.7	12.3	2,027.9	1.2	8.10	1	1	1
08/13/2021 14:00	1.7	12.3	2,023.3	1.2	8.10	1	1	1
08/13/2021 15:00	1.7	12.3	2,022.3	1.2	8.10	1	1	1
08/13/2021 16:00	1.7	12.2	2,033.0	1.2	8.10	1	1	1
08/13/2021 17:00	1.7	12.1	2,052.7	1.1	8.20	1	1	1
08/13/2021 18:00	1.7	12.0	2,093.7	1.1	8.40	1	1	1
08/13/2021 19:00	1.8	11.9	2,127.1	1.2	8.50	1	1	1
08/13/2021 20:00	1.7	11.9	2,108.1	1.1	8.40	1	1	1
08/13/2021 21:00	1.7	12.2	2,052.5	1.2	8.20	1	1	1
08/13/2021 22:00	1.7	12.3	2,050.2	1.2	8.20	1	1	1
08/13/2021 23:00	1.7	12.3	2,049.7	1.2	8.20	1	1	1
Average/Sum#:	1.5	12.8	1,888.9	1.1	173.50 #	24 #	24 #	21 #
Minimum:	1.0	11.9	1,468.4	0.8	4.40	1	1	0
Maximum:	1.8	13.9	2,127.1	1.2	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/14/2021 00:00	1.6	12.6	1,945.9	1.1	7.80	1	1	1
08/14/2021 01:00	1.3	13.9	1,668.4	1.1	6.70	1	1	0
08/14/2021 02:00	1.3	13.8	1,700.9	1.1	6.80	1	1	1
08/14/2021 03:00	1.6	12.6	1,982.9	1.1	7.90	1	1	1
08/14/2021 04:00	1.6	12.8	1,912.3	1.2	7.60	1	1	1
08/14/2021 05:00	1.2	13.9	1,676.1	1.0	6.70	1	1	0
08/14/2021 06:00	1.2	13.9	1,590.6	1.0	6.40	1	1	0
08/14/2021 07:00	1.0	13.9	1,484.1	0.8	4.50	1	1	0
08/14/2021 08:00	0.9	14.0	1,288.9	0.8	3.90	1	1	0
08/14/2021 09:00	1.2	13.9	1,566.6	1.0	6.30	1	1	0
08/14/2021 10:00	1.3	13.9	1,627.9	1.1	6.50	1	1	0
08/14/2021 11:00	1.3	13.9	1,647.0	1.1	6.60	1	1	0
08/14/2021 12:00	1.2	13.8	1,652.4	1.0	6.60	1	1	1
08/14/2021 13:00	1.6	12.4	1,984.1	1.1	7.90	1	1	1
08/14/2021 14:00	1.7	12.1	2,018.7	1.1	8.10	1	1	1
08/14/2021 15:00	1.2	13.9	1,558.2	1.0	6.20	1	1	0
08/14/2021 16:00	1.1	13.9	1,485.5	0.9	4.50	1	1	1
08/14/2021 17:00	1.7	12.2	2,011.9	1.2	8.00	1	1	1
08/14/2021 18:00	1.8	11.7	2,110.5	1.2	8.40	1	1	1
08/14/2021 19:00	1.8	11.6	2,129.1	1.1	8.50	1	1	1
08/14/2021 20:00	1.8	11.8	2,125.8	1.2	8.50	1	1	1
08/14/2021 21:00	1.7	11.9	2,104.4	1.1	8.40	1	1	1
08/14/2021 22:00	1.7	12.1	2,071.9	1.1	8.30	1	1	1
08/14/2021 23:00	1.7	12.3	2,041.4	1.2	8.20	1	1	1
Average/Sum#:	1.4	13.0	1,807.7	1.1	169.30 #	24 #	24 #	15 #
Minimum:	0.9	11.6	1,288.9	0.8	3.90	1	1	0
Maximum:	1.8	14.0	2,129.1	1.2	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/15/2021 00:00	1.6	12.8	1,927.5	1.2	7.70	1	1	1
08/15/2021 01:00	1.2	13.9	1,665.2	1.0	6.70	1	1	0
08/15/2021 02:00	1.2	13.8	1,607.7	1.0	6.40	1	1	1
08/15/2021 03:00	1.6	12.6	1,987.6	1.1	8.00	1	1	1
08/15/2021 04:00	1.6	12.8	1,910.4	1.2	7.60	1	1	1
08/15/2021 05:00	1.2	13.9	1,645.3	1.0	6.60	1	1	0
08/15/2021 06:00	1.2	13.9	1,566.2	1.0	6.30	1	1	0
08/15/2021 07:00	1.2	13.9	1,641.8	1.0	6.60	1	1	0
08/15/2021 08:00	1.1	13.9	1,477.4	0.9	4.40	1	1	0
08/15/2021 09:00	1.2	13.8	1,599.7	1.0	6.40	1	1	0
08/15/2021 10:00	1.3	13.8	1,656.6	1.1	6.60	1	1	0
08/15/2021 11:00	1.1	13.9	1,483.4	0.9	4.50	1	1	0
08/15/2021 12:00	1.5	13.2	1,707.6	1.1	6.80	1	1	1
08/15/2021 13:00	1.7	12.1	2,010.2	1.1	8.00	1	1	1
08/15/2021 14:00	1.3	13.8	1,606.3	1.1	6.40	1	1	0
08/15/2021 15:00	1.3	13.8	1,614.9	1.1	6.50	1	1	1
08/15/2021 16:00	1.7	12.2	2,002.4	1.2	8.00	1	1	1
08/15/2021 17:00	1.8	11.8	2,052.0	1.2	8.20	1	1	1
08/15/2021 18:00	1.8	11.8	2,091.8	1.2	8.40	1	1	1
08/15/2021 19:00	1.8	11.9	2,082.9	1.2	8.30	1	1	1
08/15/2021 20:00	1.7	12.0	2,073.1	1.1	8.30	1	1	1
08/15/2021 21:00	1.7	12.0	2,071.7	1.1	8.30	1	1	1
08/15/2021 22:00	1.7	12.1	2,051.9	1.1	8.20	1	1	1
08/15/2021 23:00	1.7	12.2	2,044.9	1.2	8.20	1	1	1
Average/Sum#:	1.5	13.0	1,815.8	1.1	171.40 #	24 #	24 #	15 #
Minimum:	1.1	11.8	1,477.4	0.9	4.40	1	1	0
Maximum:	1.8	13.9	2,091.8	1.2	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/16/2021 00:00	1.6	12.6	1,929.8	1.1	7.70	1	1	1
08/16/2021 01:00	1.3	13.9	1,664.6	1.1	6.70	1	1	0
08/16/2021 02:00	1.1	13.8	1,497.9	0.9	4.50	1	1	1
08/16/2021 03:00	1.6	12.6	1,958.8	1.1	7.80	1	1	1
08/16/2021 04:00	1.6	12.7	1,930.8	1.2	7.70	1	1	1
08/16/2021 05:00	1.3	13.8	1,667.6	1.1	6.70	1	1	1
08/16/2021 06:00	1.3	13.8	1,697.9	1.1	6.80	1	1	1
08/16/2021 07:00	1.6	12.6	1,947.8	1.1	7.80	1	1	1
08/16/2021 08:00	1.7	12.4	1,963.8	1.2	7.90	1	1	1
08/16/2021 09:00	1.3	13.8	1,650.0	1.1	6.60	1	1	0
08/16/2021 10:00	1.3	13.8	1,591.7	1.1	6.40	1	1	1
08/16/2021 11:00	1.7	12.3	2,001.3	1.2	8.00	1	1	1
08/16/2021 12:00	1.7	12.0	2,042.6	1.1	8.20	1	1	1
08/16/2021 13:00	1.7	12.0	2,036.5	1.1	8.10	1	1	1
08/16/2021 14:00	1.7	12.2	2,001.7	1.2	8.00	1	1	1
08/16/2021 15:00	1.8	11.9	2,060.3	1.2	8.20	1	1	1
08/16/2021 16:00	1.8	11.8	2,074.6	1.2	8.30	1	1	1
08/16/2021 17:00	1.8	11.6	2,100.2	1.1	8.40	1	1	1
08/16/2021 18:00	1.8	11.6	2,123.0	1.1	8.50	1	1	1
08/16/2021 19:00	1.8	11.7	2,119.4	1.2	8.50	1	1	1
08/16/2021 20:00	1.7	11.8	2,101.6	1.1	8.40	1	1	1
08/16/2021 21:00	1.8	11.8	2,110.5	1.2	8.40	1	1	1
08/16/2021 22:00	1.7	12.1	2,061.4	1.1	8.20	1	1	1
08/16/2021 23:00	1.7	12.2	2,063.7	1.2	8.30	1	1	1
Average/Sum#:	1.6	12.5	1,933.2	1.1	184.10 #	24 #	24 #	22 #
Minimum:	1.1	11.6	1,497.9	0.9	4.50	1	1	0
Maximum:	1.8	13.9	2,123.0	1.2	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/17/2021 00:00	1.6	12.4	2,026.8	1.1	8.10	1	1	1
08/17/2021 01:00	1.2	13.8	1,646.4	1.0	6.60	1	1	1
08/17/2021 02:00	1.2	13.8	1,603.5	1.0	6.40	1	1	1
08/17/2021 03:00	1.6	12.5	2,015.4	1.1	8.10	1	1	1
08/17/2021 04:00	1.7	12.1	2,089.8	1.1	8.40	1	1	1
08/17/2021 05:00	1.7	12.0	2,133.1	1.1	8.50	1	1	1
08/17/2021 06:00	1.5	12.4	2,034.7	1.0	8.10	1	1	1
08/17/2021 07:00	1.1	13.9	1,623.8	0.9	4.90	1	1	0
08/17/2021 08:00	1.1	13.9	1,571.2	0.9	4.70	1	1	1
08/17/2021 09:00	1.6	12.7	1,977.1	1.2	7.90	1	1	1
08/17/2021 10:00	1.6	12.8	1,906.1	1.2	7.60	1	1	1
08/17/2021 11:00	1.2	13.9	1,620.7	1.0	6.50	1	1	0
08/17/2021 12:00	1.0	13.9	1,450.2	0.8	4.40	1	1	0
08/17/2021 13:00	1.4	13.8	1,699.1	1.2	6.80	1	1	0
08/17/2021 14:00	1.5	13.3	1,774.5	1.2	7.10	1	1	1
08/17/2021 15:00	1.5	13.1	1,799.3	1.1	7.20	1	1	1
08/17/2021 16:00	1.1	13.9	1,524.8	0.9	4.60	1	1	1
08/17/2021 17:00	1.7	12.5	1,990.6	1.2	8.00	1	1	1
08/17/2021 18:00	1.7	12.0	2,089.3	1.1	8.40	1	1	1
08/17/2021 19:00	1.8	11.8	2,131.2	1.2	8.50	1	1	1
08/17/2021 20:00	1.7	11.7	2,146.4	1.1	8.60	1	1	1
08/17/2021 21:00	1.7	11.9	2,122.8	1.1	8.50	1	1	1
08/17/2021 22:00	1.6	12.2	2,084.1	1.1	8.30	1	1	1
08/17/2021 23:00	1.5	12.8	1,958.0	1.1	7.80	1	1	1
Average/Sum#:	1.5	12.9	1,875.8	1.1	174.00 #	24 #	24 #	20 #
Minimum:	1.0	11.7	1,450.2	0.8	4.40	1	1	0
Maximum:	1.8	13.9	2,146.4	1.2	8.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/18/2021 00:00	1.1	13.9	1,608.1	0.9	4.80	1	1	0
08/18/2021 01:00	1.1	14.0	1,524.6	0.9	4.60	1	1	1
08/18/2021 02:00	1.5	13.1	1,927.7	1.1	7.70	1	1	1
08/18/2021 03:00	1.5	13.1	1,902.0	1.1	7.60	1	1	1
08/18/2021 04:00	1.2	13.9	1,675.3	1.0	6.70	1	1	0
08/18/2021 05:00	1.2	13.8	1,654.9	1.0	6.60	1	1	1
08/18/2021 06:00	1.5	12.9	1,962.3	1.1	7.80	1	1	1
08/18/2021 07:00	1.5	13.0	1,920.8	1.1	7.70	1	1	1
08/18/2021 08:00	1.2	13.9	1,432.2	1.0	5.70	1	1	0
08/18/2021 09:00	1.0	14.0	1,536.3	0.9	4.60	1	1	0
08/18/2021 10:00	0.0	0.0	1,508.6	0.0	0.00	1	1	0
08/18/2021 11:00	1.0	14.1	1,452.4	0.9	4.40	1	1	0
08/18/2021 12:00	1.0	14.0	1,490.1	0.9	4.50	1	1	1
08/18/2021 13:00	1.6	12.7	2,029.5	1.2	8.10	1	1	1
08/18/2021 14:00	0.6	12.4	2,009.0	0.4	4.00	1	1	1
08/18/2021 15:00	1.2	13.9	1,651.4	1.0	6.60	1	1	0
08/18/2021 16:00	1.0	14.0	1,505.5	0.9	4.50	1	1	0
08/18/2021 17:00	1.6	12.7	1,969.6	1.2	7.90	1	1	1
08/18/2021 18:00	1.7	12.2	2,095.5	1.2	8.40	1	1	1
08/18/2021 19:00	1.6	12.7	1,957.0	1.2	7.80	1	1	1
08/18/2021 20:00	1.2	13.9	1,680.5	1.0	6.70	1	1	0
08/18/2021 21:00	1.3	13.8	1,694.8	1.1	6.80	1	1	1
08/18/2021 22:00	1.6	12.7	1,997.6	1.2	8.00	1	1	1
08/18/2021 23:00	1.6	13.0	1,903.8	1.2	7.60	1	1	1
Average/Sum#:	1.3	13.4	1,753.7	1.0	149.10 #	24 #	24 #	15 #
Minimum:	0.6	12.2	1,432.2	0.4	4.00	1	1	0
Maximum:	1.7	14.1	2,095.5	1.2	8.40	1	1	1
%SI	4.17	4.17	0.00	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/19/2021 00:00	1.2	13.9	1,585.9	1.0	6.30	1	1	0
08/19/2021 01:00	1.2	13.9	1,619.0	1.0	6.50	1	1	0
08/19/2021 02:00	1.1	13.9	1,486.9	0.9	4.50	1	1	0
08/19/2021 03:00	1.0	13.9	1,515.6	0.8	4.50	1	1	1
08/19/2021 04:00	1.6	12.7	1,996.4	1.2	8.00	1	1	1
08/19/2021 05:00	1.6	12.9	1,921.8	1.2	7.70	1	1	1
08/19/2021 06:00	1.2	13.9	1,628.2	1.0	6.50	1	1	0
08/19/2021 07:00	1.2	13.9	1,657.6	1.0	6.60	1	1	0
08/19/2021 08:00	0.9	14.0	1,342.2	0.8	4.00	1	1	0
08/19/2021 09:00	1.1	13.9	1,639.0	0.9	4.90	1	1	0
08/19/2021 10:00	1.1	14.0	1,614.0	0.9	4.80	1	1	0
08/19/2021 11:00	1.1	14.0	1,581.0	0.9	4.70	1	1	0
08/19/2021 12:00	1.3	13.9	1,665.7	1.1	6.70	1	1	1
08/19/2021 13:00	1.6	12.4	2,030.3	1.1	8.10	1	1	1
08/19/2021 14:00	1.6	12.5	1,978.7	1.1	7.90	1	1	1
08/19/2021 15:00	1.2	13.9	1,545.6	1.0	6.20	1	1	0
08/19/2021 16:00	1.3	13.8	1,637.8	1.1	6.60	1	1	1
08/19/2021 17:00	1.6	12.5	2,012.8	1.1	8.10	1	1	1
08/19/2021 18:00	1.7	12.2	2,079.1	1.2	8.30	1	1	1
08/19/2021 19:00	1.6	12.4	2,001.0	1.1	8.00	1	1	1
08/19/2021 20:00	1.2	13.9	1,671.2	1.0	6.70	1	1	0
08/19/2021 21:00	1.2	13.8	1,581.3	1.0	6.30	1	1	1
08/19/2021 22:00	1.6	12.7	1,972.2	1.2	7.90	1	1	1
08/19/2021 23:00	1.6	12.9	1,904.6	1.2	7.60	1	1	1
Average/Sum#:	1.3	13.4	1,736.2	1.0	157.40 #	24 #	24 #	13 #
Minimum:	0.9	12.2	1,342.2	0.8	4.00	1	1	0
Maximum:	1.7	14.0	2,079.1	1.2	8.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/20/2021 00:00	1.2	13.9	1,649.0	1.0	6.60	1	1	0
08/20/2021 01:00	1.2	13.9	1,647.5	1.0	6.60	1	1	0
08/20/2021 02:00	1.2	13.9	1,509.2	1.0	6.00	1	1	0
08/20/2021 03:00	0.9	14.0	1,327.0	0.8	4.00	1	1	0
08/20/2021 04:00	1.1	13.9	1,613.8	0.9	4.80	1	1	0
08/20/2021 05:00	1.2	13.7	1,689.3	1.0	6.80	1	1	1
08/20/2021 06:00	1.4	13.3	1,823.9	1.1	7.30	1	1	1
08/20/2021 07:00	1.2	13.9	1,620.6	1.0	6.50	1	1	0
08/20/2021 08:00	1.1	13.9	1,501.2	0.9	4.50	1	1	0
08/20/2021 09:00	0.9	14.0	1,292.6	0.8	3.90	1	1	0
08/20/2021 10:00	0.9	14.0	1,280.1	0.8	3.80	1	1	0
08/20/2021 11:00	0.9	14.0	1,282.2	0.8	3.80	1	1	0
08/20/2021 12:00	1.1	13.9	1,495.5	0.9	4.50	1	1	1
08/20/2021 13:00	1.6	12.6	1,991.8	1.1	8.00	1	1	1
08/20/2021 14:00	1.6	12.6	1,941.3	1.1	7.80	1	1	1
08/20/2021 15:00	1.2	13.9	1,511.6	1.0	6.00	1	1	0
08/20/2021 16:00	1.1	13.9	1,518.9	0.9	4.60	1	1	0
08/20/2021 17:00	1.6	12.4	2,012.4	1.1	8.00	1	1	1
08/20/2021 18:00	1.7	12.1	2,070.0	1.1	8.30	1	1	1
08/20/2021 19:00	1.7	12.3	2,014.4	1.2	8.10	1	1	1
08/20/2021 20:00	1.2	13.9	1,635.5	1.0	6.50	1	1	0
08/20/2021 21:00	1.4	13.8	1,674.6	1.2	6.70	1	1	1
08/20/2021 22:00	1.6	12.6	1,989.2	1.1	8.00	1	1	1
08/20/2021 23:00	1.6	12.9	1,888.3	1.2	7.60	1	1	1
Average/Sum#:	1.3	13.5	1,665.8	1.0	148.70 #	24 #	24 #	11 #
Minimum:	0.9	12.1	1,280.1	0.8	3.80	1	1	0
Maximum:	1.7	14.0	2,070.0	1.2	8.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/21/2021 00:00	3.5	15.6	587.4	3.9	1.89	1	0	0
08/21/2021 01:00	0.7	17.7	399.7	1.3	0.76	1	0	0
08/21/2021 02:00	2.1	14.4	1,115.1	1.9	7.80	1	0	0
08/21/2021 03:00	0.6	14.0	1,211.7	0.5	2.40	1	1	0
08/21/2021 04:00	0.7	14.0	1,217.6	0.6	2.40	1	1	0
08/21/2021 05:00	0.9	14.0	1,330.2	0.8	4.00	1	1	0
08/21/2021 06:00	1.0	14.0	1,331.2	0.9	4.00	1	1	0
08/21/2021 07:00	1.0	14.0	1,334.0	0.9	4.00	1	1	0
08/21/2021 08:00	1.0	14.0	1,335.8	0.9	4.00	1	1	0
08/21/2021 09:00	1.0	14.0	1,340.2	0.9	4.00	1	1	0
08/21/2021 10:00	1.0	14.0	1,340.9	0.9	4.00	1	1	0
08/21/2021 11:00	1.0	14.0	1,347.3	0.9	4.00	1	1	0
08/21/2021 12:00	1.0	14.0	1,349.1	0.9	4.00	1	1	0
08/21/2021 13:00	1.0	14.0	1,349.4	0.9	4.00	1	1	0
08/21/2021 14:00	1.0	14.0	1,348.0	0.9	4.00	1	1	0
08/21/2021 15:00	1.7	14.6	1,093.6	1.6	5.15	1	0	0
08/21/2021 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/21/2021 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/21/2021 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/21/2021 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/21/2021 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/21/2021 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/21/2021 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/21/2021 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	1.2	14.4	1,189.5	1.2	60.40 #	16 #	12 #	0 #
Minimum:	0.6	14.0	399.7	0.5	0.76	0	0	0
Maximum:	3.5	17.7	1,349.4	3.9	7.80	1	1	0
%SI	33.33	33.33	33.33	33.33	33.33	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/22/2021 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2021 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2021 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2021 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2021 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2021 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2021 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2021 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2021 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2021 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2021 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2021 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2021 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2021 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2021 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2021 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/23/2021 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2021 09:00	26.0	17.6	326.0	46.5	38.99	1	0	0
08/23/2021 10:00	11.0	17.2	389.9	17.5	25.30	1	0	0
08/23/2021 11:00	10.8	15.5	805.7	11.8	34.60	1	0	0
08/23/2021 12:00	1.0	14.8	1,070.5	1.0	2.58	1	0	0
08/23/2021 13:00	5.2	16.9	514.9	7.7	8.35	1	0	0
08/23/2021 14:00	6.9	14.5	1,103.4	6.4	25.40	1	0	0
08/23/2021 15:00	1.1	14.0	1,428.2	0.9	4.30	1	1	0
08/23/2021 16:00	1.2	13.8	1,683.5	1.0	6.70	1	1	0
08/23/2021 17:00	0.0	0.0	1,610.8	0.0	0.00	1	1	0
08/23/2021 18:00	1.2	13.8	1,656.7	1.0	6.60	1	1	0
08/23/2021 19:00	1.4	13.3	1,764.6	1.1	7.10	1	1	1
08/23/2021 20:00	1.5	13.1	1,825.4	1.1	7.30	1	1	1
08/23/2021 21:00	1.4	13.7	1,737.3	1.1	6.90	1	1	1
08/23/2021 22:00	1.6	12.8	1,964.3	1.2	7.90	1	1	1
08/23/2021 23:00	1.6	12.9	1,910.8	1.2	7.60	1	1	1
Average/Sum#:	5.1	14.6	1,319.5	7.1	189.62 #	15 #	9 #	5 #
Minimum:	1.0	12.8	326.0	0.9	2.58	0	0	0
Maximum:	26.0	17.6	1,964.3	46.5	38.99	1	1	1
%SI	41.67	41.67	37.50	41.67	41.67	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/24/2021 00:00	1.2	13.9	1,525.3	1.0	6.10	1	1	0
08/24/2021 01:00	1.3	13.9	1,590.8	1.1	6.40	1	1	0
08/24/2021 02:00	1.2	13.8	1,647.5	1.0	6.60	1	1	1
08/24/2021 03:00	1.5	13.1	1,915.7	1.1	7.70	1	1	1
08/24/2021 04:00	1.5	13.1	1,898.4	1.1	7.60	1	1	1
08/24/2021 05:00	1.2	13.9	1,641.6	1.0	6.60	1	1	0
08/24/2021 06:00	1.2	13.9	1,582.8	1.0	6.30	1	1	0
08/24/2021 07:00	1.2	13.9	1,618.6	1.0	6.50	1	1	0
08/24/2021 08:00	1.2	13.9	1,508.0	1.0	6.00	1	1	0
08/24/2021 09:00	1.2	13.9	1,662.4	1.0	6.60	1	1	0
08/24/2021 10:00	1.3	13.9	1,644.4	1.1	6.60	1	1	0
08/24/2021 11:00	1.2	13.9	1,607.9	1.0	6.40	1	1	0
08/24/2021 12:00	1.2	13.9	1,541.3	1.0	6.20	1	1	0
08/24/2021 13:00	1.2	13.8	1,630.7	1.0	6.50	1	1	1
08/24/2021 14:00	1.6	12.6	2,004.7	1.1	8.00	1	1	1
08/24/2021 15:00	1.6	12.5	2,005.7	1.1	8.00	1	1	1
08/24/2021 16:00	1.4	13.9	1,682.7	1.2	6.70	1	1	0
08/24/2021 17:00	1.4	13.7	1,725.8	1.1	6.90	1	1	1
08/24/2021 18:00	1.6	12.5	2,015.0	1.1	8.10	1	1	1
08/24/2021 19:00	1.7	12.1	2,068.0	1.1	8.30	1	1	1
08/24/2021 20:00	1.2	13.9	1,632.7	1.0	6.50	1	1	0
08/24/2021 21:00	1.4	13.7	1,746.8	1.1	7.00	1	1	1
08/24/2021 22:00	1.6	12.7	1,993.7	1.2	8.00	1	1	1
08/24/2021 23:00	1.6	12.4	2,077.0	1.1	8.30	1	1	1
Average/Sum#:	1.4	13.5	1,748.6	1.1	167.90 #	24 #	24 #	12 #
Minimum:	1.2	12.1	1,508.0	1.0	6.00	1	1	0
Maximum:	1.7	13.9	2,077.0	1.2	8.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/25/2021 00:00	1.3	13.7	1,611.4	1.1	6.40	1	1	1
08/25/2021 01:00	1.3	13.9	1,599.9	1.1	6.40	1	1	0
08/25/2021 02:00	1.2	13.9	1,550.8	1.0	6.20	1	1	1
08/25/2021 03:00	1.5	12.9	1,974.5	1.1	7.90	1	1	1
08/25/2021 04:00	1.6	12.6	2,034.8	1.1	8.10	1	1	1
08/25/2021 05:00	1.5	13.0	1,922.6	1.1	7.70	1	1	1
08/25/2021 06:00	1.2	13.9	1,573.2	1.0	6.30	1	1	0
08/25/2021 07:00	1.1	13.9	1,531.3	0.9	4.60	1	1	0
08/25/2021 08:00	1.1	13.8	1,609.4	0.9	4.80	1	1	1
08/25/2021 09:00	1.6	12.9	1,969.7	1.2	7.90	1	1	1
08/25/2021 10:00	1.5	13.0	1,915.0	1.1	7.70	1	1	1
08/25/2021 11:00	1.3	13.8	1,639.5	1.1	6.60	1	1	1
08/25/2021 12:00	1.2	13.8	1,615.2	1.0	6.50	1	1	1
08/25/2021 13:00	1.6	12.6	2,007.5	1.1	8.00	1	1	1
08/25/2021 14:00	1.6	12.5	1,996.5	1.1	8.00	1	1	1
08/25/2021 15:00	1.1	13.9	1,588.4	0.9	4.80	1	1	0
08/25/2021 16:00	1.0	14.0	1,463.0	0.9	4.40	1	1	1
08/25/2021 17:00	1.5	12.6	1,993.5	1.1	8.00	1	1	1
08/25/2021 18:00	1.7	12.3	2,074.6	1.2	8.30	1	1	1
08/25/2021 19:00	1.6	12.5	1,992.9	1.1	8.00	1	1	1
08/25/2021 20:00	1.2	13.9	1,623.2	1.0	6.50	1	1	0
08/25/2021 21:00	1.3	13.8	1,664.9	1.1	6.70	1	1	1
08/25/2021 22:00	1.6	12.7	1,987.6	1.2	8.00	1	1	1
08/25/2021 23:00	1.5	12.9	1,925.2	1.1	7.70	1	1	1
Average/Sum#:	1.4	13.3	1,786.0	1.1	165.50 #	24 #	24 #	19 #
Minimum:	1.0	12.3	1,463.0	0.9	4.40	1	1	0
Maximum:	1.7	14.0	2,074.6	1.2	8.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/26/2021 00:00	1.2	13.9	1,628.7	1.0	6.50	1	1	0
08/26/2021 01:00	1.3	13.9	1,595.5	1.1	6.40	1	1	0
08/26/2021 02:00	1.0	14.0	1,402.9	0.9	4.20	1	1	0
08/26/2021 03:00	1.1	13.9	1,559.9	0.9	4.70	1	1	1
08/26/2021 04:00	1.6	12.7	2,007.5	1.2	8.00	1	1	1
08/26/2021 05:00	1.6	12.6	2,038.1	1.1	8.20	1	1	1
08/26/2021 06:00	1.3	12.9	1,940.6	1.0	7.80	1	1	1
08/26/2021 07:00	1.2	13.8	1,657.1	1.0	6.60	1	1	1
08/26/2021 08:00	1.1	13.9	1,522.7	0.9	4.60	1	1	0
08/26/2021 09:00	1.4	13.3	1,811.3	1.1	7.20	1	1	1
08/26/2021 10:00	1.5	12.9	1,926.9	1.1	7.70	1	1	1
08/26/2021 11:00	1.3	13.9	1,695.7	1.1	6.80	1	1	0
08/26/2021 12:00	1.4	13.9	1,677.0	1.2	6.70	1	1	0
08/26/2021 13:00	1.6	12.7	1,988.0	1.2	8.00	1	1	1
08/26/2021 14:00	1.6	12.6	1,968.3	1.1	7.90	1	1	1
08/26/2021 15:00	1.3	13.8	1,691.0	1.1	6.80	1	1	0
08/26/2021 16:00	1.3	13.8	1,625.3	1.1	6.50	1	1	1
08/26/2021 17:00	1.6	12.3	1,992.0	1.1	8.00	1	1	1
08/26/2021 18:00	1.6	11.9	2,065.9	1.0	8.30	1	1	1
08/26/2021 19:00	1.6	11.8	2,135.9	1.0	8.50	1	1	1
08/26/2021 20:00	1.7	11.9	2,141.8	1.1	8.60	1	1	1
08/26/2021 21:00	1.7	12.0	2,133.0	1.1	8.50	1	1	1
08/26/2021 22:00	1.7	12.0	2,121.0	1.1	8.50	1	1	1
08/26/2021 23:00	1.6	12.3	2,036.6	1.1	8.10	1	1	1
Average/Sum#:	1.4	13.0	1,848.4	1.1	173.10 #	24 #	24 #	17 #
Minimum:	1.0	11.8	1,402.9	0.9	4.20	1	1	0
Maximum:	1.7	14.0	2,141.8	1.2	8.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/27/2021 00:00	1.3	13.9	1,669.8	1.1	6.70	1	1	0
08/27/2021 01:00	1.2	13.9	1,637.2	1.0	6.50	1	1	0
08/27/2021 02:00	1.4	13.9	1,659.6	1.2	6.60	1	1	0
08/27/2021 03:00	1.4	13.8	1,693.4	1.2	6.80	1	1	1
08/27/2021 04:00	1.6	12.6	2,016.6	1.1	8.10	1	1	1
08/27/2021 05:00	1.6	12.4	2,031.5	1.1	8.10	1	1	1
08/27/2021 06:00	1.2	13.9	1,569.5	1.0	6.30	1	1	0
08/27/2021 07:00	1.2	13.9	1,654.5	1.0	6.60	1	1	0
08/27/2021 08:00	1.1	13.9	1,511.2	0.9	4.50	1	1	0
08/27/2021 09:00	1.5	12.9	1,923.0	1.1	7.70	1	1	1
08/27/2021 10:00	1.6	12.7	1,940.6	1.2	7.80	1	1	1
08/27/2021 11:00	1.4	13.8	1,699.0	1.2	6.80	1	1	0
08/27/2021 12:00	1.4	13.8	1,694.0	1.2	6.80	1	1	1
08/27/2021 13:00	1.6	12.4	2,017.3	1.1	8.10	1	1	1
08/27/2021 14:00	1.7	11.8	2,132.2	1.1	8.50	1	1	1
08/27/2021 15:00	1.7	11.8	2,125.5	1.1	8.50	1	1	1
08/27/2021 16:00	1.7	11.8	2,126.0	1.1	8.50	1	1	1
08/27/2021 17:00	1.7	11.7	2,147.5	1.1	8.60	1	1	1
08/27/2021 18:00	1.7	11.7	2,155.6	1.1	8.60	1	1	1
08/27/2021 19:00	1.7	11.7	2,159.2	1.1	8.60	1	1	1
08/27/2021 20:00	1.7	11.7	2,167.3	1.1	8.70	1	1	1
08/27/2021 21:00	1.7	11.7	2,172.3	1.1	8.70	1	1	1
08/27/2021 22:00	1.7	12.0	2,121.9	1.1	8.50	1	1	1
08/27/2021 23:00	1.6	12.3	2,037.1	1.1	8.10	1	1	1
Average/Sum#:	1.5	12.8	1,919.2	1.1	182.70 #	24 #	24 #	17 #
Minimum:	1.1	11.7	1,511.2	0.9	4.50	1	1	0
Maximum:	1.7	13.9	2,172.3	1.2	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/28/2021 00:00	1.2	13.9	1,656.8	1.0	6.60	1	1	0
08/28/2021 01:00	1.4	13.7	1,736.2	1.1	6.90	1	1	1
08/28/2021 02:00	1.6	12.7	1,996.3	1.2	8.00	1	1	1
08/28/2021 03:00	1.5	13.0	1,904.4	1.1	7.60	1	1	1
08/28/2021 04:00	1.2	13.9	1,626.9	1.0	6.50	1	1	0
08/28/2021 05:00	1.1	14.0	1,626.3	0.9	4.90	1	1	0
08/28/2021 06:00	0.9	14.0	1,610.2	0.8	4.80	1	1	0
08/28/2021 07:00	1.3	13.9	1,635.5	1.1	6.50	1	1	0
08/28/2021 08:00	1.2	14.0	1,614.8	1.0	6.50	1	1	0
08/28/2021 09:00	1.3	13.9	1,633.2	1.1	6.50	1	1	0
08/28/2021 10:00	1.1	13.9	1,609.9	0.9	4.80	1	1	1
08/28/2021 11:00	1.6	12.4	2,030.7	1.1	8.10	1	1	1
08/28/2021 12:00	1.7	12.1	2,043.6	1.1	8.20	1	1	1
08/28/2021 13:00	1.4	13.9	1,665.0	1.2	6.70	1	1	0
08/28/2021 14:00	1.3	13.8	1,683.7	1.1	6.70	1	1	1
08/28/2021 15:00	1.7	12.5	2,004.5	1.2	8.00	1	1	1
08/28/2021 16:00	1.7	11.9	2,102.8	1.1	8.40	1	1	1
08/28/2021 17:00	1.7	11.8	2,129.3	1.1	8.50	1	1	1
08/28/2021 18:00	1.7	11.7	2,152.9	1.1	8.60	1	1	1
08/28/2021 19:00	1.7	11.7	2,168.0	1.1	8.70	1	1	1
08/28/2021 20:00	1.7	11.7	2,172.3	1.1	8.70	1	1	1
08/28/2021 21:00	1.7	11.7	2,159.9	1.1	8.60	1	1	1
08/28/2021 22:00	1.7	12.0	2,114.4	1.1	8.50	1	1	1
08/28/2021 23:00	1.6	12.3	2,064.7	1.1	8.30	1	1	1
Average/Sum#:	1.5	12.9	1,880.9	1.1	175.60 #	24 #	24 #	16 #
Minimum:	0.9	11.7	1,609.9	0.8	4.80	1	1	0
Maximum:	1.7	14.0	2,172.3	1.2	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/29/2021 00:00	1.5	12.7	1,939.1	1.1	7.80	1	1	1
08/29/2021 01:00	1.3	13.9	1,668.0	1.1	6.70	1	1	0
08/29/2021 02:00	1.4	13.7	1,737.0	1.1	6.90	1	1	1
08/29/2021 03:00	1.6	12.6	1,998.1	1.1	8.00	1	1	1
08/29/2021 04:00	1.6	12.5	2,009.1	1.1	8.00	1	1	1
08/29/2021 05:00	1.2	13.9	1,674.9	1.0	6.70	1	1	0
08/29/2021 06:00	0.7	14.0	1,608.9	0.6	3.20	1	1	0
08/29/2021 07:00	0.9	14.0	1,582.5	0.8	4.70	1	1	0
08/29/2021 08:00	1.0	14.0	1,507.1	0.9	4.50	1	1	0
08/29/2021 09:00	1.0	14.0	1,459.3	0.9	4.40	1	1	0
08/29/2021 10:00	1.3	13.2	1,829.3	1.0	7.30	1	1	1
08/29/2021 11:00	1.6	12.7	1,941.2	1.2	7.80	1	1	1
08/29/2021 12:00	1.4	13.7	1,691.1	1.1	6.80	1	1	1
08/29/2021 13:00	1.3	13.8	1,676.6	1.1	6.70	1	1	1
08/29/2021 14:00	1.7	12.2	2,029.1	1.2	8.10	1	1	1
08/29/2021 15:00	1.8	11.9	2,090.9	1.2	8.40	1	1	1
08/29/2021 16:00	1.8	11.8	2,104.8	1.2	8.40	1	1	1
08/29/2021 17:00	1.8	11.7	2,135.4	1.2	8.50	1	1	1
08/29/2021 18:00	1.7	11.7	2,142.8	1.1	8.60	1	1	1
08/29/2021 19:00	1.7	11.6	2,153.2	1.1	8.60	1	1	1
08/29/2021 20:00	1.7	11.6	2,151.1	1.1	8.60	1	1	1
08/29/2021 21:00	1.8	11.7	2,152.1	1.2	8.60	1	1	1
08/29/2021 22:00	1.7	11.9	2,111.7	1.1	8.40	1	1	1
08/29/2021 23:00	1.6	12.4	1,995.4	1.1	8.00	1	1	1
Average/Sum#:	1.5	12.8	1,891.2	1.1	173.70 #	24 #	24 #	18 #
Minimum:	0.7	11.6	1,459.3	0.6	3.20	1	1	0
Maximum:	1.8	14.0	2,153.2	1.2	8.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/30/2021 00:00	1.3	13.9	1,606.5	1.1	6.40	1	1	0
08/30/2021 01:00	1.4	13.9	1,649.1	1.2	6.60	1	1	1
08/30/2021 02:00	1.6	12.9	1,922.4	1.2	7.70	1	1	1
08/30/2021 03:00	1.6	12.4	2,007.4	1.1	8.00	1	1	1
08/30/2021 04:00	1.2	13.9	1,614.9	1.0	6.50	1	1	0
08/30/2021 05:00	1.2	13.9	1,515.2	1.0	6.10	1	1	1
08/30/2021 06:00	1.4	12.6	1,998.3	1.0	8.00	1	1	1
08/30/2021 07:00	1.6	12.6	1,971.3	1.1	7.90	1	1	1
08/30/2021 08:00	1.2	13.9	1,653.8	1.0	6.60	1	1	0
08/30/2021 09:00	1.3	13.8	1,626.1	1.1	6.50	1	1	0
08/30/2021 10:00	1.5	12.9	1,878.6	1.1	7.50	1	1	1
08/30/2021 11:00	1.7	12.2	2,025.1	1.2	8.10	1	1	1
08/30/2021 12:00	1.3	13.8	1,674.3	1.1	6.70	1	1	0
08/30/2021 13:00	1.3	13.8	1,660.1	1.1	6.60	1	1	1
08/30/2021 14:00	1.7	12.2	2,036.4	1.2	8.10	1	1	1
08/30/2021 15:00	1.8	11.9	2,102.3	1.2	8.40	1	1	1
08/30/2021 16:00	1.7	11.8	2,107.2	1.1	8.40	1	1	1
08/30/2021 17:00	1.8	11.7	2,130.7	1.2	8.50	1	1	1
08/30/2021 18:00	1.8	11.7	2,142.2	1.2	8.60	1	1	1
08/30/2021 19:00	1.8	11.7	2,156.9	1.2	8.60	1	1	1
08/30/2021 20:00	1.7	11.7	2,174.6	1.1	8.70	1	1	1
08/30/2021 21:00	1.7	11.8	2,160.1	1.1	8.60	1	1	1
08/30/2021 22:00	1.7	12.0	2,115.2	1.1	8.50	1	1	1
08/30/2021 23:00	1.7	12.3	2,018.7	1.2	8.10	1	1	1
Average/Sum#:	1.5	12.7	1,914.5	1.1	183.70 #	24 #	24 #	19 #
Minimum:	1.2	11.7	1,515.2	1.0	6.10	1	1	0
Maximum:	1.8	13.9	2,174.6	1.2	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/31/2021 00:00	1.3	13.9	1,636.0	1.1	6.50	1	1	0
08/31/2021 01:00	1.3	13.9	1,658.1	1.1	6.60	1	1	0
08/31/2021 02:00	0.9	14.0	1,300.0	0.8	3.90	1	1	0
08/31/2021 03:00	1.2	13.9	1,624.7	1.0	6.50	1	1	0
08/31/2021 04:00	1.5	13.4	1,803.6	1.2	7.20	1	1	1
08/31/2021 05:00	1.5	13.1	1,865.3	1.1	7.50	1	1	1
08/31/2021 06:00	1.3	13.7	1,754.2	1.1	7.00	1	1	0
08/31/2021 07:00	1.6	12.9	1,955.2	1.2	7.80	1	1	1
08/31/2021 08:00	1.6	12.4	2,032.1	1.1	8.10	1	1	1
08/31/2021 09:00	1.2	13.9	1,652.5	1.0	6.60	1	1	0
08/31/2021 10:00	1.3	13.8	1,668.9	1.1	6.70	1	1	0
08/31/2021 11:00	1.6	12.7	1,956.3	1.2	7.80	1	1	1
08/31/2021 12:00	1.6	12.3	2,026.7	1.1	8.10	1	1	1
08/31/2021 13:00	1.2	13.8	1,629.0	1.0	6.50	1	1	0
08/31/2021 14:00	1.2	13.8	1,684.7	1.0	6.70	1	1	0
08/31/2021 15:00	1.6	12.6	1,961.7	1.1	7.80	1	1	1
08/31/2021 16:00	1.7	12.0	2,097.3	1.1	8.40	1	1	1
08/31/2021 17:00	1.8	11.9	2,110.4	1.2	8.40	1	1	1
08/31/2021 18:00	1.7	11.9	2,121.2	1.1	8.50	1	1	1
08/31/2021 19:00	1.7	12.0	2,055.1	1.1	8.20	1	1	1
08/31/2021 20:00	1.2	13.9	1,625.0	1.0	6.50	1	1	0
08/31/2021 21:00	1.4	13.8	1,679.2	1.2	6.70	1	1	1
08/31/2021 22:00	1.6	12.7	1,983.2	1.2	7.90	1	1	1
08/31/2021 23:00	1.6	12.4	2,052.6	1.1	8.20	1	1	1
Average/Sum#:	1.4	13.1	1,830.5	1.1	174.10 #	24 #	24 #	14 #
Minimum:	0.9	11.9	1,300.0	0.8	3.90	1	1	0
Maximum:	1.8	14.0	2,121.2	1.2	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/01/2021 00:00	1.6	12.3	2,081.8	1.1	8.30	1	1	1
09/01/2021 01:00	1.5	13.0	1,906.7	1.1	7.60	1	1	1
09/01/2021 02:00	1.1	13.9	1,576.1	0.9	4.70	1	1	0
09/01/2021 03:00	1.3	13.8	1,676.1	1.1	6.70	1	1	1
09/01/2021 04:00	1.6	12.8	1,977.0	1.2	7.90	1	1	1
09/01/2021 05:00	1.6	12.4	2,078.6	1.1	8.30	1	1	1
09/01/2021 06:00	1.3	12.9	1,966.2	1.0	7.90	1	1	1
09/01/2021 07:00	1.1	13.9	1,661.3	0.9	5.00	1	1	0
09/01/2021 08:00	1.1	13.9	1,597.6	0.9	4.80	1	1	0
09/01/2021 09:00	1.5	13.2	1,854.8	1.1	7.40	1	1	1
09/01/2021 10:00	1.5	12.9	1,950.3	1.1	7.80	1	1	1
09/01/2021 11:00	1.2	13.7	1,466.1	1.0	5.90	1	1	1
09/01/2021 12:00	1.1	13.9	1,524.8	0.9	4.60	1	1	1
09/01/2021 13:00	1.6	12.8	1,946.4	1.2	7.80	1	1	1
09/01/2021 14:00	1.6	12.7	1,945.1	1.2	7.80	1	1	1
09/01/2021 15:00	1.3	13.6	1,661.0	1.1	6.60	1	1	1
09/01/2021 16:00	1.3	13.8	1,667.9	1.1	6.70	1	1	1
09/01/2021 17:00	1.6	12.5	2,009.8	1.1	8.00	1	1	1
09/01/2021 18:00	1.7	12.3	2,060.5	1.2	8.20	1	1	1
09/01/2021 19:00	1.6	12.3	2,048.1	1.1	8.20	1	1	1
09/01/2021 20:00	1.3	13.9	1,657.5	1.1	6.60	1	1	0
09/01/2021 21:00	1.0	14.0	1,370.0	0.9	4.10	1	1	0
09/01/2021 22:00	1.1	13.9	1,614.6	0.9	4.80	1	1	0
09/01/2021 23:00	1.2	13.9	1,680.2	1.0	6.70	1	1	0
Average/Sum#:	1.4	13.3	1,790.8	1.1	162.40 #	24 #	24 #	17 #
Minimum:	1.0	12.3	1,370.0	0.9	4.10	1	1	0
Maximum:	1.7	14.0	2,081.8	1.2	8.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/02/2021 00:00	1.5	13.3	1,820.1	1.2	7.30	1	1	1
09/02/2021 01:00	1.5	13.1	1,836.4	1.1	7.30	1	1	1
09/02/2021 02:00	1.0	14.0	1,349.8	0.9	4.00	1	1	0
09/02/2021 03:00	1.2	13.9	1,652.6	1.0	6.60	1	1	0
09/02/2021 04:00	1.0	14.0	1,379.3	0.9	4.10	1	1	0
09/02/2021 05:00	1.1	13.9	1,628.2	0.9	4.90	1	1	0
09/02/2021 06:00	1.2	13.4	1,789.2	0.9	5.40	1	1	1
09/02/2021 07:00	1.4	13.3	1,819.9	1.1	7.30	1	1	1
09/02/2021 08:00	1.0	14.0	1,345.5	0.9	4.00	1	1	0
09/02/2021 09:00	1.1	14.0	1,433.5	0.9	4.30	1	1	0
09/02/2021 10:00	1.1	14.0	1,488.2	0.9	4.50	1	1	0
09/02/2021 11:00	1.1	14.0	1,408.5	0.9	4.20	1	1	0
09/02/2021 12:00	1.3	13.9	1,663.3	1.1	6.70	1	1	1
09/02/2021 13:00	1.6	12.7	1,986.4	1.2	7.90	1	1	1
09/02/2021 14:00	1.6	12.7	1,948.3	1.2	7.80	1	1	1
09/02/2021 15:00	1.2	13.9	1,644.9	1.0	6.60	1	1	0
09/02/2021 16:00	1.3	13.9	1,601.5	1.1	6.40	1	1	1
09/02/2021 17:00	1.6	12.5	2,010.0	1.1	8.00	1	1	1
09/02/2021 18:00	1.6	12.3	2,048.2	1.1	8.20	1	1	1
09/02/2021 19:00	1.6	12.4	2,013.3	1.1	8.10	1	1	1
09/02/2021 20:00	1.1	13.9	1,551.2	0.9	4.70	1	1	0
09/02/2021 21:00	1.0	14.0	1,377.3	0.9	4.10	1	1	0
09/02/2021 22:00	1.2	14.0	1,588.1	1.0	6.40	1	1	0
09/02/2021 23:00	1.4	13.4	1,796.9	1.1	7.20	1	1	1
Average/Sum#:	1.3	13.5	1,674.2	1.0	146.00 #	24 #	24 #	12 #
Minimum:	1.0	12.3	1,345.5	0.9	4.00	1	1	0
Maximum:	1.6	14.0	2,048.2	1.2	8.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/03/2021 00:00	1.5	13.0	1,859.7	1.1	7.40	1	1	1
09/03/2021 01:00	1.2	13.8	1,583.7	1.0	6.30	1	1	0
09/03/2021 02:00	1.4	13.8	1,753.5	1.2	7.00	1	1	1
09/03/2021 03:00	1.5	13.2	1,905.9	1.1	7.60	1	1	1
09/03/2021 04:00	1.2	13.9	1,555.9	1.0	6.20	1	1	0
09/03/2021 05:00	1.3	13.7	1,728.4	1.1	6.90	1	1	1
09/03/2021 06:00	1.5	12.8	1,994.8	1.1	8.00	1	1	1
09/03/2021 07:00	1.5	13.0	1,928.5	1.1	7.70	1	1	1
09/03/2021 08:00	1.1	13.9	1,684.3	0.9	5.10	1	1	0
09/03/2021 09:00	1.1	14.0	1,501.1	0.9	4.50	1	1	0
09/03/2021 10:00	1.2	14.0	1,586.8	1.0	6.30	1	1	0
09/03/2021 11:00	1.2	14.0	1,583.6	1.0	6.30	1	1	0
09/03/2021 12:00	1.3	14.0	1,592.1	1.1	6.40	1	1	0
09/03/2021 13:00	1.2	13.9	1,599.0	1.0	6.40	1	1	0
09/03/2021 14:00	1.0	14.0	1,522.3	0.9	4.60	1	1	1
09/03/2021 15:00	1.6	12.5	2,014.9	1.1	8.10	1	1	1
09/03/2021 16:00	1.7	12.2	2,079.3	1.2	8.30	1	1	1
09/03/2021 17:00	1.7	12.0	2,133.2	1.1	8.50	1	1	1
09/03/2021 18:00	1.7	12.0	2,133.0	1.1	8.50	1	1	1
09/03/2021 19:00	1.7	12.2	2,047.7	1.2	8.20	1	1	1
09/03/2021 20:00	1.2	13.9	1,664.3	1.0	6.70	1	1	0
09/03/2021 21:00	1.4	13.7	1,746.3	1.1	7.00	1	1	1
09/03/2021 22:00	1.6	12.8	1,970.5	1.2	7.90	1	1	1
09/03/2021 23:00	1.5	13.0	1,919.6	1.1	7.70	1	1	1
Average/Sum#:	1.4	13.3	1,795.4	1.1	167.60 #	24 #	24 #	15 #
Minimum:	1.0	12.0	1,501.1	0.9	4.50	1	1	0
Maximum:	1.7	14.0	2,133.2	1.2	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/04/2021 00:00	1.2	13.9	1,611.0	1.0	6.40	1	1	0
09/04/2021 01:00	1.3	13.8	1,630.6	1.1	6.50	1	1	1
09/04/2021 02:00	1.6	12.8	1,976.7	1.2	7.90	1	1	1
09/04/2021 03:00	2.3	14.1	1,256.5	2.0	4.40	1	0	1
09/04/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/04/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/04/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/04/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/04/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/04/2021 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/04/2021 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/04/2021 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/04/2021 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/04/2021 13:00	18.2	17.9	342.7	35.8	20.34	1	0	0
09/04/2021 14:00	10.5	14.6	1,155.5	9.8	41.60	1	0	0
09/04/2021 15:00	1.3	13.9	1,692.1	1.1	6.80	1	1	0
09/04/2021 16:00	1.2	13.9	1,569.7	1.0	6.30	1	1	1
09/04/2021 17:00	1.6	12.3	2,053.5	1.1	8.20	1	1	1
09/04/2021 18:00	1.6	11.8	2,152.4	1.0	8.60	1	1	1
09/04/2021 19:00	1.7	11.8	2,165.8	1.1	8.70	1	1	1
09/04/2021 20:00	1.7	12.0	2,115.0	1.1	8.50	1	1	1
09/04/2021 21:00	1.7	12.2	2,078.6	1.2	8.30	1	1	1
09/04/2021 22:00	1.6	12.5	2,041.4	1.1	8.20	1	1	1
09/04/2021 23:00	1.6	12.5	2,032.9	1.1	8.10	1	1	1
Average/Sum#:	3.3	13.3	1,725.0	4.0	158.84 #	15 #	12 #	11 #
Minimum:	1.2	11.8	342.7	1.0	4.40	0	0	0
Maximum:	18.2	17.9	2,165.8	35.8	41.60	1	1	1
%SI	37.50	37.50	37.50	37.50	37.50	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/05/2021 00:00	1.5	12.9	1,927.6	1.1	7.70	1	1	1
09/05/2021 01:00	1.2	13.9	1,620.3	1.0	6.50	1	1	0
09/05/2021 02:00	1.2	13.9	1,625.8	1.0	6.50	1	1	1
09/05/2021 03:00	1.5	12.9	1,979.6	1.1	7.90	1	1	1
09/05/2021 04:00	1.5	13.1	1,907.7	1.1	7.60	1	1	1
09/05/2021 05:00	1.2	13.9	1,611.0	1.0	6.40	1	1	0
09/05/2021 06:00	1.3	13.9	1,600.6	1.1	6.40	1	1	0
09/05/2021 07:00	1.3	13.9	1,574.7	1.1	6.30	1	1	0
09/05/2021 08:00	1.3	13.9	1,605.3	1.1	6.40	1	1	0
09/05/2021 09:00	1.3	13.9	1,594.3	1.1	6.40	1	1	0
09/05/2021 10:00	1.3	13.9	1,662.0	1.1	6.60	1	1	0
09/05/2021 11:00	1.4	13.9	1,688.3	1.2	6.80	1	1	0
09/05/2021 12:00	1.4	13.9	1,678.0	1.2	6.70	1	1	0
09/05/2021 13:00	1.3	13.8	1,697.1	1.1	6.80	1	1	0
09/05/2021 14:00	1.6	12.6	1,961.0	1.1	7.80	1	1	1
09/05/2021 15:00	1.7	12.1	2,105.8	1.1	8.40	1	1	1
09/05/2021 16:00	1.7	11.9	2,123.3	1.1	8.50	1	1	1
09/05/2021 17:00	1.7	11.8	2,151.0	1.1	8.60	1	1	1
09/05/2021 18:00	1.7	11.9	2,144.8	1.1	8.60	1	1	1
09/05/2021 19:00	1.7	11.8	2,169.3	1.1	8.70	1	1	1
09/05/2021 20:00	1.7	12.0	2,115.9	1.1	8.50	1	1	1
09/05/2021 21:00	1.6	12.2	2,081.0	1.1	8.30	1	1	1
09/05/2021 22:00	1.6	12.3	2,064.4	1.1	8.30	1	1	1
09/05/2021 23:00	1.6	12.6	1,988.2	1.1	8.00	1	1	1
Average/Sum#:	1.5	13.0	1,861.5	1.1	178.70 #	24 #	24 #	14 #
Minimum:	1.2	11.8	1,574.7	1.0	6.30	1	1	0
Maximum:	1.7	13.9	2,169.3	1.2	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/06/2021 00:00	1.3	13.9	1,611.5	1.1	6.40	1	1	0
09/06/2021 01:00	1.1	13.9	1,602.2	0.9	4.80	1	1	1
09/06/2021 02:00	1.5	12.9	1,951.6	1.1	7.80	1	1	1
09/06/2021 03:00	1.5	12.8	1,936.4	1.1	7.70	1	1	1
09/06/2021 04:00	1.1	13.9	1,574.6	0.9	4.70	1	1	0
09/06/2021 05:00	1.3	13.9	1,640.8	1.1	6.60	1	1	0
09/06/2021 06:00	1.2	13.9	1,598.6	1.0	6.40	1	1	0
09/06/2021 07:00	1.2	14.0	1,607.7	1.0	6.40	1	1	0
09/06/2021 08:00	1.3	14.0	1,676.8	1.1	6.70	1	1	0
09/06/2021 09:00	1.0	14.0	1,541.7	0.9	4.60	1	1	0
09/06/2021 10:00	1.3	13.9	1,659.9	1.1	6.60	1	1	0
09/06/2021 11:00	1.3	13.9	1,649.8	1.1	6.60	1	1	1
09/06/2021 12:00	1.6	12.4	2,054.8	1.1	8.20	1	1	1
09/06/2021 13:00	1.7	11.9	2,138.3	1.1	8.60	1	1	1
09/06/2021 14:00	1.7	11.9	2,133.5	1.1	8.50	1	1	1
09/06/2021 15:00	1.7	11.9	2,138.4	1.1	8.60	1	1	1
09/06/2021 16:00	1.7	11.8	2,146.6	1.1	8.60	1	1	1
09/06/2021 17:00	1.7	11.7	2,160.6	1.1	8.60	1	1	1
09/06/2021 18:00	1.7	11.7	2,170.0	1.1	8.70	1	1	1
09/06/2021 19:00	1.7	11.7	2,174.2	1.1	8.70	1	1	1
09/06/2021 20:00	1.7	11.7	2,181.4	1.1	8.70	1	1	1
09/06/2021 21:00	1.7	11.9	2,157.0	1.1	8.60	1	1	1
09/06/2021 22:00	1.7	12.1	2,102.0	1.1	8.40	1	1	1
09/06/2021 23:00	1.6	12.5	2,005.8	1.1	8.00	1	1	1
Average/Sum#:	1.5	12.8	1,900.6	1.1	177.50 #	24 #	24 #	16 #
Minimum:	1.0	11.7	1,541.7	0.9	4.60	1	1	0
Maximum:	1.7	14.0	2,181.4	1.1	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/07/2021 00:00	1.2	13.9	1,672.9	1.0	6.70	1	1	0
09/07/2021 01:00	1.3	13.8	1,643.2	1.1	6.60	1	1	1
09/07/2021 02:00	1.6	12.6	2,000.5	1.1	8.00	1	1	1
09/07/2021 03:00	1.6	12.8	1,926.6	1.2	7.70	1	1	1
09/07/2021 04:00	1.2	13.9	1,674.9	1.0	6.70	1	1	0
09/07/2021 05:00	1.4	13.7	1,751.0	1.1	7.00	1	1	1
09/07/2021 06:00	1.4	12.7	1,980.7	1.0	7.90	1	1	1
09/07/2021 07:00	1.5	12.8	1,949.2	1.1	7.80	1	1	1
09/07/2021 08:00	1.3	13.9	1,663.9	1.1	6.70	1	1	0
09/07/2021 09:00	1.3	13.8	1,704.1	1.1	6.80	1	1	0
09/07/2021 10:00	1.6	12.7	1,950.0	1.2	7.80	1	1	1
09/07/2021 11:00	1.7	11.9	2,116.0	1.1	8.50	1	1	1
09/07/2021 12:00	1.7	12.0	2,106.0	1.1	8.40	1	1	1
09/07/2021 13:00	1.7	12.0	2,086.1	1.1	8.30	1	1	1
09/07/2021 14:00	1.7	12.0	2,075.8	1.1	8.30	1	1	1
09/07/2021 15:00	1.7	11.9	2,084.2	1.1	8.30	1	1	1
09/07/2021 16:00	1.7	11.8	2,100.8	1.1	8.40	1	1	1
09/07/2021 17:00	1.7	11.9	2,098.9	1.1	8.40	1	1	1
09/07/2021 18:00	1.6	12.2	2,069.4	1.1	8.30	1	1	1
09/07/2021 19:00	1.6	12.3	2,054.6	1.1	8.20	1	1	1
09/07/2021 20:00	1.6	12.3	2,057.0	1.1	8.20	1	1	1
09/07/2021 21:00	1.7	11.9	2,144.3	1.1	8.60	1	1	1
09/07/2021 22:00	1.7	11.8	2,171.2	1.1	8.70	1	1	1
09/07/2021 23:00	1.7	11.8	2,171.2	1.1	8.70	1	1	1
Average/Sum#:	1.6	12.6	1,968.9	1.1	189.00 #	24 #	24 #	20 #
Minimum:	1.2	11.8	1,643.2	1.0	6.60	1	1	0
Maximum:	1.7	13.9	2,171.2	1.2	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/08/2021 00:00	1.7	11.9	2,156.8	1.1	8.60	1	1	1
09/08/2021 01:00	1.6	12.1	2,096.0	1.1	8.40	1	1	1
09/08/2021 02:00	1.6	12.3	2,050.5	1.1	8.20	1	1	1
09/08/2021 03:00	1.6	12.3	2,061.1	1.1	8.20	1	1	1
09/08/2021 04:00	1.7	11.9	2,148.5	1.1	8.60	1	1	1
09/08/2021 05:00	1.7	11.8	2,168.0	1.1	8.70	1	1	1
09/08/2021 06:00	1.4	12.0	2,142.3	0.9	6.40	1	1	1
09/08/2021 07:00	1.6	12.6	1,965.9	1.1	7.90	1	1	1
09/08/2021 08:00	1.3	13.9	1,676.1	1.1	6.70	1	1	0
09/08/2021 09:00	1.3	13.8	1,685.5	1.1	6.70	1	1	0
09/08/2021 10:00	1.6	12.6	1,964.2	1.1	7.90	1	1	1
09/08/2021 11:00	1.7	11.9	2,110.4	1.1	8.40	1	1	1
09/08/2021 12:00	1.7	12.0	2,093.6	1.1	8.40	1	1	1
09/08/2021 13:00	1.7	11.9	2,093.3	1.1	8.40	1	1	1
09/08/2021 14:00	1.7	11.8	2,094.3	1.1	8.40	1	1	1
09/08/2021 15:00	1.7	11.8	2,093.8	1.1	8.40	1	1	1
09/08/2021 16:00	1.8	11.7	2,112.4	1.2	8.40	1	1	1
09/08/2021 17:00	1.7	11.6	2,131.5	1.1	8.50	1	1	1
09/08/2021 18:00	1.7	11.7	2,133.7	1.1	8.50	1	1	1
09/08/2021 19:00	1.7	11.7	2,151.0	1.1	8.60	1	1	1
09/08/2021 20:00	1.7	11.8	2,141.7	1.1	8.60	1	1	1
09/08/2021 21:00	1.7	12.0	2,099.7	1.1	8.40	1	1	1
09/08/2021 22:00	1.7	12.1	2,074.7	1.1	8.30	1	1	1
09/08/2021 23:00	1.7	11.8	2,139.9	1.1	8.60	1	1	1
Average/Sum#:	1.6	12.1	2,066.0	1.1	196.20 #	24 #	24 #	22 #
Minimum:	1.3	11.6	1,676.1	0.9	6.40	1	1	0
Maximum:	1.8	13.9	2,168.0	1.2	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/09/2021 00:00	1.7	11.7	2,150.4	1.1	8.60	1	1	1
09/09/2021 01:00	1.7	11.7	2,162.9	1.1	8.70	1	1	1
09/09/2021 02:00	1.7	11.8	2,171.9	1.1	8.70	1	1	1
09/09/2021 03:00	1.7	11.8	2,166.9	1.1	8.70	1	1	1
09/09/2021 04:00	1.7	11.8	2,170.0	1.1	8.70	1	1	1
09/09/2021 05:00	1.7	11.8	2,168.6	1.1	8.70	1	1	1
09/09/2021 06:00	1.6	11.8	2,162.1	1.0	8.60	1	1	1
09/09/2021 07:00	1.6	12.0	2,120.0	1.1	8.50	1	1	1
09/09/2021 08:00	1.7	12.0	2,109.4	1.1	8.40	1	1	1
09/09/2021 09:00	1.7	12.0	2,111.2	1.1	8.40	1	1	1
09/09/2021 10:00	1.7	11.9	2,107.8	1.1	8.40	1	1	1
09/09/2021 11:00	1.7	11.9	2,095.8	1.1	8.40	1	1	1
09/09/2021 12:00	1.7	11.9	2,078.2	1.1	8.30	1	1	1
09/09/2021 13:00	1.7	11.8	2,088.3	1.1	8.40	1	1	1
09/09/2021 14:00	1.7	11.9	2,075.2	1.1	8.30	1	1	1
09/09/2021 15:00	1.7	11.9	2,068.6	1.1	8.30	1	1	1
09/09/2021 16:00	1.7	11.8	2,085.2	1.1	8.30	1	1	1
09/09/2021 17:00	1.8	11.8	2,095.3	1.2	8.40	1	1	1
09/09/2021 18:00	1.8	11.7	2,128.4	1.2	8.50	1	1	1
09/09/2021 19:00	1.7	11.7	2,136.7	1.1	8.50	1	1	1
09/09/2021 20:00	1.8	11.7	2,145.8	1.2	8.60	1	1	1
09/09/2021 21:00	1.7	11.7	2,152.6	1.1	8.60	1	1	1
09/09/2021 22:00	1.7	11.8	2,125.0	1.1	8.50	1	1	1
09/09/2021 23:00	1.7	11.8	2,138.2	1.1	8.60	1	1	1
Average/Sum#:	1.7	11.8	2,125.6	1.1	204.10 #	24 #	24 #	24 #
Minimum:	1.6	11.7	2,068.6	1.0	8.30	1	1	1
Maximum:	1.8	12.0	2,171.9	1.2	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/10/2021 00:00	1.7	12.1	2,054.4	1.1	8.20	1	1	1
09/10/2021 01:00	1.2	13.9	1,559.1	1.0	6.20	1	1	0
09/10/2021 02:00	1.4	13.7	1,715.5	1.1	6.90	1	1	1
09/10/2021 03:00	1.6	12.5	2,014.5	1.1	8.10	1	1	1
09/10/2021 04:00	1.7	11.8	2,142.7	1.1	8.60	1	1	1
09/10/2021 05:00	1.7	12.0	2,107.5	1.1	8.40	1	1	1
09/10/2021 06:00	1.7	11.8	2,151.7	1.1	8.60	1	1	1
09/10/2021 07:00	1.3	13.5	1,616.2	1.0	6.50	1	1	1
09/10/2021 08:00	1.2	13.9	1,489.7	1.0	6.00	1	1	0
09/10/2021 09:00	1.2	13.8	1,610.2	1.0	6.40	1	1	0
09/10/2021 10:00	1.2	13.8	1,581.7	1.0	6.30	1	1	1
09/10/2021 11:00	1.6	12.5	1,984.7	1.1	7.90	1	1	1
09/10/2021 12:00	1.6	12.4	1,966.8	1.1	7.90	1	1	1
09/10/2021 13:00	1.3	13.9	1,573.7	1.1	6.30	1	1	0
09/10/2021 14:00	1.4	13.8	1,687.7	1.2	6.80	1	1	1
09/10/2021 15:00	1.6	12.4	2,008.9	1.1	8.00	1	1	1
09/10/2021 16:00	1.7	12.1	2,063.9	1.1	8.30	1	1	1
09/10/2021 17:00	1.7	11.9	2,112.9	1.1	8.50	1	1	1
09/10/2021 18:00	1.7	11.8	2,129.9	1.1	8.50	1	1	1
09/10/2021 19:00	1.7	11.8	2,130.3	1.1	8.50	1	1	1
09/10/2021 20:00	1.7	11.8	2,129.3	1.1	8.50	1	1	1
09/10/2021 21:00	1.7	11.9	2,130.3	1.1	8.50	1	1	1
09/10/2021 22:00	1.6	12.1	2,074.7	1.1	8.30	1	1	1
09/10/2021 23:00	1.6	12.4	2,012.8	1.1	8.10	1	1	1
Average/Sum#:	1.5	12.7	1,918.7	1.1	184.30 #	24 #	24 #	20 #
Minimum:	1.2	11.8	1,489.7	1.0	6.00	1	1	0
Maximum:	1.7	13.9	2,151.7	1.2	8.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/11/2021 00:00	1.5	12.9	1,893.7	1.1	7.60	1	1	1
09/11/2021 01:00	1.2	13.9	1,667.0	1.0	6.70	1	1	0
09/11/2021 02:00	1.3	13.9	1,652.8	1.1	6.60	1	1	0
09/11/2021 03:00	1.1	13.8	1,545.8	0.9	4.60	1	1	1
09/11/2021 04:00	1.6	12.7	1,979.6	1.2	7.90	1	1	1
09/11/2021 05:00	1.5	12.9	1,909.7	1.1	7.60	1	1	1
09/11/2021 06:00	1.2	13.9	1,632.8	1.0	6.50	1	1	0
09/11/2021 07:00	1.2	13.9	1,604.3	1.0	6.40	1	1	0
09/11/2021 08:00	1.1	13.9	1,499.9	0.9	4.50	1	1	0
09/11/2021 09:00	1.2	13.9	1,581.0	1.0	6.30	1	1	0
09/11/2021 10:00	1.4	13.8	1,663.1	1.2	6.70	1	1	0
09/11/2021 11:00	1.3	13.8	1,644.5	1.1	6.60	1	1	1
09/11/2021 12:00	1.6	12.6	2,005.0	1.1	8.00	1	1	1
09/11/2021 13:00	1.6	12.4	1,992.6	1.1	8.00	1	1	1
09/11/2021 14:00	1.3	13.9	1,656.8	1.1	6.60	1	1	0
09/11/2021 15:00	1.4	13.7	1,694.0	1.1	6.80	1	1	1
09/11/2021 16:00	1.6	12.5	2,007.0	1.1	8.00	1	1	1
09/11/2021 17:00	1.7	11.8	2,158.4	1.1	8.60	1	1	1
09/11/2021 18:00	1.7	11.8	2,135.8	1.1	8.50	1	1	1
09/11/2021 19:00	1.7	12.1	2,084.2	1.1	8.30	1	1	1
09/11/2021 20:00	1.7	11.9	2,125.6	1.1	8.50	1	1	1
09/11/2021 21:00	1.7	11.9	2,143.5	1.1	8.60	1	1	1
09/11/2021 22:00	1.7	12.1	2,102.3	1.1	8.40	1	1	1
09/11/2021 23:00	1.7	12.1	2,119.4	1.1	8.50	1	1	1
Average/Sum#:	1.5	13.0	1,854.1	1.1	174.80 #	24 #	24 #	16 #
Minimum:	1.1	11.8	1,499.9	0.9	4.50	1	1	0
Maximum:	1.7	13.9	2,158.4	1.2	8.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/12/2021 00:00	1.6	12.5	1,988.3	1.1	8.00	1	1	1
09/12/2021 01:00	1.2	13.9	1,666.9	1.0	6.70	1	1	0
09/12/2021 02:00	1.3	13.9	1,627.1	1.1	6.50	1	1	0
09/12/2021 03:00	1.1	13.8	1,616.9	0.9	4.90	1	1	1
09/12/2021 04:00	1.7	12.8	1,972.6	1.2	9.90	1	1	1
09/12/2021 05:00	1.6	13.0	1,909.9	1.2	7.60	1	1	1
09/12/2021 06:00	0.9	13.8	1,520.2	0.7	4.60	1	1	1
09/12/2021 07:00	1.2	13.9	1,562.6	1.0	6.30	1	1	0
09/12/2021 08:00	0.9	14.0	1,340.4	0.8	4.00	1	1	0
09/12/2021 09:00	0.9	14.0	1,277.1	0.8	3.80	1	1	0
09/12/2021 10:00	1.2	13.8	1,634.2	1.0	6.50	1	1	0
09/12/2021 11:00	1.3	13.8	1,693.6	1.1	6.80	1	1	1
09/12/2021 12:00	1.6	12.5	2,001.0	1.1	8.00	1	1	1
09/12/2021 13:00	1.7	12.1	2,043.8	1.1	8.20	1	1	1
09/12/2021 14:00	1.3	13.9	1,631.2	1.1	6.50	1	1	0
09/12/2021 15:00	1.2	13.8	1,617.1	1.0	6.50	1	1	1
09/12/2021 16:00	1.7	12.3	2,024.9	1.2	8.10	1	1	1
09/12/2021 17:00	1.7	11.8	2,145.6	1.1	8.60	1	1	1
09/12/2021 18:00	1.7	11.9	2,119.4	1.1	8.50	1	1	1
09/12/2021 19:00	1.7	12.1	2,087.6	1.1	8.40	1	1	1
09/12/2021 20:00	1.6	12.2	2,061.4	1.1	8.20	1	1	1
09/12/2021 21:00	1.6	12.3	2,044.7	1.1	8.20	1	1	1
09/12/2021 22:00	1.6	12.4	2,036.7	1.1	8.10	1	1	1
09/12/2021 23:00	1.6	12.4	2,030.3	1.1	8.10	1	1	1
Average/Sum#:	1.4	13.0	1,818.9	1.0	171.00 #	24 #	24 #	17 #
Minimum:	0.9	11.8	1,277.1	0.7	3.80	1	1	0
Maximum:	1.7	14.0	2,145.6	1.2	9.90	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/13/2021 00:00	1.5	12.9	1,903.6	1.1	7.60	1	1	1
09/13/2021 01:00	1.2	13.9	1,565.5	1.0	6.30	1	1	0
09/13/2021 02:00	1.2	13.9	1,551.7	1.0	6.20	1	1	0
09/13/2021 03:00	1.3	13.9	1,624.8	1.1	6.50	1	1	0
09/13/2021 04:00	0.9	14.0	1,318.4	0.8	4.00	1	1	0
09/13/2021 05:00	1.1	14.0	1,653.7	0.9	5.00	1	1	0
09/13/2021 06:00	1.5	13.2	1,765.5	1.1	7.10	1	1	1
09/13/2021 07:00	1.4	13.0	1,821.6	1.0	7.30	1	1	1
09/13/2021 08:00	1.0	13.9	1,520.2	0.8	4.60	1	1	0
09/13/2021 09:00	1.5	12.9	1,918.7	1.1	7.70	1	1	1
09/13/2021 10:00	1.6	12.7	1,921.0	1.2	7.70	1	1	1
09/13/2021 11:00	1.3	13.9	1,678.5	1.1	6.70	1	1	0
09/13/2021 12:00	1.3	13.8	1,655.2	1.1	6.60	1	1	0
09/13/2021 13:00	1.6	12.6	1,976.1	1.1	7.90	1	1	1
09/13/2021 14:00	1.7	11.8	2,128.0	1.1	8.50	1	1	1
09/13/2021 15:00	1.7	11.8	2,115.6	1.1	8.50	1	1	1
09/13/2021 16:00	1.7	11.8	2,112.8	1.1	8.50	1	1	1
09/13/2021 17:00	1.7	11.7	2,138.4	1.1	8.60	1	1	1
09/13/2021 18:00	1.7	11.7	2,144.2	1.1	8.60	1	1	1
09/13/2021 19:00	1.7	11.7	2,144.5	1.1	8.60	1	1	1
09/13/2021 20:00	1.7	11.9	2,124.8	1.1	8.50	1	1	1
09/13/2021 21:00	1.7	12.1	2,081.4	1.1	8.30	1	1	1
09/13/2021 22:00	1.6	12.4	2,035.1	1.1	8.10	1	1	1
09/13/2021 23:00	1.5	12.8	1,926.9	1.1	7.70	1	1	1
Average/Sum#:	1.5	12.8	1,867.8	1.1	175.10 #	24 #	24 #	16 #
Minimum:	0.9	11.7	1,318.4	0.8	4.00	1	1	0
Maximum:	1.7	14.0	2,144.5	1.2	8.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/14/2021 00:00	1.5	12.9	1,905.8	1.1	7.60	1	1	1
09/14/2021 01:00	1.2	13.9	1,547.6	1.0	6.20	1	1	0
09/14/2021 02:00	1.3	13.9	1,527.3	1.1	6.10	1	1	0
09/14/2021 03:00	1.3	13.9	1,527.1	1.1	6.10	1	1	0
09/14/2021 04:00	1.2	13.9	1,482.2	1.0	5.90	1	1	0
09/14/2021 05:00	1.5	12.9	1,957.4	1.1	7.80	1	1	1
09/14/2021 06:00	1.6	12.8	1,960.5	1.2	7.80	1	1	1
09/14/2021 07:00	1.3	13.9	1,624.6	1.1	6.50	1	1	0
09/14/2021 08:00	1.2	13.9	1,485.9	1.0	5.90	1	1	0
09/14/2021 09:00	1.2	13.9	1,457.4	1.0	5.80	1	1	0
09/14/2021 10:00	1.3	13.9	1,635.0	1.1	6.50	1	1	0
09/14/2021 11:00	1.4	13.9	1,681.5	1.2	6.70	1	1	0
09/14/2021 12:00	1.1	13.9	1,519.1	0.9	4.60	1	1	1
09/14/2021 13:00	1.6	12.7	1,961.5	1.2	7.80	1	1	1
09/14/2021 14:00	1.6	12.2	2,028.5	1.1	8.10	1	1	1
09/14/2021 15:00	1.3	13.8	1,661.0	1.1	6.60	1	1	0
09/14/2021 16:00	1.1	13.9	1,584.1	0.9	4.80	1	1	1
09/14/2021 17:00	1.6	12.3	2,024.0	1.1	8.10	1	1	1
09/14/2021 18:00	1.7	11.9	2,114.4	1.1	8.50	1	1	1
09/14/2021 19:00	1.6	12.4	1,977.1	1.1	7.90	1	1	1
09/14/2021 20:00	1.2	13.9	1,665.0	1.0	6.70	1	1	0
09/14/2021 21:00	1.4	13.8	1,712.3	1.2	6.80	1	1	1
09/14/2021 22:00	1.6	12.6	1,983.0	1.1	7.90	1	1	1
09/14/2021 23:00	1.6	12.8	1,911.2	1.2	7.60	1	1	1
Average/Sum#:	1.4	13.3	1,747.2	1.1	164.30 #	24 #	24 #	13 #
Minimum:	1.1	11.9	1,457.4	0.9	4.60	1	1	0
Maximum:	1.7	13.9	2,114.4	1.2	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/15/2021 00:00	1.2	13.9	1,520.9	1.0	6.10	1	1	0
09/15/2021 01:00	1.1	13.8	1,540.5	0.9	4.60	1	1	1
09/15/2021 02:00	1.6	12.7	1,966.0	1.2	7.90	1	1	1
09/15/2021 03:00	1.5	12.8	1,931.7	1.1	7.70	1	1	1
09/15/2021 04:00	1.3	13.8	1,659.4	1.1	6.60	1	1	1
09/15/2021 05:00	1.1	13.8	1,568.4	0.9	4.70	1	1	1
09/15/2021 06:00	1.5	12.8	1,952.9	1.1	7.80	1	1	1
09/15/2021 07:00	1.5	13.0	1,918.4	1.1	7.70	1	1	1
09/15/2021 08:00	1.0	13.9	1,452.9	0.8	4.40	1	1	0
09/15/2021 09:00	1.1	14.0	1,396.5	0.9	4.20	1	1	0
09/15/2021 10:00	1.2	14.0	1,525.8	1.0	6.10	1	1	0
09/15/2021 11:00	1.3	13.9	1,581.9	1.1	6.30	1	1	0
09/15/2021 12:00	1.0	13.9	1,514.1	0.8	4.50	1	1	1
09/15/2021 13:00	1.6	12.5	2,012.2	1.1	8.00	1	1	1
09/15/2021 14:00	1.7	12.3	2,023.9	1.2	8.10	1	1	1
09/15/2021 15:00	1.2	13.8	1,542.4	1.0	6.20	1	1	1
09/15/2021 16:00	1.2	13.8	1,558.9	1.0	6.20	1	1	1
09/15/2021 17:00	1.6	12.4	2,004.3	1.1	8.00	1	1	1
09/15/2021 18:00	1.7	12.3	2,020.7	1.2	8.10	1	1	1
09/15/2021 19:00	1.5	12.7	1,938.3	1.1	7.80	1	1	1
09/15/2021 20:00	1.3	13.6	1,663.4	1.1	6.70	1	1	1
09/15/2021 21:00	1.3	13.9	1,587.6	1.1	6.40	1	1	1
09/15/2021 22:00	1.5	13.0	1,907.1	1.1	7.60	1	1	1
09/15/2021 23:00	1.5	13.0	1,903.4	1.1	7.60	1	1	1
Average/Sum#:	1.4	13.3	1,737.2	1.0	159.30 #	24 #	24 #	19 #
Minimum:	1.0	12.3	1,396.5	0.8	4.20	1	1	0
Maximum:	1.7	14.0	2,023.9	1.2	8.10	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/16/2021 00:00	1.4	13.5	1,683.4	1.1	6.70	1	1	1
09/16/2021 01:00	2.1	14.9	911.5	2.1	3.29	1	0	0
09/16/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/16/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/16/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/16/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/16/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/16/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/16/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/16/2021 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/16/2021 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/16/2021 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/16/2021 12:00	5.4	18.9	162.2	15.9	1.92	1	0	0
09/16/2021 13:00	18.7	15.8	794.0	21.6	63.50	1	0	0
09/16/2021 14:00	1.3	13.9	1,665.5	1.1	6.70	1	1	0
09/16/2021 15:00	1.3	13.9	1,614.5	1.1	6.50	1	1	0
09/16/2021 16:00	1.0	13.9	1,509.4	0.8	4.50	1	1	1
09/16/2021 17:00	1.3	12.4	2,051.8	0.9	6.20	1	1	1
09/16/2021 18:00	1.7	12.1	2,071.2	1.1	8.30	1	1	1
09/16/2021 19:00	1.6	12.8	1,938.0	1.2	7.80	1	1	1
09/16/2021 20:00	1.4	13.6	1,685.0	1.1	6.70	1	1	1
09/16/2021 21:00	1.3	13.8	1,642.1	1.1	6.60	1	1	1
09/16/2021 22:00	1.6	12.6	1,994.2	1.1	8.00	1	1	1
09/16/2021 23:00	1.5	12.9	1,927.6	1.1	7.70	1	1	1
Average/Sum#:	3.0	13.9	1,546.5	3.7	144.41 #	14 #	11 #	9 #
Minimum:	1.0	12.1	162.2	0.8	1.92	0	0	0
Maximum:	18.7	18.9	2,071.2	21.6	63.50	1	1	1
%SI	41.67	41.67	41.67	41.67	41.67	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/17/2021 00:00	1.5	13.0	1,907.8	1.1	7.60	1	1	1
09/17/2021 01:00	1.0	13.7	1,460.7	0.8	4.40	1	1	1
09/17/2021 02:00	3.7	16.6	304.7	5.1	0.99	1	0	0
09/17/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/17/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/17/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/17/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/17/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/17/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/17/2021 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/17/2021 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/17/2021 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/17/2021 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/17/2021 13:00	19.7	18.0	292.3	40.1	17.32	1	0	0
09/17/2021 14:00	12.3	15.8	768.3	14.2	40.00	1	0	0
09/17/2021 15:00	0.9	14.0	1,474.6	0.8	4.40	1	1	0
09/17/2021 16:00	1.1	13.8	1,575.6	0.9	4.70	1	1	1
09/17/2021 17:00	1.7	12.4	2,025.4	1.2	8.10	1	1	1
09/17/2021 18:00	2.3	12.0	2,103.9	1.5	12.60	1	1	1
09/17/2021 19:00	1.9	12.6	1,969.4	1.4	9.80	1	1	1
09/17/2021 20:00	1.5	13.0	1,899.6	1.1	7.60	1	1	1
09/17/2021 21:00	1.5	12.9	1,923.3	1.1	7.70	1	1	1
09/17/2021 22:00	1.6	12.9	1,922.6	1.2	7.70	1	1	1
09/17/2021 23:00	0.8	13.7	1,472.3	0.7	2.90	1	1	1
Average/Sum#:	3.7	13.9	1,507.2	5.1	135.81 #	14 #	11 #	10 #
Minimum:	0.8	12.0	292.3	0.7	0.99	0	0	0
Maximum:	19.7	18.0	2,103.9	40.1	40.00	1	1	1
%SI	41.67	41.67	41.67	41.67	41.67	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/18/2021 00:00	3.3	16.4	316.6	4.3	0.77	1	0	0
09/18/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/18/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/18/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/18/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/18/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/18/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/18/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/18/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/18/2021 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/18/2021 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/18/2021 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/18/2021 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/18/2021 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/18/2021 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/18/2021 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/18/2021 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/18/2021 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/18/2021 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/18/2021 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/18/2021 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/18/2021 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/18/2021 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/18/2021 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	3.3	16.4	316.6	4.3	0.77 #	1 #	0 #	0 #
Minimum:	3.3	16.4	316.6	4.3	0.77	0	0	0
Maximum:	3.3	16.4	316.6	4.3	0.77	1	0	0
%SI	95.83	95.83	95.83	95.83	95.83	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/19/2021 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/19/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/19/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/19/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/19/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/19/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/19/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/19/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/19/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/19/2021 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/19/2021 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/19/2021 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/19/2021 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/19/2021 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/19/2021 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/19/2021 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/19/2021 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/19/2021 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/19/2021 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/19/2021 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/19/2021 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/19/2021 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/19/2021 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/19/2021 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/20/2021 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/20/2021 01:00	17.6	18.3	245.1	39.9	10.80	1	0	0
09/20/2021 02:00	24.5	16.9	479.2	36.1	63.70	1	0	0
09/20/2021 03:00	2.6	14.1	1,283.8	2.3	10.30	1	0	0
09/20/2021 04:00	1.0	14.0	1,432.1	0.9	4.30	1	1	0
09/20/2021 05:00	1.4	13.3	1,852.9	1.1	7.40	1	1	1
09/20/2021 06:00	1.5	13.0	1,960.2	1.1	7.80	1	1	1
09/20/2021 07:00	1.0	13.8	1,486.8	0.8	4.50	1	1	1
09/20/2021 08:00	0.9	14.1	1,284.3	0.8	3.90	1	1	0
09/20/2021 09:00	0.9	14.1	1,286.6	0.8	3.90	1	1	0
09/20/2021 10:00	0.8	14.1	1,289.3	0.7	3.90	1	1	0
09/20/2021 11:00	1.1	13.9	1,571.0	0.9	4.70	1	1	1
09/20/2021 12:00	1.6	12.9	1,953.3	1.2	7.80	1	1	1
09/20/2021 13:00	1.5	12.8	1,965.1	1.1	7.90	1	1	1
09/20/2021 14:00	1.2	13.7	1,562.4	1.0	6.20	1	1	1
09/20/2021 15:00	1.3	13.9	1,527.7	1.1	6.10	1	1	1
09/20/2021 16:00	1.6	12.5	2,021.7	1.1	8.10	1	1	1
09/20/2021 17:00	1.7	11.8	2,174.0	1.1	8.70	1	1	1
09/20/2021 18:00	1.7	11.9	2,170.9	1.1	8.70	1	1	1
09/20/2021 19:00	1.7	12.0	2,142.6	1.1	8.60	1	1	1
09/20/2021 20:00	1.6	12.1	2,110.3	1.1	8.40	1	1	1
09/20/2021 21:00	1.6	12.4	2,061.6	1.1	8.20	1	1	1
09/20/2021 22:00	1.5	13.0	1,935.9	1.1	7.70	1	1	1
09/20/2021 23:00	1.5	13.1	1,893.7	1.1	7.60	1	1	1
Average/Sum#:	3.1	13.6	1,638.7	4.3	219.20 #	23 #	20 #	16 #
Minimum:	0.8	11.8	245.1	0.7	3.90	0	0	0
Maximum:	24.5	18.3	2,174.0	39.9	63.70	1	1	1
%SI	4.17	4.17	4.17	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/21/2021 00:00	1.3	13.9	1,661.9	1.1	6.60	1	1	0
09/21/2021 01:00	1.1	13.9	1,565.4	0.9	4.70	1	1	1
09/21/2021 02:00	1.5	13.2	1,910.5	1.1	7.60	1	1	1
09/21/2021 03:00	1.5	13.2	1,902.3	1.1	7.60	1	1	1
09/21/2021 04:00	1.5	13.2	1,900.9	1.1	7.60	1	1	1
09/21/2021 05:00	1.5	13.2	1,916.2	1.1	7.70	1	1	1
09/21/2021 06:00	1.5	12.7	2,041.5	1.1	8.20	1	1	1
09/21/2021 07:00	1.5	13.1	1,901.9	1.1	7.60	1	1	1
09/21/2021 08:00	1.0	14.0	1,464.5	0.9	4.40	1	1	0
09/21/2021 09:00	1.2	14.0	1,523.5	1.0	6.10	1	1	0
09/21/2021 10:00	1.3	13.9	1,651.5	1.1	6.60	1	1	0
09/21/2021 11:00	0.9	14.0	1,619.2	0.8	4.90	1	1	1
09/21/2021 12:00	1.6	12.7	1,993.4	1.2	8.00	1	1	1
09/21/2021 13:00	1.7	12.0	2,123.1	1.1	8.50	1	1	1
09/21/2021 14:00	1.7	12.0	2,123.2	1.1	8.50	1	1	1
09/21/2021 15:00	1.7	11.9	2,137.2	1.1	8.50	1	1	1
09/21/2021 16:00	1.7	11.9	2,148.8	1.1	8.60	1	1	1
09/21/2021 17:00	1.7	11.8	2,160.3	1.1	8.60	1	1	1
09/21/2021 18:00	1.7	11.8	2,172.6	1.1	8.70	1	1	1
09/21/2021 19:00	1.7	11.9	2,139.9	1.1	8.60	1	1	1
09/21/2021 20:00	1.7	12.0	2,144.1	1.1	8.60	1	1	1
09/21/2021 21:00	1.6	12.2	2,106.0	1.1	8.40	1	1	1
09/21/2021 22:00	1.6	12.3	2,071.9	1.1	8.30	1	1	1
09/21/2021 23:00	1.6	12.6	2,002.4	1.1	8.00	1	1	1
Average/Sum#:	1.5	12.8	1,932.6	1.1	180.90 #	24 #	24 #	20 #
Minimum:	0.9	11.8	1,464.5	0.8	4.40	1	1	0
Maximum:	1.7	14.0	2,172.6	1.2	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/22/2021 00:00	1.2	13.8	1,607.2	1.0	6.40	1	1	1
09/22/2021 01:00	1.3	13.8	1,638.3	1.1	6.60	1	1	1
09/22/2021 02:00	1.5	13.1	1,898.6	1.1	7.60	1	1	1
09/22/2021 03:00	1.5	13.1	1,895.0	1.1	7.60	1	1	1
09/22/2021 04:00	1.6	12.8	2,002.8	1.2	8.00	1	1	1
09/22/2021 05:00	1.6	12.2	2,114.0	1.1	8.50	1	1	1
09/22/2021 06:00	1.6	12.6	2,046.4	1.1	8.20	1	1	1
09/22/2021 07:00	1.5	13.1	1,896.4	1.1	7.60	1	1	1
09/22/2021 08:00	1.2	13.9	1,618.8	1.0	6.50	1	1	0
09/22/2021 09:00	1.3	13.8	1,712.7	1.1	6.90	1	1	0
09/22/2021 10:00	1.5	13.0	1,902.3	1.1	7.60	1	1	1
09/22/2021 11:00	1.5	12.5	2,003.1	1.1	8.00	1	1	1
09/22/2021 12:00	1.3	13.9	1,603.8	1.1	6.40	1	1	0
09/22/2021 13:00	1.2	13.8	1,698.8	1.0	6.80	1	1	1
09/22/2021 14:00	1.6	12.4	2,034.0	1.1	8.10	1	1	1
09/22/2021 15:00	1.6	11.9	2,132.1	1.0	8.50	1	1	1
09/22/2021 16:00	1.6	11.8	2,154.4	1.0	8.60	1	1	1
09/22/2021 17:00	1.6	11.8	2,147.2	1.0	8.60	1	1	1
09/22/2021 18:00	1.6	11.9	2,154.4	1.0	8.60	1	1	1
09/22/2021 19:00	1.5	12.3	2,035.1	1.0	8.10	1	1	1
09/22/2021 20:00	1.1	13.9	1,629.9	0.9	4.90	1	1	0
09/22/2021 21:00	1.3	13.7	1,741.8	1.1	7.00	1	1	1
09/22/2021 22:00	1.5	12.7	1,973.4	1.1	7.90	1	1	1
09/22/2021 23:00	1.5	12.5	2,030.0	1.1	8.10	1	1	1
Average/Sum#:	1.4	12.9	1,902.9	1.1	181.10 #	24 #	24 #	20 #
Minimum:	1.1	11.8	1,603.8	0.9	4.90	1	1	0
Maximum:	1.6	13.9	2,154.4	1.2	8.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/23/2021 00:00	1.4	12.9	1,915.3	1.0	7.70	1	1	1
09/23/2021 01:00	1.1	13.9	1,544.6	0.9	4.60	1	1	0
09/23/2021 02:00	1.1	14.0	1,523.2	0.9	4.60	1	1	0
09/23/2021 03:00	1.3	14.0	1,623.4	1.1	6.50	1	1	0
09/23/2021 04:00	1.1	13.9	1,567.3	0.9	4.70	1	1	1
09/23/2021 05:00	1.5	12.7	2,000.5	1.1	8.00	1	1	1
09/23/2021 06:00	1.4	12.8	1,961.4	1.0	7.80	1	1	1
09/23/2021 07:00	1.2	13.9	1,644.7	1.0	6.60	1	1	0
09/23/2021 08:00	1.0	14.0	1,392.5	0.9	4.20	1	1	0
09/23/2021 09:00	1.2	13.7	1,736.5	1.0	6.90	1	1	0
09/23/2021 10:00	1.4	13.7	1,735.1	1.1	6.90	1	1	0
09/23/2021 11:00	1.3	13.7	1,729.2	1.1	6.90	1	1	0
09/23/2021 12:00	1.4	13.7	1,726.4	1.1	6.90	1	1	0
09/23/2021 13:00	1.3	13.7	1,724.7	1.1	6.90	1	1	0
09/23/2021 14:00	1.4	13.7	1,725.2	1.1	6.90	1	1	0
09/23/2021 15:00	1.4	13.7	1,724.3	1.1	6.90	1	1	0
09/23/2021 16:00	1.3	13.7	1,722.4	1.1	6.90	1	1	0
09/23/2021 17:00	1.4	13.7	1,724.6	1.1	6.90	1	1	0
09/23/2021 18:00	1.3	13.8	1,730.3	1.1	6.90	1	1	0
09/23/2021 19:00	1.4	13.8	1,732.8	1.2	6.90	1	1	0
09/23/2021 20:00	1.4	13.7	1,732.7	1.1	6.90	1	1	0
09/23/2021 21:00	1.3	13.8	1,732.8	1.1	6.90	1	1	0
09/23/2021 22:00	1.3	13.7	1,732.8	1.1	6.90	1	1	0
09/23/2021 23:00	1.4	13.7	1,736.0	1.1	6.90	1	1	0
Average/Sum#:	1.3	13.7	1,713.3	1.1	158.20 #	24 #	24 #	4 #
Minimum:	1.0	12.7	1,392.5	0.9	4.20	1	1	0
Maximum:	1.5	14.0	2,000.5	1.2	8.00	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/24/2021 00:00	1.3	13.7	1,736.8	1.1	6.90	1	1	0
09/24/2021 01:00	1.3	13.7	1,737.3	1.1	6.90	1	1	0
09/24/2021 02:00	1.4	13.7	1,738.3	1.1	7.00	1	1	0
09/24/2021 03:00	1.4	13.7	1,738.6	1.1	7.00	1	1	0
09/24/2021 04:00	1.4	13.7	1,745.1	1.1	7.00	1	1	0
09/24/2021 05:00	1.4	13.7	1,751.2	1.1	7.00	1	1	0
09/24/2021 06:00	1.3	13.7	1,751.5	1.1	7.00	1	1	0
09/24/2021 07:00	1.4	13.7	1,748.1	1.1	7.00	1	1	0
09/24/2021 08:00	1.4	13.7	1,742.3	1.1	7.00	1	1	0
09/24/2021 09:00	1.3	13.9	1,636.2	1.1	6.50	1	1	0
09/24/2021 10:00	1.1	13.9	1,515.9	0.9	4.50	1	1	0
09/24/2021 11:00	1.1	14.0	1,584.2	0.9	4.80	1	1	0
09/24/2021 12:00	1.1	14.0	1,579.0	0.9	4.70	1	1	0
09/24/2021 13:00	1.2	13.9	1,640.9	1.0	6.60	1	1	0
09/24/2021 14:00	1.3	13.8	1,678.6	1.1	6.70	1	1	0
09/24/2021 15:00	1.3	13.8	1,670.9	1.1	6.70	1	1	0
09/24/2021 16:00	1.2	13.8	1,657.4	1.0	6.60	1	1	0
09/24/2021 17:00	1.3	13.8	1,695.7	1.1	6.80	1	1	0
09/24/2021 18:00	1.3	13.9	1,637.3	1.1	6.50	1	1	0
09/24/2021 19:00	1.3	13.9	1,671.8	1.1	6.70	1	1	0
09/24/2021 20:00	1.3	13.9	1,615.8	1.1	6.50	1	1	0
09/24/2021 21:00	1.2	13.9	1,592.7	1.0	6.40	1	1	0
09/24/2021 22:00	1.3	13.9	1,627.7	1.1	6.50	1	1	0
09/24/2021 23:00	1.3	13.9	1,623.4	1.1	6.50	1	1	0
Average/Sum#:	1.3	13.8	1,671.5	1.1	155.80 #	24 #	24 #	0 #
Minimum:	1.1	13.7	1,515.9	0.9	4.50	1	1	0
Maximum:	1.4	14.0	1,751.5	1.1	7.00	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/25/2021 00:00	1.2	13.9	1,552.3	1.0	6.20	1	1	0
09/25/2021 01:00	1.3	13.9	1,618.0	1.1	6.50	1	1	0
09/25/2021 02:00	1.3	13.9	1,646.8	1.1	6.60	1	1	0
09/25/2021 03:00	1.3	13.9	1,645.9	1.1	6.60	1	1	0
09/25/2021 04:00	1.2	13.9	1,601.4	1.0	6.40	1	1	0
09/25/2021 05:00	1.2	13.9	1,581.9	1.0	6.30	1	1	0
09/25/2021 06:00	1.2	13.9	1,636.0	1.0	6.50	1	1	0
09/25/2021 07:00	1.1	13.9	1,623.5	0.9	4.90	1	1	0
09/25/2021 08:00	1.1	13.9	1,521.2	0.9	4.60	1	1	0
09/25/2021 09:00	0.9	14.0	1,328.5	0.8	4.00	1	1	0
09/25/2021 10:00	1.1	14.0	1,508.5	0.9	4.50	1	1	0
09/25/2021 11:00	1.1	13.9	1,637.1	0.9	4.90	1	1	0
09/25/2021 12:00	1.3	13.9	1,644.7	1.1	6.60	1	1	0
09/25/2021 13:00	1.3	13.9	1,638.9	1.1	6.60	1	1	0
09/25/2021 14:00	1.3	13.9	1,667.3	1.1	6.70	1	1	0
09/25/2021 15:00	1.4	13.8	1,662.9	1.2	6.70	1	1	0
09/25/2021 16:00	1.3	13.9	1,613.2	1.1	6.50	1	1	0
09/25/2021 17:00	0.9	14.0	1,316.6	0.8	3.90	1	1	0
09/25/2021 18:00	1.1	13.9	1,602.4	0.9	4.80	1	1	0
09/25/2021 19:00	1.2	13.9	1,664.1	1.0	6.70	1	1	0
09/25/2021 20:00	1.3	13.9	1,640.2	1.1	6.60	1	1	0
09/25/2021 21:00	1.1	13.9	1,548.2	0.9	4.60	1	1	0
09/25/2021 22:00	1.0	14.0	1,344.3	0.9	4.00	1	1	0
09/25/2021 23:00	1.0	14.0	1,310.5	0.9	3.90	1	1	0
Average/Sum#:	1.2	13.9	1,564.8	1.0	135.60 #	24 #	24 #	0 #
Minimum:	0.9	13.8	1,310.5	0.8	3.90	1	1	0
Maximum:	1.4	14.0	1,667.3	1.2	6.70	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/26/2021 00:00	1.0	14.0	1,313.2	0.9	3.90	1	1	0
09/26/2021 01:00	1.0	14.0	1,318.1	0.9	4.00	1	1	0
09/26/2021 02:00	1.0	14.0	1,323.5	0.9	4.00	1	1	0
09/26/2021 03:00	1.0	14.0	1,322.0	0.9	4.00	1	1	0
09/26/2021 04:00	1.0	14.0	1,323.2	0.9	4.00	1	1	0
09/26/2021 05:00	1.0	14.0	1,330.2	0.9	4.00	1	1	0
09/26/2021 06:00	1.0	14.0	1,372.8	0.9	4.10	1	1	0
09/26/2021 07:00	1.1	14.0	1,367.0	0.9	4.10	1	1	0
09/26/2021 08:00	1.0	14.0	1,326.1	0.9	4.00	1	1	0
09/26/2021 09:00	1.0	14.0	1,329.0	0.9	4.00	1	1	0
09/26/2021 10:00	1.1	14.0	1,356.2	0.9	4.10	1	1	0
09/26/2021 11:00	1.1	14.0	1,434.8	0.9	4.30	1	1	0
09/26/2021 12:00	1.1	14.0	1,329.5	0.9	4.00	1	1	0
09/26/2021 13:00	1.1	14.0	1,359.4	0.9	4.10	1	1	0
09/26/2021 14:00	1.1	14.0	1,362.0	0.9	4.10	1	1	0
09/26/2021 15:00	1.0	14.0	1,433.4	0.9	4.30	1	1	0
09/26/2021 16:00	0.9	14.0	1,415.0	0.8	4.20	1	1	0
09/26/2021 17:00	1.0	14.0	1,334.4	0.9	4.00	1	1	0
09/26/2021 18:00	1.0	14.0	1,323.7	0.9	4.00	1	1	0
09/26/2021 19:00	1.0	14.0	1,315.2	0.9	3.90	1	1	0
09/26/2021 20:00	1.0	14.0	1,316.4	0.9	3.90	1	1	0
09/26/2021 21:00	1.0	14.0	1,316.8	0.9	4.00	1	1	0
09/26/2021 22:00	1.1	14.0	1,317.8	0.9	4.00	1	1	0
09/26/2021 23:00	1.1	14.0	1,319.9	0.9	4.00	1	1	0
Average/Sum#:	1.0	14.0	1,344.2	0.9	97.00 #	24 #	24 #	0 #
Minimum:	0.9	14.0	1,313.2	0.8	3.90	1	1	0
Maximum:	1.1	14.0	1,434.8	0.9	4.30	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/27/2021 00:00	1.1	14.0	1,319.1	0.9	4.00	1	1	0
09/27/2021 01:00	1.1	14.0	1,318.1	0.9	4.00	1	1	0
09/27/2021 02:00	1.1	14.0	1,320.2	0.9	4.00	1	1	0
09/27/2021 03:00	1.1	14.0	1,320.1	0.9	4.00	1	1	0
09/27/2021 04:00	1.1	13.9	1,401.6	0.9	4.20	1	1	0
09/27/2021 05:00	1.3	13.8	1,659.9	1.1	6.60	1	1	0
09/27/2021 06:00	1.1	13.9	1,610.2	0.9	4.80	1	1	0
09/27/2021 07:00	0.9	13.9	1,472.0	0.8	4.40	1	1	0
09/27/2021 08:00	0.9	14.0	1,319.9	0.8	4.00	1	1	0
09/27/2021 09:00	1.0	14.0	1,319.3	0.9	4.00	1	1	0
09/27/2021 10:00	1.1	14.0	1,328.2	0.9	4.00	1	1	0
09/27/2021 11:00	1.1	14.0	1,332.5	0.9	4.00	1	1	0
09/27/2021 12:00	1.1	14.0	1,333.2	0.9	4.00	1	1	0
09/27/2021 13:00	1.1	14.0	1,329.4	0.9	4.00	1	1	0
09/27/2021 14:00	1.1	14.0	1,331.6	0.9	4.00	1	1	0
09/27/2021 15:00	1.1	14.0	1,325.6	0.9	4.00	1	1	0
09/27/2021 16:00	1.1	13.9	1,453.7	0.9	4.40	1	1	0
09/27/2021 17:00	0.8	14.0	1,364.5	0.7	4.10	1	1	0
09/27/2021 18:00	1.0	14.0	1,456.9	0.9	4.40	1	1	0
09/27/2021 19:00	1.1	14.0	1,462.7	0.9	4.40	1	1	0
09/27/2021 20:00	1.0	13.9	1,571.5	0.8	4.70	1	1	0
09/27/2021 21:00	1.0	14.0	1,415.2	0.9	4.20	1	1	0
09/27/2021 22:00	1.0	14.0	1,379.9	0.9	4.10	1	1	0
09/27/2021 23:00	1.1	14.0	1,320.0	0.9	4.00	1	1	0
Average/Sum#:	1.1	14.0	1,394.4	0.9	102.30 #	24 #	24 #	0 #
Minimum:	0.8	13.8	1,318.1	0.7	4.00	1	1	0
Maximum:	1.3	14.0	1,659.9	1.1	6.60	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/28/2021 00:00	1.1	14.0	1,321.8	0.9	4.00	1	1	0
09/28/2021 01:00	1.1	14.0	1,321.4	0.9	4.00	1	1	0
09/28/2021 02:00	1.1	14.0	1,319.6	0.9	4.00	1	1	0
09/28/2021 03:00	1.1	14.0	1,318.0	0.9	4.00	1	1	0
09/28/2021 04:00	1.2	14.0	1,421.4	1.0	5.70	1	1	0
09/28/2021 05:00	1.1	14.0	1,341.8	0.9	4.00	1	1	0
09/28/2021 06:00	1.2	14.0	1,504.3	1.0	6.00	1	1	0
09/28/2021 07:00	0.8	14.0	1,420.7	0.7	4.30	1	1	0
09/28/2021 08:00	1.0	14.0	1,438.2	0.9	4.30	1	1	0
09/28/2021 09:00	1.1	14.0	1,336.7	0.9	4.00	1	1	0
09/28/2021 10:00	1.2	14.1	1,340.8	1.0	5.40	1	1	0
09/28/2021 11:00	1.2	14.1	1,344.3	1.0	5.40	1	1	0
09/28/2021 12:00	1.2	14.1	1,344.2	1.0	5.40	1	1	0
09/28/2021 13:00	1.2	14.1	1,344.9	1.0	5.40	1	1	0
09/28/2021 14:00	1.2	14.1	1,344.7	1.0	5.40	1	1	0
09/28/2021 15:00	1.1	14.1	1,343.2	1.0	5.40	1	1	0
09/28/2021 16:00	1.2	14.0	1,461.7	1.0	5.80	1	1	1
09/28/2021 17:00	1.5	12.7	2,020.9	1.1	8.10	1	1	1
09/28/2021 18:00	1.7	12.1	2,133.9	1.1	8.50	1	1	1
09/28/2021 19:00	1.5	13.0	1,927.9	1.1	7.70	1	1	1
09/28/2021 20:00	1.5	13.1	1,907.3	1.1	7.60	1	1	1
09/28/2021 21:00	1.5	13.1	1,888.7	1.1	7.60	1	1	1
09/28/2021 22:00	0.8	14.0	1,353.7	0.7	4.10	1	1	0
09/28/2021 23:00	1.0	14.1	1,324.7	0.9	4.00	1	1	0
Average/Sum#:	1.2	13.8	1,492.7	1.0	130.10 #	24 #	24 #	6 #
Minimum:	0.8	12.1	1,318.0	0.7	4.00	1	1	0
Maximum:	1.7	14.1	2,133.9	1.1	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/29/2021 00:00	1.1	14.1	1,324.8	1.0	5.30	1	1	0
09/29/2021 01:00	1.1	14.0	1,324.9	0.9	4.00	1	1	0
09/29/2021 02:00	1.1	14.0	1,323.8	0.9	4.00	1	1	0
09/29/2021 03:00	1.2	13.9	1,611.5	1.0	6.40	1	1	0
09/29/2021 04:00	1.0	13.9	1,616.2	0.8	4.80	1	1	0
09/29/2021 05:00	1.2	13.8	1,733.8	1.0	6.90	1	1	0
09/29/2021 06:00	1.3	13.7	1,773.0	1.1	7.10	1	1	0
09/29/2021 07:00	1.4	13.7	1,768.9	1.1	7.10	1	1	0
09/29/2021 08:00	1.4	13.7	1,759.0	1.1	7.00	1	1	0
09/29/2021 09:00	1.0	13.9	1,493.7	0.8	4.50	1	1	0
09/29/2021 10:00	1.2	14.0	1,537.1	1.0	6.10	1	1	0
09/29/2021 11:00	1.1	13.9	1,463.8	0.9	4.40	1	1	0
09/29/2021 12:00	1.1	14.1	1,462.1	1.0	5.80	1	1	0
09/29/2021 13:00	1.1	14.0	1,619.6	0.9	4.90	1	1	0
09/29/2021 14:00	1.2	13.9	1,650.9	1.0	6.60	1	1	0
09/29/2021 15:00	1.3	13.9	1,658.9	1.1	6.60	1	1	0
09/29/2021 16:00	1.3	13.9	1,645.7	1.1	6.60	1	1	0
09/29/2021 17:00	0.9	14.0	1,415.3	0.8	4.20	1	1	0
09/29/2021 18:00	0.9	14.1	1,373.6	0.8	4.10	1	1	0
09/29/2021 19:00	1.1	13.9	1,628.7	0.9	4.90	1	1	0
09/29/2021 20:00	1.3	13.9	1,644.4	1.1	6.60	1	1	0
09/29/2021 21:00	1.2	13.9	1,608.9	1.0	6.40	1	1	0
09/29/2021 22:00	1.3	13.9	1,637.4	1.1	6.50	1	1	0
09/29/2021 23:00	1.2	13.9	1,514.1	1.0	6.10	1	1	0
Average/Sum#:	1.2	13.9	1,566.3	1.0	136.90 #	24 #	24 #	0 #
Minimum:	0.9	13.7	1,323.8	0.8	4.00	1	1	0
Maximum:	1.4	14.1	1,773.0	1.1	7.10	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/30/2021 00:00	1.1	14.0	1,492.1	0.9	4.50	1	1	0
09/30/2021 01:00	0.9	14.1	1,306.7	0.8	3.90	1	1	0
09/30/2021 02:00	1.0	14.1	1,281.8	0.9	3.80	1	1	0
09/30/2021 03:00	1.0	14.0	1,534.4	0.9	4.60	1	1	0
09/30/2021 04:00	1.1	14.0	1,594.3	0.9	4.80	1	1	0
09/30/2021 05:00	0.9	14.1	1,319.4	0.8	4.00	1	1	0
09/30/2021 06:00	7.4	16.2	349.6	9.3	2.14	1	0	0
09/30/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/30/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/30/2021 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/30/2021 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/30/2021 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/30/2021 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/30/2021 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/30/2021 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/30/2021 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/30/2021 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/30/2021 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/30/2021 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/30/2021 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/30/2021 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/30/2021 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/30/2021 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/30/2021 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	1.9	14.4	1,268.3	2.1	27.74 #	7 #	6 #	0 #
Minimum:	0.9	14.0	349.6	0.8	2.14	0	0	0
Maximum:	7.4	16.2	1,594.3	9.3	4.80	1	1	0
%SI	70.83	70.83	70.83	70.83	70.83	0.00	0.00	0.00

ATTACHMENT 7
Hourly Emissions – CO

FCD: AQ-16
Title V: #6

Daily Summary Report

CT1 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/01/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/02/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/03/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/04/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/05/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/06/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/07/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/08/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/08/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/08/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/08/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/08/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/08/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/08/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/08/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/08/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/08/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/08/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/08/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/08/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/08/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/08/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/08/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/08/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/08/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/08/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/08/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/08/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/08/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/08/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/08/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/09/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/09/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/09/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/09/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/09/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/09/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/09/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/09/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/09/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/09/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/09/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/09/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/09/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/09/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/09/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/09/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/09/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/09/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/09/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/09/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/09/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/09/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/09/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/09/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/10/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/10/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/10/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/10/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/10/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/10/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/10/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/10/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/10/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/10/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/10/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/10/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/10/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/10/2021 13:00	75.8	17.5	277.5	0.0	43.3	1	0	0
07/10/2021 14:00	20.7	16.9	364.5	0.0	24.9	1	0	0
07/10/2021 15:00	64.0	15.6	636.7	0.0	101.5	1	0	0
07/10/2021 16:00	9.0	14.0	1,294.4	0.0	22.3	1	0	0
07/10/2021 17:00	0.1	13.5	1,643.7	0.0	0.3	1	0	0
07/10/2021 18:00	0.2	13.4	1,705.4	0.0	0.6	1	0	0
07/10/2021 19:00	0.2	13.4	1,711.6	0.2	0.6	1	0	0
07/10/2021 20:00	0.2	13.4	1,730.2	0.2	0.6	1	0	0
07/10/2021 21:00	0.2	13.4	1,742.3	0.2	0.6	1	0	0
07/10/2021 22:00	0.2	13.4	1,743.5	0.2	0.6	1	0	0
07/10/2021 23:00	14.8	14.1	1,326.0	0.0	26.7	1	0	0
Average/Sum#:	16.9	14.4	1,288.7	0.2	222.0 #	11 #	0 #	0 #
Minimum:	0.1	13.4	277.5	0.2	0.3	0	0	0
Maximum:	75.8	17.5	1,743.5	0.2	101.5	1	0	0
%SI	54.17	54.17	54.17	83.33	54.17	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/11/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/11/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/11/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/11/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/11/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/11/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/11/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/11/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/11/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/11/2021 09:00	53.4	17.5	319.9	0.0	43.2	1	0	0
07/11/2021 10:00	27.0	16.9	408.6	0.0	36.4	1	0	0
07/11/2021 11:00	39.5	14.4	1,082.8	0.0	86.9	1	0	0
07/11/2021 12:00	0.1	13.8	1,380.4	0.0	0.3	1	0	0
07/11/2021 13:00	0.1	13.7	1,485.8	0.0	0.3	1	0	0
07/11/2021 14:00	0.1	13.5	1,680.2	0.1	0.3	1	0	0
07/11/2021 15:00	0.2	13.5	1,625.7	0.1	0.6	1	0	0
07/11/2021 16:00	0.1	13.3	1,704.5	0.1	0.3	1	0	0
07/11/2021 17:00	0.1	13.4	1,707.9	0.1	0.3	1	0	0
07/11/2021 18:00	0.2	13.4	1,715.3	0.1	0.6	1	0	0
07/11/2021 19:00	0.2	13.4	1,723.8	0.2	0.6	1	0	0
07/11/2021 20:00	0.2	13.4	1,722.9	0.2	0.6	1	0	0
07/11/2021 21:00	0.2	13.5	1,709.5	0.2	0.6	1	0	0
07/11/2021 22:00	0.2	13.6	1,704.6	0.2	0.6	1	0	0
07/11/2021 23:00	0.2	13.5	1,673.2	0.2	0.6	1	0	0
Average/Sum#:	8.1	14.1	1,443.0	0.2	172.2 #	15 #	0 #	0 #
Minimum:	0.1	13.3	319.9	0.1	0.3	0	0	0
Maximum:	53.4	17.5	1,723.8	0.2	86.9	1	0	0
%SI	37.50	37.50	37.50	58.33	37.50	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/12/2021 00:00	0.2	13.5	1,705.3	0.2	0.6	1	0	0
07/12/2021 01:00	36.9	15.6	501.7	0.0	9.2	1	0	0
07/12/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/12/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/12/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/12/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/12/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/12/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/12/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/12/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/12/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	1	0
07/12/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	1	0
07/12/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	1	0
07/12/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	1	0
07/12/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	1	0
07/12/2021 15:00	98.6	17.9	277.5	0.0	44.6	1	1	0
07/12/2021 16:00	32.1	14.9	1,085.2	0.0	76.7	1	1	0
07/12/2021 17:00	0.1	13.4	1,748.9	0.0	0.3	1	1	0
07/12/2021 18:00	0.1	13.5	1,731.1	0.0	0.3	1	1	0
07/12/2021 19:00	0.1	13.5	1,735.7	0.1	0.3	1	1	0
07/12/2021 20:00	0.2	13.4	1,771.0	0.1	0.6	1	1	0
07/12/2021 21:00	0.2	13.4	1,756.0	0.2	0.6	1	1	0
07/12/2021 22:00	12.6	14.1	1,360.8	0.0	30.0	1	1	0
07/12/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	1	0
Average/Sum#:	18.1	14.3	1,367.3	0.2	163.2 #	10 #	14 #	0 #
Minimum:	0.1	13.4	277.5	0.1	0.3	0	0	0
Maximum:	98.6	17.9	1,771.0	0.2	76.7	1	1	0
%SI	58.33	58.33	58.33	83.33	58.33	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/13/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	1	0
07/13/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	1	0
07/13/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/13/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/13/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/13/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/13/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/13/2021 07:00	54.1	17.6	333.6	0.0	44.8	1	0	0
07/13/2021 08:00	35.9	17.0	390.2	0.0	47.4	1	0	0
07/13/2021 09:00	38.1	17.1	345.5	0.0	44.4	1	0	0
07/13/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/13/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/13/2021 12:00	51.9	17.2	390.1	0.0	67.2	1	0	0
07/13/2021 13:00	188.8	15.8	618.9	0.0	227.0	1	0	0
07/13/2021 14:00	26.0	18.3	220.8	0.0	7.3	1	0	0
07/13/2021 15:00	173.0	15.9	661.2	0.0	302.1	1	0	0
07/13/2021 16:00	82.2	14.4	1,270.7	0.0	212.2	1	0	0
07/13/2021 17:00	0.1	13.4	1,757.7	0.0	0.3	1	0	0
07/13/2021 18:00	0.3	13.5	1,553.6	0.0	0.8	1	0	0
07/13/2021 19:00	0.2	13.4	1,726.7	0.2	0.6	1	1	0
07/13/2021 20:00	0.1	13.4	1,774.9	0.2	0.3	1	1	0
07/13/2021 21:00	19.0	14.0	1,397.2	0.0	48.3	1	1	0
07/13/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	1	0
07/13/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	1	0
Average/Sum#:	51.5	15.5	957.0	0.2	1,002.7 #	13 #	7 #	0 #
Minimum:	0.1	13.4	220.8	0.2	0.3	0	0	0
Maximum:	188.8	18.3	1,774.9	0.2	302.1	1	1	0
%SI	45.83	45.83	45.83	91.67	45.83	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/14/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	1	0
07/14/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	1	0
07/14/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	1	0
07/14/2021 03:00	161.4	16.5	562.5	0.0	158.1	1	1	0
07/14/2021 04:00	25.4	13.9	1,425.1	0.0	68.3	1	1	0
07/14/2021 05:00	0.1	13.6	1,702.9	0.0	0.3	1	1	0
07/14/2021 06:00	0.2	13.6	1,641.4	0.0	0.6	1	1	0
07/14/2021 07:00	0.8	13.6	1,679.9	0.3	2.4	1	1	1
07/14/2021 08:00	1.2	12.3	1,910.2	0.5	3.5	1	1	1
07/14/2021 09:00	1.6	12.4	1,992.3	0.8	5.0	1	1	1
07/14/2021 10:00	0.1	13.6	1,664.5	0.7	0.3	1	1	0
07/14/2021 11:00	0.3	13.6	1,595.0	0.5	0.9	1	1	1
07/14/2021 12:00	0.7	12.0	2,096.4	0.3	2.2	1	1	1
07/14/2021 13:00	0.3	11.2	2,237.6	0.3	0.9	1	1	1
07/14/2021 14:00	0.2	11.2	2,233.0	0.3	0.6	1	1	1
07/14/2021 15:00	0.2	11.3	2,218.1	0.1	0.6	1	1	1
07/14/2021 16:00	0.1	11.2	2,235.0	0.1	0.3	1	1	1
07/14/2021 17:00	0.2	11.2	2,238.8	0.1	0.6	1	1	1
07/14/2021 18:00	0.2	11.3	2,222.0	0.1	0.6	1	1	1
07/14/2021 19:00	0.3	11.6	2,174.9	0.1	0.9	1	1	1
07/14/2021 20:00	0.3	11.6	2,159.8	0.2	0.9	1	1	1
07/14/2021 21:00	0.4	11.9	2,112.7	0.2	1.2	1	1	1
07/14/2021 22:00	0.5	11.9	2,111.8	0.3	1.5	1	1	1
07/14/2021 23:00	0.6	12.0	2,105.2	0.3	1.9	1	1	1
Average/Sum#:	9.3	12.5	1,920.0	0.3	251.6 #	21 #	24 #	16 #
Minimum:	0.1	11.2	562.5	0.1	0.3	0	1	0
Maximum:	161.4	16.5	2,238.8	0.8	158.1	1	1	1
%SI	12.50	12.50	12.50	29.17	12.50	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/15/2021 00:00	1.1	12.3	2,016.4	0.5	3.4	1	1	1
07/15/2021 01:00	0.3	13.6	1,562.9	0.5	0.8	1	1	0
07/15/2021 02:00	0.2	13.7	1,509.7	0.4	0.6	1	1	0
07/15/2021 03:00	0.3	13.7	1,490.1	0.2	0.8	1	1	0
07/15/2021 04:00	0.1	13.6	1,712.7	0.2	0.3	1	1	0
07/15/2021 05:00	0.9	12.4	1,975.5	0.3	2.8	1	1	1
07/15/2021 06:00	0.9	12.3	2,039.9	0.4	2.8	1	1	1
07/15/2021 07:00	0.1	13.6	1,646.3	0.4	0.3	1	1	1
07/15/2021 08:00	0.1	13.6	1,646.6	0.3	0.3	1	1	0
07/15/2021 09:00	0.1	13.7	1,574.1	0.1	0.3	1	1	0
07/15/2021 10:00	0.0	13.7	1,677.1	0.1	0.0	1	1	0
07/15/2021 11:00	0.3	13.7	1,575.4	0.1	0.9	1	1	1
07/15/2021 12:00	1.1	12.0	2,105.0	0.3	3.4	1	1	1
07/15/2021 13:00	0.5	11.7	2,152.1	0.4	1.5	1	1	1
07/15/2021 14:00	0.5	11.6	2,176.0	0.4	1.5	1	1	1
07/15/2021 15:00	0.4	11.6	2,180.0	0.3	1.2	1	1	1
07/15/2021 16:00	0.4	11.5	2,189.0	0.3	1.2	1	1	1
07/15/2021 17:00	0.4	11.5	2,181.1	0.3	1.2	1	1	1
07/15/2021 18:00	0.4	11.4	2,216.8	0.3	1.2	1	1	1
07/15/2021 19:00	0.4	11.3	2,224.1	0.2	1.2	1	1	1
07/15/2021 20:00	0.4	11.4	2,234.4	0.2	1.2	1	1	1
07/15/2021 21:00	0.5	11.7	2,169.3	0.2	1.6	1	1	1
07/15/2021 22:00	0.7	12.0	2,110.6	0.3	2.2	1	1	1
07/15/2021 23:00	0.7	12.0	2,120.0	0.4	2.2	1	1	1
Average/Sum#:	0.5	12.5	1,936.9	0.3	32.9 #	24 #	24 #	17 #
Minimum:	0.0	11.3	1,490.1	0.1	0.0	1	1	0
Maximum:	1.1	13.7	2,234.4	0.5	3.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/16/2021 00:00	0.7	12.1	2,113.2	0.5	2.2	1	1	1
07/16/2021 01:00	1.8	12.5	1,998.9	0.8	5.7	1	1	1
07/16/2021 02:00	0.1	13.6	1,639.8	0.6	0.3	1	1	0
07/16/2021 03:00	0.3	13.6	1,483.0	0.5	0.8	1	1	0
07/16/2021 04:00	0.1	13.6	1,636.0	0.1	0.3	1	1	0
07/16/2021 05:00	2.2	12.9	1,820.7	0.6	6.6	1	1	1
07/16/2021 06:00	1.0	12.7	1,887.8	0.8	3.0	1	1	1
07/16/2021 07:00	0.1	13.6	1,686.1	0.8	0.3	1	1	0
07/16/2021 08:00	0.1	13.6	1,688.3	0.3	0.3	1	1	0
07/16/2021 09:00	0.1	13.6	1,657.6	0.1	0.3	1	1	0
07/16/2021 10:00	0.1	13.6	1,705.4	0.1	0.3	1	1	0
07/16/2021 11:00	0.3	13.6	1,530.9	0.1	0.8	1	1	0
07/16/2021 12:00	1.1	12.3	2,041.8	0.4	3.4	1	1	1
07/16/2021 13:00	0.8	12.2	2,025.2	0.5	2.5	1	1	1
07/16/2021 14:00	0.1	13.6	1,667.1	0.5	0.3	1	1	0
07/16/2021 15:00	0.3	13.6	1,614.4	0.3	0.9	1	1	1
07/16/2021 16:00	1.1	12.0	2,126.2	0.3	3.5	1	1	1
07/16/2021 17:00	0.4	11.2	2,262.6	0.4	1.2	1	1	1
07/16/2021 18:00	0.3	11.1	2,284.9	0.4	0.9	1	1	1
07/16/2021 19:00	0.3	11.1	2,280.3	0.2	0.9	1	1	1
07/16/2021 20:00	0.4	11.3	2,263.6	0.2	1.2	1	1	1
07/16/2021 21:00	0.4	11.5	2,207.6	0.2	1.2	1	1	1
07/16/2021 22:00	0.5	11.7	2,174.9	0.3	1.6	1	1	1
07/16/2021 23:00	0.7	11.9	2,129.1	0.4	2.2	1	1	1
Average/Sum#:	0.6	12.6	1,913.6	0.4	40.7 #	24 #	24 #	15 #
Minimum:	0.1	11.1	1,483.0	0.1	0.3	1	1	0
Maximum:	2.2	13.6	2,284.9	0.8	6.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/17/2021 00:00	1.3	12.5	1,972.6	0.6	4.0	1	1	1
07/17/2021 01:00	0.2	13.6	1,666.8	0.5	0.6	1	1	0
07/17/2021 02:00	0.7	13.7	1,328.0	0.6	1.7	1	1	0
07/17/2021 03:00	0.1	13.7	1,634.2	0.3	0.3	1	1	0
07/17/2021 04:00	0.9	13.1	1,844.6	0.5	2.8	1	1	1
07/17/2021 05:00	0.9	12.9	1,879.3	0.5	2.8	1	1	1
07/17/2021 06:00	0.1	13.6	1,645.7	0.5	0.3	1	1	0
07/17/2021 07:00	0.1	13.7	1,649.0	0.3	0.3	1	1	0
07/17/2021 08:00	0.1	13.7	1,609.6	0.1	0.3	1	1	0
07/17/2021 09:00	0.1	13.6	1,703.5	0.1	0.3	1	1	0
07/17/2021 10:00	0.1	13.7	1,622.1	0.1	0.3	1	1	0
07/17/2021 11:00	0.1	13.7	1,538.1	0.1	0.3	1	1	0
07/17/2021 12:00	0.2	13.6	1,639.8	0.1	0.6	1	1	1
07/17/2021 13:00	0.9	11.9	2,136.6	0.3	2.8	1	1	1
07/17/2021 14:00	0.4	11.3	2,246.5	0.3	1.2	1	1	1
07/17/2021 15:00	0.3	11.3	2,243.6	0.3	0.9	1	1	1
07/17/2021 16:00	0.3	11.2	2,262.7	0.2	0.9	1	1	1
07/17/2021 17:00	0.2	11.1	2,283.0	0.2	0.6	1	1	1
07/17/2021 18:00	0.3	11.1	2,286.9	0.2	0.9	1	1	1
07/17/2021 19:00	0.3	11.0	2,279.2	0.2	0.9	1	1	1
07/17/2021 20:00	0.3	11.2	2,258.8	0.2	0.9	1	1	1
07/17/2021 21:00	0.3	11.3	2,224.9	0.2	0.9	1	1	1
07/17/2021 22:00	0.5	11.7	2,172.0	0.2	1.6	1	1	1
07/17/2021 23:00	0.5	11.7	2,167.3	0.3	1.6	1	1	1
Average/Sum#:	0.4	12.5	1,929.0	0.3	27.8 #	24 #	24 #	15 #
Minimum:	0.1	11.0	1,328.0	0.1	0.3	1	1	0
Maximum:	1.3	13.7	2,286.9	0.6	4.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/18/2021 00:00	0.8	12.2	2,036.6	0.4	2.5	1	1	1
07/18/2021 01:00	0.2	13.6	1,668.4	0.3	0.6	1	1	0
07/18/2021 02:00	0.4	13.6	1,587.1	0.3	1.1	1	1	1
07/18/2021 03:00	1.1	12.3	2,060.2	0.4	3.5	1	1	1
07/18/2021 04:00	1.0	12.4	2,004.2	0.6	3.1	1	1	1
07/18/2021 05:00	0.2	13.6	1,675.6	0.6	0.6	1	1	0
07/18/2021 06:00	0.1	13.6	1,676.3	0.3	0.3	1	1	0
07/18/2021 07:00	0.1	13.7	1,669.6	0.1	0.3	1	1	0
07/18/2021 08:00	0.1	13.6	1,691.3	0.1	0.3	1	1	0
07/18/2021 09:00	0.0	13.7	1,665.4	0.1	0.0	1	1	0
07/18/2021 10:00	0.1	13.7	1,606.5	0.1	0.3	1	1	0
07/18/2021 11:00	0.2	13.6	1,723.2	0.1	0.6	1	1	1
07/18/2021 12:00	0.9	11.9	2,125.3	0.3	2.8	1	1	1
07/18/2021 13:00	0.3	11.1	2,274.2	0.3	0.9	1	1	1
07/18/2021 14:00	0.2	11.1	2,280.6	0.3	0.6	1	1	1
07/18/2021 15:00	0.2	11.1	2,277.0	0.1	0.6	1	1	1
07/18/2021 16:00	0.2	11.0	2,268.0	0.1	0.6	1	1	1
07/18/2021 17:00	0.2	11.0	2,262.4	0.1	0.6	1	1	1
07/18/2021 18:00	0.3	11.2	2,228.6	0.1	0.9	1	1	1
07/18/2021 19:00	0.3	11.4	2,208.5	0.2	0.9	1	1	1
07/18/2021 20:00	0.4	11.5	2,203.7	0.2	1.2	1	1	1
07/18/2021 21:00	0.3	11.3	2,246.1	0.2	0.9	1	1	1
07/18/2021 22:00	0.4	11.4	2,236.8	0.2	1.2	1	1	1
07/18/2021 23:00	0.3	11.4	2,233.9	0.2	0.9	1	1	1
Average/Sum#:	0.3	12.3	1,996.2	0.2	25.3 #	24 #	24 #	17 #
Minimum:	0.0	11.0	1,587.1	0.1	0.0	1	1	0
Maximum:	1.1	13.7	2,280.6	0.6	3.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/19/2021 00:00	0.4	11.5	2,213.9	0.2	1.2	1	1	1
07/19/2021 01:00	0.2	13.3	1,723.8	0.2	0.6	1	1	1
07/19/2021 02:00	0.1	13.6	1,698.0	0.2	0.3	1	1	0
07/19/2021 03:00	0.2	13.6	1,645.9	0.2	0.6	1	1	0
07/19/2021 04:00	0.2	13.6	1,714.6	0.2	0.6	1	1	1
07/19/2021 05:00	0.8	11.9	2,086.0	0.3	2.4	1	1	1
07/19/2021 06:00	0.7	11.8	2,125.0	0.4	2.2	1	1	1
07/19/2021 07:00	0.2	13.6	1,614.4	0.4	0.6	1	1	0
07/19/2021 08:00	0.2	13.6	1,636.5	0.3	0.6	1	1	0
07/19/2021 09:00	0.3	13.6	1,598.9	0.2	0.9	1	1	0
07/19/2021 10:00	0.6	12.0	2,098.5	0.3	1.9	1	1	1
07/19/2021 11:00	0.3	11.2	2,247.4	0.3	0.9	1	1	1
07/19/2021 12:00	0.3	11.1	2,271.4	0.3	0.9	1	1	1
07/19/2021 13:00	0.3	11.1	2,271.8	0.2	0.9	1	1	1
07/19/2021 14:00	0.3	11.1	2,276.4	0.2	0.9	1	1	1
07/19/2021 15:00	0.3	11.0	2,265.0	0.2	0.9	1	1	1
07/19/2021 16:00	0.2	11.0	2,276.1	0.2	0.6	1	1	1
07/19/2021 17:00	0.3	11.1	2,275.8	0.2	0.9	1	1	1
07/19/2021 18:00	0.3	11.1	2,278.6	0.2	0.9	1	1	1
07/19/2021 19:00	0.3	11.1	2,290.5	0.2	0.9	1	1	1
07/19/2021 20:00	0.3	11.1	2,284.8	0.2	0.9	1	1	1
07/19/2021 21:00	0.3	11.2	2,252.2	0.2	0.9	1	1	1
07/19/2021 22:00	0.5	11.8	2,141.8	0.2	1.6	1	1	1
07/19/2021 23:00	0.6	11.9	2,128.5	0.3	1.9	1	1	1
Average/Sum#:	0.3	12.0	2,059.0	0.2	25.0 #	24 #	24 #	19 #
Minimum:	0.1	11.0	1,598.9	0.2	0.3	1	1	0
Maximum:	0.8	13.6	2,290.5	0.4	2.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/20/2021 00:00	0.7	12.0	2,099.3	0.4	2.2	1	1	1
07/20/2021 01:00	0.2	13.5	1,690.0	0.4	0.6	1	1	1
07/20/2021 02:00	0.1	13.6	1,700.2	0.3	0.3	1	1	0
07/20/2021 03:00	0.2	13.6	1,701.4	0.2	0.6	1	1	1
07/20/2021 04:00	1.2	12.3	2,073.1	0.4	3.8	1	1	1
07/20/2021 05:00	0.6	11.7	2,204.6	0.5	1.9	1	1	1
07/20/2021 06:00	0.3	13.3	1,694.2	0.5	0.9	1	1	1
07/20/2021 07:00	0.1	13.6	1,657.8	0.2	0.3	1	1	0
07/20/2021 08:00	0.2	13.6	1,606.9	0.2	0.6	1	1	0
07/20/2021 09:00	0.1	13.6	1,643.0	0.1	0.3	1	1	0
07/20/2021 10:00	0.1	13.6	1,677.9	0.1	0.3	1	1	0
07/20/2021 11:00	0.2	13.6	1,603.9	0.1	0.6	1	1	0
07/20/2021 12:00	0.1	13.6	1,675.6	0.1	0.3	1	1	1
07/20/2021 13:00	1.1	12.0	2,089.1	0.3	3.4	1	1	1
07/20/2021 14:00	0.4	11.3	2,204.6	0.3	1.2	1	1	1
07/20/2021 15:00	0.3	11.2	2,237.2	0.4	0.9	1	1	1
07/20/2021 16:00	0.2	11.0	2,268.2	0.2	0.6	1	1	1
07/20/2021 17:00	0.2	11.0	2,269.9	0.1	0.6	1	1	1
07/20/2021 18:00	0.3	11.0	2,272.6	0.1	0.9	1	1	1
07/20/2021 19:00	0.3	11.0	2,266.0	0.2	0.9	1	1	1
07/20/2021 20:00	0.3	11.0	2,288.8	0.2	0.9	1	1	1
07/20/2021 21:00	0.4	11.3	2,224.6	0.2	1.2	1	1	1
07/20/2021 22:00	0.5	11.5	2,198.7	0.2	1.5	1	1	1
07/20/2021 23:00	0.5	11.7	2,174.3	0.3	1.6	1	1	1
Average/Sum#:	0.4	12.3	1,980.1	0.3	26.4 #	24 #	24 #	18 #
Minimum:	0.1	11.0	1,603.9	0.1	0.3	1	1	0
Maximum:	1.2	13.6	2,288.8	0.5	3.8	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/21/2021 00:00	0.7	12.2	2,055.4	0.4	2.2	1	1	1
07/21/2021 01:00	0.1	13.6	1,647.8	0.3	0.3	1	1	0
07/21/2021 02:00	0.0	13.6	1,669.5	0.2	0.0	1	1	0
07/21/2021 03:00	0.5	12.9	1,864.7	0.2	1.5	1	1	1
07/21/2021 04:00	0.6	12.1	2,071.1	0.3	1.9	1	1	1
07/21/2021 05:00	0.1	13.6	1,635.7	0.3	0.3	1	1	0
07/21/2021 06:00	0.2	13.6	1,593.0	0.2	0.6	1	1	1
07/21/2021 07:00	1.0	12.3	2,065.1	0.3	3.2	1	1	1
07/21/2021 08:00	1.0	12.5	1,992.1	0.5	3.1	1	1	1
07/21/2021 09:00	0.1	13.6	1,705.7	0.5	0.3	1	1	0
07/21/2021 10:00	0.3	13.6	1,619.9	0.3	0.9	1	1	1
07/21/2021 11:00	0.8	12.0	2,109.5	0.3	2.5	1	1	1
07/21/2021 12:00	0.6	11.7	2,154.6	0.4	1.9	1	1	1
07/21/2021 13:00	0.6	11.7	2,175.1	0.4	1.9	1	1	1
07/21/2021 14:00	0.5	11.5	2,188.9	0.4	1.5	1	1	1
07/21/2021 15:00	0.5	11.4	2,210.2	0.3	1.5	1	1	1
07/21/2021 16:00	0.4	11.4	2,206.1	0.3	1.2	1	1	1
07/21/2021 17:00	0.4	11.3	2,229.6	0.2	1.2	1	1	1
07/21/2021 18:00	0.4	11.0	2,270.4	0.2	1.2	1	1	1
07/21/2021 19:00	0.4	11.0	2,270.4	0.2	1.2	1	1	1
07/21/2021 20:00	0.4	11.0	2,281.4	0.2	1.2	1	1	1
07/21/2021 21:00	0.5	11.3	2,240.9	0.2	1.5	1	1	1
07/21/2021 22:00	0.6	11.5	2,206.0	0.3	1.9	1	1	1
07/21/2021 23:00	0.7	11.8	2,143.1	0.4	2.2	1	1	1
Average/Sum#:	0.5	12.2	2,025.3	0.3	35.2 #	24 #	24 #	20 #
Minimum:	0.0	11.0	1,593.0	0.2	0.0	1	1	0
Maximum:	1.0	13.6	2,281.4	0.5	3.2	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/22/2021 00:00	0.9	12.2	2,045.5	0.5	2.8	1	1	1
07/22/2021 01:00	0.2	13.6	1,676.7	0.4	0.6	1	1	0
07/22/2021 02:00	0.5	13.5	1,576.1	0.4	1.4	1	1	1
07/22/2021 03:00	0.7	12.2	2,056.5	0.4	2.2	1	1	1
07/22/2021 04:00	0.6	12.4	1,998.4	0.4	1.9	1	1	1
07/22/2021 05:00	0.1	13.6	1,615.0	0.3	0.3	1	1	0
07/22/2021 06:00	0.1	13.5	1,705.5	0.2	0.3	1	1	1
07/22/2021 07:00	0.9	12.2	2,067.2	0.3	2.8	1	1	1
07/22/2021 08:00	1.0	12.5	2,005.3	0.5	3.2	1	1	1
07/22/2021 09:00	0.3	13.5	1,627.9	0.5	0.9	1	1	1
07/22/2021 10:00	0.2	13.6	1,651.1	0.4	0.6	1	1	0
07/22/2021 11:00	0.1	13.5	1,770.1	0.2	0.3	1	1	1
07/22/2021 12:00	1.0	11.9	2,135.0	0.3	3.1	1	1	1
07/22/2021 13:00	0.5	11.3	2,257.4	0.4	1.6	1	1	1
07/22/2021 14:00	0.5	11.4	2,230.9	0.4	1.6	1	1	1
07/22/2021 15:00	0.5	11.4	2,225.0	0.3	1.5	1	1	1
07/22/2021 16:00	0.4	11.2	2,264.5	0.3	1.2	1	1	1
07/22/2021 17:00	0.4	11.3	2,246.1	0.2	1.2	1	1	1
07/22/2021 18:00	0.4	11.1	2,284.5	0.2	1.2	1	1	1
07/22/2021 19:00	0.4	11.1	2,277.1	0.2	1.2	1	1	1
07/22/2021 20:00	0.4	11.2	2,257.8	0.2	1.2	1	1	1
07/22/2021 21:00	0.5	11.6	2,172.3	0.2	1.5	1	1	1
07/22/2021 22:00	0.6	11.7	2,155.3	0.3	1.9	1	1	1
07/22/2021 23:00	0.7	12.0	2,074.1	0.4	2.2	1	1	1
Average/Sum#:	0.5	12.2	2,015.6	0.3	36.7 #	24 #	24 #	21 #
Minimum:	0.1	11.1	1,576.1	0.2	0.3	1	1	0
Maximum:	1.0	13.6	2,284.5	0.5	3.2	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/23/2021 00:00	0.1	13.6	1,691.2	0.3	0.3	1	1	0
07/23/2021 01:00	0.2	13.6	1,662.7	0.3	0.6	1	1	1
07/23/2021 02:00	1.2	12.2	2,074.7	0.4	3.8	1	1	1
07/23/2021 03:00	1.0	12.5	1,976.9	0.6	3.1	1	1	1
07/23/2021 04:00	0.1	13.6	1,696.4	0.5	0.3	1	1	0
07/23/2021 05:00	0.2	13.6	1,664.0	0.3	0.6	1	1	0
07/23/2021 06:00	0.2	13.6	1,678.0	0.2	0.6	1	1	0
07/23/2021 07:00	0.2	13.6	1,651.9	0.2	0.6	1	1	0
07/23/2021 08:00	0.1	13.6	1,690.7	0.2	0.3	1	1	0
07/23/2021 09:00	0.1	13.6	1,674.8	0.1	0.3	1	1	0
07/23/2021 10:00	0.1	13.6	1,713.8	0.1	0.3	1	1	0
07/23/2021 11:00	0.2	13.5	1,725.3	0.1	0.6	1	1	1
07/23/2021 12:00	0.7	11.7	2,166.0	0.2	2.2	1	1	1
07/23/2021 13:00	0.3	11.1	2,284.6	0.3	0.9	1	1	1
07/23/2021 14:00	0.3	11.1	2,290.7	0.3	0.9	1	1	1
07/23/2021 15:00	0.2	11.1	2,287.8	0.2	0.6	1	1	1
07/23/2021 16:00	0.2	11.1	2,284.9	0.1	0.6	1	1	1
07/23/2021 17:00	0.2	11.1	2,289.6	0.1	0.6	1	1	1
07/23/2021 18:00	0.3	11.0	2,287.2	0.1	0.9	1	1	1
07/23/2021 19:00	0.3	11.0	2,294.7	0.2	0.9	1	1	1
07/23/2021 20:00	0.3	11.1	2,284.1	0.2	0.9	1	1	1
07/23/2021 21:00	0.5	11.5	2,224.0	0.2	1.6	1	1	1
07/23/2021 22:00	0.7	11.8	2,143.6	0.3	2.2	1	1	1
07/23/2021 23:00	0.7	11.9	2,134.5	0.4	2.2	1	1	1
Average/Sum#:	0.4	12.3	1,994.7	0.2	25.9 #	24 #	24 #	16 #
Minimum:	0.1	11.0	1,651.9	0.1	0.3	1	1	0
Maximum:	1.2	13.6	2,294.7	0.6	3.8	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/24/2021 00:00	0.7	12.0	2,122.2	0.5	2.2	1	1	1
07/24/2021 01:00	0.9	12.5	1,978.3	0.5	2.8	1	1	1
07/24/2021 02:00	0.2	13.6	1,669.3	0.4	0.6	1	1	0
07/24/2021 03:00	0.3	13.6	1,738.0	0.3	0.9	1	1	1
07/24/2021 04:00	1.0	12.3	2,058.4	0.4	3.2	1	1	1
07/24/2021 05:00	1.1	12.6	1,980.7	0.6	3.5	1	1	1
07/24/2021 06:00	0.2	13.6	1,663.6	0.6	0.6	1	1	0
07/24/2021 07:00	0.3	13.6	1,622.5	0.4	0.9	1	1	0
07/24/2021 08:00	0.2	13.6	1,633.2	0.2	0.6	1	1	0
07/24/2021 09:00	0.1	13.6	1,662.8	0.2	0.3	1	1	0
07/24/2021 10:00	0.1	13.6	1,624.6	0.1	0.3	1	1	0
07/24/2021 11:00	0.0	13.6	1,664.4	0.1	0.0	1	1	0
07/24/2021 12:00	1.0	12.0	2,089.7	0.3	3.1	1	1	1
07/24/2021 13:00	0.6	11.4	2,191.7	0.4	1.8	1	1	1
07/24/2021 14:00	0.6	11.6	2,142.8	0.5	1.8	1	1	1
07/24/2021 15:00	0.0	13.6	1,687.8	0.3	0.0	1	1	0
07/24/2021 16:00	0.1	13.6	1,711.0	0.2	0.3	1	1	1
07/24/2021 17:00	0.9	11.9	2,094.4	0.2	2.8	1	1	1
07/24/2021 18:00	0.6	11.3	2,201.5	0.4	1.8	1	1	1
07/24/2021 19:00	0.4	11.0	2,273.6	0.4	1.2	1	1	1
07/24/2021 20:00	0.4	11.0	2,282.5	0.3	1.2	1	1	1
07/24/2021 21:00	0.5	11.2	2,252.2	0.2	1.5	1	1	1
07/24/2021 22:00	0.6	11.6	2,176.1	0.3	1.9	1	1	1
07/24/2021 23:00	0.6	11.5	2,189.6	0.4	1.8	1	1	1
Average/Sum#:	0.5	12.5	1,946.3	0.3	35.1 #	24 #	24 #	16 #
Minimum:	0.0	11.0	1,622.5	0.1	0.0	1	1	0
Maximum:	1.1	13.6	2,282.5	0.6	3.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/25/2021 00:00	0.8	12.3	2,006.6	0.4	2.5	1	1	1
07/25/2021 01:00	0.2	13.6	1,660.5	0.4	0.6	1	1	0
07/25/2021 02:00	0.3	13.6	1,601.6	0.3	0.9	1	1	1
07/25/2021 03:00	0.8	12.1	2,080.6	0.3	2.5	1	1	1
07/25/2021 04:00	0.7	12.4	1,978.5	0.4	2.2	1	1	1
07/25/2021 05:00	0.2	13.6	1,686.6	0.4	0.6	1	1	0
07/25/2021 06:00	0.2	13.6	1,676.1	0.3	0.6	1	1	0
07/25/2021 07:00	0.2	13.6	1,686.1	0.2	0.6	1	1	0
07/25/2021 08:00	0.2	13.6	1,697.9	0.2	0.6	1	1	0
07/25/2021 09:00	0.2	13.6	1,692.5	0.2	0.6	1	1	0
07/25/2021 10:00	0.1	13.6	1,688.9	0.2	0.3	1	1	0
07/25/2021 11:00	0.4	13.6	1,538.8	0.2	1.1	1	1	1
07/25/2021 12:00	0.9	11.8	2,117.2	0.3	2.8	1	1	1
07/25/2021 13:00	0.6	11.6	2,129.1	0.4	1.8	1	1	1
07/25/2021 14:00	0.0	13.6	1,683.6	0.3	0.0	1	1	0
07/25/2021 15:00	0.0	13.5	1,719.6	0.1	0.0	1	1	0
07/25/2021 16:00	0.0	13.4	1,730.4	0.0	0.0	1	1	1
07/25/2021 17:00	0.8	11.5	2,141.1	0.2	2.4	1	1	1
07/25/2021 18:00	0.4	11.0	2,253.0	0.2	1.2	1	1	1
07/25/2021 19:00	0.5	11.3	2,206.5	0.3	1.5	1	1	1
07/25/2021 20:00	0.6	11.5	2,160.7	0.3	1.8	1	1	1
07/25/2021 21:00	0.7	11.8	2,123.6	0.4	2.2	1	1	1
07/25/2021 22:00	0.8	11.9	2,108.7	0.5	2.5	1	1	1
07/25/2021 23:00	0.7	11.8	2,133.2	0.5	2.2	1	1	1
Average/Sum#:	0.4	12.7	1,895.9	0.3	31.5 #	24 #	24 #	15 #
Minimum:	0.0	11.0	1,538.8	0.0	0.0	1	1	0
Maximum:	0.9	13.6	2,253.0	0.5	2.8	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/26/2021 00:00	0.9	12.4	2,001.4	0.5	2.8	1	1	1
07/26/2021 01:00	0.2	13.6	1,617.4	0.4	0.6	1	1	0
07/26/2021 02:00	0.1	13.6	1,646.6	0.3	0.3	1	1	1
07/26/2021 03:00	0.8	12.2	2,062.3	0.3	2.5	1	1	1
07/26/2021 04:00	0.7	12.0	2,085.0	0.4	2.2	1	1	1
07/26/2021 05:00	0.0	13.6	1,698.6	0.3	0.0	1	1	1
07/26/2021 06:00	0.0	13.6	1,624.4	0.2	0.0	1	1	0
07/26/2021 07:00	0.3	13.6	1,538.3	0.1	0.8	1	1	0
07/26/2021 08:00	0.1	13.6	1,683.2	0.1	0.3	1	1	0
07/26/2021 09:00	0.3	13.6	1,565.3	0.2	0.8	1	1	0
07/26/2021 10:00	0.1	13.6	1,679.6	0.1	0.3	1	1	1
07/26/2021 11:00	1.0	12.0	2,101.0	0.3	3.1	1	1	1
07/26/2021 12:00	0.5	11.2	2,245.3	0.4	1.5	1	1	1
07/26/2021 13:00	0.5	11.2	2,241.8	0.4	1.5	1	1	1
07/26/2021 14:00	0.5	11.4	2,207.6	0.3	1.5	1	1	1
07/26/2021 15:00	0.4	11.1	2,268.8	0.3	1.2	1	1	1
07/26/2021 16:00	0.4	11.0	2,267.0	0.2	1.2	1	1	1
07/26/2021 17:00	0.5	11.2	2,234.1	0.2	1.5	1	1	1
07/26/2021 18:00	0.5	11.2	2,247.4	0.3	1.5	1	1	1
07/26/2021 19:00	0.5	11.2	2,243.5	0.3	1.5	1	1	1
07/26/2021 20:00	0.6	11.3	2,234.6	0.3	1.8	1	1	1
07/26/2021 21:00	0.5	11.2	2,281.9	0.3	1.6	1	1	1
07/26/2021 22:00	0.6	11.5	2,214.6	0.4	1.9	1	1	1
07/26/2021 23:00	0.9	12.2	2,057.6	0.4	2.8	1	1	1
Average/Sum#:	0.5	12.2	2,002.0	0.3	33.2 #	24 #	24 #	19 #
Minimum:	0.0	11.0	1,538.3	0.1	0.0	1	1	0
Maximum:	1.0	13.6	2,281.9	0.5	3.1	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/27/2021 00:00	0.2	13.6	1,632.3	0.4	0.6	1	1	0
07/27/2021 01:00	0.2	13.6	1,700.7	0.3	0.6	1	1	1
07/27/2021 02:00	1.2	12.6	1,981.7	0.4	3.8	1	1	1
07/27/2021 03:00	1.2	12.6	1,950.6	0.7	3.7	1	1	1
07/27/2021 04:00	0.2	13.6	1,654.6	0.7	0.6	1	1	0
07/27/2021 05:00	0.1	13.6	1,738.1	0.4	0.3	1	1	1
07/27/2021 06:00	1.0	12.3	2,067.6	0.3	3.2	1	1	1
07/27/2021 07:00	0.6	12.6	1,958.7	0.4	1.9	1	1	1
07/27/2021 08:00	0.0	13.7	1,686.7	0.4	0.0	1	1	0
07/27/2021 09:00	0.1	13.7	1,700.5	0.2	0.3	1	1	0
07/27/2021 10:00	0.1	13.6	1,701.0	0.1	0.3	1	1	0
07/27/2021 11:00	0.1	13.6	1,710.7	0.1	0.3	1	1	0
07/27/2021 12:00	0.9	12.1	2,118.3	0.3	2.9	1	1	1
07/27/2021 13:00	0.6	11.3	2,264.0	0.4	1.9	1	1	1
07/27/2021 14:00	0.5	11.4	2,257.6	0.4	1.6	1	1	1
07/27/2021 15:00	0.5	11.4	2,252.5	0.3	1.6	1	1	1
07/27/2021 16:00	0.6	11.6	2,215.2	0.3	1.9	1	1	1
07/27/2021 17:00	0.5	11.3	2,263.8	0.3	1.6	1	1	1
07/27/2021 18:00	0.5	11.3	2,273.8	0.3	1.6	1	1	1
07/27/2021 19:00	0.5	11.3	2,274.4	0.3	1.6	1	1	1
07/27/2021 20:00	0.5	11.3	2,269.4	0.3	1.6	1	1	1
07/27/2021 21:00	0.5	11.4	2,267.5	0.3	1.6	1	1	1
07/27/2021 22:00	0.5	11.5	2,240.1	0.3	1.6	1	1	1
07/27/2021 23:00	0.6	11.5	2,227.1	0.3	1.9	1	1	1
Average/Sum#:	0.5	12.4	2,017.0	0.3	37.0 #	24 #	24 #	18 #
Minimum:	0.0	11.3	1,632.3	0.1	0.0	1	1	0
Maximum:	1.2	13.7	2,274.4	0.7	3.8	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/28/2021 00:00	0.6	11.8	2,180.2	0.4	1.9	1	1	1
07/28/2021 01:00	0.9	12.5	1,979.6	0.5	2.8	1	1	1
07/28/2021 02:00	0.1	13.6	1,690.5	0.4	0.3	1	1	0
07/28/2021 03:00	0.2	13.6	1,679.4	0.3	0.6	1	1	1
07/28/2021 04:00	1.2	12.2	2,087.5	0.4	3.8	1	1	1
07/28/2021 05:00	0.6	11.5	2,230.0	0.5	1.9	1	1	1
07/28/2021 06:00	0.7	11.7	2,149.9	0.5	2.2	1	1	1
07/28/2021 07:00	0.1	13.6	1,669.3	0.3	0.3	1	1	0
07/28/2021 08:00	0.1	13.5	1,712.9	0.2	0.3	1	1	1
07/28/2021 09:00	0.6	11.8	2,093.3	0.2	1.8	1	1	1
07/28/2021 10:00	0.5	11.1	2,252.5	0.3	1.5	1	1	1
07/28/2021 11:00	0.4	11.1	2,248.6	0.3	1.2	1	1	1
07/28/2021 12:00	0.4	11.2	2,237.6	0.2	1.2	1	1	1
07/28/2021 13:00	0.4	11.1	2,239.8	0.2	1.2	1	1	1
07/28/2021 14:00	0.4	11.2	2,236.4	0.2	1.2	1	1	1
07/28/2021 15:00	0.4	11.1	2,227.9	0.2	1.2	1	1	1
07/28/2021 16:00	0.4	11.1	2,228.3	0.2	1.2	1	1	1
07/28/2021 17:00	0.4	11.1	2,224.5	0.2	1.2	1	1	1
07/28/2021 18:00	0.4	11.2	2,209.0	0.2	1.2	1	1	1
07/28/2021 19:00	0.5	11.4	2,182.4	0.2	1.5	1	1	1
07/28/2021 20:00	0.6	11.5	2,166.0	0.3	1.8	1	1	1
07/28/2021 21:00	0.5	11.2	2,228.9	0.3	1.5	1	1	1
07/28/2021 22:00	0.5	11.4	2,202.9	0.3	1.5	1	1	1
07/28/2021 23:00	0.6	11.3	2,217.5	0.3	1.8	1	1	1
Average/Sum#:	0.5	11.8	2,107.3	0.3	35.1 #	24 #	24 #	22 #
Minimum:	0.1	11.1	1,669.3	0.2	0.3	1	1	0
Maximum:	1.2	13.6	2,252.5	0.5	3.8	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/29/2021 00:00	0.6	11.2	2,249.3	0.4	1.8	1	1	1
07/29/2021 01:00	0.6	11.4	2,211.3	0.4	1.8	1	1	1
07/29/2021 02:00	0.4	13.2	1,628.3	0.4	1.1	1	1	1
07/29/2021 03:00	0.3	13.6	1,728.2	0.3	0.9	1	1	1
07/29/2021 04:00	1.0	12.0	2,104.2	0.4	3.1	1	1	1
07/29/2021 05:00	0.6	11.4	2,237.5	0.4	1.9	1	1	1
07/29/2021 06:00	0.7	11.8	2,127.8	0.5	2.2	1	1	1
07/29/2021 07:00	0.1	13.6	1,658.6	0.3	0.3	1	1	0
07/29/2021 08:00	0.3	13.6	1,688.4	0.3	0.9	1	1	1
07/29/2021 09:00	1.1	12.1	2,056.7	0.3	3.4	1	1	1
07/29/2021 10:00	0.5	11.0	2,272.3	0.4	1.5	1	1	1
07/29/2021 11:00	0.4	11.0	2,271.4	0.4	1.2	1	1	1
07/29/2021 12:00	0.4	11.0	2,262.6	0.2	1.2	1	1	1
07/29/2021 13:00	0.4	11.0	2,258.5	0.2	1.2	1	1	1
07/29/2021 14:00	0.4	11.0	2,250.1	0.2	1.2	1	1	1
07/29/2021 15:00	0.3	11.0	2,246.5	0.2	0.9	1	1	1
07/29/2021 16:00	0.3	11.0	2,241.6	0.2	0.9	1	1	1
07/29/2021 17:00	0.4	11.0	2,241.8	0.2	1.2	1	1	1
07/29/2021 18:00	0.4	11.0	2,240.1	0.2	1.2	1	1	1
07/29/2021 19:00	0.4	11.0	2,241.8	0.2	1.2	1	1	1
07/29/2021 20:00	0.5	11.1	2,218.7	0.2	1.5	1	1	1
07/29/2021 21:00	0.5	11.1	2,246.9	0.3	1.5	1	1	1
07/29/2021 22:00	0.5	11.2	2,240.0	0.3	1.5	1	1	1
07/29/2021 23:00	0.5	11.2	2,229.3	0.3	1.5	1	1	1
Average/Sum#:	0.5	11.6	2,131.3	0.3	35.1 #	24 #	24 #	23 #
Minimum:	0.1	11.0	1,628.3	0.2	0.3	1	1	0
Maximum:	1.1	13.6	2,272.3	0.5	3.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/30/2021 00:00	0.6	11.4	2,209.5	0.3	1.8	1	1	1
07/30/2021 01:00	0.6	11.6	2,137.2	0.4	1.8	1	1	1
07/30/2021 02:00	0.3	13.5	1,702.8	0.3	0.9	1	1	1
07/30/2021 03:00	0.2	13.6	1,742.5	0.3	0.6	1	1	1
07/30/2021 04:00	0.9	11.8	2,141.4	0.3	2.8	1	1	1
07/30/2021 05:00	0.6	11.1	2,285.8	0.4	1.8	1	1	1
07/30/2021 06:00	0.6	11.3	2,246.4	0.5	1.9	1	1	1
07/30/2021 07:00	0.6	11.3	2,237.5	0.4	1.8	1	1	1
07/30/2021 08:00	0.6	11.3	2,217.5	0.4	1.8	1	1	1
07/30/2021 09:00	0.5	11.2	2,240.6	0.4	1.5	1	1	1
07/30/2021 10:00	0.5	11.1	2,244.0	0.3	1.5	1	1	1
07/30/2021 11:00	0.4	11.0	2,257.2	0.3	1.2	1	1	1
07/30/2021 12:00	0.4	11.0	2,250.5	0.2	1.2	1	1	1
07/30/2021 13:00	0.4	11.0	2,247.3	0.2	1.2	1	1	1
07/30/2021 14:00	0.4	11.0	2,241.3	0.2	1.2	1	1	1
07/30/2021 15:00	0.4	11.0	2,235.8	0.2	1.2	1	1	1
07/30/2021 16:00	0.4	11.1	2,228.6	0.2	1.2	1	1	1
07/30/2021 17:00	0.4	11.1	2,227.9	0.2	1.2	1	1	1
07/30/2021 18:00	0.4	11.1	2,219.0	0.2	1.2	1	1	1
07/30/2021 19:00	0.4	11.0	2,238.0	0.2	1.2	1	1	1
07/30/2021 20:00	0.4	11.0	2,246.4	0.2	1.2	1	1	1
07/30/2021 21:00	0.4	11.1	2,226.5	0.2	1.2	1	1	1
07/30/2021 22:00	0.4	11.1	2,236.3	0.2	1.2	1	1	1
07/30/2021 23:00	0.5	11.1	2,250.8	0.2	1.5	1	1	1
Average/Sum#:	0.5	11.4	2,188.0	0.3	34.1 #	24 #	24 #	24 #
Minimum:	0.2	11.0	1,702.8	0.2	0.6	1	1	1
Maximum:	0.9	13.6	2,285.8	0.5	2.8	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/31/2021 00:00	0.5	11.1	2,278.6	0.3	1.5	1	1	1
07/31/2021 01:00	0.5	11.3	2,268.1	0.3	1.6	1	1	1
07/31/2021 02:00	0.6	11.5	2,221.4	0.3	1.9	1	1	1
07/31/2021 03:00	0.3	13.3	1,705.9	0.3	0.9	1	1	1
07/31/2021 04:00	0.1	13.5	1,783.4	0.2	0.3	1	1	0
07/31/2021 05:00	1.2	12.5	1,944.3	0.4	3.7	1	1	1
07/31/2021 06:00	0.8	11.8	2,128.1	0.5	2.5	1	1	1
07/31/2021 07:00	0.1	13.6	1,692.5	0.5	0.3	1	1	0
07/31/2021 08:00	0.4	13.6	1,592.9	0.3	1.2	1	1	1
07/31/2021 09:00	1.1	12.2	2,072.5	0.4	3.5	1	1	1
07/31/2021 10:00	0.9	11.9	2,124.4	0.5	2.8	1	1	1
07/31/2021 11:00	0.8	11.8	2,137.8	0.6	2.5	1	1	1
07/31/2021 12:00	0.7	11.7	2,147.2	0.5	2.2	1	1	1
07/31/2021 13:00	0.7	11.7	2,140.4	0.4	2.2	1	1	1
07/31/2021 14:00	0.7	11.7	2,146.8	0.4	2.2	1	1	1
07/31/2021 15:00	0.7	11.6	2,155.2	0.4	2.1	1	1	1
07/31/2021 16:00	0.6	11.5	2,161.5	0.4	1.8	1	1	1
07/31/2021 17:00	0.6	11.4	2,195.2	0.4	1.8	1	1	1
07/31/2021 18:00	0.6	11.3	2,221.4	0.4	1.8	1	1	1
07/31/2021 19:00	0.6	11.4	2,218.5	0.4	1.9	1	1	1
07/31/2021 20:00	0.6	11.2	2,264.0	0.4	1.8	1	1	1
07/31/2021 21:00	0.6	11.3	2,237.7	0.4	1.8	1	1	1
07/31/2021 22:00	0.6	11.5	2,210.9	0.4	1.9	1	1	1
07/31/2021 23:00	0.8	11.9	2,144.6	0.4	2.5	1	1	1
Average/Sum#:	0.6	11.9	2,091.4	0.4	46.7 #	24 #	24 #	22 #
Minimum:	0.1	11.1	1,592.9	0.2	0.3	1	1	0
Maximum:	1.2	13.6	2,278.6	0.6	3.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/01/2021 00:00	1.1	12.5	1,998.4	0.6	3.5	1	1	1
08/01/2021 01:00	0.2	13.6	1,662.9	0.5	0.6	1	1	0
08/01/2021 02:00	0.3	13.6	1,707.2	0.4	0.9	1	1	1
08/01/2021 03:00	1.2	12.3	2,048.0	0.4	3.8	1	1	1
08/01/2021 04:00	1.0	12.4	2,006.0	0.6	3.1	1	1	1
08/01/2021 05:00	0.2	13.6	1,692.6	0.6	0.6	1	1	0
08/01/2021 06:00	0.2	13.6	1,641.8	0.4	0.6	1	1	0
08/01/2021 07:00	0.2	13.6	1,623.5	0.2	0.6	1	1	0
08/01/2021 08:00	0.4	13.7	1,418.4	0.2	1.0	1	1	0
08/01/2021 09:00	0.3	13.6	1,582.5	0.2	0.9	1	1	1
08/01/2021 10:00	1.0	12.1	2,082.3	0.4	3.1	1	1	1
08/01/2021 11:00	0.9	12.1	2,028.7	0.5	2.7	1	1	1
08/01/2021 12:00	0.1	13.6	1,635.4	0.5	0.3	1	1	0
08/01/2021 13:00	0.1	13.6	1,680.1	0.3	0.3	1	1	0
08/01/2021 14:00	0.0	13.6	1,693.6	0.1	0.0	1	1	0
08/01/2021 15:00	0.0	13.6	1,713.5	0.0	0.0	1	1	0
08/01/2021 16:00	0.6	12.9	1,838.5	0.1	1.8	1	1	1
08/01/2021 17:00	0.6	11.2	2,247.6	0.3	1.8	1	1	1
08/01/2021 18:00	0.5	11.0	2,288.1	0.4	1.5	1	1	1
08/01/2021 19:00	0.5	11.1	2,280.7	0.3	1.5	1	1	1
08/01/2021 20:00	0.5	11.0	2,299.7	0.3	1.5	1	1	1
08/01/2021 21:00	0.5	11.1	2,297.8	0.3	1.5	1	1	1
08/01/2021 22:00	0.6	11.2	2,274.7	0.3	1.9	1	1	1
08/01/2021 23:00	0.6	11.4	2,243.3	0.4	1.9	1	1	1
Average/Sum#:	0.5	12.6	1,916.1	0.3	35.4 #	24 #	24 #	15 #
Minimum:	0.0	11.0	1,418.4	0.0	0.0	1	1	0
Maximum:	1.2	13.7	2,299.7	0.6	3.8	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/02/2021 00:00	0.6	11.4	2,258.7	0.4	1.9	1	1	1
08/02/2021 01:00	0.7	11.6	2,221.7	0.4	2.2	1	1	1
08/02/2021 02:00	0.4	13.4	1,665.6	0.4	1.2	1	1	1
08/02/2021 03:00	0.2	13.6	1,701.4	0.3	0.6	1	1	1
08/02/2021 04:00	1.1	12.3	2,093.8	0.4	3.5	1	1	1
08/02/2021 05:00	0.7	11.5	2,260.2	0.5	2.2	1	1	1
08/02/2021 06:00	0.8	11.8	2,177.6	0.6	2.5	1	1	1
08/02/2021 07:00	0.4	13.3	1,710.0	0.4	1.2	1	1	1
08/02/2021 08:00	0.4	13.6	1,606.7	0.4	1.2	1	1	1
08/02/2021 09:00	1.0	12.2	2,095.5	0.4	3.2	1	1	1
08/02/2021 10:00	0.8	11.6	2,204.1	0.5	2.5	1	1	1
08/02/2021 11:00	0.7	11.5	2,224.2	0.5	2.2	1	1	1
08/02/2021 12:00	0.7	11.6	2,202.4	0.4	2.2	1	1	1
08/02/2021 13:00	0.7	11.6	2,197.5	0.4	2.2	1	1	1
08/02/2021 14:00	0.7	11.6	2,192.2	0.4	2.2	1	1	1
08/02/2021 15:00	0.7	11.6	2,194.6	0.4	2.2	1	1	1
08/02/2021 16:00	0.7	11.6	2,195.5	0.4	2.2	1	1	1
08/02/2021 17:00	0.6	11.5	2,217.6	0.4	1.9	1	1	1
08/02/2021 18:00	0.6	11.2	2,277.9	0.4	1.9	1	1	1
08/02/2021 19:00	0.6	11.1	2,289.2	0.4	1.9	1	1	1
08/02/2021 20:00	0.5	11.1	2,302.7	0.4	1.6	1	1	1
08/02/2021 21:00	0.5	11.2	2,302.3	0.3	1.6	1	1	1
08/02/2021 22:00	0.5	11.2	2,300.8	0.3	1.6	1	1	1
08/02/2021 23:00	0.5	11.2	2,302.2	0.3	1.6	1	1	1
Average/Sum#:	0.6	11.8	2,133.1	0.4	47.5 #	24 #	24 #	24 #
Minimum:	0.2	11.1	1,606.7	0.3	0.6	1	1	1
Maximum:	1.1	13.6	2,302.7	0.6	3.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/03/2021 00:00	0.6	11.5	2,242.8	0.3	1.9	1	1	1
08/03/2021 01:00	0.6	11.5	2,238.0	0.4	1.9	1	1	1
08/03/2021 02:00	0.3	13.3	1,752.8	0.3	0.9	1	1	1
08/03/2021 03:00	0.3	13.5	1,785.3	0.3	1.0	1	1	1
08/03/2021 04:00	1.4	12.2	2,099.5	0.4	4.5	1	0	1
08/03/2021 05:00	1.3	11.8	2,204.3	0.6	4.2	1	0	1
08/03/2021 06:00	1.3	11.8	2,170.9	0.8	4.1	1	0	1
08/03/2021 07:00	1.2	11.7	2,187.0	0.8	3.8	1	0	1
08/03/2021 08:00	1.1	11.6	2,210.3	0.8	3.5	1	0	1
08/03/2021 09:00	1.0	11.5	2,231.7	0.7	3.1	1	0	1
08/03/2021 10:00	0.9	11.3	2,271.6	0.6	2.8	1	0	1
08/03/2021 11:00	0.7	12.0	1,974.7	0.6	2.1	1	0	1
08/03/2021 12:00	0.2	13.8	1,332.6	0.4	0.5	1	0	0
08/03/2021 13:00	0.1	13.6	1,718.2	0.3	0.3	1	1	1
08/03/2021 14:00	0.9	11.9	2,133.2	0.3	2.8	1	1	1
08/03/2021 15:00	0.7	11.6	2,189.3	0.4	2.2	1	1	1
08/03/2021 16:00	0.6	11.5	2,195.3	0.5	1.9	1	1	1
08/03/2021 17:00	0.6	11.4	2,208.6	0.4	1.8	1	1	1
08/03/2021 18:00	0.6	11.2	2,267.7	0.4	1.9	1	1	1
08/03/2021 19:00	0.5	11.1	2,280.8	0.4	1.5	1	1	1
08/03/2021 20:00	0.5	11.1	2,294.7	0.3	1.5	1	1	1
08/03/2021 21:00	0.5	11.1	2,288.8	0.3	1.5	1	1	1
08/03/2021 22:00	0.5	11.2	2,276.6	0.3	1.5	1	1	1
08/03/2021 23:00	0.6	11.4	2,258.9	0.3	1.9	1	1	1
Average/Sum#:	0.7	11.9	2,117.2	0.5	53.1 #	24 #	15 #	23 #
Minimum:	0.1	11.1	1,332.6	0.3	0.3	1	0	0
Maximum:	1.4	13.8	2,294.7	0.8	4.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/04/2021 00:00	0.8	11.9	2,097.3	0.4	2.5	1	1	1
08/04/2021 01:00	0.1	13.6	1,678.6	0.3	0.3	1	1	0
08/04/2021 02:00	0.2	13.5	1,780.1	0.3	0.6	1	1	1
08/04/2021 03:00	1.1	12.3	2,071.5	0.4	3.5	1	1	1
08/04/2021 04:00	0.7	11.5	2,242.4	0.5	2.2	1	1	1
08/04/2021 05:00	0.7	11.3	2,265.6	0.5	2.2	1	1	1
08/04/2021 06:00	0.9	11.9	2,127.2	0.5	2.8	1	1	1
08/04/2021 07:00	0.9	12.5	1,984.9	0.5	2.8	1	1	1
08/04/2021 08:00	0.1	13.6	1,645.9	0.4	0.3	1	1	0
08/04/2021 09:00	0.1	13.5	1,717.4	0.3	0.3	1	1	0
08/04/2021 10:00	1.0	12.1	2,079.9	0.3	3.1	1	1	1
08/04/2021 11:00	0.6	11.4	2,222.3	0.4	1.9	1	1	1
08/04/2021 12:00	0.6	11.5	2,189.0	0.5	1.8	1	1	1
08/04/2021 13:00	0.6	11.5	2,176.6	0.4	1.8	1	1	1
08/04/2021 14:00	0.6	11.5	2,176.9	0.4	1.8	1	1	1
08/04/2021 15:00	0.6	11.4	2,183.3	0.4	1.8	1	1	1
08/04/2021 16:00	0.5	11.2	2,213.6	0.4	1.5	1	1	1
08/04/2021 17:00	0.5	11.2	2,226.0	0.3	1.5	1	1	1
08/04/2021 18:00	0.5	11.2	2,240.1	0.3	1.5	1	1	1
08/04/2021 19:00	0.5	11.1	2,262.3	0.3	1.5	1	1	1
08/04/2021 20:00	0.5	11.1	2,280.6	0.3	1.5	1	1	1
08/04/2021 21:00	0.5	11.1	2,289.4	0.3	1.5	1	1	1
08/04/2021 22:00	0.5	11.2	2,285.8	0.3	1.6	1	1	1
08/04/2021 23:00	0.7	11.6	2,192.1	0.3	2.2	1	1	1
Average/Sum#:	0.6	11.9	2,109.5	0.4	42.5 #	24 #	24 #	21 #
Minimum:	0.1	11.1	1,645.9	0.3	0.3	1	1	0
Maximum:	1.1	13.6	2,289.4	0.5	3.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/05/2021 00:00	0.8	11.8	2,174.5	0.4	2.5	1	1	1
08/05/2021 01:00	0.7	11.7	2,188.6	0.4	2.2	1	1	1
08/05/2021 02:00	0.5	11.7	2,182.7	0.4	1.6	1	1	1
08/05/2021 03:00	0.4	11.5	2,230.8	0.3	1.3	1	1	1
08/05/2021 04:00	0.4	11.4	2,253.0	0.3	1.3	1	1	1
08/05/2021 05:00	0.4	11.5	2,245.7	0.3	1.3	1	1	1
08/05/2021 06:00	0.6	12.3	2,038.3	0.3	1.9	1	1	1
08/05/2021 07:00	0.1	13.6	1,662.7	0.3	0.3	1	1	0
08/05/2021 08:00	0.2	13.6	1,644.7	0.2	0.6	1	1	1
08/05/2021 09:00	1.2	12.6	1,997.8	0.4	3.8	1	1	1
08/05/2021 10:00	0.8	12.1	2,080.9	0.5	2.5	1	1	1
08/05/2021 11:00	0.1	13.6	1,690.5	0.5	0.3	1	1	0
08/05/2021 12:00	0.0	13.6	1,759.6	0.2	0.0	1	1	1
08/05/2021 13:00	1.0	12.1	2,087.9	0.3	3.1	1	1	1
08/05/2021 14:00	0.7	11.8	2,141.6	0.4	2.2	1	1	1
08/05/2021 15:00	0.7	11.8	2,152.2	0.6	2.2	1	1	1
08/05/2021 16:00	0.7	11.6	2,184.5	0.5	2.2	1	1	1
08/05/2021 17:00	0.7	11.7	2,164.5	0.4	2.2	1	1	1
08/05/2021 18:00	0.6	11.3	2,259.7	0.4	1.9	1	1	1
08/05/2021 19:00	0.6	11.2	2,278.3	0.4	1.9	1	1	1
08/05/2021 20:00	0.5	11.2	2,282.9	0.4	1.6	1	1	1
08/05/2021 21:00	0.6	11.4	2,236.3	0.4	1.9	1	1	1
08/05/2021 22:00	0.7	11.7	2,165.0	0.4	2.2	1	1	1
08/05/2021 23:00	0.8	11.9	2,137.0	0.4	2.5	1	1	1
Average/Sum#:	0.6	12.0	2,093.3	0.4	43.5 #	24 #	24 #	22 #
Minimum:	0.0	11.2	1,644.7	0.2	0.0	1	1	0
Maximum:	1.2	13.6	2,282.9	0.6	3.8	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/06/2021 00:00	0.8	12.0	2,076.7	0.5	2.5	1	1	1
08/06/2021 01:00	0.3	13.6	1,695.4	0.4	0.9	1	1	0
08/06/2021 02:00	0.3	13.6	1,691.4	0.3	0.9	1	1	0
08/06/2021 03:00	0.3	13.6	1,639.6	0.2	0.9	1	1	1
08/06/2021 04:00	1.4	12.3	2,055.5	0.5	4.4	1	1	1
08/06/2021 05:00	0.9	12.3	2,077.3	0.6	2.9	1	1	1
08/06/2021 06:00	0.1	13.7	1,600.7	0.6	0.3	1	1	0
08/06/2021 07:00	0.1	13.7	1,665.4	0.3	0.3	1	1	0
08/06/2021 08:00	0.2	13.6	1,667.2	0.1	0.6	1	1	0
08/06/2021 09:00	1.1	12.4	2,007.8	0.4	3.4	1	1	1
08/06/2021 10:00	1.0	12.4	1,995.8	0.6	3.1	1	1	1
08/06/2021 11:00	0.3	13.6	1,660.3	0.6	0.9	1	1	0
08/06/2021 12:00	0.2	13.7	1,530.6	0.4	0.6	1	1	0
08/06/2021 13:00	1.1	12.3	2,034.7	0.4	3.4	1	1	1
08/06/2021 14:00	0.8	11.8	2,128.3	0.5	2.5	1	1	1
08/06/2021 15:00	0.8	11.8	2,112.5	0.6	2.5	1	1	1
08/06/2021 16:00	0.7	11.5	2,166.2	0.5	2.1	1	1	1
08/06/2021 17:00	0.6	11.4	2,170.9	0.4	1.8	1	1	1
08/06/2021 18:00	0.5	11.2	2,221.4	0.4	1.5	1	1	1
08/06/2021 19:00	0.6	11.5	2,173.4	0.4	1.8	1	1	1
08/06/2021 20:00	0.6	11.5	2,141.6	0.4	1.8	1	1	1
08/06/2021 21:00	0.6	11.7	2,111.7	0.4	1.8	1	1	1
08/06/2021 22:00	0.9	11.9	2,096.0	0.5	2.8	1	1	1
08/06/2021 23:00	0.8	12.4	1,955.7	0.5	2.4	1	1	1
Average/Sum#:	0.6	12.5	1,944.8	0.4	46.1 #	24 #	24 #	17 #
Minimum:	0.1	11.2	1,530.6	0.1	0.3	1	1	0
Maximum:	1.4	13.7	2,221.4	0.6	4.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/07/2021 00:00	0.2	13.6	1,703.0	0.5	0.6	1	1	0
08/07/2021 01:00	0.4	13.5	1,630.7	0.4	1.2	1	1	1
08/07/2021 02:00	0.9	12.4	1,991.3	0.4	2.8	1	1	1
08/07/2021 03:00	15.4	13.9	1,196.2	0.0	16.7	1	0	1
08/07/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/07/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/07/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/07/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/07/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/07/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/07/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/07/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/07/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/07/2021 13:00	24.1	18.5	172.7	0.0	4.6	1	1	0
08/07/2021 14:00	51.2	15.4	813.4	0.0	100.0	1	1	0
08/07/2021 15:00	0.1	13.6	1,657.0	0.0	0.3	1	1	0
08/07/2021 16:00	0.3	13.6	1,536.5	0.0	0.8	1	1	1
08/07/2021 17:00	1.2	11.9	2,068.8	0.4	3.6	1	1	1
08/07/2021 18:00	0.8	11.6	2,140.2	0.5	2.4	1	1	1
08/07/2021 19:00	0.8	11.9	2,049.0	0.6	2.4	1	1	1
08/07/2021 20:00	0.1	13.5	1,687.8	0.4	0.3	1	1	0
08/07/2021 21:00	0.2	13.5	1,656.9	0.3	0.6	1	1	1
08/07/2021 22:00	1.5	12.4	1,999.2	0.4	4.7	1	1	1
08/07/2021 23:00	1.0	11.9	2,078.2	0.6	3.0	1	1	1
Average/Sum#:	6.5	13.4	1,625.4	0.5	144.0 #	15 #	14 #	10 #
Minimum:	0.1	11.6	172.7	0.3	0.3	0	0	0
Maximum:	51.2	18.5	2,140.2	0.6	100.0	1	1	1
%SI	37.50	37.50	37.50	58.33	37.50	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/08/2021 00:00	0.2	13.6	1,601.3	0.6	0.6	1	1	0
08/08/2021 01:00	0.4	13.5	1,571.0	0.4	1.1	1	1	1
08/08/2021 02:00	1.0	12.5	1,979.4	0.4	3.1	1	1	1
08/08/2021 03:00	0.5	13.4	1,496.5	0.5	1.3	1	1	1
08/08/2021 04:00	42.8	16.3	332.8	0.0	7.4	1	1	0
08/08/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	1	0
08/08/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	1	0
08/08/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	1	0
08/08/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	1	0
08/08/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	1	0
08/08/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	1	0
08/08/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	1	0
08/08/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	1	0
08/08/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	1	0
08/08/2021 14:00	28.3	18.6	165.6	0.0	5.9	1	1	0
08/08/2021 15:00	50.8	15.4	815.0	0.0	99.4	1	1	0
08/08/2021 16:00	0.0	13.6	1,604.6	0.0	0.0	1	1	0
08/08/2021 17:00	0.6	12.8	1,811.1	0.0	1.8	1	1	1
08/08/2021 18:00	0.8	11.5	2,154.8	0.3	2.4	1	1	1
08/08/2021 19:00	0.7	11.4	2,181.1	0.4	2.1	1	1	1
08/08/2021 20:00	0.5	11.3	2,225.9	0.4	1.5	1	1	1
08/08/2021 21:00	0.6	11.5	2,174.0	0.4	1.8	1	1	1
08/08/2021 22:00	0.7	11.9	2,090.8	0.4	2.1	1	1	1
08/08/2021 23:00	0.7	12.4	1,968.1	0.5	2.1	1	1	1
Average/Sum#:	8.6	13.3	1,611.5	0.4	132.6 #	15 #	24 #	10 #
Minimum:	0.0	11.3	165.6	0.3	0.0	0	1	0
Maximum:	50.8	18.6	2,225.9	0.6	99.4	1	1	1
%SI	37.50	37.50	37.50	58.33	37.50	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/09/2021 00:00	0.1	13.6	1,595.0	0.4	0.3	1	1	0
08/09/2021 01:00	0.2	13.5	1,755.9	0.3	0.6	1	1	1
08/09/2021 02:00	1.0	12.3	2,038.3	0.3	3.1	1	1	1
08/09/2021 03:00	0.8	12.5	1,963.2	0.5	2.5	1	1	1
08/09/2021 04:00	0.1	13.6	1,692.9	0.5	0.3	1	1	0
08/09/2021 05:00	0.2	13.4	1,767.7	0.3	0.6	1	1	1
08/09/2021 06:00	1.0	12.4	2,019.5	0.3	3.1	1	1	1
08/09/2021 07:00	0.8	12.2	2,022.1	0.5	2.5	1	1	1
08/09/2021 08:00	0.1	13.6	1,592.2	0.4	0.3	1	1	0
08/09/2021 09:00	0.1	13.6	1,650.0	0.2	0.3	1	1	0
08/09/2021 10:00	0.1	13.5	1,682.3	0.1	0.3	1	1	0
08/09/2021 11:00	0.8	12.2	2,001.9	0.2	2.4	1	1	1
08/09/2021 12:00	0.7	11.6	2,089.2	0.3	2.1	1	1	1
08/09/2021 13:00	0.0	13.6	1,718.3	0.3	0.0	1	1	0
08/09/2021 14:00	0.5	12.8	1,829.5	0.3	1.5	1	1	1
08/09/2021 15:00	0.6	11.4	2,178.7	0.3	1.8	1	1	1
08/09/2021 16:00	0.5	11.3	2,187.8	0.4	1.5	1	1	1
08/09/2021 17:00	0.5	11.3	2,189.8	0.3	1.5	1	1	1
08/09/2021 18:00	0.6	11.3	2,191.4	0.3	1.8	1	1	1
08/09/2021 19:00	0.5	11.1	2,246.4	0.3	1.5	1	1	1
08/09/2021 20:00	0.5	11.0	2,265.8	0.3	1.5	1	1	1
08/09/2021 21:00	0.5	11.2	2,231.9	0.3	1.5	1	1	1
08/09/2021 22:00	0.7	11.8	2,133.8	0.4	2.2	1	1	1
08/09/2021 23:00	0.8	11.8	2,139.5	0.4	2.5	1	1	1
Average/Sum#:	0.5	12.4	1,966.0	0.3	35.7 #	24 #	24 #	18 #
Minimum:	0.0	11.0	1,592.2	0.1	0.0	1	1	0
Maximum:	1.0	13.6	2,265.8	0.5	3.1	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/10/2021 00:00	0.8	12.2	2,030.6	0.5	2.5	1	1	1
08/10/2021 01:00	0.1	13.6	1,631.7	0.4	0.3	1	1	0
08/10/2021 02:00	0.1	13.6	1,637.3	0.2	0.3	1	1	0
08/10/2021 03:00	0.2	13.5	1,746.1	0.1	0.6	1	1	1
08/10/2021 04:00	0.9	12.2	2,079.9	0.3	2.8	1	1	1
08/10/2021 05:00	0.8	12.2	2,086.2	0.4	2.5	1	1	1
08/10/2021 06:00	0.1	13.6	1,661.3	0.4	0.3	1	1	0
08/10/2021 07:00	0.3	13.5	1,633.4	0.3	0.9	1	1	1
08/10/2021 08:00	1.1	12.3	2,050.1	0.4	3.5	1	1	1
08/10/2021 09:00	0.8	12.5	1,978.1	0.5	2.5	1	1	1
08/10/2021 10:00	0.0	13.6	1,703.6	0.5	0.0	1	1	0
08/10/2021 11:00	0.1	13.6	1,715.4	0.2	0.3	1	1	1
08/10/2021 12:00	0.8	12.0	2,086.5	0.2	2.5	1	1	1
08/10/2021 13:00	0.6	11.5	2,182.7	0.3	1.8	1	1	1
08/10/2021 14:00	0.5	11.4	2,177.7	0.4	1.5	1	1	1
08/10/2021 15:00	0.6	11.4	2,181.0	0.4	1.8	1	1	1
08/10/2021 16:00	0.6	11.3	2,202.8	0.4	1.8	1	1	1
08/10/2021 17:00	0.6	11.3	2,207.7	0.4	1.8	1	1	1
08/10/2021 18:00	0.5	11.1	2,250.4	0.4	1.5	1	1	1
08/10/2021 19:00	0.5	11.0	2,266.3	0.3	1.5	1	1	1
08/10/2021 20:00	0.5	11.0	2,267.5	0.3	1.5	1	1	1
08/10/2021 21:00	0.5	11.1	2,258.8	0.3	1.5	1	1	1
08/10/2021 22:00	0.6	11.5	2,180.8	0.3	1.8	1	1	1
08/10/2021 23:00	0.7	11.7	2,157.9	0.4	2.2	1	1	1
Average/Sum#:	0.5	12.2	2,015.6	0.3	37.7 #	24 #	24 #	20 #
Minimum:	0.0	11.0	1,631.7	0.1	0.0	1	1	0
Maximum:	1.1	13.6	2,267.5	0.5	3.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/11/2021 00:00	0.8	11.9	2,094.7	0.4	2.5	1	1	1
08/11/2021 01:00	0.1	13.5	1,699.9	0.3	0.3	1	1	0
08/11/2021 02:00	0.1	13.6	1,633.8	0.2	0.3	1	1	0
08/11/2021 03:00	0.2	13.6	1,622.4	0.1	0.6	1	1	0
08/11/2021 04:00	0.2	13.5	1,644.3	0.2	0.6	1	1	1
08/11/2021 05:00	0.8	12.1	2,066.9	0.3	2.5	1	1	1
08/11/2021 06:00	0.7	12.1	2,092.2	0.4	2.2	1	1	1
08/11/2021 07:00	0.1	13.6	1,664.7	0.4	0.3	1	1	0
08/11/2021 08:00	0.1	13.5	1,764.9	0.2	0.3	1	1	0
08/11/2021 09:00	1.0	12.0	2,101.4	0.3	3.1	1	1	1
08/11/2021 10:00	0.6	11.4	2,206.8	0.4	1.8	1	1	1
08/11/2021 11:00	0.6	11.4	2,194.0	0.5	1.8	1	1	1
08/11/2021 12:00	0.6	11.6	2,149.1	0.4	1.8	1	1	1
08/11/2021 13:00	0.6	11.5	2,149.9	0.4	1.8	1	1	1
08/11/2021 14:00	0.4	11.5	2,137.2	0.4	1.2	1	1	1
08/11/2021 15:00	0.5	11.9	2,002.5	0.3	1.5	1	1	1
08/11/2021 16:00	0.6	11.5	2,157.0	0.3	1.8	1	1	1
08/11/2021 17:00	0.5	11.4	2,171.9	0.3	1.5	1	1	1
08/11/2021 18:00	0.4	11.1	2,230.3	0.3	1.2	1	1	1
08/11/2021 19:00	0.5	11.0	2,244.4	0.3	1.5	1	1	1
08/11/2021 20:00	0.5	11.0	2,252.9	0.3	1.5	1	1	1
08/11/2021 21:00	0.6	11.3	2,219.2	0.3	1.8	1	1	1
08/11/2021 22:00	0.7	11.6	2,161.8	0.4	2.1	1	1	1
08/11/2021 23:00	0.7	11.7	2,164.1	0.4	2.2	1	1	1
Average/Sum#:	0.5	12.1	2,034.4	0.3	36.2 #	24 #	24 #	19 #
Minimum:	0.1	11.0	1,622.4	0.1	0.3	1	1	0
Maximum:	1.0	13.6	2,252.9	0.5	3.1	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/12/2021 00:00	0.8	11.9	2,120.6	0.4	2.5	1	1	1
08/12/2021 01:00	0.2	13.6	1,693.4	0.4	0.6	1	1	1
08/12/2021 02:00	0.2	13.5	1,651.0	0.3	0.6	1	1	1
08/12/2021 03:00	0.8	12.2	2,052.6	0.3	2.5	1	1	1
08/12/2021 04:00	0.8	12.2	2,033.5	0.4	2.5	1	1	1
08/12/2021 05:00	0.2	13.6	1,699.4	0.4	0.6	1	1	0
08/12/2021 06:00	0.2	13.5	1,780.9	0.3	0.6	1	1	1
08/12/2021 07:00	1.2	12.3	2,048.0	0.4	3.8	1	1	1
08/12/2021 08:00	0.9	12.4	1,978.2	0.5	2.8	1	1	1
08/12/2021 09:00	0.1	13.6	1,709.6	0.5	0.3	1	1	0
08/12/2021 10:00	0.1	13.6	1,722.3	0.3	0.3	1	1	1
08/12/2021 11:00	0.9	12.0	2,091.6	0.3	2.8	1	1	1
08/12/2021 12:00	0.7	11.6	2,141.2	0.4	2.1	1	1	1
08/12/2021 13:00	0.7	11.7	2,124.6	0.5	2.1	1	1	1
08/12/2021 14:00	0.7	11.7	2,111.7	0.4	2.1	1	1	1
08/12/2021 15:00	0.7	11.6	2,119.3	0.4	2.1	1	1	1
08/12/2021 16:00	0.6	11.6	2,133.9	0.4	1.8	1	1	1
08/12/2021 17:00	0.6	11.5	2,145.0	0.4	1.8	1	1	1
08/12/2021 18:00	0.5	11.3	2,196.1	0.4	1.5	1	1	1
08/12/2021 19:00	0.5	11.2	2,203.9	0.3	1.5	1	1	1
08/12/2021 20:00	0.5	11.2	2,239.6	0.3	1.5	1	1	1
08/12/2021 21:00	0.6	11.4	2,201.1	0.3	1.8	1	1	1
08/12/2021 22:00	0.7	11.8	2,145.5	0.4	2.2	1	1	1
08/12/2021 23:00	0.8	12.1	2,082.4	0.5	2.5	1	1	1
Average/Sum#:	0.6	12.2	2,017.7	0.4	42.9 #	24 #	24 #	22 #
Minimum:	0.1	11.2	1,651.0	0.3	0.3	1	1	0
Maximum:	1.2	13.6	2,239.6	0.5	3.8	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/13/2021 00:00	0.8	12.5	1,980.3	0.5	2.5	1	1	1
08/13/2021 01:00	0.3	13.5	1,655.2	0.4	0.9	1	1	1
08/13/2021 02:00	0.3	13.6	1,502.2	0.3	0.8	1	1	1
08/13/2021 03:00	0.9	12.3	2,040.5	0.3	2.8	1	1	1
08/13/2021 04:00	0.9	12.6	1,963.8	0.5	2.8	1	1	1
08/13/2021 05:00	0.1	13.6	1,684.7	0.4	0.3	1	1	0
08/13/2021 06:00	0.1	13.6	1,652.6	0.3	0.3	1	1	0
08/13/2021 07:00	0.4	13.6	1,568.8	0.2	1.1	1	1	1
08/13/2021 08:00	1.6	12.3	2,033.2	0.5	5.0	1	1	1
08/13/2021 09:00	0.9	12.4	1,989.1	0.7	2.8	1	1	1
08/13/2021 10:00	0.0	13.6	1,599.3	0.6	0.0	1	1	0
08/13/2021 11:00	0.0	13.6	1,600.0	0.2	0.0	1	1	1
08/13/2021 12:00	1.0	12.1	2,076.3	0.2	3.1	1	1	1
08/13/2021 13:00	0.8	11.9	2,112.6	0.4	2.5	1	1	1
08/13/2021 14:00	0.8	11.9	2,105.4	0.6	2.5	1	1	1
08/13/2021 15:00	0.7	11.8	2,102.1	0.5	2.1	1	1	1
08/13/2021 16:00	0.7	11.7	2,109.3	0.5	2.1	1	1	1
08/13/2021 17:00	0.7	11.6	2,129.1	0.4	2.1	1	1	1
08/13/2021 18:00	0.6	11.4	2,179.8	0.4	1.8	1	1	1
08/13/2021 19:00	0.6	11.3	2,221.0	0.4	1.8	1	1	1
08/13/2021 20:00	0.6	11.4	2,199.3	0.4	1.8	1	1	1
08/13/2021 21:00	0.8	11.7	2,129.2	0.4	2.4	1	1	1
08/13/2021 22:00	0.8	11.8	2,126.3	0.5	2.5	1	1	1
08/13/2021 23:00	0.8	11.8	2,125.0	0.5	2.5	1	1	1
Average/Sum#:	0.6	12.4	1,953.5	0.4	46.5 #	24 #	24 #	21 #
Minimum:	0.0	11.3	1,502.2	0.2	0.0	1	1	0
Maximum:	1.6	13.6	2,221.0	0.7	5.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/14/2021 00:00	0.9	12.2	2,009.9	0.5	2.7	1	1	1
08/14/2021 01:00	0.1	13.6	1,710.5	0.4	0.3	1	1	0
08/14/2021 02:00	0.2	13.5	1,751.2	0.3	0.6	1	1	1
08/14/2021 03:00	1.1	12.2	2,055.0	0.3	3.4	1	1	1
08/14/2021 04:00	1.0	12.4	1,975.7	0.5	3.1	1	1	1
08/14/2021 05:00	0.2	13.6	1,717.7	0.5	0.6	1	1	0
08/14/2021 06:00	0.3	13.6	1,630.6	0.4	0.9	1	1	0
08/14/2021 07:00	0.4	13.6	1,519.8	0.2	1.1	1	1	0
08/14/2021 08:00	0.3	13.7	1,317.3	0.2	0.7	1	1	0
08/14/2021 09:00	0.0	13.6	1,594.8	0.2	0.0	1	1	0
08/14/2021 10:00	0.0	13.6	1,665.3	0.1	0.0	1	1	0
08/14/2021 11:00	0.0	13.6	1,689.3	0.0	0.0	1	1	0
08/14/2021 12:00	0.0	13.6	1,693.4	0.0	0.0	1	1	1
08/14/2021 13:00	0.9	12.0	2,046.4	0.2	2.7	1	1	1
08/14/2021 14:00	0.7	11.6	2,090.5	0.3	2.1	1	1	1
08/14/2021 15:00	0.0	13.6	1,592.7	0.3	0.0	1	1	0
08/14/2021 16:00	0.0	13.7	1,510.0	0.1	0.0	1	1	0
08/14/2021 17:00	0.8	11.8	2,075.0	0.2	2.4	1	1	1
08/14/2021 18:00	0.5	11.1	2,194.8	0.3	1.5	1	1	1
08/14/2021 19:00	0.5	11.0	2,210.3	0.4	1.5	1	1	1
08/14/2021 20:00	0.5	11.2	2,201.9	0.3	1.5	1	1	1
08/14/2021 21:00	0.6	11.4	2,179.8	0.3	1.8	1	1	1
08/14/2021 22:00	0.7	11.6	2,145.3	0.4	2.1	1	1	1
08/14/2021 23:00	0.8	11.8	2,121.5	0.4	2.5	1	1	1
Average/Sum#:	0.4	12.7	1,862.4	0.3	31.5 #	24 #	24 #	14 #
Minimum:	0.0	11.0	1,317.3	0.0	0.0	1	1	0
Maximum:	1.1	13.7	2,210.3	0.5	3.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/15/2021 00:00	0.8	12.4	1,993.4	0.5	2.5	1	1	1
08/15/2021 01:00	0.1	13.6	1,707.4	0.4	0.3	1	1	0
08/15/2021 02:00	0.2	13.5	1,645.3	0.3	0.6	1	1	1
08/15/2021 03:00	0.9	12.2	2,057.7	0.3	2.8	1	1	1
08/15/2021 04:00	0.9	12.5	1,972.3	0.5	2.8	1	1	1
08/15/2021 05:00	0.2	13.6	1,687.4	0.5	0.6	1	1	0
08/15/2021 06:00	0.2	13.6	1,606.4	0.3	0.6	1	1	0
08/15/2021 07:00	0.1	13.6	1,684.1	0.2	0.3	1	1	0
08/15/2021 08:00	0.3	13.6	1,513.1	0.2	0.8	1	1	0
08/15/2021 09:00	0.1	13.6	1,638.4	0.1	0.3	1	1	0
08/15/2021 10:00	0.1	13.6	1,697.0	0.1	0.3	1	1	0
08/15/2021 11:00	0.1	13.6	1,523.7	0.1	0.3	1	1	0
08/15/2021 12:00	0.4	12.8	1,761.4	0.2	1.1	1	1	1
08/15/2021 13:00	0.8	11.6	2,076.9	0.3	2.4	1	1	1
08/15/2021 14:00	0.0	13.5	1,644.2	0.3	0.0	1	1	0
08/15/2021 15:00	0.0	13.5	1,654.9	0.2	0.0	1	1	1
08/15/2021 16:00	0.9	11.7	2,090.7	0.2	2.7	1	1	1
08/15/2021 17:00	0.6	11.3	2,146.6	0.3	1.8	1	1	1
08/15/2021 18:00	0.6	11.1	2,191.1	0.5	1.8	1	1	1
08/15/2021 19:00	0.6	11.3	2,180.2	0.4	1.8	1	1	1
08/15/2021 20:00	0.7	11.4	2,163.3	0.4	2.1	1	1	1
08/15/2021 21:00	0.7	11.5	2,159.1	0.4	2.1	1	1	1
08/15/2021 22:00	0.8	11.6	2,135.4	0.4	2.4	1	1	1
08/15/2021 23:00	0.8	11.7	2,126.5	0.5	2.4	1	1	1
Average/Sum#:	0.5	12.6	1,877.4	0.3	32.8 #	24 #	24 #	15 #
Minimum:	0.0	11.1	1,513.1	0.1	0.0	1	1	0
Maximum:	0.9	13.6	2,191.1	0.5	2.8	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/16/2021 00:00	0.9	12.2	1,998.1	0.5	2.7	1	1	1
08/16/2021 01:00	0.1	13.6	1,707.9	0.4	0.3	1	1	0
08/16/2021 02:00	0.3	13.5	1,542.2	0.3	0.8	1	1	1
08/16/2021 03:00	1.1	12.2	2,031.8	0.3	3.4	1	1	1
08/16/2021 04:00	1.0	12.3	2,002.7	0.5	3.1	1	1	1
08/16/2021 05:00	0.2	13.6	1,715.7	0.5	0.6	1	1	1
08/16/2021 06:00	0.1	13.5	1,750.3	0.3	0.3	1	1	1
08/16/2021 07:00	1.1	12.1	2,031.2	0.3	3.4	1	1	1
08/16/2021 08:00	0.9	12.0	2,035.4	0.5	2.7	1	1	1
08/16/2021 09:00	0.1	13.5	1,685.7	0.5	0.3	1	1	0
08/16/2021 10:00	0.1	13.6	1,631.4	0.3	0.3	1	1	1
08/16/2021 11:00	1.0	11.8	2,088.4	0.3	3.0	1	1	1
08/16/2021 12:00	0.8	11.5	2,130.0	0.4	2.4	1	1	1
08/16/2021 13:00	0.7	11.5	2,123.1	0.5	2.1	1	1	1
08/16/2021 14:00	0.8	11.7	2,083.8	0.5	2.4	1	1	1
08/16/2021 15:00	0.6	11.3	2,157.0	0.4	1.8	1	1	1
08/16/2021 16:00	0.6	11.2	2,178.3	0.4	1.8	1	1	1
08/16/2021 17:00	0.5	11.0	2,211.6	0.4	1.5	1	1	1
08/16/2021 18:00	0.5	10.9	2,241.1	0.3	1.5	1	1	1
08/16/2021 19:00	0.6	11.0	2,228.5	0.3	1.8	1	1	1
08/16/2021 20:00	0.6	11.2	2,201.6	0.4	1.8	1	1	1
08/16/2021 21:00	0.6	11.1	2,210.1	0.4	1.8	1	1	1
08/16/2021 22:00	0.7	11.6	2,144.2	0.4	2.1	1	1	1
08/16/2021 23:00	0.8	11.7	2,138.5	0.4	2.5	1	1	1
Average/Sum#:	0.6	12.1	2,011.2	0.4	44.4 #	24 #	24 #	22 #
Minimum:	0.1	10.9	1,542.2	0.3	0.3	1	1	0
Maximum:	1.1	13.6	2,241.1	0.5	3.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/17/2021 00:00	0.8	11.9	2,101.8	0.5	2.5	1	1	1
08/17/2021 01:00	0.1	13.5	1,690.4	0.4	0.3	1	1	1
08/17/2021 02:00	0.3	13.5	1,651.6	0.3	0.9	1	1	1
08/17/2021 03:00	1.0	12.0	2,088.3	0.3	3.1	1	1	1
08/17/2021 04:00	0.8	11.6	2,168.9	0.5	2.5	1	1	1
08/17/2021 05:00	0.6	11.3	2,217.7	0.5	1.8	1	1	1
08/17/2021 06:00	0.7	11.8	2,104.1	0.5	2.1	1	1	1
08/17/2021 07:00	0.1	13.6	1,663.8	0.3	0.3	1	1	0
08/17/2021 08:00	0.2	13.6	1,607.8	0.3	0.6	1	1	1
08/17/2021 09:00	1.0	12.3	2,044.4	0.3	3.1	1	1	1
08/17/2021 10:00	0.8	12.5	1,970.1	0.5	2.5	1	1	1
08/17/2021 11:00	0.1	13.6	1,663.1	0.5	0.3	1	1	0
08/17/2021 12:00	0.3	13.6	1,486.4	0.3	0.8	1	1	0
08/17/2021 13:00	0.0	13.5	1,761.0	0.1	0.0	1	1	0
08/17/2021 14:00	0.6	12.9	1,849.5	0.2	1.8	1	1	1
08/17/2021 15:00	0.7	12.6	1,872.6	0.3	2.1	1	1	1
08/17/2021 16:00	0.1	13.6	1,565.3	0.3	0.3	1	1	1
08/17/2021 17:00	1.0	12.0	2,077.4	0.4	3.1	1	1	1
08/17/2021 18:00	0.7	11.4	2,192.1	0.4	2.1	1	1	1
08/17/2021 19:00	0.5	11.2	2,237.3	0.5	1.5	1	1	1
08/17/2021 20:00	0.5	11.1	2,258.0	0.3	1.5	1	1	1
08/17/2021 21:00	0.5	11.3	2,221.8	0.3	1.5	1	1	1
08/17/2021 22:00	0.7	11.7	2,170.8	0.3	2.2	1	1	1
08/17/2021 23:00	0.8	12.4	2,032.3	0.4	2.5	1	1	1
Average/Sum#:	0.5	12.4	1,945.7	0.4	39.4 #	24 #	24 #	20 #
Minimum:	0.0	11.1	1,486.4	0.1	0.0	1	1	0
Maximum:	1.0	13.6	2,258.0	0.5	3.1	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/18/2021 00:00	0.1	13.6	1,649.7	0.4	0.3	1	1	0
08/18/2021 01:00	0.2	13.7	1,562.7	0.3	0.6	1	1	1
08/18/2021 02:00	0.9	12.7	1,985.3	0.3	2.9	1	1	1
08/18/2021 03:00	1.0	12.7	1,965.1	0.5	3.2	1	1	1
08/18/2021 04:00	0.2	13.6	1,715.8	0.5	0.6	1	1	0
08/18/2021 05:00	0.1	13.5	1,694.9	0.3	0.3	1	1	1
08/18/2021 06:00	1.1	12.5	2,032.6	0.4	3.5	1	1	1
08/18/2021 07:00	0.9	12.6	1,982.0	0.5	2.8	1	1	1
08/18/2021 08:00	0.3	13.7	1,458.9	0.5	0.8	1	1	0
08/18/2021 09:00	0.0	0.0	1,569.1	0.0	0.0	1	1	0
08/18/2021 10:00	0.1	14.0	1,541.4	0.0	0.3	1	1	0
08/18/2021 11:00	0.0	14.0	1,482.0	0.0	0.0	1	1	0
08/18/2021 12:00	0.0	13.9	1,527.9	0.0	0.0	1	1	1
08/18/2021 13:00	0.9	12.4	2,102.0	0.2	2.9	1	1	1
08/18/2021 14:00	0.9	12.1	2,088.5	0.4	2.8	1	1	1
08/18/2021 15:00	0.2	13.8	1,692.3	0.5	0.6	1	1	0
08/18/2021 16:00	0.1	13.9	1,547.5	0.3	0.3	1	1	0
08/18/2021 17:00	0.9	12.4	2,040.2	0.3	2.9	1	1	1
08/18/2021 18:00	0.8	11.8	2,188.5	0.4	2.5	1	1	1
08/18/2021 19:00	0.9	12.4	2,028.9	0.6	2.8	1	1	1
08/18/2021 20:00	0.1	13.8	1,724.9	0.4	0.3	1	1	0
08/18/2021 21:00	0.1	13.7	1,749.7	0.3	0.3	1	1	1
08/18/2021 22:00	1.1	12.4	2,079.3	0.3	3.6	1	1	1
08/18/2021 23:00	0.9	12.7	1,968.6	0.5	2.9	1	1	1
Average/Sum#:	0.5	13.1	1,807.4	0.4	37.2 #	24 #	24 #	15 #
Minimum:	0.0	11.8	1,458.9	0.0	0.0	1	1	0
Maximum:	1.1	14.0	2,188.5	0.6	3.6	1	1	1
%SI	4.17	4.17	0.00	12.50	4.17	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/19/2021 00:00	0.2	13.8	1,628.3	0.5	0.6	1	1	0
08/19/2021 01:00	0.1	13.8	1,660.5	0.3	0.3	1	1	0
08/19/2021 02:00	0.3	13.8	1,522.6	0.2	0.8	1	1	0
08/19/2021 03:00	0.3	13.8	1,557.9	0.2	0.9	1	1	1
08/19/2021 04:00	1.1	12.4	2,070.5	0.4	3.5	1	1	1
08/19/2021 05:00	1.0	12.8	1,990.8	0.6	3.2	1	1	1
08/19/2021 06:00	0.1	13.8	1,670.2	0.5	0.3	1	1	0
08/19/2021 07:00	0.1	13.8	1,701.0	0.3	0.3	1	1	0
08/19/2021 08:00	0.2	13.9	1,364.1	0.1	0.5	1	1	0
08/19/2021 09:00	0.0	0.0	1,688.3	0.0	0.0	1	1	0
08/19/2021 10:00	0.0	14.0	1,654.6	0.0	0.0	1	1	0
08/19/2021 11:00	0.1	13.9	1,623.7	0.0	0.3	1	1	0
08/19/2021 12:00	0.5	13.9	1,708.0	0.2	1.6	1	1	1
08/19/2021 13:00	0.0	0.0	2,118.7	0.0	0.0	1	1	1
08/19/2021 14:00	1.4	12.5	2,052.8	0.0	4.5	1	1	1
08/19/2021 15:00	0.7	13.9	1,586.0	0.0	2.1	1	1	0
08/19/2021 16:00	0.7	13.9	1,669.5	0.7	2.2	1	1	1
08/19/2021 17:00	1.5	12.3	2,091.5	0.7	4.8	1	1	1
08/19/2021 18:00	1.3	11.9	2,168.3	0.8	4.1	1	1	1
08/19/2021 19:00	1.3	12.2	2,081.9	0.9	4.1	1	1	1
08/19/2021 20:00	0.6	13.9	1,714.6	0.8	1.9	1	1	0
08/19/2021 21:00	0.8	13.8	1,621.2	0.7	2.4	1	1	1
08/19/2021 22:00	1.5	12.5	2,043.6	0.8	4.8	1	1	1
08/19/2021 23:00	1.4	12.8	1,963.7	0.9	4.5	1	1	1
Average/Sum#:	0.7	13.3	1,789.7	0.5	47.7 #	24 #	24 #	13 #
Minimum:	0.0	11.9	1,364.1	0.1	0.0	1	1	0
Maximum:	1.5	14.0	2,168.3	0.9	4.8	1	1	1
%SI	8.33	8.33	0.00	25.00	8.33	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/20/2021 00:00	0.7	13.9	1,690.4	0.9	2.2	1	1	0
08/20/2021 01:00	0.7	13.9	1,688.0	0.7	2.2	1	1	0
08/20/2021 02:00	0.8	13.9	1,546.8	0.6	2.3	1	1	0
08/20/2021 03:00	1.1	13.9	1,355.8	0.7	2.8	1	1	0
08/20/2021 04:00	0.6	13.9	1,652.9	0.7	1.9	1	1	0
08/20/2021 05:00	2.3	13.4	1,729.8	1.1	7.0	1	1	1
08/20/2021 06:00	1.6	13.1	1,865.4	1.2	5.1	1	1	1
08/20/2021 07:00	0.7	13.9	1,660.7	1.2	2.2	1	1	0
08/20/2021 08:00	0.8	13.9	1,526.6	0.8	2.3	1	1	0
08/20/2021 09:00	0.9	14.0	1,320.0	0.7	2.3	1	1	0
08/20/2021 10:00	0.8	14.0	1,308.3	0.7	2.0	1	1	0
08/20/2021 11:00	0.8	14.0	1,310.3	0.7	2.0	1	1	0
08/20/2021 12:00	0.7	13.9	1,524.4	0.7	2.0	1	1	1
08/20/2021 13:00	1.6	12.3	2,070.7	0.8	5.1	1	1	1
08/20/2021 14:00	1.4	12.5	2,004.6	0.9	4.4	1	1	1
08/20/2021 15:00	0.7	13.9	1,544.0	0.9	2.0	1	1	0
08/20/2021 16:00	0.8	13.8	1,552.9	0.8	2.3	1	1	0
08/20/2021 17:00	1.4	12.2	2,093.1	0.7	4.4	1	1	1
08/20/2021 18:00	1.3	11.9	2,156.3	0.8	4.1	1	1	1
08/20/2021 19:00	1.3	12.1	2,093.0	0.9	4.1	1	1	1
08/20/2021 20:00	0.7	13.9	1,676.8	0.8	2.2	1	1	0
08/20/2021 21:00	0.7	13.7	1,722.8	0.7	2.2	1	1	1
08/20/2021 22:00	1.6	12.4	2,063.8	0.8	5.1	1	1	1
08/20/2021 23:00	1.5	12.8	1,944.1	0.9	4.8	1	1	1
Average/Sum#:	1.1	13.4	1,712.6	0.8	77.0 #	24 #	24 #	11 #
Minimum:	0.6	11.9	1,308.3	0.6	1.9	1	1	0
Maximum:	2.3	14.0	2,156.3	1.2	7.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/21/2021 00:00	29.5	15.7	595.3	0.0	10.3	1	0	0
08/21/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	1	0
08/21/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	1	0
08/21/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	1	0
08/21/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	1	0
08/21/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	1	0
08/21/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	1	0
08/21/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	1	0
08/21/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	1	0
08/21/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	1	0
08/21/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	1	0
08/21/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	1	0
08/21/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	1	0
08/21/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	29.5	15.7	595.3	0.0	10.3 #	1 #	12 #	0 #
Minimum:	29.5	15.7	595.3	0.0	10.3	0	0	0
Maximum:	29.5	15.7	595.3	0.0	10.3	1	1	0
%SI	95.83	95.83	95.83	100.00	95.83	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/22/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/23/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	1	0
08/23/2021 16:00	61.3	17.8	320.6	0.0	75.3	1	1	0
08/23/2021 17:00	39.9	15.9	783.7	0.0	82.6	1	1	0
08/23/2021 18:00	0.5	14.1	1,703.5	0.0	1.7	1	1	0
08/23/2021 19:00	1.0	13.6	1,820.0	0.0	3.3	1	1	1
08/23/2021 20:00	1.4	13.1	1,884.9	0.8	4.5	1	1	1
08/23/2021 21:00	0.6	14.0	1,788.3	0.8	2.1	1	1	1
08/23/2021 22:00	1.6	13.0	2,028.3	0.9	5.4	1	1	1
08/23/2021 23:00	1.3	13.2	1,964.9	0.9	4.4	1	1	1
Average/Sum#:	13.5	14.3	1,536.8	0.9	179.3 #	8 #	9 #	5 #
Minimum:	0.5	13.0	320.6	0.8	1.7	0	0	0
Maximum:	61.3	17.8	2,028.3	0.9	82.6	1	1	1
%SI	66.67	66.67	66.67	83.33	66.67	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/24/2021 00:00	0.7	14.2	1,562.4	0.9	2.2	1	1	0
08/24/2021 01:00	0.6	14.2	1,629.4	0.7	1.9	1	1	0
08/24/2021 02:00	0.6	14.1	1,680.4	0.5	2.0	1	1	1
08/24/2021 03:00	1.3	13.4	1,948.6	0.7	4.5	1	1	1
08/24/2021 04:00	1.2	13.4	1,926.1	0.8	4.1	1	1	1
08/24/2021 05:00	0.6	14.2	1,667.1	0.8	2.0	1	1	0
08/24/2021 06:00	0.6	14.2	1,616.4	0.6	1.9	1	1	0
08/24/2021 07:00	0.5	14.2	1,658.7	0.5	1.6	1	1	0
08/24/2021 08:00	0.5	14.2	1,544.5	0.4	1.5	1	1	0
08/24/2021 09:00	0.5	14.2	1,704.8	0.4	1.7	1	1	0
08/24/2021 10:00	0.5	14.2	1,687.9	0.4	1.7	1	1	0
08/24/2021 11:00	0.5	14.2	1,652.2	0.4	1.6	1	1	0
08/24/2021 12:00	0.4	14.3	1,580.3	0.4	1.3	1	1	0
08/24/2021 13:00	0.5	14.2	1,661.3	0.4	1.6	1	1	1
08/24/2021 14:00	1.5	12.7	2,084.6	0.6	5.0	1	1	1
08/24/2021 15:00	1.4	12.7	2,079.1	0.8	4.7	1	1	1
08/24/2021 16:00	0.5	14.2	1,719.6	0.8	1.7	1	1	0
08/24/2021 17:00	0.6	14.0	1,770.8	0.6	2.0	1	1	1
08/24/2021 18:00	1.5	12.6	2,098.5	0.7	5.0	1	1	1
08/24/2021 19:00	1.2	12.2	2,154.7	0.8	3.9	1	1	1
08/24/2021 20:00	0.6	14.1	1,674.7	0.8	2.0	1	1	0
08/24/2021 21:00	0.7	14.0	1,798.3	0.6	2.4	1	1	1
08/24/2021 22:00	1.5	12.9	2,066.9	0.7	5.1	1	1	1
08/24/2021 23:00	1.4	12.5	2,164.1	0.9	4.8	1	1	1
Average/Sum#:	0.8	13.7	1,797.1	0.6	66.2 #	24 #	24 #	12 #
Minimum:	0.4	12.2	1,544.5	0.4	1.3	1	1	0
Maximum:	1.5	14.3	2,164.1	0.9	5.1	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/25/2021 00:00	0.8	13.9	1,651.0	0.9	2.5	1	1	1
08/25/2021 01:00	0.7	14.1	1,639.7	0.8	2.2	1	1	0
08/25/2021 02:00	0.7	14.1	1,590.9	0.6	2.2	1	1	1
08/25/2021 03:00	1.3	13.1	2,017.4	0.7	4.4	1	1	1
08/25/2021 04:00	1.2	12.8	2,088.8	0.8	4.1	1	1	1
08/25/2021 05:00	1.1	13.4	1,955.8	0.9	3.8	1	1	1
08/25/2021 06:00	0.6	14.2	1,607.1	0.8	1.9	1	1	0
08/25/2021 07:00	0.6	14.2	1,567.2	0.6	1.9	1	1	0
08/25/2021 08:00	0.6	14.1	1,642.5	0.5	1.9	1	1	1
08/25/2021 09:00	1.4	13.1	2,033.4	0.7	4.8	1	1	1
08/25/2021 10:00	1.3	13.3	1,972.7	0.9	4.5	1	1	1
08/25/2021 11:00	0.7	14.1	1,683.0	0.9	2.3	1	1	1
08/25/2021 12:00	0.7	14.1	1,650.6	0.7	2.2	1	1	1
08/25/2021 13:00	1.4	12.7	2,087.9	0.7	4.7	1	1	1
08/25/2021 14:00	1.4	12.6	2,077.7	0.9	4.6	1	1	1
08/25/2021 15:00	0.6	14.2	1,625.2	0.8	1.9	1	1	0
08/25/2021 16:00	0.7	14.2	1,482.5	0.7	2.0	1	1	1
08/25/2021 17:00	1.6	12.7	2,080.3	0.8	5.4	1	1	1
08/25/2021 18:00	1.3	12.2	2,175.5	0.9	4.3	1	1	1
08/25/2021 19:00	1.4	12.6	2,078.9	1.0	4.6	1	1	1
08/25/2021 20:00	0.6	14.1	1,666.9	0.8	1.9	1	1	0
08/25/2021 21:00	0.7	14.0	1,713.5	0.7	2.3	1	1	1
08/25/2021 22:00	1.5	12.9	2,057.5	0.7	5.1	1	1	1
08/25/2021 23:00	1.4	13.2	1,975.4	0.9	4.7	1	1	1
Average/Sum#:	1.0	13.5	1,838.4	0.8	80.2 #	24 #	24 #	19 #
Minimum:	0.6	12.2	1,482.5	0.5	1.9	1	1	0
Maximum:	1.6	14.2	2,175.5	1.0	5.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/26/2021 00:00	0.7	14.1	1,670.7	0.9	2.3	1	1	0
08/26/2021 01:00	0.7	14.1	1,636.5	0.8	2.2	1	1	0
08/26/2021 02:00	0.9	14.2	1,426.6	0.7	2.5	1	1	0
08/26/2021 03:00	0.7	14.1	1,591.5	0.7	2.2	1	1	1
08/26/2021 04:00	1.5	12.9	2,071.1	0.8	5.1	1	1	1
08/26/2021 05:00	1.5	12.8	2,103.5	0.9	5.1	1	1	1
08/26/2021 06:00	1.4	13.2	1,981.1	1.1	4.8	1	1	1
08/26/2021 07:00	0.7	14.1	1,698.6	0.9	2.3	1	1	1
08/26/2021 08:00	0.8	14.1	1,569.6	0.8	2.4	1	1	0
08/26/2021 09:00	1.0	13.5	1,865.4	0.7	3.3	1	1	1
08/26/2021 10:00	1.4	13.1	1,987.7	0.9	4.7	1	1	1
08/26/2021 11:00	0.7	14.1	1,726.8	0.8	2.3	1	1	0
08/26/2021 12:00	0.6	14.1	1,708.9	0.7	2.0	1	1	0
08/26/2021 13:00	1.4	12.8	2,066.9	0.7	4.7	1	1	1
08/26/2021 14:00	1.4	12.7	2,033.7	0.8	4.6	1	1	1
08/26/2021 15:00	0.6	14.1	1,725.7	0.8	2.0	1	1	0
08/26/2021 16:00	0.6	14.0	1,659.2	0.7	1.9	1	1	1
08/26/2021 17:00	1.4	12.3	2,150.8	0.7	4.6	1	1	1
08/26/2021 18:00	1.2	11.6	2,282.5	0.8	3.9	1	1	1
08/26/2021 19:00	1.1	11.6	2,300.4	0.8	3.6	1	1	1
08/26/2021 20:00	1.1	11.8	2,249.0	0.7	3.6	1	1	1
08/26/2021 21:00	1.2	11.9	2,232.7	0.7	3.9	1	1	1
08/26/2021 22:00	1.2	12.0	2,215.2	0.8	3.9	1	1	1
08/26/2021 23:00	1.4	12.4	2,112.7	0.9	4.6	1	1	1
Average/Sum#:	1.1	13.2	1,919.5	0.8	82.5 #	24 #	24 #	17 #
Minimum:	0.6	11.6	1,426.6	0.7	1.9	1	1	0
Maximum:	1.5	14.2	2,300.4	1.1	5.1	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/27/2021 00:00	0.6	14.0	1,712.6	0.8	2.0	1	1	0
08/27/2021 01:00	0.6	14.1	1,676.9	0.7	2.0	1	1	0
08/27/2021 02:00	0.5	14.0	1,708.6	0.5	1.6	1	1	0
08/27/2021 03:00	0.6	13.9	1,757.8	0.5	2.0	1	1	1
08/27/2021 04:00	1.6	12.6	2,098.9	0.7	5.3	1	1	1
08/27/2021 05:00	1.4	12.5	2,116.0	0.9	4.7	1	1	1
08/27/2021 06:00	0.7	14.0	1,610.2	0.9	2.2	1	1	0
08/27/2021 07:00	0.7	14.0	1,698.6	0.7	2.3	1	1	0
08/27/2021 08:00	0.8	14.0	1,554.4	0.6	2.4	1	1	0
08/27/2021 09:00	1.5	12.9	1,988.1	0.8	4.9	1	1	1
08/27/2021 10:00	1.5	12.7	2,014.5	1.0	4.9	1	1	1
08/27/2021 11:00	0.5	14.0	1,740.0	0.9	1.7	1	1	0
08/27/2021 12:00	0.5	14.0	1,736.3	0.6	1.7	1	1	1
08/27/2021 13:00	1.4	12.4	2,096.7	0.6	4.6	1	1	1
08/27/2021 14:00	1.1	11.8	2,210.8	0.7	3.5	1	1	1
08/27/2021 15:00	1.1	11.7	2,202.0	0.8	3.5	1	1	1
08/27/2021 16:00	1.1	11.7	2,198.8	0.7	3.5	1	1	1
08/27/2021 17:00	1.1	11.6	2,220.2	0.7	3.5	1	1	1
08/27/2021 18:00	1.1	11.6	2,231.5	0.7	3.5	1	1	1
08/27/2021 19:00	1.1	11.6	2,230.2	0.7	3.5	1	1	1
08/27/2021 20:00	1.1	11.6	2,235.5	0.7	3.5	1	1	1
08/27/2021 21:00	1.1	11.6	2,256.9	0.7	3.5	1	1	1
08/27/2021 22:00	1.2	11.9	2,210.2	0.7	3.9	1	1	1
08/27/2021 23:00	1.3	12.2	2,118.0	0.8	4.2	1	1	1
Average/Sum#:	1.0	12.8	1,984.3	0.7	78.4 #	24 #	24 #	17 #
Minimum:	0.5	11.6	1,554.4	0.5	1.6	1	1	0
Maximum:	1.6	14.1	2,256.9	1.0	5.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/28/2021 00:00	0.6	14.0	1,703.5	0.7	2.0	1	1	0
08/28/2021 01:00	0.7	13.8	1,792.7	0.7	2.3	1	1	1
08/28/2021 02:00	1.5	12.6	2,069.5	0.7	4.9	1	1	1
08/28/2021 03:00	1.3	13.0	1,965.6	0.9	4.3	1	1	1
08/28/2021 04:00	0.7	14.0	1,670.8	0.9	2.2	1	1	0
08/28/2021 05:00	0.6	14.1	1,666.0	0.7	1.9	1	1	0
08/28/2021 06:00	0.5	14.1	1,655.6	0.5	1.6	1	1	0
08/28/2021 07:00	0.5	14.0	1,692.8	0.4	1.6	1	1	0
08/28/2021 08:00	0.5	14.1	1,655.0	0.4	1.6	1	1	0
08/28/2021 09:00	0.5	13.9	1,694.6	0.4	1.6	1	1	0
08/28/2021 10:00	0.5	14.0	1,653.6	0.4	1.6	1	1	1
08/28/2021 11:00	1.5	12.3	2,114.8	0.6	4.9	1	1	1
08/28/2021 12:00	1.3	12.0	2,120.6	0.8	4.1	1	1	1
08/28/2021 13:00	0.5	14.0	1,704.8	0.8	1.6	1	1	0
08/28/2021 14:00	0.6	14.0	1,723.2	0.6	2.0	1	1	1
08/28/2021 15:00	1.5	12.4	2,080.0	0.6	4.8	1	1	1
08/28/2021 16:00	1.2	11.8	2,195.1	0.8	3.8	1	1	1
08/28/2021 17:00	1.1	11.6	2,230.8	0.8	3.5	1	1	1
08/28/2021 18:00	1.1	11.5	2,270.2	0.7	3.5	1	1	1
08/28/2021 19:00	1.0	11.4	2,290.7	0.7	3.2	1	1	1
08/28/2021 20:00	1.0	11.4	2,294.1	0.6	3.2	1	1	1
08/28/2021 21:00	1.0	11.5	2,276.2	0.6	3.2	1	1	1
08/28/2021 22:00	1.2	11.9	2,210.2	0.7	3.9	1	1	1
08/28/2021 23:00	1.3	12.2	2,147.8	0.8	4.2	1	1	1
Average/Sum#:	0.9	12.9	1,953.3	0.7	71.5 #	24 #	24 #	16 #
Minimum:	0.5	11.4	1,653.6	0.4	1.6	1	1	0
Maximum:	1.5	14.1	2,294.1	0.9	4.9	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/29/2021 00:00	1.3	12.7	2,008.0	0.9	4.2	1	1	1
08/29/2021 01:00	0.6	13.9	1,713.5	0.8	1.9	1	1	0
08/29/2021 02:00	0.7	13.7	1,797.6	0.7	2.3	1	1	1
08/29/2021 03:00	1.5	12.5	2,077.9	0.7	4.9	1	1	1
08/29/2021 04:00	1.5	12.3	2,082.6	0.9	4.8	1	1	1
08/29/2021 05:00	0.5	14.0	1,715.6	0.8	1.6	1	1	0
08/29/2021 06:00	0.5	14.0	1,647.3	0.6	1.6	1	1	0
08/29/2021 07:00	0.5	14.0	1,621.7	0.4	1.6	1	1	0
08/29/2021 08:00	0.5	14.1	1,544.6	0.4	1.5	1	1	0
08/29/2021 09:00	0.5	14.1	1,495.7	0.4	1.5	1	1	0
08/29/2021 10:00	1.0	13.3	1,824.9	0.5	3.2	1	1	1
08/29/2021 11:00	1.6	12.6	2,022.3	0.8	5.1	1	1	1
08/29/2021 12:00	0.6	13.8	1,734.4	0.8	1.9	1	1	1
08/29/2021 13:00	0.7	13.9	1,715.0	0.7	2.3	1	1	1
08/29/2021 14:00	1.5	12.1	2,115.5	0.7	4.8	1	1	1
08/29/2021 15:00	1.2	11.7	2,187.1	0.8	3.8	1	1	1
08/29/2021 16:00	1.2	11.6	2,203.9	0.9	3.8	1	1	1
08/29/2021 17:00	1.1	11.4	2,248.6	0.8	3.4	1	1	1
08/29/2021 18:00	1.1	11.4	2,257.6	0.7	3.5	1	1	1
08/29/2021 19:00	1.1	11.3	2,267.8	0.7	3.4	1	1	1
08/29/2021 20:00	1.0	11.3	2,265.7	0.7	3.1	1	1	1
08/29/2021 21:00	1.0	11.3	2,266.7	0.6	3.1	1	1	1
08/29/2021 22:00	1.1	11.6	2,216.8	0.6	3.5	1	1	1
08/29/2021 23:00	1.3	12.2	2,074.9	0.7	4.1	1	1	1
Average/Sum#:	1.0	12.7	1,962.7	0.7	74.9 #	24 #	24 #	18 #
Minimum:	0.5	11.3	1,495.7	0.4	1.5	1	1	0
Maximum:	1.6	14.1	2,267.8	0.9	5.1	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/30/2021 00:00	0.7	13.9	1,651.0	0.7	2.2	1	1	0
08/30/2021 01:00	0.7	13.9	1,696.1	0.7	2.2	1	1	1
08/30/2021 02:00	1.5	12.8	1,985.9	0.8	4.9	1	1	1
08/30/2021 03:00	1.5	12.3	2,078.8	0.9	4.8	1	1	1
08/30/2021 04:00	0.7	13.9	1,656.6	0.9	2.2	1	1	0
08/30/2021 05:00	0.8	13.9	1,556.2	0.8	2.3	1	1	1
08/30/2021 06:00	1.6	12.5	2,066.0	0.8	5.2	1	1	1
08/30/2021 07:00	1.5	12.5	2,034.9	1.0	4.8	1	1	1
08/30/2021 08:00	0.7	13.9	1,695.3	0.9	2.2	1	1	0
08/30/2021 09:00	0.7	13.8	1,666.0	0.8	2.2	1	1	0
08/30/2021 10:00	1.4	12.8	1,959.6	0.7	4.5	1	1	1
08/30/2021 11:00	1.4	12.1	2,092.0	0.8	4.4	1	1	1
08/30/2021 12:00	0.6	13.9	1,714.4	0.8	1.9	1	1	0
08/30/2021 13:00	0.7	13.9	1,700.3	0.7	2.2	1	1	1
08/30/2021 14:00	1.4	12.1	2,122.8	0.7	4.5	1	1	1
08/30/2021 15:00	1.2	11.6	2,198.3	0.8	3.7	1	1	1
08/30/2021 16:00	1.1	11.6	2,206.6	0.8	3.4	1	1	1
08/30/2021 17:00	1.1	11.4	2,239.3	0.7	3.4	1	1	1
08/30/2021 18:00	1.0	11.3	2,256.6	0.7	3.1	1	1	1
08/30/2021 19:00	1.0	11.3	2,272.2	0.6	3.1	1	1	1
08/30/2021 20:00	1.0	11.4	2,298.6	0.6	3.2	1	1	1
08/30/2021 21:00	1.1	11.5	2,279.5	0.6	3.5	1	1	1
08/30/2021 22:00	1.2	11.8	2,219.8	0.7	3.9	1	1	1
08/30/2021 23:00	1.3	12.2	2,099.9	0.8	4.1	1	1	1
Average/Sum#:	1.1	12.6	1,989.4	0.8	81.9 #	24 #	24 #	19 #
Minimum:	0.6	11.3	1,556.2	0.6	1.9	1	1	0
Maximum:	1.6	13.9	2,298.6	1.0	5.2	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/31/2021 00:00	0.7	13.9	1,680.9	0.8	2.2	1	1	0
08/31/2021 01:00	0.7	13.9	1,701.9	0.7	2.2	1	1	0
08/31/2021 02:00	1.0	14.0	1,331.1	0.7	2.5	1	1	0
08/31/2021 03:00	0.6	13.9	1,669.0	0.7	1.9	1	1	0
08/31/2021 04:00	1.1	13.4	1,835.1	0.8	3.6	1	1	1
08/31/2021 05:00	1.4	13.1	1,913.5	0.8	4.5	1	1	1
08/31/2021 06:00	0.6	13.7	1,797.8	0.8	2.0	1	1	0
08/31/2021 07:00	1.6	12.8	2,017.4	0.9	5.3	1	1	1
08/31/2021 08:00	1.4	12.3	2,098.8	0.9	4.5	1	1	1
08/31/2021 09:00	0.7	13.9	1,694.7	0.9	2.2	1	1	0
08/31/2021 10:00	0.7	13.8	1,710.3	0.7	2.2	1	1	0
08/31/2021 11:00	1.5	12.6	2,040.7	0.8	4.9	1	1	1
08/31/2021 12:00	1.4	12.1	2,106.5	0.9	4.4	1	1	1
08/31/2021 13:00	0.6	13.9	1,666.0	0.8	1.9	1	1	0
08/31/2021 14:00	0.6	13.8	1,726.0	0.6	1.9	1	1	0
08/31/2021 15:00	1.6	12.5	2,037.7	0.7	5.1	1	1	1
08/31/2021 16:00	1.3	11.7	2,188.2	0.8	4.1	1	1	1
08/31/2021 17:00	1.2	11.6	2,213.8	0.9	3.8	1	1	1
08/31/2021 18:00	1.2	11.6	2,221.7	0.8	3.8	1	1	1
08/31/2021 19:00	1.2	11.8	2,142.2	0.8	3.7	1	1	1
08/31/2021 20:00	0.6	13.9	1,665.8	0.7	1.9	1	1	0
08/31/2021 21:00	0.7	13.8	1,727.7	0.6	2.2	1	1	1
08/31/2021 22:00	1.2	12.6	2,039.4	0.7	3.9	1	1	1
08/31/2021 23:00	1.1	12.3	2,104.3	0.8	3.6	1	1	1
Average/Sum#:	1.0	13.0	1,888.8	0.8	78.3 #	24 #	24 #	14 #
Minimum:	0.6	11.6	1,331.1	0.6	1.9	1	1	0
Maximum:	1.6	14.0	2,221.7	0.9	5.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/01/2021 00:00	0.8	12.2	2,119.6	0.7	2.6	1	1	1
09/01/2021 01:00	0.8	12.9	1,948.2	0.6	2.6	1	1	1
09/01/2021 02:00	0.5	13.9	1,611.5	0.5	1.5	1	1	0
09/01/2021 03:00	0.6	13.8	1,708.0	0.5	1.9	1	1	1
09/01/2021 04:00	1.3	12.7	2,026.0	0.6	4.2	1	1	1
09/01/2021 05:00	1.2	12.2	2,137.0	0.7	3.9	1	1	1
09/01/2021 06:00	1.1	12.7	2,014.6	0.8	3.6	1	1	1
09/01/2021 07:00	0.4	13.9	1,688.3	0.6	1.3	1	1	0
09/01/2021 08:00	0.5	13.9	1,627.2	0.5	1.5	1	1	0
09/01/2021 09:00	1.2	13.2	1,903.9	0.5	3.9	1	1	1
09/01/2021 10:00	1.3	12.8	2,008.3	0.7	4.3	1	1	1
09/01/2021 11:00	1.0	13.7	1,502.1	0.9	2.8	1	1	1
09/01/2021 12:00	0.7	13.9	1,567.5	0.8	2.1	1	1	1
09/01/2021 13:00	1.6	12.6	2,028.4	0.8	5.2	1	1	1
09/01/2021 14:00	1.5	12.6	2,015.2	0.9	4.8	1	1	1
09/01/2021 15:00	0.8	13.6	1,702.8	0.9	2.5	1	1	1
09/01/2021 16:00	0.7	13.8	1,707.8	0.8	2.2	1	1	1
09/01/2021 17:00	1.6	12.4	2,082.1	0.8	5.2	1	1	1
09/01/2021 18:00	1.5	12.1	2,135.8	0.9	4.8	1	1	1
09/01/2021 19:00	1.4	12.1	2,131.5	1.0	4.5	1	1	1
09/01/2021 20:00	0.6	13.9	1,700.1	0.8	1.9	1	1	0
09/01/2021 21:00	1.1	14.0	1,393.2	0.8	2.9	1	1	0
09/01/2021 22:00	0.6	13.9	1,652.8	0.6	1.9	1	1	0
09/01/2021 23:00	0.5	13.9	1,715.5	0.6	1.6	1	1	0
Average/Sum#:	1.0	13.2	1,838.6	0.7	73.7 #	24 #	24 #	17 #
Minimum:	0.4	12.1	1,393.2	0.5	1.3	1	1	0
Maximum:	1.6	14.0	2,137.0	1.0	5.2	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/02/2021 00:00	1.0	13.3	1,857.1	0.6	3.2	1	1	1
09/02/2021 01:00	1.0	13.1	1,876.2	0.7	3.2	1	1	1
09/02/2021 02:00	1.0	14.0	1,370.3	0.8	2.6	1	1	0
09/02/2021 03:00	0.6	13.9	1,683.9	0.7	1.9	1	1	0
09/02/2021 04:00	0.9	14.0	1,400.5	0.7	2.4	1	1	0
09/02/2021 05:00	0.6	13.9	1,663.2	0.6	1.9	1	1	0
09/02/2021 06:00	0.9	13.5	1,825.7	0.7	2.9	1	1	1
09/02/2021 07:00	1.2	13.4	1,846.9	0.7	3.9	1	1	1
09/02/2021 08:00	0.8	14.0	1,369.4	0.8	2.1	1	1	0
09/02/2021 09:00	0.7	14.0	1,457.6	0.7	2.0	1	1	0
09/02/2021 10:00	0.6	14.0	1,514.8	0.6	1.7	1	1	0
09/02/2021 11:00	0.8	14.0	1,439.1	0.6	2.2	1	1	0
09/02/2021 12:00	0.6	13.9	1,706.5	0.6	1.9	1	1	1
09/02/2021 13:00	1.6	12.6	2,063.2	0.8	5.3	1	1	1
09/02/2021 14:00	1.4	12.6	2,016.1	0.9	4.5	1	1	1
09/02/2021 15:00	0.6	13.9	1,683.5	0.9	1.9	1	1	0
09/02/2021 16:00	0.7	13.9	1,647.4	0.7	2.2	1	1	1
09/02/2021 17:00	1.6	12.4	2,091.0	0.7	5.2	1	1	1
09/02/2021 18:00	1.5	12.2	2,123.3	0.9	4.8	1	1	1
09/02/2021 19:00	1.5	12.3	2,091.3	1.0	4.8	1	1	1
09/02/2021 20:00	0.7	13.9	1,588.0	0.9	2.1	1	1	0
09/02/2021 21:00	0.7	14.0	1,400.2	0.7	1.9	1	1	0
09/02/2021 22:00	0.6	14.0	1,624.0	0.6	1.9	1	1	0
09/02/2021 23:00	1.2	13.4	1,853.7	0.7	3.9	1	1	1
Average/Sum#:	1.0	13.5	1,716.4	0.7	70.4 #	24 #	24 #	12 #
Minimum:	0.6	12.2	1,369.4	0.6	1.7	1	1	0
Maximum:	1.6	14.0	2,123.3	1.0	5.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/03/2021 00:00	1.4	13.0	1,910.7	0.8	4.5	1	1	1
09/03/2021 01:00	0.8	13.8	1,617.8	0.9	2.4	1	1	0
09/03/2021 02:00	0.6	13.7	1,793.5	0.7	2.0	1	1	1
09/03/2021 03:00	1.5	13.1	1,925.9	0.8	4.9	1	1	1
09/03/2021 04:00	0.6	13.9	1,590.6	0.7	1.8	1	1	0
09/03/2021 05:00	0.6	13.7	1,755.9	0.7	1.9	1	1	1
09/03/2021 06:00	1.3	12.7	2,045.0	0.6	4.3	1	1	1
09/03/2021 07:00	1.1	12.9	1,969.9	0.7	3.6	1	1	1
09/03/2021 08:00	0.5	13.9	1,715.3	0.7	1.6	1	1	0
09/03/2021 09:00	0.5	14.0	1,526.3	0.5	1.5	1	1	0
09/03/2021 10:00	0.5	14.0	1,614.6	0.4	1.5	1	1	0
09/03/2021 11:00	1.2	14.0	1,620.6	0.6	3.7	1	1	0
09/03/2021 12:00	0.5	14.0	1,628.9	0.6	1.6	1	1	0
09/03/2021 13:00	0.5	14.0	1,643.2	0.6	1.6	1	1	0
09/03/2021 14:00	0.6	14.0	1,562.2	0.4	1.8	1	1	1
09/03/2021 15:00	1.6	12.3	2,094.4	0.7	5.1	1	1	1
09/03/2021 16:00	1.4	12.0	2,163.6	0.8	4.5	1	1	1
09/03/2021 17:00	1.3	11.7	2,230.1	0.9	4.2	1	1	1
09/03/2021 18:00	1.3	11.7	2,225.2	0.8	4.2	1	1	1
09/03/2021 19:00	1.3	12.0	2,132.1	0.8	4.1	1	1	1
09/03/2021 20:00	0.6	13.9	1,709.0	0.7	1.9	1	1	0
09/03/2021 21:00	0.7	13.7	1,806.1	0.7	2.3	1	1	1
09/03/2021 22:00	1.6	12.7	2,041.0	0.8	5.3	1	1	1
09/03/2021 23:00	1.5	12.9	1,978.4	1.0	4.9	1	1	1
Average/Sum#:	1.0	13.2	1,845.8	0.7	75.2 #	24 #	24 #	15 #
Minimum:	0.5	11.7	1,526.3	0.4	1.5	1	1	0
Maximum:	1.6	14.0	2,230.1	1.0	5.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/04/2021 00:00	0.7	13.9	1,650.1	1.0	2.2	1	1	0
09/04/2021 01:00	0.8	13.8	1,674.7	0.8	2.5	1	1	1
09/04/2021 02:00	1.7	12.7	2,039.5	0.8	5.6	1	1	1
09/04/2021 03:00	11.8	14.0	1,289.6	0.0	14.6	1	0	1
09/04/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2021 09:00	21.8	18.5	252.8	0.0	8.5	1	0	0
09/04/2021 10:00	38.4	15.6	860.7	0.0	82.4	1	0	0
09/04/2021 11:00	0.5	14.1	1,392.6	0.0	1.4	1	0	0
09/04/2021 12:00	0.5	14.1	1,380.3	0.0	1.3	1	0	0
09/04/2021 13:00	0.5	13.9	1,672.0	0.4	1.6	1	0	0
09/04/2021 14:00	0.7	14.0	1,458.3	0.5	2.0	1	0	0
09/04/2021 15:00	0.6	13.9	1,725.1	0.5	2.0	1	1	0
09/04/2021 16:00	0.7	13.9	1,622.1	0.6	2.1	1	1	1
09/04/2021 17:00	1.6	12.1	2,143.0	0.7	5.1	1	1	1
09/04/2021 18:00	1.3	11.5	2,257.2	0.8	4.1	1	1	1
09/04/2021 19:00	1.2	11.5	2,278.9	0.9	3.8	1	1	1
09/04/2021 20:00	1.3	11.8	2,210.2	0.8	4.2	1	1	1
09/04/2021 21:00	1.4	12.1	2,164.2	0.8	4.5	1	1	1
09/04/2021 22:00	1.5	12.3	2,115.0	0.9	4.9	1	1	1
09/04/2021 23:00	1.5	12.4	2,102.2	1.0	4.9	1	1	1
Average/Sum#:	4.7	13.5	1,699.4	0.8	157.7 #	19 #	12 #	11 #
Minimum:	0.5	11.5	252.8	0.4	1.3	0	0	0
Maximum:	38.4	18.5	2,278.9	1.0	82.4	1	1	1
%SI	20.83	20.83	20.83	41.67	20.83	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/05/2021 00:00	1.4	12.8	1,980.3	1.0	4.5	1	1	1
09/05/2021 01:00	0.7	13.9	1,662.6	0.9	2.2	1	1	0
09/05/2021 02:00	0.7	13.9	1,674.5	0.7	2.2	1	1	1
09/05/2021 03:00	1.6	12.7	2,044.6	0.8	5.3	1	1	1
09/05/2021 04:00	1.5	13.0	1,964.0	1.0	4.9	1	1	1
09/05/2021 05:00	0.7	13.9	1,654.9	1.0	2.2	1	1	0
09/05/2021 06:00	0.7	13.9	1,643.1	0.8	2.2	1	1	0
09/05/2021 07:00	0.7	13.9	1,615.9	0.6	2.1	1	1	0
09/05/2021 08:00	0.7	13.9	1,646.7	0.6	2.2	1	1	0
09/05/2021 09:00	0.7	13.9	1,636.0	0.6	2.2	1	1	0
09/05/2021 10:00	0.6	13.9	1,704.5	0.6	1.9	1	1	0
09/05/2021 11:00	0.6	13.9	1,730.3	0.5	2.0	1	1	0
09/05/2021 12:00	0.6	13.9	1,717.8	0.5	1.9	1	1	0
09/05/2021 13:00	0.6	13.9	1,734.3	0.5	2.0	1	1	0
09/05/2021 14:00	1.5	12.5	2,046.7	0.7	4.8	1	1	1
09/05/2021 15:00	1.3	11.9	2,203.4	0.8	4.2	1	1	1
09/05/2021 16:00	1.2	11.7	2,225.0	0.9	3.8	1	1	1
09/05/2021 17:00	1.1	11.5	2,263.7	0.8	3.5	1	1	1
09/05/2021 18:00	1.2	11.6	2,250.1	0.8	3.8	1	1	1
09/05/2021 19:00	1.1	11.5	2,281.4	0.7	3.5	1	1	1
09/05/2021 20:00	1.3	11.8	2,210.7	0.8	4.2	1	1	1
09/05/2021 21:00	1.4	12.1	2,164.2	0.8	4.5	1	1	1
09/05/2021 22:00	1.4	12.2	2,142.8	0.9	4.6	1	1	1
09/05/2021 23:00	1.4	12.5	2,050.0	0.9	4.5	1	1	1
Average/Sum#:	1.0	12.9	1,927.0	0.8	79.2 #	24 #	24 #	14 #
Minimum:	0.6	11.5	1,615.9	0.5	1.9	1	1	0
Maximum:	1.6	13.9	2,281.4	1.0	5.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/06/2021 00:00	0.7	13.9	1,652.7	0.8	2.2	1	1	0
09/06/2021 01:00	0.7	13.9	1,625.0	0.7	2.1	1	1	1
09/06/2021 02:00	1.2	12.8	1,957.6	0.7	3.8	1	1	1
09/06/2021 03:00	1.0	12.8	1,935.8	0.7	3.2	1	1	1
09/06/2021 04:00	0.5	14.0	1,604.9	0.7	1.5	1	1	0
09/06/2021 05:00	0.7	13.9	1,680.6	0.6	2.2	1	1	0
09/06/2021 06:00	0.7	13.9	1,635.7	0.5	2.2	1	1	0
09/06/2021 07:00	0.6	14.0	1,635.3	0.6	1.9	1	1	0
09/06/2021 08:00	0.5	14.0	1,706.4	0.5	1.6	1	1	0
09/06/2021 09:00	0.5	14.0	1,567.3	0.4	1.5	1	1	0
09/06/2021 10:00	0.4	13.9	1,706.1	0.4	1.3	1	1	0
09/06/2021 11:00	0.5	13.9	1,699.3	0.4	1.6	1	1	1
09/06/2021 12:00	1.6	12.2	2,137.3	0.6	5.2	1	1	1
09/06/2021 13:00	1.3	11.7	2,221.8	0.8	4.1	1	1	1
09/06/2021 14:00	1.2	11.7	2,213.1	0.9	3.8	1	1	1
09/06/2021 15:00	1.2	11.6	2,219.5	0.8	3.8	1	1	1
09/06/2021 16:00	1.1	11.6	2,226.8	0.8	3.5	1	1	1
09/06/2021 17:00	1.1	11.5	2,239.8	0.7	3.5	1	1	1
09/06/2021 18:00	1.1	11.4	2,242.5	0.7	3.4	1	1	1
09/06/2021 19:00	1.1	11.5	2,252.5	0.7	3.5	1	1	1
09/06/2021 20:00	1.1	11.5	2,261.6	0.7	3.5	1	1	1
09/06/2021 21:00	1.1	11.6	2,238.3	0.7	3.5	1	1	1
09/06/2021 22:00	1.3	11.9	2,174.2	0.8	4.1	1	1	1
09/06/2021 23:00	1.4	12.4	2,074.3	0.9	4.5	1	1	1
Average/Sum#:	0.9	12.7	1,954.5	0.7	71.5 #	24 #	24 #	16 #
Minimum:	0.4	11.4	1,567.3	0.4	1.3	1	1	0
Maximum:	1.6	14.0	2,261.6	0.9	5.2	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/07/2021 00:00	0.6	13.9	1,717.1	0.8	1.9	1	1	0
09/07/2021 01:00	0.6	13.8	1,693.8	0.7	1.9	1	1	1
09/07/2021 02:00	1.3	12.8	2,023.7	0.6	4.3	1	1	1
09/07/2021 03:00	1.2	13.0	1,958.1	0.8	3.9	1	1	1
09/07/2021 04:00	0.7	13.9	1,720.2	0.8	2.3	1	1	0
09/07/2021 05:00	0.8	13.7	1,806.0	0.7	2.7	1	1	1
09/07/2021 06:00	1.6	12.7	2,046.2	0.8	5.3	1	1	1
09/07/2021 07:00	1.4	12.7	2,011.4	1.0	4.5	1	1	1
09/07/2021 08:00	0.6	13.9	1,708.1	0.9	1.9	1	1	0
09/07/2021 09:00	0.6	13.8	1,750.7	0.7	2.0	1	1	0
09/07/2021 10:00	1.5	12.6	2,039.3	0.7	4.9	1	1	1
09/07/2021 11:00	1.2	11.7	2,224.5	0.8	3.8	1	1	1
09/07/2021 12:00	1.2	11.7	2,207.4	0.9	3.8	1	1	1
09/07/2021 13:00	1.2	11.8	2,182.0	0.8	3.8	1	1	1
09/07/2021 14:00	1.2	11.8	2,170.1	0.8	3.8	1	1	1
09/07/2021 15:00	1.1	11.7	2,180.3	0.8	3.4	1	1	1
09/07/2021 16:00	1.1	11.6	2,201.9	0.7	3.4	1	1	1
09/07/2021 17:00	1.1	11.7	2,194.2	0.7	3.5	1	1	1
09/07/2021 18:00	1.2	12.0	2,154.8	0.7	3.8	1	1	1
09/07/2021 19:00	1.3	12.1	2,140.7	0.8	4.2	1	1	1
09/07/2021 20:00	1.4	12.1	2,150.4	0.9	4.5	1	1	1
09/07/2021 21:00	1.2	11.7	2,252.7	0.9	3.9	1	1	1
09/07/2021 22:00	1.1	11.4	2,283.7	0.8	3.5	1	1	1
09/07/2021 23:00	1.1	11.5	2,284.5	0.7	3.5	1	1	1
Average/Sum#:	1.1	12.5	2,045.9	0.8	84.5 #	24 #	24 #	20 #
Minimum:	0.6	11.4	1,693.8	0.6	1.9	1	1	0
Maximum:	1.6	13.9	2,284.5	1.0	5.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/08/2021 00:00	1.1	11.6	2,263.8	0.7	3.5	1	1	1
09/08/2021 01:00	1.2	11.9	2,186.0	0.7	3.8	1	1	1
09/08/2021 02:00	1.4	12.2	2,133.6	0.8	4.5	1	1	1
09/08/2021 03:00	1.4	12.2	2,144.7	0.9	4.6	1	1	1
09/08/2021 04:00	1.2	11.7	2,254.9	0.9	3.9	1	1	1
09/08/2021 05:00	1.2	11.6	2,279.4	0.8	3.9	1	1	1
09/08/2021 06:00	1.2	11.7	2,238.7	0.8	3.9	1	1	1
09/08/2021 07:00	1.4	12.5	2,044.9	0.9	4.5	1	1	1
09/08/2021 08:00	0.6	13.9	1,716.5	0.8	1.9	1	1	0
09/08/2021 09:00	0.6	13.8	1,728.7	0.7	1.9	1	1	1
09/08/2021 10:00	1.5	12.4	2,089.6	0.7	4.9	1	1	1
09/08/2021 11:00	1.3	11.7	2,191.9	0.8	4.1	1	1	1
09/08/2021 12:00	1.3	11.8	2,166.9	0.9	4.1	1	1	1
09/08/2021 13:00	1.2	11.7	2,166.2	0.8	3.7	1	1	1
09/08/2021 14:00	1.2	11.6	2,167.2	0.8	3.7	1	1	1
09/08/2021 15:00	1.1	11.6	2,165.3	0.8	3.4	1	1	1
09/08/2021 16:00	1.1	11.5	2,186.0	0.7	3.4	1	1	1
09/08/2021 17:00	1.1	11.4	2,203.1	0.7	3.4	1	1	1
09/08/2021 18:00	1.1	11.5	2,204.6	0.7	3.4	1	1	1
09/08/2021 19:00	1.1	11.5	2,220.7	0.7	3.4	1	1	1
09/08/2021 20:00	1.1	11.6	2,210.2	0.7	3.5	1	1	1
09/08/2021 21:00	1.2	11.8	2,171.2	0.7	3.8	1	1	1
09/08/2021 22:00	1.3	11.9	2,146.3	0.8	4.1	1	1	1
09/08/2021 23:00	1.2	11.6	2,213.3	0.8	3.8	1	1	1
Average/Sum#:	1.2	11.9	2,145.6	0.8	89.1 #	24 #	24 #	23 #
Minimum:	0.6	11.4	1,716.5	0.7	1.9	1	1	0
Maximum:	1.5	13.9	2,279.4	0.9	4.9	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/09/2021 00:00	1.1	11.5	2,226.4	0.8	3.4	1	1	1
09/09/2021 01:00	1.1	11.5	2,235.7	0.7	3.5	1	1	1
09/09/2021 02:00	1.1	11.6	2,241.1	0.7	3.5	1	1	1
09/09/2021 03:00	1.1	11.6	2,238.9	0.7	3.5	1	1	1
09/09/2021 04:00	1.1	11.5	2,242.2	0.7	3.5	1	1	1
09/09/2021 05:00	1.1	11.5	2,245.9	0.7	3.5	1	1	1
09/09/2021 06:00	1.1	11.6	2,235.2	0.7	3.5	1	1	1
09/09/2021 07:00	1.2	11.8	2,188.7	0.7	3.8	1	1	1
09/09/2021 08:00	1.2	11.8	2,180.0	0.8	3.8	1	1	1
09/09/2021 09:00	1.2	11.7	2,181.9	0.8	3.8	1	1	1
09/09/2021 10:00	1.2	11.7	2,180.9	0.8	3.8	1	1	1
09/09/2021 11:00	1.2	11.7	2,165.1	0.8	3.7	1	1	1
09/09/2021 12:00	1.1	11.8	2,145.6	0.8	3.4	1	1	1
09/09/2021 13:00	1.1	11.6	2,155.1	0.7	3.4	1	1	1
09/09/2021 14:00	1.1	11.7	2,142.4	0.7	3.4	1	1	1
09/09/2021 15:00	1.2	11.7	2,137.4	0.7	3.7	1	1	1
09/09/2021 16:00	1.1	11.6	2,152.0	0.7	3.4	1	1	1
09/09/2021 17:00	1.1	11.6	2,162.8	0.7	3.4	1	1	1
09/09/2021 18:00	1.1	11.4	2,199.0	0.7	3.4	1	1	1
09/09/2021 19:00	1.1	11.4	2,204.7	0.7	3.4	1	1	1
09/09/2021 20:00	1.1	11.5	2,219.3	0.7	3.4	1	1	1
09/09/2021 21:00	1.1	11.5	2,220.9	0.7	3.4	1	1	1
09/09/2021 22:00	1.1	11.6	2,192.1	0.7	3.4	1	1	1
09/09/2021 23:00	1.2	11.6	2,206.7	0.7	3.8	1	1	1
Average/Sum#:	1.1	11.6	2,195.8	0.7	84.8 #	24 #	24 #	24 #
Minimum:	1.1	11.4	2,137.4	0.7	3.4	1	1	1
Maximum:	1.2	11.8	2,245.9	0.8	3.8	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/10/2021 00:00	1.2	11.9	2,121.5	0.8	3.7	1	1	1
09/10/2021 01:00	0.6	13.9	1,595.7	0.7	1.8	1	1	0
09/10/2021 02:00	0.6	13.7	1,762.7	0.6	1.9	1	1	1
09/10/2021 03:00	1.5	12.4	2,082.3	0.7	4.9	1	1	1
09/10/2021 04:00	1.2	11.8	2,203.4	0.8	3.8	1	1	1
09/10/2021 05:00	1.2	11.9	2,162.2	0.9	3.8	1	1	1
09/10/2021 06:00	1.1	11.8	2,217.1	0.8	3.5	1	1	1
09/10/2021 07:00	0.8	13.5	1,658.1	0.7	2.4	1	1	1
09/10/2021 08:00	0.6	13.9	1,527.7	0.6	1.7	1	1	0
09/10/2021 09:00	0.4	13.9	1,649.6	0.5	1.2	1	1	0
09/10/2021 10:00	0.5	13.8	1,627.3	0.4	1.5	1	1	1
09/10/2021 11:00	1.5	12.4	2,066.7	0.6	4.8	1	1	1
09/10/2021 12:00	1.4	12.3	2,038.6	0.8	4.4	1	1	1
09/10/2021 13:00	0.5	13.9	1,607.4	0.8	1.5	1	1	0
09/10/2021 14:00	0.5	13.8	1,726.8	0.6	1.6	1	1	1
09/10/2021 15:00	1.5	12.2	2,089.8	0.6	4.8	1	1	1
09/10/2021 16:00	1.3	11.9	2,151.3	0.8	4.1	1	1	1
09/10/2021 17:00	1.2	11.6	2,212.6	0.9	3.8	1	1	1
09/10/2021 18:00	1.1	11.5	2,232.2	0.8	3.4	1	1	1
09/10/2021 19:00	1.1	11.5	2,232.9	0.7	3.5	1	1	1
09/10/2021 20:00	1.2	11.6	2,229.3	0.7	3.8	1	1	1
09/10/2021 21:00	1.2	11.6	2,229.1	0.8	3.8	1	1	1
09/10/2021 22:00	1.3	11.9	2,159.0	0.8	4.1	1	1	1
09/10/2021 23:00	1.4	12.3	2,087.1	0.9	4.5	1	1	1
Average/Sum#:	1.0	12.5	1,986.3	0.7	78.3 #	24 #	24 #	20 #
Minimum:	0.4	11.5	1,527.7	0.4	1.2	1	1	0
Maximum:	1.5	13.9	2,232.9	0.9	4.9	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/11/2021 00:00	1.4	12.8	1,952.2	1.0	4.5	1	1	1
09/11/2021 01:00	0.6	13.9	1,709.2	0.8	1.9	1	1	0
09/11/2021 02:00	0.6	13.9	1,694.1	0.7	1.9	1	1	0
09/11/2021 03:00	0.9	13.8	1,583.2	0.6	2.7	1	1	1
09/11/2021 04:00	1.7	12.6	2,039.4	0.8	5.5	1	1	1
09/11/2021 05:00	1.4	13.0	1,962.4	1.0	4.6	1	1	1
09/11/2021 06:00	0.6	13.9	1,672.1	0.9	1.9	1	1	0
09/11/2021 07:00	0.7	13.8	1,644.5	0.7	2.1	1	1	0
09/11/2021 08:00	0.6	13.9	1,525.9	0.5	1.7	1	1	0
09/11/2021 09:00	0.5	13.9	1,608.1	0.5	1.5	1	1	0
09/11/2021 10:00	0.4	13.9	1,703.1	0.4	1.3	1	1	0
09/11/2021 11:00	0.6	13.8	1,688.8	0.4	1.9	1	1	1
09/11/2021 12:00	1.5	12.2	2,095.8	0.6	4.8	1	1	1
09/11/2021 13:00	1.4	12.1	2,076.8	0.8	4.4	1	1	1
09/11/2021 14:00	0.5	13.9	1,695.9	0.8	1.6	1	1	0
09/11/2021 15:00	0.5	13.7	1,735.3	0.6	1.6	1	1	1
09/11/2021 16:00	1.4	12.3	2,087.0	0.6	4.5	1	1	1
09/11/2021 17:00	1.1	11.4	2,270.9	0.7	3.5	1	1	1
09/11/2021 18:00	1.1	11.5	2,236.7	0.8	3.5	1	1	1
09/11/2021 19:00	1.2	11.9	2,176.8	0.7	3.8	1	1	1
09/11/2021 20:00	1.2	11.7	2,220.5	0.8	3.8	1	1	1
09/11/2021 21:00	1.1	11.6	2,242.3	0.8	3.5	1	1	1
09/11/2021 22:00	1.2	11.9	2,189.2	0.8	3.9	1	1	1
09/11/2021 23:00	1.2	11.8	2,202.1	0.8	3.8	1	1	1
Average/Sum#:	1.0	12.9	1,917.2	0.7	74.2 #	24 #	24 #	16 #
Minimum:	0.4	11.4	1,525.9	0.4	1.3	1	1	0
Maximum:	1.7	13.9	2,270.9	1.0	5.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/12/2021 00:00	1.4	12.4	2,055.2	0.9	4.5	1	1	1
09/12/2021 01:00	0.5	13.9	1,710.0	0.7	1.6	1	1	0
09/12/2021 02:00	0.4	14.0	1,667.0	0.6	1.3	1	1	0
09/12/2021 03:00	1.1	13.7	1,666.4	0.5	3.4	1	1	1
09/12/2021 04:00	1.7	12.7	2,028.8	0.8	5.6	1	1	1
09/12/2021 05:00	1.5	13.0	1,969.1	1.1	4.9	1	1	1
09/12/2021 06:00	0.9	13.8	1,557.1	1.0	2.6	1	1	1
09/12/2021 07:00	0.6	13.9	1,601.5	0.8	1.8	1	1	0
09/12/2021 08:00	0.6	14.0	1,367.1	0.6	1.6	1	1	0
09/12/2021 09:00	0.5	14.0	1,298.1	0.5	1.2	1	1	0
09/12/2021 10:00	0.4	13.9	1,676.8	0.4	1.3	1	1	0
09/12/2021 11:00	0.6	13.8	1,746.7	0.4	1.9	1	1	1
09/12/2021 12:00	1.6	12.3	2,083.6	0.6	5.1	1	1	1
09/12/2021 13:00	1.3	11.9	2,115.0	0.8	4.0	1	1	1
09/12/2021 14:00	0.5	13.9	1,670.3	0.8	1.6	1	1	0
09/12/2021 15:00	0.7	13.8	1,657.2	0.6	2.2	1	1	1
09/12/2021 16:00	1.5	12.1	2,116.2	0.7	4.8	1	1	1
09/12/2021 17:00	1.2	11.4	2,257.9	0.8	3.8	1	1	1
09/12/2021 18:00	1.2	11.6	2,220.7	0.8	3.8	1	1	1
09/12/2021 19:00	1.3	11.8	2,183.1	0.8	4.1	1	1	1
09/12/2021 20:00	1.4	12.0	2,151.7	0.8	4.5	1	1	1
09/12/2021 21:00	1.4	12.1	2,128.6	0.9	4.5	1	1	1
09/12/2021 22:00	1.4	12.2	2,114.7	0.9	4.5	1	1	1
09/12/2021 23:00	1.4	12.3	2,107.9	0.9	4.5	1	1	1
Average/Sum#:	1.0	12.9	1,881.3	0.7	79.1 #	24 #	24 #	17 #
Minimum:	0.4	11.4	1,298.1	0.4	1.2	1	1	0
Maximum:	1.7	14.0	2,257.9	1.1	5.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/13/2021 00:00	1.4	12.8	1,967.5	1.0	4.5	1	1	1
09/13/2021 01:00	0.6	13.9	1,606.9	0.8	1.8	1	1	0
09/13/2021 02:00	0.7	13.9	1,592.6	0.7	2.1	1	1	0
09/13/2021 03:00	0.6	13.9	1,667.3	0.5	1.9	1	1	0
09/13/2021 04:00	0.7	14.0	1,347.6	0.6	1.8	1	1	0
09/13/2021 05:00	0.5	14.0	1,695.4	0.5	1.6	1	1	0
09/13/2021 06:00	1.1	13.4	1,826.7	0.6	3.5	1	1	1
09/13/2021 07:00	1.4	13.0	1,875.7	0.8	4.4	1	1	1
09/13/2021 08:00	0.7	13.9	1,544.6	0.8	2.0	1	1	0
09/13/2021 09:00	1.6	12.7	1,991.2	0.9	5.1	1	1	1
09/13/2021 10:00	1.5	12.6	1,997.8	1.0	4.8	1	1	1
09/13/2021 11:00	0.6	13.9	1,724.6	0.9	2.0	1	1	0
09/13/2021 12:00	0.6	13.8	1,697.5	0.7	1.9	1	1	0
09/13/2021 13:00	1.6	12.4	2,062.3	0.7	5.1	1	1	1
09/13/2021 14:00	1.2	11.5	2,232.7	0.8	3.8	1	1	1
09/13/2021 15:00	1.1	11.6	2,216.2	0.9	3.5	1	1	1
09/13/2021 16:00	1.1	11.5	2,210.5	0.7	3.4	1	1	1
09/13/2021 17:00	1.1	11.4	2,243.4	0.7	3.4	1	1	1
09/13/2021 18:00	1.1	11.4	2,248.1	0.7	3.4	1	1	1
09/13/2021 19:00	1.1	11.4	2,243.6	0.7	3.4	1	1	1
09/13/2021 20:00	1.2	11.6	2,222.3	0.7	3.8	1	1	1
09/13/2021 21:00	1.3	11.9	2,166.7	0.8	4.1	1	1	1
09/13/2021 22:00	1.4	12.2	2,106.5	0.9	4.5	1	1	1
09/13/2021 23:00	1.4	12.7	1,990.8	0.9	4.5	1	1	1
Average/Sum#:	1.1	12.7	1,936.6	0.8	80.3 #	24 #	24 #	16 #
Minimum:	0.5	11.4	1,347.6	0.5	1.6	1	1	0
Maximum:	1.6	14.0	2,248.1	1.0	5.1	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/14/2021 00:00	1.4	12.8	1,965.4	1.0	4.5	1	1	1
09/14/2021 01:00	0.7	13.9	1,588.9	0.9	2.1	1	1	0
09/14/2021 02:00	0.7	13.9	1,566.1	0.7	2.1	1	1	0
09/14/2021 03:00	0.7	13.9	1,565.7	0.6	2.1	1	1	0
09/14/2021 04:00	0.9	13.9	1,509.7	0.7	2.6	1	1	0
09/14/2021 05:00	1.6	12.5	2,022.2	0.8	5.1	1	1	1
09/14/2021 06:00	1.5	12.6	2,022.1	1.0	4.8	1	1	1
09/14/2021 07:00	1.0	13.9	1,665.4	1.0	3.1	1	1	0
09/14/2021 08:00	0.8	13.9	1,523.2	0.9	2.3	1	1	0
09/14/2021 09:00	0.8	13.9	1,489.7	0.7	2.2	1	1	0
09/14/2021 10:00	0.6	13.9	1,664.4	0.6	1.9	1	1	0
09/14/2021 11:00	0.6	13.9	1,712.1	0.6	1.9	1	1	0
09/14/2021 12:00	0.6	13.9	1,557.2	0.5	1.8	1	1	1
09/14/2021 13:00	1.6	12.5	2,045.9	0.7	5.1	1	1	1
09/14/2021 14:00	1.4	12.0	2,114.7	0.8	4.4	1	1	1
09/14/2021 15:00	0.6	13.8	1,698.1	0.8	1.9	1	1	0
09/14/2021 16:00	0.6	13.8	1,625.0	0.6	1.8	1	1	1
09/14/2021 17:00	1.6	12.1	2,108.7	0.7	5.1	1	1	1
09/14/2021 18:00	1.3	11.5	2,212.1	0.8	4.0	1	1	1
09/14/2021 19:00	1.4	12.2	2,057.0	0.9	4.4	1	1	1
09/14/2021 20:00	0.6	13.8	1,711.4	0.7	1.9	1	1	0
09/14/2021 21:00	0.6	13.7	1,772.0	0.6	2.0	1	1	1
09/14/2021 22:00	1.7	12.5	2,062.5	0.7	5.5	1	1	1
09/14/2021 23:00	1.5	12.7	1,979.7	0.9	4.8	1	1	1
Average/Sum#:	1.0	13.2	1,801.6	0.8	77.4 #	24 #	24 #	13 #
Minimum:	0.6	11.5	1,489.7	0.5	1.8	1	1	0
Maximum:	1.7	13.9	2,212.1	1.0	5.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/15/2021 00:00	0.7	13.9	1,558.6	1.0	2.1	1	1	0
09/15/2021 01:00	0.8	13.8	1,587.9	0.8	2.4	1	1	1
09/15/2021 02:00	1.7	12.6	2,035.2	0.8	5.5	1	1	1
09/15/2021 03:00	1.5	12.8	1,989.8	1.0	4.9	1	1	1
09/15/2021 04:00	0.8	13.8	1,697.9	1.0	2.5	1	1	1
09/15/2021 05:00	0.7	13.7	1,608.1	0.8	2.1	1	1	1
09/15/2021 06:00	1.9	12.8	2,006.8	0.9	6.2	1	1	1
09/15/2021 07:00	1.5	12.9	1,957.5	1.0	4.8	1	1	1
09/15/2021 08:00	0.8	13.9	1,483.0	1.1	2.2	1	1	0
09/15/2021 09:00	0.6	14.0	1,420.2	0.8	1.6	1	1	0
09/15/2021 10:00	0.5	14.0	1,552.3	0.5	1.5	1	1	0
09/15/2021 11:00	0.6	13.9	1,619.9	0.5	1.8	1	1	0
09/15/2021 12:00	0.7	13.9	1,547.8	0.5	2.0	1	1	1
09/15/2021 13:00	1.6	12.3	2,080.9	0.7	5.1	1	1	1
09/15/2021 14:00	1.5	12.1	2,096.8	0.9	4.7	1	1	1
09/15/2021 15:00	0.7	13.8	1,576.0	0.9	2.1	1	1	1
09/15/2021 16:00	0.9	13.8	1,587.1	0.8	2.7	1	1	1
09/15/2021 17:00	1.5	12.2	2,081.4	0.8	4.7	1	1	1
09/15/2021 18:00	1.4	12.1	2,092.8	0.9	4.4	1	1	1
09/15/2021 19:00	1.4	12.6	1,995.0	1.0	4.4	1	1	1
09/15/2021 20:00	0.8	13.6	1,706.4	0.8	2.5	1	1	1
09/15/2021 21:00	0.7	13.9	1,628.6	0.7	2.2	1	1	1
09/15/2021 22:00	1.6	12.9	1,959.9	0.8	5.2	1	1	1
09/15/2021 23:00	1.5	13.0	1,951.9	1.0	4.9	1	1	1
Average/Sum#:	1.1	13.3	1,784.2	0.8	82.5 #	24 #	24 #	19 #
Minimum:	0.5	12.1	1,420.2	0.5	1.5	1	1	0
Maximum:	1.9	14.0	2,096.8	1.1	6.2	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/16/2021 00:00	1.1	13.5	1,720.7	1.1	3.4	1	1	1
09/16/2021 01:00	0.8	13.9	1,542.6	0.9	2.3	1	0	0
09/16/2021 02:00	0.6	13.8	1,778.0	0.7	2.0	1	0	0
09/16/2021 03:00	0.6	13.8	1,780.3	0.6	2.0	1	0	0
09/16/2021 04:00	0.8	14.0	1,407.5	0.6	2.2	1	0	0
09/16/2021 05:00	0.9	14.0	1,331.1	0.7	2.3	1	0	0
09/16/2021 06:00	0.8	13.9	1,385.8	0.7	2.1	1	0	0
09/16/2021 07:00	0.9	13.9	1,359.7	0.8	2.3	1	0	0
09/16/2021 08:00	0.8	13.9	1,364.4	0.7	2.1	1	0	0
09/16/2021 09:00	0.7	13.9	1,368.0	0.7	1.8	1	0	0
09/16/2021 10:00	0.6	14.0	1,375.5	0.6	1.6	1	0	0
09/16/2021 11:00	0.6	14.0	1,376.0	0.5	1.6	1	0	0
09/16/2021 12:00	0.6	13.9	1,607.3	0.5	1.8	1	0	0
09/16/2021 13:00	0.7	13.9	1,543.6	0.5	2.0	1	0	0
09/16/2021 14:00	0.6	13.9	1,709.6	0.5	1.9	1	1	0
09/16/2021 15:00	0.6	13.9	1,651.1	0.5	1.9	1	1	0
09/16/2021 16:00	0.8	13.9	1,547.5	0.6	2.3	1	1	1
09/16/2021 17:00	1.6	12.1	2,136.0	0.8	5.1	1	1	1
09/16/2021 18:00	1.4	11.9	2,149.0	0.9	4.4	1	1	1
09/16/2021 19:00	1.4	12.6	1,998.5	1.0	4.5	1	1	1
09/16/2021 20:00	0.9	13.6	1,730.7	0.9	2.8	1	1	1
09/16/2021 21:00	0.7	13.7	1,691.7	0.8	2.2	1	1	1
09/16/2021 22:00	1.4	12.5	2,056.9	0.8	4.5	1	1	1
09/16/2021 23:00	1.3	12.8	1,977.6	0.8	4.2	1	1	1
Average/Sum#:	0.9	13.6	1,649.5	0.7	63.3 #	24 #	11 #	9 #
Minimum:	0.6	11.9	1,331.1	0.5	1.6	1	0	0
Maximum:	1.6	14.0	2,149.0	1.1	5.1	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/17/2021 00:00	1.3	12.9	1,950.3	1.0	4.2	1	1	1
09/17/2021 01:00	1.0	13.7	1,501.4	0.9	2.8	1	1	1
09/17/2021 02:00	0.7	13.9	1,529.8	0.8	2.0	1	0	0
09/17/2021 03:00	0.7	13.9	1,529.3	0.7	2.0	1	0	0
09/17/2021 04:00	0.6	13.9	1,510.5	0.6	1.7	1	0	0
09/17/2021 05:00	0.7	13.9	1,541.5	0.6	2.0	1	0	0
09/17/2021 06:00	0.7	13.9	1,479.7	0.6	2.0	1	0	0
09/17/2021 07:00	0.7	13.9	1,439.4	0.6	1.9	1	0	0
09/17/2021 08:00	0.8	13.9	1,355.1	0.6	2.0	1	0	0
09/17/2021 09:00	0.7	14.0	1,358.1	0.6	1.8	1	0	0
09/17/2021 10:00	0.6	14.0	1,359.8	0.6	1.6	1	0	0
09/17/2021 11:00	0.6	14.0	1,368.7	0.5	1.6	1	0	0
09/17/2021 12:00	0.6	14.0	1,368.2	0.5	1.6	1	0	0
09/17/2021 13:00	0.6	13.9	1,607.2	0.5	1.8	1	0	0
09/17/2021 14:00	0.5	13.9	1,491.4	0.5	1.4	1	0	0
09/17/2021 15:00	0.6	13.9	1,504.1	0.5	1.7	1	1	0
09/17/2021 16:00	0.7	13.8	1,606.3	0.5	2.1	1	1	1
09/17/2021 17:00	1.5	12.1	2,109.7	0.7	4.7	1	1	1
09/17/2021 18:00	1.3	11.8	2,191.9	0.8	4.1	1	1	1
09/17/2021 19:00	1.3	12.5	2,036.8	0.9	4.2	1	1	1
09/17/2021 20:00	1.4	12.9	1,957.5	0.9	4.5	1	1	1
09/17/2021 21:00	1.5	12.8	1,977.9	1.0	4.8	1	1	1
09/17/2021 22:00	1.5	12.8	1,973.1	1.1	4.8	1	1	1
09/17/2021 23:00	1.1	13.7	1,516.1	1.0	3.1	1	1	1
Average/Sum#:	0.9	13.5	1,636.0	0.7	64.4 #	24 #	11 #	10 #
Minimum:	0.5	11.8	1,355.1	0.5	1.4	1	0	0
Maximum:	1.5	14.0	2,191.9	1.1	4.8	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/18/2021 00:00	0.8	14.0	1,371.7	0.9	2.1	1	0	0
09/18/2021 01:00	0.8	14.0	1,347.8	0.8	2.1	1	0	0
09/18/2021 02:00	0.8	14.0	1,350.6	0.7	2.1	1	0	0
09/18/2021 03:00	0.8	14.0	1,356.0	0.7	2.1	1	0	0
09/18/2021 04:00	0.7	13.9	1,430.5	0.7	1.9	1	0	0
09/18/2021 05:00	0.8	13.9	1,380.1	0.7	2.1	1	0	0
09/18/2021 06:00	0.8	13.9	1,391.4	0.7	2.1	1	0	0
09/18/2021 07:00	0.8	13.9	1,368.4	0.7	2.1	1	0	0
09/18/2021 08:00	0.8	13.9	1,370.3	0.7	2.1	1	0	0
09/18/2021 09:00	0.7	13.9	1,371.9	0.7	1.8	1	0	0
09/18/2021 10:00	0.7	14.0	1,376.0	0.6	1.8	1	0	0
09/18/2021 11:00	0.6	14.0	1,374.9	0.6	1.6	1	0	0
09/18/2021 12:00	0.6	14.0	1,371.2	0.5	1.6	1	0	0
09/18/2021 13:00	0.5	14.0	1,369.9	0.5	1.3	1	0	0
09/18/2021 14:00	0.6	14.0	1,366.4	0.5	1.6	1	0	0
09/18/2021 15:00	0.6	14.0	1,363.9	0.5	1.6	1	0	0
09/18/2021 16:00	0.6	14.0	1,402.4	0.5	1.6	1	0	0
09/18/2021 17:00	0.6	14.0	1,414.2	0.5	1.6	1	0	0
09/18/2021 18:00	0.6	14.0	1,397.7	0.5	1.6	1	0	0
09/18/2021 19:00	0.6	14.0	1,364.0	0.5	1.6	1	0	0
09/18/2021 20:00	0.5	13.9	1,566.9	0.5	1.5	1	0	0
09/18/2021 21:00	0.6	13.9	1,489.9	0.5	1.7	1	0	0
09/18/2021 22:00	0.6	13.9	1,526.8	0.5	1.7	1	0	0
09/18/2021 23:00	0.7	13.9	1,355.6	0.5	1.8	1	0	0
Average/Sum#:	0.7	14.0	1,394.9	0.6	43.1 #	24 #	0 #	0 #
Minimum:	0.5	13.9	1,347.8	0.5	1.3	1	0	0
Maximum:	0.8	14.0	1,566.9	0.9	2.1	1	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/19/2021 00:00	0.7	13.9	1,357.3	0.6	1.8	1	0	0
09/19/2021 01:00	0.8	13.9	1,356.0	0.6	2.0	1	0	0
09/19/2021 02:00	0.8	13.9	1,353.3	0.7	2.0	1	0	0
09/19/2021 03:00	0.8	13.9	1,358.9	0.7	2.1	1	0	0
09/19/2021 04:00	0.7	13.9	1,409.4	0.7	1.9	1	0	0
09/19/2021 05:00	0.8	13.9	1,420.9	0.7	2.1	1	0	0
09/19/2021 06:00	0.8	13.9	1,358.3	0.7	2.1	1	0	0
09/19/2021 07:00	0.8	13.9	1,359.8	0.7	2.1	1	0	0
09/19/2021 08:00	0.8	13.9	1,356.8	0.7	2.0	1	0	0
09/19/2021 09:00	0.7	13.9	1,360.6	0.7	1.8	1	0	0
09/19/2021 10:00	0.6	14.0	1,387.7	0.6	1.6	1	0	0
09/19/2021 11:00	0.5	14.0	1,372.1	0.5	1.3	1	0	0
09/19/2021 12:00	0.5	14.0	1,372.9	0.4	1.3	1	0	0
09/19/2021 13:00	0.5	14.0	1,369.1	0.4	1.3	1	0	0
09/19/2021 14:00	0.5	14.0	1,400.8	0.4	1.3	1	0	0
09/19/2021 15:00	0.5	14.0	1,369.5	0.4	1.3	1	0	0
09/19/2021 16:00	0.5	14.0	1,551.9	0.4	1.5	1	0	0
09/19/2021 17:00	0.5	13.9	1,729.4	0.4	1.6	1	0	0
09/19/2021 18:00	0.5	13.9	1,563.0	0.4	1.5	1	0	0
09/19/2021 19:00	0.5	14.0	1,424.6	0.4	1.4	1	0	0
09/19/2021 20:00	0.5	14.0	1,559.1	0.4	1.5	1	0	0
09/19/2021 21:00	0.5	14.0	1,400.9	0.4	1.3	1	0	0
09/19/2021 22:00	0.5	14.0	1,364.0	0.4	1.3	1	0	0
09/19/2021 23:00	0.6	14.0	1,363.1	0.4	1.6	1	0	0
Average/Sum#:	0.6	14.0	1,413.3	0.5	39.7 #	24 #	0 #	0 #
Minimum:	0.5	13.9	1,353.3	0.4	1.3	1	0	0
Maximum:	0.8	14.0	1,729.4	0.7	2.1	1	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/20/2021 00:00	0.6	14.0	1,361.9	0.5	1.6	1	0	0
09/20/2021 01:00	0.5	13.9	1,520.4	0.5	1.4	1	0	0
09/20/2021 02:00	0.5	13.9	1,724.2	0.4	1.6	1	0	0
09/20/2021 03:00	0.6	14.0	1,304.8	0.4	1.5	1	0	0
09/20/2021 04:00	0.5	14.0	1,469.6	0.4	1.4	1	1	0
09/20/2021 05:00	2.8	13.1	1,899.9	1.0	9.0	1	1	1
09/20/2021 06:00	1.6	12.8	2,007.4	1.2	5.2	1	1	1
09/20/2021 07:00	1.0	13.8	1,514.1	1.4	2.8	1	1	1
09/20/2021 08:00	0.5	14.1	1,307.3	0.8	1.3	1	1	0
09/20/2021 09:00	0.5	14.1	1,310.2	0.5	1.3	1	1	0
09/20/2021 10:00	0.4	14.1	1,312.2	0.4	1.0	1	1	0
09/20/2021 11:00	0.5	13.9	1,605.4	0.4	1.5	1	1	1
09/20/2021 12:00	1.6	12.7	2,034.5	0.6	5.2	1	1	1
09/20/2021 13:00	1.4	12.7	2,034.2	0.9	4.6	1	1	1
09/20/2021 14:00	0.7	13.7	1,596.8	0.9	2.1	1	1	1
09/20/2021 15:00	0.5	13.9	1,562.1	0.7	1.5	1	1	1
09/20/2021 16:00	1.7	12.4	2,103.8	0.7	5.6	1	1	1
09/20/2021 17:00	1.1	11.5	2,286.4	0.8	3.5	1	1	1
09/20/2021 18:00	1.1	11.5	2,280.4	0.9	3.5	1	1	1
09/20/2021 19:00	1.1	11.7	2,243.1	0.7	3.5	1	1	1
09/20/2021 20:00	1.2	11.9	2,203.6	0.7	3.9	1	1	1
09/20/2021 21:00	1.3	12.2	2,143.5	0.8	4.2	1	1	1
09/20/2021 22:00	1.4	12.9	1,994.7	0.9	4.6	1	1	1
09/20/2021 23:00	1.5	13.0	1,945.9	1.0	4.9	1	1	1
Average/Sum#:	1.0	13.2	1,781.9	0.7	76.7 #	24 #	20 #	16 #
Minimum:	0.4	11.5	1,304.8	0.4	1.0	1	0	0
Maximum:	2.8	14.1	2,286.4	1.4	9.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/21/2021 00:00	0.6	13.9	1,703.3	0.9	1.9	1	1	0
09/21/2021 01:00	0.8	13.9	1,604.3	0.8	2.4	1	1	1
09/21/2021 02:00	2.5	13.1	1,966.7	1.0	8.3	1	1	1
09/21/2021 03:00	1.7	13.1	1,958.2	1.3	5.6	1	1	1
09/21/2021 04:00	1.8	13.1	1,954.7	1.5	6.0	1	1	1
09/21/2021 05:00	1.7	13.0	1,969.9	1.3	5.6	1	1	1
09/21/2021 06:00	1.5	12.5	2,101.0	1.3	5.0	1	1	1
09/21/2021 07:00	1.6	13.1	1,949.9	1.2	5.3	1	1	1
09/21/2021 08:00	0.7	13.9	1,493.1	1.0	2.0	1	1	0
09/21/2021 09:00	0.5	14.0	1,549.6	0.7	1.5	1	1	0
09/21/2021 10:00	0.4	13.9	1,682.3	0.4	1.3	1	1	0
09/21/2021 11:00	0.5	14.0	1,653.4	0.4	1.6	1	1	1
09/21/2021 12:00	1.6	12.5	2,070.7	0.6	5.2	1	1	1
09/21/2021 13:00	1.3	11.8	2,198.1	0.8	4.1	1	1	1
09/21/2021 14:00	1.2	11.8	2,201.4	0.9	3.8	1	1	1
09/21/2021 15:00	1.2	11.7	2,212.8	0.8	3.8	1	1	1
09/21/2021 16:00	1.1	11.6	2,228.5	0.8	3.5	1	1	1
09/21/2021 17:00	1.1	11.6	2,235.1	0.7	3.5	1	1	1
09/21/2021 18:00	1.1	11.5	2,251.1	0.7	3.5	1	1	1
09/21/2021 19:00	1.1	11.7	2,218.9	0.7	3.5	1	1	1
09/21/2021 20:00	1.1	11.7	2,237.7	0.7	3.5	1	1	1
09/21/2021 21:00	1.2	11.9	2,184.0	0.7	3.8	1	1	1
09/21/2021 22:00	1.3	12.2	2,143.1	0.8	4.2	1	1	1
09/21/2021 23:00	1.3	12.5	2,064.6	0.9	4.2	1	1	1
Average/Sum#:	1.2	12.7	1,993.0	0.9	93.1 #	24 #	24 #	20 #
Minimum:	0.4	11.5	1,493.1	0.4	1.3	1	1	0
Maximum:	2.5	14.0	2,251.1	1.5	8.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/22/2021 00:00	0.8	13.8	1,648.7	0.8	2.5	1	1	1
09/22/2021 01:00	0.7	13.8	1,682.3	0.7	2.2	1	1	1
09/22/2021 02:00	3.5	13.0	1,957.6	1.3	11.5	1	1	1
09/22/2021 03:00	3.1	13.1	1,955.1	1.8	10.3	1	1	1
09/22/2021 04:00	2.1	12.7	2,066.4	2.1	7.0	1	1	1
09/22/2021 05:00	1.4	12.0	2,188.9	1.6	4.5	1	1	1
09/22/2021 06:00	1.4	12.3	2,111.4	1.1	4.5	1	1	1
09/22/2021 07:00	1.6	13.0	1,948.2	1.0	5.2	1	1	1
09/22/2021 08:00	0.7	13.9	1,657.2	0.9	2.2	1	1	0
09/22/2021 09:00	0.6	13.8	1,755.2	0.8	2.0	1	1	0
09/22/2021 10:00	1.6	12.9	1,972.5	0.8	5.2	1	1	1
09/22/2021 11:00	1.5	12.3	2,083.3	0.9	4.8	1	1	1
09/22/2021 12:00	0.6	13.9	1,639.6	0.9	1.9	1	1	0
09/22/2021 13:00	0.6	13.8	1,735.7	0.7	1.9	1	1	1
09/22/2021 14:00	1.5	12.2	2,113.9	0.7	4.8	1	1	1
09/22/2021 15:00	1.2	11.6	2,224.9	0.8	3.8	1	1	1
09/22/2021 16:00	1.0	11.5	2,252.4	0.8	3.2	1	1	1
09/22/2021 17:00	1.1	11.5	2,241.3	0.7	3.5	1	1	1
09/22/2021 18:00	1.1	11.6	2,247.3	0.7	3.5	1	1	1
09/22/2021 19:00	1.2	12.1	2,112.8	0.7	3.8	1	1	1
09/22/2021 20:00	0.6	13.9	1,674.1	0.7	1.9	1	1	0
09/22/2021 21:00	0.7	13.7	1,798.4	0.6	2.3	1	1	1
09/22/2021 22:00	1.6	12.6	2,042.1	0.7	5.2	1	1	1
09/22/2021 23:00	1.5	12.3	2,097.0	0.9	4.8	1	1	1
Average/Sum#:	1.3	12.8	1,966.9	0.9	102.5 #	24 #	24 #	20 #
Minimum:	0.6	11.5	1,639.6	0.6	1.9	1	1	0
Maximum:	3.5	13.9	2,252.4	2.1	11.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/23/2021 00:00	1.4	12.8	1,975.9	1.0	4.5	1	1	1
09/23/2021 01:00	0.7	13.9	1,584.6	0.9	2.1	1	1	0
09/23/2021 02:00	0.6	14.0	1,549.0	0.7	1.8	1	1	0
09/23/2021 03:00	0.5	14.0	1,658.9	0.5	1.6	1	1	0
09/23/2021 04:00	0.5	13.9	1,608.1	0.4	1.5	1	1	1
09/23/2021 05:00	1.6	12.4	2,061.1	0.6	5.1	1	1	1
09/23/2021 06:00	1.4	12.6	2,023.1	0.8	4.5	1	1	1
09/23/2021 07:00	0.6	13.9	1,684.9	0.9	1.9	1	1	0
09/23/2021 08:00	0.7	14.0	1,419.6	0.7	1.9	1	1	0
09/23/2021 09:00	0.6	13.8	1,783.4	0.5	2.0	1	1	0
09/23/2021 10:00	0.6	13.7	1,784.9	0.5	2.0	1	1	0
09/23/2021 11:00	0.6	13.7	1,787.1	0.5	2.0	1	1	0
09/23/2021 12:00	0.6	13.7	1,781.7	0.5	2.0	1	1	0
09/23/2021 13:00	0.6	13.7	1,779.9	0.5	2.0	1	1	0
09/23/2021 14:00	0.5	13.7	1,779.4	0.5	1.6	1	1	0
09/23/2021 15:00	0.5	13.7	1,779.1	0.4	1.6	1	1	0
09/23/2021 16:00	0.5	13.7	1,778.1	0.4	1.6	1	1	0
09/23/2021 17:00	0.6	13.7	1,781.0	0.4	2.0	1	1	0
09/23/2021 18:00	0.6	13.7	1,788.5	0.5	2.0	1	1	0
09/23/2021 19:00	0.7	13.7	1,794.0	0.5	2.3	1	1	0
09/23/2021 20:00	0.7	13.7	1,801.3	0.6	2.3	1	1	0
09/23/2021 21:00	0.6	13.7	1,801.3	0.6	2.0	1	1	0
09/23/2021 22:00	0.6	13.7	1,799.1	0.5	2.0	1	1	0
09/23/2021 23:00	0.6	13.7	1,796.4	0.5	2.0	1	1	0
Average/Sum#:	0.7	13.6	1,765.9	0.6	54.3 #	24 #	24 #	4 #
Minimum:	0.5	12.4	1,419.6	0.4	1.5	1	1	0
Maximum:	1.6	14.0	2,061.1	1.0	5.1	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/24/2021 00:00	0.6	13.7	1,797.5	0.5	2.0	1	1	0
09/24/2021 01:00	0.6	13.7	1,797.8	0.5	2.0	1	1	0
09/24/2021 02:00	0.6	13.7	1,798.8	0.5	2.0	1	1	0
09/24/2021 03:00	0.6	13.7	1,799.7	0.5	2.0	1	1	0
09/24/2021 04:00	0.6	13.7	1,803.6	0.5	2.0	1	1	0
09/24/2021 05:00	0.7	13.7	1,799.4	0.5	2.3	1	1	0
09/24/2021 06:00	0.7	13.7	1,802.9	0.6	2.3	1	1	0
09/24/2021 07:00	0.7	13.7	1,805.4	0.6	2.3	1	1	0
09/24/2021 08:00	0.6	13.7	1,802.4	0.6	2.0	1	1	0
09/24/2021 09:00	0.6	13.9	1,677.0	0.5	1.9	1	1	0
09/24/2021 10:00	0.6	13.9	1,557.3	0.5	1.8	1	1	0
09/24/2021 11:00	0.4	14.0	1,630.3	0.4	1.2	1	1	0
09/24/2021 12:00	0.4	13.9	1,630.4	0.4	1.2	1	1	0
09/24/2021 13:00	0.5	13.9	1,683.8	0.3	1.6	1	1	0
09/24/2021 14:00	0.5	13.9	1,722.1	0.4	1.6	1	1	0
09/24/2021 15:00	0.6	13.8	1,713.7	0.4	1.9	1	1	0
09/24/2021 16:00	0.6	13.9	1,698.6	0.5	1.9	1	1	0
09/24/2021 17:00	0.6	13.7	1,741.7	0.5	1.9	1	1	0
09/24/2021 18:00	0.6	13.9	1,678.0	0.5	1.9	1	1	0
09/24/2021 19:00	0.6	13.9	1,712.1	0.5	1.9	1	1	0
09/24/2021 20:00	0.7	13.9	1,655.7	0.5	2.2	1	1	0
09/24/2021 21:00	0.7	13.9	1,633.4	0.6	2.2	1	1	0
09/24/2021 22:00	0.7	13.8	1,669.3	0.6	2.2	1	1	0
09/24/2021 23:00	0.7	13.9	1,665.3	0.6	2.2	1	1	0
Average/Sum#:	0.6	13.8	1,719.8	0.5	46.5 #	24 #	24 #	0 #
Minimum:	0.4	13.7	1,557.3	0.3	1.2	1	1	0
Maximum:	0.7	14.0	1,805.4	0.6	2.3	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/25/2021 00:00	0.7	13.9	1,591.8	0.6	2.1	1	1	0
09/25/2021 01:00	0.7	13.8	1,658.5	0.6	2.2	1	1	0
09/25/2021 02:00	0.7	13.8	1,686.9	0.6	2.2	1	1	0
09/25/2021 03:00	0.7	13.8	1,685.7	0.6	2.2	1	1	0
09/25/2021 04:00	0.6	13.9	1,639.5	0.6	1.9	1	1	0
09/25/2021 05:00	0.6	13.9	1,620.9	0.5	1.8	1	1	0
09/25/2021 06:00	0.6	13.9	1,665.6	0.5	1.9	1	1	0
09/25/2021 07:00	0.6	13.9	1,660.0	0.5	1.9	1	1	0
09/25/2021 08:00	0.6	13.9	1,553.0	0.5	1.8	1	1	0
09/25/2021 09:00	0.7	14.0	1,356.2	0.5	1.8	1	1	0
09/25/2021 10:00	0.5	13.9	1,545.0	0.5	1.5	1	1	0
09/25/2021 11:00	0.5	13.9	1,675.0	0.5	1.6	1	1	0
09/25/2021 12:00	0.6	13.9	1,685.3	0.4	1.9	1	1	0
09/25/2021 13:00	0.6	13.9	1,672.1	0.5	1.9	1	1	0
09/25/2021 14:00	0.6	13.9	1,704.6	0.5	1.9	1	1	0
09/25/2021 15:00	0.6	13.8	1,701.0	0.5	1.9	1	1	0
09/25/2021 16:00	0.6	13.8	1,650.4	0.5	1.8	1	1	0
09/25/2021 17:00	0.8	14.0	1,344.2	0.6	2.1	1	1	0
09/25/2021 18:00	0.6	13.9	1,643.0	0.6	1.9	1	1	0
09/25/2021 19:00	0.6	13.9	1,701.4	0.6	1.9	1	1	0
09/25/2021 20:00	0.7	13.9	1,664.9	0.5	2.2	1	1	0
09/25/2021 21:00	0.8	13.9	1,575.6	0.6	2.4	1	1	0
09/25/2021 22:00	11.3	15.0	907.9	0.0	10.4	1	1	0
09/25/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	1	0
Average/Sum#:	1.1	13.9	1,590.8	0.5	53.2 #	23 #	24 #	0 #
Minimum:	0.5	13.8	907.9	0.4	1.5	0	1	0
Maximum:	11.3	15.0	1,704.6	0.6	10.4	1	1	0
%SI	4.17	4.17	4.17	8.33	4.17	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/26/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/26/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/26/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/26/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/26/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/26/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/26/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/26/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/26/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/26/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/26/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/26/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/26/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/26/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/26/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/26/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/26/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/26/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/26/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/26/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/26/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/26/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/26/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/26/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	1	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	24 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	1	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	1	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/27/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/27/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/27/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/27/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/27/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/27/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/27/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/27/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/27/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/27/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/27/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/27/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/27/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/27/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/27/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/27/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/27/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/27/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/27/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/27/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/27/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/27/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/27/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/27/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	1	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	24 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	1	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	1	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/28/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/28/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/28/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/28/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/28/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/28/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/28/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/28/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/28/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/28/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/28/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/28/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/28/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/28/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/28/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/28/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/28/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/28/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/28/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/28/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/28/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/28/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/28/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/28/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	1	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	24 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	1	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	1	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/29/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/29/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/29/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/29/2021 03:00	62.1	17.9	263.9	0.0	50.5	1	1	0
09/29/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/29/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/29/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/29/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/29/2021 08:00	15.7	18.1	223.9	0.0	9.1	1	1	0
09/29/2021 09:00	33.6	15.4	866.8	0.0	69.9	1	1	0
09/29/2021 10:00	0.3	14.0	1,574.3	0.0	0.9	1	1	0
09/29/2021 11:00	0.4	0.0	1,499.4	0.0	0.4	1	1	0
09/29/2021 12:00	0.3	0.0	1,487.6	0.0	0.3	1	1	0
09/29/2021 13:00	0.2	14.0	1,660.5	0.0	0.6	1	1	0
09/29/2021 14:00	0.3	13.9	1,691.4	0.0	1.0	1	1	0
09/29/2021 15:00	0.3	13.9	1,700.0	0.3	1.0	1	1	0
09/29/2021 16:00	0.3	13.9	1,687.6	0.3	1.0	1	1	0
09/29/2021 17:00	0.4	14.0	1,449.6	0.3	1.1	1	1	0
09/29/2021 18:00	0.3	14.1	1,406.0	0.3	0.8	1	1	0
09/29/2021 19:00	0.3	13.9	1,663.2	0.3	0.9	1	1	0
09/29/2021 20:00	0.3	13.9	1,672.2	0.3	0.9	1	1	0
09/29/2021 21:00	0.4	13.9	1,642.1	0.3	1.2	1	1	0
09/29/2021 22:00	0.3	13.9	1,677.9	0.3	0.9	1	1	0
09/29/2021 23:00	0.4	13.9	1,549.8	0.3	1.2	1	1	0
Average/Sum#:	6.8	14.6	1,395.1	0.3	141.0 #	17 #	24 #	0 #
Minimum:	0.2	13.9	223.9	0.3	0.6	0	1	0
Maximum:	62.1	18.1	1,700.0	0.3	69.9	1	1	0
%SI	29.17	37.50	29.17	62.50	37.50	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/30/2021 00:00	0.3	14.0	1,520.5	0.3	0.9	1	1	0
09/30/2021 01:00	0.2	14.1	1,336.6	0.3	0.5	1	1	0
09/30/2021 02:00	0.2	14.1	1,310.2	0.2	0.5	1	1	0
09/30/2021 03:00	0.2	14.0	1,569.4	0.2	0.6	1	1	0
09/30/2021 04:00	0.2	14.0	1,630.0	0.2	0.6	1	1	0
09/30/2021 05:00	0.2	14.1	1,357.1	0.2	0.5	1	1	0
09/30/2021 06:00	0.4	14.0	1,460.2	0.2	1.1	1	0	0
09/30/2021 07:00	0.3	14.1	1,350.2	0.3	0.8	1	0	0
09/30/2021 08:00	0.2	14.1	1,348.2	0.3	0.5	1	0	0
09/30/2021 09:00	0.2	14.1	1,362.1	0.2	0.5	1	0	0
09/30/2021 10:00	0.2	14.1	1,366.0	0.2	0.5	1	0	0
09/30/2021 11:00	0.2	14.1	1,366.5	0.2	0.5	1	0	0
09/30/2021 12:00	0.1	14.1	1,367.6	0.2	0.3	1	0	0
09/30/2021 13:00	0.1	14.1	1,362.4	0.1	0.3	1	0	0
09/30/2021 14:00	0.2	14.1	1,386.1	0.1	0.5	1	0	1
09/30/2021 15:00	1.9	13.0	1,970.2	0.6	6.3	1	0	1
09/30/2021 16:00	1.4	12.7	2,026.7	0.9	4.6	1	0	1
09/30/2021 17:00	1.3	12.8	1,997.0	1.1	4.2	1	0	1
09/30/2021 18:00	1.4	13.0	1,967.0	1.0	4.6	1	0	1
09/30/2021 19:00	1.4	13.0	1,965.3	1.0	4.6	1	0	1
09/30/2021 20:00	1.4	13.0	1,950.1	1.0	4.6	1	0	1
09/30/2021 21:00	1.5	13.0	1,953.0	1.0	4.9	1	0	1
09/30/2021 22:00	1.6	13.2	1,921.7	1.1	5.3	1	0	1
09/30/2021 23:00	0.5	14.0	1,410.1	0.9	1.3	1	0	0
Average/Sum#:	0.7	13.7	1,593.9	0.5	49.0 #	24 #	6 #	9 #
Minimum:	0.1	12.7	1,310.2	0.1	0.3	1	0	0
Maximum:	1.9	14.1	2,026.7	1.1	6.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/01/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/01/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/02/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/02/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/03/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/04/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/05/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/06/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/07/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/07/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/08/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/08/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/08/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/08/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/08/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/08/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/08/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/08/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/08/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/08/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/08/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/08/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/08/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/08/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/08/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/08/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/08/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/08/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/08/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/08/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/08/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/08/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/08/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/08/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/09/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/09/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/09/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/09/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/09/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/09/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/09/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/09/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/09/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/09/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/09/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/09/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/09/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/09/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/09/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/09/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/09/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/09/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/09/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/09/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/09/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/09/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/09/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/09/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/10/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/10/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/10/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/10/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/10/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/10/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/10/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/10/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/10/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/10/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/10/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/10/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/10/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/10/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/10/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/10/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/10/2021 16:00	96.6	18.1	174.5	0.0	27.8	1	0	0
07/10/2021 17:00	39.7	17.6	205.2	0.0	15.3	1	0	0
07/10/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/10/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/10/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/10/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/10/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/10/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	68.2	17.9	189.9	0.0	43.1 #	2 #	0 #	0 #
Minimum:	39.7	17.6	174.5	0.0	15.3	0	0	0
Maximum:	96.6	18.1	205.2	0.0	27.8	1	0	0
%SI	91.67	91.67	91.67	100.00	91.67	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/11/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/11/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/11/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/11/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/11/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/11/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/11/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/11/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/11/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/11/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/11/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/11/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/11/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/11/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/11/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/11/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/11/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/11/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/11/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/11/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/11/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/11/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/11/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/11/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/12/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/12/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/12/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/12/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/12/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/12/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/12/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/12/2021 07:00	65.7	0.0	307.2	0.0	9.0	1	0	0
07/12/2021 08:00	24.3	0.0	373.7	0.0	5.7	1	0	0
07/12/2021 09:00	30.3	0.0	649.9	0.0	12.4	1	0	0
07/12/2021 10:00	0.3	13.9	1,339.1	0.0	0.8	1	1	0
07/12/2021 11:00	0.3	13.7	1,666.6	0.0	0.9	1	1	0
07/12/2021 12:00	0.3	13.6	1,721.4	0.2	0.9	1	1	0
07/12/2021 13:00	0.3	13.6	1,719.6	0.2	0.9	1	1	0
07/12/2021 14:00	0.3	13.6	1,715.2	0.2	0.9	1	1	0
07/12/2021 15:00	0.3	13.6	1,707.5	0.2	0.9	1	1	0
07/12/2021 16:00	0.3	13.8	1,546.3	0.2	0.9	1	1	0
07/12/2021 17:00	0.3	13.6	1,697.5	0.2	0.9	1	1	0
07/12/2021 18:00	0.3	13.6	1,692.4	0.2	0.9	1	1	0
07/12/2021 19:00	0.3	13.7	1,692.1	0.2	0.9	1	1	0
07/12/2021 20:00	0.3	13.6	1,716.2	0.2	0.9	1	1	0
07/12/2021 21:00	0.4	13.6	1,715.7	0.2	1.2	1	1	0
07/12/2021 22:00	0.4	13.7	1,684.2	0.3	1.2	1	1	0
07/12/2021 23:00	0.4	13.6	1,741.8	0.3	1.3	1	1	0
Average/Sum#:	7.3	13.7	1,452.1	0.2	13.5 #	17 #	14 #	0 #
Minimum:	0.3	13.6	307.2	0.2	0.8	0	0	0
Maximum:	65.7	13.9	1,741.8	0.3	1.3	1	1	0
%SI	29.17	41.67	29.17	50.00	41.67	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/13/2021 00:00	0.4	13.6	1,747.3	0.3	1.3	1	1	0
07/13/2021 01:00	0.4	13.6	1,751.2	0.3	1.3	1	1	0
07/13/2021 02:00	14.3	14.8	1,048.1	0.0	13.9	1	0	0
07/13/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/13/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/13/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/13/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/13/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/13/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/13/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/13/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/13/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/13/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/13/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/13/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/13/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/13/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/13/2021 17:00	63.3	17.7	326.6	0.0	53.7	1	0	0
07/13/2021 18:00	49.2	14.9	990.6	0.0	107.3	1	0	0
07/13/2021 19:00	0.0	13.7	1,674.6	0.0	0.0	1	1	0
07/13/2021 20:00	0.5	12.8	1,882.4	0.0	1.5	1	1	1
07/13/2021 21:00	0.2	13.5	1,539.9	0.2	0.5	1	1	1
07/13/2021 22:00	0.0	14.0	1,292.6	0.2	0.0	1	1	0
07/13/2021 23:00	0.0	13.8	1,692.2	0.1	0.0	1	1	0
Average/Sum#:	12.8	14.2	1,394.6	0.2	179.5 #	10 #	7 #	2 #
Minimum:	0.0	12.8	326.6	0.1	0.0	0	0	0
Maximum:	63.3	17.7	1,882.4	0.3	107.3	1	1	1
%SI	58.33	58.33	58.33	79.17	58.33	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/14/2021 00:00	0.0	13.9	1,549.0	0.0	0.0	1	1	0
07/14/2021 01:00	0.0	13.9	1,513.0	0.0	0.0	1	1	0
07/14/2021 02:00	0.0	13.9	1,523.5	0.0	0.0	1	1	0
07/14/2021 03:00	0.0	13.9	1,608.3	0.0	0.0	1	1	0
07/14/2021 04:00	0.0	13.9	1,484.0	0.0	0.0	1	1	0
07/14/2021 05:00	0.0	13.9	1,671.9	0.0	0.0	1	1	0
07/14/2021 06:00	0.0	13.9	1,601.0	0.0	0.0	1	1	0
07/14/2021 07:00	0.0	13.8	1,643.1	0.0	0.0	1	1	1
07/14/2021 08:00	1.4	12.7	1,971.0	0.3	4.4	1	1	1
07/14/2021 09:00	1.4	12.8	1,909.3	0.7	4.4	1	1	1
07/14/2021 10:00	0.0	13.9	1,625.4	0.7	0.0	1	1	0
07/14/2021 11:00	0.0	13.9	1,561.8	0.3	0.0	1	1	1
07/14/2021 12:00	1.3	12.6	1,971.1	0.3	4.1	1	1	1
07/14/2021 13:00	0.1	12.1	2,046.9	0.3	0.3	1	1	1
07/14/2021 14:00	0.1	12.1	2,041.2	0.4	0.3	1	1	1
07/14/2021 15:00	0.1	12.2	2,032.1	0.1	0.3	1	1	1
07/14/2021 16:00	0.0	12.1	2,034.4	0.1	0.0	1	1	1
07/14/2021 17:00	0.0	12.1	2,044.1	0.0	0.0	1	1	1
07/14/2021 18:00	0.0	12.2	2,039.3	0.0	0.0	1	1	1
07/14/2021 19:00	0.2	12.3	2,021.2	0.0	0.6	1	1	1
07/14/2021 20:00	0.3	12.3	2,015.5	0.1	0.9	1	1	1
07/14/2021 21:00	0.6	12.5	1,990.7	0.2	1.9	1	1	1
07/14/2021 22:00	0.6	12.5	1,992.9	0.3	1.9	1	1	1
07/14/2021 23:00	0.7	12.6	1,990.3	0.4	2.2	1	1	1
Average/Sum#:	0.3	13.0	1,828.4	0.2	21.3 #	24 #	24 #	16 #
Minimum:	0.0	12.1	1,484.0	0.0	0.0	1	1	0
Maximum:	1.4	13.9	2,046.9	0.7	4.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/15/2021 00:00	1.2	12.8	1,929.1	0.6	3.8	1	1	1
07/15/2021 01:00	0.0	13.9	1,534.2	0.5	0.0	1	1	0
07/15/2021 02:00	0.0	13.9	1,485.1	0.3	0.0	1	1	0
07/15/2021 03:00	0.0	13.9	1,466.4	0.0	0.0	1	1	0
07/15/2021 04:00	0.0	13.9	1,674.5	0.0	0.0	1	1	0
07/15/2021 05:00	1.4	13.0	1,913.8	0.3	4.5	1	1	1
07/15/2021 06:00	0.8	12.8	1,950.4	0.5	2.5	1	1	1
07/15/2021 07:00	0.0	13.9	1,607.5	0.5	0.0	1	1	1
07/15/2021 08:00	0.0	13.9	1,606.7	0.2	0.0	1	1	0
07/15/2021 09:00	0.0	13.9	1,535.6	0.0	0.0	1	1	0
07/15/2021 10:00	0.0	13.9	1,636.1	0.0	0.0	1	1	0
07/15/2021 11:00	0.0	14.0	1,533.8	0.0	0.0	1	1	1
07/15/2021 12:00	1.5	12.6	2,000.2	0.4	4.8	1	1	1
07/15/2021 13:00	0.6	12.3	2,048.0	0.5	1.9	1	1	1
07/15/2021 14:00	0.3	12.2	2,064.3	0.6	0.9	1	1	1
07/15/2021 15:00	0.2	12.2	2,065.4	0.2	0.6	1	1	1
07/15/2021 16:00	0.2	12.1	2,069.6	0.1	0.6	1	1	1
07/15/2021 17:00	0.2	12.2	2,071.0	0.1	0.6	1	1	1
07/15/2021 18:00	0.0	12.1	2,096.3	0.1	0.0	1	1	1
07/15/2021 19:00	0.0	12.0	2,101.8	0.0	0.0	1	1	1
07/15/2021 20:00	0.0	12.0	2,104.1	0.0	0.0	1	1	1
07/15/2021 21:00	0.3	12.3	2,058.4	0.1	0.9	1	1	1
07/15/2021 22:00	0.8	12.5	2,015.7	0.3	2.5	1	1	1
07/15/2021 23:00	0.9	12.5	2,027.7	0.5	2.9	1	1	1
Average/Sum#:	0.4	13.0	1,858.2	0.2	26.5 #	24 #	24 #	17 #
Minimum:	0.0	12.0	1,466.4	0.0	0.0	1	1	0
Maximum:	1.5	14.0	2,104.1	0.6	4.8	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/16/2021 00:00	0.9	12.6	2,030.5	0.6	2.9	1	1	1
07/16/2021 01:00	2.2	12.9	1,931.7	0.9	7.0	1	1	1
07/16/2021 02:00	0.0	13.9	1,601.5	0.7	0.0	1	1	0
07/16/2021 03:00	0.0	13.9	1,447.7	0.5	0.0	1	1	0
07/16/2021 04:00	0.0	13.9	1,595.9	0.0	0.0	1	1	0
07/16/2021 05:00	1.6	13.5	1,777.5	0.4	5.1	1	1	1
07/16/2021 06:00	1.1	13.3	1,839.7	0.7	3.5	1	1	1
07/16/2021 07:00	0.0	13.9	1,650.3	0.7	0.0	1	1	0
07/16/2021 08:00	0.0	13.9	1,646.5	0.3	0.0	1	1	0
07/16/2021 09:00	0.0	13.9	1,615.7	0.0	0.0	1	1	0
07/16/2021 10:00	0.0	13.9	1,662.6	0.0	0.0	1	1	0
07/16/2021 11:00	0.0	13.9	1,491.7	0.0	0.0	1	1	0
07/16/2021 12:00	1.9	12.8	1,949.3	0.5	6.0	1	1	1
07/16/2021 13:00	1.5	12.7	1,941.8	0.8	4.7	1	1	1
07/16/2021 14:00	0.0	13.9	1,627.9	0.8	0.0	1	1	0
07/16/2021 15:00	0.0	13.9	1,565.9	0.4	0.0	1	1	1
07/16/2021 16:00	1.6	12.6	2,009.2	0.4	5.1	1	1	1
07/16/2021 17:00	0.0	12.0	2,122.2	0.4	0.0	1	1	1
07/16/2021 18:00	0.0	11.9	2,140.2	0.4	0.0	1	1	1
07/16/2021 19:00	0.0	11.9	2,141.8	0.0	0.0	1	1	1
07/16/2021 20:00	0.0	12.0	2,127.2	0.0	0.0	1	1	1
07/16/2021 21:00	0.2	12.1	2,089.3	0.0	0.6	1	1	1
07/16/2021 22:00	0.4	12.3	2,060.5	0.1	1.3	1	1	1
07/16/2021 23:00	0.9	12.4	2,028.6	0.3	2.8	1	1	1
Average/Sum#:	0.5	13.1	1,837.3	0.4	39.0 #	24 #	24 #	15 #
Minimum:	0.0	11.9	1,447.7	0.0	0.0	1	1	0
Maximum:	2.2	13.9	2,141.8	0.9	7.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/17/2021 00:00	2.5	12.9	1,901.5	0.9	7.8	1	1	1
07/17/2021 01:00	0.0	13.9	1,626.2	0.8	0.0	1	1	0
07/17/2021 02:00	0.0	14.0	1,296.9	0.6	0.0	1	1	0
07/17/2021 03:00	0.0	13.9	1,595.3	0.0	0.0	1	1	0
07/17/2021 04:00	2.4	13.4	1,785.2	0.6	7.5	1	1	1
07/17/2021 05:00	1.3	13.1	1,811.7	1.0	4.0	1	1	1
07/17/2021 06:00	0.0	13.9	1,606.1	1.0	0.0	1	1	0
07/17/2021 07:00	0.0	13.9	1,609.3	0.3	0.0	1	1	0
07/17/2021 08:00	0.0	14.0	1,571.3	0.0	0.0	1	1	0
07/17/2021 09:00	0.0	13.8	1,664.0	0.0	0.0	1	1	0
07/17/2021 10:00	0.0	13.9	1,587.3	0.0	0.0	1	1	0
07/17/2021 11:00	0.0	14.0	1,512.4	0.0	0.0	1	1	0
07/17/2021 12:00	0.0	13.9	1,599.6	0.0	0.0	1	1	1
07/17/2021 13:00	1.3	12.4	2,023.8	0.3	4.1	1	1	1
07/17/2021 14:00	0.1	12.0	2,111.8	0.3	0.3	1	1	1
07/17/2021 15:00	0.0	12.0	2,109.8	0.3	0.0	1	1	1
07/17/2021 16:00	0.0	11.9	2,119.4	0.0	0.0	1	1	1
07/17/2021 17:00	0.0	11.8	2,137.7	0.0	0.0	1	1	1
07/17/2021 18:00	0.0	11.8	2,141.2	0.0	0.0	1	1	1
07/17/2021 19:00	0.0	11.8	2,140.3	0.0	0.0	1	1	1
07/17/2021 20:00	0.0	11.9	2,123.7	0.0	0.0	1	1	1
07/17/2021 21:00	0.0	12.0	2,100.9	0.0	0.0	1	1	1
07/17/2021 22:00	0.3	12.3	2,052.5	0.1	0.9	1	1	1
07/17/2021 23:00	0.3	12.3	2,057.4	0.1	0.9	1	1	1
Average/Sum#:	0.3	13.0	1,845.2	0.3	25.5 #	24 #	24 #	15 #
Minimum:	0.0	11.8	1,296.9	0.0	0.0	1	1	0
Maximum:	2.5	14.0	2,141.2	1.0	7.8	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/18/2021 00:00	1.3	12.7	1,954.7	0.4	4.1	1	1	1
07/18/2021 01:00	0.0	13.9	1,627.7	0.4	0.0	1	1	0
07/18/2021 02:00	0.0	13.9	1,551.8	0.3	0.0	1	1	1
07/18/2021 03:00	1.4	12.7	1,978.9	0.3	4.5	1	1	1
07/18/2021 04:00	1.8	12.8	1,946.2	0.8	5.7	1	1	1
07/18/2021 05:00	0.0	13.9	1,635.2	0.8	0.0	1	1	0
07/18/2021 06:00	0.0	13.9	1,635.6	0.4	0.0	1	1	0
07/18/2021 07:00	0.0	13.9	1,629.0	0.0	0.0	1	1	0
07/18/2021 08:00	0.0	13.8	1,651.5	0.0	0.0	1	1	0
07/18/2021 09:00	0.0	13.9	1,620.6	0.0	0.0	1	1	0
07/18/2021 10:00	0.0	14.0	1,568.9	0.0	0.0	1	1	0
07/18/2021 11:00	0.0	13.9	1,682.7	0.0	0.0	1	1	1
07/18/2021 12:00	1.1	12.5	2,012.7	0.3	3.5	1	1	1
07/18/2021 13:00	0.0	11.9	2,130.5	0.3	0.0	1	1	1
07/18/2021 14:00	0.0	11.8	2,133.9	0.3	0.0	1	1	1
07/18/2021 15:00	0.0	11.8	2,132.0	0.0	0.0	1	1	1
07/18/2021 16:00	0.0	11.8	2,124.8	0.0	0.0	1	1	1
07/18/2021 17:00	0.0	11.8	2,123.5	0.0	0.0	1	1	1
07/18/2021 18:00	0.0	11.9	2,103.3	0.0	0.0	1	1	1
07/18/2021 19:00	0.0	12.1	2,087.1	0.0	0.0	1	1	1
07/18/2021 20:00	0.0	12.1	2,085.7	0.0	0.0	1	1	1
07/18/2021 21:00	0.0	12.0	2,119.4	0.0	0.0	1	1	1
07/18/2021 22:00	0.0	12.0	2,114.2	0.0	0.0	1	1	1
07/18/2021 23:00	0.0	12.0	2,113.9	0.0	0.0	1	1	1
Average/Sum#:	0.2	12.8	1,906.8	0.2	17.8 #	24 #	24 #	17 #
Minimum:	0.0	11.8	1,551.8	0.0	0.0	1	1	0
Maximum:	1.8	14.0	2,133.9	0.8	5.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/19/2021 00:00	0.0	12.1	2,099.9	0.0	0.0	1	1	1
07/19/2021 01:00	0.1	13.6	1,678.5	0.0	0.3	1	1	1
07/19/2021 02:00	0.0	13.9	1,655.1	0.0	0.0	1	1	0
07/19/2021 03:00	0.0	13.9	1,603.6	0.0	0.0	1	1	0
07/19/2021 04:00	0.0	13.9	1,672.3	0.0	0.0	1	1	1
07/19/2021 05:00	2.2	12.7	2,010.3	0.5	7.1	1	1	1
07/19/2021 06:00	0.9	12.6	2,020.6	0.7	2.9	1	1	1
07/19/2021 07:00	0.0	13.9	1,574.5	0.7	0.0	1	1	0
07/19/2021 08:00	0.0	13.9	1,595.5	0.2	0.0	1	1	0
07/19/2021 09:00	0.0	13.9	1,560.4	0.0	0.0	1	1	1
07/19/2021 10:00	1.0	12.6	2,007.6	0.2	3.2	1	1	1
07/19/2021 11:00	0.0	11.8	2,143.7	0.2	0.0	1	1	1
07/19/2021 12:00	0.0	11.8	2,141.9	0.2	0.0	1	1	1
07/19/2021 13:00	0.0	11.8	2,132.7	0.0	0.0	1	1	1
07/19/2021 14:00	0.0	11.8	2,137.1	0.0	0.0	1	1	1
07/19/2021 15:00	0.0	11.8	2,129.4	0.0	0.0	1	1	1
07/19/2021 16:00	0.0	11.8	2,138.3	0.0	0.0	1	1	1
07/19/2021 17:00	0.0	11.9	2,136.9	0.0	0.0	1	1	1
07/19/2021 18:00	0.0	11.9	2,140.8	0.0	0.0	1	1	1
07/19/2021 19:00	0.0	11.9	2,142.5	0.0	0.0	1	1	1
07/19/2021 20:00	0.0	11.9	2,140.0	0.0	0.0	1	1	1
07/19/2021 21:00	0.0	11.9	2,122.1	0.0	0.0	1	1	1
07/19/2021 22:00	0.5	12.4	2,038.8	0.1	1.6	1	1	1
07/19/2021 23:00	0.6	12.4	2,026.9	0.2	1.9	1	1	1
Average/Sum#:	0.2	12.6	1,960.4	0.1	17.0 #	24 #	24 #	20 #
Minimum:	0.0	11.8	1,560.4	0.0	0.0	1	1	0
Maximum:	2.2	13.9	2,143.7	0.7	7.1	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/20/2021 00:00	0.9	12.5	2,010.8	0.4	2.8	1	1	1
07/20/2021 01:00	0.0	13.8	1,650.2	0.3	0.0	1	1	1
07/20/2021 02:00	0.0	13.9	1,659.6	0.2	0.0	1	1	0
07/20/2021 03:00	0.0	13.9	1,661.2	0.0	0.0	1	1	1
07/20/2021 04:00	1.8	12.7	2,001.4	0.4	5.8	1	1	1
07/20/2021 05:00	0.2	12.3	2,100.5	0.5	0.6	1	1	1
07/20/2021 06:00	0.3	13.6	1,651.5	0.5	0.9	1	1	1
07/20/2021 07:00	0.0	13.9	1,618.2	0.1	0.0	1	1	0
07/20/2021 08:00	0.0	13.9	1,568.9	0.1	0.0	1	1	0
07/20/2021 09:00	0.0	13.9	1,603.5	0.0	0.0	1	1	0
07/20/2021 10:00	0.0	13.9	1,639.1	0.0	0.0	1	1	0
07/20/2021 11:00	0.0	13.9	1,568.7	0.0	0.0	1	1	0
07/20/2021 12:00	0.0	13.9	1,636.5	0.0	0.0	1	1	1
07/20/2021 13:00	1.2	12.7	1,978.7	0.3	3.8	1	1	1
07/20/2021 14:00	0.1	12.0	2,080.2	0.3	0.3	1	1	1
07/20/2021 15:00	0.0	11.9	2,104.9	0.3	0.0	1	1	1
07/20/2021 16:00	0.0	11.8	2,128.0	0.0	0.0	1	1	1
07/20/2021 17:00	0.0	11.8	2,130.3	0.0	0.0	1	1	1
07/20/2021 18:00	0.0	11.8	2,132.8	0.0	0.0	1	1	1
07/20/2021 19:00	0.0	11.8	2,129.0	0.0	0.0	1	1	1
07/20/2021 20:00	0.0	11.8	2,144.6	0.0	0.0	1	1	1
07/20/2021 21:00	0.1	12.0	2,103.2	0.0	0.3	1	1	1
07/20/2021 22:00	0.2	12.2	2,087.1	0.1	0.6	1	1	1
07/20/2021 23:00	0.3	12.2	2,071.3	0.1	0.9	1	1	1
Average/Sum#:	0.2	12.8	1,894.2	0.2	16.0 #	24 #	24 #	18 #
Minimum:	0.0	11.8	1,568.7	0.0	0.0	1	1	0
Maximum:	1.8	13.9	2,144.6	0.5	5.8	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/21/2021 00:00	1.2	12.7	1,969.4	0.4	3.8	1	1	1
07/21/2021 01:00	0.0	13.9	1,609.0	0.4	0.0	1	1	0
07/21/2021 02:00	0.0	13.9	1,635.6	0.3	0.0	1	1	0
07/21/2021 03:00	1.1	13.3	1,809.6	0.3	3.5	1	1	1
07/21/2021 04:00	0.8	12.6	1,986.5	0.5	2.5	1	1	1
07/21/2021 05:00	0.0	13.9	1,596.8	0.5	0.0	1	1	0
07/21/2021 06:00	0.0	13.9	1,556.5	0.2	0.0	1	1	1
07/21/2021 07:00	1.3	12.8	1,978.9	0.3	4.2	1	1	1
07/21/2021 08:00	2.0	12.9	1,918.1	0.8	6.3	1	1	1
07/21/2021 09:00	0.0	13.9	1,664.0	0.8	0.0	1	1	0
07/21/2021 10:00	0.0	13.9	1,577.3	0.5	0.0	1	1	1
07/21/2021 11:00	1.1	12.6	2,003.1	0.3	3.5	1	1	1
07/21/2021 12:00	0.6	12.3	2,052.4	0.4	1.9	1	1	1
07/21/2021 13:00	0.5	12.3	2,060.2	0.5	1.6	1	1	1
07/21/2021 14:00	0.4	12.1	2,070.6	0.3	1.2	1	1	1
07/21/2021 15:00	0.3	12.1	2,087.0	0.3	0.9	1	1	1
07/21/2021 16:00	0.3	12.0	2,085.8	0.2	0.9	1	1	1
07/21/2021 17:00	0.2	12.0	2,102.3	0.2	0.6	1	1	1
07/21/2021 18:00	0.0	11.8	2,131.7	0.1	0.0	1	1	1
07/21/2021 19:00	0.0	11.8	2,133.7	0.0	0.0	1	1	1
07/21/2021 20:00	0.0	11.8	2,141.9	0.0	0.0	1	1	1
07/21/2021 21:00	0.1	12.0	2,116.8	0.0	0.3	1	1	1
07/21/2021 22:00	0.3	12.1	2,093.2	0.1	0.9	1	1	1
07/21/2021 23:00	0.6	12.4	2,045.1	0.2	1.9	1	1	1
Average/Sum#:	0.5	12.7	1,934.4	0.3	34.0 #	24 #	24 #	20 #
Minimum:	0.0	11.8	1,556.5	0.0	0.0	1	1	0
Maximum:	2.0	13.9	2,141.9	0.8	6.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/22/2021 00:00	1.3	12.7	1,966.0	0.5	4.1	1	1	1
07/22/2021 01:00	0.0	13.9	1,636.5	0.4	0.0	1	1	0
07/22/2021 02:00	0.0	13.8	1,535.6	0.3	0.0	1	1	1
07/22/2021 03:00	1.1	12.7	1,977.8	0.3	3.5	1	1	1
07/22/2021 04:00	1.3	12.9	1,923.0	0.6	4.1	1	1	1
07/22/2021 05:00	0.0	13.9	1,577.5	0.6	0.0	1	1	0
07/22/2021 06:00	0.0	13.8	1,665.6	0.3	0.0	1	1	1
07/22/2021 07:00	1.5	12.7	1,979.6	0.4	4.8	1	1	1
07/22/2021 08:00	2.2	12.9	1,928.8	0.9	7.0	1	1	1
07/22/2021 09:00	0.0	13.8	1,590.3	0.9	0.0	1	1	1
07/22/2021 10:00	0.0	13.9	1,613.2	0.5	0.0	1	1	0
07/22/2021 11:00	0.0	13.7	1,730.7	0.0	0.0	1	1	1
07/22/2021 12:00	1.4	12.5	2,028.7	0.3	4.5	1	1	1
07/22/2021 13:00	0.3	12.0	2,128.6	0.4	0.9	1	1	1
07/22/2021 14:00	0.4	12.1	2,104.7	0.5	1.3	1	1	1
07/22/2021 15:00	0.4	12.1	2,100.7	0.3	1.3	1	1	1
07/22/2021 16:00	0.2	11.9	2,130.2	0.2	0.6	1	1	1
07/22/2021 17:00	0.2	12.0	2,115.4	0.2	0.6	1	1	1
07/22/2021 18:00	0.1	11.9	2,140.1	0.1	0.3	1	1	1
07/22/2021 19:00	0.1	11.9	2,133.9	0.1	0.3	1	1	1
07/22/2021 20:00	0.1	11.9	2,127.4	0.1	0.3	1	1	1
07/22/2021 21:00	0.5	12.2	2,065.2	0.2	1.6	1	1	1
07/22/2021 22:00	0.6	12.3	2,054.6	0.3	1.9	1	1	1
07/22/2021 23:00	0.9	12.5	1,986.9	0.4	2.8	1	1	1
Average/Sum#:	0.5	12.8	1,926.7	0.4	39.9 #	24 #	24 #	21 #
Minimum:	0.0	11.9	1,535.6	0.0	0.0	1	1	0
Maximum:	2.2	13.9	2,140.1	0.9	7.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/23/2021 00:00	0.0	13.9	1,649.8	0.3	0.0	1	1	0
07/23/2021 01:00	0.0	13.9	1,621.3	0.2	0.0	1	1	1
07/23/2021 02:00	1.3	12.8	1,980.5	0.3	4.2	1	1	1
07/23/2021 03:00	1.6	13.0	1,904.4	0.7	5.1	1	1	1
07/23/2021 04:00	0.0	13.9	1,655.8	0.7	0.0	1	1	0
07/23/2021 05:00	0.0	13.9	1,623.0	0.4	0.0	1	1	0
07/23/2021 06:00	0.0	13.9	1,634.9	0.0	0.0	1	1	0
07/23/2021 07:00	0.0	13.9	1,610.7	0.0	0.0	1	1	0
07/23/2021 08:00	0.0	13.9	1,648.3	0.0	0.0	1	1	0
07/23/2021 09:00	0.0	13.9	1,632.5	0.0	0.0	1	1	0
07/23/2021 10:00	0.0	13.9	1,672.3	0.0	0.0	1	1	0
07/23/2021 11:00	0.2	13.8	1,683.2	0.1	0.6	1	1	1
07/23/2021 12:00	1.0	12.3	2,057.3	0.3	3.2	1	1	1
07/23/2021 13:00	0.0	11.8	2,147.1	0.3	0.0	1	1	1
07/23/2021 14:00	0.0	11.8	2,144.2	0.2	0.0	1	1	1
07/23/2021 15:00	0.0	11.8	2,147.1	0.0	0.0	1	1	1
07/23/2021 16:00	0.0	11.8	2,147.4	0.0	0.0	1	1	1
07/23/2021 17:00	0.0	11.8	2,150.6	0.0	0.0	1	1	1
07/23/2021 18:00	0.0	11.8	2,149.6	0.0	0.0	1	1	1
07/23/2021 19:00	0.0	11.8	2,150.1	0.0	0.0	1	1	1
07/23/2021 20:00	0.0	11.9	2,142.8	0.0	0.0	1	1	1
07/23/2021 21:00	0.3	12.1	2,098.2	0.1	0.9	1	1	1
07/23/2021 22:00	0.7	12.4	2,041.0	0.2	2.2	1	1	1
07/23/2021 23:00	0.8	12.4	2,037.4	0.4	2.5	1	1	1
Average/Sum#:	0.2	12.9	1,905.4	0.2	18.7 #	24 #	24 #	16 #
Minimum:	0.0	11.8	1,610.7	0.0	0.0	1	1	0
Maximum:	1.6	13.9	2,150.6	0.7	5.1	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/24/2021 00:00	0.8	12.5	2,024.5	0.6	2.5	1	1	1
07/24/2021 01:00	1.8	12.9	1,904.0	0.8	5.7	1	1	1
07/24/2021 02:00	0.0	13.9	1,628.7	0.6	0.0	1	1	0
07/24/2021 03:00	0.0	13.9	1,695.4	0.4	0.0	1	1	1
07/24/2021 04:00	2.0	12.8	1,975.1	0.5	6.4	1	1	1
07/24/2021 05:00	2.2	13.0	1,916.7	1.0	7.0	1	1	1
07/24/2021 06:00	0.0	13.9	1,622.6	1.0	0.0	1	1	0
07/24/2021 07:00	0.0	13.9	1,582.5	0.5	0.0	1	1	0
07/24/2021 08:00	0.0	13.9	1,593.8	0.0	0.0	1	1	0
07/24/2021 09:00	0.0	13.9	1,622.7	0.0	0.0	1	1	0
07/24/2021 10:00	0.0	13.9	1,587.8	0.0	0.0	1	1	0
07/24/2021 11:00	0.0	13.9	1,613.8	0.0	0.0	1	1	1
07/24/2021 12:00	1.7	12.6	1,995.9	0.4	5.4	1	1	1
07/24/2021 13:00	0.6	12.1	2,074.0	0.5	1.9	1	1	1
07/24/2021 14:00	0.6	12.2	2,033.6	0.7	1.9	1	1	1
07/24/2021 15:00	0.0	13.9	1,648.3	0.3	0.0	1	1	0
07/24/2021 16:00	0.0	13.9	1,670.3	0.1	0.0	1	1	1
07/24/2021 17:00	1.5	12.5	1,995.3	0.4	4.7	1	1	1
07/24/2021 18:00	0.4	12.0	2,084.0	0.5	1.2	1	1	1
07/24/2021 19:00	0.0	11.8	2,137.7	0.5	0.0	1	1	1
07/24/2021 20:00	0.0	11.8	2,142.0	0.1	0.0	1	1	1
07/24/2021 21:00	0.2	11.9	2,113.9	0.0	0.6	1	1	1
07/24/2021 22:00	0.5	12.2	2,060.9	0.1	1.6	1	1	1
07/24/2021 23:00	0.4	12.2	2,073.4	0.2	1.3	1	1	1
Average/Sum#:	0.5	13.0	1,866.5	0.4	40.2 #	24 #	24 #	17 #
Minimum:	0.0	11.8	1,582.5	0.0	0.0	1	1	0
Maximum:	2.2	13.9	2,142.0	1.0	7.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/25/2021 00:00	1.4	12.8	1,921.7	0.5	4.4	1	1	1
07/25/2021 01:00	0.0	13.9	1,618.3	0.4	0.0	1	1	0
07/25/2021 02:00	0.0	13.9	1,569.9	0.3	0.0	1	1	1
07/25/2021 03:00	1.0	12.6	1,986.5	0.2	3.2	1	1	1
07/25/2021 04:00	1.3	12.9	1,906.0	0.6	4.1	1	1	1
07/25/2021 05:00	0.0	13.9	1,646.6	0.6	0.0	1	1	0
07/25/2021 06:00	0.0	13.9	1,635.3	0.3	0.0	1	1	0
07/25/2021 07:00	0.0	13.9	1,645.9	0.0	0.0	1	1	0
07/25/2021 08:00	0.0	13.9	1,658.8	0.0	0.0	1	1	0
07/25/2021 09:00	0.0	13.9	1,652.5	0.0	0.0	1	1	0
07/25/2021 10:00	0.0	13.9	1,651.5	0.0	0.0	1	1	0
07/25/2021 11:00	0.0	13.9	1,508.0	0.0	0.0	1	1	1
07/25/2021 12:00	1.2	12.4	2,032.8	0.3	3.8	1	1	1
07/25/2021 13:00	0.5	12.1	2,043.7	0.4	1.5	1	1	1
07/25/2021 14:00	0.0	13.8	1,646.0	0.4	0.0	1	1	0
07/25/2021 15:00	0.0	13.7	1,678.7	0.1	0.0	1	1	0
07/25/2021 16:00	0.0	13.7	1,679.0	0.0	0.0	1	1	1
07/25/2021 17:00	1.0	12.2	2,023.5	0.2	3.1	1	1	1
07/25/2021 18:00	0.1	11.8	2,113.1	0.3	0.3	1	1	1
07/25/2021 19:00	0.2	12.0	2,085.4	0.3	0.6	1	1	1
07/25/2021 20:00	0.4	12.2	2,052.2	0.2	1.2	1	1	1
07/25/2021 21:00	0.6	12.3	2,018.7	0.3	1.9	1	1	1
07/25/2021 22:00	0.7	12.4	2,007.0	0.4	2.2	1	1	1
07/25/2021 23:00	0.6	12.4	2,027.4	0.4	1.9	1	1	1
Average/Sum#:	0.4	13.1	1,825.4	0.3	28.2 #	24 #	24 #	15 #
Minimum:	0.0	11.8	1,508.0	0.0	0.0	1	1	0
Maximum:	1.4	13.9	2,113.1	0.6	4.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/26/2021 00:00	1.7	12.8	1,917.7	0.7	5.3	1	1	1
07/26/2021 01:00	0.0	13.9	1,586.0	0.5	0.0	1	1	0
07/26/2021 02:00	0.0	13.9	1,608.8	0.4	0.0	1	1	1
07/26/2021 03:00	0.9	12.7	1,972.0	0.2	2.9	1	1	1
07/26/2021 04:00	0.5	12.5	1,993.3	0.3	1.6	1	1	1
07/26/2021 05:00	0.0	13.8	1,659.8	0.3	0.0	1	1	1
07/26/2021 06:00	0.0	13.9	1,587.1	0.1	0.0	1	1	0
07/26/2021 07:00	0.0	13.9	1,504.7	0.0	0.0	1	1	0
07/26/2021 08:00	0.0	13.9	1,650.7	0.0	0.0	1	1	0
07/26/2021 09:00	0.0	13.9	1,533.4	0.0	0.0	1	1	0
07/26/2021 10:00	0.0	13.8	1,642.4	0.0	0.0	1	1	1
07/26/2021 11:00	1.7	12.6	2,000.8	0.4	5.4	1	1	1
07/26/2021 12:00	0.3	11.9	2,121.8	0.5	0.9	1	1	1
07/26/2021 13:00	0.2	12.0	2,119.2	0.5	0.6	1	1	1
07/26/2021 14:00	0.3	12.1	2,095.6	0.2	0.9	1	1	1
07/26/2021 15:00	0.1	11.8	2,140.9	0.1	0.3	1	1	1
07/26/2021 16:00	0.1	11.8	2,142.0	0.1	0.3	1	1	1
07/26/2021 17:00	0.2	11.9	2,124.4	0.1	0.6	1	1	1
07/26/2021 18:00	0.1	11.9	2,127.0	0.1	0.3	1	1	1
07/26/2021 19:00	0.2	11.9	2,126.3	0.1	0.6	1	1	1
07/26/2021 20:00	0.3	11.9	2,126.3	0.1	0.9	1	1	1
07/26/2021 21:00	0.2	11.9	2,152.1	0.1	0.6	1	1	1
07/26/2021 22:00	0.4	12.1	2,105.2	0.2	1.3	1	1	1
07/26/2021 23:00	1.2	12.6	1,976.6	0.4	3.8	1	1	1
Average/Sum#:	0.4	12.7	1,917.3	0.2	26.3 #	24 #	24 #	19 #
Minimum:	0.0	11.8	1,504.7	0.0	0.0	1	1	0
Maximum:	1.7	13.9	2,152.1	0.7	5.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/27/2021 00:00	0.0	13.9	1,591.4	0.4	0.0	1	1	0
07/27/2021 01:00	0.0	13.9	1,659.8	0.3	0.0	1	1	1
07/27/2021 02:00	3.2	13.0	1,912.0	0.8	10.2	1	1	1
07/27/2021 03:00	3.1	13.0	1,884.5	1.6	9.8	1	1	1
07/27/2021 04:00	0.0	13.9	1,614.5	1.6	0.0	1	1	0
07/27/2021 05:00	0.0	13.9	1,696.3	0.8	0.0	1	1	1
07/27/2021 06:00	1.8	12.7	1,994.8	0.4	5.8	1	1	1
07/27/2021 07:00	2.0	12.9	1,934.5	0.9	6.4	1	1	1
07/27/2021 08:00	0.0	13.9	1,639.3	0.9	0.0	1	1	0
07/27/2021 09:00	0.0	13.9	1,653.7	0.5	0.0	1	1	0
07/27/2021 10:00	0.0	13.9	1,657.0	0.0	0.0	1	1	0
07/27/2021 11:00	0.0	13.9	1,668.3	0.0	0.0	1	1	0
07/27/2021 12:00	1.6	12.6	2,016.6	0.4	5.1	1	1	1
07/27/2021 13:00	0.4	12.0	2,135.2	0.5	1.3	1	1	1
07/27/2021 14:00	0.3	12.1	2,134.1	0.5	1.0	1	1	1
07/27/2021 15:00	0.3	12.1	2,129.9	0.2	1.0	1	1	1
07/27/2021 16:00	0.4	12.2	2,097.5	0.2	1.3	1	1	1
07/27/2021 17:00	0.3	12.0	2,133.9	0.2	0.9	1	1	1
07/27/2021 18:00	0.2	12.0	2,143.9	0.2	0.6	1	1	1
07/27/2021 19:00	0.3	12.0	2,146.6	0.2	1.0	1	1	1
07/27/2021 20:00	0.3	12.0	2,147.9	0.2	1.0	1	1	1
07/27/2021 21:00	0.3	12.0	2,146.4	0.2	1.0	1	1	1
07/27/2021 22:00	0.3	12.1	2,128.4	0.2	1.0	1	1	1
07/27/2021 23:00	0.4	12.2	2,119.7	0.2	1.3	1	1	1
Average/Sum#:	0.6	12.8	1,932.8	0.5	48.7 #	24 #	24 #	18 #
Minimum:	0.0	12.0	1,591.4	0.0	0.0	1	1	0
Maximum:	3.2	13.9	2,147.9	1.6	10.2	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/28/2021 00:00	0.5	12.3	2,084.0	0.3	1.6	1	1	1
07/28/2021 01:00	2.1	13.0	1,910.8	0.7	6.7	1	1	1
07/28/2021 02:00	0.0	13.9	1,648.8	0.6	0.0	1	1	0
07/28/2021 03:00	0.0	13.9	1,638.9	0.5	0.0	1	1	1
07/28/2021 04:00	1.6	12.7	2,001.1	0.4	5.2	1	1	1
07/28/2021 05:00	0.3	12.2	2,119.3	0.5	1.0	1	1	1
07/28/2021 06:00	0.8	12.4	2,051.9	0.7	2.6	1	1	1
07/28/2021 07:00	0.0	13.9	1,625.2	0.3	0.0	1	1	0
07/28/2021 08:00	0.0	13.9	1,665.1	0.2	0.0	1	1	1
07/28/2021 09:00	0.9	12.3	2,042.5	0.2	2.8	1	1	1
07/28/2021 10:00	0.1	11.8	2,134.9	0.2	0.3	1	1	1
07/28/2021 11:00	0.0	11.8	2,139.3	0.2	0.0	1	1	1
07/28/2021 12:00	0.0	11.8	2,134.6	0.0	0.0	1	1	1
07/28/2021 13:00	0.0	11.8	2,138.0	0.0	0.0	1	1	1
07/28/2021 14:00	0.0	11.8	2,136.4	0.0	0.0	1	1	1
07/28/2021 15:00	0.0	11.8	2,121.5	0.0	0.0	1	1	1
07/28/2021 16:00	0.0	11.8	2,129.0	0.0	0.0	1	1	1
07/28/2021 17:00	0.0	11.8	2,125.0	0.0	0.0	1	1	1
07/28/2021 18:00	0.0	11.8	2,114.1	0.0	0.0	1	1	1
07/28/2021 19:00	0.1	11.9	2,096.7	0.0	0.3	1	1	1
07/28/2021 20:00	0.2	12.0	2,082.4	0.1	0.6	1	1	1
07/28/2021 21:00	0.0	11.8	2,131.3	0.1	0.0	1	1	1
07/28/2021 22:00	0.1	12.0	2,109.8	0.1	0.3	1	1	1
07/28/2021 23:00	0.2	11.9	2,120.6	0.1	0.6	1	1	1
Average/Sum#:	0.3	12.3	2,020.9	0.2	22.0 #	24 #	24 #	22 #
Minimum:	0.0	11.8	1,625.2	0.0	0.0	1	1	0
Maximum:	2.1	13.9	2,139.3	0.7	6.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/29/2021 00:00	0.1	11.8	2,147.7	0.1	0.3	1	1	1
07/29/2021 01:00	0.2	11.9	2,121.2	0.1	0.6	1	1	1
07/29/2021 02:00	0.2	13.6	1,583.8	0.1	0.6	1	1	1
07/29/2021 03:00	0.0	13.9	1,688.6	0.1	0.0	1	1	1
07/29/2021 04:00	1.3	12.6	2,008.6	0.4	4.2	1	1	1
07/29/2021 05:00	0.3	12.1	2,117.5	0.4	1.0	1	1	1
07/29/2021 06:00	0.8	12.5	2,026.8	0.6	2.5	1	1	1
07/29/2021 07:00	0.0	13.9	1,617.3	0.3	0.0	1	1	0
07/29/2021 08:00	0.0	13.8	1,645.9	0.2	0.0	1	1	1
07/29/2021 09:00	1.7	12.6	1,965.2	0.4	5.3	1	1	1
07/29/2021 10:00	0.1	11.8	2,131.6	0.4	0.3	1	1	1
07/29/2021 11:00	0.0	11.8	2,132.3	0.4	0.0	1	1	1
07/29/2021 12:00	0.0	11.8	2,130.5	0.0	0.0	1	1	1
07/29/2021 13:00	0.0	11.7	2,127.4	0.0	0.0	1	1	1
07/29/2021 14:00	0.0	11.7	2,117.5	0.0	0.0	1	1	1
07/29/2021 15:00	0.0	11.7	2,110.6	0.0	0.0	1	1	1
07/29/2021 16:00	0.0	11.7	2,107.1	0.0	0.0	1	1	1
07/29/2021 17:00	0.0	11.7	2,109.8	0.0	0.0	1	1	1
07/29/2021 18:00	0.0	11.7	2,110.3	0.0	0.0	1	1	1
07/29/2021 19:00	0.0	11.7	2,112.1	0.0	0.0	1	1	1
07/29/2021 20:00	0.1	11.8	2,102.6	0.0	0.3	1	1	1
07/29/2021 21:00	0.0	11.8	2,119.3	0.0	0.0	1	1	1
07/29/2021 22:00	0.1	11.9	2,117.9	0.1	0.3	1	1	1
07/29/2021 23:00	0.1	11.9	2,112.8	0.1	0.3	1	1	1
Average/Sum#:	0.2	12.2	2,023.5	0.2	15.7 #	24 #	24 #	23 #
Minimum:	0.0	11.7	1,583.8	0.0	0.0	1	1	0
Maximum:	1.7	13.9	2,147.7	0.6	5.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/30/2021 00:00	0.2	12.0	2,101.0	0.1	0.6	1	1	1
07/30/2021 01:00	0.5	12.2	2,044.9	0.2	1.6	1	1	1
07/30/2021 02:00	0.1	13.8	1,657.9	0.2	0.3	1	1	1
07/30/2021 03:00	0.0	13.8	1,698.6	0.1	0.0	1	1	1
07/30/2021 04:00	1.0	12.4	2,027.8	0.3	3.2	1	1	1
07/30/2021 05:00	0.1	11.9	2,145.3	0.3	0.3	1	1	1
07/30/2021 06:00	0.2	11.9	2,127.9	0.3	0.6	1	1	1
07/30/2021 07:00	0.1	11.9	2,135.8	0.1	0.3	1	1	1
07/30/2021 08:00	0.1	11.9	2,119.7	0.1	0.3	1	1	1
07/30/2021 09:00	0.0	11.8	2,141.0	0.1	0.0	1	1	1
07/30/2021 10:00	0.0	11.8	2,137.2	0.0	0.0	1	1	1
07/30/2021 11:00	0.0	11.7	2,143.6	0.0	0.0	1	1	1
07/30/2021 12:00	0.0	11.7	2,141.3	0.0	0.0	1	1	1
07/30/2021 13:00	0.0	11.6	2,136.5	0.0	0.0	1	1	1
07/30/2021 14:00	0.0	11.6	2,129.0	0.0	0.0	1	1	1
07/30/2021 15:00	0.0	11.7	2,124.5	0.0	0.0	1	1	1
07/30/2021 16:00	0.0	11.7	2,120.2	0.0	0.0	1	1	1
07/30/2021 17:00	0.0	11.7	2,118.8	0.0	0.0	1	1	1
07/30/2021 18:00	0.0	11.7	2,117.4	0.0	0.0	1	1	1
07/30/2021 19:00	0.0	11.6	2,130.8	0.0	0.0	1	1	1
07/30/2021 20:00	0.0	11.6	2,138.7	0.0	0.0	1	1	1
07/30/2021 21:00	0.0	11.7	2,127.4	0.0	0.0	1	1	1
07/30/2021 22:00	0.0	11.7	2,133.5	0.0	0.0	1	1	1
07/30/2021 23:00	0.0	11.7	2,145.3	0.0	0.0	1	1	1
Average/Sum#:	0.1	12.0	2,085.2	0.1	7.2 #	24 #	24 #	24 #
Minimum:	0.0	11.6	1,657.9	0.0	0.0	1	1	1
Maximum:	1.0	13.8	2,145.3	0.3	3.2	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/31/2021 00:00	0.0	11.7	2,171.5	0.0	0.0	1	1	1
07/31/2021 01:00	0.0	11.8	2,167.1	0.0	0.0	1	1	1
07/31/2021 02:00	0.1	12.0	2,135.1	0.0	0.3	1	1	1
07/31/2021 03:00	0.1	13.6	1,662.2	0.1	0.3	1	1	1
07/31/2021 04:00	0.0	13.7	1,738.8	0.1	0.0	1	1	0
07/31/2021 05:00	1.6	13.1	1,885.5	0.4	5.1	1	1	1
07/31/2021 06:00	0.7	12.4	2,050.9	0.6	2.2	1	1	1
07/31/2021 07:00	0.0	13.9	1,653.5	0.6	0.0	1	1	0
07/31/2021 08:00	0.0	13.9	1,556.8	0.2	0.0	1	1	1
07/31/2021 09:00	1.5	12.6	1,991.9	0.4	4.8	1	1	1
07/31/2021 10:00	0.6	12.3	2,042.1	0.5	1.9	1	1	1
07/31/2021 11:00	0.5	12.3	2,052.9	0.6	1.6	1	1	1
07/31/2021 12:00	0.5	12.2	2,063.6	0.3	1.6	1	1	1
07/31/2021 13:00	0.5	12.2	2,055.3	0.3	1.6	1	1	1
07/31/2021 14:00	0.5	12.2	2,059.5	0.3	1.6	1	1	1
07/31/2021 15:00	0.4	12.1	2,067.7	0.3	1.2	1	1	1
07/31/2021 16:00	0.3	12.0	2,071.5	0.3	0.9	1	1	1
07/31/2021 17:00	0.2	11.9	2,101.0	0.2	0.6	1	1	1
07/31/2021 18:00	0.1	11.9	2,120.4	0.1	0.3	1	1	1
07/31/2021 19:00	0.1	11.9	2,113.7	0.1	0.3	1	1	1
07/31/2021 20:00	0.0	11.8	2,148.5	0.1	0.0	1	1	1
07/31/2021 21:00	0.1	11.9	2,139.0	0.1	0.3	1	1	1
07/31/2021 22:00	0.2	12.0	2,113.7	0.1	0.6	1	1	1
07/31/2021 23:00	0.5	12.3	2,057.7	0.2	1.6	1	1	1
Average/Sum#:	0.4	12.4	2,009.2	0.2	26.8 #	24 #	24 #	22 #
Minimum:	0.0	11.7	1,556.8	0.0	0.0	1	1	0
Maximum:	1.6	13.9	2,171.5	0.6	5.1	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/01/2021 00:00	1.7	12.8	1,926.0	0.5	5.3	1	1	1
08/01/2021 01:00	0.0	13.9	1,622.4	0.5	0.0	1	1	0
08/01/2021 02:00	0.0	13.8	1,665.8	0.4	0.0	1	1	1
08/01/2021 03:00	1.5	12.7	1,987.6	0.4	4.8	1	1	1
08/01/2021 04:00	1.4	12.8	1,950.4	0.7	4.5	1	1	1
08/01/2021 05:00	0.0	13.9	1,652.6	0.7	0.0	1	1	0
08/01/2021 06:00	0.0	13.9	1,602.6	0.3	0.0	1	1	0
08/01/2021 07:00	0.0	13.9	1,593.7	0.0	0.0	1	1	0
08/01/2021 08:00	0.0	13.9	1,393.0	0.0	0.0	1	1	0
08/01/2021 09:00	0.0	13.9	1,539.5	0.0	0.0	1	1	1
08/01/2021 10:00	1.6	12.6	2,000.8	0.4	5.1	1	1	1
08/01/2021 11:00	1.2	12.6	1,965.6	0.7	3.8	1	1	1
08/01/2021 12:00	0.0	13.9	1,598.3	0.7	0.0	1	1	0
08/01/2021 13:00	0.0	13.8	1,643.0	0.3	0.0	1	1	0
08/01/2021 14:00	0.0	13.8	1,654.7	0.0	0.0	1	1	0
08/01/2021 15:00	0.0	13.8	1,673.6	0.0	0.0	1	1	0
08/01/2021 16:00	0.9	13.2	1,782.2	0.2	2.8	1	1	1
08/01/2021 17:00	0.1	11.8	2,137.7	0.3	0.3	1	1	1
08/01/2021 18:00	0.0	11.7	2,170.2	0.3	0.0	1	1	1
08/01/2021 19:00	0.0	11.8	2,161.9	0.0	0.0	1	1	1
08/01/2021 20:00	0.0	11.7	2,178.7	0.0	0.0	1	1	1
08/01/2021 21:00	0.0	11.7	2,185.4	0.0	0.0	1	1	1
08/01/2021 22:00	0.0	11.8	2,171.6	0.0	0.0	1	1	1
08/01/2021 23:00	0.1	11.9	2,148.3	0.0	0.3	1	1	1
Average/Sum#:	0.4	13.0	1,850.2	0.3	26.9 #	24 #	24 #	15 #
Minimum:	0.0	11.7	1,393.0	0.0	0.0	1	1	0
Maximum:	1.7	13.9	2,185.4	0.7	5.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/02/2021 00:00	0.0	11.9	2,165.2	0.0	0.0	1	1	1
08/02/2021 01:00	0.2	12.1	2,135.9	0.1	0.6	1	1	1
08/02/2021 02:00	0.2	13.7	1,624.9	0.1	0.6	1	1	1
08/02/2021 03:00	0.0	13.8	1,665.0	0.1	0.0	1	1	1
08/02/2021 04:00	1.2	12.6	2,031.6	0.4	3.9	1	1	1
08/02/2021 05:00	0.2	12.0	2,170.4	0.3	0.6	1	1	1
08/02/2021 06:00	0.5	12.4	2,104.8	0.4	1.6	1	1	1
08/02/2021 07:00	0.2	13.6	1,666.9	0.2	0.6	1	1	1
08/02/2021 08:00	0.0	13.8	1,570.7	0.2	0.0	1	1	0
08/02/2021 09:00	1.4	12.7	2,013.4	0.4	4.5	1	1	1
08/02/2021 10:00	0.3	12.1	2,112.0	0.4	1.0	1	1	1
08/02/2021 11:00	0.1	12.0	2,126.2	0.4	0.3	1	1	1
08/02/2021 12:00	0.2	12.1	2,111.3	0.1	0.6	1	1	1
08/02/2021 13:00	0.3	12.1	2,109.2	0.1	0.9	1	1	1
08/02/2021 14:00	0.3	12.1	2,102.4	0.2	0.9	1	1	1
08/02/2021 15:00	0.3	12.1	2,100.4	0.2	0.9	1	1	1
08/02/2021 16:00	0.3	12.1	2,100.3	0.2	0.9	1	1	1
08/02/2021 17:00	0.2	12.0	2,115.4	0.2	0.6	1	1	1
08/02/2021 18:00	0.0	11.8	2,163.2	0.1	0.0	1	1	1
08/02/2021 19:00	0.0	11.7	2,174.9	0.0	0.0	1	1	1
08/02/2021 20:00	0.0	11.8	2,182.3	0.0	0.0	1	1	1
08/02/2021 21:00	0.0	11.8	2,187.4	0.0	0.0	1	1	1
08/02/2021 22:00	0.0	11.8	2,189.6	0.0	0.0	1	1	1
08/02/2021 23:00	0.0	11.8	2,192.8	0.0	0.0	1	1	1
Average/Sum#:	0.2	12.3	2,046.5	0.2	18.5 #	24 #	24 #	23 #
Minimum:	0.0	11.7	1,570.7	0.0	0.0	1	1	0
Maximum:	1.4	13.8	2,192.8	0.4	4.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/03/2021 00:00	0.1	12.0	2,150.5	0.0	0.3	1	1	1
08/03/2021 01:00	0.1	12.0	2,142.2	0.1	0.3	1	1	1
08/03/2021 02:00	0.1	13.6	1,706.1	0.1	0.3	1	1	1
08/03/2021 03:00	0.0	13.8	1,743.4	0.1	0.0	1	1	1
08/03/2021 04:00	2.6	13.0	1,929.7	0.0	5.7	1	0	1
08/03/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/03/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/03/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/03/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/03/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/03/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/03/2021 11:00	52.2	16.6	578.5	0.0	76.9	1	0	0
08/03/2021 12:00	0.0	14.1	1,305.3	0.0	0.0	1	0	0
08/03/2021 13:00	0.0	13.8	1,681.1	0.0	0.0	1	1	1
08/03/2021 14:00	0.4	12.3	2,042.2	0.0	1.3	1	1	1
08/03/2021 15:00	0.0	12.1	2,097.4	0.1	0.0	1	1	1
08/03/2021 16:00	0.0	12.0	2,102.5	0.1	0.0	1	1	1
08/03/2021 17:00	0.0	12.0	2,114.9	0.0	0.0	1	1	1
08/03/2021 18:00	0.0	11.8	2,157.6	0.0	0.0	1	1	1
08/03/2021 19:00	0.0	11.7	2,165.7	0.0	0.0	1	1	1
08/03/2021 20:00	0.0	11.7	2,174.2	0.0	0.0	1	1	1
08/03/2021 21:00	0.0	11.7	2,172.4	0.0	0.0	1	1	1
08/03/2021 22:00	0.0	11.8	2,167.7	0.0	0.0	1	1	1
08/03/2021 23:00	0.0	11.9	2,151.9	0.0	0.0	1	1	1
Average/Sum#:	3.1	12.7	1,921.3	0.0	84.8 #	18 #	15 #	16 #
Minimum:	0.0	11.7	578.5	0.0	0.0	0	0	0
Maximum:	52.2	16.6	2,174.2	0.1	76.9	1	1	1
%SI	25.00	25.00	25.00	45.83	25.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/04/2021 00:00	0.1	12.4	2,031.1	0.0	0.3	1	1	1
08/04/2021 01:00	0.0	13.9	1,635.9	0.0	0.0	1	1	0
08/04/2021 02:00	0.0	13.7	1,741.2	0.0	0.0	1	1	1
08/04/2021 03:00	1.1	12.7	2,000.0	0.3	3.5	1	1	1
08/04/2021 04:00	0.0	12.0	2,147.6	0.3	0.0	1	1	1
08/04/2021 05:00	0.0	11.9	2,169.2	0.3	0.0	1	1	1
08/04/2021 06:00	0.1	12.4	2,053.5	0.0	0.3	1	1	1
08/04/2021 07:00	1.0	12.8	1,920.2	0.3	3.1	1	1	1
08/04/2021 08:00	0.0	13.9	1,608.0	0.3	0.0	1	1	0
08/04/2021 09:00	0.0	13.8	1,679.0	0.2	0.0	1	1	0
08/04/2021 10:00	0.7	12.6	2,001.1	0.2	2.2	1	1	1
08/04/2021 11:00	0.0	11.9	2,120.9	0.2	0.0	1	1	1
08/04/2021 12:00	0.0	12.0	2,095.2	0.2	0.0	1	1	1
08/04/2021 13:00	0.0	12.0	2,089.5	0.0	0.0	1	1	1
08/04/2021 14:00	0.0	12.0	2,088.2	0.0	0.0	1	1	1
08/04/2021 15:00	0.0	11.9	2,091.3	0.0	0.0	1	1	1
08/04/2021 16:00	0.0	11.8	2,112.6	0.0	0.0	1	1	1
08/04/2021 17:00	0.0	11.8	2,122.7	0.0	0.0	1	1	1
08/04/2021 18:00	0.0	11.8	2,136.8	0.0	0.0	1	1	1
08/04/2021 19:00	0.0	11.7	2,149.2	0.0	0.0	1	1	1
08/04/2021 20:00	0.0	11.7	2,162.6	0.0	0.0	1	1	1
08/04/2021 21:00	0.0	11.7	2,174.4	0.0	0.0	1	1	1
08/04/2021 22:00	0.0	11.8	2,177.9	0.0	0.0	1	1	1
08/04/2021 23:00	0.0	12.1	2,112.1	0.0	0.0	1	1	1
Average/Sum#:	0.1	12.3	2,025.8	0.1	9.4 #	24 #	24 #	21 #
Minimum:	0.0	11.7	1,608.0	0.0	0.0	1	1	0
Maximum:	1.1	13.9	2,177.9	0.3	3.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/05/2021 00:00	0.0	12.2	2,100.7	0.0	0.0	1	1	1
08/05/2021 01:00	0.0	12.2	2,120.0	0.0	0.0	1	1	1
08/05/2021 02:00	0.0	12.2	2,118.7	0.0	0.0	1	1	1
08/05/2021 03:00	0.0	12.0	2,162.2	0.0	0.0	1	1	1
08/05/2021 04:00	0.0	12.0	2,170.9	0.0	0.0	1	1	1
08/05/2021 05:00	0.0	12.0	2,165.4	0.0	0.0	1	1	1
08/05/2021 06:00	0.9	12.8	1,990.6	0.2	2.9	1	1	1
08/05/2021 07:00	0.0	13.9	1,630.9	0.2	0.0	1	1	0
08/05/2021 08:00	0.0	13.9	1,609.8	0.2	0.0	1	1	1
08/05/2021 09:00	1.8	13.0	1,939.5	0.4	5.8	1	1	1
08/05/2021 10:00	0.4	12.5	2,007.0	0.5	1.3	1	1	1
08/05/2021 11:00	0.0	13.8	1,652.7	0.5	0.0	1	1	0
08/05/2021 12:00	0.0	13.8	1,720.3	0.1	0.0	1	1	1
08/05/2021 13:00	0.6	12.5	2,007.3	0.1	1.9	1	1	1
08/05/2021 14:00	0.0	12.3	2,054.8	0.1	0.0	1	1	1
08/05/2021 15:00	0.0	12.2	2,064.2	0.1	0.0	1	1	1
08/05/2021 16:00	0.0	12.1	2,093.1	0.0	0.0	1	1	1
08/05/2021 17:00	0.0	12.2	2,071.3	0.0	0.0	1	1	1
08/05/2021 18:00	0.0	11.9	2,148.0	0.0	0.0	1	1	1
08/05/2021 19:00	0.0	11.8	2,162.0	0.0	0.0	1	1	1
08/05/2021 20:00	0.0	11.7	2,167.7	0.0	0.0	1	1	1
08/05/2021 21:00	0.0	11.9	2,137.4	0.0	0.0	1	1	1
08/05/2021 22:00	0.0	12.1	2,084.5	0.0	0.0	1	1	1
08/05/2021 23:00	0.0	12.3	2,061.4	0.0	0.0	1	1	1
Average/Sum#:	0.2	12.5	2,018.4	0.1	11.9 #	24 #	24 #	22 #
Minimum:	0.0	11.7	1,609.8	0.0	0.0	1	1	0
Maximum:	1.8	13.9	2,170.9	0.5	5.8	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/06/2021 00:00	0.1	12.4	2,006.9	0.0	0.3	1	1	1
08/06/2021 01:00	0.0	13.9	1,655.7	0.0	0.0	1	1	0
08/06/2021 02:00	0.0	13.9	1,650.5	0.0	0.0	1	1	0
08/06/2021 03:00	0.0	13.8	1,596.5	0.0	0.0	1	1	1
08/06/2021 04:00	1.3	12.7	1,985.9	0.3	4.2	1	1	1
08/06/2021 05:00	0.5	12.5	2,005.7	0.4	1.6	1	1	1
08/06/2021 06:00	0.0	13.9	1,572.2	0.4	0.0	1	1	0
08/06/2021 07:00	0.0	13.9	1,638.9	0.1	0.0	1	1	0
08/06/2021 08:00	0.0	13.9	1,634.5	0.0	0.0	1	1	0
08/06/2021 09:00	1.3	12.8	1,960.6	0.3	4.2	1	1	1
08/06/2021 10:00	1.1	12.8	1,933.7	0.6	3.5	1	1	1
08/06/2021 11:00	0.0	13.9	1,630.7	0.6	0.0	1	1	0
08/06/2021 12:00	0.0	14.0	1,504.0	0.3	0.0	1	1	0
08/06/2021 13:00	1.0	12.8	1,960.0	0.2	3.2	1	1	1
08/06/2021 14:00	0.1	12.3	2,050.8	0.3	0.3	1	1	1
08/06/2021 15:00	0.1	12.3	2,039.2	0.3	0.3	1	1	1
08/06/2021 16:00	0.0	12.1	2,083.3	0.1	0.0	1	1	1
08/06/2021 17:00	0.0	12.0	2,094.5	0.0	0.0	1	1	1
08/06/2021 18:00	0.0	11.8	2,140.5	0.0	0.0	1	1	1
08/06/2021 19:00	0.0	12.0	2,093.1	0.0	0.0	1	1	1
08/06/2021 20:00	0.0	12.0	2,087.9	0.0	0.0	1	1	1
08/06/2021 21:00	0.1	12.1	2,063.0	0.0	0.3	1	1	1
08/06/2021 22:00	0.1	12.3	2,027.9	0.1	0.3	1	1	1
08/06/2021 23:00	0.8	12.7	1,916.9	0.3	2.5	1	1	1
Average/Sum#:	0.3	12.9	1,888.9	0.2	20.7 #	24 #	24 #	17 #
Minimum:	0.0	11.8	1,504.0	0.0	0.0	1	1	0
Maximum:	1.3	14.0	2,140.5	0.6	4.2	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/07/2021 00:00	0.0	13.9	1,660.6	0.2	0.0	1	1	0
08/07/2021 01:00	0.0	13.8	1,585.9	0.2	0.0	1	1	1
08/07/2021 02:00	0.7	12.8	1,919.9	0.2	2.2	1	1	1
08/07/2021 03:00	9.6	14.3	1,164.1	0.0	10.8	1	0	1
08/07/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/07/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/07/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/07/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/07/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/07/2021 09:00	9.8	18.7	181.5	0.0	2.4	1	0	0
08/07/2021 10:00	46.4	16.4	552.2	0.0	75.2	1	0	0
08/07/2021 11:00	62.5	15.9	597.4	0.0	44.4	1	0	0
08/07/2021 12:00	38.9	16.0	737.1	0.0	71.9	1	0	0
08/07/2021 13:00	0.0	13.9	1,548.6	0.0	0.0	1	1	0
08/07/2021 14:00	0.0	13.9	1,453.5	0.0	0.0	1	1	0
08/07/2021 15:00	0.0	13.9	1,620.2	0.0	0.0	1	1	0
08/07/2021 16:00	0.0	14.0	1,498.8	0.0	0.0	1	1	1
08/07/2021 17:00	0.6	12.5	1,986.9	0.1	1.9	1	1	1
08/07/2021 18:00	0.1	12.1	2,049.2	0.2	0.3	1	1	1
08/07/2021 19:00	0.1	12.4	1,973.2	0.2	0.3	1	1	1
08/07/2021 20:00	0.0	13.8	1,646.0	0.1	0.0	1	1	0
08/07/2021 21:00	0.0	13.8	1,613.3	0.0	0.0	1	1	1
08/07/2021 22:00	1.6	12.9	1,928.0	0.4	5.1	1	1	1
08/07/2021 23:00	0.2	12.4	2,004.3	0.4	0.6	1	1	1
Average/Sum#:	9.0	14.1	1,459.0	0.2	215.1 #	19 #	14 #	10 #
Minimum:	0.0	12.1	181.5	0.0	0.0	0	0	0
Maximum:	62.5	18.7	2,049.2	0.4	75.2	1	1	1
%SI	20.83	20.83	20.83	50.00	20.83	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/08/2021 00:00	0.0	13.9	1,561.0	0.4	0.0	1	1	0
08/08/2021 01:00	0.0	13.8	1,529.1	0.0	0.0	1	1	1
08/08/2021 02:00	2.1	13.0	1,908.5	0.5	6.7	1	1	1
08/08/2021 03:00	0.3	13.7	1,462.5	0.6	0.8	1	1	1
08/08/2021 04:00	0.0	14.0	1,363.8	0.6	0.0	1	1	0
08/08/2021 05:00	0.0	14.0	1,350.3	0.1	0.0	1	1	0
08/08/2021 06:00	0.0	14.0	1,352.9	0.0	0.0	1	1	0
08/08/2021 07:00	0.0	14.0	1,357.3	0.0	0.0	1	1	0
08/08/2021 08:00	0.0	14.0	1,361.9	0.0	0.0	1	1	0
08/08/2021 09:00	0.0	14.0	1,362.8	0.0	0.0	1	1	0
08/08/2021 10:00	0.0	14.0	1,363.1	0.0	0.0	1	1	0
08/08/2021 11:00	0.0	14.0	1,367.2	0.0	0.0	1	1	0
08/08/2021 12:00	0.0	14.0	1,370.8	0.0	0.0	1	1	0
08/08/2021 13:00	0.0	14.0	1,438.0	0.0	0.0	1	1	0
08/08/2021 14:00	0.0	13.9	1,563.7	0.0	0.0	1	1	0
08/08/2021 15:00	0.0	13.9	1,469.3	0.0	0.0	1	1	0
08/08/2021 16:00	0.0	13.9	1,568.8	0.0	0.0	1	1	0
08/08/2021 17:00	0.4	13.2	1,745.4	0.1	1.2	1	1	1
08/08/2021 18:00	0.0	12.1	2,066.5	0.1	0.0	1	1	1
08/08/2021 19:00	0.0	12.0	2,088.5	0.1	0.0	1	1	1
08/08/2021 20:00	0.0	11.9	2,123.8	0.0	0.0	1	1	1
08/08/2021 21:00	0.0	12.0	2,085.2	0.0	0.0	1	1	1
08/08/2021 22:00	0.1	12.4	2,013.0	0.0	0.3	1	1	1
08/08/2021 23:00	0.9	12.8	1,904.5	0.3	2.8	1	1	1
Average/Sum#:	0.2	13.4	1,615.7	0.1	11.8 #	24 #	24 #	10 #
Minimum:	0.0	11.9	1,350.3	0.0	0.0	1	1	0
Maximum:	2.1	14.0	2,123.8	0.6	6.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/09/2021 00:00	0.0	13.9	1,554.3	0.3	0.0	1	1	0
08/09/2021 01:00	0.0	13.8	1,703.8	0.2	0.0	1	1	1
08/09/2021 02:00	1.1	12.7	1,963.1	0.3	3.5	1	1	1
08/09/2021 03:00	1.4	12.9	1,906.6	0.6	4.4	1	1	1
08/09/2021 04:00	0.0	13.9	1,652.3	0.6	0.0	1	1	0
08/09/2021 05:00	0.0	13.7	1,731.1	0.3	0.0	1	1	1
08/09/2021 06:00	1.4	12.8	1,962.9	0.3	4.5	1	1	1
08/09/2021 07:00	0.7	12.6	1,959.9	0.5	2.2	1	1	1
08/09/2021 08:00	0.0	13.9	1,553.5	0.5	0.0	1	1	0
08/09/2021 09:00	0.0	13.9	1,608.7	0.2	0.0	1	1	0
08/09/2021 10:00	0.0	13.8	1,641.4	0.0	0.0	1	1	0
08/09/2021 11:00	1.1	12.7	1,955.3	0.3	3.5	1	1	1
08/09/2021 12:00	0.0	12.1	2,018.6	0.3	0.0	1	1	1
08/09/2021 13:00	0.0	13.8	1,679.6	0.3	0.0	1	1	0
08/09/2021 14:00	0.3	13.2	1,773.7	0.1	0.9	1	1	1
08/09/2021 15:00	0.0	12.0	2,085.0	0.1	0.0	1	1	1
08/09/2021 16:00	0.0	11.9	2,093.5	0.1	0.0	1	1	1
08/09/2021 17:00	0.0	11.9	2,097.0	0.0	0.0	1	1	1
08/09/2021 18:00	0.0	11.9	2,099.9	0.0	0.0	1	1	1
08/09/2021 19:00	0.0	11.7	2,137.6	0.0	0.0	1	1	1
08/09/2021 20:00	0.0	11.7	2,149.8	0.0	0.0	1	1	1
08/09/2021 21:00	0.0	11.9	2,127.8	0.0	0.0	1	1	1
08/09/2021 22:00	0.0	12.3	2,048.8	0.0	0.0	1	1	1
08/09/2021 23:00	0.0	12.3	2,056.0	0.0	0.0	1	1	1
Average/Sum#:	0.3	12.8	1,898.3	0.2	19.0 #	24 #	24 #	18 #
Minimum:	0.0	11.7	1,553.5	0.0	0.0	1	1	0
Maximum:	1.4	13.9	2,149.8	0.6	4.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/10/2021 00:00	0.5	12.6	1,960.3	0.1	1.6	1	1	1
08/10/2021 01:00	0.0	13.9	1,593.3	0.1	0.0	1	1	0
08/10/2021 02:00	0.0	13.9	1,596.1	0.1	0.0	1	1	0
08/10/2021 03:00	0.0	13.8	1,698.6	0.0	0.0	1	1	1
08/10/2021 04:00	0.9	12.6	2,014.3	0.2	2.9	1	1	1
08/10/2021 05:00	0.3	12.4	2,021.4	0.3	0.9	1	1	1
08/10/2021 06:00	0.0	13.9	1,620.6	0.3	0.0	1	1	0
08/10/2021 07:00	0.0	13.8	1,590.5	0.1	0.0	1	1	1
08/10/2021 08:00	1.1	12.7	1,975.6	0.3	3.5	1	1	1
08/10/2021 09:00	1.0	12.9	1,909.7	0.5	3.2	1	1	1
08/10/2021 10:00	0.0	13.9	1,660.0	0.5	0.0	1	1	0
08/10/2021 11:00	0.0	13.8	1,675.5	0.2	0.0	1	1	1
08/10/2021 12:00	0.9	12.5	2,008.1	0.2	2.8	1	1	1
08/10/2021 13:00	0.0	12.0	2,102.4	0.2	0.0	1	1	1
08/10/2021 14:00	0.0	11.9	2,102.6	0.2	0.0	1	1	1
08/10/2021 15:00	0.0	11.9	2,097.3	0.0	0.0	1	1	1
08/10/2021 16:00	0.0	11.9	2,107.9	0.0	0.0	1	1	1
08/10/2021 17:00	0.0	11.8	2,112.5	0.0	0.0	1	1	1
08/10/2021 18:00	0.0	11.7	2,145.2	0.0	0.0	1	1	1
08/10/2021 19:00	0.0	11.7	2,157.2	0.0	0.0	1	1	1
08/10/2021 20:00	0.0	11.7	2,159.3	0.0	0.0	1	1	1
08/10/2021 21:00	0.0	11.7	2,157.0	0.0	0.0	1	1	1
08/10/2021 22:00	0.0	12.0	2,100.8	0.0	0.0	1	1	1
08/10/2021 23:00	0.0	12.1	2,086.9	0.0	0.0	1	1	1
Average/Sum#:	0.2	12.6	1,943.9	0.1	14.9 #	24 #	24 #	20 #
Minimum:	0.0	11.7	1,590.5	0.0	0.0	1	1	0
Maximum:	1.1	13.9	2,159.3	0.5	3.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/11/2021 00:00	0.1	12.3	2,032.6	0.0	0.3	1	1	1
08/11/2021 01:00	0.0	13.8	1,656.6	0.0	0.0	1	1	0
08/11/2021 02:00	0.0	13.9	1,592.8	0.0	0.0	1	1	0
08/11/2021 03:00	0.0	13.9	1,581.0	0.0	0.0	1	1	0
08/11/2021 04:00	0.0	13.8	1,606.8	0.0	0.0	1	1	1
08/11/2021 05:00	1.1	12.6	2,023.6	0.3	3.5	1	1	1
08/11/2021 06:00	0.4	12.5	2,037.3	0.4	1.3	1	1	1
08/11/2021 07:00	0.0	13.9	1,622.1	0.4	0.0	1	1	0
08/11/2021 08:00	0.0	13.7	1,716.3	0.1	0.0	1	1	1
08/11/2021 09:00	0.8	12.5	2,008.6	0.2	2.5	1	1	1
08/11/2021 10:00	0.0	12.0	2,106.4	0.2	0.0	1	1	1
08/11/2021 11:00	0.0	12.0	2,108.9	0.2	0.0	1	1	1
08/11/2021 12:00	0.0	12.1	2,074.1	0.0	0.0	1	1	1
08/11/2021 13:00	0.0	12.1	2,078.0	0.0	0.0	1	1	1
08/11/2021 14:00	0.0	11.9	2,095.8	0.0	0.0	1	1	1
08/11/2021 15:00	0.1	12.1	2,037.4	0.0	0.3	1	1	1
08/11/2021 16:00	0.0	12.0	2,067.6	0.0	0.0	1	1	1
08/11/2021 17:00	0.0	11.9	2,091.5	0.0	0.0	1	1	1
08/11/2021 18:00	0.0	11.7	2,134.0	0.0	0.0	1	1	1
08/11/2021 19:00	0.0	11.7	2,137.5	0.0	0.0	1	1	1
08/11/2021 20:00	0.0	11.7	2,144.0	0.0	0.0	1	1	1
08/11/2021 21:00	0.0	11.8	2,117.6	0.0	0.0	1	1	1
08/11/2021 22:00	0.0	12.1	2,078.6	0.0	0.0	1	1	1
08/11/2021 23:00	0.0	12.2	2,083.5	0.0	0.0	1	1	1
Average/Sum#:	0.1	12.5	1,968.0	0.1	7.9 #	24 #	24 #	20 #
Minimum:	0.0	11.7	1,581.0	0.0	0.0	1	1	0
Maximum:	1.1	13.9	2,144.0	0.4	3.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/12/2021 00:00	0.2	12.3	2,043.0	0.0	0.6	1	1	1
08/12/2021 01:00	0.0	13.9	1,652.2	0.0	0.0	1	1	0
08/12/2021 02:00	0.0	13.8	1,606.3	0.0	0.0	1	1	1
08/12/2021 03:00	0.3	12.7	1,974.9	0.1	1.0	1	1	1
08/12/2021 04:00	0.4	12.6	1,974.7	0.2	1.3	1	1	1
08/12/2021 05:00	0.0	13.9	1,657.7	0.2	0.0	1	1	0
08/12/2021 06:00	0.0	13.8	1,736.6	0.1	0.0	1	1	1
08/12/2021 07:00	1.1	12.7	1,981.0	0.3	3.5	1	1	1
08/12/2021 08:00	1.0	12.8	1,915.9	0.5	3.1	1	1	1
08/12/2021 09:00	0.0	13.9	1,668.4	0.5	0.0	1	1	0
08/12/2021 10:00	0.0	13.9	1,680.0	0.2	0.0	1	1	1
08/12/2021 11:00	0.6	12.5	2,006.9	0.1	1.9	1	1	1
08/12/2021 12:00	0.0	12.1	2,053.9	0.1	0.0	1	1	1
08/12/2021 13:00	0.0	12.2	2,043.5	0.1	0.0	1	1	1
08/12/2021 14:00	0.0	12.2	2,034.6	0.0	0.0	1	1	1
08/12/2021 15:00	0.0	12.1	2,039.2	0.0	0.0	1	1	1
08/12/2021 16:00	0.0	12.1	2,054.7	0.0	0.0	1	1	1
08/12/2021 17:00	0.0	12.0	2,064.9	0.0	0.0	1	1	1
08/12/2021 18:00	0.0	11.9	2,108.2	0.0	0.0	1	1	1
08/12/2021 19:00	0.0	11.8	2,117.5	0.0	0.0	1	1	1
08/12/2021 20:00	0.0	11.8	2,137.9	0.0	0.0	1	1	1
08/12/2021 21:00	0.0	12.0	2,110.9	0.0	0.0	1	1	1
08/12/2021 22:00	0.0	12.2	2,062.5	0.0	0.0	1	1	1
08/12/2021 23:00	0.0	12.5	2,016.3	0.0	0.0	1	1	1
Average/Sum#:	0.2	12.7	1,947.6	0.1	11.4 #	24 #	24 #	21 #
Minimum:	0.0	11.8	1,606.3	0.0	0.0	1	1	0
Maximum:	1.1	13.9	2,137.9	0.5	3.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/13/2021 00:00	1.1	12.9	1,922.2	0.3	3.5	1	1	1
08/13/2021 01:00	0.2	13.8	1,613.8	0.3	0.6	1	1	1
08/13/2021 02:00	0.0	13.9	1,468.4	0.3	0.0	1	1	1
08/13/2021 03:00	0.8	12.7	1,977.5	0.3	2.5	1	1	1
08/13/2021 04:00	1.6	13.0	1,908.9	0.6	5.1	1	1	1
08/13/2021 05:00	0.0	13.9	1,643.1	0.6	0.0	1	1	0
08/13/2021 06:00	0.0	13.9	1,611.3	0.4	0.0	1	1	0
08/13/2021 07:00	0.0	13.9	1,536.4	0.0	0.0	1	1	1
08/13/2021 08:00	1.4	12.8	1,965.9	0.3	4.5	1	1	1
08/13/2021 09:00	0.8	12.7	1,927.0	0.5	2.5	1	1	1
08/13/2021 10:00	0.0	13.9	1,564.2	0.5	0.0	1	1	0
08/13/2021 11:00	0.0	13.9	1,564.0	0.2	0.0	1	1	1
08/13/2021 12:00	0.7	12.5	1,989.4	0.2	2.2	1	1	1
08/13/2021 13:00	0.1	12.3	2,027.9	0.2	0.3	1	1	1
08/13/2021 14:00	0.0	12.3	2,023.3	0.2	0.0	1	1	1
08/13/2021 15:00	0.0	12.3	2,022.3	0.0	0.0	1	1	1
08/13/2021 16:00	0.0	12.2	2,033.0	0.0	0.0	1	1	1
08/13/2021 17:00	0.0	12.1	2,052.7	0.0	0.0	1	1	1
08/13/2021 18:00	0.0	12.0	2,093.7	0.0	0.0	1	1	1
08/13/2021 19:00	0.0	11.9	2,127.1	0.0	0.0	1	1	1
08/13/2021 20:00	0.0	11.9	2,108.1	0.0	0.0	1	1	1
08/13/2021 21:00	0.0	12.2	2,052.5	0.0	0.0	1	1	1
08/13/2021 22:00	0.0	12.3	2,050.2	0.0	0.0	1	1	1
08/13/2021 23:00	0.0	12.3	2,049.7	0.0	0.0	1	1	1
Average/Sum#:	0.3	12.8	1,888.9	0.2	21.2 #	24 #	24 #	21 #
Minimum:	0.0	11.9	1,468.4	0.0	0.0	1	1	0
Maximum:	1.6	13.9	2,127.1	0.6	5.1	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/14/2021 00:00	0.5	12.6	1,945.9	0.1	1.5	1	1	1
08/14/2021 01:00	0.0	13.9	1,668.4	0.1	0.0	1	1	0
08/14/2021 02:00	0.0	13.8	1,700.9	0.1	0.0	1	1	1
08/14/2021 03:00	0.8	12.6	1,982.9	0.2	2.5	1	1	1
08/14/2021 04:00	1.4	12.8	1,912.3	0.5	4.4	1	1	1
08/14/2021 05:00	0.0	13.9	1,676.1	0.5	0.0	1	1	0
08/14/2021 06:00	0.0	13.9	1,590.6	0.3	0.0	1	1	0
08/14/2021 07:00	0.0	13.9	1,484.1	0.0	0.0	1	1	0
08/14/2021 08:00	0.0	14.0	1,288.9	0.0	0.0	1	1	0
08/14/2021 09:00	0.0	13.9	1,566.6	0.0	0.0	1	1	0
08/14/2021 10:00	0.0	13.9	1,627.9	0.0	0.0	1	1	0
08/14/2021 11:00	0.0	13.9	1,647.0	0.0	0.0	1	1	0
08/14/2021 12:00	0.0	13.8	1,652.4	0.0	0.0	1	1	1
08/14/2021 13:00	0.5	12.4	1,984.1	0.1	1.5	1	1	1
08/14/2021 14:00	0.1	12.1	2,018.7	0.1	0.3	1	1	1
08/14/2021 15:00	0.0	13.9	1,558.2	0.1	0.0	1	1	0
08/14/2021 16:00	0.0	13.9	1,485.5	0.0	0.0	1	1	1
08/14/2021 17:00	0.2	12.2	2,011.9	0.0	0.6	1	1	1
08/14/2021 18:00	0.0	11.7	2,110.5	0.0	0.0	1	1	1
08/14/2021 19:00	0.0	11.6	2,129.1	0.0	0.0	1	1	1
08/14/2021 20:00	0.0	11.8	2,125.8	0.0	0.0	1	1	1
08/14/2021 21:00	0.0	11.9	2,104.4	0.0	0.0	1	1	1
08/14/2021 22:00	0.0	12.1	2,071.9	0.0	0.0	1	1	1
08/14/2021 23:00	0.0	12.3	2,041.4	0.0	0.0	1	1	1
Average/Sum#:	0.1	13.0	1,807.7	0.1	10.8 #	24 #	24 #	15 #
Minimum:	0.0	11.6	1,288.9	0.0	0.0	1	1	0
Maximum:	1.4	14.0	2,129.1	0.5	4.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/15/2021 00:00	0.9	12.8	1,927.5	0.2	2.8	1	1	1
08/15/2021 01:00	0.0	13.9	1,665.2	0.2	0.0	1	1	0
08/15/2021 02:00	0.0	13.8	1,607.7	0.2	0.0	1	1	1
08/15/2021 03:00	0.7	12.6	1,987.6	0.2	2.2	1	1	1
08/15/2021 04:00	1.3	12.8	1,910.4	0.5	4.0	1	1	1
08/15/2021 05:00	0.0	13.9	1,645.3	0.5	0.0	1	1	0
08/15/2021 06:00	0.0	13.9	1,566.2	0.3	0.0	1	1	0
08/15/2021 07:00	0.0	13.9	1,641.8	0.0	0.0	1	1	0
08/15/2021 08:00	0.0	13.9	1,477.4	0.0	0.0	1	1	0
08/15/2021 09:00	0.0	13.8	1,599.7	0.0	0.0	1	1	0
08/15/2021 10:00	0.0	13.8	1,656.6	0.0	0.0	1	1	0
08/15/2021 11:00	0.0	13.9	1,483.4	0.0	0.0	1	1	0
08/15/2021 12:00	0.1	13.2	1,707.6	0.0	0.3	1	1	1
08/15/2021 13:00	0.1	12.1	2,010.2	0.1	0.3	1	1	1
08/15/2021 14:00	0.0	13.8	1,606.3	0.1	0.0	1	1	0
08/15/2021 15:00	0.0	13.8	1,614.9	0.0	0.0	1	1	1
08/15/2021 16:00	0.3	12.2	2,002.4	0.1	0.9	1	1	1
08/15/2021 17:00	0.0	11.8	2,052.0	0.1	0.0	1	1	1
08/15/2021 18:00	0.0	11.8	2,091.8	0.1	0.0	1	1	1
08/15/2021 19:00	0.0	11.9	2,082.9	0.0	0.0	1	1	1
08/15/2021 20:00	0.0	12.0	2,073.1	0.0	0.0	1	1	1
08/15/2021 21:00	0.0	12.0	2,071.7	0.0	0.0	1	1	1
08/15/2021 22:00	0.0	12.1	2,051.9	0.0	0.0	1	1	1
08/15/2021 23:00	0.0	12.2	2,044.9	0.0	0.0	1	1	1
Average/Sum#:	0.1	13.0	1,815.8	0.1	10.5 #	24 #	24 #	15 #
Minimum:	0.0	11.8	1,477.4	0.0	0.0	1	1	0
Maximum:	1.3	13.9	2,091.8	0.5	4.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/16/2021 00:00	0.5	12.6	1,929.8	0.1	1.5	1	1	1
08/16/2021 01:00	0.0	13.9	1,664.6	0.1	0.0	1	1	0
08/16/2021 02:00	0.0	13.8	1,497.9	0.1	0.0	1	1	1
08/16/2021 03:00	1.0	12.6	1,958.8	0.2	3.1	1	1	1
08/16/2021 04:00	0.9	12.7	1,930.8	0.4	2.8	1	1	1
08/16/2021 05:00	0.0	13.8	1,667.6	0.4	0.0	1	1	1
08/16/2021 06:00	0.0	13.8	1,697.9	0.2	0.0	1	1	1
08/16/2021 07:00	0.7	12.6	1,947.8	0.2	2.2	1	1	1
08/16/2021 08:00	0.3	12.4	1,963.8	0.2	0.9	1	1	1
08/16/2021 09:00	0.0	13.8	1,650.0	0.2	0.0	1	1	0
08/16/2021 10:00	0.0	13.8	1,591.7	0.1	0.0	1	1	1
08/16/2021 11:00	0.5	12.3	2,001.3	0.1	1.5	1	1	1
08/16/2021 12:00	0.1	12.0	2,042.6	0.1	0.3	1	1	1
08/16/2021 13:00	0.1	12.0	2,036.5	0.2	0.3	1	1	1
08/16/2021 14:00	0.1	12.2	2,001.7	0.1	0.3	1	1	1
08/16/2021 15:00	0.0	11.9	2,060.3	0.1	0.0	1	1	1
08/16/2021 16:00	0.0	11.8	2,074.6	0.0	0.0	1	1	1
08/16/2021 17:00	0.0	11.6	2,100.2	0.0	0.0	1	1	1
08/16/2021 18:00	0.0	11.6	2,123.0	0.0	0.0	1	1	1
08/16/2021 19:00	0.0	11.7	2,119.4	0.0	0.0	1	1	1
08/16/2021 20:00	0.0	11.8	2,101.6	0.0	0.0	1	1	1
08/16/2021 21:00	0.0	11.8	2,110.5	0.0	0.0	1	1	1
08/16/2021 22:00	0.0	12.1	2,061.4	0.0	0.0	1	1	1
08/16/2021 23:00	0.0	12.2	2,063.7	0.0	0.0	1	1	1
Average/Sum#:	0.2	12.5	1,933.2	0.1	12.9 #	24 #	24 #	22 #
Minimum:	0.0	11.6	1,497.9	0.0	0.0	1	1	0
Maximum:	1.0	13.9	2,123.0	0.4	3.1	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/17/2021 00:00	0.1	12.4	2,026.8	0.0	0.3	1	1	1
08/17/2021 01:00	0.0	13.8	1,646.4	0.0	0.0	1	1	1
08/17/2021 02:00	0.0	13.8	1,603.5	0.0	0.0	1	1	1
08/17/2021 03:00	0.5	12.5	2,015.4	0.1	1.6	1	1	1
08/17/2021 04:00	0.0	12.1	2,089.8	0.1	0.0	1	1	1
08/17/2021 05:00	0.0	12.0	2,133.1	0.1	0.0	1	1	1
08/17/2021 06:00	0.2	12.4	2,034.7	0.0	0.6	1	1	1
08/17/2021 07:00	0.0	13.9	1,623.8	0.0	0.0	1	1	0
08/17/2021 08:00	0.0	13.9	1,571.2	0.0	0.0	1	1	1
08/17/2021 09:00	0.7	12.7	1,977.1	0.2	2.2	1	1	1
08/17/2021 10:00	0.8	12.8	1,906.1	0.4	2.5	1	1	1
08/17/2021 11:00	0.0	13.9	1,620.7	0.4	0.0	1	1	0
08/17/2021 12:00	0.0	13.9	1,450.2	0.2	0.0	1	1	0
08/17/2021 13:00	0.0	13.8	1,699.1	0.0	0.0	1	1	0
08/17/2021 14:00	0.5	13.3	1,774.5	0.1	1.5	1	1	1
08/17/2021 15:00	0.6	13.1	1,799.3	0.3	1.8	1	1	1
08/17/2021 16:00	0.0	13.9	1,524.8	0.3	0.0	1	1	1
08/17/2021 17:00	0.6	12.5	1,990.6	0.3	1.9	1	1	1
08/17/2021 18:00	0.0	12.0	2,089.3	0.1	0.0	1	1	1
08/17/2021 19:00	0.0	11.8	2,131.2	0.1	0.0	1	1	1
08/17/2021 20:00	0.0	11.7	2,146.4	0.0	0.0	1	1	1
08/17/2021 21:00	0.0	11.9	2,122.8	0.0	0.0	1	1	1
08/17/2021 22:00	0.0	12.2	2,084.1	0.0	0.0	1	1	1
08/17/2021 23:00	0.7	12.8	1,958.0	0.2	2.2	1	1	1
Average/Sum#:	0.2	12.9	1,875.8	0.1	14.6 #	24 #	24 #	20 #
Minimum:	0.0	11.7	1,450.2	0.0	0.0	1	1	0
Maximum:	0.8	13.9	2,146.4	0.4	2.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/18/2021 00:00	0.0	13.9	1,608.1	0.2	0.0	1	1	0
08/18/2021 01:00	0.0	14.0	1,524.6	0.2	0.0	1	1	1
08/18/2021 02:00	1.0	13.1	1,927.7	0.3	3.3	1	1	1
08/18/2021 03:00	1.2	13.1	1,902.0	0.6	3.9	1	1	1
08/18/2021 04:00	0.0	13.9	1,675.3	0.6	0.0	1	1	0
08/18/2021 05:00	0.0	13.8	1,654.9	0.3	0.0	1	1	1
08/18/2021 06:00	1.3	12.9	1,962.3	0.3	4.2	1	1	1
08/18/2021 07:00	1.3	13.0	1,920.8	0.7	4.2	1	1	1
08/18/2021 08:00	0.0	13.9	1,432.2	0.7	0.0	1	1	0
08/18/2021 09:00	0.0	14.0	1,536.3	0.3	0.0	1	1	0
08/18/2021 10:00	0.0	0.0	1,508.6	0.0	0.0	1	1	0
08/18/2021 11:00	0.0	14.1	1,452.4	0.0	0.0	1	1	0
08/18/2021 12:00	0.0	14.0	1,490.1	0.0	0.0	1	1	1
08/18/2021 13:00	0.7	12.7	2,029.5	0.2	2.3	1	1	1
08/18/2021 14:00	0.2	12.4	2,009.0	0.2	0.6	1	1	1
08/18/2021 15:00	0.0	13.9	1,651.4	0.2	0.0	1	1	0
08/18/2021 16:00	0.0	14.0	1,505.5	0.0	0.0	1	1	0
08/18/2021 17:00	0.5	12.7	1,969.6	0.1	1.6	1	1	1
08/18/2021 18:00	0.0	12.2	2,095.5	0.1	0.0	1	1	1
08/18/2021 19:00	0.4	12.7	1,957.0	0.2	1.3	1	1	1
08/18/2021 20:00	0.0	13.9	1,680.5	0.1	0.0	1	1	0
08/18/2021 21:00	0.0	13.8	1,694.8	0.1	0.0	1	1	1
08/18/2021 22:00	0.7	12.7	1,997.6	0.2	2.3	1	1	1
08/18/2021 23:00	1.3	13.0	1,903.8	0.5	4.1	1	1	1
Average/Sum#:	0.4	13.4	1,753.7	0.3	27.8 #	24 #	24 #	15 #
Minimum:	0.0	12.2	1,432.2	0.0	0.0	1	1	0
Maximum:	1.3	14.1	2,095.5	0.7	4.2	1	1	1
%SI	4.17	4.17	0.00	12.50	4.17	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/19/2021 00:00	0.0	13.9	1,585.9	0.5	0.0	1	1	0
08/19/2021 01:00	0.0	13.9	1,619.0	0.3	0.0	1	1	0
08/19/2021 02:00	0.0	13.9	1,486.9	0.0	0.0	1	1	0
08/19/2021 03:00	0.0	13.9	1,515.6	0.0	0.0	1	1	1
08/19/2021 04:00	0.7	12.7	1,996.4	0.2	2.3	1	1	1
08/19/2021 05:00	1.1	12.9	1,921.8	0.4	3.5	1	1	1
08/19/2021 06:00	0.0	13.9	1,628.2	0.4	0.0	1	1	0
08/19/2021 07:00	0.0	13.9	1,657.6	0.3	0.0	1	1	0
08/19/2021 08:00	0.0	14.0	1,342.2	0.0	0.0	1	1	0
08/19/2021 09:00	0.0	13.9	1,639.0	0.0	0.0	1	1	0
08/19/2021 10:00	0.0	14.0	1,614.0	0.0	0.0	1	1	0
08/19/2021 11:00	0.0	14.0	1,581.0	0.0	0.0	1	1	0
08/19/2021 12:00	0.0	13.9	1,665.7	0.0	0.0	1	1	1
08/19/2021 13:00	0.6	12.4	2,030.3	0.1	1.9	1	1	1
08/19/2021 14:00	0.3	12.5	1,978.7	0.2	0.9	1	1	1
08/19/2021 15:00	0.0	13.9	1,545.6	0.2	0.0	1	1	0
08/19/2021 16:00	0.0	13.8	1,637.8	0.1	0.0	1	1	1
08/19/2021 17:00	0.6	12.5	2,012.8	0.1	1.9	1	1	1
08/19/2021 18:00	0.0	12.2	2,079.1	0.1	0.0	1	1	1
08/19/2021 19:00	0.1	12.4	2,001.0	0.2	0.3	1	1	1
08/19/2021 20:00	0.0	13.9	1,671.2	0.0	0.0	1	1	0
08/19/2021 21:00	0.0	13.8	1,581.3	0.0	0.0	1	1	1
08/19/2021 22:00	0.9	12.7	1,972.2	0.2	2.9	1	1	1
08/19/2021 23:00	1.3	12.9	1,904.6	0.5	4.1	1	1	1
Average/Sum#:	0.2	13.4	1,736.2	0.2	17.8 #	24 #	24 #	13 #
Minimum:	0.0	12.2	1,342.2	0.0	0.0	1	1	0
Maximum:	1.3	14.0	2,079.1	0.5	4.1	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/20/2021 00:00	0.0	13.9	1,649.0	0.5	0.0	1	1	0
08/20/2021 01:00	0.0	13.9	1,647.5	0.3	0.0	1	1	0
08/20/2021 02:00	0.0	13.9	1,509.2	0.0	0.0	1	1	0
08/20/2021 03:00	0.0	14.0	1,327.0	0.0	0.0	1	1	0
08/20/2021 04:00	0.0	13.9	1,613.8	0.0	0.0	1	1	0
08/20/2021 05:00	1.3	13.7	1,689.3	0.4	4.0	1	1	1
08/20/2021 06:00	1.8	13.3	1,823.9	0.8	5.7	1	1	1
08/20/2021 07:00	0.0	13.9	1,620.6	0.8	0.0	1	1	0
08/20/2021 08:00	0.0	13.9	1,501.2	0.5	0.0	1	1	0
08/20/2021 09:00	0.0	14.0	1,292.6	0.0	0.0	1	1	0
08/20/2021 10:00	0.0	14.0	1,280.1	0.0	0.0	1	1	0
08/20/2021 11:00	0.0	14.0	1,282.2	0.0	0.0	1	1	0
08/20/2021 12:00	0.0	13.9	1,495.5	0.0	0.0	1	1	1
08/20/2021 13:00	0.7	12.6	1,991.8	0.2	2.2	1	1	1
08/20/2021 14:00	0.4	12.6	1,941.3	0.3	1.2	1	1	1
08/20/2021 15:00	0.0	13.9	1,511.6	0.3	0.0	1	1	0
08/20/2021 16:00	0.0	13.9	1,518.9	0.1	0.0	1	1	0
08/20/2021 17:00	0.3	12.4	2,012.4	0.1	0.9	1	1	1
08/20/2021 18:00	0.0	12.1	2,070.0	0.1	0.0	1	1	1
08/20/2021 19:00	0.1	12.3	2,014.4	0.1	0.3	1	1	1
08/20/2021 20:00	0.0	13.9	1,635.5	0.0	0.0	1	1	0
08/20/2021 21:00	0.0	13.8	1,674.6	0.0	0.0	1	1	1
08/20/2021 22:00	0.7	12.6	1,989.2	0.2	2.2	1	1	1
08/20/2021 23:00	1.4	12.9	1,888.3	0.5	4.4	1	1	1
Average/Sum#:	0.3	13.5	1,665.8	0.2	20.9 #	24 #	24 #	11 #
Minimum:	0.0	12.1	1,280.1	0.0	0.0	1	1	0
Maximum:	1.8	14.0	2,070.0	0.8	5.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/21/2021 00:00	20.1	15.6	587.4	0.0	6.8	1	0	0
08/21/2021 01:00	24.7	17.7	399.7	0.0	15.5	1	0	0
08/21/2021 02:00	13.9	14.4	1,115.1	0.0	31.5	1	0	0
08/21/2021 03:00	0.0	14.0	1,211.7	0.0	0.0	1	1	0
08/21/2021 04:00	0.0	14.0	1,217.6	0.0	0.0	1	1	0
08/21/2021 05:00	0.0	14.0	1,330.2	0.0	0.0	1	1	0
08/21/2021 06:00	0.0	14.0	1,331.2	0.0	0.0	1	1	0
08/21/2021 07:00	0.0	14.0	1,334.0	0.0	0.0	1	1	0
08/21/2021 08:00	0.0	14.0	1,335.8	0.0	0.0	1	1	0
08/21/2021 09:00	0.0	14.0	1,340.2	0.0	0.0	1	1	0
08/21/2021 10:00	0.0	14.0	1,340.9	0.0	0.0	1	1	0
08/21/2021 11:00	0.0	14.0	1,347.3	0.0	0.0	1	1	0
08/21/2021 12:00	0.0	14.0	1,349.1	0.0	0.0	1	1	0
08/21/2021 13:00	0.0	14.0	1,349.4	0.0	0.0	1	1	0
08/21/2021 14:00	0.0	14.0	1,348.0	0.0	0.0	1	1	0
08/21/2021 15:00	5.7	14.6	1,093.6	0.0	10.2	1	0	0
08/21/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	4.0	14.4	1,189.5	0.0	64.0 #	16 #	12 #	0 #
Minimum:	0.0	14.0	399.7	0.0	0.0	0	0	0
Maximum:	24.7	17.7	1,349.4	0.0	31.5	1	1	0
%SI	33.33	33.33	33.33	58.33	33.33	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/22/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/23/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2021 09:00	82.3	17.6	326.0	0.0	75.2	1	0	0
08/23/2021 10:00	23.8	17.2	389.9	0.0	33.1	1	0	0
08/23/2021 11:00	48.4	15.5	805.7	0.0	95.4	1	0	0
08/23/2021 12:00	7.9	14.8	1,070.5	0.0	11.0	1	0	0
08/23/2021 13:00	41.9	16.9	514.9	0.0	41.3	1	0	0
08/23/2021 14:00	21.7	14.5	1,103.4	0.0	49.4	1	0	0
08/23/2021 15:00	0.0	14.0	1,428.2	0.0	0.0	1	1	0
08/23/2021 16:00	0.0	13.8	1,683.5	0.0	0.0	1	1	0
08/23/2021 17:00	0.0	0.0	1,610.8	0.0	0.0	1	1	0
08/23/2021 18:00	0.0	13.8	1,656.7	0.0	0.0	1	1	0
08/23/2021 19:00	0.4	13.3	1,764.6	0.0	1.2	1	1	1
08/23/2021 20:00	0.4	13.1	1,825.4	0.2	1.2	1	1	1
08/23/2021 21:00	0.0	13.7	1,737.3	0.2	0.0	1	1	1
08/23/2021 22:00	1.0	12.8	1,964.3	0.3	3.2	1	1	1
08/23/2021 23:00	1.1	12.9	1,910.8	0.5	3.5	1	1	1
Average/Sum#:	15.3	14.6	1,319.5	0.3	314.5 #	15 #	9 #	5 #
Minimum:	0.0	12.8	326.0	0.2	0.0	0	0	0
Maximum:	82.3	17.6	1,964.3	0.5	95.4	1	1	1
%SI	37.50	41.67	37.50	83.33	41.67	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/24/2021 00:00	0.0	13.9	1,525.3	0.5	0.0	1	1	0
08/24/2021 01:00	0.0	13.9	1,590.8	0.3	0.0	1	1	0
08/24/2021 02:00	0.0	13.8	1,647.5	0.0	0.0	1	1	1
08/24/2021 03:00	2.9	13.1	1,915.7	0.7	9.4	1	1	1
08/24/2021 04:00	2.5	13.1	1,898.4	1.4	8.0	1	1	1
08/24/2021 05:00	0.0	13.9	1,641.6	1.4	0.0	1	1	0
08/24/2021 06:00	0.0	13.9	1,582.8	0.6	0.0	1	1	0
08/24/2021 07:00	0.0	13.9	1,618.6	0.0	0.0	1	1	0
08/24/2021 08:00	0.0	13.9	1,508.0	0.0	0.0	1	1	0
08/24/2021 09:00	0.0	13.9	1,662.4	0.0	0.0	1	1	0
08/24/2021 10:00	0.0	13.9	1,644.4	0.0	0.0	1	1	0
08/24/2021 11:00	0.0	13.9	1,607.9	0.0	0.0	1	1	0
08/24/2021 12:00	0.0	13.9	1,541.3	0.0	0.0	1	1	0
08/24/2021 13:00	0.0	13.8	1,630.7	0.0	0.0	1	1	1
08/24/2021 14:00	0.5	12.6	2,004.7	0.1	1.6	1	1	1
08/24/2021 15:00	0.2	12.5	2,005.7	0.2	0.6	1	1	1
08/24/2021 16:00	0.0	13.9	1,682.7	0.2	0.0	1	1	0
08/24/2021 17:00	0.0	13.7	1,725.8	0.0	0.0	1	1	1
08/24/2021 18:00	0.4	12.5	2,015.0	0.1	1.3	1	1	1
08/24/2021 19:00	0.0	12.1	2,068.0	0.1	0.0	1	1	1
08/24/2021 20:00	0.0	13.9	1,632.7	0.1	0.0	1	1	0
08/24/2021 21:00	0.0	13.7	1,746.8	0.0	0.0	1	1	1
08/24/2021 22:00	0.4	12.7	1,993.7	0.1	1.3	1	1	1
08/24/2021 23:00	0.1	12.4	2,077.0	0.1	0.3	1	1	1
Average/Sum#:	0.3	13.5	1,748.6	0.2	22.5 #	24 #	24 #	12 #
Minimum:	0.0	12.1	1,508.0	0.0	0.0	1	1	0
Maximum:	2.9	13.9	2,077.0	1.4	9.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/25/2021 00:00	0.0	13.7	1,611.4	0.1	0.0	1	1	1
08/25/2021 01:00	0.0	13.9	1,599.9	0.0	0.0	1	1	0
08/25/2021 02:00	0.0	13.9	1,550.8	0.0	0.0	1	1	1
08/25/2021 03:00	0.7	12.9	1,974.5	0.2	2.3	1	1	1
08/25/2021 04:00	0.1	12.6	2,034.8	0.2	0.3	1	1	1
08/25/2021 05:00	0.4	13.0	1,922.6	0.3	1.3	1	1	1
08/25/2021 06:00	0.0	13.9	1,573.2	0.1	0.0	1	1	0
08/25/2021 07:00	0.0	13.9	1,531.3	0.1	0.0	1	1	0
08/25/2021 08:00	0.0	13.8	1,609.4	0.0	0.0	1	1	1
08/25/2021 09:00	0.9	12.9	1,969.7	0.2	2.9	1	1	1
08/25/2021 10:00	1.4	13.0	1,915.0	0.6	4.5	1	1	1
08/25/2021 11:00	0.2	13.8	1,639.5	0.6	0.6	1	1	1
08/25/2021 12:00	0.0	13.8	1,615.2	0.4	0.0	1	1	1
08/25/2021 13:00	0.6	12.6	2,007.5	0.2	1.9	1	1	1
08/25/2021 14:00	0.2	12.5	1,996.5	0.2	0.6	1	1	1
08/25/2021 15:00	0.0	13.9	1,588.4	0.2	0.0	1	1	0
08/25/2021 16:00	0.0	14.0	1,463.0	0.0	0.0	1	1	1
08/25/2021 17:00	0.4	12.6	1,993.5	0.1	1.3	1	1	1
08/25/2021 18:00	0.0	12.3	2,074.6	0.1	0.0	1	1	1
08/25/2021 19:00	0.1	12.5	1,992.9	0.1	0.3	1	1	1
08/25/2021 20:00	0.0	13.9	1,623.2	0.0	0.0	1	1	0
08/25/2021 21:00	0.0	13.8	1,664.9	0.0	0.0	1	1	1
08/25/2021 22:00	0.6	12.7	1,987.6	0.1	1.9	1	1	1
08/25/2021 23:00	1.0	12.9	1,925.2	0.4	3.2	1	1	1
Average/Sum#:	0.3	13.3	1,786.0	0.2	21.1 #	24 #	24 #	19 #
Minimum:	0.0	12.3	1,463.0	0.0	0.0	1	1	0
Maximum:	1.4	14.0	2,074.6	0.6	4.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/26/2021 00:00	0.0	13.9	1,628.7	0.4	0.0	1	1	0
08/26/2021 01:00	0.0	13.9	1,595.5	0.2	0.0	1	1	0
08/26/2021 02:00	0.0	14.0	1,402.9	0.0	0.0	1	1	0
08/26/2021 03:00	0.0	13.9	1,559.9	0.0	0.0	1	1	1
08/26/2021 04:00	0.6	12.7	2,007.5	0.1	1.9	1	1	1
08/26/2021 05:00	0.3	12.6	2,038.1	0.2	1.0	1	1	1
08/26/2021 06:00	0.9	12.9	1,940.6	0.4	2.9	1	1	1
08/26/2021 07:00	0.0	13.8	1,657.1	0.3	0.0	1	1	1
08/26/2021 08:00	0.0	13.9	1,522.7	0.2	0.0	1	1	0
08/26/2021 09:00	0.7	13.3	1,811.3	0.2	2.2	1	1	1
08/26/2021 10:00	1.0	12.9	1,926.9	0.4	3.2	1	1	1
08/26/2021 11:00	0.0	13.9	1,695.7	0.4	0.0	1	1	0
08/26/2021 12:00	0.0	13.9	1,677.0	0.2	0.0	1	1	0
08/26/2021 13:00	0.7	12.7	1,988.0	0.2	2.2	1	1	1
08/26/2021 14:00	0.4	12.6	1,968.3	0.3	1.3	1	1	1
08/26/2021 15:00	0.0	13.8	1,691.0	0.3	0.0	1	1	0
08/26/2021 16:00	0.0	13.8	1,625.3	0.1	0.0	1	1	1
08/26/2021 17:00	0.2	12.3	1,992.0	0.0	0.6	1	1	1
08/26/2021 18:00	0.0	11.9	2,065.9	0.0	0.0	1	1	1
08/26/2021 19:00	0.0	11.8	2,135.9	0.0	0.0	1	1	1
08/26/2021 20:00	0.0	11.9	2,141.8	0.0	0.0	1	1	1
08/26/2021 21:00	0.0	12.0	2,133.0	0.0	0.0	1	1	1
08/26/2021 22:00	0.0	12.0	2,121.0	0.0	0.0	1	1	1
08/26/2021 23:00	0.4	12.3	2,036.6	0.1	1.3	1	1	1
Average/Sum#:	0.2	13.0	1,848.4	0.2	16.6 #	24 #	24 #	17 #
Minimum:	0.0	11.8	1,402.9	0.0	0.0	1	1	0
Maximum:	1.0	14.0	2,141.8	0.4	3.2	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/27/2021 00:00	0.0	13.9	1,669.8	0.1	0.0	1	1	0
08/27/2021 01:00	0.0	13.9	1,637.2	0.1	0.0	1	1	0
08/27/2021 02:00	0.0	13.9	1,659.6	0.0	0.0	1	1	0
08/27/2021 03:00	0.0	13.8	1,693.4	0.0	0.0	1	1	1
08/27/2021 04:00	0.6	12.6	2,016.6	0.1	1.9	1	1	1
08/27/2021 05:00	0.2	12.4	2,031.5	0.2	0.6	1	1	1
08/27/2021 06:00	0.0	13.9	1,569.5	0.2	0.0	1	1	0
08/27/2021 07:00	0.0	13.9	1,654.5	0.0	0.0	1	1	0
08/27/2021 08:00	0.0	13.9	1,511.2	0.0	0.0	1	1	0
08/27/2021 09:00	0.7	12.9	1,923.0	0.2	2.2	1	1	1
08/27/2021 10:00	0.3	12.7	1,940.6	0.2	0.9	1	1	1
08/27/2021 11:00	0.0	13.8	1,699.0	0.2	0.0	1	1	0
08/27/2021 12:00	0.0	13.8	1,694.0	0.1	0.0	1	1	1
08/27/2021 13:00	0.5	12.4	2,017.3	0.1	1.6	1	1	1
08/27/2021 14:00	0.0	11.8	2,132.2	0.1	0.0	1	1	1
08/27/2021 15:00	0.0	11.8	2,125.5	0.1	0.0	1	1	1
08/27/2021 16:00	0.0	11.8	2,126.0	0.0	0.0	1	1	1
08/27/2021 17:00	0.0	11.7	2,147.5	0.0	0.0	1	1	1
08/27/2021 18:00	0.0	11.7	2,155.6	0.0	0.0	1	1	1
08/27/2021 19:00	0.0	11.7	2,159.2	0.0	0.0	1	1	1
08/27/2021 20:00	0.0	11.7	2,167.3	0.0	0.0	1	1	1
08/27/2021 21:00	0.0	11.7	2,172.3	0.0	0.0	1	1	1
08/27/2021 22:00	0.0	12.0	2,121.9	0.0	0.0	1	1	1
08/27/2021 23:00	0.1	12.3	2,037.1	0.0	0.3	1	1	1
Average/Sum#:	0.1	12.8	1,919.2	0.1	7.5 #	24 #	24 #	17 #
Minimum:	0.0	11.7	1,511.2	0.0	0.0	1	1	0
Maximum:	0.7	13.9	2,172.3	0.2	2.2	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/28/2021 00:00	0.0	13.9	1,656.8	0.0	0.0	1	1	0
08/28/2021 01:00	0.0	13.7	1,736.2	0.0	0.0	1	1	1
08/28/2021 02:00	0.5	12.7	1,996.3	0.1	1.6	1	1	1
08/28/2021 03:00	0.8	13.0	1,904.4	0.3	2.5	1	1	1
08/28/2021 04:00	0.0	13.9	1,626.9	0.3	0.0	1	1	0
08/28/2021 05:00	0.0	14.0	1,626.3	0.2	0.0	1	1	0
08/28/2021 06:00	0.0	14.0	1,610.2	0.0	0.0	1	1	0
08/28/2021 07:00	0.0	13.9	1,635.5	0.0	0.0	1	1	0
08/28/2021 08:00	0.0	14.0	1,614.8	0.0	0.0	1	1	0
08/28/2021 09:00	0.0	13.9	1,633.2	0.0	0.0	1	1	0
08/28/2021 10:00	0.0	13.9	1,609.9	0.0	0.0	1	1	1
08/28/2021 11:00	0.5	12.4	2,030.7	0.1	1.6	1	1	1
08/28/2021 12:00	0.0	12.1	2,043.6	0.1	0.0	1	1	1
08/28/2021 13:00	0.0	13.9	1,665.0	0.1	0.0	1	1	0
08/28/2021 14:00	0.0	13.8	1,683.7	0.0	0.0	1	1	1
08/28/2021 15:00	0.7	12.5	2,004.5	0.2	2.2	1	1	1
08/28/2021 16:00	0.0	11.9	2,102.8	0.2	0.0	1	1	1
08/28/2021 17:00	0.0	11.8	2,129.3	0.2	0.0	1	1	1
08/28/2021 18:00	0.0	11.7	2,152.9	0.0	0.0	1	1	1
08/28/2021 19:00	0.0	11.7	2,168.0	0.0	0.0	1	1	1
08/28/2021 20:00	0.0	11.7	2,172.3	0.0	0.0	1	1	1
08/28/2021 21:00	0.0	11.7	2,159.9	0.0	0.0	1	1	1
08/28/2021 22:00	0.0	12.0	2,114.4	0.0	0.0	1	1	1
08/28/2021 23:00	0.0	12.3	2,064.7	0.0	0.0	1	1	1
Average/Sum#:	0.1	12.9	1,880.9	0.1	7.9 #	24 #	24 #	16 #
Minimum:	0.0	11.7	1,609.9	0.0	0.0	1	1	0
Maximum:	0.8	14.0	2,172.3	0.3	2.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/29/2021 00:00	0.3	12.7	1,939.1	0.1	0.9	1	1	1
08/29/2021 01:00	0.0	13.9	1,668.0	0.1	0.0	1	1	0
08/29/2021 02:00	0.0	13.7	1,737.0	0.1	0.0	1	1	1
08/29/2021 03:00	0.5	12.6	1,998.1	0.1	1.6	1	1	1
08/29/2021 04:00	0.3	12.5	2,009.1	0.2	0.9	1	1	1
08/29/2021 05:00	0.0	13.9	1,674.9	0.2	0.0	1	1	0
08/29/2021 06:00	0.0	14.0	1,608.9	0.1	0.0	1	1	0
08/29/2021 07:00	0.0	14.0	1,582.5	0.0	0.0	1	1	0
08/29/2021 08:00	0.0	14.0	1,507.1	0.0	0.0	1	1	0
08/29/2021 09:00	0.0	14.0	1,459.3	0.0	0.0	1	1	0
08/29/2021 10:00	2.2	13.2	1,829.3	0.6	6.9	1	1	1
08/29/2021 11:00	0.4	12.7	1,941.2	0.7	1.3	1	1	1
08/29/2021 12:00	0.0	13.7	1,691.1	0.7	0.0	1	1	1
08/29/2021 13:00	0.0	13.8	1,676.6	0.1	0.0	1	1	1
08/29/2021 14:00	0.3	12.2	2,029.1	0.1	0.9	1	1	1
08/29/2021 15:00	0.0	11.9	2,090.9	0.1	0.0	1	1	1
08/29/2021 16:00	0.0	11.8	2,104.8	0.1	0.0	1	1	1
08/29/2021 17:00	0.0	11.7	2,135.4	0.0	0.0	1	1	1
08/29/2021 18:00	0.0	11.7	2,142.8	0.0	0.0	1	1	1
08/29/2021 19:00	0.0	11.6	2,153.2	0.0	0.0	1	1	1
08/29/2021 20:00	0.0	11.6	2,151.1	0.0	0.0	1	1	1
08/29/2021 21:00	0.0	11.7	2,152.1	0.0	0.0	1	1	1
08/29/2021 22:00	0.0	11.9	2,111.7	0.0	0.0	1	1	1
08/29/2021 23:00	0.1	12.4	1,995.4	0.0	0.3	1	1	1
Average/Sum#:	0.2	12.8	1,891.2	0.1	12.8 #	24 #	24 #	18 #
Minimum:	0.0	11.6	1,459.3	0.0	0.0	1	1	0
Maximum:	2.2	14.0	2,153.2	0.7	6.9	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/30/2021 00:00	0.0	13.9	1,606.5	0.0	0.0	1	1	0
08/30/2021 01:00	0.0	13.9	1,649.1	0.0	0.0	1	1	1
08/30/2021 02:00	1.1	12.9	1,922.4	0.3	3.5	1	1	1
08/30/2021 03:00	0.2	12.4	2,007.4	0.3	0.6	1	1	1
08/30/2021 04:00	0.0	13.9	1,614.9	0.3	0.0	1	1	0
08/30/2021 05:00	0.0	13.9	1,515.2	0.0	0.0	1	1	1
08/30/2021 06:00	0.3	12.6	1,998.3	0.1	1.0	1	1	1
08/30/2021 07:00	0.3	12.6	1,971.3	0.1	0.9	1	1	1
08/30/2021 08:00	0.0	13.9	1,653.8	0.1	0.0	1	1	0
08/30/2021 09:00	0.0	13.8	1,626.1	0.1	0.0	1	1	0
08/30/2021 10:00	0.6	12.9	1,878.6	0.1	1.9	1	1	1
08/30/2021 11:00	0.1	12.2	2,025.1	0.2	0.3	1	1	1
08/30/2021 12:00	0.0	13.8	1,674.3	0.2	0.0	1	1	0
08/30/2021 13:00	0.0	13.8	1,660.1	0.0	0.0	1	1	1
08/30/2021 14:00	0.3	12.2	2,036.4	0.1	0.9	1	1	1
08/30/2021 15:00	0.0	11.9	2,102.3	0.1	0.0	1	1	1
08/30/2021 16:00	0.0	11.8	2,107.2	0.1	0.0	1	1	1
08/30/2021 17:00	0.0	11.7	2,130.7	0.0	0.0	1	1	1
08/30/2021 18:00	0.0	11.7	2,142.2	0.0	0.0	1	1	1
08/30/2021 19:00	0.0	11.7	2,156.9	0.0	0.0	1	1	1
08/30/2021 20:00	0.0	11.7	2,174.6	0.0	0.0	1	1	1
08/30/2021 21:00	0.0	11.8	2,160.1	0.0	0.0	1	1	1
08/30/2021 22:00	0.0	12.0	2,115.2	0.0	0.0	1	1	1
08/30/2021 23:00	0.1	12.3	2,018.7	0.0	0.3	1	1	1
Average/Sum#:	0.1	12.7	1,914.5	0.1	9.4 #	24 #	24 #	19 #
Minimum:	0.0	11.7	1,515.2	0.0	0.0	1	1	0
Maximum:	1.1	13.9	2,174.6	0.3	3.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/31/2021 00:00	0.0	13.9	1,636.0	0.0	0.0	1	1	0
08/31/2021 01:00	0.0	13.9	1,658.1	0.0	0.0	1	1	0
08/31/2021 02:00	0.0	14.0	1,300.0	0.0	0.0	1	1	0
08/31/2021 03:00	0.0	13.9	1,624.7	0.0	0.0	1	1	0
08/31/2021 04:00	0.9	13.4	1,803.6	0.2	2.9	1	1	1
08/31/2021 05:00	1.1	13.1	1,865.3	0.5	3.5	1	1	1
08/31/2021 06:00	0.0	13.7	1,754.2	0.5	0.0	1	1	0
08/31/2021 07:00	0.9	12.9	1,955.2	0.5	2.9	1	1	1
08/31/2021 08:00	0.1	12.4	2,032.1	0.3	0.3	1	1	1
08/31/2021 09:00	0.0	13.9	1,652.5	0.3	0.0	1	1	0
08/31/2021 10:00	0.0	13.8	1,668.9	0.0	0.0	1	1	0
08/31/2021 11:00	0.4	12.7	1,956.3	0.1	1.3	1	1	1
08/31/2021 12:00	0.1	12.3	2,026.7	0.1	0.3	1	1	1
08/31/2021 13:00	0.0	13.8	1,629.0	0.1	0.0	1	1	0
08/31/2021 14:00	0.0	13.8	1,684.7	0.0	0.0	1	1	0
08/31/2021 15:00	0.5	12.6	1,961.7	0.1	1.6	1	1	1
08/31/2021 16:00	0.0	12.0	2,097.3	0.1	0.0	1	1	1
08/31/2021 17:00	0.0	11.9	2,110.4	0.1	0.0	1	1	1
08/31/2021 18:00	0.0	11.9	2,121.2	0.0	0.0	1	1	1
08/31/2021 19:00	0.0	12.0	2,055.1	0.0	0.0	1	1	1
08/31/2021 20:00	0.0	13.9	1,625.0	0.0	0.0	1	1	0
08/31/2021 21:00	0.0	13.8	1,679.2	0.0	0.0	1	1	1
08/31/2021 22:00	0.9	12.7	1,983.2	0.2	2.9	1	1	1
08/31/2021 23:00	0.0	12.4	2,052.6	0.2	0.0	1	1	1
Average/Sum#:	0.2	13.1	1,830.5	0.1	15.7 #	24 #	24 #	14 #
Minimum:	0.0	11.9	1,300.0	0.0	0.0	1	1	0
Maximum:	1.1	14.0	2,121.2	0.5	3.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/01/2021 00:00	0.0	12.3	2,081.8	0.2	0.0	1	1	1
09/01/2021 01:00	0.3	13.0	1,906.7	0.1	1.0	1	1	1
09/01/2021 02:00	0.0	13.9	1,576.1	0.1	0.0	1	1	0
09/01/2021 03:00	0.0	13.8	1,676.1	0.1	0.0	1	1	1
09/01/2021 04:00	0.5	12.8	1,977.0	0.1	1.6	1	1	1
09/01/2021 05:00	0.0	12.4	2,078.6	0.1	0.0	1	1	1
09/01/2021 06:00	0.5	12.9	1,966.2	0.3	1.6	1	1	1
09/01/2021 07:00	0.0	13.9	1,661.3	0.1	0.0	1	1	0
09/01/2021 08:00	0.0	13.9	1,597.6	0.1	0.0	1	1	0
09/01/2021 09:00	1.2	13.2	1,854.8	0.3	3.8	1	1	1
09/01/2021 10:00	0.9	12.9	1,950.3	0.5	2.9	1	1	1
09/01/2021 11:00	0.0	13.7	1,466.1	0.5	0.0	1	1	1
09/01/2021 12:00	0.0	13.9	1,524.8	0.2	0.0	1	1	1
09/01/2021 13:00	0.6	12.8	1,946.4	0.1	1.9	1	1	1
09/01/2021 14:00	0.3	12.7	1,945.1	0.2	0.9	1	1	1
09/01/2021 15:00	0.0	13.6	1,661.0	0.2	0.0	1	1	1
09/01/2021 16:00	0.0	13.8	1,667.9	0.1	0.0	1	1	1
09/01/2021 17:00	0.4	12.5	2,009.8	0.1	1.3	1	1	1
09/01/2021 18:00	0.0	12.3	2,060.5	0.1	0.0	1	1	1
09/01/2021 19:00	0.0	12.3	2,048.1	0.1	0.0	1	1	1
09/01/2021 20:00	0.0	13.9	1,657.5	0.0	0.0	1	1	0
09/01/2021 21:00	0.0	14.0	1,370.0	0.0	0.0	1	1	0
09/01/2021 22:00	0.0	13.9	1,614.6	0.0	0.0	1	1	0
09/01/2021 23:00	0.0	13.9	1,680.2	0.0	0.0	1	1	0
Average/Sum#:	0.2	13.3	1,790.8	0.2	15.0 #	24 #	24 #	17 #
Minimum:	0.0	12.3	1,370.0	0.0	0.0	1	1	0
Maximum:	1.2	14.0	2,081.8	0.5	3.8	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/02/2021 00:00	0.3	13.3	1,820.1	0.1	0.9	1	1	1
09/02/2021 01:00	0.2	13.1	1,836.4	0.1	0.6	1	1	1
09/02/2021 02:00	0.0	14.0	1,349.8	0.1	0.0	1	1	0
09/02/2021 03:00	0.0	13.9	1,652.6	0.1	0.0	1	1	0
09/02/2021 04:00	0.0	14.0	1,379.3	0.0	0.0	1	1	0
09/02/2021 05:00	0.0	13.9	1,628.2	0.0	0.0	1	1	0
09/02/2021 06:00	1.4	13.4	1,789.2	0.4	4.4	1	1	1
09/02/2021 07:00	0.7	13.3	1,819.9	0.5	2.2	1	1	1
09/02/2021 08:00	0.0	14.0	1,345.5	0.5	0.0	1	1	0
09/02/2021 09:00	0.0	14.0	1,433.5	0.2	0.0	1	1	0
09/02/2021 10:00	0.0	14.0	1,488.2	0.0	0.0	1	1	0
09/02/2021 11:00	0.0	14.0	1,408.5	0.0	0.0	1	1	0
09/02/2021 12:00	0.0	13.9	1,663.3	0.0	0.0	1	1	1
09/02/2021 13:00	0.5	12.7	1,986.4	0.1	1.6	1	1	1
09/02/2021 14:00	0.3	12.7	1,948.3	0.2	0.9	1	1	1
09/02/2021 15:00	0.0	13.9	1,644.9	0.2	0.0	1	1	0
09/02/2021 16:00	0.0	13.9	1,601.5	0.1	0.0	1	1	1
09/02/2021 17:00	0.4	12.5	2,010.0	0.1	1.3	1	1	1
09/02/2021 18:00	0.1	12.3	2,048.2	0.1	0.3	1	1	1
09/02/2021 19:00	0.1	12.4	2,013.3	0.2	0.3	1	1	1
09/02/2021 20:00	0.0	13.9	1,551.2	0.1	0.0	1	1	0
09/02/2021 21:00	0.0	14.0	1,377.3	0.0	0.0	1	1	0
09/02/2021 22:00	0.0	14.0	1,588.1	0.0	0.0	1	1	0
09/02/2021 23:00	1.0	13.4	1,796.9	0.3	3.2	1	1	1
Average/Sum#:	0.2	13.5	1,674.2	0.1	15.7 #	24 #	24 #	12 #
Minimum:	0.0	12.3	1,345.5	0.0	0.0	1	1	0
Maximum:	1.4	14.0	2,048.2	0.5	4.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/03/2021 00:00	0.4	13.0	1,859.7	0.4	1.2	1	1	1
09/03/2021 01:00	0.0	13.8	1,583.7	0.4	0.0	1	1	0
09/03/2021 02:00	0.0	13.8	1,753.5	0.1	0.0	1	1	1
09/03/2021 03:00	2.8	13.2	1,905.9	0.7	9.2	1	1	1
09/03/2021 04:00	0.0	13.9	1,555.9	0.7	0.0	1	1	0
09/03/2021 05:00	0.0	13.7	1,728.4	0.7	0.0	1	1	1
09/03/2021 06:00	0.1	12.8	1,994.8	0.0	0.3	1	1	1
09/03/2021 07:00	0.1	13.0	1,928.5	0.1	0.3	1	1	1
09/03/2021 08:00	0.0	13.9	1,684.3	0.1	0.0	1	1	0
09/03/2021 09:00	0.0	14.0	1,501.1	0.0	0.0	1	1	0
09/03/2021 10:00	0.0	14.0	1,586.8	0.0	0.0	1	1	0
09/03/2021 11:00	0.2	14.0	1,583.6	0.1	0.6	1	1	0
09/03/2021 12:00	0.0	14.0	1,592.1	0.1	0.0	1	1	0
09/03/2021 13:00	0.0	13.9	1,599.0	0.1	0.0	1	1	0
09/03/2021 14:00	0.0	14.0	1,522.3	0.0	0.0	1	1	1
09/03/2021 15:00	0.4	12.5	2,014.9	0.1	1.3	1	1	1
09/03/2021 16:00	0.1	12.2	2,079.3	0.1	0.3	1	1	1
09/03/2021 17:00	0.0	12.0	2,133.2	0.1	0.0	1	1	1
09/03/2021 18:00	0.0	12.0	2,133.0	0.0	0.0	1	1	1
09/03/2021 19:00	0.0	12.2	2,047.7	0.0	0.0	1	1	1
09/03/2021 20:00	0.0	13.9	1,664.3	0.0	0.0	1	1	0
09/03/2021 21:00	0.0	13.7	1,746.3	0.0	0.0	1	1	1
09/03/2021 22:00	0.9	12.8	1,970.5	0.2	2.9	1	1	1
09/03/2021 23:00	0.9	13.0	1,919.6	0.5	2.9	1	1	1
Average/Sum#:	0.2	13.3	1,795.4	0.2	19.0 #	24 #	24 #	15 #
Minimum:	0.0	12.0	1,501.1	0.0	0.0	1	1	0
Maximum:	2.8	14.0	2,133.2	0.7	9.2	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/04/2021 00:00	0.0	13.9	1,611.0	0.5	0.0	1	1	0
09/04/2021 01:00	0.0	13.8	1,630.6	0.2	0.0	1	1	1
09/04/2021 02:00	1.1	12.8	1,976.7	0.3	3.5	1	1	1
09/04/2021 03:00	8.2	14.1	1,256.5	0.0	10.0	1	0	1
09/04/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2021 13:00	25.4	17.9	342.7	0.0	17.2	1	0	0
09/04/2021 14:00	15.9	14.6	1,155.5	0.0	38.5	1	0	0
09/04/2021 15:00	0.0	13.9	1,692.1	0.0	0.0	1	1	0
09/04/2021 16:00	0.0	13.9	1,569.7	0.0	0.0	1	1	1
09/04/2021 17:00	0.2	12.3	2,053.5	0.0	0.6	1	1	1
09/04/2021 18:00	0.0	11.8	2,152.4	0.0	0.0	1	1	1
09/04/2021 19:00	0.0	11.8	2,165.8	0.0	0.0	1	1	1
09/04/2021 20:00	0.0	12.0	2,115.0	0.0	0.0	1	1	1
09/04/2021 21:00	0.0	12.2	2,078.6	0.0	0.0	1	1	1
09/04/2021 22:00	0.1	12.5	2,041.4	0.0	0.3	1	1	1
09/04/2021 23:00	0.2	12.5	2,032.9	0.1	0.6	1	1	1
Average/Sum#:	3.4	13.3	1,725.0	0.1	70.7 #	15 #	12 #	11 #
Minimum:	0.0	11.8	342.7	0.0	0.0	0	0	0
Maximum:	25.4	17.9	2,165.8	0.5	38.5	1	1	1
%SI	37.50	37.50	37.50	58.33	37.50	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/05/2021 00:00	0.6	12.9	1,927.6	0.2	1.9	1	1	1
09/05/2021 01:00	0.0	13.9	1,620.3	0.2	0.0	1	1	0
09/05/2021 02:00	0.0	13.9	1,625.8	0.1	0.0	1	1	1
09/05/2021 03:00	0.5	12.9	1,979.6	0.1	1.6	1	1	1
09/05/2021 04:00	0.8	13.1	1,907.7	0.3	2.6	1	1	1
09/05/2021 05:00	0.0	13.9	1,611.0	0.3	0.0	1	1	0
09/05/2021 06:00	0.0	13.9	1,600.6	0.2	0.0	1	1	0
09/05/2021 07:00	0.0	13.9	1,574.7	0.0	0.0	1	1	0
09/05/2021 08:00	0.0	13.9	1,605.3	0.0	0.0	1	1	0
09/05/2021 09:00	0.0	13.9	1,594.3	0.0	0.0	1	1	0
09/05/2021 10:00	0.0	13.9	1,662.0	0.0	0.0	1	1	0
09/05/2021 11:00	0.0	13.9	1,688.3	0.0	0.0	1	1	0
09/05/2021 12:00	0.0	13.9	1,678.0	0.0	0.0	1	1	0
09/05/2021 13:00	0.0	13.8	1,697.1	0.0	0.0	1	1	0
09/05/2021 14:00	0.4	12.6	1,961.0	0.1	1.2	1	1	1
09/05/2021 15:00	0.1	12.1	2,105.8	0.1	0.3	1	1	1
09/05/2021 16:00	0.0	11.9	2,123.3	0.1	0.0	1	1	1
09/05/2021 17:00	0.0	11.8	2,151.0	0.0	0.0	1	1	1
09/05/2021 18:00	0.0	11.9	2,144.8	0.0	0.0	1	1	1
09/05/2021 19:00	0.0	11.8	2,169.3	0.0	0.0	1	1	1
09/05/2021 20:00	0.0	12.0	2,115.9	0.0	0.0	1	1	1
09/05/2021 21:00	0.0	12.2	2,081.0	0.0	0.0	1	1	1
09/05/2021 22:00	0.1	12.3	2,064.4	0.0	0.3	1	1	1
09/05/2021 23:00	0.2	12.6	1,988.2	0.1	0.6	1	1	1
Average/Sum#:	0.1	13.0	1,861.5	0.1	8.5 #	24 #	24 #	14 #
Minimum:	0.0	11.8	1,574.7	0.0	0.0	1	1	0
Maximum:	0.8	13.9	2,169.3	0.3	2.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/06/2021 00:00	0.0	13.9	1,611.5	0.1	0.0	1	1	0
09/06/2021 01:00	0.0	13.9	1,602.2	0.0	0.0	1	1	1
09/06/2021 02:00	0.7	12.9	1,951.6	0.2	2.3	1	1	1
09/06/2021 03:00	0.4	12.8	1,936.4	0.3	1.3	1	1	1
09/06/2021 04:00	0.0	13.9	1,574.6	0.3	0.0	1	1	0
09/06/2021 05:00	0.0	13.9	1,640.8	0.1	0.0	1	1	0
09/06/2021 06:00	0.0	13.9	1,598.6	0.0	0.0	1	1	0
09/06/2021 07:00	0.0	14.0	1,607.7	0.0	0.0	1	1	0
09/06/2021 08:00	0.0	14.0	1,676.8	0.0	0.0	1	1	0
09/06/2021 09:00	0.0	14.0	1,541.7	0.0	0.0	1	1	0
09/06/2021 10:00	0.0	13.9	1,659.9	0.0	0.0	1	1	0
09/06/2021 11:00	0.0	13.9	1,649.8	0.0	0.0	1	1	1
09/06/2021 12:00	0.3	12.4	2,054.8	0.1	1.0	1	1	1
09/06/2021 13:00	0.0	11.9	2,138.3	0.1	0.0	1	1	1
09/06/2021 14:00	0.0	11.9	2,133.5	0.1	0.0	1	1	1
09/06/2021 15:00	0.0	11.9	2,138.4	0.0	0.0	1	1	1
09/06/2021 16:00	0.0	11.8	2,146.6	0.0	0.0	1	1	1
09/06/2021 17:00	0.0	11.7	2,160.6	0.0	0.0	1	1	1
09/06/2021 18:00	0.0	11.7	2,170.0	0.0	0.0	1	1	1
09/06/2021 19:00	0.0	11.7	2,174.2	0.0	0.0	1	1	1
09/06/2021 20:00	0.0	11.7	2,181.4	0.0	0.0	1	1	1
09/06/2021 21:00	0.0	11.9	2,157.0	0.0	0.0	1	1	1
09/06/2021 22:00	0.0	12.1	2,102.0	0.0	0.0	1	1	1
09/06/2021 23:00	0.1	12.5	2,005.8	0.0	0.3	1	1	1
Average/Sum#:	0.1	12.8	1,900.6	0.1	4.9 #	24 #	24 #	16 #
Minimum:	0.0	11.7	1,541.7	0.0	0.0	1	1	0
Maximum:	0.7	14.0	2,181.4	0.3	2.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/07/2021 00:00	0.0	13.9	1,672.9	0.0	0.0	1	1	0
09/07/2021 01:00	0.0	13.8	1,643.2	0.0	0.0	1	1	1
09/07/2021 02:00	0.4	12.6	2,000.5	0.1	1.3	1	1	1
09/07/2021 03:00	0.3	12.8	1,926.6	0.2	0.9	1	1	1
09/07/2021 04:00	0.0	13.9	1,674.9	0.2	0.0	1	1	0
09/07/2021 05:00	0.0	13.7	1,751.0	0.1	0.0	1	1	1
09/07/2021 06:00	1.2	12.7	1,980.7	0.3	3.8	1	1	1
09/07/2021 07:00	0.5	12.8	1,949.2	0.4	1.6	1	1	1
09/07/2021 08:00	0.0	13.9	1,663.9	0.4	0.0	1	1	0
09/07/2021 09:00	0.0	13.8	1,704.1	0.1	0.0	1	1	0
09/07/2021 10:00	0.4	12.7	1,950.0	0.1	1.3	1	1	1
09/07/2021 11:00	0.0	11.9	2,116.0	0.1	0.0	1	1	1
09/07/2021 12:00	0.0	12.0	2,106.0	0.1	0.0	1	1	1
09/07/2021 13:00	0.0	12.0	2,086.1	0.0	0.0	1	1	1
09/07/2021 14:00	0.0	12.0	2,075.8	0.0	0.0	1	1	1
09/07/2021 15:00	0.0	11.9	2,084.2	0.0	0.0	1	1	1
09/07/2021 16:00	0.0	11.8	2,100.8	0.0	0.0	1	1	1
09/07/2021 17:00	0.0	11.9	2,098.9	0.0	0.0	1	1	1
09/07/2021 18:00	0.0	12.2	2,069.4	0.0	0.0	1	1	1
09/07/2021 19:00	0.0	12.3	2,054.6	0.0	0.0	1	1	1
09/07/2021 20:00	0.0	12.3	2,057.0	0.0	0.0	1	1	1
09/07/2021 21:00	0.0	11.9	2,144.3	0.0	0.0	1	1	1
09/07/2021 22:00	0.0	11.8	2,171.2	0.0	0.0	1	1	1
09/07/2021 23:00	0.0	11.8	2,171.2	0.0	0.0	1	1	1
Average/Sum#:	0.1	12.6	1,968.9	0.1	8.9 #	24 #	24 #	20 #
Minimum:	0.0	11.8	1,643.2	0.0	0.0	1	1	0
Maximum:	1.2	13.9	2,171.2	0.4	3.8	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/08/2021 00:00	0.0	11.9	2,156.8	0.0	0.0	1	1	1
09/08/2021 01:00	0.0	12.1	2,096.0	0.0	0.0	1	1	1
09/08/2021 02:00	0.0	12.3	2,050.5	0.0	0.0	1	1	1
09/08/2021 03:00	0.1	12.3	2,061.1	0.0	0.3	1	1	1
09/08/2021 04:00	0.0	11.9	2,148.5	0.0	0.0	1	1	1
09/08/2021 05:00	0.0	11.8	2,168.0	0.0	0.0	1	1	1
09/08/2021 06:00	0.0	12.0	2,142.3	0.0	0.0	1	1	1
09/08/2021 07:00	0.2	12.6	1,965.9	0.0	0.6	1	1	1
09/08/2021 08:00	0.0	13.9	1,676.1	0.0	0.0	1	1	0
09/08/2021 09:00	0.0	13.8	1,685.5	0.0	0.0	1	1	0
09/08/2021 10:00	0.3	12.6	1,964.2	0.1	0.9	1	1	1
09/08/2021 11:00	0.0	11.9	2,110.4	0.1	0.0	1	1	1
09/08/2021 12:00	0.0	12.0	2,093.6	0.1	0.0	1	1	1
09/08/2021 13:00	0.0	11.9	2,093.3	0.0	0.0	1	1	1
09/08/2021 14:00	0.0	11.8	2,094.3	0.0	0.0	1	1	1
09/08/2021 15:00	0.0	11.8	2,093.8	0.0	0.0	1	1	1
09/08/2021 16:00	0.0	11.7	2,112.4	0.0	0.0	1	1	1
09/08/2021 17:00	0.0	11.6	2,131.5	0.0	0.0	1	1	1
09/08/2021 18:00	0.0	11.7	2,133.7	0.0	0.0	1	1	1
09/08/2021 19:00	0.0	11.7	2,151.0	0.0	0.0	1	1	1
09/08/2021 20:00	0.0	11.8	2,141.7	0.0	0.0	1	1	1
09/08/2021 21:00	0.0	12.0	2,099.7	0.0	0.0	1	1	1
09/08/2021 22:00	0.0	12.1	2,074.7	0.0	0.0	1	1	1
09/08/2021 23:00	0.0	11.8	2,139.9	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.1	2,066.0	0.0	1.8 #	24 #	24 #	22 #
Minimum:	0.0	11.6	1,676.1	0.0	0.0	1	1	0
Maximum:	0.3	13.9	2,168.0	0.1	0.9	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/09/2021 00:00	0.0	11.7	2,150.4	0.0	0.0	1	1	1
09/09/2021 01:00	0.0	11.7	2,162.9	0.0	0.0	1	1	1
09/09/2021 02:00	0.0	11.8	2,171.9	0.0	0.0	1	1	1
09/09/2021 03:00	0.0	11.8	2,166.9	0.0	0.0	1	1	1
09/09/2021 04:00	0.0	11.8	2,170.0	0.0	0.0	1	1	1
09/09/2021 05:00	0.0	11.8	2,168.6	0.0	0.0	1	1	1
09/09/2021 06:00	0.0	11.8	2,162.1	0.0	0.0	1	1	1
09/09/2021 07:00	0.0	12.0	2,120.0	0.0	0.0	1	1	1
09/09/2021 08:00	0.0	12.0	2,109.4	0.0	0.0	1	1	1
09/09/2021 09:00	0.0	12.0	2,111.2	0.0	0.0	1	1	1
09/09/2021 10:00	0.0	11.9	2,107.8	0.0	0.0	1	1	1
09/09/2021 11:00	0.0	11.9	2,095.8	0.0	0.0	1	1	1
09/09/2021 12:00	0.0	11.9	2,078.2	0.0	0.0	1	1	1
09/09/2021 13:00	0.0	11.8	2,088.3	0.0	0.0	1	1	1
09/09/2021 14:00	0.0	11.9	2,075.2	0.0	0.0	1	1	1
09/09/2021 15:00	0.0	11.9	2,068.6	0.0	0.0	1	1	1
09/09/2021 16:00	0.0	11.8	2,085.2	0.0	0.0	1	1	1
09/09/2021 17:00	0.0	11.8	2,095.3	0.0	0.0	1	1	1
09/09/2021 18:00	0.0	11.7	2,128.4	0.0	0.0	1	1	1
09/09/2021 19:00	0.0	11.7	2,136.7	0.0	0.0	1	1	1
09/09/2021 20:00	0.0	11.7	2,145.8	0.0	0.0	1	1	1
09/09/2021 21:00	0.0	11.7	2,152.6	0.0	0.0	1	1	1
09/09/2021 22:00	0.0	11.8	2,125.0	0.0	0.0	1	1	1
09/09/2021 23:00	0.0	11.8	2,138.2	0.0	0.0	1	1	1
Average/Sum#:	0.0	11.8	2,125.6	0.0	0.0 #	24 #	24 #	24 #
Minimum:	0.0	11.7	2,068.6	0.0	0.0	1	1	1
Maximum:	0.0	12.0	2,171.9	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/10/2021 00:00	0.0	12.1	2,054.4	0.0	0.0	1	1	1
09/10/2021 01:00	0.0	13.9	1,559.1	0.0	0.0	1	1	0
09/10/2021 02:00	0.0	13.7	1,715.5	0.0	0.0	1	1	1
09/10/2021 03:00	0.3	12.5	2,014.5	0.1	1.0	1	1	1
09/10/2021 04:00	0.0	11.8	2,142.7	0.1	0.0	1	1	1
09/10/2021 05:00	0.0	12.0	2,107.5	0.1	0.0	1	1	1
09/10/2021 06:00	0.0	11.8	2,151.7	0.0	0.0	1	1	1
09/10/2021 07:00	0.0	13.5	1,616.2	0.0	0.0	1	1	1
09/10/2021 08:00	0.0	13.9	1,489.7	0.0	0.0	1	1	0
09/10/2021 09:00	0.0	13.8	1,610.2	0.0	0.0	1	1	0
09/10/2021 10:00	0.0	13.8	1,581.7	0.0	0.0	1	1	1
09/10/2021 11:00	0.4	12.5	1,984.7	0.1	1.2	1	1	1
09/10/2021 12:00	0.0	12.4	1,966.8	0.1	0.0	1	1	1
09/10/2021 13:00	0.0	13.9	1,573.7	0.1	0.0	1	1	0
09/10/2021 14:00	0.0	13.8	1,687.7	0.0	0.0	1	1	1
09/10/2021 15:00	0.3	12.4	2,008.9	0.1	0.9	1	1	1
09/10/2021 16:00	0.0	12.1	2,063.9	0.1	0.0	1	1	1
09/10/2021 17:00	0.0	11.9	2,112.9	0.1	0.0	1	1	1
09/10/2021 18:00	0.0	11.8	2,129.9	0.0	0.0	1	1	1
09/10/2021 19:00	0.0	11.8	2,130.3	0.0	0.0	1	1	1
09/10/2021 20:00	0.0	11.8	2,129.3	0.0	0.0	1	1	1
09/10/2021 21:00	0.0	11.9	2,130.3	0.0	0.0	1	1	1
09/10/2021 22:00	0.0	12.1	2,074.7	0.0	0.0	1	1	1
09/10/2021 23:00	0.0	12.4	2,012.8	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.7	1,918.7	0.0	3.1 #	24 #	24 #	20 #
Minimum:	0.0	11.8	1,489.7	0.0	0.0	1	1	0
Maximum:	0.4	13.9	2,151.7	0.1	1.2	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/11/2021 00:00	0.6	12.9	1,893.7	0.1	1.9	1	1	1
09/11/2021 01:00	0.0	13.9	1,667.0	0.1	0.0	1	1	0
09/11/2021 02:00	0.0	13.9	1,652.8	0.1	0.0	1	1	0
09/11/2021 03:00	0.0	13.8	1,545.8	0.0	0.0	1	1	1
09/11/2021 04:00	0.7	12.7	1,979.6	0.2	2.2	1	1	1
09/11/2021 05:00	0.8	12.9	1,909.7	0.4	2.5	1	1	1
09/11/2021 06:00	0.0	13.9	1,632.8	0.4	0.0	1	1	0
09/11/2021 07:00	0.0	13.9	1,604.3	0.2	0.0	1	1	0
09/11/2021 08:00	0.0	13.9	1,499.9	0.0	0.0	1	1	0
09/11/2021 09:00	0.0	13.9	1,581.0	0.0	0.0	1	1	0
09/11/2021 10:00	0.0	13.8	1,663.1	0.0	0.0	1	1	0
09/11/2021 11:00	0.0	13.8	1,644.5	0.0	0.0	1	1	1
09/11/2021 12:00	0.1	12.6	2,005.0	0.0	0.3	1	1	1
09/11/2021 13:00	0.0	12.4	1,992.6	0.0	0.0	1	1	1
09/11/2021 14:00	0.0	13.9	1,656.8	0.0	0.0	1	1	0
09/11/2021 15:00	0.0	13.7	1,694.0	0.0	0.0	1	1	1
09/11/2021 16:00	0.4	12.5	2,007.0	0.1	1.3	1	1	1
09/11/2021 17:00	0.0	11.8	2,158.4	0.1	0.0	1	1	1
09/11/2021 18:00	0.0	11.8	2,135.8	0.1	0.0	1	1	1
09/11/2021 19:00	0.0	12.1	2,084.2	0.0	0.0	1	1	1
09/11/2021 20:00	0.0	11.9	2,125.6	0.0	0.0	1	1	1
09/11/2021 21:00	0.0	11.9	2,143.5	0.0	0.0	1	1	1
09/11/2021 22:00	0.0	12.1	2,102.3	0.0	0.0	1	1	1
09/11/2021 23:00	0.0	12.1	2,119.4	0.0	0.0	1	1	1
Average/Sum#:	0.1	13.0	1,854.1	0.1	8.2 #	24 #	24 #	16 #
Minimum:	0.0	11.8	1,499.9	0.0	0.0	1	1	0
Maximum:	0.8	13.9	2,158.4	0.4	2.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/12/2021 00:00	0.1	12.5	1,988.3	0.0	0.3	1	1	1
09/12/2021 01:00	0.0	13.9	1,666.9	0.0	0.0	1	1	0
09/12/2021 02:00	0.0	13.9	1,627.1	0.0	0.0	1	1	0
09/12/2021 03:00	0.6	13.8	1,616.9	0.2	1.8	1	1	1
09/12/2021 04:00	0.6	12.8	1,972.6	0.3	1.9	1	1	1
09/12/2021 05:00	0.8	13.0	1,909.9	0.5	2.6	1	1	1
09/12/2021 06:00	0.4	13.8	1,520.2	0.4	1.1	1	1	1
09/12/2021 07:00	0.0	13.9	1,562.6	0.3	0.0	1	1	0
09/12/2021 08:00	0.0	14.0	1,340.4	0.1	0.0	1	1	0
09/12/2021 09:00	0.0	14.0	1,277.1	0.0	0.0	1	1	0
09/12/2021 10:00	0.0	13.8	1,634.2	0.0	0.0	1	1	0
09/12/2021 11:00	0.0	13.8	1,693.6	0.0	0.0	1	1	1
09/12/2021 12:00	0.4	12.5	2,001.0	0.1	1.3	1	1	1
09/12/2021 13:00	0.0	12.1	2,043.8	0.1	0.0	1	1	1
09/12/2021 14:00	0.0	13.9	1,631.2	0.1	0.0	1	1	0
09/12/2021 15:00	0.0	13.8	1,617.1	0.0	0.0	1	1	1
09/12/2021 16:00	0.2	12.3	2,024.9	0.0	0.6	1	1	1
09/12/2021 17:00	0.0	11.8	2,145.6	0.0	0.0	1	1	1
09/12/2021 18:00	0.0	11.9	2,119.4	0.0	0.0	1	1	1
09/12/2021 19:00	0.0	12.1	2,087.6	0.0	0.0	1	1	1
09/12/2021 20:00	0.0	12.2	2,061.4	0.0	0.0	1	1	1
09/12/2021 21:00	0.0	12.3	2,044.7	0.0	0.0	1	1	1
09/12/2021 22:00	0.0	12.4	2,036.7	0.0	0.0	1	1	1
09/12/2021 23:00	0.0	12.4	2,030.3	0.0	0.0	1	1	1
Average/Sum#:	0.1	13.0	1,818.9	0.1	9.6 #	24 #	24 #	17 #
Minimum:	0.0	11.8	1,277.1	0.0	0.0	1	1	0
Maximum:	0.8	14.0	2,145.6	0.5	2.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/13/2021 00:00	0.3	12.9	1,903.6	0.1	0.9	1	1	1
09/13/2021 01:00	0.0	13.9	1,565.5	0.1	0.0	1	1	0
09/13/2021 02:00	0.0	13.9	1,551.7	0.1	0.0	1	1	0
09/13/2021 03:00	0.0	13.9	1,624.8	0.0	0.0	1	1	0
09/13/2021 04:00	0.0	14.0	1,318.4	0.0	0.0	1	1	0
09/13/2021 05:00	0.0	14.0	1,653.7	0.0	0.0	1	1	0
09/13/2021 06:00	0.9	13.2	1,765.5	0.2	2.7	1	1	1
09/13/2021 07:00	0.3	13.0	1,821.6	0.3	0.9	1	1	1
09/13/2021 08:00	0.0	13.9	1,520.2	0.3	0.0	1	1	0
09/13/2021 09:00	0.5	12.9	1,918.7	0.2	1.6	1	1	1
09/13/2021 10:00	0.3	12.7	1,921.0	0.2	0.9	1	1	1
09/13/2021 11:00	0.0	13.9	1,678.5	0.2	0.0	1	1	0
09/13/2021 12:00	0.0	13.8	1,655.2	0.1	0.0	1	1	0
09/13/2021 13:00	0.5	12.6	1,976.1	0.1	1.6	1	1	1
09/13/2021 14:00	0.0	11.8	2,128.0	0.1	0.0	1	1	1
09/13/2021 15:00	0.0	11.8	2,115.6	0.1	0.0	1	1	1
09/13/2021 16:00	0.0	11.8	2,112.8	0.0	0.0	1	1	1
09/13/2021 17:00	0.0	11.7	2,138.4	0.0	0.0	1	1	1
09/13/2021 18:00	0.0	11.7	2,144.2	0.0	0.0	1	1	1
09/13/2021 19:00	0.0	11.7	2,144.5	0.0	0.0	1	1	1
09/13/2021 20:00	0.0	11.9	2,124.8	0.0	0.0	1	1	1
09/13/2021 21:00	0.0	12.1	2,081.4	0.0	0.0	1	1	1
09/13/2021 22:00	0.0	12.4	2,035.1	0.0	0.0	1	1	1
09/13/2021 23:00	0.2	12.8	1,926.9	0.0	0.6	1	1	1
Average/Sum#:	0.1	12.8	1,867.8	0.1	9.2 #	24 #	24 #	16 #
Minimum:	0.0	11.7	1,318.4	0.0	0.0	1	1	0
Maximum:	0.9	14.0	2,144.5	0.3	2.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/14/2021 00:00	0.4	12.9	1,905.8	0.1	1.3	1	1	1
09/14/2021 01:00	0.0	13.9	1,547.6	0.1	0.0	1	1	0
09/14/2021 02:00	0.0	13.9	1,527.3	0.1	0.0	1	1	0
09/14/2021 03:00	0.0	13.9	1,527.1	0.0	0.0	1	1	0
09/14/2021 04:00	0.0	13.9	1,482.2	0.0	0.0	1	1	0
09/14/2021 05:00	1.2	12.9	1,957.4	0.3	3.9	1	1	1
09/14/2021 06:00	0.6	12.8	1,960.5	0.4	1.9	1	1	1
09/14/2021 07:00	0.0	13.9	1,624.6	0.4	0.0	1	1	0
09/14/2021 08:00	0.0	13.9	1,485.9	0.1	0.0	1	1	0
09/14/2021 09:00	0.0	13.9	1,457.4	0.0	0.0	1	1	0
09/14/2021 10:00	0.0	13.9	1,635.0	0.0	0.0	1	1	0
09/14/2021 11:00	0.0	13.9	1,681.5	0.0	0.0	1	1	0
09/14/2021 12:00	0.0	13.9	1,519.1	0.0	0.0	1	1	1
09/14/2021 13:00	1.0	12.7	1,961.5	0.2	3.2	1	1	1
09/14/2021 14:00	0.1	12.2	2,028.5	0.3	0.3	1	1	1
09/14/2021 15:00	0.0	13.8	1,661.0	0.3	0.0	1	1	0
09/14/2021 16:00	0.0	13.9	1,584.1	0.0	0.0	1	1	1
09/14/2021 17:00	0.3	12.3	2,024.0	0.1	0.9	1	1	1
09/14/2021 18:00	0.0	11.9	2,114.4	0.1	0.0	1	1	1
09/14/2021 19:00	0.0	12.4	1,977.1	0.1	0.0	1	1	1
09/14/2021 20:00	0.0	13.9	1,665.0	0.0	0.0	1	1	0
09/14/2021 21:00	0.0	13.8	1,712.3	0.0	0.0	1	1	1
09/14/2021 22:00	0.4	12.6	1,983.0	0.1	1.3	1	1	1
09/14/2021 23:00	0.3	12.8	1,911.2	0.2	0.9	1	1	1
Average/Sum#:	0.2	13.3	1,747.2	0.1	13.7 #	24 #	24 #	13 #
Minimum:	0.0	11.9	1,457.4	0.0	0.0	1	1	0
Maximum:	1.2	13.9	2,114.4	0.4	3.9	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/15/2021 00:00	0.0	13.9	1,520.9	0.2	0.0	1	1	0
09/15/2021 01:00	0.0	13.8	1,540.5	0.1	0.0	1	1	1
09/15/2021 02:00	0.6	12.7	1,966.0	0.1	1.9	1	1	1
09/15/2021 03:00	0.8	12.8	1,931.7	0.3	2.5	1	1	1
09/15/2021 04:00	0.0	13.8	1,659.4	0.3	0.0	1	1	1
09/15/2021 05:00	0.0	13.8	1,568.4	0.2	0.0	1	1	1
09/15/2021 06:00	0.9	12.8	1,952.9	0.2	2.9	1	1	1
09/15/2021 07:00	0.9	13.0	1,918.4	0.5	2.9	1	1	1
09/15/2021 08:00	0.0	13.9	1,452.9	0.5	0.0	1	1	0
09/15/2021 09:00	0.0	14.0	1,396.5	0.2	0.0	1	1	0
09/15/2021 10:00	0.0	14.0	1,525.8	0.0	0.0	1	1	0
09/15/2021 11:00	0.0	13.9	1,581.9	0.0	0.0	1	1	0
09/15/2021 12:00	0.0	13.9	1,514.1	0.0	0.0	1	1	1
09/15/2021 13:00	0.4	12.5	2,012.2	0.1	1.3	1	1	1
09/15/2021 14:00	0.1	12.3	2,023.9	0.1	0.3	1	1	1
09/15/2021 15:00	0.0	13.8	1,542.4	0.1	0.0	1	1	1
09/15/2021 16:00	0.0	13.8	1,558.9	0.0	0.0	1	1	1
09/15/2021 17:00	0.2	12.4	2,004.3	0.0	0.6	1	1	1
09/15/2021 18:00	0.0	12.3	2,020.7	0.0	0.0	1	1	1
09/15/2021 19:00	0.2	12.7	1,938.3	0.1	0.6	1	1	1
09/15/2021 20:00	0.1	13.6	1,663.4	0.1	0.3	1	1	1
09/15/2021 21:00	0.0	13.9	1,587.6	0.1	0.0	1	1	1
09/15/2021 22:00	1.5	13.0	1,907.1	0.4	4.8	1	1	1
09/15/2021 23:00	1.5	13.0	1,903.4	0.7	4.8	1	1	1
Average/Sum#:	0.3	13.3	1,737.2	0.2	22.9 #	24 #	24 #	19 #
Minimum:	0.0	12.3	1,396.5	0.0	0.0	1	1	0
Maximum:	1.5	14.0	2,023.9	0.7	4.8	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/16/2021 00:00	1.0	13.5	1,683.4	1.0	3.0	1	1	1
09/16/2021 01:00	9.6	14.9	911.5	0.0	8.7	1	0	0
09/16/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/16/2021 12:00	16.3	18.9	162.2	0.0	3.5	1	0	0
09/16/2021 13:00	26.0	15.8	794.0	0.0	53.5	1	0	0
09/16/2021 14:00	0.0	13.9	1,665.5	0.0	0.0	1	1	0
09/16/2021 15:00	0.0	13.9	1,614.5	0.0	0.0	1	1	0
09/16/2021 16:00	0.0	13.9	1,509.4	0.0	0.0	1	1	1
09/16/2021 17:00	0.5	12.4	2,051.8	0.1	1.6	1	1	1
09/16/2021 18:00	0.0	12.1	2,071.2	0.1	0.0	1	1	1
09/16/2021 19:00	0.1	12.8	1,938.0	0.1	0.3	1	1	1
09/16/2021 20:00	0.0	13.6	1,685.0	0.0	0.0	1	1	1
09/16/2021 21:00	0.0	13.8	1,642.1	0.0	0.0	1	1	1
09/16/2021 22:00	0.4	12.6	1,994.2	0.1	1.3	1	1	1
09/16/2021 23:00	0.5	12.9	1,927.6	0.2	1.6	1	1	1
Average/Sum#:	3.9	13.9	1,546.5	0.2	73.5 #	14 #	11 #	9 #
Minimum:	0.0	12.1	162.2	0.0	0.0	0	0	0
Maximum:	26.0	18.9	2,071.2	1.0	53.5	1	1	1
%SI	41.67	41.67	41.67	62.50	41.67	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/17/2021 00:00	1.0	13.0	1,907.8	0.5	3.2	1	1	1
09/17/2021 01:00	0.0	13.7	1,460.7	0.4	0.0	1	1	1
09/17/2021 02:00	29.1	16.6	304.7	0.0	4.6	1	0	0
09/17/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/17/2021 13:00	26.7	18.0	292.3	0.0	14.2	1	0	0
09/17/2021 14:00	22.1	15.8	768.3	0.0	44.0	1	0	0
09/17/2021 15:00	0.0	14.0	1,474.6	0.0	0.0	1	1	0
09/17/2021 16:00	0.0	13.8	1,575.6	0.0	0.0	1	1	1
09/17/2021 17:00	0.2	12.4	2,025.4	0.0	0.6	1	1	1
09/17/2021 18:00	0.0	12.0	2,103.9	0.0	0.0	1	1	1
09/17/2021 19:00	0.1	12.6	1,969.4	0.1	0.3	1	1	1
09/17/2021 20:00	0.7	13.0	1,899.6	0.2	2.2	1	1	1
09/17/2021 21:00	0.6	12.9	1,923.3	0.3	1.9	1	1	1
09/17/2021 22:00	0.7	12.9	1,922.6	0.5	2.2	1	1	1
09/17/2021 23:00	0.1	13.7	1,472.3	0.3	0.3	1	1	1
Average/Sum#:	5.8	13.9	1,507.2	0.3	73.5 #	14 #	11 #	10 #
Minimum:	0.0	12.0	292.3	0.0	0.0	0	0	0
Maximum:	29.1	18.0	2,103.9	0.5	44.0	1	1	1
%SI	41.67	41.67	41.67	62.50	41.67	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/18/2021 00:00	30.9	16.4	316.6	0.0	4.3	1	0	0
09/18/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/18/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/18/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/18/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/18/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/18/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/18/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/18/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/18/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/18/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/18/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/18/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/18/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/18/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/18/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/18/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/18/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/18/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/18/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/18/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/18/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/18/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/18/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	30.9	16.4	316.6	0.0	4.3 #	1 #	0 #	0 #
Minimum:	30.9	16.4	316.6	0.0	4.3	0	0	0
Maximum:	30.9	16.4	316.6	0.0	4.3	1	0	0
%SI	95.83	95.83	95.83	100.00	95.83	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/19/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/19/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/20/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/20/2021 01:00	110.9	18.3	245.1	0.0	41.4	1	0	0
09/20/2021 02:00	28.6	16.9	479.2	0.0	45.3	1	0	0
09/20/2021 03:00	0.2	14.1	1,283.8	0.0	0.5	1	0	0
09/20/2021 04:00	0.0	14.0	1,432.1	0.0	0.0	1	1	0
09/20/2021 05:00	1.7	13.3	1,852.9	0.0	5.5	1	1	1
09/20/2021 06:00	1.3	13.0	1,960.2	0.8	4.3	1	1	1
09/20/2021 07:00	0.2	13.8	1,486.8	0.8	0.6	1	1	1
09/20/2021 08:00	0.0	14.1	1,284.3	0.4	0.0	1	1	0
09/20/2021 09:00	0.0	14.1	1,286.6	0.1	0.0	1	1	0
09/20/2021 10:00	0.0	14.1	1,289.3	0.0	0.0	1	1	0
09/20/2021 11:00	0.0	13.9	1,571.0	0.0	0.0	1	1	1
09/20/2021 12:00	0.5	12.9	1,953.3	0.1	1.6	1	1	1
09/20/2021 13:00	0.2	12.8	1,965.1	0.2	0.6	1	1	1
09/20/2021 14:00	0.0	13.7	1,562.4	0.2	0.0	1	1	1
09/20/2021 15:00	0.0	13.9	1,527.7	0.0	0.0	1	1	1
09/20/2021 16:00	0.5	12.5	2,021.7	0.1	1.6	1	1	1
09/20/2021 17:00	0.0	11.8	2,174.0	0.1	0.0	1	1	1
09/20/2021 18:00	0.0	11.9	2,170.9	0.1	0.0	1	1	1
09/20/2021 19:00	0.0	12.0	2,142.6	0.0	0.0	1	1	1
09/20/2021 20:00	0.0	12.1	2,110.3	0.0	0.0	1	1	1
09/20/2021 21:00	0.0	12.4	2,061.6	0.0	0.0	1	1	1
09/20/2021 22:00	0.5	13.0	1,935.9	0.1	1.6	1	1	1
09/20/2021 23:00	1.0	13.1	1,893.7	0.4	3.2	1	1	1
Average/Sum#:	6.3	13.6	1,638.7	0.2	106.2 #	23 #	20 #	16 #
Minimum:	0.0	11.8	245.1	0.0	0.0	0	0	0
Maximum:	110.9	18.3	2,174.0	0.8	45.3	1	1	1
%SI	4.17	4.17	4.17	25.00	4.17	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/21/2021 00:00	0.0	13.9	1,661.9	0.4	0.0	1	1	0
09/21/2021 01:00	0.0	13.9	1,565.4	0.3	0.0	1	1	1
09/21/2021 02:00	2.7	13.2	1,910.5	0.7	8.8	1	1	1
09/21/2021 03:00	2.0	13.2	1,902.3	1.2	6.5	1	1	1
09/21/2021 04:00	2.2	13.2	1,900.9	1.8	7.2	1	1	1
09/21/2021 05:00	1.8	13.2	1,916.2	1.5	5.9	1	1	1
09/21/2021 06:00	0.1	12.7	2,041.5	1.1	0.3	1	1	1
09/21/2021 07:00	1.7	13.1	1,901.9	0.9	5.5	1	1	1
09/21/2021 08:00	0.0	14.0	1,464.5	0.5	0.0	1	1	0
09/21/2021 09:00	0.0	14.0	1,523.5	0.4	0.0	1	1	0
09/21/2021 10:00	0.0	13.9	1,651.5	0.0	0.0	1	1	0
09/21/2021 11:00	0.0	14.0	1,619.2	0.0	0.0	1	1	1
09/21/2021 12:00	0.7	12.7	1,993.4	0.2	2.2	1	1	1
09/21/2021 13:00	0.0	12.0	2,123.1	0.2	0.0	1	1	1
09/21/2021 14:00	0.0	12.0	2,123.2	0.2	0.0	1	1	1
09/21/2021 15:00	0.0	11.9	2,137.2	0.0	0.0	1	1	1
09/21/2021 16:00	0.0	11.9	2,148.8	0.0	0.0	1	1	1
09/21/2021 17:00	0.0	11.8	2,160.3	0.0	0.0	1	1	1
09/21/2021 18:00	0.0	11.8	2,172.6	0.0	0.0	1	1	1
09/21/2021 19:00	0.0	11.9	2,139.9	0.0	0.0	1	1	1
09/21/2021 20:00	0.0	12.0	2,144.1	0.0	0.0	1	1	1
09/21/2021 21:00	0.0	12.2	2,106.0	0.0	0.0	1	1	1
09/21/2021 22:00	0.0	12.3	2,071.9	0.0	0.0	1	1	1
09/21/2021 23:00	0.2	12.6	2,002.4	0.0	0.6	1	1	1
Average/Sum#:	0.5	12.8	1,932.6	0.4	37.0 #	24 #	24 #	20 #
Minimum:	0.0	11.8	1,464.5	0.0	0.0	1	1	0
Maximum:	2.7	14.0	2,172.6	1.8	8.8	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/22/2021 00:00	0.0	13.8	1,607.2	0.0	0.0	1	1	1
09/22/2021 01:00	0.0	13.8	1,638.3	0.0	0.0	1	1	1
09/22/2021 02:00	2.0	13.1	1,898.6	0.5	6.4	1	1	1
09/22/2021 03:00	2.1	13.1	1,895.0	1.0	6.7	1	1	1
09/22/2021 04:00	0.8	12.8	2,002.8	1.2	2.6	1	1	1
09/22/2021 05:00	0.0	12.2	2,114.0	0.7	0.0	1	1	1
09/22/2021 06:00	0.1	12.6	2,046.4	0.2	0.3	1	1	1
09/22/2021 07:00	1.4	13.1	1,896.4	0.4	4.5	1	1	1
09/22/2021 08:00	0.0	13.9	1,618.8	0.4	0.0	1	1	0
09/22/2021 09:00	0.0	13.8	1,712.7	0.4	0.0	1	1	0
09/22/2021 10:00	0.5	13.0	1,902.3	0.1	1.6	1	1	1
09/22/2021 11:00	0.1	12.5	2,003.1	0.2	0.3	1	1	1
09/22/2021 12:00	0.0	13.9	1,603.8	0.2	0.0	1	1	0
09/22/2021 13:00	0.0	13.8	1,698.8	0.0	0.0	1	1	1
09/22/2021 14:00	0.3	12.4	2,034.0	0.1	0.9	1	1	1
09/22/2021 15:00	0.0	11.9	2,132.1	0.1	0.0	1	1	1
09/22/2021 16:00	0.0	11.8	2,154.4	0.1	0.0	1	1	1
09/22/2021 17:00	0.0	11.8	2,147.2	0.0	0.0	1	1	1
09/22/2021 18:00	0.0	11.9	2,154.4	0.0	0.0	1	1	1
09/22/2021 19:00	0.0	12.3	2,035.1	0.0	0.0	1	1	1
09/22/2021 20:00	0.0	13.9	1,629.9	0.0	0.0	1	1	0
09/22/2021 21:00	0.0	13.7	1,741.8	0.0	0.0	1	1	1
09/22/2021 22:00	0.5	12.7	1,973.4	0.1	1.6	1	1	1
09/22/2021 23:00	0.0	12.5	2,030.0	0.1	0.0	1	1	1
Average/Sum#:	0.3	12.9	1,902.9	0.2	24.9 #	24 #	24 #	20 #
Minimum:	0.0	11.8	1,603.8	0.0	0.0	1	1	0
Maximum:	2.1	13.9	2,154.4	1.2	6.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/23/2021 00:00	0.3	12.9	1,915.3	0.2	0.9	1	1	1
09/23/2021 01:00	0.0	13.9	1,544.6	0.1	0.0	1	1	0
09/23/2021 02:00	0.0	14.0	1,523.2	0.1	0.0	1	1	0
09/23/2021 03:00	0.0	14.0	1,623.4	0.0	0.0	1	1	0
09/23/2021 04:00	0.0	13.9	1,567.3	0.0	0.0	1	1	1
09/23/2021 05:00	0.3	12.7	2,000.5	0.1	1.0	1	1	1
09/23/2021 06:00	0.4	12.8	1,961.4	0.2	1.3	1	1	1
09/23/2021 07:00	0.0	13.9	1,644.7	0.2	0.0	1	1	0
09/23/2021 08:00	0.0	14.0	1,392.5	0.1	0.0	1	1	0
09/23/2021 09:00	0.0	13.7	1,736.5	0.0	0.0	1	1	0
09/23/2021 10:00	0.0	13.7	1,735.1	0.0	0.0	1	1	0
09/23/2021 11:00	0.0	13.7	1,729.2	0.0	0.0	1	1	0
09/23/2021 12:00	0.0	13.7	1,726.4	0.0	0.0	1	1	0
09/23/2021 13:00	0.0	13.7	1,724.7	0.0	0.0	1	1	0
09/23/2021 14:00	0.0	13.7	1,725.2	0.0	0.0	1	1	0
09/23/2021 15:00	0.0	13.7	1,724.3	0.0	0.0	1	1	0
09/23/2021 16:00	0.0	13.7	1,722.4	0.0	0.0	1	1	0
09/23/2021 17:00	0.0	13.7	1,724.6	0.0	0.0	1	1	0
09/23/2021 18:00	0.0	13.8	1,730.3	0.0	0.0	1	1	0
09/23/2021 19:00	0.0	13.8	1,732.8	0.0	0.0	1	1	0
09/23/2021 20:00	0.0	13.7	1,732.7	0.0	0.0	1	1	0
09/23/2021 21:00	0.0	13.8	1,732.8	0.0	0.0	1	1	0
09/23/2021 22:00	0.0	13.7	1,732.8	0.0	0.0	1	1	0
09/23/2021 23:00	0.0	13.7	1,736.0	0.0	0.0	1	1	0
Average/Sum#:	0.0	13.7	1,713.3	0.0	3.2 #	24 #	24 #	4 #
Minimum:	0.0	12.7	1,392.5	0.0	0.0	1	1	0
Maximum:	0.4	14.0	2,000.5	0.2	1.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/24/2021 00:00	0.0	13.7	1,736.8	0.0	0.0	1	1	0
09/24/2021 01:00	0.0	13.7	1,737.3	0.0	0.0	1	1	0
09/24/2021 02:00	0.0	13.7	1,738.3	0.0	0.0	1	1	0
09/24/2021 03:00	0.0	13.7	1,738.6	0.0	0.0	1	1	0
09/24/2021 04:00	0.0	13.7	1,745.1	0.0	0.0	1	1	0
09/24/2021 05:00	0.0	13.7	1,751.2	0.0	0.0	1	1	0
09/24/2021 06:00	0.0	13.7	1,751.5	0.0	0.0	1	1	0
09/24/2021 07:00	0.0	13.7	1,748.1	0.0	0.0	1	1	0
09/24/2021 08:00	0.0	13.7	1,742.3	0.0	0.0	1	1	0
09/24/2021 09:00	0.0	13.9	1,636.2	0.0	0.0	1	1	0
09/24/2021 10:00	0.0	13.9	1,515.9	0.0	0.0	1	1	0
09/24/2021 11:00	0.0	14.0	1,584.2	0.0	0.0	1	1	0
09/24/2021 12:00	0.0	14.0	1,579.0	0.0	0.0	1	1	0
09/24/2021 13:00	0.0	13.9	1,640.9	0.0	0.0	1	1	0
09/24/2021 14:00	0.0	13.8	1,678.6	0.0	0.0	1	1	0
09/24/2021 15:00	0.0	13.8	1,670.9	0.0	0.0	1	1	0
09/24/2021 16:00	0.0	13.8	1,657.4	0.0	0.0	1	1	0
09/24/2021 17:00	0.0	13.8	1,695.7	0.0	0.0	1	1	0
09/24/2021 18:00	0.0	13.9	1,637.3	0.0	0.0	1	1	0
09/24/2021 19:00	0.0	13.9	1,671.8	0.0	0.0	1	1	0
09/24/2021 20:00	0.0	13.9	1,615.8	0.0	0.0	1	1	0
09/24/2021 21:00	0.0	13.9	1,592.7	0.0	0.0	1	1	0
09/24/2021 22:00	0.0	13.9	1,627.7	0.0	0.0	1	1	0
09/24/2021 23:00	0.0	13.9	1,623.4	0.0	0.0	1	1	0
Average/Sum#:	0.0	13.8	1,671.5	0.0	0.0 #	24 #	24 #	0 #
Minimum:	0.0	13.7	1,515.9	0.0	0.0	1	1	0
Maximum:	0.0	14.0	1,751.5	0.0	0.0	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/25/2021 00:00	0.0	13.9	1,552.3	0.0	0.0	1	1	0
09/25/2021 01:00	0.0	13.9	1,618.0	0.0	0.0	1	1	0
09/25/2021 02:00	0.0	13.9	1,646.8	0.0	0.0	1	1	0
09/25/2021 03:00	0.0	13.9	1,645.9	0.0	0.0	1	1	0
09/25/2021 04:00	0.0	13.9	1,601.4	0.0	0.0	1	1	0
09/25/2021 05:00	0.0	13.9	1,581.9	0.0	0.0	1	1	0
09/25/2021 06:00	0.0	13.9	1,636.0	0.0	0.0	1	1	0
09/25/2021 07:00	0.0	13.9	1,623.5	0.0	0.0	1	1	0
09/25/2021 08:00	0.0	13.9	1,521.2	0.0	0.0	1	1	0
09/25/2021 09:00	0.0	14.0	1,328.5	0.0	0.0	1	1	0
09/25/2021 10:00	0.0	14.0	1,508.5	0.0	0.0	1	1	0
09/25/2021 11:00	0.0	13.9	1,637.1	0.0	0.0	1	1	0
09/25/2021 12:00	0.0	13.9	1,644.7	0.0	0.0	1	1	0
09/25/2021 13:00	0.0	13.9	1,638.9	0.0	0.0	1	1	0
09/25/2021 14:00	0.0	13.9	1,667.3	0.0	0.0	1	1	0
09/25/2021 15:00	0.0	13.8	1,662.9	0.0	0.0	1	1	0
09/25/2021 16:00	0.0	13.9	1,613.2	0.0	0.0	1	1	0
09/25/2021 17:00	0.0	14.0	1,316.6	0.0	0.0	1	1	0
09/25/2021 18:00	0.0	13.9	1,602.4	0.0	0.0	1	1	0
09/25/2021 19:00	0.0	13.9	1,664.1	0.0	0.0	1	1	0
09/25/2021 20:00	0.0	13.9	1,640.2	0.0	0.0	1	1	0
09/25/2021 21:00	0.0	13.9	1,548.2	0.0	0.0	1	1	0
09/25/2021 22:00	0.0	14.0	1,344.3	0.0	0.0	1	1	0
09/25/2021 23:00	0.0	14.0	1,310.5	0.0	0.0	1	1	0
Average/Sum#:	0.0	13.9	1,564.8	0.0	0.0 #	24 #	24 #	0 #
Minimum:	0.0	13.8	1,310.5	0.0	0.0	1	1	0
Maximum:	0.0	14.0	1,667.3	0.0	0.0	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/26/2021 00:00	0.0	14.0	1,313.2	0.0	0.0	1	1	0
09/26/2021 01:00	0.0	14.0	1,318.1	0.0	0.0	1	1	0
09/26/2021 02:00	0.0	14.0	1,323.5	0.0	0.0	1	1	0
09/26/2021 03:00	0.0	14.0	1,322.0	0.0	0.0	1	1	0
09/26/2021 04:00	0.0	14.0	1,323.2	0.0	0.0	1	1	0
09/26/2021 05:00	0.0	14.0	1,330.2	0.0	0.0	1	1	0
09/26/2021 06:00	0.0	14.0	1,372.8	0.0	0.0	1	1	0
09/26/2021 07:00	0.0	14.0	1,367.0	0.0	0.0	1	1	0
09/26/2021 08:00	0.0	14.0	1,326.1	0.0	0.0	1	1	0
09/26/2021 09:00	0.0	14.0	1,329.0	0.0	0.0	1	1	0
09/26/2021 10:00	0.0	14.0	1,356.2	0.0	0.0	1	1	0
09/26/2021 11:00	0.0	14.0	1,434.8	0.0	0.0	1	1	0
09/26/2021 12:00	0.0	14.0	1,329.5	0.0	0.0	1	1	0
09/26/2021 13:00	0.0	14.0	1,359.4	0.0	0.0	1	1	0
09/26/2021 14:00	0.0	14.0	1,362.0	0.0	0.0	1	1	0
09/26/2021 15:00	0.0	14.0	1,433.4	0.0	0.0	1	1	0
09/26/2021 16:00	0.0	14.0	1,415.0	0.0	0.0	1	1	0
09/26/2021 17:00	0.0	14.0	1,334.4	0.0	0.0	1	1	0
09/26/2021 18:00	0.0	14.0	1,323.7	0.0	0.0	1	1	0
09/26/2021 19:00	0.0	14.0	1,315.2	0.0	0.0	1	1	0
09/26/2021 20:00	0.0	14.0	1,316.4	0.0	0.0	1	1	0
09/26/2021 21:00	0.0	14.0	1,316.8	0.0	0.0	1	1	0
09/26/2021 22:00	0.0	14.0	1,317.8	0.0	0.0	1	1	0
09/26/2021 23:00	0.0	14.0	1,319.9	0.0	0.0	1	1	0
Average/Sum#:	0.0	14.0	1,344.2	0.0	0.0 #	24 #	24 #	0 #
Minimum:	0.0	14.0	1,313.2	0.0	0.0	1	1	0
Maximum:	0.0	14.0	1,434.8	0.0	0.0	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/27/2021 00:00	0.0	14.0	1,319.1	0.0	0.0	1	1	0
09/27/2021 01:00	0.0	14.0	1,318.1	0.0	0.0	1	1	0
09/27/2021 02:00	0.0	14.0	1,320.2	0.0	0.0	1	1	0
09/27/2021 03:00	0.0	14.0	1,320.1	0.0	0.0	1	1	0
09/27/2021 04:00	0.0	13.9	1,401.6	0.0	0.0	1	1	0
09/27/2021 05:00	0.0	13.8	1,659.9	0.0	0.0	1	1	0
09/27/2021 06:00	0.0	13.9	1,610.2	0.0	0.0	1	1	0
09/27/2021 07:00	0.0	13.9	1,472.0	0.0	0.0	1	1	0
09/27/2021 08:00	0.0	14.0	1,319.9	0.0	0.0	1	1	0
09/27/2021 09:00	0.0	14.0	1,319.3	0.0	0.0	1	1	0
09/27/2021 10:00	0.0	14.0	1,328.2	0.0	0.0	1	1	0
09/27/2021 11:00	0.0	14.0	1,332.5	0.0	0.0	1	1	0
09/27/2021 12:00	0.0	14.0	1,333.2	0.0	0.0	1	1	0
09/27/2021 13:00	0.0	14.0	1,329.4	0.0	0.0	1	1	0
09/27/2021 14:00	0.0	14.0	1,331.6	0.0	0.0	1	1	0
09/27/2021 15:00	0.0	14.0	1,325.6	0.0	0.0	1	1	0
09/27/2021 16:00	0.0	13.9	1,453.7	0.0	0.0	1	1	0
09/27/2021 17:00	0.0	14.0	1,364.5	0.0	0.0	1	1	0
09/27/2021 18:00	0.0	14.0	1,456.9	0.0	0.0	1	1	0
09/27/2021 19:00	0.0	14.0	1,462.7	0.0	0.0	1	1	0
09/27/2021 20:00	0.0	13.9	1,571.5	0.0	0.0	1	1	0
09/27/2021 21:00	0.0	14.0	1,415.2	0.0	0.0	1	1	0
09/27/2021 22:00	0.0	14.0	1,379.9	0.0	0.0	1	1	0
09/27/2021 23:00	0.0	14.0	1,320.0	0.0	0.0	1	1	0
Average/Sum#:	0.0	14.0	1,394.4	0.0	0.0 #	24 #	24 #	0 #
Minimum:	0.0	13.8	1,318.1	0.0	0.0	1	1	0
Maximum:	0.0	14.0	1,659.9	0.0	0.0	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/28/2021 00:00	0.0	14.0	1,321.8	0.0	0.0	1	1	0
09/28/2021 01:00	0.0	14.0	1,321.4	0.0	0.0	1	1	0
09/28/2021 02:00	0.0	14.0	1,319.6	0.0	0.0	1	1	0
09/28/2021 03:00	0.0	14.0	1,318.0	0.0	0.0	1	1	0
09/28/2021 04:00	0.0	14.0	1,421.4	0.0	0.0	1	1	0
09/28/2021 05:00	0.0	14.0	1,341.8	0.0	0.0	1	1	0
09/28/2021 06:00	0.0	14.0	1,504.3	0.0	0.0	1	1	0
09/28/2021 07:00	0.0	14.0	1,420.7	0.0	0.0	1	1	0
09/28/2021 08:00	0.0	14.0	1,438.2	0.0	0.0	1	1	0
09/28/2021 09:00	0.0	14.0	1,336.7	0.0	0.0	1	1	0
09/28/2021 10:00	0.0	14.1	1,340.8	0.0	0.0	1	1	0
09/28/2021 11:00	0.0	14.1	1,344.3	0.0	0.0	1	1	0
09/28/2021 12:00	0.0	14.1	1,344.2	0.0	0.0	1	1	0
09/28/2021 13:00	0.0	14.1	1,344.9	0.0	0.0	1	1	0
09/28/2021 14:00	0.0	14.1	1,344.7	0.0	0.0	1	1	0
09/28/2021 15:00	0.0	14.1	1,343.2	0.0	0.0	1	1	0
09/28/2021 16:00	0.0	14.0	1,461.7	0.0	0.0	1	1	1
09/28/2021 17:00	1.3	12.7	2,020.9	0.3	4.2	1	1	1
09/28/2021 18:00	0.2	12.1	2,133.9	0.3	0.6	1	1	1
09/28/2021 19:00	1.2	13.0	1,927.9	0.6	3.9	1	1	1
09/28/2021 20:00	2.0	13.1	1,907.3	0.8	6.5	1	1	1
09/28/2021 21:00	2.1	13.1	1,888.7	1.3	6.7	1	1	1
09/28/2021 22:00	0.0	14.0	1,353.7	1.0	0.0	1	1	0
09/28/2021 23:00	0.0	14.1	1,324.7	0.5	0.0	1	1	0
Average/Sum#:	0.3	13.8	1,492.7	0.2	21.9 #	24 #	24 #	6 #
Minimum:	0.0	12.1	1,318.0	0.0	0.0	1	1	0
Maximum:	2.1	14.1	2,133.9	1.3	6.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/29/2021 00:00	0.0	14.1	1,324.8	0.0	0.0	1	1	0
09/29/2021 01:00	0.0	14.0	1,324.9	0.0	0.0	1	1	0
09/29/2021 02:00	0.0	14.0	1,323.8	0.0	0.0	1	1	0
09/29/2021 03:00	0.0	13.9	1,611.5	0.0	0.0	1	1	0
09/29/2021 04:00	0.0	13.9	1,616.2	0.0	0.0	1	1	0
09/29/2021 05:00	0.0	13.8	1,733.8	0.0	0.0	1	1	0
09/29/2021 06:00	0.0	13.7	1,773.0	0.0	0.0	1	1	0
09/29/2021 07:00	0.0	13.7	1,768.9	0.0	0.0	1	1	0
09/29/2021 08:00	0.0	13.7	1,759.0	0.0	0.0	1	1	0
09/29/2021 09:00	0.0	13.9	1,493.7	0.0	0.0	1	1	0
09/29/2021 10:00	0.0	14.0	1,537.1	0.0	0.0	1	1	0
09/29/2021 11:00	0.0	13.9	1,463.8	0.0	0.0	1	1	0
09/29/2021 12:00	0.0	14.1	1,462.1	0.0	0.0	1	1	0
09/29/2021 13:00	0.0	14.0	1,619.6	0.0	0.0	1	1	0
09/29/2021 14:00	0.0	13.9	1,650.9	0.0	0.0	1	1	0
09/29/2021 15:00	0.0	13.9	1,658.9	0.0	0.0	1	1	0
09/29/2021 16:00	0.0	13.9	1,645.7	0.0	0.0	1	1	0
09/29/2021 17:00	0.0	14.0	1,415.3	0.0	0.0	1	1	0
09/29/2021 18:00	0.0	14.1	1,373.6	0.0	0.0	1	1	0
09/29/2021 19:00	0.0	13.9	1,628.7	0.0	0.0	1	1	0
09/29/2021 20:00	0.0	13.9	1,644.4	0.0	0.0	1	1	0
09/29/2021 21:00	0.0	13.9	1,608.9	0.0	0.0	1	1	0
09/29/2021 22:00	0.0	13.9	1,637.4	0.0	0.0	1	1	0
09/29/2021 23:00	0.0	13.9	1,514.1	0.0	0.0	1	1	0
Average/Sum#:	0.0	13.9	1,566.3	0.0	0.0 #	24 #	24 #	0 #
Minimum:	0.0	13.7	1,323.8	0.0	0.0	1	1	0
Maximum:	0.0	14.1	1,773.0	0.0	0.0	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/30/2021 00:00	0.0	14.0	1,492.1	0.0	0.0	1	1	0
09/30/2021 01:00	0.0	14.1	1,306.7	0.0	0.0	1	1	0
09/30/2021 02:00	0.0	14.1	1,281.8	0.0	0.0	1	1	0
09/30/2021 03:00	0.0	14.0	1,534.4	0.0	0.0	1	1	0
09/30/2021 04:00	0.0	14.0	1,594.3	0.0	0.0	1	1	0
09/30/2021 05:00	0.0	14.1	1,319.4	0.0	0.0	1	1	0
09/30/2021 06:00	19.5	16.2	349.6	0.0	3.5	1	0	0
09/30/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/30/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/30/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/30/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/30/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/30/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/30/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/30/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/30/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/30/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/30/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/30/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/30/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/30/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/30/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/30/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/30/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	2.8	14.4	1,268.3	0.0	3.5 #	7 #	6 #	0 #
Minimum:	0.0	14.0	349.6	0.0	0.0	0	0	0
Maximum:	19.5	16.2	1,594.3	0.0	3.5	1	1	0
%SI	70.83	70.83	70.83	75.00	70.83	0.00	0.00	0.00

Excess Emission Report

CT1 - CO Lb 1-Day Block Average

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/04/2021 10:36 **Location:** Maxwell, CA

Tag Name: CT1_CO_Lb_1D
Total Operating Time: 1,776.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 432.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,776.00 Hour(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - CO Lb 1-Day Block Average

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/04/2021 10:37 **Location:** Maxwell, CA

Tag Name: CT2_CO_Lb_1D
Total Operating Time: 1,779.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 429.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,779.00 Hour(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

ATTACHMENT 8
Hourly Emissions – NH_3

FCD: AQ-18
Title V: #6

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
07/01/2021 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2021 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2021 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2021 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2021 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2021 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2021 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2021 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2021 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2021 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2021 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2021 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2021 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2021 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2021 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2021 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
07/02/2021 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2021 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2021 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2021 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2021 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2021 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2021 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2021 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2021 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2021 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2021 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2021 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2021 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2021 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2021 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2021 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
07/03/2021 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/03/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/03/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/03/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/03/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/03/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/03/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/03/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/03/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/03/2021 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/03/2021 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/03/2021 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/03/2021 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/03/2021 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/03/2021 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/03/2021 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/03/2021 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/03/2021 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/03/2021 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/03/2021 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/03/2021 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/03/2021 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/03/2021 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/03/2021 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
07/04/2021 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2021 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2021 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2021 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2021 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2021 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2021 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2021 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2021 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2021 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2021 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2021 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2021 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2021 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2021 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2021 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
07/05/2021 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/05/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/05/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/05/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/05/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/05/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/05/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/05/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/05/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/05/2021 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/05/2021 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/05/2021 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/05/2021 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/05/2021 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/05/2021 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/05/2021 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/05/2021 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/05/2021 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/05/2021 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/05/2021 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/05/2021 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/05/2021 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/05/2021 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/05/2021 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
07/06/2021 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/06/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/06/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/06/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/06/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/06/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/06/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/06/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/06/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/06/2021 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/06/2021 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/06/2021 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/06/2021 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/06/2021 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/06/2021 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/06/2021 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/06/2021 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/06/2021 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/06/2021 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/06/2021 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/06/2021 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/06/2021 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/06/2021 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/06/2021 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
07/07/2021 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/07/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/07/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/07/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/07/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/07/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/07/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/07/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/07/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/07/2021 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/07/2021 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/07/2021 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/07/2021 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/07/2021 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/07/2021 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/07/2021 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/07/2021 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/07/2021 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/07/2021 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/07/2021 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/07/2021 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/07/2021 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/07/2021 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/07/2021 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
07/08/2021 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/08/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/08/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/08/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/08/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/08/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/08/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/08/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/08/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/08/2021 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/08/2021 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/08/2021 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/08/2021 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/08/2021 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/08/2021 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/08/2021 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/08/2021 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/08/2021 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/08/2021 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/08/2021 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/08/2021 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/08/2021 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/08/2021 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/08/2021 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
07/09/2021 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/09/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/09/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/09/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/09/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/09/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/09/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/09/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/09/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/09/2021 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/09/2021 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/09/2021 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/09/2021 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/09/2021 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/09/2021 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/09/2021 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/09/2021 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/09/2021 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/09/2021 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/09/2021 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/09/2021 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/09/2021 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/09/2021 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/09/2021 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
07/10/2021 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/10/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/10/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/10/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/10/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/10/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/10/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/10/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/10/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/10/2021 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/10/2021 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/10/2021 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/10/2021 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/10/2021 13:00	37.6	17.3	61.6	0.0	1,117,692.0	277.5	0.0	0.0
07/10/2021 14:00	46.4	17.0	70.2	186.1	1,247,888.0	364.5	0.0	0.0
07/10/2021 15:00	48.8	15.7	55.4	282.2	1,645,117.9	636.7	5.4	1.3
07/10/2021 16:00	15.3	14.0	13.1	152.0	2,568,960.8	1,294.4	2.0	1.0
07/10/2021 17:00	10.1	13.6	8.2	145.9	3,041,787.6	1,643.7	1.6	1.0
07/10/2021 18:00	10.4	13.5	8.3	155.9	3,113,888.5	1,705.4	1.7	1.2
07/10/2021 19:00	10.4	13.5	8.3	147.5	3,125,209.0	1,711.6	1.6	1.0
07/10/2021 20:00	10.2	13.5	8.1	143.8	3,159,170.8	1,730.2	1.5	1.0
07/10/2021 21:00	10.0	13.5	8.0	140.8	3,181,264.1	1,742.3	1.5	1.0
07/10/2021 22:00	10.0	13.5	8.0	143.9	3,183,455.2	1,743.5	1.5	1.0
07/10/2021 23:00	13.9	14.3	12.4	152.5	2,670,377.5	1,326.0	1.9	0.9
Average/Sum#:	20.3	14.5	23.8	150.1	2,550,437.4	1,288.7	1.7	0.9
Minimum:	10.0	13.5	8.0	0.0	1,117,692.0	277.5	0.0	0.0
Maximum:	48.8	17.3	70.2	282.2	3,183,455.2	1,743.5	5.4	1.3
%SI	54.17	54.17	54.17	54.17	54.17	54.17	54.17	54.17

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
07/11/2021 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/11/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/11/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/11/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/11/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/11/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/11/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/11/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/11/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/11/2021 09:00	39.6	17.3	64.9	22.2	1,288,467.2	319.9	0.0	0.0
07/11/2021 10:00	45.1	16.9	66.5	281.4	1,398,867.0	408.6	6.3	1.0
07/11/2021 11:00	27.9	14.5	25.7	218.7	2,281,250.3	1,082.8	3.1	1.3
07/11/2021 12:00	9.8	13.8	8.1	90.7	2,662,469.6	1,380.4	1.1	0.6
07/11/2021 13:00	10.8	13.8	9.0	112.5	2,825,959.4	1,485.8	1.3	0.7
07/11/2021 14:00	10.4	13.6	8.4	134.0	3,109,333.6	1,680.2	1.5	1.0
07/11/2021 15:00	10.7	13.6	8.6	106.8	3,008,477.3	1,625.7	1.2	0.8
07/11/2021 16:00	10.7	13.5	8.5	111.2	3,071,294.6	1,704.5	1.2	0.9
07/11/2021 17:00	10.6	13.5	8.5	159.9	3,118,453.2	1,707.9	1.8	1.2
07/11/2021 18:00	10.5	13.5	8.4	147.0	3,131,964.9	1,715.3	1.6	1.0
07/11/2021 19:00	10.4	13.5	8.3	147.6	3,147,485.0	1,723.8	1.6	1.0
07/11/2021 20:00	10.2	13.5	8.1	142.2	3,145,841.7	1,722.9	1.5	1.0
07/11/2021 21:00	9.8	13.6	7.9	134.6	3,163,555.4	1,709.5	1.4	0.9
07/11/2021 22:00	9.6	13.7	7.9	130.1	3,197,699.7	1,704.6	1.4	0.9
07/11/2021 23:00	10.3	13.6	8.3	139.5	3,096,379.6	1,673.2	1.5	1.0
Average/Sum#:	15.8	14.1	17.1	138.6	2,776,499.9	1,443.0	1.8	0.9
Minimum:	9.6	13.5	7.9	22.2	1,288,467.2	319.9	0.0	0.0
Maximum:	45.1	17.3	66.5	281.4	3,197,699.7	1,723.8	6.3	1.3
%SI	37.50	37.50	37.50	37.50	37.50	37.50	37.50	37.50

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
07/12/2021 00:00	10.2	13.5	8.1	144.8	3,155,783.0	1,705.3	1.6	1.0
07/12/2021 01:00	24.0	16.2	30.1	195.6	1,296,302.3	501.7	5.1	1.0
07/12/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/12/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/12/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/12/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/12/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/12/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/12/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/12/2021 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/12/2021 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/12/2021 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/12/2021 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/12/2021 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/12/2021 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/12/2021 15:00	28.1	17.6	50.2	0.0	1,266,717.6	277.5	0.0	0.0
07/12/2021 16:00	30.5	14.9	30.0	159.5	2,476,832.2	1,085.2	2.1	0.9
07/12/2021 17:00	10.3	13.5	8.2	149.0	3,193,315.1	1,748.9	1.6	1.0
07/12/2021 18:00	10.0	13.6	8.1	135.7	3,203,527.8	1,731.1	1.4	0.9
07/12/2021 19:00	9.9	13.6	8.0	139.4	3,212,040.4	1,735.7	1.5	1.0
07/12/2021 20:00	10.2	13.5	8.1	142.6	3,233,667.4	1,771.0	1.5	1.1
07/12/2021 21:00	9.9	13.5	7.9	136.6	3,206,279.0	1,756.0	1.4	0.9
07/12/2021 22:00	13.2	14.3	11.8	140.0	2,740,459.9	1,360.8	1.7	1.0
07/12/2021 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	15.6	14.4	17.1	134.3	2,698,492.5	1,367.3	1.8	0.9
Minimum:	9.9	13.5	7.9	0.0	1,266,717.6	277.5	0.0	0.0
Maximum:	30.5	17.6	50.2	195.6	3,233,667.4	1,771.0	5.1	1.1
%SI	58.33	58.33	58.33	58.33	58.33	58.33	58.33	58.33

Daily Summary Report

CT1 - NH3 Slip



From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
07/13/2021 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/13/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/13/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/13/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/13/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/13/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/13/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/13/2021 07:00	34.1	17.4	57.5	68.2	1,384,363.6	333.6	0.0	0.0
07/13/2021 08:00	39.3	17.1	61.0	283.8	1,370,126.7	390.2	6.6	1.0
07/13/2021 09:00	33.3	17.3	54.6	269.2	1,245,095.1	345.5	7.0	0.9
07/13/2021 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/13/2021 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/13/2021 12:00	39.8	17.1	61.8	229.5	1,443,817.4	390.1	4.7	0.7
07/13/2021 13:00	44.9	16.0	54.1	264.1	1,661,836.8	618.9	5.0	1.2
07/13/2021 14:00	27.2	17.8	51.8	217.2	1,162,957.3	220.8	5.9	0.5
07/13/2021 15:00	47.0	16.0	56.6	280.5	1,810,926.8	661.2	4.7	1.2
07/13/2021 16:00	23.7	14.4	21.5	206.2	2,677,119.3	1,270.7	2.5	1.3
07/13/2021 17:00	10.3	13.5	8.2	134.7	3,209,383.0	1,757.7	1.4	0.9
07/13/2021 18:00	10.8	13.6	8.7	116.2	2,875,051.0	1,553.6	1.3	0.8
07/13/2021 19:00	10.6	13.5	8.5	137.9	3,152,780.1	1,726.7	1.5	1.0
07/13/2021 20:00	10.5	13.5	8.4	133.0	3,240,788.5	1,774.9	1.4	0.9
07/13/2021 21:00	13.4	14.3	12.0	137.2	2,772,985.1	1,397.2	1.6	0.8
07/13/2021 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/13/2021 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	26.5	15.5	35.7	190.6	2,154,402.4	957.0	3.4	0.9
Minimum:	10.3	13.5	8.2	68.2	1,162,957.3	220.8	0.0	0.0
Maximum:	47.0	17.8	61.8	283.8	3,240,788.5	1,774.9	7.0	1.3
%SI	45.83	45.83	45.83	45.83	45.83	45.83	45.83	45.83

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
07/14/2021 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/14/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/14/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/14/2021 03:00	41.2	16.3	52.8	223.8	1,750,684.6	562.5	3.8	0.8
07/14/2021 04:00	17.0	14.0	14.5	163.9	2,787,952.4	1,425.1	1.9	1.0
07/14/2021 05:00	10.0	13.8	8.3	109.7	3,194,510.7	1,702.9	1.1	0.7
07/14/2021 06:00	10.6	13.7	8.7	107.1	3,079,141.3	1,641.4	1.1	0.7
07/14/2021 07:00	10.1	13.7	8.3	106.9	3,151,364.4	1,679.9	1.1	0.7
07/14/2021 08:00	10.5	13.5	8.4	149.6	3,041,714.5	1,910.2	1.7	1.3
07/14/2021 09:00	10.5	13.4	8.3	152.2	3,209,769.6	1,992.3	1.6	1.2
07/14/2021 10:00	10.7	13.7	8.8	129.1	3,122,475.2	1,664.5	1.4	0.8
07/14/2021 11:00	10.6	13.7	8.7	121.4	2,992,098.5	1,595.0	1.4	0.8
07/14/2021 12:00	10.6	13.4	8.3	163.3	3,225,686.8	2,096.4	1.7	1.5
07/14/2021 13:00	10.6	13.4	8.3	197.7	3,158,993.8	2,237.6	2.2	1.8
07/14/2021 14:00	10.6	13.4	8.3	200.0	3,152,499.6	2,233.0	2.2	1.8
07/14/2021 15:00	10.5	13.4	8.3	195.4	3,164,083.6	2,218.1	2.2	1.8
07/14/2021 16:00	10.5	13.4	8.3	200.3	3,155,323.2	2,235.0	2.2	1.8
07/14/2021 17:00	10.5	13.4	8.3	200.1	3,160,687.9	2,238.8	2.2	1.8
07/14/2021 18:00	10.4	13.4	8.2	194.8	3,169,646.9	2,222.0	2.1	1.8
07/14/2021 19:00	10.4	13.4	8.2	183.9	3,202,538.8	2,174.9	2.0	1.7
07/14/2021 20:00	10.4	13.4	8.2	182.9	3,180,304.1	2,159.8	2.0	1.7
07/14/2021 21:00	10.4	13.4	8.2	175.5	3,214,647.7	2,112.7	1.9	1.5
07/14/2021 22:00	10.4	13.4	8.2	173.2	3,213,278.2	2,111.8	1.9	1.5
07/14/2021 23:00	10.3	13.4	8.1	167.8	3,239,227.2	2,105.2	1.8	1.5
Average/Sum#:	12.2	13.6	10.7	166.6	3,074,601.4	1,920.0	1.9	1.3
Minimum:	10.0	13.4	8.1	106.9	1,750,684.6	562.5	1.1	0.7
Maximum:	41.2	16.3	52.8	223.8	3,239,227.2	2,238.8	3.8	1.8
%SI	12.50	12.50	12.50	12.50	12.50	12.50	12.50	12.50

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
07/15/2021 00:00	10.1	13.4	7.9	153.6	3,210,822.5	2,016.4	1.6	1.2
07/15/2021 01:00	10.5	13.7	8.6	115.8	2,931,881.3	1,562.9	1.3	0.8
07/15/2021 02:00	10.4	13.7	8.5	105.7	2,871,416.7	1,509.7	1.2	0.8
07/15/2021 03:00	10.5	13.8	8.7	107.0	2,834,137.9	1,490.1	1.2	0.7
07/15/2021 04:00	9.8	13.8	8.1	118.2	3,212,894.7	1,712.7	1.2	0.9
07/15/2021 05:00	9.9	13.5	7.9	145.4	3,182,703.4	1,975.5	1.6	1.2
07/15/2021 06:00	10.2	13.5	8.1	151.1	3,248,242.8	2,039.9	1.6	1.2
07/15/2021 07:00	10.3	13.7	8.4	120.4	3,088,333.4	1,646.3	1.3	0.8
07/15/2021 08:00	10.3	13.8	8.6	120.4	3,088,896.2	1,646.6	1.3	0.8
07/15/2021 09:00	10.4	13.8	8.6	111.2	2,993,904.1	1,574.1	1.2	0.8
07/15/2021 10:00	9.8	13.8	8.1	114.6	3,189,807.8	1,677.1	1.2	0.8
07/15/2021 11:00	10.4	13.8	8.6	115.5	2,996,376.6	1,575.4	1.3	0.8
07/15/2021 12:00	10.9	13.2	8.4	158.0	3,238,919.5	2,105.0	1.7	1.5
07/15/2021 13:00	11.0	13.1	8.3	172.9	3,203,411.1	2,152.1	1.9	1.5
07/15/2021 14:00	11.0	13.1	8.3	176.2	3,204,158.6	2,176.0	1.9	1.5
07/15/2021 15:00	11.0	13.1	8.3	177.9	3,210,048.6	2,180.0	1.9	1.5
07/15/2021 16:00	11.0	13.1	8.3	179.8	3,189,010.6	2,189.0	2.0	1.8
07/15/2021 17:00	10.9	13.1	8.2	180.5	3,177,501.6	2,181.1	2.0	1.7
07/15/2021 18:00	11.0	13.0	8.2	187.3	3,195,515.8	2,216.8	2.0	1.8
07/15/2021 19:00	11.0	13.0	8.2	190.2	3,172,642.5	2,224.1	2.1	1.8
07/15/2021 20:00	11.0	13.0	8.2	191.4	3,220,886.2	2,234.4	2.1	1.8
07/15/2021 21:00	10.8	13.1	8.2	178.7	3,229,013.4	2,169.3	1.9	1.5
07/15/2021 22:00	10.6	13.2	8.1	165.3	3,247,536.1	2,110.6	1.8	1.5
07/15/2021 23:00	10.5	13.2	8.0	164.3	3,261,999.7	2,120.0	1.7	1.5
Average/Sum#:	10.6	13.4	8.3	150.1	3,141,669.2	1,936.9	1.6	1.3
Minimum:	9.8	13.0	7.9	105.7	2,834,137.9	1,490.1	1.2	0.7
Maximum:	11.0	13.8	8.7	191.4	3,261,999.7	2,234.4	2.1	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
07/16/2021 00:00	10.5	13.2	8.0	163.8	3,288,485.9	2,113.2	1.7	1.5
07/16/2021 01:00	10.3	13.3	8.0	148.8	3,258,741.0	1,998.9	1.6	1.2
07/16/2021 02:00	10.1	13.7	8.3	119.0	3,076,139.9	1,639.8	1.3	0.8
07/16/2021 03:00	10.4	13.8	8.6	103.7	2,781,995.0	1,483.0	1.2	0.7
07/16/2021 04:00	10.2	13.7	8.4	120.5	3,069,011.4	1,636.0	1.3	0.8
07/16/2021 05:00	9.9	13.6	8.0	131.2	3,116,638.7	1,820.7	1.4	0.9
07/16/2021 06:00	10.5	13.4	8.3	143.7	3,152,682.1	1,887.8	1.5	1.1
07/16/2021 07:00	10.4	13.7	8.5	126.2	3,162,995.1	1,686.1	1.3	0.8
07/16/2021 08:00	10.4	13.7	8.5	128.2	3,167,122.2	1,688.3	1.4	0.8
07/16/2021 09:00	10.6	13.7	8.7	126.3	3,109,531.3	1,657.6	1.4	0.8
07/16/2021 10:00	10.4	13.7	8.5	129.3	3,199,200.5	1,705.4	1.4	0.9
07/16/2021 11:00	10.5	13.7	8.6	112.2	2,871,851.8	1,530.9	1.3	0.8
07/16/2021 12:00	10.8	13.2	8.3	151.4	3,251,268.3	2,041.8	1.6	1.2
07/16/2021 13:00	10.7	13.2	8.2	154.8	3,187,768.1	2,025.2	1.7	1.4
07/16/2021 14:00	10.4	13.7	8.5	131.5	3,127,352.6	1,667.1	1.4	0.8
07/16/2021 15:00	10.5	13.7	8.6	118.1	3,028,491.4	1,614.4	1.3	0.8
07/16/2021 16:00	10.9	13.2	8.4	163.9	3,271,539.5	2,126.2	1.7	1.5
07/16/2021 17:00	11.1	13.0	8.3	194.7	3,194,288.3	2,262.6	2.1	1.8
07/16/2021 18:00	11.1	13.0	8.3	204.7	3,192,854.9	2,284.9	2.2	1.8
07/16/2021 19:00	11.1	13.0	8.3	205.9	3,186,427.0	2,280.3	2.3	2.1
07/16/2021 20:00	11.0	13.0	8.2	200.3	3,228,988.6	2,263.6	2.2	1.8
07/16/2021 21:00	10.9	13.1	8.2	186.5	3,216,107.7	2,207.6	2.0	1.8
07/16/2021 22:00	10.8	13.1	8.2	180.3	3,237,349.0	2,174.9	1.9	1.5
07/16/2021 23:00	10.7	13.1	8.1	170.2	3,239,601.6	2,129.1	1.8	1.5
Average/Sum#:	10.6	13.4	8.3	150.6	3,150,684.7	1,913.6	1.6	1.2
Minimum:	9.9	13.0	8.0	103.7	2,781,995.0	1,483.0	1.2	0.7
Maximum:	11.1	13.8	8.7	205.9	3,288,485.9	2,284.9	2.3	2.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
07/17/2021 00:00	10.5	13.3	8.2	151.7	3,215,864.9	1,972.6	1.6	1.2
07/17/2021 01:00	10.5	13.7	8.6	131.1	3,126,789.8	1,666.8	1.4	0.8
07/17/2021 02:00	10.9	13.8	9.1	98.4	2,525,827.2	1,328.0	1.3	0.7
07/17/2021 03:00	10.3	13.8	8.6	123.0	3,108,213.0	1,634.2	1.3	0.8
07/17/2021 04:00	10.2	13.5	8.1	135.4	3,238,513.1	1,844.6	1.4	0.9
07/17/2021 05:00	10.5	13.3	8.2	150.6	3,216,949.1	1,879.3	1.6	1.1
07/17/2021 06:00	10.4	13.8	8.6	119.5	3,087,207.8	1,645.7	1.3	0.8
07/17/2021 07:00	10.2	13.8	8.5	120.0	3,136,362.2	1,649.0	1.3	0.8
07/17/2021 08:00	10.2	13.8	8.5	115.4	3,061,424.3	1,609.6	1.2	0.8
07/17/2021 09:00	9.9	13.7	8.1	117.2	3,195,636.2	1,703.5	1.2	0.9
07/17/2021 10:00	10.1	13.8	8.4	114.3	3,085,199.0	1,622.1	1.2	0.8
07/17/2021 11:00	10.1	13.8	8.4	107.2	2,925,432.8	1,538.1	1.2	0.8
07/17/2021 12:00	10.2	13.7	8.4	118.0	3,076,139.9	1,639.8	1.3	0.8
07/17/2021 13:00	11.0	13.2	8.4	160.2	3,251,013.5	2,136.6	1.7	1.5
07/17/2021 14:00	11.1	13.1	8.4	192.3	3,204,595.7	2,246.5	2.1	1.8
07/17/2021 15:00	11.0	13.1	8.3	192.1	3,200,458.9	2,243.6	2.1	1.8
07/17/2021 16:00	11.0	13.0	8.2	198.2	3,194,429.4	2,262.7	2.2	1.8
07/17/2021 17:00	11.0	13.0	8.2	203.8	3,190,199.9	2,283.0	2.2	1.8
07/17/2021 18:00	10.9	13.0	8.1	204.8	3,195,649.6	2,286.9	2.2	1.8
07/17/2021 19:00	10.9	13.0	8.1	205.6	3,152,719.2	2,279.2	2.3	2.1
07/17/2021 20:00	10.9	13.0	8.1	199.8	3,188,923.5	2,258.8	2.2	1.8
07/17/2021 21:00	10.8	13.0	8.1	192.3	3,173,783.7	2,224.9	2.1	1.8
07/17/2021 22:00	10.7	13.1	8.1	177.7	3,233,032.3	2,172.0	1.9	1.5
07/17/2021 23:00	10.6	13.1	8.0	175.1	3,226,036.4	2,167.3	1.9	1.5
Average/Sum#:	10.6	13.4	8.3	154.3	3,133,766.7	1,929.0	1.7	1.3
Minimum:	9.9	13.0	8.0	98.4	2,525,827.2	1,328.0	1.2	0.7
Maximum:	11.1	13.8	9.1	205.6	3,251,013.5	2,286.9	2.3	2.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
07/18/2021 00:00	10.6	13.2	8.1	163.4	3,205,712.3	2,036.6	1.8	1.4
07/18/2021 01:00	10.4	13.7	8.5	132.4	3,129,791.3	1,668.4	1.4	0.8
07/18/2021 02:00	10.5	13.7	8.6	122.1	2,977,278.7	1,587.1	1.4	0.8
07/18/2021 03:00	10.6	13.2	8.1	149.0	3,280,567.6	2,060.2	1.5	1.2
07/18/2021 04:00	10.4	13.3	8.1	150.2	3,228,941.6	2,004.2	1.6	1.2
07/18/2021 05:00	10.3	13.7	8.4	134.4	3,143,297.9	1,675.6	1.4	0.8
07/18/2021 06:00	10.1	13.8	8.4	117.0	3,144,611.1	1,676.3	1.2	0.8
07/18/2021 07:00	10.1	13.8	8.4	122.4	3,175,543.0	1,669.6	1.3	0.8
07/18/2021 08:00	9.9	13.7	8.1	117.7	3,172,749.9	1,691.3	1.2	0.8
07/18/2021 09:00	10.0	13.8	8.3	120.7	3,167,554.7	1,665.4	1.3	0.8
07/18/2021 10:00	9.9	13.8	8.2	110.6	3,055,528.2	1,606.5	1.2	0.8
07/18/2021 11:00	10.0	13.7	8.2	128.3	3,232,591.9	1,723.2	1.3	0.9
07/18/2021 12:00	10.9	13.2	8.4	161.0	3,233,819.6	2,125.3	1.7	1.5
07/18/2021 13:00	11.0	13.0	8.2	198.0	3,177,903.0	2,274.2	2.2	1.8
07/18/2021 14:00	10.9	13.0	8.1	202.0	3,186,846.2	2,280.6	2.2	1.8
07/18/2021 15:00	10.9	13.0	8.1	202.7	3,181,815.6	2,277.0	2.2	1.8
07/18/2021 16:00	10.9	13.0	8.1	200.3	3,137,226.8	2,268.0	2.2	1.8
07/18/2021 17:00	10.9	13.0	8.1	200.1	3,129,480.5	2,262.4	2.2	1.8
07/18/2021 18:00	10.7	13.0	8.0	187.7	3,146,287.8	2,228.6	2.1	1.8
07/18/2021 19:00	10.5	13.1	7.9	180.6	3,183,551.3	2,208.5	2.0	1.8
07/18/2021 20:00	10.5	13.1	7.9	181.9	3,210,426.1	2,203.7	2.0	1.8
07/18/2021 21:00	10.7	13.0	8.0	193.4	3,204,025.1	2,246.1	2.1	1.8
07/18/2021 22:00	10.7	13.1	8.1	191.6	3,224,345.7	2,236.8	2.1	1.8
07/18/2021 23:00	10.6	13.0	7.9	189.9	3,220,165.4	2,233.9	2.1	1.8
Average/Sum#:	10.5	13.3	8.2	160.7	3,172,919.2	1,996.2	1.7	1.4
Minimum:	9.9	13.0	7.9	110.6	2,977,278.7	1,587.1	1.2	0.8
Maximum:	11.0	13.8	8.6	202.7	3,280,567.6	2,280.6	2.2	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
07/19/2021 00:00	10.6	13.1	8.0	185.0	3,225,285.8	2,213.9	2.0	1.8
07/19/2021 01:00	10.1	13.6	8.2	136.9	3,106,070.7	1,723.8	1.5	1.0
07/19/2021 02:00	10.2	13.7	8.4	128.0	3,185,318.6	1,698.0	1.3	0.8
07/19/2021 03:00	10.5	13.7	8.6	130.0	3,087,583.0	1,645.9	1.4	0.8
07/19/2021 04:00	10.2	13.7	8.4	126.7	3,216,459.0	1,714.6	1.3	0.9
07/19/2021 05:00	10.6	13.2	8.1	158.0	3,174,021.4	2,086.0	1.7	1.5
07/19/2021 06:00	10.9	13.1	8.2	172.0	3,197,831.7	2,125.0	1.9	1.5
07/19/2021 07:00	10.7	13.7	8.8	128.8	3,028,491.4	1,614.4	1.4	0.8
07/19/2021 08:00	10.7	13.7	8.8	130.8	3,069,949.3	1,636.5	1.4	0.8
07/19/2021 09:00	10.7	13.7	8.8	127.1	2,999,414.6	1,598.9	1.4	0.8
07/19/2021 10:00	11.1	13.1	8.4	166.0	3,228,918.1	2,098.5	1.8	1.5
07/19/2021 11:00	11.3	13.0	8.4	199.9	3,172,829.2	2,247.4	2.2	1.8
07/19/2021 12:00	11.1	13.0	8.3	202.7	3,173,990.4	2,271.4	2.2	1.8
07/19/2021 13:00	11.0	13.0	8.2	200.6	3,174,549.3	2,271.8	2.2	1.8
07/19/2021 14:00	11.0	13.0	8.2	202.3	3,180,977.2	2,276.4	2.2	1.8
07/19/2021 15:00	11.0	13.0	8.2	200.5	3,133,077.0	2,265.0	2.2	1.8
07/19/2021 16:00	10.9	13.0	8.1	203.4	3,148,431.2	2,276.1	2.3	2.0
07/19/2021 17:00	10.9	13.0	8.1	202.6	3,180,138.8	2,275.8	2.2	1.8
07/19/2021 18:00	10.9	13.0	8.1	203.6	3,184,051.4	2,278.6	2.2	1.8
07/19/2021 19:00	10.9	13.0	8.1	205.4	3,200,680.2	2,290.5	2.3	2.1
07/19/2021 20:00	10.9	13.0	8.1	205.7	3,192,715.1	2,284.8	2.3	2.1
07/19/2021 21:00	10.8	13.0	8.1	198.8	3,179,605.8	2,252.2	2.2	1.8
07/19/2021 22:00	10.6	13.1	8.0	171.0	3,223,113.3	2,141.8	1.8	1.5
07/19/2021 23:00	10.5	13.1	7.9	166.7	3,238,688.7	2,128.5	1.8	1.5
Average/Sum#:	10.8	13.2	8.3	173.0	3,162,591.3	2,059.0	1.9	1.5
Minimum:	10.1	13.0	7.9	126.7	2,999,414.6	1,598.9	1.3	0.8
Maximum:	11.3	13.7	8.8	205.7	3,238,688.7	2,290.5	2.3	2.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
07/20/2021 00:00	10.4	13.2	8.0	162.3	3,230,149.0	2,099.3	1.7	1.5
07/20/2021 01:00	10.1	13.7	8.3	130.8	3,127,469.2	1,690.0	1.4	0.8
07/20/2021 02:00	10.2	13.7	8.4	129.2	3,189,445.7	1,700.2	1.4	0.9
07/20/2021 03:00	10.2	13.7	8.4	127.3	3,191,696.8	1,701.4	1.3	0.9
07/20/2021 04:00	10.5	13.2	8.0	151.6	3,301,108.9	2,073.1	1.6	1.2
07/20/2021 05:00	10.7	13.1	8.1	168.6	3,281,557.6	2,204.6	1.8	1.5
07/20/2021 06:00	10.5	13.6	8.5	132.6	3,052,735.3	1,694.2	1.5	1.0
07/20/2021 07:00	10.6	13.7	8.7	128.6	3,109,906.5	1,657.8	1.4	0.8
07/20/2021 08:00	10.7	13.7	8.8	126.0	3,014,422.0	1,606.9	1.4	0.8
07/20/2021 09:00	10.7	13.7	8.8	126.2	3,082,142.8	1,643.0	1.4	0.8
07/20/2021 10:00	10.5	13.7	8.6	128.3	3,147,612.6	1,677.9	1.4	0.8
07/20/2021 11:00	10.7	13.7	8.8	122.8	3,008,794.2	1,603.9	1.4	0.8
07/20/2021 12:00	10.5	13.7	8.6	129.6	3,143,297.9	1,675.6	1.4	0.8
07/20/2021 13:00	10.9	13.2	8.4	154.1	3,214,454.5	2,089.1	1.6	1.3
07/20/2021 14:00	11.0	13.0	8.2	182.6	3,144,826.0	2,204.6	2.0	1.8
07/20/2021 15:00	10.9	13.0	8.1	191.2	3,158,429.1	2,237.2	2.1	1.8
07/20/2021 16:00	10.9	13.0	8.1	198.3	3,137,503.4	2,268.2	2.2	1.8
07/20/2021 17:00	10.8	13.0	8.1	199.0	3,139,855.0	2,269.9	2.2	1.8
07/20/2021 18:00	10.8	13.0	8.1	196.9	3,143,589.8	2,272.6	2.2	1.8
07/20/2021 19:00	10.8	13.0	8.1	185.1	3,134,460.3	2,266.0	2.1	1.8
07/20/2021 20:00	10.7	13.0	8.0	144.1	3,165,998.5	2,288.8	1.6	1.4
07/20/2021 21:00	10.6	13.0	7.9	140.2	3,173,355.7	2,224.6	1.5	1.3
07/20/2021 22:00	10.5	13.1	7.9	137.9	3,203,141.9	2,198.7	1.5	1.3
07/20/2021 23:00	10.4	13.1	7.9	135.4	3,236,455.9	2,174.3	1.4	1.1
Average/Sum#:	10.6	13.3	8.3	151.2	3,155,517.0	1,980.1	1.6	1.2
Minimum:	10.1	13.0	7.9	122.8	3,008,794.2	1,603.9	1.3	0.8
Maximum:	11.0	13.7	8.8	199.0	3,301,108.9	2,288.8	2.2	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
07/21/2021 00:00	10.1	13.2	7.7	124.8	3,235,304.5	2,055.4	1.3	1.0
07/21/2021 01:00	9.9	13.7	8.1	106.5	3,091,147.3	1,647.8	1.1	0.7
07/21/2021 02:00	9.5	13.8	7.9	105.6	3,131,854.8	1,669.5	1.1	0.7
07/21/2021 03:00	9.8	13.4	7.7	115.5	3,191,957.1	1,864.7	1.2	0.9
07/21/2021 04:00	10.0	13.2	7.7	126.7	3,222,971.4	2,071.1	1.3	1.0
07/21/2021 05:00	9.6	13.8	8.0	125.4	3,068,448.6	1,635.7	1.4	0.8
07/21/2021 06:00	10.3	13.7	8.4	120.4	2,988,346.6	1,593.0	1.3	0.8
07/21/2021 07:00	10.5	13.2	8.0	145.5	3,288,370.1	2,065.1	1.5	1.2
07/21/2021 08:00	10.2	13.3	7.9	145.6	3,247,655.1	1,992.1	1.5	1.2
07/21/2021 09:00	10.0	13.7	8.2	134.0	3,199,763.2	1,705.7	1.4	0.9
07/21/2021 10:00	10.4	13.7	8.5	125.5	3,038,809.0	1,619.9	1.4	0.8
07/21/2021 11:00	10.3	13.4	8.1	155.5	3,245,843.5	2,109.5	1.6	1.3
07/21/2021 12:00	10.5	13.2	8.0	170.1	3,207,132.4	2,154.6	1.8	1.5
07/21/2021 13:00	10.6	13.1	8.0	173.7	3,237,646.7	2,175.1	1.9	1.5
07/21/2021 14:00	10.7	13.1	8.1	178.6	3,188,864.9	2,188.9	1.9	1.5
07/21/2021 15:00	10.8	13.1	8.2	183.0	3,186,001.9	2,210.2	2.0	1.8
07/21/2021 16:00	10.8	13.1	8.2	183.1	3,180,091.7	2,206.1	2.0	1.8
07/21/2021 17:00	10.8	13.0	8.1	190.5	3,180,488.1	2,229.6	2.1	1.8
07/21/2021 18:00	10.9	13.0	8.1	200.7	3,140,546.6	2,270.4	2.2	1.8
07/21/2021 19:00	10.9	13.0	8.1	201.3	3,140,546.6	2,270.4	2.2	1.8
07/21/2021 20:00	10.8	13.0	8.1	204.5	3,155,762.4	2,281.4	2.3	2.1
07/21/2021 21:00	10.7	13.0	8.0	192.8	3,196,607.4	2,240.9	2.1	1.8
07/21/2021 22:00	10.6	13.1	8.0	183.9	3,213,776.8	2,206.0	2.0	1.8
07/21/2021 23:00	10.5	13.1	7.9	170.5	3,225,069.7	2,143.1	1.8	1.5
Average/Sum#:	10.4	13.3	8.0	156.8	3,175,125.3	2,025.3	1.7	1.3
Minimum:	9.5	13.0	7.7	105.6	2,988,346.6	1,593.0	1.1	0.7
Maximum:	10.9	13.8	8.5	204.5	3,288,370.1	2,281.4	2.3	2.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
07/22/2021 00:00	10.3	13.2	7.9	157.4	3,219,721.4	2,045.5	1.7	1.4
07/22/2021 01:00	10.1	13.7	8.3	132.5	3,145,361.5	1,676.7	1.4	0.8
07/22/2021 02:00	10.3	13.7	8.4	116.1	2,916,688.9	1,576.1	1.3	0.8
07/22/2021 03:00	10.3	13.3	8.0	147.7	3,237,035.9	2,056.5	1.6	1.2
07/22/2021 04:00	9.9	13.3	7.7	143.7	3,219,597.3	1,998.4	1.5	1.2
07/22/2021 05:00	9.8	13.8	8.1	118.5	3,029,617.0	1,615.0	1.3	0.8
07/22/2021 06:00	10.0	13.7	8.2	120.1	3,156,153.1	1,705.5	1.3	0.9
07/22/2021 07:00	10.5	13.2	8.0	152.6	3,253,878.3	2,067.2	1.6	1.2
07/22/2021 08:00	10.5	13.3	8.2	150.1	3,269,174.7	2,005.3	1.6	1.2
07/22/2021 09:00	10.6	13.7	8.7	134.2	3,012,548.6	1,627.9	1.5	1.0
07/22/2021 10:00	10.6	13.7	8.7	128.2	3,097,337.8	1,651.1	1.4	0.8
07/22/2021 11:00	9.8	13.6	7.9	123.9	3,275,700.1	1,770.1	1.3	0.9
07/22/2021 12:00	10.8	13.1	8.2	161.3	3,248,579.0	2,135.0	1.7	1.5
07/22/2021 13:00	10.9	13.1	8.2	191.8	3,220,144.4	2,257.4	2.1	1.8
07/22/2021 14:00	10.7	13.1	8.1	183.9	3,215,840.9	2,230.9	2.0	1.8
07/22/2021 15:00	10.7	13.1	8.1	182.6	3,207,336.1	2,225.0	2.0	1.8
07/22/2021 16:00	10.8	13.0	8.1	194.0	3,196,970.6	2,264.5	2.1	1.8
07/22/2021 17:00	10.7	13.0	8.0	191.4	3,204,025.1	2,246.1	2.1	1.8
07/22/2021 18:00	10.7	13.0	8.0	199.3	3,192,295.9	2,284.5	2.2	1.8
07/22/2021 19:00	10.6	13.0	7.9	197.7	3,181,955.4	2,277.1	2.2	1.8
07/22/2021 20:00	10.6	13.0	7.9	192.9	3,187,511.7	2,257.8	2.1	1.8
07/22/2021 21:00	10.4	13.1	7.9	177.1	3,198,710.3	2,172.3	1.9	1.5
07/22/2021 22:00	10.5	13.1	7.9	171.7	3,208,174.3	2,155.3	1.9	1.5
07/22/2021 23:00	10.3	13.1	7.8	162.5	3,191,374.3	2,074.1	1.8	1.5
Average/Sum#:	10.4	13.3	8.1	159.6	3,178,572.2	2,015.6	1.7	1.4
Minimum:	9.8	13.0	7.7	116.1	2,916,688.9	1,576.1	1.3	0.8
Maximum:	10.9	13.8	8.7	199.3	3,275,700.1	2,284.5	2.2	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
07/23/2021 00:00	10.1	13.7	8.3	132.7	3,172,562.4	1,691.2	1.4	0.8
07/23/2021 01:00	10.2	13.7	8.4	124.6	3,119,098.5	1,662.7	1.3	0.8
07/23/2021 02:00	10.5	13.2	8.0	150.9	3,265,683.6	2,074.7	1.6	1.2
07/23/2021 03:00	10.2	13.3	7.9	143.2	3,222,875.1	1,976.9	1.5	1.2
07/23/2021 04:00	10.0	13.7	8.2	129.3	3,182,317.2	1,696.4	1.4	0.8
07/23/2021 05:00	10.4	13.7	8.5	127.3	3,121,537.2	1,664.0	1.4	0.8
07/23/2021 06:00	10.6	13.7	8.7	129.3	3,147,800.2	1,678.0	1.4	0.8
07/23/2021 07:00	10.7	13.7	8.8	127.2	3,098,838.5	1,651.9	1.4	0.8
07/23/2021 08:00	10.4	13.7	8.5	130.5	3,171,624.4	1,690.7	1.4	0.8
07/23/2021 09:00	10.6	13.7	8.7	130.8	3,141,797.2	1,674.8	1.4	0.8
07/23/2021 10:00	10.2	13.7	8.4	131.1	3,214,958.2	1,713.8	1.4	0.9
07/23/2021 11:00	10.2	13.7	8.4	129.3	3,192,794.4	1,725.3	1.4	0.9
07/23/2021 12:00	10.4	13.4	8.2	173.3	3,224,101.3	2,166.0	1.9	1.5
07/23/2021 13:00	10.7	13.1	8.1	201.2	3,192,435.7	2,284.6	2.2	1.8
07/23/2021 14:00	10.8	13.0	8.1	200.9	3,200,959.6	2,290.7	2.2	1.8
07/23/2021 15:00	10.6	13.0	7.9	199.4	3,196,907.3	2,287.8	2.2	1.8
07/23/2021 16:00	10.6	13.0	7.9	202.1	3,192,854.9	2,284.9	2.2	1.8
07/23/2021 17:00	10.6	13.0	7.9	201.4	3,199,422.5	2,289.6	2.2	1.8
07/23/2021 18:00	10.7	13.0	8.0	199.7	3,163,785.3	2,287.2	2.2	1.8
07/23/2021 19:00	10.6	13.0	7.9	202.7	3,174,159.7	2,294.7	2.2	1.8
07/23/2021 20:00	10.6	13.0	7.9	201.2	3,191,737.0	2,284.1	2.2	1.8
07/23/2021 21:00	10.4	13.1	7.9	186.5	3,239,999.8	2,224.0	2.0	1.8
07/23/2021 22:00	10.4	13.1	7.9	169.4	3,225,822.1	2,143.6	1.8	1.5
07/23/2021 23:00	10.4	13.1	7.9	168.5	3,247,818.2	2,134.5	1.8	1.5
Average/Sum#:	10.5	13.3	8.2	162.2	3,187,578.8	1,994.7	1.8	1.3
Minimum:	10.0	13.0	7.9	124.6	3,098,838.5	1,651.9	1.3	0.8
Maximum:	10.8	13.7	8.8	202.7	3,265,683.6	2,294.7	2.2	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
07/24/2021 00:00	10.5	13.2	8.0	165.9	3,265,384.8	2,122.2	1.8	1.5
07/24/2021 01:00	10.3	13.3	8.0	149.0	3,225,157.5	1,978.3	1.6	1.2
07/24/2021 02:00	10.3	13.7	8.4	130.8	3,131,479.6	1,669.3	1.4	0.8
07/24/2021 03:00	9.9	13.7	8.1	127.3	3,260,355.6	1,738.0	1.3	0.9
07/24/2021 04:00	10.4	13.2	8.0	149.4	3,277,701.3	2,058.4	1.6	1.2
07/24/2021 05:00	10.1	13.3	7.8	144.3	3,267,974.6	1,980.7	1.5	1.2
07/24/2021 06:00	10.6	13.7	8.7	130.5	3,120,786.9	1,663.6	1.4	0.8
07/24/2021 07:00	10.7	13.7	8.8	127.8	3,043,686.4	1,622.5	1.4	0.8
07/24/2021 08:00	10.7	13.7	8.8	129.0	3,063,758.8	1,633.2	1.4	0.8
07/24/2021 09:00	10.6	13.7	8.7	130.9	3,119,286.1	1,662.8	1.4	0.8
07/24/2021 10:00	10.7	13.7	8.8	125.3	3,047,625.8	1,624.6	1.4	0.8
07/24/2021 11:00	10.3	13.7	8.4	122.2	3,122,287.6	1,664.4	1.3	0.8
07/24/2021 12:00	10.9	13.2	8.4	159.1	3,215,377.7	2,089.7	1.7	1.5
07/24/2021 13:00	11.0	13.1	8.3	178.9	3,159,334.1	2,191.7	2.0	1.8
07/24/2021 14:00	10.8	13.1	8.2	179.2	3,155,271.6	2,142.8	2.0	1.7
07/24/2021 15:00	10.1	13.7	8.3	133.8	3,166,184.2	1,687.8	1.4	0.8
07/24/2021 16:00	10.1	13.7	8.3	129.0	3,209,705.6	1,711.0	1.3	0.9
07/24/2021 17:00	10.9	13.2	8.4	158.9	3,186,802.7	2,094.4	1.7	1.5
07/24/2021 18:00	11.0	13.0	8.2	184.7	3,140,403.9	2,201.5	2.0	1.8
07/24/2021 19:00	11.0	13.0	8.2	204.7	3,144,973.0	2,273.6	2.3	2.0
07/24/2021 20:00	10.9	13.0	8.1	205.8	3,157,284.0	2,282.5	2.3	2.1
07/24/2021 21:00	10.8	13.0	8.1	198.6	3,179,605.8	2,252.2	2.2	1.8
07/24/2021 22:00	10.7	13.1	8.1	181.5	3,204,305.8	2,176.1	2.0	1.7
07/24/2021 23:00	10.7	13.1	8.1	184.1	3,189,884.7	2,189.6	2.0	1.8
Average/Sum#:	10.6	13.4	8.3	155.4	3,168,942.4	1,946.3	1.7	1.3
Minimum:	9.9	13.0	7.8	122.2	3,043,686.4	1,622.5	1.3	0.8
Maximum:	11.0	13.7	8.8	205.8	3,277,701.3	2,282.5	2.3	2.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
07/25/2021 00:00	10.4	13.2	8.0	154.3	3,195,217.4	2,006.6	1.7	1.4
07/25/2021 01:00	10.3	13.7	8.4	134.5	3,114,971.5	1,660.5	1.5	1.0
07/25/2021 02:00	10.5	13.7	8.6	120.4	3,004,479.6	1,601.6	1.3	0.8
07/25/2021 03:00	10.5	13.2	8.0	152.0	3,237,755.0	2,080.6	1.6	1.2
07/25/2021 04:00	10.1	13.3	7.8	145.4	3,187,536.6	1,978.5	1.6	1.2
07/25/2021 05:00	10.2	13.7	8.4	133.8	3,163,933.1	1,686.6	1.4	0.8
07/25/2021 06:00	10.7	13.7	8.8	136.1	3,144,235.9	1,676.1	1.5	1.0
07/25/2021 07:00	10.8	13.7	8.9	132.5	3,162,995.1	1,686.1	1.4	0.8
07/25/2021 08:00	10.6	13.7	8.7	135.1	3,185,131.0	1,697.9	1.4	0.8
07/25/2021 09:00	10.5	13.7	8.6	133.3	3,175,001.1	1,692.5	1.4	0.8
07/25/2021 10:00	10.5	13.7	8.6	129.0	3,168,247.7	1,688.9	1.4	0.8
07/25/2021 11:00	10.6	13.7	8.7	117.2	2,886,671.6	1,538.8	1.4	0.8
07/25/2021 12:00	10.4	13.4	8.2	161.5	3,186,093.7	2,117.2	1.7	1.5
07/25/2021 13:00	10.3	13.4	8.1	177.9	3,135,098.3	2,129.1	2.0	1.7
07/25/2021 14:00	10.2	13.7	8.4	132.5	3,158,305.3	1,683.6	1.4	0.8
07/25/2021 15:00	10.2	13.6	8.2	130.6	3,182,246.2	1,719.6	1.4	0.9
07/25/2021 16:00	10.5	13.5	8.4	132.3	3,159,535.9	1,730.4	1.4	0.9
07/25/2021 17:00	11.2	13.1	8.5	168.7	3,119,228.2	2,141.1	1.9	1.5
07/25/2021 18:00	11.2	13.0	8.4	197.0	3,116,477.9	2,253.0	2.2	1.8
07/25/2021 19:00	10.8	13.0	8.1	185.3	3,147,536.4	2,206.5	2.1	1.8
07/25/2021 20:00	10.6	13.1	8.0	175.5	3,147,782.2	2,160.7	1.9	1.5
07/25/2021 21:00	10.6	13.1	8.0	169.7	3,195,724.9	2,123.6	1.8	1.5
07/25/2021 22:00	10.6	13.1	8.0	168.4	3,208,561.3	2,108.7	1.8	1.5
07/25/2021 23:00	10.6	13.1	8.0	168.5	3,210,171.5	2,133.2	1.8	1.5
Average/Sum#:	10.5	13.4	8.3	149.6	3,149,705.7	1,895.9	1.6	1.2
Minimum:	10.1	13.0	7.8	117.2	2,886,671.6	1,538.8	1.3	0.8
Maximum:	11.2	13.7	8.9	197.0	3,237,755.0	2,253.0	2.2	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
07/26/2021 00:00	10.3	13.2	7.9	149.0	3,224,430.5	2,001.4	1.6	1.2
07/26/2021 01:00	10.2	13.7	8.4	125.1	3,034,119.2	1,617.4	1.4	0.8
07/26/2021 02:00	9.9	13.7	8.1	116.3	3,088,896.2	1,646.6	1.3	0.8
07/26/2021 03:00	10.3	13.3	8.0	149.1	3,246,165.4	2,062.3	1.6	1.2
07/26/2021 04:00	10.2	13.2	7.8	156.7	3,208,145.9	2,085.0	1.7	1.5
07/26/2021 05:00	9.4	13.7	7.7	131.6	3,186,444.2	1,698.6	1.4	0.8
07/26/2021 06:00	10.2	13.8	8.5	118.1	3,047,250.6	1,624.4	1.3	0.8
07/26/2021 07:00	10.4	13.8	8.6	112.3	2,885,733.6	1,538.3	1.3	0.8
07/26/2021 08:00	10.2	13.7	8.4	132.5	3,157,555.0	1,683.2	1.4	0.8
07/26/2021 09:00	10.6	13.7	8.7	120.6	2,936,383.5	1,565.3	1.4	0.8
07/26/2021 10:00	10.1	13.7	8.3	122.0	3,150,801.6	1,679.6	1.3	0.8
07/26/2021 11:00	10.8	13.2	8.3	158.2	3,232,764.8	2,101.0	1.7	1.5
07/26/2021 12:00	10.9	13.0	8.1	191.6	3,169,864.5	2,245.3	2.1	1.8
07/26/2021 13:00	10.9	13.0	8.1	189.7	3,164,923.3	2,241.8	2.1	1.8
07/26/2021 14:00	10.7	13.1	8.1	186.5	3,182,254.0	2,207.6	2.0	1.8
07/26/2021 15:00	10.8	13.0	8.1	199.6	3,170,357.2	2,268.8	2.2	1.8
07/26/2021 16:00	10.8	13.0	8.1	200.7	3,135,843.5	2,267.0	2.2	1.8
07/26/2021 17:00	10.7	13.0	8.0	191.9	3,154,052.6	2,234.1	2.1	1.8
07/26/2021 18:00	10.7	13.0	8.0	194.2	3,172,829.2	2,247.4	2.1	1.8
07/26/2021 19:00	10.7	13.0	8.0	195.0	3,167,323.3	2,243.5	2.2	1.8
07/26/2021 20:00	10.8	13.0	8.1	195.2	3,187,620.6	2,234.6	2.1	1.8
07/26/2021 21:00	10.8	13.0	8.1	206.4	3,221,535.6	2,281.9	2.2	1.8
07/26/2021 22:00	10.6	13.1	8.0	186.0	3,226,305.6	2,214.6	2.0	1.8
07/26/2021 23:00	10.3	13.2	7.9	160.5	3,238,767.4	2,057.6	1.7	1.4
Average/Sum#:	10.5	13.3	8.1	162.0	3,149,598.6	2,002.0	1.8	1.4
Minimum:	9.4	13.0	7.7	112.3	2,885,733.6	1,538.3	1.3	0.8
Maximum:	10.9	13.8	8.7	206.4	3,246,165.4	2,281.9	2.2	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
07/27/2021 00:00	10.5	13.7	8.6	132.1	3,062,070.4	1,632.3	1.5	1.0
07/27/2021 01:00	10.1	13.7	8.3	130.3	3,190,383.6	1,700.7	1.4	0.9
07/27/2021 02:00	10.4	13.3	8.1	143.0	3,269,624.5	1,981.7	1.5	1.2
07/27/2021 03:00	10.3	13.3	8.0	144.8	3,218,312.3	1,950.6	1.5	1.2
07/27/2021 04:00	10.4	13.7	8.5	129.6	3,103,903.5	1,654.6	1.4	0.8
07/27/2021 05:00	10.0	13.7	8.2	128.1	3,260,543.2	1,738.1	1.3	0.9
07/27/2021 06:00	10.6	13.3	8.2	147.4	3,292,351.0	2,067.6	1.5	1.2
07/27/2021 07:00	10.2	13.4	8.0	144.8	3,231,676.6	1,958.7	1.5	1.2
07/27/2021 08:00	9.3	13.8	7.7	119.7	3,208,066.8	1,686.7	1.3	0.8
07/27/2021 09:00	9.4	13.8	7.8	112.4	3,234,314.1	1,700.5	1.2	0.9
07/27/2021 10:00	9.9	13.7	8.1	134.4	3,190,946.4	1,701.0	1.4	0.9
07/27/2021 11:00	10.3	13.7	8.4	131.2	3,209,142.9	1,710.7	1.4	0.9
07/27/2021 12:00	10.7	13.2	8.2	157.0	3,296,422.4	2,118.3	1.6	1.3
07/27/2021 13:00	10.8	13.1	8.2	193.7	3,229,559.2	2,264.0	2.1	1.8
07/27/2021 14:00	10.7	13.1	8.1	193.2	3,254,328.9	2,257.6	2.1	1.8
07/27/2021 15:00	10.7	13.1	8.1	194.0	3,246,977.3	2,252.5	2.1	1.8
07/27/2021 16:00	10.6	13.1	8.0	185.3	3,261,880.5	2,215.2	2.0	1.8
07/27/2021 17:00	10.6	13.1	8.0	196.5	3,229,273.9	2,263.8	2.1	1.8
07/27/2021 18:00	10.6	13.1	8.0	201.2	3,243,538.7	2,273.8	2.2	1.8
07/27/2021 19:00	10.5	13.1	7.9	197.6	3,244,394.6	2,274.4	2.1	1.8
07/27/2021 20:00	10.5	13.1	7.9	198.8	3,237,262.2	2,269.4	2.2	1.8
07/27/2021 21:00	10.5	13.1	7.9	197.3	3,268,599.8	2,267.5	2.1	1.8
07/27/2021 22:00	10.4	13.1	7.9	189.9	3,263,454.9	2,240.1	2.0	1.8
07/27/2021 23:00	10.4	13.1	7.9	186.6	3,244,516.0	2,227.1	2.0	1.8
Average/Sum#:	10.4	13.4	8.1	162.0	3,228,814.3	2,017.0	1.7	1.4
Minimum:	9.3	13.1	7.7	112.4	3,062,070.4	1,632.3	1.2	0.8
Maximum:	10.8	13.8	8.6	201.2	3,296,422.4	2,274.4	2.2	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
07/28/2021 00:00	10.3	13.1	7.8	176.7	3,280,900.0	2,180.2	1.9	1.5
07/28/2021 01:00	10.1	13.3	7.8	150.6	3,227,276.8	1,979.6	1.6	1.2
07/28/2021 02:00	10.1	13.7	8.3	134.0	3,171,249.2	1,690.5	1.4	0.8
07/28/2021 03:00	10.2	13.7	8.4	128.9	3,150,426.5	1,679.4	1.4	0.8
07/28/2021 04:00	10.4	13.2	8.0	157.2	3,285,831.5	2,087.5	1.6	1.3
07/28/2021 05:00	10.6	13.1	8.0	188.6	3,248,740.8	2,230.0	2.0	1.8
07/28/2021 06:00	10.7	13.2	8.2	173.0	3,200,136.4	2,149.9	1.9	1.5
07/28/2021 07:00	10.1	13.7	8.3	127.4	3,131,479.6	1,669.3	1.4	0.8
07/28/2021 08:00	10.0	13.7	8.2	124.9	3,169,847.3	1,712.9	1.3	0.9
07/28/2021 09:00	10.6	13.4	8.3	165.5	3,150,127.5	2,093.3	1.8	1.5
07/28/2021 10:00	10.3	13.4	8.1	202.4	3,147,580.0	2,252.5	2.3	2.0
07/28/2021 11:00	10.3	13.4	8.1	203.9	3,142,130.3	2,248.6	2.3	2.0
07/28/2021 12:00	10.3	13.4	8.1	202.4	3,158,993.8	2,237.6	2.2	1.8
07/28/2021 13:00	10.2	13.4	8.0	202.8	3,129,833.4	2,239.8	2.3	2.0
07/28/2021 14:00	10.2	13.4	8.0	203.7	3,157,299.7	2,236.4	2.3	2.0
07/28/2021 15:00	10.2	13.4	8.0	201.4	3,113,204.7	2,227.9	2.3	2.0
07/28/2021 16:00	10.2	13.4	8.0	201.8	3,113,763.6	2,228.3	2.3	2.0
07/28/2021 17:00	10.2	13.4	8.0	201.5	3,108,453.6	2,224.5	2.3	2.0
07/28/2021 18:00	10.2	13.4	8.0	194.9	3,118,617.0	2,209.0	2.2	1.8
07/28/2021 19:00	10.2	13.4	8.0	190.1	3,145,928.2	2,182.4	2.1	1.7
07/28/2021 20:00	10.2	13.4	8.0	183.5	3,155,503.4	2,166.0	2.0	1.7
07/28/2021 21:00	10.1	13.4	7.9	196.8	3,146,711.3	2,228.9	2.2	1.8
07/28/2021 22:00	10.1	13.4	7.9	188.9	3,175,478.9	2,202.9	2.1	1.8
07/28/2021 23:00	10.2	13.4	8.0	194.4	3,163,227.7	2,217.5	2.2	1.8
Average/Sum#:	10.3	13.4	8.1	179.0	3,166,364.2	2,107.3	2.0	1.6
Minimum:	10.0	13.1	7.8	124.9	3,108,453.6	1,669.3	1.3	0.8
Maximum:	10.7	13.7	8.4	203.9	3,285,831.5	2,252.5	2.3	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
07/29/2021 00:00	10.3	13.4	8.1	206.2	3,175,511.6	2,249.3	2.3	2.0
07/29/2021 01:00	10.2	13.4	8.0	196.7	3,187,587.5	2,211.3	2.2	1.8
07/29/2021 02:00	10.5	13.6	8.5	137.6	2,895,888.0	1,628.3	1.6	1.0
07/29/2021 03:00	10.2	13.7	8.4	137.4	3,241,971.5	1,728.2	1.4	0.9
07/29/2021 04:00	10.8	13.1	8.2	161.4	3,237,688.5	2,104.2	1.7	1.5
07/29/2021 05:00	10.9	13.0	8.1	208.0	3,225,354.8	2,237.5	2.3	2.0
07/29/2021 06:00	10.8	13.1	8.2	174.8	3,202,045.3	2,127.8	1.9	1.5
07/29/2021 07:00	10.6	13.7	8.7	140.6	3,111,407.2	1,658.6	1.5	1.0
07/29/2021 08:00	10.5	13.7	8.6	136.4	3,167,309.8	1,688.4	1.4	0.8
07/29/2021 09:00	10.8	13.2	8.3	156.3	3,200,562.6	2,056.7	1.7	1.4
07/29/2021 10:00	11.1	13.0	8.3	199.0	3,143,174.8	2,272.3	2.2	1.8
07/29/2021 11:00	11.1	13.0	8.3	197.6	3,141,929.8	2,271.4	2.2	1.8
07/29/2021 12:00	11.0	13.0	8.2	199.1	3,129,757.2	2,262.6	2.2	1.8
07/29/2021 13:00	11.0	13.0	8.2	197.4	3,124,085.8	2,258.5	2.2	1.8
07/29/2021 14:00	11.0	13.0	8.2	197.0	3,112,466.5	2,250.1	2.2	1.8
07/29/2021 15:00	10.9	13.0	8.1	196.2	3,107,486.7	2,246.5	2.2	1.8
07/29/2021 16:00	11.0	13.0	8.2	197.4	3,100,708.8	2,241.6	2.2	1.8
07/29/2021 17:00	11.0	13.0	8.2	199.0	3,100,985.4	2,241.8	2.2	1.8
07/29/2021 18:00	11.0	13.0	8.2	198.3	3,098,633.9	2,240.1	2.2	1.8
07/29/2021 19:00	11.2	12.9	8.3	200.2	3,100,985.4	2,241.8	2.3	2.0
07/29/2021 20:00	11.1	13.0	8.3	191.3	3,100,348.9	2,218.7	2.2	1.8
07/29/2021 21:00	11.0	13.0	8.2	198.1	3,139,754.7	2,246.9	2.2	1.8
07/29/2021 22:00	10.9	13.0	8.1	195.2	3,162,382.1	2,240.0	2.2	1.8
07/29/2021 23:00	10.8	13.0	8.1	189.8	3,147,276.1	2,229.3	2.1	1.8
Average/Sum#:	10.8	13.2	8.3	183.8	3,139,804.3	2,131.3	2.0	1.6
Minimum:	10.2	12.9	8.0	136.4	2,895,888.0	1,628.3	1.4	0.8
Maximum:	11.2	13.7	8.7	208.0	3,241,971.5	2,272.3	2.3	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
07/30/2021 00:00	10.8	13.0	8.1	185.9	3,184,992.8	2,209.5	2.0	1.8
07/30/2021 01:00	10.7	13.1	8.1	173.5	3,147,025.6	2,137.2	1.9	1.5
07/30/2021 02:00	10.4	13.6	8.4	143.6	3,151,156.5	1,702.8	1.5	1.0
07/30/2021 03:00	10.2	13.7	8.4	134.7	3,268,797.2	1,742.5	1.4	0.9
07/30/2021 04:00	11.0	13.1	8.3	166.3	3,222,511.4	2,141.4	1.8	1.5
07/30/2021 05:00	11.1	13.0	8.3	220.1	3,194,112.5	2,285.8	2.4	2.1
07/30/2021 06:00	11.3	13.0	8.4	193.0	3,204,453.1	2,246.4	2.1	1.8
07/30/2021 07:00	11.1	13.0	8.3	193.2	3,191,757.4	2,237.5	2.1	1.8
07/30/2021 08:00	11.0	13.0	8.2	191.8	3,163,227.7	2,217.5	2.1	1.8
07/30/2021 09:00	11.1	13.0	8.3	196.7	3,163,229.1	2,240.6	2.2	1.8
07/30/2021 10:00	11.1	13.0	8.3	195.1	3,135,702.4	2,244.0	2.2	1.8
07/30/2021 11:00	11.0	13.0	8.2	199.7	3,122,287.6	2,257.2	2.2	1.8
07/30/2021 12:00	11.1	13.0	8.3	197.8	3,113,019.8	2,250.5	2.2	1.8
07/30/2021 13:00	11.0	13.0	8.2	196.5	3,108,593.4	2,247.3	2.2	1.8
07/30/2021 14:00	11.0	13.0	8.2	196.0	3,100,293.8	2,241.3	2.2	1.8
07/30/2021 15:00	11.0	13.0	8.2	197.6	3,092,685.9	2,235.8	2.2	1.8
07/30/2021 16:00	11.0	13.0	8.2	196.1	3,114,182.8	2,228.6	2.2	1.8
07/30/2021 17:00	11.0	13.0	8.2	193.3	3,113,204.7	2,227.9	2.2	1.8
07/30/2021 18:00	10.9	13.0	8.1	192.7	3,100,768.1	2,219.0	2.2	1.8
07/30/2021 19:00	11.0	13.0	8.2	197.3	3,095,729.1	2,238.0	2.2	1.8
07/30/2021 20:00	10.9	13.0	8.1	198.1	3,107,348.4	2,246.4	2.2	1.8
07/30/2021 21:00	10.8	13.0	8.1	192.8	3,111,248.4	2,226.5	2.2	1.8
07/30/2021 22:00	10.8	13.0	8.1	194.8	3,124,942.6	2,236.3	2.2	1.8
07/30/2021 23:00	10.9	13.0	8.1	199.5	3,145,204.5	2,250.8	2.2	1.8
Average/Sum#:	10.9	13.1	8.2	189.4	3,144,853.1	2,188.0	2.1	1.7
Minimum:	10.2	13.0	8.1	134.7	3,092,685.9	1,702.8	1.4	0.9
Maximum:	11.3	13.7	8.4	220.1	3,268,797.2	2,285.8	2.4	2.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
07/31/2021 00:00	10.8	13.0	8.1	203.9	3,184,051.4	2,278.6	2.2	1.8
07/31/2021 01:00	10.7	13.0	8.0	198.2	3,235,407.8	2,268.1	2.1	1.8
07/31/2021 02:00	10.5	13.1	7.9	184.7	3,236,212.0	2,221.4	2.0	1.8
07/31/2021 03:00	10.2	13.6	8.2	140.6	3,073,817.2	1,705.9	1.6	1.0
07/31/2021 04:00	9.7	13.6	7.8	123.7	3,300,312.8	1,783.4	1.3	0.9
07/31/2021 05:00	10.2	13.4	8.0	147.2	3,169,728.4	1,944.3	1.6	1.2
07/31/2021 06:00	10.8	13.1	8.2	168.5	3,202,496.7	2,128.1	1.8	1.5
07/31/2021 07:00	10.5	13.7	8.6	137.1	3,175,001.1	1,692.5	1.5	1.0
07/31/2021 08:00	10.5	13.7	8.6	120.5	2,988,159.0	1,592.9	1.3	0.8
07/31/2021 09:00	10.9	13.2	8.4	155.2	3,262,220.7	2,072.5	1.6	1.2
07/31/2021 10:00	10.9	13.1	8.2	169.5	3,232,450.2	2,124.4	1.8	1.5
07/31/2021 11:00	10.9	13.1	8.2	172.1	3,217,093.9	2,137.8	1.8	1.5
07/31/2021 12:00	10.9	13.1	8.2	175.0	3,196,117.4	2,147.2	1.9	1.5
07/31/2021 13:00	10.9	13.1	8.2	173.4	3,185,995.6	2,140.4	1.9	1.5
07/31/2021 14:00	10.9	13.1	8.2	175.0	3,195,522.0	2,146.8	1.9	1.5
07/31/2021 15:00	11.1	13.1	8.4	178.8	3,173,530.6	2,155.2	1.9	1.5
07/31/2021 16:00	11.1	13.1	8.4	182.3	3,148,947.7	2,161.5	2.0	1.7
07/31/2021 17:00	11.1	13.0	8.3	187.4	3,164,379.4	2,195.2	2.1	1.8
07/31/2021 18:00	11.0	13.0	8.2	193.2	3,168,791.0	2,221.4	2.1	1.8
07/31/2021 19:00	11.0	13.0	8.2	191.2	3,197,966.3	2,218.5	2.1	1.8
07/31/2021 20:00	11.0	13.0	8.2	201.6	3,196,264.7	2,264.0	2.2	1.8
07/31/2021 21:00	10.9	13.0	8.1	194.8	3,192,042.6	2,237.7	2.1	1.8
07/31/2021 22:00	10.8	13.0	8.1	186.1	3,220,915.3	2,210.9	2.0	1.8
07/31/2021 23:00	10.6	13.1	8.0	172.2	3,263,186.1	2,144.6	1.8	1.5
Average/Sum#:	10.7	13.2	8.2	172.2	3,190,858.7	2,091.4	1.9	1.5
Minimum:	9.7	13.0	7.8	120.5	2,988,159.0	1,592.9	1.3	0.8
Maximum:	11.1	13.7	8.6	203.9	3,300,312.8	2,278.6	2.2	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
08/01/2021 00:00	10.4	13.3	8.1	155.6	3,257,925.8	1,998.4	1.6	1.2
08/01/2021 01:00	10.4	13.7	8.5	135.2	3,119,473.7	1,662.9	1.5	1.0
08/01/2021 02:00	10.2	13.6	8.2	127.4	3,202,577.1	1,707.2	1.3	0.9
08/01/2021 03:00	10.6	13.2	8.1	152.4	3,261,140.9	2,048.0	1.6	1.2
08/01/2021 04:00	10.4	13.3	8.1	152.5	3,231,841.5	2,006.0	1.6	1.2
08/01/2021 05:00	10.2	13.7	8.4	138.5	3,175,188.6	1,692.6	1.5	1.0
08/01/2021 06:00	10.8	13.7	8.9	129.8	3,079,891.7	1,641.8	1.4	0.8
08/01/2021 07:00	10.9	13.7	8.9	132.8	3,045,562.3	1,623.5	1.5	1.0
08/01/2021 08:00	10.8	13.8	9.0	101.1	2,697,766.0	1,418.4	1.2	0.7
08/01/2021 09:00	10.4	13.7	8.5	128.1	2,968,649.4	1,582.5	1.5	0.9
08/01/2021 10:00	10.4	13.4	8.2	158.1	3,240,400.4	2,082.3	1.7	1.5
08/01/2021 11:00	10.4	13.4	8.2	162.6	3,156,990.1	2,028.7	1.8	1.4
08/01/2021 12:00	10.6	13.7	8.7	137.0	3,067,885.8	1,635.4	1.5	1.0
08/01/2021 13:00	10.5	13.7	8.6	132.6	3,151,739.6	1,680.1	1.4	0.8
08/01/2021 14:00	10.4	13.7	8.5	133.1	3,177,064.6	1,693.6	1.4	0.8
08/01/2021 15:00	10.3	13.7	8.4	128.7	3,214,395.5	1,713.5	1.3	0.9
08/01/2021 16:00	10.5	13.4	8.3	135.5	3,147,108.4	1,838.5	1.5	1.1
08/01/2021 17:00	11.3	13.0	8.4	192.7	3,173,111.6	2,247.6	2.1	1.8
08/01/2021 18:00	11.2	13.0	8.4	204.7	3,165,030.2	2,288.1	2.3	2.1
08/01/2021 19:00	11.0	13.0	8.2	203.1	3,186,985.9	2,280.7	2.2	1.8
08/01/2021 20:00	11.0	13.0	8.2	208.4	3,181,076.0	2,299.7	2.3	2.1
08/01/2021 21:00	10.9	13.0	8.1	210.0	3,210,881.0	2,297.8	2.3	2.1
08/01/2021 22:00	10.8	13.0	8.1	204.9	3,211,370.8	2,274.7	2.2	1.8
08/01/2021 23:00	10.8	13.0	8.1	194.5	3,233,715.5	2,243.3	2.1	1.8
Average/Sum#:	10.6	13.4	8.4	156.6	3,148,240.5	1,916.1	1.7	1.3
Minimum:	10.2	13.0	8.1	101.1	2,697,766.0	1,418.4	1.2	0.7
Maximum:	11.3	13.8	9.0	210.0	3,261,140.9	2,299.7	2.3	2.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
08/02/2021 00:00	10.7	13.0	8.0	196.9	3,255,914.6	2,258.7	2.1	1.8
08/02/2021 01:00	10.5	13.1	7.9	186.5	3,271,451.8	2,221.7	2.0	1.8
08/02/2021 02:00	10.3	13.6	8.3	137.3	3,041,217.7	1,665.6	1.5	1.0
08/02/2021 03:00	10.2	13.7	8.4	128.8	3,191,696.8	1,701.4	1.4	0.9
08/02/2021 04:00	10.5	13.2	8.0	157.0	3,334,070.7	2,093.8	1.6	1.3
08/02/2021 05:00	10.7	13.1	8.1	183.2	3,292,737.2	2,260.2	1.9	1.6
08/02/2021 06:00	10.8	13.1	8.2	168.3	3,276,987.4	2,177.6	1.8	1.5
08/02/2021 07:00	10.5	13.6	8.5	139.6	3,081,204.9	1,710.0	1.5	1.0
08/02/2021 08:00	10.6	13.7	8.7	129.9	3,014,046.8	1,606.7	1.4	0.8
08/02/2021 09:00	10.9	13.2	8.4	158.9	3,298,423.9	2,095.5	1.6	1.3
08/02/2021 10:00	10.9	13.1	8.2	184.4	3,245,535.8	2,204.1	2.0	1.8
08/02/2021 11:00	10.9	13.1	8.2	189.2	3,240,291.2	2,224.2	2.0	1.8
08/02/2021 12:00	10.9	13.1	8.2	184.3	3,243,032.5	2,202.4	2.0	1.8
08/02/2021 13:00	10.9	13.1	8.2	184.4	3,235,817.3	2,197.5	2.0	1.8
08/02/2021 14:00	10.9	13.1	8.2	182.2	3,228,013.0	2,192.2	2.0	1.8
08/02/2021 15:00	10.9	13.1	8.2	182.7	3,231,547.0	2,194.6	2.0	1.8
08/02/2021 16:00	10.9	13.1	8.2	184.4	3,232,872.3	2,195.5	2.0	1.8
08/02/2021 17:00	11.0	13.1	8.3	187.9	3,230,676.1	2,217.6	2.0	1.8
08/02/2021 18:00	11.1	13.0	8.3	202.0	3,215,888.5	2,277.9	2.2	1.8
08/02/2021 19:00	11.1	13.0	8.3	207.8	3,198,863.6	2,289.2	2.3	2.1
08/02/2021 20:00	11.0	13.0	8.2	210.9	3,217,728.1	2,302.7	2.3	2.1
08/02/2021 21:00	10.9	13.0	8.1	211.1	3,250,335.8	2,302.3	2.3	2.1
08/02/2021 22:00	10.8	13.0	8.1	211.0	3,248,218.2	2,300.8	2.3	2.1
08/02/2021 23:00	10.7	13.0	8.0	211.0	3,250,194.7	2,302.2	2.3	2.1
Average/Sum#:	10.8	13.2	8.2	180.0	3,221,948.6	2,133.1	1.9	1.7
Minimum:	10.2	13.0	7.9	128.8	3,014,046.8	1,606.7	1.4	0.8
Maximum:	11.1	13.7	8.7	211.1	3,334,070.7	2,302.7	2.3	2.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
08/03/2021 00:00	10.5	13.1	7.9	192.8	3,267,388.3	2,242.8	2.1	1.8
08/03/2021 01:00	10.6	13.1	8.0	191.5	3,260,395.5	2,238.0	2.0	1.8
08/03/2021 02:00	10.0	13.6	8.1	140.1	3,158,325.1	1,752.8	1.5	1.1
08/03/2021 03:00	9.6	13.6	7.8	124.5	3,303,828.9	1,785.3	1.3	0.9
08/03/2021 04:00	10.7	13.2	8.2	170.8	3,304,720.1	2,099.5	1.8	1.5
08/03/2021 05:00	11.0	13.1	8.3	179.6	3,317,167.2	2,204.3	1.9	1.5
08/03/2021 06:00	11.2	13.1	8.5	201.1	3,266,904.8	2,170.9	2.1	1.7
08/03/2021 07:00	11.3	13.1	8.5	198.1	3,255,359.9	2,187.0	2.1	1.7
08/03/2021 08:00	11.3	13.1	8.5	204.7	3,254,665.3	2,210.3	2.2	1.8
08/03/2021 09:00	11.4	13.1	8.6	220.9	3,251,217.4	2,231.7	2.4	2.0
08/03/2021 10:00	11.5	13.0	8.6	220.3	3,240,400.4	2,271.6	2.4	2.0
08/03/2021 11:00	10.8	13.5	8.6	189.4	3,038,429.6	1,974.7	2.2	1.6
08/03/2021 12:00	10.8	13.9	9.1	93.1	2,570,274.6	1,332.6	1.2	0.7
08/03/2021 13:00	10.0	13.7	8.2	132.8	3,223,212.3	1,718.2	1.4	0.9
08/03/2021 14:00	11.1	13.2	8.5	164.7	3,245,840.1	2,133.2	1.7	1.5
08/03/2021 15:00	11.0	13.1	8.3	182.8	3,223,742.8	2,189.3	2.0	1.8
08/03/2021 16:00	11.0	13.1	8.3	185.6	3,198,188.7	2,195.3	2.0	1.8
08/03/2021 17:00	11.1	13.1	8.4	189.5	3,183,695.5	2,208.6	2.1	1.8
08/03/2021 18:00	11.1	13.0	8.3	204.2	3,201,488.3	2,267.7	2.2	1.8
08/03/2021 19:00	11.1	13.0	8.3	206.5	3,187,125.6	2,280.8	2.3	2.1
08/03/2021 20:00	11.0	13.0	8.2	208.3	3,206,549.1	2,294.7	2.3	2.1
08/03/2021 21:00	11.0	13.0	8.2	207.6	3,198,304.6	2,288.8	2.3	2.1
08/03/2021 22:00	10.9	13.0	8.1	207.1	3,214,053.1	2,276.6	2.3	2.0
08/03/2021 23:00	10.7	13.1	8.1	196.9	3,256,202.9	2,258.9	2.1	1.8
Average/Sum#:	10.9	13.2	8.3	183.9	3,201,145.0	2,117.2	2.0	1.7
Minimum:	9.6	13.0	7.8	93.1	2,570,274.6	1,332.6	1.2	0.7
Maximum:	11.5	13.9	9.1	220.9	3,317,167.2	2,294.7	2.4	2.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
08/04/2021 00:00	10.5	13.2	8.0	175.0	3,191,215.3	2,097.3	1.9	1.5
08/04/2021 01:00	10.3	13.7	8.4	133.5	3,148,925.7	1,678.6	1.4	0.8
08/04/2021 02:00	9.8	13.6	7.9	128.8	3,294,205.9	1,780.1	1.3	0.9
08/04/2021 03:00	10.6	13.2	8.1	156.6	3,298,561.2	2,071.5	1.6	1.2
08/04/2021 04:00	10.8	13.1	8.2	192.1	3,266,805.6	2,242.4	2.0	1.8
08/04/2021 05:00	10.8	13.0	8.1	186.7	3,231,841.5	2,265.6	2.0	1.8
08/04/2021 06:00	10.9	13.2	8.4	171.4	3,236,710.6	2,127.2	1.8	1.5
08/04/2021 07:00	10.7	13.3	8.3	155.8	3,235,917.2	1,984.9	1.6	1.2
08/04/2021 08:00	10.6	13.7	8.7	136.2	3,087,583.0	1,645.9	1.5	1.0
08/04/2021 09:00	10.5	13.6	8.5	133.2	3,178,174.9	1,717.4	1.4	0.9
08/04/2021 10:00	11.0	13.2	8.4	160.5	3,236,665.7	2,079.9	1.7	1.5
08/04/2021 11:00	11.1	13.1	8.4	190.0	3,203,444.0	2,222.3	2.1	1.8
08/04/2021 12:00	11.0	13.1	8.3	182.4	3,189,010.6	2,189.0	2.0	1.8
08/04/2021 13:00	10.9	13.1	8.2	183.3	3,170,945.9	2,176.6	2.0	1.7
08/04/2021 14:00	10.9	13.1	8.2	183.8	3,171,382.9	2,176.9	2.0	1.7
08/04/2021 15:00	10.9	13.1	8.2	187.0	3,147,225.5	2,183.3	2.1	1.7
08/04/2021 16:00	11.0	13.0	8.2	194.1	3,125,111.2	2,213.6	2.2	1.8
08/04/2021 17:00	11.0	13.0	8.2	195.6	3,142,617.2	2,226.0	2.2	1.8
08/04/2021 18:00	10.9	13.0	8.1	197.6	3,162,523.3	2,240.1	2.2	1.8
08/04/2021 19:00	10.8	13.0	8.1	198.6	3,161,274.3	2,262.3	2.2	1.8
08/04/2021 20:00	10.8	13.0	8.1	203.4	3,186,846.2	2,280.6	2.2	1.8
08/04/2021 21:00	10.8	13.0	8.1	204.3	3,199,143.0	2,289.4	2.2	1.8
08/04/2021 22:00	10.7	13.0	8.0	203.3	3,227,041.5	2,285.8	2.2	1.8
08/04/2021 23:00	10.4	13.1	7.9	181.1	3,227,865.8	2,192.1	2.0	1.8
Average/Sum#:	10.7	13.2	8.2	176.4	3,196,709.9	2,109.5	1.9	1.6
Minimum:	9.8	13.0	7.9	128.8	3,087,583.0	1,645.9	1.3	0.8
Maximum:	11.1	13.7	8.7	204.3	3,298,561.2	2,289.4	2.2	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
08/05/2021 00:00	10.4	13.1	7.9	173.0	3,272,322.3	2,174.5	1.8	1.5
08/05/2021 01:00	10.4	13.1	7.9	176.2	3,257,741.5	2,188.6	1.9	1.5
08/05/2021 02:00	10.0	13.1	7.6	169.1	3,248,959.4	2,182.7	1.8	1.5
08/05/2021 03:00	9.9	13.1	7.5	177.8	3,249,906.3	2,230.8	1.9	1.6
08/05/2021 04:00	9.9	13.1	7.5	181.6	3,247,698.0	2,253.0	2.0	1.8
08/05/2021 05:00	9.9	13.1	7.5	164.9	3,271,613.1	2,245.7	1.7	1.6
08/05/2021 06:00	10.1	13.2	7.7	150.2	3,245,695.0	2,038.3	1.6	1.2
08/05/2021 07:00	10.3	13.7	8.4	135.0	3,119,098.5	1,662.7	1.5	1.0
08/05/2021 08:00	10.1	13.7	8.3	121.6	3,085,331.9	1,644.7	1.3	0.8
08/05/2021 09:00	10.4	13.3	8.1	143.7	3,296,188.0	1,997.8	1.5	1.2
08/05/2021 10:00	10.5	13.2	8.0	162.5	3,238,221.8	2,080.9	1.7	1.5
08/05/2021 11:00	10.2	13.7	8.4	136.0	3,171,249.2	1,690.5	1.4	0.8
08/05/2021 12:00	9.7	13.7	7.9	123.9	3,300,875.5	1,759.6	1.3	0.9
08/05/2021 13:00	10.8	13.2	8.3	156.4	3,249,115.0	2,087.9	1.6	1.3
08/05/2021 14:00	10.8	13.1	8.2	170.5	3,222,812.4	2,141.6	1.8	1.5
08/05/2021 15:00	10.8	13.1	8.2	174.8	3,238,763.9	2,152.2	1.9	1.5
08/05/2021 16:00	10.9	13.1	8.2	183.7	3,216,674.8	2,184.5	2.0	1.7
08/05/2021 17:00	10.8	13.1	8.2	179.2	3,221,868.6	2,164.5	1.9	1.5
08/05/2021 18:00	10.9	13.0	8.1	198.1	3,223,425.3	2,259.7	2.1	1.8
08/05/2021 19:00	10.9	13.0	8.1	204.6	3,216,453.2	2,278.3	2.2	1.8
08/05/2021 20:00	10.9	13.0	8.1	203.2	3,222,947.3	2,282.9	2.2	1.8
08/05/2021 21:00	10.8	13.0	8.1	193.2	3,223,625.0	2,236.3	2.1	1.8
08/05/2021 22:00	10.7	13.1	8.1	177.4	3,222,612.8	2,165.0	1.9	1.5
08/05/2021 23:00	10.6	13.1	8.0	171.8	3,251,622.1	2,137.0	1.8	1.5
Average/Sum#:	10.4	13.2	8.0	167.9	3,229,784.2	2,093.3	1.8	1.4
Minimum:	9.7	13.0	7.5	121.6	3,085,331.9	1,644.7	1.3	0.8
Maximum:	10.9	13.7	8.4	204.6	3,300,875.5	2,282.9	2.2	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
08/06/2021 00:00	10.5	13.2	8.0	166.5	3,195,374.9	2,076.7	1.8	1.5
08/06/2021 01:00	10.1	13.7	8.3	134.8	3,180,441.2	1,695.4	1.4	0.8
08/06/2021 02:00	10.4	13.7	8.5	130.3	3,172,937.5	1,691.4	1.4	0.8
08/06/2021 03:00	10.4	13.6	8.4	123.4	3,075,764.7	1,639.6	1.3	0.8
08/06/2021 04:00	10.6	13.2	8.1	151.4	3,273,083.5	2,055.5	1.6	1.2
08/06/2021 05:00	10.7	13.2	8.2	176.8	3,307,796.8	2,077.3	1.8	1.5
08/06/2021 06:00	10.5	13.7	8.6	122.6	3,044,496.7	1,600.7	1.3	0.8
08/06/2021 07:00	9.7	13.8	8.1	114.6	3,167,554.7	1,665.4	1.2	0.8
08/06/2021 08:00	9.9	13.7	8.1	118.5	3,127,540.2	1,667.2	1.3	0.8
08/06/2021 09:00	10.7	13.2	8.2	156.1	3,234,741.5	2,007.8	1.7	1.4
08/06/2021 10:00	10.6	13.2	8.1	152.2	3,215,408.5	1,995.8	1.6	1.2
08/06/2021 11:00	10.4	13.7	8.5	135.6	3,114,596.3	1,660.3	1.5	1.0
08/06/2021 12:00	10.3	13.8	8.6	107.6	2,911,168.0	1,530.6	1.2	0.8
08/06/2021 13:00	10.7	13.2	8.2	157.2	3,239,962.6	2,034.7	1.7	1.4
08/06/2021 14:00	10.9	13.1	8.2	172.0	3,202,797.7	2,128.3	1.9	1.5
08/06/2021 15:00	10.8	13.2	8.3	170.6	3,179,020.9	2,112.5	1.9	1.5
08/06/2021 16:00	10.8	13.1	8.2	184.9	3,155,794.8	2,166.2	2.0	1.7
08/06/2021 17:00	10.8	13.1	8.2	184.7	3,129,350.9	2,170.9	2.1	1.7
08/06/2021 18:00	10.8	13.0	8.1	194.0	3,136,123.0	2,221.4	2.2	1.8
08/06/2021 19:00	10.5	13.1	7.9	179.9	3,166,284.0	2,173.4	2.0	1.7
08/06/2021 20:00	10.6	13.1	8.0	182.9	3,119,956.7	2,141.6	2.0	1.7
08/06/2021 21:00	10.3	13.2	7.9	168.2	3,143,275.5	2,111.7	1.9	1.5
08/06/2021 22:00	10.6	13.1	8.0	170.0	3,189,237.2	2,096.0	1.8	1.5
08/06/2021 23:00	10.2	13.3	7.9	152.1	3,150,803.8	1,955.7	1.7	1.4
Average/Sum#:	10.5	13.3	8.2	154.5	3,159,729.7	1,944.8	1.7	1.3
Minimum:	9.7	13.0	7.9	107.6	2,911,168.0	1,530.6	1.2	0.8
Maximum:	10.9	13.8	8.6	194.0	3,307,796.8	2,221.4	2.2	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
08/07/2021 00:00	10.2	13.7	8.4	140.5	3,194,698.3	1,703.0	1.5	1.0
08/07/2021 01:00	10.7	13.6	8.6	129.3	3,017,730.2	1,630.7	1.4	0.8
08/07/2021 02:00	10.4	13.3	8.1	142.1	3,208,158.6	1,991.3	1.5	1.2
08/07/2021 03:00	16.6	14.7	15.8	161.8	2,340,150.6	1,196.2	2.3	1.1
08/07/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/07/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/07/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/07/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/07/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/07/2021 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/07/2021 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/07/2021 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/07/2021 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/07/2021 13:00	23.9	17.8	45.5	0.0	985,415.0	172.7	0.0	0.0
08/07/2021 14:00	40.4	15.5	44.1	212.3	2,025,254.2	813.4	3.3	1.1
08/07/2021 15:00	10.2	13.7	8.4	112.2	3,108,405.8	1,657.0	1.2	0.8
08/07/2021 16:00	10.6	13.7	8.7	125.4	2,882,356.9	1,536.5	1.5	0.9
08/07/2021 17:00	11.0	13.1	8.3	157.4	3,147,850.2	2,068.8	1.7	1.4
08/07/2021 18:00	11.0	13.1	8.3	170.0	3,151,443.1	2,140.2	1.9	1.5
08/07/2021 19:00	10.8	13.1	8.2	164.7	3,117,722.8	2,049.0	1.8	1.4
08/07/2021 20:00	10.2	13.7	8.4	136.4	3,123,397.9	1,687.8	1.5	1.0
08/07/2021 21:00	10.6	13.6	8.6	131.7	3,066,215.2	1,656.9	1.4	0.8
08/07/2021 22:00	10.5	13.2	8.0	143.6	3,220,886.2	1,999.2	1.5	1.2
08/07/2021 23:00	10.6	13.1	8.0	161.7	3,162,153.1	2,078.2	1.8	1.5
Average/Sum#:	13.8	13.9	13.7	139.3	2,850,122.5	1,625.4	1.6	1.0
Minimum:	10.2	13.1	8.0	0.0	985,415.0	172.7	0.0	0.0
Maximum:	40.4	17.8	45.5	212.3	3,220,886.2	2,140.2	3.3	1.5
%SI	37.50	37.50	37.50	37.50	37.50	37.50	37.50	37.50

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
08/08/2021 00:00	10.6	13.7	8.7	130.2	3,003,916.8	1,601.3	1.5	1.0
08/08/2021 01:00	10.6	13.6	8.6	122.1	2,907,251.0	1,571.0	1.4	0.8
08/08/2021 02:00	10.4	13.2	8.0	142.6	3,226,950.7	1,979.4	1.5	1.2
08/08/2021 03:00	10.6	13.6	8.6	115.7	2,732,458.1	1,496.5	1.4	0.7
08/08/2021 04:00	25.9	16.9	38.2	194.3	990,748.8	332.8	6.6	0.8
08/08/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/08/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/08/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/08/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/08/2021 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/08/2021 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/08/2021 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/08/2021 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/08/2021 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/08/2021 14:00	22.3	18.0	45.4	0.0	985,985.6	165.6	0.0	0.0
08/08/2021 15:00	40.8	15.5	44.6	196.3	2,029,238.0	815.0	3.1	1.0
08/08/2021 16:00	9.9	13.7	8.1	112.0	3,010,107.4	1,604.6	1.2	0.8
08/08/2021 17:00	10.2	13.4	8.0	135.6	3,061,931.5	1,811.1	1.5	1.1
08/08/2021 18:00	10.7	13.1	8.1	170.7	3,139,186.9	2,154.8	1.9	1.5
08/08/2021 19:00	10.7	13.1	8.1	202.7	3,144,054.2	2,181.1	2.3	2.0
08/08/2021 20:00	10.7	13.0	8.0	187.9	3,175,210.1	2,225.9	2.1	1.8
08/08/2021 21:00	10.6	13.1	8.0	177.6	3,167,158.1	2,174.0	1.9	1.5
08/08/2021 22:00	10.4	13.1	7.9	162.1	3,181,325.0	2,090.8	1.8	1.5
08/08/2021 23:00	10.3	13.2	7.9	148.3	3,170,781.3	1,968.1	1.6	1.2
Average/Sum#:	14.3	14.0	15.1	146.5	2,728,420.2	1,611.5	2.0	1.1
Minimum:	9.9	13.0	7.9	0.0	985,985.6	165.6	0.0	0.0
Maximum:	40.8	18.0	45.4	202.7	3,226,950.7	2,225.9	6.6	2.0
%SI	37.50	37.50	37.50	37.50	37.50	37.50	37.50	37.50

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
08/09/2021 00:00	10.7	13.7	8.8	131.9	2,992,098.5	1,595.0	1.5	1.0
08/09/2021 01:00	10.1	13.6	8.2	132.1	3,249,422.0	1,755.9	1.4	0.9
08/09/2021 02:00	10.4	13.2	8.0	146.1	3,245,695.0	2,038.3	1.5	1.2
08/09/2021 03:00	10.1	13.3	7.8	143.2	3,200,540.4	1,963.2	1.5	1.2
08/09/2021 04:00	10.2	13.7	8.4	136.7	3,175,751.4	1,692.9	1.5	1.0
08/09/2021 05:00	9.9	13.6	8.0	124.5	3,227,642.0	1,767.7	1.3	0.9
08/09/2021 06:00	10.5	13.2	8.0	144.2	3,253,591.2	2,019.5	1.5	1.2
08/09/2021 07:00	10.4	13.2	8.0	150.6	3,182,888.6	2,022.1	1.6	1.2
08/09/2021 08:00	10.6	13.7	8.7	127.9	2,986,845.9	1,592.2	1.4	0.8
08/09/2021 09:00	10.7	13.7	8.8	138.5	3,095,274.3	1,650.0	1.5	1.0
08/09/2021 10:00	10.4	13.6	8.4	130.9	3,113,219.8	1,682.3	1.4	0.8
08/09/2021 11:00	10.3	13.4	8.1	150.7	3,151,092.7	2,001.9	1.6	1.2
08/09/2021 12:00	10.2	13.4	8.0	171.4	3,076,345.6	2,089.2	1.9	1.5
08/09/2021 13:00	9.9	13.7	8.1	135.6	3,223,399.9	1,718.3	1.4	0.9
08/09/2021 14:00	10.3	13.4	8.1	137.0	3,093,039.4	1,829.5	1.5	1.1
08/09/2021 15:00	10.8	13.1	8.2	175.7	3,140,594.6	2,178.7	1.9	1.5
08/09/2021 16:00	10.6	13.1	8.0	180.6	3,120,861.1	2,187.8	2.0	1.8
08/09/2021 17:00	10.6	13.0	7.9	183.8	3,123,714.1	2,189.8	2.1	1.8
08/09/2021 18:00	10.6	13.0	7.9	183.9	3,125,996.5	2,191.4	2.1	1.8
08/09/2021 19:00	10.7	13.0	8.0	195.7	3,139,056.1	2,246.4	2.2	1.8
08/09/2021 20:00	10.6	13.0	7.9	196.1	3,134,183.6	2,265.8	2.2	1.8
08/09/2021 21:00	10.4	13.0	7.8	190.4	3,150,946.7	2,231.9	2.1	1.8
08/09/2021 22:00	10.3	13.1	7.8	170.3	3,211,074.5	2,133.8	1.8	1.5
08/09/2021 23:00	10.3	13.1	7.8	167.7	3,219,652.2	2,139.5	1.8	1.5
Average/Sum#:	10.4	13.3	8.1	156.1	3,151,371.9	1,966.0	1.7	1.3
Minimum:	9.9	13.0	7.8	124.5	2,986,845.9	1,592.2	1.3	0.8
Maximum:	10.8	13.7	8.8	196.1	3,253,591.2	2,265.8	2.2	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
08/10/2021 00:00	10.2	13.2	7.8	158.1	3,196,268.0	2,030.6	1.7	1.4
08/10/2021 01:00	10.4	13.7	8.5	136.0	3,060,944.9	1,631.7	1.5	1.0
08/10/2021 02:00	10.5	13.7	8.6	133.1	3,071,450.1	1,637.3	1.5	1.0
08/10/2021 03:00	10.2	13.6	8.2	132.1	3,231,286.4	1,746.1	1.4	0.9
08/10/2021 04:00	10.3	13.2	7.9	151.7	3,273,868.7	2,079.9	1.6	1.2
08/10/2021 05:00	10.2	13.2	7.8	181.7	3,283,785.2	2,086.2	1.9	1.5
08/10/2021 06:00	10.5	13.7	8.6	136.5	3,116,472.2	1,661.3	1.5	1.0
08/10/2021 07:00	10.3	13.7	8.4	122.8	3,022,726.7	1,633.4	1.4	0.8
08/10/2021 08:00	10.4	13.2	8.0	147.2	3,264,484.8	2,050.1	1.5	1.2
08/10/2021 09:00	10.2	13.3	7.9	149.5	3,224,831.4	1,978.1	1.6	1.2
08/10/2021 10:00	10.2	13.7	8.4	141.1	3,195,823.8	1,703.6	1.5	1.0
08/10/2021 11:00	10.2	13.7	8.4	134.6	3,217,959.7	1,715.4	1.4	0.9
08/10/2021 12:00	10.2	13.4	8.0	158.4	3,210,453.9	2,086.5	1.7	1.5
08/10/2021 13:00	10.0	13.4	7.9	179.8	3,179,832.6	2,182.7	2.0	1.7
08/10/2021 14:00	9.9	13.4	7.8	181.4	3,139,153.1	2,177.7	2.0	1.7
08/10/2021 15:00	10.2	13.3	7.9	182.8	3,143,910.1	2,181.0	2.0	1.7
08/10/2021 16:00	10.7	13.1	8.1	185.3	3,142,258.4	2,202.8	2.1	1.8
08/10/2021 17:00	10.7	13.0	8.0	185.9	3,149,248.1	2,207.7	2.1	1.8
08/10/2021 18:00	10.8	13.0	8.1	197.2	3,144,645.5	2,250.4	2.2	1.8
08/10/2021 19:00	10.6	13.0	7.9	202.0	3,134,875.2	2,266.3	2.3	2.0
08/10/2021 20:00	10.6	13.0	7.9	203.1	3,136,535.1	2,267.5	2.3	2.0
08/10/2021 21:00	10.6	13.0	7.9	201.8	3,156,383.5	2,258.8	2.2	1.8
08/10/2021 22:00	10.4	13.1	7.9	179.3	3,177,064.6	2,180.8	2.0	1.7
08/10/2021 23:00	10.4	13.1	7.9	175.2	3,212,044.4	2,157.9	1.9	1.5
Average/Sum#:	10.4	13.3	8.1	164.9	3,170,262.8	2,015.6	1.8	1.4
Minimum:	9.9	13.0	7.8	122.8	3,022,726.7	1,631.7	1.4	0.8
Maximum:	10.8	13.7	8.6	203.1	3,283,785.2	2,267.5	2.3	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
08/11/2021 00:00	10.4	13.1	7.9	166.8	3,187,259.2	2,094.7	1.8	1.5
08/11/2021 01:00	10.1	13.7	8.3	137.5	3,145,789.9	1,699.9	1.5	1.0
08/11/2021 02:00	10.7	13.7	8.8	135.7	3,064,884.3	1,633.8	1.5	1.0
08/11/2021 03:00	10.7	13.7	8.8	129.6	3,043,498.8	1,622.4	1.4	0.8
08/11/2021 04:00	10.5	13.6	8.5	127.0	3,042,898.0	1,644.3	1.4	0.8
08/11/2021 05:00	10.6	13.2	8.1	153.0	3,216,435.5	2,066.9	1.6	1.2
08/11/2021 06:00	10.8	13.1	8.2	163.3	3,255,806.5	2,092.2	1.7	1.5
08/11/2021 07:00	10.4	13.7	8.5	137.3	3,122,850.4	1,664.7	1.5	1.0
08/11/2021 08:00	10.0	13.6	8.1	129.5	3,266,077.2	1,764.9	1.3	0.9
08/11/2021 09:00	10.8	13.2	8.3	158.0	3,233,380.2	2,101.4	1.7	1.5
08/11/2021 10:00	10.9	13.1	8.2	185.5	3,181,100.8	2,206.8	2.0	1.8
08/11/2021 11:00	10.3	13.4	8.1	189.6	3,162,649.6	2,194.0	2.1	1.8
08/11/2021 12:00	10.1	13.4	7.9	182.5	3,164,548.3	2,149.1	2.0	1.7
08/11/2021 13:00	10.1	13.4	7.9	183.0	3,132,048.4	2,149.9	2.0	1.7
08/11/2021 14:00	10.2	13.4	8.0	173.8	3,113,546.6	2,137.2	1.9	1.5
08/11/2021 15:00	10.6	13.2	8.1	151.5	3,046,969.3	2,002.5	1.7	1.4
08/11/2021 16:00	10.7	13.1	8.1	160.2	3,142,391.9	2,157.0	1.8	1.5
08/11/2021 17:00	10.7	13.1	8.1	162.6	3,130,792.4	2,171.9	1.8	1.5
08/11/2021 18:00	10.7	13.0	8.0	166.0	3,116,558.4	2,230.3	1.8	1.6
08/11/2021 19:00	10.7	13.0	8.0	166.9	3,104,581.9	2,244.4	1.9	1.6
08/11/2021 20:00	10.8	13.0	8.1	167.9	3,116,339.6	2,252.9	1.9	1.6
08/11/2021 21:00	10.7	13.0	8.0	165.1	3,165,652.7	2,219.2	1.8	1.6
08/11/2021 22:00	10.7	13.1	8.1	160.3	3,183,249.1	2,161.8	1.7	1.5
08/11/2021 23:00	10.6	13.1	8.0	160.1	3,221,273.2	2,164.1	1.7	1.5
Average/Sum#:	10.5	13.3	8.2	158.9	3,148,357.6	2,034.4	1.7	1.4
Minimum:	10.0	13.0	7.9	127.0	3,042,898.0	1,622.4	1.3	0.8
Maximum:	10.9	13.7	8.8	189.6	3,266,077.2	2,252.9	2.1	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
08/12/2021 00:00	10.5	13.1	7.9	155.4	3,226,668.2	2,120.6	1.7	1.5
08/12/2021 01:00	10.3	13.7	8.4	129.9	3,176,689.4	1,693.4	1.4	0.8
08/12/2021 02:00	10.4	13.6	8.4	125.6	3,055,296.8	1,651.0	1.4	0.8
08/12/2021 03:00	10.3	13.2	7.9	147.1	3,230,897.1	2,052.6	1.6	1.2
08/12/2021 04:00	10.2	13.2	7.8	147.0	3,200,832.7	2,033.5	1.6	1.2
08/12/2021 05:00	10.0	13.7	8.2	138.6	3,187,944.9	1,699.4	1.5	1.0
08/12/2021 06:00	9.7	13.6	7.8	126.3	3,295,686.3	1,780.9	1.3	0.9
08/12/2021 07:00	10.7	13.2	8.2	152.1	3,261,140.9	2,048.0	1.6	1.2
08/12/2021 08:00	10.6	13.2	8.1	153.2	3,187,053.3	1,978.2	1.6	1.2
08/12/2021 09:00	10.3	13.7	8.4	136.5	3,207,079.4	1,709.6	1.4	0.9
08/12/2021 10:00	10.2	13.7	8.4	136.0	3,230,903.6	1,722.3	1.4	0.9
08/12/2021 11:00	10.9	13.2	8.4	156.1	3,218,301.2	2,091.6	1.7	1.5
08/12/2021 12:00	10.9	13.1	8.2	172.8	3,152,915.6	2,141.2	1.9	1.5
08/12/2021 13:00	10.8	13.1	8.2	170.2	3,162,477.2	2,124.6	1.9	1.5
08/12/2021 14:00	10.7	13.1	8.1	169.3	3,143,275.5	2,111.7	1.9	1.5
08/12/2021 15:00	10.8	13.1	8.2	169.0	3,120,667.8	2,119.3	1.9	1.5
08/12/2021 16:00	10.8	13.1	8.2	175.0	3,142,166.3	2,133.9	1.9	1.5
08/12/2021 17:00	10.9	13.1	8.2	177.2	3,124,909.9	2,145.0	2.0	1.7
08/12/2021 18:00	10.9	13.0	8.1	188.8	3,132,700.9	2,196.1	2.1	1.8
08/12/2021 19:00	10.8	13.0	8.1	188.6	3,111,416.9	2,203.9	2.1	1.8
08/12/2021 20:00	10.7	13.0	8.0	194.4	3,161,817.4	2,239.6	2.2	1.8
08/12/2021 21:00	10.5	13.0	7.8	182.2	3,172,884.2	2,201.1	2.0	1.8
08/12/2021 22:00	10.4	13.1	7.9	169.7	3,228,681.3	2,145.5	1.8	1.5
08/12/2021 23:00	10.4	13.2	8.0	160.8	3,240,556.1	2,082.4	1.7	1.5
Average/Sum#:	10.5	13.3	8.1	159.2	3,182,206.8	2,017.7	1.7	1.4
Minimum:	9.7	13.0	7.8	125.6	3,055,296.8	1,651.0	1.3	0.8
Maximum:	10.9	13.7	8.4	194.4	3,295,686.3	2,239.6	2.2	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
08/13/2021 00:00	10.3	13.3	8.0	149.1	3,228,418.0	1,980.3	1.6	1.2
08/13/2021 01:00	10.4	13.7	8.5	138.6	3,063,069.2	1,655.2	1.5	1.0
08/13/2021 02:00	10.5	13.7	8.6	113.7	2,818,012.8	1,502.2	1.3	0.8
08/13/2021 03:00	10.4	13.2	8.0	146.8	3,249,198.2	2,040.5	1.5	1.2
08/13/2021 04:00	10.3	13.3	8.0	144.9	3,240,091.1	1,963.8	1.5	1.2
08/13/2021 05:00	10.2	13.7	8.4	133.7	3,160,368.8	1,684.7	1.4	0.8
08/13/2021 06:00	10.6	13.7	8.7	128.4	3,100,151.7	1,652.6	1.4	0.8
08/13/2021 07:00	10.7	13.7	8.8	124.8	2,942,949.3	1,568.8	1.4	0.8
08/13/2021 08:00	10.7	13.2	8.2	147.8	3,237,574.0	2,033.2	1.6	1.2
08/13/2021 09:00	10.8	13.2	8.3	154.8	3,204,614.2	1,989.1	1.7	1.4
08/13/2021 10:00	10.8	13.7	8.9	133.9	3,000,165.0	1,599.3	1.5	1.0
08/13/2021 11:00	10.5	13.7	8.6	120.7	3,001,478.1	1,600.0	1.3	0.8
08/13/2021 12:00	10.9	13.2	8.4	158.0	3,231,063.5	2,076.3	1.7	1.5
08/13/2021 13:00	10.9	13.1	8.2	166.9	3,214,495.5	2,112.6	1.8	1.5
08/13/2021 14:00	10.8	13.1	8.2	164.6	3,203,540.1	2,105.4	1.8	1.5
08/13/2021 15:00	10.8	13.1	8.2	164.3	3,163,370.3	2,102.1	1.8	1.5
08/13/2021 16:00	10.9	13.1	8.2	169.5	3,139,703.1	2,109.3	1.9	1.5
08/13/2021 17:00	10.9	13.1	8.2	171.5	3,135,098.3	2,129.1	1.9	1.5
08/13/2021 18:00	10.9	13.0	8.1	183.5	3,142,180.3	2,179.8	2.0	1.7
08/13/2021 19:00	10.9	13.0	8.1	189.7	3,168,220.4	2,221.0	2.1	1.8
08/13/2021 20:00	10.8	13.0	8.1	186.8	3,170,289.5	2,199.3	2.1	1.8
08/13/2021 21:00	10.8	13.1	8.2	174.9	3,169,324.3	2,129.2	1.9	1.5
08/13/2021 22:00	10.8	13.1	8.2	173.0	3,199,788.0	2,126.3	1.9	1.5
08/13/2021 23:00	10.8	13.1	8.2	169.1	3,197,831.7	2,125.0	1.8	1.5
Average/Sum#:	10.7	13.3	8.3	154.5	3,140,874.8	1,953.5	1.7	1.3
Minimum:	10.2	13.0	8.0	113.7	2,818,012.8	1,502.2	1.3	0.8
Maximum:	10.9	13.7	8.9	189.7	3,249,198.2	2,221.0	2.1	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
08/14/2021 00:00	10.5	13.2	8.0	158.4	3,163,685.1	2,009.9	1.7	1.4
08/14/2021 01:00	10.1	13.7	8.3	142.3	3,208,767.7	1,710.5	1.5	1.0
08/14/2021 02:00	10.3	13.6	8.3	133.8	3,240,724.3	1,751.2	1.4	0.9
08/14/2021 03:00	10.6	13.2	8.1	151.2	3,234,674.8	2,055.0	1.6	1.2
08/14/2021 04:00	10.4	13.2	8.0	150.5	3,183,025.6	1,975.7	1.6	1.2
08/14/2021 05:00	10.3	13.7	8.4	141.7	3,222,274.3	1,717.7	1.5	1.0
08/14/2021 06:00	10.9	13.7	8.9	132.0	3,058,881.4	1,630.6	1.4	0.8
08/14/2021 07:00	10.9	13.7	8.9	118.3	2,851,029.0	1,519.8	1.4	0.8
08/14/2021 08:00	10.9	13.8	9.1	100.4	2,505,476.0	1,317.3	1.3	0.7
08/14/2021 09:00	10.2	13.8	8.5	117.7	2,991,723.3	1,594.8	1.3	0.8
08/14/2021 10:00	10.0	13.7	8.2	124.1	3,123,975.9	1,665.3	1.3	0.8
08/14/2021 11:00	10.3	13.7	8.4	133.4	3,168,998.1	1,689.3	1.4	0.8
08/14/2021 12:00	10.5	13.7	8.6	135.5	3,176,689.4	1,693.4	1.4	0.8
08/14/2021 13:00	10.6	13.4	8.3	155.1	3,148,752.9	2,046.4	1.7	1.4
08/14/2021 14:00	10.4	13.4	8.2	171.7	3,078,259.9	2,090.5	1.9	1.5
08/14/2021 15:00	10.5	13.7	8.6	131.9	2,987,783.9	1,592.7	1.5	1.0
08/14/2021 16:00	10.5	13.8	8.7	116.2	2,871,987.2	1,510.0	1.3	0.8
08/14/2021 17:00	10.6	13.4	8.3	163.6	3,122,588.6	2,075.0	1.8	1.5
08/14/2021 18:00	10.6	13.4	8.3	192.8	3,066,951.7	2,194.8	2.2	1.8
08/14/2021 19:00	10.5	13.3	8.2	199.6	3,057,412.8	2,210.3	2.3	2.0
08/14/2021 20:00	10.3	13.4	8.1	195.2	3,108,593.4	2,201.9	2.2	1.8
08/14/2021 21:00	10.1	13.4	7.9	187.2	3,142,180.3	2,179.8	2.1	1.7
08/14/2021 22:00	10.1	13.4	7.9	178.9	3,158,952.8	2,145.3	2.0	1.7
08/14/2021 23:00	10.1	13.4	7.9	172.9	3,192,564.6	2,121.5	1.9	1.5
Average/Sum#:	10.4	13.5	8.3	150.2	3,086,081.4	1,862.4	1.7	1.2
Minimum:	10.0	13.2	7.9	100.4	2,505,476.0	1,317.3	1.3	0.7
Maximum:	10.9	13.8	9.1	199.6	3,240,724.3	2,210.3	2.3	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
08/15/2021 00:00	10.0	13.4	7.9	153.6	3,211,541.8	1,993.4	1.6	1.2
08/15/2021 01:00	10.2	13.7	8.4	140.6	3,202,952.3	1,707.4	1.5	1.0
08/15/2021 02:00	10.5	13.6	8.5	128.8	3,044,748.6	1,645.3	1.4	0.8
08/15/2021 03:00	10.6	13.2	8.1	150.2	3,238,924.8	2,057.7	1.6	1.2
08/15/2021 04:00	10.4	13.2	8.0	147.4	3,215,375.8	1,972.3	1.6	1.2
08/15/2021 05:00	10.3	13.7	8.4	140.5	3,165,433.8	1,687.4	1.5	1.0
08/15/2021 06:00	11.0	13.7	9.0	129.2	3,013,484.0	1,606.4	1.4	0.8
08/15/2021 07:00	10.6	13.7	8.7	140.4	3,159,243.3	1,684.1	1.5	1.0
08/15/2021 08:00	11.1	13.7	9.1	116.3	2,838,460.3	1,513.1	1.4	0.8
08/15/2021 09:00	10.8	13.7	8.9	137.6	3,073,513.6	1,638.4	1.5	1.0
08/15/2021 10:00	10.4	13.7	8.5	131.1	3,183,442.7	1,697.0	1.4	0.8
08/15/2021 11:00	10.8	13.7	8.9	118.1	2,858,345.1	1,523.7	1.4	0.8
08/15/2021 12:00	10.7	13.5	8.5	135.9	2,977,906.3	1,761.4	1.5	1.1
08/15/2021 13:00	10.6	13.4	8.3	171.0	3,058,233.9	2,076.9	1.9	1.5
08/15/2021 14:00	10.7	13.7	8.8	145.2	3,042,712.9	1,644.2	1.6	1.0
08/15/2021 15:00	10.8	13.7	8.9	135.8	3,062,514.1	1,654.9	1.5	1.0
08/15/2021 16:00	11.4	13.1	8.6	163.2	3,112,016.9	2,090.7	1.8	1.5
08/15/2021 17:00	11.5	13.0	8.6	180.6	3,062,090.0	2,146.6	2.0	1.7
08/15/2021 18:00	11.3	13.0	8.4	189.4	3,061,781.4	2,191.1	2.2	1.8
08/15/2021 19:00	11.0	13.0	8.2	187.6	3,110,019.8	2,180.2	2.1	1.7
08/15/2021 20:00	10.8	13.0	8.1	182.5	3,118,395.5	2,163.3	2.0	1.7
08/15/2021 21:00	10.8	13.1	8.2	181.5	3,145,451.3	2,159.1	2.0	1.7
08/15/2021 22:00	10.8	13.1	8.2	174.8	3,144,375.1	2,135.4	1.9	1.5
08/15/2021 23:00	10.7	13.1	8.1	172.1	3,165,305.4	2,126.5	1.9	1.5
Average/Sum#:	10.7	13.4	8.5	152.2	3,094,427.9	1,877.4	1.7	1.2
Minimum:	10.0	13.0	7.9	116.3	2,838,460.3	1,513.1	1.4	0.8
Maximum:	11.5	13.7	9.1	189.4	3,238,924.8	2,191.1	2.2	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
08/16/2021 00:00	10.6	13.2	8.1	158.1	3,145,111.3	1,998.1	1.7	1.4
08/16/2021 01:00	10.2	13.7	8.4	137.4	3,203,890.3	1,707.9	1.4	0.9
08/16/2021 02:00	10.6	13.7	8.7	118.5	2,853,954.4	1,542.2	1.4	0.8
08/16/2021 03:00	10.7	13.2	8.2	152.9	3,198,156.9	2,031.8	1.6	1.2
08/16/2021 04:00	10.6	13.2	8.1	154.6	3,189,007.2	2,002.7	1.7	1.4
08/16/2021 05:00	10.3	13.6	8.3	142.0	3,218,522.5	1,715.7	1.5	1.0
08/16/2021 06:00	10.3	13.6	8.3	130.5	3,239,058.8	1,750.3	1.4	0.9
08/16/2021 07:00	10.9	13.2	8.4	150.8	3,160,880.5	2,031.2	1.6	1.2
08/16/2021 08:00	10.8	13.1	8.2	159.7	3,131,827.4	2,035.4	1.8	1.4
08/16/2021 09:00	10.2	13.7	8.4	139.7	3,119,511.7	1,685.7	1.5	1.0
08/16/2021 10:00	10.7	13.7	8.8	131.4	3,060,382.1	1,631.4	1.4	0.8
08/16/2021 11:00	11.1	13.1	8.4	161.9	3,142,753.7	2,088.4	1.8	1.5
08/16/2021 12:00	11.1	13.1	8.4	177.2	3,103,057.4	2,130.0	2.0	1.7
08/16/2021 13:00	11.1	13.1	8.4	178.6	3,093,005.2	2,123.1	2.0	1.7
08/16/2021 14:00	11.0	13.1	8.3	172.2	3,101,746.2	2,083.8	1.9	1.5
08/16/2021 15:00	11.2	13.0	8.4	187.0	3,076,925.4	2,157.0	2.1	1.7
08/16/2021 16:00	11.2	13.0	8.4	191.6	3,075,275.4	2,178.3	2.2	1.7
08/16/2021 17:00	11.2	12.9	8.3	198.8	3,059,211.1	2,211.6	2.3	2.0
08/16/2021 18:00	11.1	12.9	8.2	203.1	3,069,017.0	2,241.1	2.3	2.0
08/16/2021 19:00	11.0	12.9	8.1	197.8	3,082,588.1	2,228.5	2.2	1.8
08/16/2021 20:00	10.8	13.0	8.1	190.6	3,108,169.8	2,201.6	2.1	1.8
08/16/2021 21:00	10.8	13.0	8.1	193.2	3,088,331.5	2,210.1	2.2	1.8
08/16/2021 22:00	10.6	13.1	8.0	179.0	3,157,333.1	2,144.2	2.0	1.7
08/16/2021 23:00	10.6	13.1	8.0	177.8	3,183,167.4	2,138.5	1.9	1.5
Average/Sum#:	10.8	13.2	8.3	166.0	3,119,203.5	2,011.2	1.8	1.4
Minimum:	10.2	12.9	8.0	118.5	2,853,954.4	1,542.2	1.4	0.8
Maximum:	11.2	13.7	8.8	203.1	3,239,058.8	2,241.1	2.3	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
08/17/2021 00:00	10.5	13.2	8.0	168.4	3,198,062.4	2,101.8	1.8	1.5
08/17/2021 01:00	10.2	13.7	8.4	137.4	3,128,209.4	1,690.4	1.5	1.0
08/17/2021 02:00	10.5	13.6	8.5	131.9	3,056,407.2	1,651.6	1.5	1.0
08/17/2021 03:00	10.6	13.2	8.1	159.6	3,213,223.5	2,088.3	1.7	1.5
08/17/2021 04:00	10.6	13.1	8.0	179.0	3,193,703.8	2,168.9	1.9	1.5
08/17/2021 05:00	10.6	13.1	8.0	222.7	3,163,513.0	2,217.7	2.5	2.2
08/17/2021 06:00	10.6	13.2	8.1	170.0	3,166,380.1	2,104.1	1.9	1.5
08/17/2021 07:00	10.5	13.7	8.6	140.0	3,121,162.0	1,663.8	1.5	1.0
08/17/2021 08:00	10.3	13.7	8.4	120.8	3,016,110.3	1,607.8	1.3	0.8
08/17/2021 09:00	10.5	13.2	8.0	150.9	3,255,408.4	2,044.4	1.6	1.2
08/17/2021 10:00	10.3	13.3	8.0	151.1	3,211,789.3	1,970.1	1.6	1.2
08/17/2021 11:00	10.5	13.7	8.6	141.0	3,119,848.9	1,663.1	1.5	1.0
08/17/2021 12:00	10.8	13.8	9.0	109.5	2,788,373.2	1,486.4	1.3	0.7
08/17/2021 13:00	10.3	13.6	8.3	140.7	3,258,859.9	1,761.0	1.5	1.1
08/17/2021 14:00	10.5	13.3	8.2	138.8	3,165,938.0	1,849.5	1.5	1.1
08/17/2021 15:00	10.4	13.3	8.1	146.8	3,089,619.4	1,872.6	1.6	1.1
08/17/2021 16:00	10.4	13.7	8.5	124.7	2,936,383.5	1,565.3	1.4	0.8
08/17/2021 17:00	10.7	13.2	8.2	152.8	3,196,451.9	2,077.4	1.6	1.2
08/17/2021 18:00	10.7	13.0	8.0	183.0	3,159,910.7	2,192.1	2.0	1.8
08/17/2021 19:00	10.7	13.0	8.0	197.2	3,158,570.3	2,237.3	2.2	1.8
08/17/2021 20:00	10.7	13.0	8.0	199.1	3,155,265.6	2,258.0	2.2	1.8
08/17/2021 21:00	10.6	13.0	7.9	191.4	3,169,361.6	2,221.8	2.1	1.8
08/17/2021 22:00	10.4	13.1	7.9	176.3	3,231,246.1	2,170.8	1.9	1.5
08/17/2021 23:00	10.0	13.3	7.8	157.1	3,274,213.1	2,032.3	1.6	1.2
Average/Sum#:	10.5	13.3	8.2	157.9	3,142,833.8	1,945.7	1.7	1.3
Minimum:	10.0	13.0	7.8	109.5	2,788,373.2	1,486.4	1.3	0.7
Maximum:	10.8	13.8	9.0	222.7	3,274,213.1	2,258.0	2.5	2.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
08/18/2021 00:00	10.2	13.7	8.4	135.0	3,094,711.5	1,649.7	1.5	1.0
08/18/2021 01:00	10.3	13.8	8.6	123.6	2,972,221.5	1,562.7	1.4	0.8
08/18/2021 02:00	10.2	13.3	7.9	145.9	3,315,510.0	1,985.3	1.5	1.2
08/18/2021 03:00	10.1	13.3	7.8	144.7	3,281,775.4	1,965.1	1.5	1.2
08/18/2021 04:00	10.0	13.7	8.2	134.7	3,218,710.1	1,715.8	1.4	0.9
08/18/2021 05:00	10.3	13.7	8.4	138.4	3,136,537.0	1,694.9	1.5	1.0
08/18/2021 06:00	10.4	13.3	8.1	141.8	3,313,681.0	2,032.6	1.4	1.0
08/18/2021 07:00	10.2	13.3	7.9	148.1	3,270,119.4	1,982.0	1.5	1.2
08/18/2021 08:00	10.4	13.8	8.6	156.5	2,774,796.2	1,458.9	1.9	1.0
08/18/2021 09:00	9.6	13.9	8.1	160.8	1,028,116.7	1,569.1	5.7	3.5
08/18/2021 10:00	9.4	13.9	7.9	111.9	3,059,175.0	1,541.4	1.2	0.8
08/18/2021 11:00	9.5	13.9	8.0	99.9	2,941,285.4	1,482.0	1.1	0.6
08/18/2021 12:00	9.7	13.8	8.1	115.4	2,989,062.2	1,527.9	1.3	0.8
08/18/2021 13:00	10.3	13.2	7.9	147.3	3,386,505.9	2,102.0	1.5	1.3
08/18/2021 14:00	10.2	13.2	7.8	160.5	3,250,048.7	2,088.5	1.7	1.5
08/18/2021 15:00	9.9	13.7	8.1	166.1	3,264,052.0	1,692.3	1.7	1.2
08/18/2021 16:00	10.5	13.8	8.7	125.1	3,027,406.0	1,547.5	1.4	0.8
08/18/2021 17:00	10.4	13.3	8.1	155.5	3,286,940.7	2,040.2	1.6	1.2
08/18/2021 18:00	10.4	13.1	7.9	176.9	3,293,390.4	2,188.5	1.9	1.5
08/18/2021 19:00	10.1	13.3	7.8	157.3	3,268,735.5	2,028.9	1.7	1.4
08/18/2021 20:00	9.8	13.7	8.0	138.3	3,326,929.7	1,724.9	1.4	0.9
08/18/2021 21:00	10.1	13.6	8.2	137.0	3,327,891.5	1,749.7	1.4	0.9
08/18/2021 22:00	10.4	13.2	8.0	151.9	3,349,934.3	2,079.3	1.5	1.2
08/18/2021 23:00	10.1	13.3	7.8	151.4	3,287,620.5	1,968.6	1.6	1.2
Average/Sum#:	10.1	13.5	8.1	142.7	3,192,914.8	1,807.4	1.5	1.1
Minimum:	9.4	13.1	7.8	99.9	2,774,796.2	1,458.9	1.1	0.6
Maximum:	10.5	13.9	8.7	176.9	3,386,505.9	2,188.5	1.9	1.5
%SI	0.00	0.00	0.00	0.00	4.17	0.00	4.17	4.17

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
08/19/2021 00:00	10.4	13.7	8.5	132.8	3,140,610.9	1,628.3	1.4	0.8
08/19/2021 01:00	10.5	13.7	8.6	138.2	3,202,717.2	1,660.5	1.5	1.0
08/19/2021 02:00	10.8	13.7	8.9	120.0	2,936,740.2	1,522.6	1.4	0.8
08/19/2021 03:00	10.4	13.7	8.5	121.0	3,004,825.7	1,557.9	1.3	0.8
08/19/2021 04:00	10.4	13.2	8.0	154.8	3,335,756.7	2,070.5	1.6	1.2
08/19/2021 05:00	10.3	13.3	8.0	177.2	3,365,740.8	1,990.8	1.8	1.4
08/19/2021 06:00	10.5	13.7	8.6	136.7	3,221,426.2	1,670.2	1.4	0.8
08/19/2021 07:00	10.6	13.7	8.7	144.0	3,280,832.2	1,701.0	1.5	1.0
08/19/2021 08:00	10.7	13.9	9.0	98.2	2,668,616.9	1,364.1	1.2	0.7
08/19/2021 09:00	0.0	0.0	0.0	154.2	1,106,219.7	1,688.3	5.2	3.4
08/19/2021 10:00	9.7	13.8	8.1	138.8	3,283,840.0	1,654.6	1.4	0.8
08/19/2021 11:00	9.7	13.8	8.1	123.2	3,176,477.7	1,623.7	1.3	0.8
08/19/2021 12:00	9.9	13.7	8.1	116.1	3,341,395.5	1,708.0	1.1	0.7
08/19/2021 13:00	10.4	13.2	8.0	129.5	1,388,229.4	2,118.7	3.3	2.8
08/19/2021 14:00	10.3	13.2	7.9	129.2	3,346,612.4	2,052.8	1.3	1.0
08/19/2021 15:00	10.6	13.7	8.7	104.6	3,102,724.4	1,586.0	1.1	0.6
08/19/2021 16:00	10.2	13.7	8.4	107.4	3,266,077.2	1,669.5	1.1	0.7
08/19/2021 17:00	10.6	13.2	8.1	129.9	3,330,408.3	2,091.5	1.3	1.0
08/19/2021 18:00	10.6	13.1	8.0	142.9	3,299,247.7	2,168.3	1.5	1.3
08/19/2021 19:00	10.4	13.2	8.0	133.9	3,277,016.8	2,081.9	1.4	1.0
08/19/2021 20:00	10.0	13.7	8.2	110.2	3,354,307.2	1,714.6	1.1	0.7
08/19/2021 21:00	10.5	13.6	8.5	105.1	3,126,916.6	1,621.2	1.1	0.6
08/19/2021 22:00	10.7	13.2	8.2	125.4	3,331,613.9	2,043.6	1.2	1.0
08/19/2021 23:00	10.5	13.3	8.2	120.2	3,319,924.3	1,963.7	1.2	1.0
Average/Sum#:	10.4	13.5	8.3	128.9	3,214,264.9	1,789.7	1.3	0.9
Minimum:	9.7	13.1	7.9	98.2	2,668,616.9	1,364.1	1.1	0.6
Maximum:	10.8	13.9	9.0	177.2	3,365,740.8	2,168.3	1.8	1.4
%SI	4.17	4.17	4.17	0.00	8.33	0.00	8.33	8.33

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
08/20/2021 00:00	10.4	13.7	8.5	110.2	3,306,964.3	1,690.4	1.1	0.7
08/20/2021 01:00	10.7	13.7	8.8	110.0	3,302,269.1	1,688.0	1.1	0.7
08/20/2021 02:00	10.8	13.7	8.9	102.0	3,026,036.6	1,546.8	1.1	0.6
08/20/2021 03:00	11.0	13.8	9.1	92.0	2,652,379.4	1,355.8	1.1	0.5
08/20/2021 04:00	10.4	13.7	8.5	107.3	3,233,602.2	1,652.9	1.1	0.7
08/20/2021 05:00	9.8	13.7	8.0	113.7	3,158,440.4	1,729.8	1.2	0.9
08/20/2021 06:00	10.4	13.4	8.2	116.6	3,275,031.1	1,865.4	1.2	0.9
08/20/2021 07:00	10.7	13.7	8.8	108.8	3,248,861.5	1,660.7	1.1	0.7
08/20/2021 08:00	10.8	13.7	8.9	100.3	2,986,518.9	1,526.6	1.1	0.6
08/20/2021 09:00	11.4	13.9	9.6	91.2	2,619,768.4	1,320.0	1.1	0.5
08/20/2021 10:00	11.2	13.9	9.4	90.7	2,596,547.7	1,308.3	1.1	0.5
08/20/2021 11:00	10.9	13.9	9.2	90.1	2,600,517.1	1,310.3	1.1	0.5
08/20/2021 12:00	10.4	13.8	8.6	99.1	2,982,215.0	1,524.4	1.1	0.6
08/20/2021 13:00	10.8	13.2	8.3	127.4	3,297,287.3	2,070.7	1.3	1.0
08/20/2021 14:00	10.6	13.2	8.1	126.1	3,268,033.5	2,004.6	1.3	1.0
08/20/2021 15:00	10.8	13.7	8.9	105.7	3,020,558.9	1,544.0	1.1	0.6
08/20/2021 16:00	10.6	13.7	8.7	101.0	2,995,181.9	1,552.9	1.1	0.6
08/20/2021 17:00	10.9	13.1	8.2	132.4	3,294,646.2	2,093.1	1.3	1.0
08/20/2021 18:00	10.8	13.1	8.2	143.7	3,280,988.7	2,156.3	1.5	1.3
08/20/2021 19:00	10.5	13.1	7.9	139.5	3,257,051.4	2,093.0	1.5	1.3
08/20/2021 20:00	10.4	13.7	8.5	109.8	3,280,358.3	1,676.8	1.1	0.7
08/20/2021 21:00	10.5	13.6	8.5	111.7	3,276,728.2	1,722.8	1.1	0.7
08/20/2021 22:00	10.7	13.2	8.2	126.8	3,324,962.4	2,063.8	1.3	1.0
08/20/2021 23:00	10.4	13.3	8.1	119.2	3,286,787.6	1,944.1	1.2	1.0
Average/Sum#:	10.7	13.6	8.6	111.5	3,107,155.7	1,712.6	1.2	0.8
Minimum:	9.8	13.1	7.9	90.1	2,596,547.7	1,308.3	1.1	0.5
Maximum:	11.4	13.9	9.6	143.7	3,324,962.4	2,156.3	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
08/21/2021 00:00	21.8	16.0	26.2	173.8	1,567,727.6	595.3	3.7	0.8
08/21/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/21/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/21/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/21/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/21/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/21/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/21/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/21/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/21/2021 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/21/2021 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/21/2021 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/21/2021 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/21/2021 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/21/2021 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/21/2021 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/21/2021 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/21/2021 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/21/2021 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/21/2021 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/21/2021 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/21/2021 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/21/2021 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/21/2021 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	21.8	16.0	26.2	173.8	1,567,727.6	595.3	3.7	0.8
Minimum:	21.8	16.0	26.2	173.8	1,567,727.6	595.3	3.7	0.8
Maximum:	21.8	16.0	26.2	173.8	1,567,727.6	595.3	3.7	0.8
%SI	95.83	95.83	95.83	95.83	95.83	95.83	95.83	95.83

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
08/22/2021 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/22/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/22/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/22/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/22/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/22/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/22/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/22/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/22/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/22/2021 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/22/2021 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/22/2021 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/22/2021 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/22/2021 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/22/2021 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/22/2021 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/22/2021 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/22/2021 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/22/2021 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/22/2021 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/22/2021 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/22/2021 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/22/2021 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/22/2021 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
08/23/2021 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/23/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/23/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/23/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/23/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/23/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/23/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/23/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/23/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/23/2021 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/23/2021 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/23/2021 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/23/2021 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/23/2021 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/23/2021 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/23/2021 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/23/2021 16:00	37.7	17.2	60.1	9.4	1,416,249.9	320.6	0.0	0.0
08/23/2021 17:00	45.0	15.5	49.2	255.3	2,146,435.8	783.7	3.8	1.2
08/23/2021 18:00	9.5	13.6	7.7	117.7	3,430,609.5	1,703.5	1.1	0.7
08/23/2021 19:00	10.0	13.4	7.9	114.9	3,414,181.3	1,820.0	1.1	0.7
08/23/2021 20:00	10.2	13.3	7.9	119.1	3,309,266.7	1,884.9	1.2	0.9
08/23/2021 21:00	9.9	13.5	7.9	113.4	3,549,190.8	1,788.3	1.0	0.7
08/23/2021 22:00	10.3	13.3	8.0	122.4	3,515,953.8	2,028.3	1.1	0.8
08/23/2021 23:00	10.2	13.3	7.9	118.5	3,494,522.0	1,964.9	1.1	0.8
Average/Sum#:	17.9	14.1	19.6	121.3	3,034,551.2	1,536.8	1.3	0.7
Minimum:	9.5	13.3	7.7	9.4	1,416,249.9	320.6	0.0	0.0
Maximum:	45.0	17.2	60.1	255.3	3,549,190.8	2,028.3	3.8	1.2
%SI	66.67	66.67	66.67	66.67	66.67	66.67	66.67	66.67

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
08/24/2021 00:00	10.5	13.7	8.6	102.0	3,193,415.9	1,562.4	1.0	0.6
08/24/2021 01:00	10.4	13.7	8.5	105.8	3,330,358.3	1,629.4	1.0	0.7
08/24/2021 02:00	10.0	13.6	8.1	106.9	3,384,089.3	1,680.4	1.0	0.7
08/24/2021 03:00	9.8	13.3	7.6	114.9	3,557,947.1	1,948.6	1.1	0.8
08/24/2021 04:00	9.7	13.3	7.5	114.4	3,516,864.4	1,926.1	1.1	0.8
08/24/2021 05:00	9.7	13.7	7.9	109.1	3,407,414.0	1,667.1	1.0	0.7
08/24/2021 06:00	10.5	13.7	8.6	106.3	3,303,787.4	1,616.4	1.0	0.6
08/24/2021 07:00	10.2	13.7	8.4	107.8	3,390,245.1	1,658.7	1.0	0.7
08/24/2021 08:00	10.3	13.7	8.4	100.9	3,156,829.8	1,544.5	1.0	0.6
08/24/2021 09:00	9.5	13.8	7.9	108.2	3,484,469.7	1,704.8	1.0	0.7
08/24/2021 10:00	9.4	13.8	7.8	107.2	3,449,927.5	1,687.9	1.0	0.7
08/24/2021 11:00	9.5	13.8	7.9	105.3	3,376,959.7	1,652.2	1.0	0.7
08/24/2021 12:00	9.8	13.8	8.1	102.0	3,278,941.4	1,580.3	1.0	0.6
08/24/2021 13:00	9.8	13.7	8.0	105.7	3,395,559.3	1,661.3	1.0	0.7
08/24/2021 14:00	10.4	13.2	8.0	126.6	3,481,344.0	2,084.6	1.2	1.0
08/24/2021 15:00	10.5	13.2	8.0	128.1	3,472,158.8	2,079.1	1.2	1.0
08/24/2021 16:00	9.8	13.7	8.0	110.3	3,514,719.7	1,719.6	1.0	0.7
08/24/2021 17:00	9.9	13.6	8.0	111.5	3,514,459.0	1,770.8	1.0	0.7
08/24/2021 18:00	10.6	13.2	8.1	129.2	3,462,333.8	2,098.5	1.2	1.0
08/24/2021 19:00	10.6	13.1	8.0	147.1	3,391,607.7	2,154.7	1.5	1.3
08/24/2021 20:00	10.2	13.7	8.4	108.9	3,372,610.3	1,674.7	1.0	0.7
08/24/2021 21:00	9.9	13.5	7.9	113.8	3,569,037.5	1,798.3	1.0	0.7
08/24/2021 22:00	10.3	13.2	7.9	125.0	3,538,079.1	2,066.9	1.2	1.0
08/24/2021 23:00	10.4	13.1	7.9	135.4	3,528,061.1	2,164.1	1.3	1.1
Average/Sum#:	10.1	13.5	8.1	113.9	3,419,634.2	1,797.1	1.1	0.8
Minimum:	9.4	13.1	7.5	100.9	3,156,829.8	1,544.5	1.0	0.6
Maximum:	10.6	13.8	8.6	147.1	3,569,037.5	2,164.1	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
08/25/2021 00:00	10.3	13.6	8.3	107.5	3,229,885.2	1,651.0	1.1	0.7
08/25/2021 01:00	10.6	13.7	8.7	107.2	3,302,125.2	1,639.7	1.0	0.7
08/25/2021 02:00	10.7	13.7	8.8	104.3	3,203,848.9	1,590.9	1.0	0.6
08/25/2021 03:00	9.9	13.3	7.7	120.2	3,541,893.3	2,017.4	1.1	0.8
08/25/2021 04:00	9.9	13.2	7.6	126.4	3,531,424.3	2,088.8	1.2	1.0
08/25/2021 05:00	9.3	13.4	7.3	120.4	3,571,093.6	1,955.8	1.1	0.8
08/25/2021 06:00	10.2	13.7	8.4	107.7	3,284,779.0	1,607.1	1.1	0.6
08/25/2021 07:00	10.3	13.8	8.6	104.9	3,203,226.7	1,567.2	1.1	0.6
08/25/2021 08:00	10.1	13.7	8.3	107.5	3,307,764.0	1,642.5	1.1	0.7
08/25/2021 09:00	10.4	13.2	8.0	122.1	3,569,984.0	2,033.4	1.1	0.8
08/25/2021 10:00	10.3	13.3	8.0	118.2	3,554,557.2	1,972.7	1.1	0.8
08/25/2021 11:00	10.3	13.7	8.4	115.3	3,389,325.4	1,683.0	1.1	0.7
08/25/2021 12:00	10.2	13.7	8.4	105.6	3,324,076.3	1,650.6	1.0	0.7
08/25/2021 13:00	10.7	13.2	8.2	129.0	3,486,855.1	2,087.9	1.2	1.0
08/25/2021 14:00	10.5	13.2	8.0	131.0	3,428,015.7	2,077.7	1.3	1.0
08/25/2021 15:00	10.1	13.8	8.4	105.1	3,321,773.9	1,625.2	1.0	0.7
08/25/2021 16:00	10.3	13.8	8.6	96.7	3,030,106.9	1,482.5	1.0	0.6
08/25/2021 17:00	10.7	13.2	8.2	127.5	3,474,162.9	2,080.3	1.2	1.0
08/25/2021 18:00	10.8	13.1	8.2	144.7	3,424,348.0	2,175.5	1.4	1.1
08/25/2021 19:00	10.6	13.2	8.1	134.9	3,429,995.6	2,078.9	1.3	1.0
08/25/2021 20:00	10.3	13.7	8.4	108.5	3,356,902.2	1,666.9	1.0	0.7
08/25/2021 21:00	10.2	13.6	8.2	109.7	3,400,737.2	1,713.5	1.0	0.7
08/25/2021 22:00	10.5	13.2	8.0	124.9	3,521,988.3	2,057.5	1.2	1.0
08/25/2021 23:00	10.1	13.3	7.8	120.0	3,513,196.0	1,975.4	1.1	0.8
Average/Sum#:	10.3	13.5	8.2	116.6	3,391,752.7	1,838.4	1.1	0.8
Minimum:	9.3	13.1	7.3	96.7	3,030,106.9	1,482.5	1.0	0.6
Maximum:	10.8	13.8	8.8	144.7	3,571,093.6	2,175.5	1.4	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
08/26/2021 00:00	10.4	13.7	8.5	109.1	3,364,554.9	1,670.7	1.0	0.7
08/26/2021 01:00	10.5	13.7	8.6	107.4	3,295,680.9	1,636.5	1.1	0.7
08/26/2021 02:00	10.7	13.8	8.9	94.3	2,915,852.0	1,426.6	1.0	0.6
08/26/2021 03:00	10.2	13.7	8.4	101.8	3,205,057.2	1,591.5	1.0	0.6
08/26/2021 04:00	10.3	13.2	7.9	125.0	3,545,268.6	2,071.1	1.2	1.0
08/26/2021 05:00	10.3	13.2	7.9	129.6	3,556,276.8	2,103.5	1.2	1.1
08/26/2021 06:00	10.1	13.4	7.9	119.7	3,523,333.3	1,981.1	1.1	0.8
08/26/2021 07:00	10.2	13.7	8.4	115.5	3,420,741.6	1,698.6	1.1	0.7
08/26/2021 08:00	10.4	13.7	8.5	104.7	3,160,953.7	1,569.6	1.1	0.6
08/26/2021 09:00	10.2	13.4	8.0	116.8	3,452,059.8	1,865.4	1.1	0.7
08/26/2021 10:00	10.4	13.3	8.1	120.4	3,489,749.8	1,987.7	1.1	0.8
08/26/2021 11:00	9.9	13.7	8.1	111.6	3,477,532.4	1,726.8	1.0	0.7
08/26/2021 12:00	10.0	13.7	8.2	109.1	3,441,484.3	1,708.9	1.0	0.7
08/26/2021 13:00	10.8	13.2	8.3	126.4	3,494,399.1	2,066.9	1.2	1.0
08/26/2021 14:00	10.6	13.2	8.1	127.1	3,396,339.5	2,033.7	1.2	1.0
08/26/2021 15:00	9.7	13.7	7.9	110.4	3,475,317.1	1,725.7	1.0	0.7
08/26/2021 16:00	10.3	13.7	8.4	106.5	3,292,969.5	1,659.2	1.0	0.7
08/26/2021 17:00	10.9	13.1	8.2	142.6	3,424,834.8	2,150.8	1.4	1.1
08/26/2021 18:00	11.0	13.0	8.2	166.6	3,360,979.7	2,282.5	1.7	1.6
08/26/2021 19:00	10.9	13.0	8.1	171.0	3,387,337.5	2,300.4	1.7	1.6
08/26/2021 20:00	10.7	13.0	8.0	160.5	3,384,434.5	2,249.0	1.6	1.3
08/26/2021 21:00	10.7	13.1	8.1	155.1	3,397,237.6	2,232.7	1.6	1.3
08/26/2021 22:00	10.6	13.1	8.0	151.3	3,408,481.9	2,215.2	1.5	1.3
08/26/2021 23:00	10.4	13.2	8.0	141.1	3,403,744.6	2,112.7	1.4	1.1
Average/Sum#:	10.4	13.4	8.2	126.0	3,386,442.5	1,919.5	1.2	0.9
Minimum:	9.7	13.0	7.9	94.3	2,915,852.0	1,426.6	1.0	0.6
Maximum:	11.0	13.8	8.9	171.0	3,556,276.8	2,300.4	1.7	1.6
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
08/27/2021 00:00	9.9	13.7	8.1	110.0	3,398,951.0	1,712.6	1.1	0.7
08/27/2021 01:00	9.8	13.7	8.0	106.9	3,377,040.8	1,676.9	1.0	0.7
08/27/2021 02:00	9.6	13.7	7.9	108.1	3,391,012.3	1,708.6	1.0	0.7
08/27/2021 03:00	9.9	13.6	8.0	111.2	3,438,820.3	1,757.8	1.1	0.7
08/27/2021 04:00	10.4	13.2	8.0	130.3	3,462,993.8	2,098.9	1.3	1.0
08/27/2021 05:00	10.5	13.1	7.9	145.7	3,449,645.2	2,116.0	1.4	1.1
08/27/2021 06:00	10.4	13.7	8.5	108.6	3,195,720.5	1,610.2	1.1	0.6
08/27/2021 07:00	10.0	13.7	8.2	111.8	3,371,165.6	1,698.6	1.1	0.7
08/27/2021 08:00	10.5	13.7	8.6	104.0	3,084,975.7	1,554.4	1.1	0.6
08/27/2021 09:00	10.5	13.3	8.2	120.9	3,403,190.8	1,988.1	1.2	1.0
08/27/2021 10:00	10.4	13.2	8.0	124.3	3,364,274.9	2,014.5	1.2	1.0
08/27/2021 11:00	9.6	13.7	7.9	110.1	3,453,331.1	1,740.0	1.0	0.7
08/27/2021 12:00	9.6	13.7	7.9	109.4	3,445,987.8	1,736.3	1.0	0.7
08/27/2021 13:00	10.2	13.5	8.1	134.2	3,377,967.2	2,096.7	1.3	1.0
08/27/2021 14:00	10.1	13.4	7.9	160.9	3,326,948.8	2,210.8	1.7	1.5
08/27/2021 15:00	10.1	13.4	7.9	158.5	3,277,687.5	2,202.0	1.7	1.5
08/27/2021 16:00	10.1	13.4	7.9	156.9	3,272,924.3	2,198.8	1.6	1.3
08/27/2021 17:00	10.1	13.4	7.9	164.2	3,269,243.0	2,220.2	1.7	1.6
08/27/2021 18:00	10.0	13.4	7.9	163.1	3,285,882.3	2,231.5	1.7	1.6
08/27/2021 19:00	9.9	13.4	7.8	167.7	3,283,968.0	2,230.2	1.8	1.6
08/27/2021 20:00	9.9	13.4	7.8	163.8	3,291,772.3	2,235.5	1.7	1.6
08/27/2021 21:00	10.2	13.2	7.8	165.8	3,323,283.8	2,256.9	1.7	1.6
08/27/2021 22:00	10.5	13.1	7.9	151.9	3,363,002.0	2,210.2	1.5	1.3
08/27/2021 23:00	10.3	13.1	7.8	143.8	3,333,840.1	2,118.0	1.5	1.3
Average/Sum#:	10.1	13.4	8.0	134.7	3,343,484.5	1,984.3	1.4	1.1
Minimum:	9.6	13.1	7.8	104.0	3,084,975.7	1,554.4	1.0	0.6
Maximum:	10.5	13.7	8.6	167.7	3,462,993.8	2,256.9	1.8	1.6
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
08/28/2021 00:00	9.9	13.7	8.1	109.8	3,380,890.5	1,703.5	1.1	0.7
08/28/2021 01:00	9.9	13.5	7.9	113.3	3,457,700.1	1,792.7	1.1	0.7
08/28/2021 02:00	10.4	13.2	8.0	126.6	3,414,486.5	2,069.5	1.2	1.0
08/28/2021 03:00	10.2	13.3	7.9	119.3	3,407,266.5	1,965.6	1.2	1.0
08/28/2021 04:00	10.2	13.7	8.4	108.2	3,315,991.7	1,670.8	1.1	0.7
08/28/2021 05:00	9.6	13.7	7.9	109.0	3,355,089.7	1,666.0	1.1	0.7
08/28/2021 06:00	9.7	13.8	8.1	106.2	3,334,145.6	1,655.6	1.0	0.7
08/28/2021 07:00	9.7	13.8	8.1	107.4	3,359,654.5	1,692.8	1.0	0.7
08/28/2021 08:00	9.2	13.8	7.6	104.4	3,332,937.3	1,655.0	1.0	0.7
08/28/2021 09:00	9.7	13.7	7.9	107.5	3,315,180.8	1,694.6	1.1	0.7
08/28/2021 10:00	9.4	13.8	7.8	106.1	3,281,855.3	1,653.6	1.1	0.7
08/28/2021 11:00	10.0	13.4	7.9	135.9	3,367,510.1	2,114.8	1.4	1.1
08/28/2021 12:00	9.9	13.4	7.8	144.7	3,262,922.9	2,120.6	1.5	1.3
08/28/2021 13:00	9.5	13.7	7.8	108.8	3,383,470.6	1,704.8	1.0	0.7
08/28/2021 14:00	9.5	13.7	7.8	108.6	3,419,988.5	1,723.2	1.0	0.7
08/28/2021 15:00	10.7	13.2	8.2	131.5	3,351,062.0	2,080.0	1.3	1.0
08/28/2021 16:00	10.8	13.1	8.2	149.6	3,303,322.5	2,195.1	1.5	1.3
08/28/2021 17:00	10.7	13.0	8.0	159.8	3,284,851.5	2,230.8	1.7	1.6
08/28/2021 18:00	10.8	13.0	8.1	171.2	3,307,305.6	2,270.2	1.8	1.6
08/28/2021 19:00	10.7	13.0	8.0	169.7	3,302,042.6	2,290.7	1.8	1.6
08/28/2021 20:00	10.6	13.0	7.9	171.7	3,306,943.7	2,294.1	1.8	1.6
08/28/2021 21:00	10.6	13.0	7.9	165.6	3,316,046.6	2,276.2	1.7	1.6
08/28/2021 22:00	10.4	13.1	7.9	152.2	3,363,002.0	2,210.2	1.5	1.3
08/28/2021 23:00	10.3	13.2	7.9	139.0	3,380,746.8	2,147.8	1.4	1.1
Average/Sum#:	10.1	13.4	8.0	130.3	3,346,017.2	1,953.3	1.3	1.0
Minimum:	9.2	13.0	7.6	104.4	3,262,922.9	1,653.6	1.0	0.7
Maximum:	10.8	13.8	8.4	171.7	3,457,700.1	2,294.1	1.8	1.6
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
08/29/2021 00:00	10.1	13.3	7.8	125.4	3,353,419.7	2,008.0	1.3	1.0
08/29/2021 01:00	9.9	13.7	8.1	109.6	3,352,155.3	1,713.5	1.1	0.7
08/29/2021 02:00	10.0	13.5	8.0	113.7	3,418,996.2	1,797.6	1.1	0.7
08/29/2021 03:00	10.5	13.2	8.0	127.1	3,387,532.1	2,077.9	1.2	1.0
08/29/2021 04:00	10.4	13.2	8.0	134.4	3,316,236.3	2,082.6	1.4	1.0
08/29/2021 05:00	9.2	13.7	7.5	111.4	3,404,905.0	1,715.6	1.1	0.7
08/29/2021 06:00	9.5	13.8	7.9	107.5	3,269,351.9	1,647.3	1.1	0.7
08/29/2021 07:00	9.4	13.8	7.8	105.6	3,218,544.2	1,621.7	1.1	0.6
08/29/2021 08:00	9.6	13.8	8.0	101.1	3,110,607.2	1,544.6	1.1	0.6
08/29/2021 09:00	9.9	13.8	8.2	99.1	3,012,129.5	1,495.7	1.1	0.6
08/29/2021 10:00	10.3	13.5	8.2	116.6	3,288,240.2	1,824.9	1.2	0.9
08/29/2021 11:00	10.4	13.4	8.2	126.8	3,336,610.8	2,022.3	1.3	1.0
08/29/2021 12:00	10.2	13.6	8.2	111.9	3,345,253.0	1,734.4	1.1	0.7
08/29/2021 13:00	10.2	13.7	8.4	109.9	3,355,089.7	1,715.0	1.1	0.7
08/29/2021 14:00	11.1	13.1	8.4	136.7	3,292,065.1	2,115.5	1.4	1.1
08/29/2021 15:00	11.1	13.0	8.3	152.0	3,255,508.8	2,187.1	1.6	1.3
08/29/2021 16:00	11.1	13.0	8.3	156.3	3,245,241.3	2,203.9	1.6	1.3
08/29/2021 17:00	11.1	12.9	8.2	164.2	3,241,355.4	2,248.6	1.7	1.6
08/29/2021 18:00	11.0	12.9	8.1	167.1	3,254,328.9	2,257.6	1.8	1.6
08/29/2021 19:00	10.9	12.9	8.0	168.1	3,234,979.8	2,267.8	1.8	1.6
08/29/2021 20:00	10.9	12.9	8.0	169.4	3,231,984.2	2,265.7	1.8	1.6
08/29/2021 21:00	10.8	13.0	8.1	166.2	3,233,410.7	2,266.7	1.8	1.6
08/29/2021 22:00	10.7	13.0	8.0	154.9	3,264,236.5	2,216.8	1.6	1.3
08/29/2021 23:00	10.5	13.1	7.9	137.1	3,265,998.5	2,074.9	1.4	1.0
Average/Sum#:	10.4	13.3	8.1	132.2	3,278,674.2	1,962.7	1.4	1.0
Minimum:	9.2	12.9	7.5	99.1	3,012,129.5	1,495.7	1.1	0.6
Maximum:	11.1	13.8	8.4	169.4	3,418,996.2	2,267.8	1.8	1.6
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
08/30/2021 00:00	10.5	13.7	8.6	109.5	3,229,885.2	1,651.0	1.1	0.7
08/30/2021 01:00	10.7	13.7	8.8	111.0	3,318,115.3	1,696.1	1.1	0.7
08/30/2021 02:00	10.7	13.2	8.2	120.2	3,357,456.6	1,985.9	1.2	1.0
08/30/2021 03:00	10.7	13.1	8.1	133.5	3,310,185.4	2,078.8	1.4	1.0
08/30/2021 04:00	10.5	13.7	8.6	108.3	3,240,840.6	1,656.6	1.1	0.7
08/30/2021 05:00	10.5	13.7	8.6	105.4	3,044,426.0	1,556.2	1.1	0.6
08/30/2021 06:00	10.9	13.2	8.4	127.6	3,368,131.9	2,066.0	1.3	1.0
08/30/2021 07:00	10.7	13.2	8.2	129.0	3,317,430.6	2,034.9	1.3	1.0
08/30/2021 08:00	10.3	13.7	8.4	110.1	3,316,550.2	1,695.3	1.1	0.7
08/30/2021 09:00	10.5	13.6	8.5	107.1	3,213,325.4	1,666.0	1.1	0.7
08/30/2021 10:00	10.7	13.3	8.3	123.6	3,312,992.6	1,959.6	1.2	1.0
08/30/2021 11:00	10.3	13.4	8.1	142.7	3,255,495.2	2,092.0	1.5	1.3
08/30/2021 12:00	9.9	13.7	8.1	109.9	3,353,915.9	1,714.4	1.1	0.7
08/30/2021 13:00	10.0	13.7	8.2	108.9	3,326,331.8	1,700.3	1.1	0.7
08/30/2021 14:00	10.9	13.1	8.2	137.0	3,303,425.1	2,122.8	1.4	1.1
08/30/2021 15:00	10.9	13.0	8.1	152.7	3,236,995.3	2,198.3	1.6	1.3
08/30/2021 16:00	10.9	13.0	8.1	155.0	3,249,217.0	2,206.6	1.6	1.3
08/30/2021 17:00	10.9	13.0	8.1	160.6	3,227,949.5	2,239.3	1.7	1.6
08/30/2021 18:00	10.8	12.9	8.0	166.2	3,219,003.2	2,256.6	1.8	1.6
08/30/2021 19:00	10.7	12.9	7.9	166.1	3,241,256.3	2,272.2	1.8	1.6
08/30/2021 20:00	10.6	13.0	7.9	167.4	3,313,430.4	2,298.6	1.7	1.6
08/30/2021 21:00	10.5	13.0	7.8	161.0	3,320,854.1	2,279.5	1.7	1.6
08/30/2021 22:00	10.5	13.0	7.8	148.8	3,340,492.6	2,219.8	1.5	1.3
08/30/2021 23:00	10.4	13.1	7.9	137.8	3,305,349.7	2,099.9	1.4	1.0
Average/Sum#:	10.6	13.3	8.2	133.3	3,280,127.3	1,989.4	1.4	1.1
Minimum:	9.9	12.9	7.8	105.4	3,044,426.0	1,556.2	1.1	0.6
Maximum:	10.9	13.7	8.8	167.4	3,368,131.9	2,298.6	1.8	1.6
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
08/31/2021 00:00	10.2	13.7	8.4	108.6	3,288,379.2	1,680.9	1.1	0.7
08/31/2021 01:00	10.1	13.7	8.3	109.1	3,329,461.9	1,701.9	1.1	0.7
08/31/2021 02:00	10.8	13.8	9.0	91.4	2,641,798.3	1,331.1	1.1	0.5
08/31/2021 03:00	9.9	13.7	8.1	106.8	3,265,099.0	1,669.0	1.1	0.7
08/31/2021 04:00	9.8	13.4	7.7	114.1	3,350,707.6	1,835.1	1.1	0.7
08/31/2021 05:00	10.2	13.3	7.9	118.7	3,359,478.9	1,913.5	1.2	1.0
08/31/2021 06:00	10.0	13.5	8.0	114.5	3,419,376.6	1,797.8	1.1	0.7
08/31/2021 07:00	10.5	13.3	8.2	123.0	3,410,712.0	2,017.4	1.2	1.0
08/31/2021 08:00	10.5	13.1	7.9	134.1	3,342,032.4	2,098.8	1.4	1.0
08/31/2021 09:00	10.2	13.7	8.4	109.9	3,315,376.4	1,694.7	1.1	0.7
08/31/2021 10:00	10.1	13.6	8.2	109.2	3,298,769.8	1,710.3	1.1	0.7
08/31/2021 11:00	10.7	13.2	8.2	124.0	3,366,969.1	2,040.7	1.2	1.0
08/31/2021 12:00	10.7	13.1	8.1	134.9	3,278,059.6	2,106.5	1.4	1.1
08/31/2021 13:00	10.1	13.7	8.3	108.6	3,259,230.0	1,666.0	1.1	0.7
08/31/2021 14:00	10.0	13.6	8.1	109.8	3,329,051.4	1,726.0	1.1	0.7
08/31/2021 15:00	10.7	13.2	8.2	125.1	3,321,995.3	2,037.7	1.3	1.0
08/31/2021 16:00	10.9	13.1	8.2	146.5	3,257,146.1	2,188.2	1.5	1.3
08/31/2021 17:00	10.8	13.0	8.1	150.4	3,259,819.0	2,213.8	1.6	1.3
08/31/2021 18:00	10.6	13.0	7.9	155.2	3,271,451.8	2,221.7	1.6	1.3
08/31/2021 19:00	10.5	13.1	7.9	144.9	3,223,715.3	2,142.2	1.5	1.3
08/31/2021 20:00	10.2	13.7	8.4	108.1	3,258,838.8	1,665.8	1.1	0.7
08/31/2021 21:00	10.3	13.6	8.3	110.6	3,332,330.3	1,727.7	1.1	0.7
08/31/2021 22:00	10.5	13.1	7.9	124.6	3,364,824.2	2,039.4	1.2	1.0
08/31/2021 23:00	10.4	13.1	7.9	132.2	3,350,790.4	2,104.3	1.3	1.1
Average/Sum#:	10.4	13.4	8.2	121.4	3,287,308.9	1,888.8	1.2	0.9
Minimum:	9.8	13.0	7.7	91.4	2,641,798.3	1,331.1	1.1	0.5
Maximum:	10.9	13.8	9.0	155.2	3,419,376.6	2,221.7	1.6	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
09/01/2021 00:00	10.0	13.1	7.6	133.6	3,336,358.5	2,119.6	1.4	1.1
09/01/2021 01:00	9.5	13.3	7.4	116.7	3,334,890.7	1,948.2	1.2	1.0
09/01/2021 02:00	9.6	13.7	7.9	103.2	3,152,610.6	1,611.5	1.1	0.6
09/01/2021 03:00	9.6	13.6	7.8	107.6	3,294,333.6	1,708.0	1.1	0.7
09/01/2021 04:00	9.8	13.3	7.6	121.5	3,383,480.2	2,026.0	1.2	1.0
09/01/2021 05:00	9.8	13.2	7.5	132.7	3,363,747.0	2,137.0	1.3	1.1
09/01/2021 06:00	9.9	13.3	7.7	123.6	3,364,441.9	2,014.6	1.2	1.0
09/01/2021 07:00	9.3	13.7	7.6	107.9	3,302,856.0	1,688.3	1.1	0.7
09/01/2021 08:00	9.8	13.7	8.0	104.3	3,183,324.8	1,627.2	1.1	0.7
09/01/2021 09:00	10.1	13.4	7.9	116.1	3,386,035.2	1,903.9	1.1	0.8
09/01/2021 10:00	10.4	13.3	8.1	128.4	3,395,327.1	2,008.3	1.3	1.0
09/01/2021 11:00	10.6	13.6	8.6	102.0	2,856,961.6	1,502.1	1.2	0.8
09/01/2021 12:00	10.3	13.7	8.4	101.3	3,066,532.5	1,567.5	1.1	0.6
09/01/2021 13:00	10.5	13.2	8.0	122.4	3,346,675.2	2,028.4	1.2	1.0
09/01/2021 14:00	10.5	13.2	8.0	122.7	3,324,896.4	2,015.2	1.2	1.0
09/01/2021 15:00	10.4	13.6	8.4	112.3	3,194,323.1	1,702.8	1.2	0.9
09/01/2021 16:00	10.2	13.7	8.4	109.4	3,293,947.8	1,707.8	1.1	0.7
09/01/2021 17:00	10.7	13.2	8.2	129.5	3,354,445.3	2,082.1	1.3	1.0
09/01/2021 18:00	10.7	13.1	8.1	137.6	3,323,655.2	2,135.8	1.4	1.1
09/01/2021 19:00	10.5	13.1	7.9	138.3	3,316,963.7	2,131.5	1.4	1.1
09/01/2021 20:00	10.0	13.7	8.2	109.6	3,325,940.6	1,700.1	1.1	0.7
09/01/2021 21:00	10.8	13.8	9.0	92.2	2,765,046.5	1,393.2	1.1	0.6
09/01/2021 22:00	10.1	13.7	8.3	106.7	3,233,406.6	1,652.8	1.1	0.7
09/01/2021 23:00	9.4	13.7	7.7	108.5	3,356,067.9	1,715.5	1.1	0.7
Average/Sum#:	10.1	13.5	8.0	116.2	3,260,677.8	1,838.6	1.2	0.9
Minimum:	9.3	13.1	7.4	92.2	2,765,046.5	1,393.2	1.1	0.6
Maximum:	10.8	13.8	9.0	138.3	3,395,327.1	2,137.0	1.4	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
09/02/2021 00:00	9.6	13.4	7.6	115.0	3,346,260.6	1,857.1	1.1	0.7
09/02/2021 01:00	9.5	13.4	7.5	116.7	3,293,992.3	1,876.2	1.2	0.9
09/02/2021 02:00	10.3	13.8	8.6	90.2	2,719,597.4	1,370.3	1.1	0.5
09/02/2021 03:00	9.6	13.7	7.9	107.2	3,294,248.2	1,683.9	1.1	0.7
09/02/2021 04:00	10.4	13.8	8.6	91.9	2,779,534.6	1,400.5	1.1	0.6
09/02/2021 05:00	10.0	13.7	8.2	104.4	3,253,752.3	1,663.2	1.0	0.7
09/02/2021 06:00	9.8	13.5	7.8	113.8	3,378,592.0	1,825.7	1.1	0.7
09/02/2021 07:00	9.5	13.5	7.6	112.9	3,372,253.2	1,846.9	1.1	0.7
09/02/2021 08:00	10.4	13.8	8.6	90.8	2,717,811.2	1,369.4	1.1	0.5
09/02/2021 09:00	10.3	13.8	8.6	94.8	2,892,859.4	1,457.6	1.1	0.6
09/02/2021 10:00	10.1	13.8	8.4	98.4	3,006,382.7	1,514.8	1.1	0.6
09/02/2021 11:00	10.6	13.8	8.8	95.0	2,856,142.9	1,439.1	1.1	0.6
09/02/2021 12:00	9.8	13.7	8.0	108.5	3,338,461.0	1,706.5	1.1	0.7
09/02/2021 13:00	10.5	13.2	8.0	125.1	3,404,092.0	2,063.2	1.2	1.0
09/02/2021 14:00	10.5	13.3	8.2	124.2	3,326,381.3	2,016.1	1.2	1.0
09/02/2021 15:00	10.1	13.7	8.3	109.4	3,293,465.6	1,683.5	1.1	0.7
09/02/2021 16:00	10.3	13.7	8.4	106.5	3,222,842.5	1,647.4	1.1	0.7
09/02/2021 17:00	10.8	13.2	8.3	128.3	3,368,784.0	2,091.0	1.3	1.0
09/02/2021 18:00	10.7	13.1	8.1	132.1	3,342,182.5	2,123.3	1.3	1.1
09/02/2021 19:00	10.6	13.2	8.1	130.8	3,330,089.8	2,091.3	1.3	1.0
09/02/2021 20:00	10.3	13.7	8.4	103.4	3,106,637.0	1,588.0	1.1	0.6
09/02/2021 21:00	10.5	13.9	8.9	91.8	2,778,939.2	1,400.2	1.1	0.6
09/02/2021 22:00	9.8	13.8	8.1	103.9	3,223,109.0	1,624.0	1.0	0.6
09/02/2021 23:00	9.9	13.4	7.8	114.6	3,384,669.3	1,853.7	1.1	0.7
Average/Sum#:	10.2	13.6	8.2	108.7	3,167,961.7	1,716.4	1.1	0.7
Minimum:	9.5	13.1	7.5	90.2	2,717,811.2	1,369.4	1.0	0.5
Maximum:	10.8	13.9	8.9	132.1	3,404,092.0	2,123.3	1.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
09/03/2021 00:00	10.2	13.3	7.9	120.2	3,312,100.2	1,910.7	1.2	1.0
09/03/2021 01:00	10.3	13.6	8.3	104.2	3,120,358.8	1,617.8	1.1	0.6
09/03/2021 02:00	9.7	13.6	7.8	112.8	3,411,198.1	1,793.5	1.1	0.7
09/03/2021 03:00	9.6	13.4	7.6	114.2	3,381,249.3	1,925.9	1.1	0.8
09/03/2021 04:00	9.7	13.8	8.1	102.9	3,111,723.5	1,590.6	1.1	0.6
09/03/2021 05:00	9.7	13.6	7.8	108.8	3,339,683.7	1,755.9	1.1	0.7
09/03/2021 06:00	10.1	13.3	7.8	123.5	3,415,210.8	2,045.0	1.2	1.0
09/03/2021 07:00	9.7	13.3	7.5	118.8	3,372,036.4	1,969.9	1.2	1.0
09/03/2021 08:00	9.1	13.8	7.6	107.5	3,355,676.6	1,715.3	1.0	0.7
09/03/2021 09:00	9.9	13.8	8.2	98.6	3,029,206.4	1,526.3	1.1	0.6
09/03/2021 10:00	9.9	13.8	8.2	103.9	3,204,453.1	1,614.6	1.1	0.6
09/03/2021 11:00	9.7	13.8	8.1	104.1	3,216,361.1	1,620.6	1.0	0.6
09/03/2021 12:00	9.6	13.8	8.0	104.0	3,232,833.9	1,628.9	1.0	0.7
09/03/2021 13:00	10.0	13.8	8.3	105.7	3,261,214.7	1,643.2	1.0	0.7
09/03/2021 14:00	10.0	13.8	8.3	101.6	3,100,456.2	1,562.2	1.1	0.6
09/03/2021 15:00	10.7	13.2	8.2	130.4	3,335,026.1	2,094.4	1.3	1.0
09/03/2021 16:00	10.8	13.1	8.2	143.5	3,329,086.1	2,163.6	1.5	1.3
09/03/2021 17:00	10.9	13.0	8.1	156.5	3,319,514.5	2,230.1	1.6	1.3
09/03/2021 18:00	10.9	13.1	8.2	158.0	3,312,220.8	2,225.2	1.6	1.3
09/03/2021 19:00	10.6	13.1	8.0	144.7	3,280,617.7	2,132.1	1.5	1.3
09/03/2021 20:00	10.0	13.7	8.2	110.4	3,343,351.8	1,709.0	1.1	0.7
09/03/2021 21:00	10.1	13.5	8.1	114.1	3,435,163.0	1,806.1	1.1	0.7
09/03/2021 22:00	10.5	13.2	8.0	123.4	3,408,530.7	2,041.0	1.2	1.0
09/03/2021 23:00	10.3	13.3	8.0	120.0	3,386,586.5	1,978.4	1.2	1.0
Average/Sum#:	10.1	13.5	8.0	118.0	3,292,244.2	1,845.8	1.2	0.9
Minimum:	9.1	13.0	7.5	98.6	3,029,206.4	1,526.3	1.0	0.6
Maximum:	10.9	13.8	8.3	158.0	3,435,163.0	2,230.1	1.6	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
09/04/2021 00:00	10.4	13.7	8.5	107.6	3,228,124.5	1,650.1	1.1	0.7
09/04/2021 01:00	10.5	13.6	8.5	107.6	3,230,105.7	1,674.7	1.1	0.7
09/04/2021 02:00	10.4	13.3	8.1	123.5	3,406,025.6	2,039.5	1.2	1.0
09/04/2021 03:00	16.0	14.5	14.8	147.5	2,559,434.3	1,289.6	1.9	0.9
09/04/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/04/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/04/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/04/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/04/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/04/2021 09:00	26.9	17.8	51.2	167.2	1,442,460.4	252.8	0.0	0.0
09/04/2021 10:00	40.8	15.4	43.8	245.5	2,223,893.5	860.7	3.4	1.1
09/04/2021 11:00	10.3	13.9	8.7	95.0	2,804,500.6	1,392.6	1.1	0.6
09/04/2021 12:00	10.3	13.9	8.7	89.6	2,779,730.1	1,380.3	1.0	0.6
09/04/2021 13:00	9.9	13.7	8.1	105.7	3,270,968.0	1,672.0	1.1	0.7
09/04/2021 14:00	10.8	13.8	9.0	101.6	2,894,248.7	1,458.3	1.1	0.6
09/04/2021 15:00	9.9	13.8	8.2	109.4	3,374,848.6	1,725.1	1.1	0.7
09/04/2021 16:00	10.8	13.7	8.9	105.7	3,173,347.6	1,622.1	1.1	0.6
09/04/2021 17:00	11.0	13.1	8.3	138.3	3,334,859.6	2,143.0	1.4	1.1
09/04/2021 18:00	11.1	13.0	8.3	161.4	3,288,366.7	2,257.2	1.7	1.6
09/04/2021 19:00	11.0	13.0	8.2	168.6	3,319,980.0	2,278.9	1.7	1.6
09/04/2021 20:00	11.0	13.1	8.3	156.1	3,326,045.9	2,210.2	1.6	1.3
09/04/2021 21:00	10.8	13.1	8.2	145.4	3,367,850.3	2,164.2	1.5	1.3
09/04/2021 22:00	10.7	13.2	8.2	136.1	3,367,828.6	2,115.0	1.4	1.1
09/04/2021 23:00	10.7	13.2	8.2	134.6	3,386,828.2	2,102.2	1.3	1.1
Average/Sum#:	13.3	13.8	12.9	134.0	3,041,023.5	1,699.4	1.4	0.9
Minimum:	9.9	13.0	8.1	89.6	1,442,460.4	252.8	0.0	0.0
Maximum:	40.8	17.8	51.2	245.5	3,406,025.6	2,278.9	3.4	1.6
%SI	20.83	20.83	20.83	20.83	20.83	20.83	20.83	20.83

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
09/05/2021 00:00	10.4	13.3	8.1	123.8	3,347,989.0	1,980.3	1.2	1.0
09/05/2021 01:00	10.9	13.7	8.9	111.9	3,252,578.5	1,662.6	1.1	0.7
09/05/2021 02:00	10.6	13.7	8.7	108.6	3,275,858.8	1,674.5	1.1	0.7
09/05/2021 03:00	10.6	13.3	8.2	124.6	3,414,542.8	2,044.6	1.2	1.0
09/05/2021 04:00	10.5	13.3	8.2	121.0	3,404,493.0	1,964.0	1.2	1.0
09/05/2021 05:00	10.8	13.7	8.9	112.7	3,237,514.9	1,654.9	1.1	0.7
09/05/2021 06:00	11.3	13.7	9.3	109.6	3,214,430.3	1,643.1	1.1	0.7
09/05/2021 07:00	11.3	13.7	9.3	108.1	3,161,218.4	1,615.9	1.1	0.6
09/05/2021 08:00	11.2	13.7	9.2	111.3	3,221,473.0	1,646.7	1.1	0.7
09/05/2021 09:00	11.2	13.7	9.2	109.6	3,200,540.4	1,636.0	1.1	0.7
09/05/2021 10:00	10.5	13.7	8.6	110.4	3,334,548.4	1,704.5	1.1	0.7
09/05/2021 11:00	10.1	13.7	8.3	110.7	3,385,021.4	1,730.3	1.1	0.7
09/05/2021 12:00	10.1	13.7	8.3	110.1	3,360,567.4	1,717.8	1.1	0.7
09/05/2021 13:00	9.8	13.7	8.0	110.0	3,392,846.7	1,734.3	1.1	0.7
09/05/2021 14:00	10.7	13.2	8.2	128.7	3,336,667.7	2,046.7	1.3	1.0
09/05/2021 15:00	10.9	13.1	8.2	147.9	3,352,655.2	2,203.4	1.5	1.3
09/05/2021 16:00	10.9	13.1	8.2	156.3	3,311,923.1	2,225.0	1.6	1.3
09/05/2021 17:00	11.0	13.0	8.2	165.5	3,297,836.1	2,263.7	1.7	1.6
09/05/2021 18:00	10.8	13.0	8.1	160.6	3,313,270.8	2,250.1	1.7	1.6
09/05/2021 19:00	10.9	13.0	8.1	169.2	3,323,622.1	2,281.4	1.7	1.6
09/05/2021 20:00	10.7	13.1	8.1	154.2	3,326,798.3	2,210.7	1.6	1.3
09/05/2021 21:00	10.5	13.1	7.9	144.4	3,367,850.3	2,164.2	1.5	1.3
09/05/2021 22:00	10.5	13.2	8.0	138.7	3,372,876.5	2,142.8	1.4	1.1
09/05/2021 23:00	10.3	13.2	7.9	129.3	3,342,047.6	2,050.0	1.3	1.0
Average/Sum#:	10.7	13.4	8.4	128.2	3,314,548.8	1,927.0	1.3	1.0
Minimum:	9.8	13.0	7.9	108.1	3,161,218.4	1,615.9	1.1	0.6
Maximum:	11.3	13.7	9.3	169.2	3,414,542.8	2,281.4	1.7	1.6
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
09/06/2021 00:00	10.5	13.7	8.6	108.6	3,233,211.0	1,652.7	1.1	0.7
09/06/2021 01:00	10.4	13.7	8.5	105.5	3,179,020.9	1,625.0	1.1	0.7
09/06/2021 02:00	10.5	13.4	8.3	124.3	3,309,611.3	1,957.6	1.2	1.0
09/06/2021 03:00	10.1	13.4	7.9	128.0	3,272,755.2	1,935.8	1.3	1.0
09/06/2021 04:00	9.6	13.8	8.0	103.6	3,185,201.7	1,604.9	1.1	0.6
09/06/2021 05:00	10.4	13.7	8.5	110.1	3,287,792.3	1,680.6	1.1	0.7
09/06/2021 06:00	11.1	13.7	9.1	108.0	3,199,953.5	1,635.7	1.1	0.7
09/06/2021 07:00	10.5	13.8	8.7	106.9	3,245,535.8	1,635.3	1.1	0.7
09/06/2021 08:00	9.4	13.8	7.8	111.1	3,386,646.0	1,706.4	1.1	0.7
09/06/2021 09:00	10.0	13.8	8.3	101.9	3,110,578.0	1,567.3	1.1	0.6
09/06/2021 10:00	9.9	13.7	8.1	108.6	3,337,678.5	1,706.1	1.1	0.7
09/06/2021 11:00	9.9	13.7	8.1	108.4	3,324,375.5	1,699.3	1.1	0.7
09/06/2021 12:00	10.1	13.5	8.1	137.3	3,364,219.2	2,137.3	1.4	1.1
09/06/2021 13:00	10.2	13.4	8.0	156.2	3,307,159.9	2,221.8	1.6	1.3
09/06/2021 14:00	10.3	13.4	8.1	158.9	3,294,209.9	2,213.1	1.7	1.5
09/06/2021 15:00	10.3	13.4	8.1	162.4	3,268,212.3	2,219.5	1.7	1.6
09/06/2021 16:00	10.3	13.4	8.1	165.4	3,278,961.5	2,226.8	1.7	1.6
09/06/2021 17:00	10.4	13.4	8.2	170.3	3,263,017.8	2,239.8	1.8	1.6
09/06/2021 18:00	10.4	13.4	8.2	167.7	3,232,562.3	2,242.5	1.8	1.6
09/06/2021 19:00	10.3	13.4	8.1	172.3	3,281,519.6	2,252.5	1.8	1.6
09/06/2021 20:00	10.3	13.4	8.1	171.0	3,294,776.8	2,261.6	1.8	1.6
09/06/2021 21:00	10.2	13.4	8.0	162.2	3,295,895.3	2,238.3	1.7	1.6
09/06/2021 22:00	10.2	13.4	8.0	152.2	3,308,225.0	2,174.2	1.6	1.3
09/06/2021 23:00	10.2	13.4	8.0	136.0	3,341,878.8	2,074.3	1.4	1.0
Average/Sum#:	10.2	13.5	8.2	134.9	3,275,124.9	1,954.5	1.4	1.1
Minimum:	9.4	13.4	7.8	101.9	3,110,578.0	1,567.3	1.1	0.6
Maximum:	11.1	13.8	9.1	172.3	3,386,646.0	2,261.6	1.8	1.6
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
09/07/2021 00:00	9.9	13.7	8.1	114.0	3,359,198.0	1,717.1	1.1	0.7
09/07/2021 01:00	10.6	13.6	8.6	113.2	3,266,945.1	1,693.8	1.1	0.7
09/07/2021 02:00	10.8	13.2	8.3	124.2	3,421,363.1	2,023.7	1.2	1.0
09/07/2021 03:00	10.6	13.3	8.2	119.6	3,394,265.7	1,958.1	1.2	1.0
09/07/2021 04:00	10.5	13.7	8.6	112.2	3,365,262.6	1,720.2	1.1	0.7
09/07/2021 05:00	10.3	13.5	8.2	115.6	3,434,972.8	1,806.0	1.1	0.7
09/07/2021 06:00	10.9	13.2	8.4	126.2	3,417,214.8	2,046.2	1.2	1.0
09/07/2021 07:00	10.7	13.3	8.3	127.0	3,359,097.8	2,011.4	1.3	1.0
09/07/2021 08:00	10.6	13.7	8.7	112.5	3,341,591.1	1,708.1	1.1	0.7
09/07/2021 09:00	10.3	13.7	8.4	111.9	3,376,691.9	1,750.7	1.1	0.7
09/07/2021 10:00	11.0	13.2	8.4	129.7	3,364,659.2	2,039.3	1.3	1.0
09/07/2021 11:00	11.2	13.1	8.5	160.4	3,311,178.9	2,224.5	1.7	1.6
09/07/2021 12:00	11.0	13.1	8.3	157.9	3,285,725.4	2,207.4	1.6	1.3
09/07/2021 13:00	10.9	13.1	8.2	154.2	3,283,608.8	2,182.0	1.6	1.3
09/07/2021 14:00	10.9	13.1	8.2	152.8	3,265,700.9	2,170.1	1.6	1.3
09/07/2021 15:00	11.0	13.1	8.3	154.5	3,245,386.9	2,180.3	1.6	1.3
09/07/2021 16:00	11.1	13.0	8.3	163.0	3,242,296.3	2,201.9	1.7	1.5
09/07/2021 17:00	10.9	13.1	8.2	157.4	3,266,077.2	2,194.2	1.6	1.3
09/07/2021 18:00	10.8	13.1	8.2	148.7	3,315,545.7	2,154.8	1.5	1.3
09/07/2021 19:00	10.7	13.2	8.2	144.3	3,331,280.4	2,140.7	1.5	1.3
09/07/2021 20:00	10.7	13.2	8.2	143.7	3,346,375.2	2,150.4	1.5	1.3
09/07/2021 21:00	10.8	13.0	8.1	164.6	3,353,154.7	2,252.7	1.7	1.6
09/07/2021 22:00	10.9	13.0	8.1	171.8	3,291,952.1	2,283.7	1.8	1.6
09/07/2021 23:00	10.9	13.0	8.1	172.5	3,328,138.3	2,284.5	1.8	1.6
Average/Sum#:	10.8	13.3	8.3	139.7	3,331,986.8	2,045.9	1.4	1.1
Minimum:	9.9	13.0	8.1	111.9	3,242,296.3	1,693.8	1.1	0.7
Maximum:	11.2	13.7	8.7	172.5	3,434,972.8	2,284.5	1.8	1.6
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
09/08/2021 00:00	10.7	13.1	8.1	167.6	3,333,444.0	2,263.8	1.7	1.6
09/08/2021 01:00	10.5	13.1	7.9	151.2	3,326,179.7	2,186.0	1.6	1.3
09/08/2021 02:00	10.5	13.2	8.0	141.6	3,358,395.2	2,133.6	1.4	1.1
09/08/2021 03:00	10.5	13.2	8.0	140.4	3,375,867.2	2,144.7	1.4	1.1
09/08/2021 04:00	10.7	13.1	8.1	162.9	3,356,429.4	2,254.9	1.7	1.6
09/08/2021 05:00	10.7	13.0	8.0	191.1	3,356,415.0	2,279.4	2.0	1.8
09/08/2021 06:00	10.9	13.1	8.2	160.5	3,332,315.6	2,238.7	1.6	1.3
09/08/2021 07:00	10.6	13.2	8.1	134.0	3,333,733.2	2,044.9	1.4	1.0
09/08/2021 08:00	9.9	13.7	8.1	111.4	3,358,024.2	1,716.5	1.1	0.7
09/08/2021 09:00	10.0	13.7	8.2	110.2	3,334,259.1	1,728.7	1.1	0.7
09/08/2021 10:00	10.9	13.2	8.4	133.0	3,366,528.5	2,089.6	1.3	1.0
09/08/2021 11:00	10.3	13.4	8.1	158.5	3,262,653.6	2,191.9	1.7	1.5
09/08/2021 12:00	10.3	13.4	8.1	156.0	3,260,885.4	2,166.9	1.6	1.3
09/08/2021 13:00	10.3	13.4	8.1	156.3	3,224,399.0	2,166.2	1.7	1.5
09/08/2021 14:00	10.4	13.4	8.2	158.9	3,191,200.6	2,167.2	1.7	1.5
09/08/2021 15:00	10.4	13.4	8.2	157.0	3,188,402.8	2,165.3	1.7	1.5
09/08/2021 16:00	10.4	13.4	8.2	162.0	3,184,640.1	2,186.0	1.7	1.5
09/08/2021 17:00	10.3	13.4	8.1	164.9	3,175,767.2	2,203.1	1.8	1.5
09/08/2021 18:00	10.2	13.4	8.0	166.2	3,211,737.2	2,204.6	1.8	1.5
09/08/2021 19:00	10.1	13.4	7.9	166.5	3,235,192.3	2,220.7	1.8	1.6
09/08/2021 20:00	10.1	13.4	7.9	164.2	3,254,518.0	2,210.2	1.7	1.5
09/08/2021 21:00	10.1	13.4	7.9	154.1	3,267,356.3	2,171.2	1.6	1.3
09/08/2021 22:00	10.2	13.4	8.0	149.9	3,265,772.8	2,146.3	1.6	1.3
09/08/2021 23:00	10.3	13.4	8.1	165.1	3,259,082.8	2,213.3	1.7	1.5
Average/Sum#:	10.4	13.3	8.1	153.5	3,283,883.3	2,145.6	1.6	1.3
Minimum:	9.9	13.0	7.9	110.2	3,175,767.2	1,716.5	1.1	0.7
Maximum:	10.9	13.7	8.4	191.1	3,375,867.2	2,279.4	2.0	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
09/09/2021 00:00	10.2	13.4	8.0	168.2	3,243,496.2	2,226.4	1.8	1.6
09/09/2021 01:00	10.1	13.4	7.9	166.4	3,257,044.8	2,235.7	1.8	1.6
09/09/2021 02:00	9.9	13.4	7.8	167.2	3,300,018.3	2,241.1	1.7	1.6
09/09/2021 03:00	10.1	13.4	7.9	166.3	3,296,778.8	2,238.9	1.7	1.6
09/09/2021 04:00	10.1	13.4	7.9	171.3	3,266,514.2	2,242.2	1.8	1.6
09/09/2021 05:00	10.1	13.4	7.9	176.8	3,271,904.5	2,245.9	1.9	1.6
09/09/2021 06:00	10.3	13.4	8.1	164.7	3,291,330.5	2,235.2	1.7	1.6
09/09/2021 07:00	10.2	13.4	8.0	154.6	3,293,691.4	2,188.7	1.6	1.3
09/09/2021 08:00	10.2	13.4	8.0	154.9	3,280,599.1	2,180.0	1.6	1.3
09/09/2021 09:00	10.3	13.4	8.1	156.1	3,247,768.5	2,181.9	1.6	1.3
09/09/2021 10:00	10.2	13.4	8.0	153.4	3,246,280.0	2,180.9	1.6	1.3
09/09/2021 11:00	10.3	13.4	8.1	155.1	3,222,761.7	2,165.1	1.6	1.3
09/09/2021 12:00	10.3	13.4	8.1	153.6	3,228,831.8	2,145.6	1.6	1.3
09/09/2021 13:00	10.4	13.4	8.2	155.6	3,173,383.3	2,155.1	1.7	1.5
09/09/2021 14:00	10.4	13.4	8.2	153.4	3,188,972.6	2,142.4	1.6	1.3
09/09/2021 15:00	10.4	13.4	8.2	153.1	3,181,530.1	2,137.4	1.6	1.3
09/09/2021 16:00	10.4	13.4	8.2	154.4	3,168,818.6	2,152.0	1.7	1.5
09/09/2021 17:00	10.3	13.4	8.1	156.6	3,184,721.6	2,162.8	1.7	1.5
09/09/2021 18:00	10.3	13.4	8.1	162.0	3,169,857.1	2,199.0	1.8	1.5
09/09/2021 19:00	10.3	13.4	8.1	165.1	3,178,073.6	2,204.7	1.8	1.5
09/09/2021 20:00	10.2	13.4	8.0	163.6	3,233,152.7	2,219.3	1.7	1.6
09/09/2021 21:00	10.2	13.4	8.0	167.9	3,235,483.6	2,220.9	1.8	1.6
09/09/2021 22:00	10.2	13.4	8.0	158.7	3,227,865.8	2,192.1	1.7	1.5
09/09/2021 23:00	10.2	13.4	8.0	162.8	3,249,364.3	2,206.7	1.7	1.5
Average/Sum#:	10.2	13.4	8.0	160.9	3,234,926.8	2,195.8	1.7	1.5
Minimum:	9.9	13.4	7.8	153.1	3,168,818.6	2,137.4	1.6	1.3
Maximum:	10.4	13.4	8.2	176.8	3,300,018.3	2,245.9	1.9	1.6
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
09/10/2021 00:00	10.2	13.4	8.0	150.2	3,228,037.6	2,121.5	1.6	1.3
09/10/2021 01:00	10.4	13.7	8.5	105.3	3,121,700.7	1,595.7	1.1	0.6
09/10/2021 02:00	10.1	13.5	8.1	112.3	3,352,617.2	1,762.7	1.1	0.7
09/10/2021 03:00	10.9	13.1	8.2	130.0	3,354,767.5	2,082.3	1.3	1.0
09/10/2021 04:00	11.0	12.9	8.1	150.4	3,315,812.8	2,203.4	1.5	1.3
09/10/2021 05:00	10.9	13.0	8.1	146.0	3,289,966.0	2,162.2	1.5	1.3
09/10/2021 06:00	11.3	12.9	8.3	151.6	3,336,429.5	2,217.1	1.5	1.3
09/10/2021 07:00	10.7	13.5	8.5	114.1	3,068,435.9	1,658.1	1.2	0.8
09/10/2021 08:00	10.9	13.7	8.9	102.2	2,988,670.9	1,527.7	1.1	0.6
09/10/2021 09:00	9.9	13.7	8.1	105.7	3,227,146.4	1,649.6	1.1	0.7
09/10/2021 10:00	10.1	13.6	8.2	104.4	3,138,682.1	1,627.3	1.1	0.7
09/10/2021 11:00	10.7	13.2	8.2	130.1	3,329,634.6	2,066.7	1.3	1.0
09/10/2021 12:00	10.7	13.1	8.1	134.5	3,246,172.7	2,038.6	1.4	1.0
09/10/2021 13:00	10.3	13.7	8.4	106.4	3,144,589.6	1,607.4	1.1	0.6
09/10/2021 14:00	9.9	13.6	8.0	109.5	3,330,594.4	1,726.8	1.1	0.7
09/10/2021 15:00	10.9	13.2	8.4	134.4	3,289,451.8	2,089.8	1.4	1.0
09/10/2021 16:00	11.0	13.1	8.3	147.0	3,273,380.8	2,151.3	1.5	1.3
09/10/2021 17:00	11.0	13.0	8.2	157.5	3,258,052.0	2,212.6	1.7	1.5
09/10/2021 18:00	11.1	13.0	8.3	165.5	3,251,945.9	2,232.2	1.7	1.6
09/10/2021 19:00	11.0	13.0	8.2	161.7	3,252,965.6	2,232.9	1.7	1.6
09/10/2021 20:00	11.0	13.0	8.2	161.8	3,282,642.8	2,229.3	1.7	1.6
09/10/2021 21:00	10.9	13.0	8.1	161.2	3,282,348.3	2,229.1	1.7	1.6
09/10/2021 22:00	10.8	13.1	8.2	149.0	3,285,096.9	2,159.0	1.5	1.3
09/10/2021 23:00	10.8	13.1	8.2	138.6	3,323,401.9	2,087.1	1.4	1.0
Average/Sum#:	10.7	13.3	8.2	134.6	3,248,856.0	1,986.3	1.4	1.1
Minimum:	9.9	12.9	8.0	102.2	2,988,670.9	1,527.7	1.1	0.6
Maximum:	11.3	13.7	8.9	165.5	3,354,767.5	2,232.9	1.7	1.6
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
09/11/2021 00:00	10.6	13.2	8.1	124.1	3,300,481.8	1,952.2	1.3	1.0
09/11/2021 01:00	10.3	13.7	8.4	113.0	3,343,743.1	1,709.2	1.1	0.7
09/11/2021 02:00	10.6	13.7	8.7	111.6	3,314,202.6	1,694.1	1.1	0.7
09/11/2021 03:00	10.7	13.6	8.6	106.4	3,053,623.5	1,583.2	1.1	0.6
09/11/2021 04:00	10.8	13.2	8.3	126.5	3,364,824.2	2,039.4	1.2	1.0
09/11/2021 05:00	10.7	13.2	8.2	130.2	3,401,719.5	1,962.4	1.3	1.0
09/11/2021 06:00	11.2	13.7	9.2	114.2	3,271,163.6	1,672.1	1.1	0.7
09/11/2021 07:00	11.4	13.7	9.3	113.7	3,171,856.9	1,644.5	1.2	0.8
09/11/2021 08:00	11.1	13.7	9.1	101.8	2,985,149.5	1,525.9	1.1	0.6
09/11/2021 09:00	10.5	13.7	8.6	105.6	3,145,959.1	1,608.1	1.1	0.6
09/11/2021 10:00	9.8	13.7	8.0	108.4	3,331,809.5	1,703.1	1.1	0.7
09/11/2021 11:00	10.6	13.6	8.6	110.8	3,257,301.3	1,688.8	1.1	0.7
09/11/2021 12:00	10.4	13.4	8.2	134.0	3,298,896.1	2,095.8	1.4	1.0
09/11/2021 13:00	10.2	13.4	8.0	138.7	3,231,841.5	2,076.8	1.5	1.2
09/11/2021 14:00	10.0	13.7	8.2	110.2	3,317,724.0	1,695.9	1.1	0.7
09/11/2021 15:00	10.2	13.6	8.2	111.2	3,300,503.0	1,735.3	1.1	0.7
09/11/2021 16:00	10.8	13.2	8.3	133.4	3,323,242.7	2,087.0	1.3	1.0
09/11/2021 17:00	10.9	13.0	8.1	169.2	3,273,500.9	2,270.9	1.8	1.6
09/11/2021 18:00	10.9	13.0	8.1	163.7	3,258,501.6	2,236.7	1.7	1.6
09/11/2021 19:00	10.7	13.1	8.1	151.1	3,312,181.1	2,176.8	1.6	1.3
09/11/2021 20:00	10.7	13.1	8.1	158.5	3,305,224.8	2,220.5	1.6	1.3
09/11/2021 21:00	10.7	13.0	8.0	161.8	3,301,785.3	2,242.3	1.7	1.6
09/11/2021 22:00	10.6	13.1	8.0	150.5	3,331,048.7	2,189.2	1.5	1.3
09/11/2021 23:00	10.5	13.1	7.9	152.6	3,313,856.5	2,202.1	1.6	1.3
Average/Sum#:	10.6	13.4	8.3	129.2	3,271,255.9	1,917.2	1.3	1.0
Minimum:	9.8	13.0	7.9	101.8	2,985,149.5	1,525.9	1.1	0.6
Maximum:	11.4	13.7	9.3	169.2	3,401,719.5	2,270.9	1.8	1.6
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
09/12/2021 00:00	10.3	13.2	7.9	133.9	3,311,107.1	2,055.2	1.4	1.0
09/12/2021 01:00	9.4	13.7	7.7	108.8	3,345,308.1	1,710.0	1.1	0.7
09/12/2021 02:00	9.1	13.8	7.6	105.1	3,308,449.9	1,667.0	1.0	0.7
09/12/2021 03:00	9.5	13.7	7.8	105.0	3,169,456.7	1,666.4	1.1	0.7
09/12/2021 04:00	10.2	13.2	7.8	123.3	3,388,156.3	2,028.8	1.2	1.0
09/12/2021 05:00	10.3	13.3	8.0	121.2	3,413,333.6	1,969.1	1.2	1.0
09/12/2021 06:00	10.9	13.7	8.9	106.8	3,003,282.7	1,557.1	1.2	0.8
09/12/2021 07:00	10.6	13.8	8.8	105.3	3,133,047.4	1,601.5	1.1	0.6
09/12/2021 08:00	10.5	13.9	8.9	92.8	2,713,246.5	1,367.1	1.1	0.5
09/12/2021 09:00	10.1	13.9	8.5	88.8	2,576,304.0	1,298.1	1.1	0.5
09/12/2021 10:00	9.5	13.7	7.8	105.5	3,280,358.3	1,676.8	1.1	0.7
09/12/2021 11:00	9.7	13.6	7.8	110.2	3,368,976.9	1,746.7	1.1	0.7
09/12/2021 12:00	10.4	13.4	8.2	136.0	3,317,828.7	2,083.6	1.4	1.0
09/12/2021 13:00	10.3	13.4	8.1	150.4	3,218,147.3	2,115.0	1.6	1.3
09/12/2021 14:00	10.6	13.7	8.7	113.7	3,267,642.2	1,670.3	1.1	0.7
09/12/2021 15:00	10.5	13.6	8.5	108.7	3,196,352.2	1,657.2	1.1	0.7
09/12/2021 16:00	11.0	13.1	8.3	139.7	3,293,154.4	2,116.2	1.4	1.1
09/12/2021 17:00	11.1	13.0	8.3	170.5	3,254,761.4	2,257.9	1.8	1.6
09/12/2021 18:00	11.0	13.0	8.2	158.7	3,269,979.3	2,220.7	1.7	1.6
09/12/2021 19:00	10.8	13.1	8.2	153.6	3,285,264.1	2,183.1	1.6	1.3
09/12/2021 20:00	10.7	13.1	8.1	146.5	3,310,775.8	2,151.7	1.5	1.3
09/12/2021 21:00	10.6	13.1	8.0	140.2	3,312,450.8	2,128.6	1.4	1.1
09/12/2021 22:00	10.5	13.2	8.0	138.0	3,328,645.7	2,114.7	1.4	1.1
09/12/2021 23:00	10.4	13.2	8.0	137.3	3,356,522.9	2,107.9	1.4	1.1
Average/Sum#:	10.3	13.4	8.2	125.0	3,225,939.7	1,881.3	1.3	1.0
Minimum:	9.1	13.0	7.6	88.8	2,576,304.0	1,298.1	1.0	0.5
Maximum:	11.1	13.9	8.9	170.5	3,413,333.6	2,257.9	1.8	1.6
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
09/13/2021 00:00	10.3	13.3	8.0	122.8	3,326,348.7	1,967.5	1.2	1.0
09/13/2021 01:00	10.5	13.7	8.6	106.1	3,143,611.5	1,606.9	1.1	0.6
09/13/2021 02:00	10.6	13.7	8.7	104.8	3,115,636.1	1,592.6	1.1	0.6
09/13/2021 03:00	10.3	13.7	8.4	108.6	3,261,773.3	1,667.3	1.1	0.7
09/13/2021 04:00	10.4	13.9	8.8	91.6	2,674,545.4	1,347.6	1.1	0.5
09/13/2021 05:00	9.0	13.8	7.5	101.4	3,364,814.6	1,695.4	1.0	0.7
09/13/2021 06:00	10.0	13.5	8.0	114.6	3,335,370.0	1,826.7	1.1	0.7
09/13/2021 07:00	10.2	13.4	8.0	118.5	3,251,429.5	1,875.7	1.2	0.9
09/13/2021 08:00	10.2	13.7	8.4	100.3	3,021,732.7	1,544.6	1.1	0.6
09/13/2021 09:00	10.3	13.3	8.0	121.7	3,325,363.2	1,991.2	1.2	1.0
09/13/2021 10:00	10.3	13.3	8.0	122.4	3,296,188.0	1,997.8	1.2	1.0
09/13/2021 11:00	9.4	13.7	7.7	108.9	3,373,870.4	1,724.6	1.1	0.7
09/13/2021 12:00	10.0	13.6	8.1	108.3	3,274,081.5	1,697.5	1.1	0.7
09/13/2021 13:00	10.5	13.2	8.0	129.1	3,322,545.8	2,062.3	1.3	1.0
09/13/2021 14:00	10.7	13.0	8.0	157.8	3,252,674.3	2,232.7	1.7	1.6
09/13/2021 15:00	10.6	13.0	7.9	155.4	3,263,353.0	2,216.2	1.6	1.3
09/13/2021 16:00	10.5	13.0	7.8	157.4	3,220,332.6	2,210.5	1.7	1.5
09/13/2021 17:00	10.6	13.0	7.9	160.7	3,233,859.6	2,243.4	1.7	1.6
09/13/2021 18:00	10.6	13.0	7.9	164.2	3,240,634.7	2,248.1	1.7	1.6
09/13/2021 19:00	10.6	13.0	7.9	161.3	3,234,147.9	2,243.6	1.7	1.6
09/13/2021 20:00	10.5	13.0	7.8	155.9	3,272,335.3	2,222.3	1.6	1.3
09/13/2021 21:00	10.3	13.1	7.8	143.3	3,296,813.1	2,166.7	1.5	1.3
09/13/2021 22:00	10.2	13.2	7.8	132.6	3,315,738.5	2,106.5	1.3	1.1
09/13/2021 23:00	10.1	13.3	7.8	120.4	3,324,695.2	1,990.8	1.2	1.0
Average/Sum#:	10.3	13.4	8.0	127.8	3,239,245.6	1,936.6	1.3	1.0
Minimum:	9.0	13.0	7.5	91.6	2,674,545.4	1,347.6	1.0	0.5
Maximum:	10.7	13.9	8.8	164.2	3,373,870.4	2,248.1	1.7	1.6
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
09/14/2021 00:00	10.0	13.3	7.8	119.0	3,322,798.4	1,965.4	1.2	1.0
09/14/2021 01:00	10.3	13.7	8.4	104.2	3,108,397.7	1,588.9	1.1	0.6
09/14/2021 02:00	10.5	13.7	8.6	103.1	3,063,793.6	1,566.1	1.1	0.6
09/14/2021 03:00	10.5	13.7	8.6	103.0	3,063,011.1	1,565.7	1.1	0.6
09/14/2021 04:00	10.7	13.7	8.8	98.8	2,953,457.1	1,509.7	1.1	0.6
09/14/2021 05:00	10.1	13.4	7.9	120.8	3,296,726.2	2,022.2	1.2	1.0
09/14/2021 06:00	10.3	13.3	8.0	123.6	3,336,280.8	2,022.1	1.2	1.0
09/14/2021 07:00	10.2	13.7	8.4	108.1	3,258,056.2	1,665.4	1.1	0.7
09/14/2021 08:00	10.6	13.7	8.7	100.1	2,979,867.5	1,523.2	1.1	0.6
09/14/2021 09:00	10.7	13.7	8.8	97.8	2,914,330.7	1,489.7	1.1	0.6
09/14/2021 10:00	10.3	13.7	8.4	107.8	3,256,099.9	1,664.4	1.1	0.7
09/14/2021 11:00	9.6	13.7	7.9	108.2	3,349,416.4	1,712.1	1.1	0.7
09/14/2021 12:00	10.3	13.8	8.6	100.8	3,046,382.4	1,557.2	1.1	0.6
09/14/2021 13:00	10.7	13.2	8.2	127.4	3,335,363.5	2,045.9	1.3	1.0
09/14/2021 14:00	10.7	13.1	8.1	139.9	3,253,844.7	2,114.7	1.5	1.3
09/14/2021 15:00	10.0	13.7	8.2	111.4	3,275,238.8	1,698.1	1.1	0.7
09/14/2021 16:00	10.4	13.7	8.5	106.2	3,134,245.9	1,625.0	1.1	0.7
09/14/2021 17:00	11.0	13.1	8.3	138.9	3,281,483.2	2,108.7	1.4	1.1
09/14/2021 18:00	11.0	13.0	8.2	157.6	3,222,663.5	2,212.1	1.7	1.5
09/14/2021 19:00	10.6	13.2	8.1	136.1	3,237,822.9	2,057.0	1.4	1.0
09/14/2021 20:00	9.9	13.7	8.1	110.6	3,300,891.4	1,711.4	1.1	0.7
09/14/2021 21:00	10.1	13.6	8.2	112.9	3,370,305.6	1,772.0	1.1	0.7
09/14/2021 22:00	10.6	13.2	8.1	128.5	3,362,425.9	2,062.5	1.3	1.0
09/14/2021 23:00	10.4	13.3	8.1	123.7	3,306,157.9	1,979.7	1.2	1.0
Average/Sum#:	10.4	13.5	8.3	116.2	3,209,544.2	1,801.6	1.2	0.8
Minimum:	9.6	13.0	7.8	97.8	2,914,330.7	1,489.7	1.1	0.6
Maximum:	11.0	13.8	8.8	157.6	3,370,305.6	2,212.1	1.7	1.5
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
09/15/2021 00:00	10.5	13.7	8.6	102.6	3,049,121.2	1,558.6	1.1	0.6
09/15/2021 01:00	10.5	13.6	8.5	103.2	3,062,688.7	1,587.9	1.1	0.6
09/15/2021 02:00	10.5	13.2	8.0	124.9	3,357,894.6	2,035.2	1.2	1.0
09/15/2021 03:00	10.3	13.3	8.0	123.0	3,364,050.2	1,989.8	1.2	1.0
09/15/2021 04:00	10.2	13.7	8.4	113.9	3,274,853.0	1,697.9	1.1	0.7
09/15/2021 05:00	10.4	13.7	8.5	106.8	3,058,571.3	1,608.1	1.1	0.6
09/15/2021 06:00	10.1	13.3	7.8	120.9	3,392,791.2	2,006.8	1.2	1.0
09/15/2021 07:00	10.1	13.3	7.8	118.3	3,350,810.3	1,957.5	1.2	1.0
09/15/2021 08:00	10.5	13.7	8.6	97.4	2,901,223.4	1,483.0	1.1	0.6
09/15/2021 09:00	10.3	13.8	8.6	92.4	2,818,632.6	1,420.2	1.1	0.6
09/15/2021 10:00	9.9	13.8	8.2	100.1	3,080,807.9	1,552.3	1.1	0.6
09/15/2021 11:00	10.4	13.7	8.5	105.7	3,169,043.7	1,619.9	1.1	0.6
09/15/2021 12:00	10.2	13.7	8.4	100.3	3,027,992.9	1,547.8	1.1	0.6
09/15/2021 13:00	10.5	13.2	8.0	129.7	3,313,529.3	2,080.9	1.3	1.0
09/15/2021 14:00	10.4	13.2	8.0	131.6	3,262,964.8	2,096.8	1.4	1.0
09/15/2021 15:00	10.3	13.7	8.4	103.9	3,039,736.4	1,576.0	1.1	0.6
09/15/2021 16:00	10.2	13.7	8.4	102.4	3,061,145.7	1,587.1	1.1	0.6
09/15/2021 17:00	10.5	13.2	8.0	130.4	3,276,229.8	2,081.4	1.3	1.0
09/15/2021 18:00	10.4	13.2	8.0	133.1	3,256,740.2	2,092.8	1.4	1.0
09/15/2021 19:00	10.2	13.3	7.9	122.6	3,291,568.2	1,995.0	1.2	1.0
09/15/2021 20:00	10.1	13.6	8.2	110.9	3,201,076.4	1,706.4	1.1	0.7
09/15/2021 21:00	10.1	13.7	8.3	105.3	3,186,063.6	1,628.6	1.1	0.7
09/15/2021 22:00	10.1	13.3	7.8	117.1	3,354,918.6	1,959.9	1.2	1.0
09/15/2021 23:00	9.9	13.3	7.7	116.4	3,383,518.3	1,951.9	1.1	0.8
Average/Sum#:	10.3	13.5	8.2	113.0	3,188,998.8	1,784.2	1.2	0.8
Minimum:	9.9	13.2	7.7	92.4	2,818,632.6	1,420.2	1.1	0.6
Maximum:	10.5	13.8	8.6	133.1	3,392,791.2	2,096.8	1.4	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
09/16/2021 00:00	9.9	13.5	7.9	109.2	3,184,281.8	1,720.7	1.1	0.7
09/16/2021 01:00	9.7	13.7	7.9	100.1	3,017,820.1	1,542.6	1.1	0.6
09/16/2021 02:00	9.1	13.6	7.4	111.1	3,429,347.3	1,778.0	1.1	0.7
09/16/2021 03:00	9.1	13.6	7.4	111.3	3,433,783.4	1,780.3	1.1	0.7
09/16/2021 04:00	10.1	13.8	8.4	94.0	2,793,427.3	1,407.5	1.1	0.6
09/16/2021 05:00	10.4	13.8	8.6	90.2	2,641,798.3	1,331.1	1.1	0.5
09/16/2021 06:00	10.5	13.8	8.7	92.5	2,711,069.0	1,385.8	1.1	0.6
09/16/2021 07:00	10.2	13.8	8.5	89.5	2,660,009.0	1,359.7	1.1	0.5
09/16/2021 08:00	10.1	13.8	8.4	89.3	2,669,203.8	1,364.4	1.1	0.5
09/16/2021 09:00	10.1	13.8	8.4	89.3	2,676,246.5	1,368.0	1.1	0.5
09/16/2021 10:00	10.1	13.8	8.4	89.4	2,729,917.7	1,375.5	1.1	0.6
09/16/2021 11:00	10.1	13.8	8.4	89.4	2,730,910.1	1,376.0	1.1	0.6
09/16/2021 12:00	9.9	13.7	8.1	101.8	3,144,394.0	1,607.3	1.1	0.6
09/16/2021 13:00	10.2	13.7	8.4	100.8	3,019,776.4	1,543.6	1.1	0.6
09/16/2021 14:00	9.7	13.7	7.9	108.3	3,344,525.6	1,709.6	1.1	0.7
09/16/2021 15:00	10.1	13.7	8.3	107.5	3,230,080.9	1,651.1	1.1	0.7
09/16/2021 16:00	10.3	13.7	8.4	100.8	3,027,406.0	1,547.5	1.1	0.6
09/16/2021 17:00	10.5	13.1	7.9	139.5	3,323,966.5	2,136.0	1.4	1.1
09/16/2021 18:00	10.4	13.1	7.9	139.0	3,269,881.1	2,149.0	1.4	1.1
09/16/2021 19:00	10.2	13.3	7.9	121.8	3,297,342.9	1,998.5	1.2	1.0
09/16/2021 20:00	9.8	13.6	7.9	111.4	3,246,661.3	1,730.7	1.1	0.7
09/16/2021 21:00	10.2	13.6	8.2	108.8	3,217,576.7	1,691.7	1.1	0.7
09/16/2021 22:00	10.3	13.2	7.9	125.8	3,353,296.4	2,056.9	1.3	1.0
09/16/2021 23:00	10.1	13.3	7.8	119.3	3,343,424.3	1,977.6	1.2	1.0
Average/Sum#:	10.0	13.6	8.1	105.8	3,062,339.4	1,649.5	1.1	0.7
Minimum:	9.1	13.1	7.4	89.3	2,641,798.3	1,331.1	1.1	0.5
Maximum:	10.5	13.8	8.7	139.5	3,433,783.4	2,149.0	1.4	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
09/17/2021 00:00	9.9	13.3	7.7	116.9	3,338,485.5	1,950.3	1.2	1.0
09/17/2021 01:00	10.3	13.7	8.4	100.4	2,855,630.2	1,501.4	1.2	0.8
09/17/2021 02:00	10.0	13.7	8.2	99.4	2,992,779.2	1,529.8	1.1	0.6
09/17/2021 03:00	9.9	13.7	8.1	99.2	2,991,801.0	1,529.3	1.1	0.6
09/17/2021 04:00	9.9	13.7	8.1	97.7	2,955,022.2	1,510.5	1.1	0.6
09/17/2021 05:00	9.8	13.7	8.0	98.8	3,015,668.1	1,541.5	1.1	0.6
09/17/2021 06:00	10.4	13.7	8.5	97.4	2,894,767.5	1,479.7	1.1	0.6
09/17/2021 07:00	10.2	13.8	8.5	94.7	2,815,927.8	1,439.4	1.1	0.6
09/17/2021 08:00	10.4	13.8	8.6	89.5	2,651,010.0	1,355.1	1.1	0.5
09/17/2021 09:00	10.3	13.8	8.6	89.3	2,695,384.4	1,358.1	1.1	0.5
09/17/2021 10:00	10.1	13.8	8.4	88.9	2,698,758.4	1,359.8	1.1	0.5
09/17/2021 11:00	9.9	13.8	8.2	88.6	2,716,422.0	1,368.7	1.1	0.5
09/17/2021 12:00	9.9	13.9	8.3	88.7	2,715,429.6	1,368.2	1.1	0.5
09/17/2021 13:00	9.7	13.7	7.9	102.0	3,144,198.4	1,607.2	1.1	0.6
09/17/2021 14:00	9.8	13.8	8.1	98.3	2,917,656.5	1,491.4	1.1	0.6
09/17/2021 15:00	9.9	13.8	8.2	98.0	2,942,501.7	1,504.1	1.1	0.6
09/17/2021 16:00	10.2	13.7	8.4	104.0	3,098,178.0	1,606.3	1.1	0.6
09/17/2021 17:00	10.6	13.1	8.0	133.3	3,283,039.3	2,109.7	1.4	1.1
09/17/2021 18:00	10.4	13.1	7.9	145.3	3,298,506.9	2,191.9	1.5	1.3
09/17/2021 19:00	10.0	13.2	7.7	125.9	3,320,528.1	2,036.8	1.3	1.0
09/17/2021 20:00	10.0	13.3	7.8	117.1	3,350,810.3	1,957.5	1.2	1.0
09/17/2021 21:00	10.1	13.3	7.8	119.2	3,343,931.5	1,977.9	1.2	1.0
09/17/2021 22:00	10.0	13.3	7.8	119.1	3,335,816.4	1,973.1	1.2	1.0
09/17/2021 23:00	10.2	13.7	8.4	101.4	2,883,589.3	1,516.1	1.2	0.8
Average/Sum#:	10.1	13.6	8.2	104.7	3,010,660.1	1,636.0	1.2	0.7
Minimum:	9.7	13.1	7.7	88.6	2,651,010.0	1,355.1	1.1	0.5
Maximum:	10.6	13.9	8.6	145.3	3,350,810.3	2,191.9	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
09/18/2021 00:00	10.3	13.8	8.6	91.7	2,722,376.0	1,371.7	1.1	0.5
09/18/2021 01:00	10.2	13.8	8.5	89.5	2,674,942.3	1,347.8	1.1	0.5
09/18/2021 02:00	10.1	13.8	8.4	89.3	2,680,499.4	1,350.6	1.1	0.5
09/18/2021 03:00	10.1	13.8	8.4	89.3	2,691,216.6	1,356.0	1.1	0.5
09/18/2021 04:00	10.0	13.8	8.3	93.7	2,798,516.5	1,430.5	1.1	0.6
09/18/2021 05:00	10.2	13.8	8.5	91.3	2,699,918.0	1,380.1	1.1	0.6
09/18/2021 06:00	10.5	13.8	8.7	92.3	2,722,024.4	1,391.4	1.1	0.6
09/18/2021 07:00	10.4	13.8	8.6	90.3	2,677,029.0	1,368.4	1.1	0.5
09/18/2021 08:00	10.4	13.8	8.6	90.4	2,680,746.0	1,370.3	1.1	0.5
09/18/2021 09:00	10.4	13.8	8.6	90.1	2,683,876.2	1,371.9	1.1	0.5
09/18/2021 10:00	10.3	13.8	8.6	90.0	2,730,910.1	1,376.0	1.1	0.6
09/18/2021 11:00	10.3	13.8	8.6	89.7	2,728,726.9	1,374.9	1.1	0.5
09/18/2021 12:00	10.1	13.8	8.4	89.6	2,721,383.6	1,371.2	1.1	0.5
09/18/2021 13:00	10.2	13.8	8.5	89.5	2,718,803.6	1,369.9	1.1	0.5
09/18/2021 14:00	10.2	13.8	8.5	89.5	2,711,857.2	1,366.4	1.1	0.5
09/18/2021 15:00	10.2	13.8	8.5	89.7	2,706,895.5	1,363.9	1.1	0.5
09/18/2021 16:00	10.2	13.8	8.5	91.9	2,783,305.4	1,402.4	1.1	0.6
09/18/2021 17:00	10.1	13.8	8.4	92.9	2,806,724.6	1,414.2	1.1	0.6
09/18/2021 18:00	10.2	13.8	8.5	92.5	2,773,977.5	1,397.7	1.1	0.6
09/18/2021 19:00	10.2	13.8	8.5	90.0	2,707,094.0	1,364.0	1.1	0.5
09/18/2021 20:00	9.9	13.7	8.1	101.5	3,065,358.7	1,566.9	1.1	0.6
09/18/2021 21:00	9.8	13.8	8.1	97.5	2,914,722.0	1,489.9	1.1	0.6
09/18/2021 22:00	9.8	13.7	8.0	98.9	2,986,910.2	1,526.8	1.1	0.6
09/18/2021 23:00	10.0	13.8	8.3	89.1	2,651,988.1	1,355.6	1.1	0.5
Average/Sum#:	10.2	13.8	8.4	91.7	2,751,658.4	1,394.9	1.1	0.5
Minimum:	9.8	13.7	8.0	89.1	2,651,988.1	1,347.8	1.1	0.5
Maximum:	10.5	13.8	8.7	101.5	3,065,358.7	1,566.9	1.1	0.6
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
09/19/2021 00:00	9.9	13.8	8.2	89.1	2,655,313.9	1,357.3	1.1	0.5
09/19/2021 01:00	10.1	13.8	8.4	89.4	2,652,770.7	1,356.0	1.1	0.5
09/19/2021 02:00	10.1	13.8	8.4	89.3	2,647,488.6	1,353.3	1.1	0.5
09/19/2021 03:00	10.1	13.8	8.4	89.3	2,658,444.0	1,358.9	1.1	0.5
09/19/2021 04:00	10.0	13.8	8.3	92.3	2,757,238.2	1,409.4	1.1	0.6
09/19/2021 05:00	9.9	13.7	8.1	93.0	2,779,735.9	1,420.9	1.1	0.6
09/19/2021 06:00	10.5	13.8	8.7	90.1	2,657,270.2	1,358.3	1.1	0.5
09/19/2021 07:00	10.3	13.8	8.6	89.7	2,660,204.7	1,359.8	1.1	0.5
09/19/2021 08:00	10.2	13.8	8.5	89.5	2,654,335.7	1,356.8	1.1	0.5
09/19/2021 09:00	10.1	13.8	8.4	89.3	2,661,769.7	1,360.6	1.1	0.5
09/19/2021 10:00	9.8	13.8	8.1	90.1	2,754,130.8	1,387.7	1.1	0.6
09/19/2021 11:00	9.8	13.9	8.3	88.8	2,723,169.9	1,372.1	1.1	0.5
09/19/2021 12:00	9.6	13.9	8.1	88.7	2,724,757.6	1,372.9	1.1	0.5
09/19/2021 13:00	9.6	13.9	8.1	88.4	2,717,215.8	1,369.1	1.1	0.5
09/19/2021 14:00	9.5	13.9	8.0	90.3	2,780,130.0	1,400.8	1.1	0.6
09/19/2021 15:00	9.5	13.9	8.0	88.2	2,718,009.7	1,369.5	1.1	0.5
09/19/2021 16:00	9.4	13.8	7.8	98.1	3,080,014.1	1,551.9	1.0	0.6
09/19/2021 17:00	9.4	13.7	7.7	109.2	3,383,260.8	1,729.4	1.1	0.7
09/19/2021 18:00	9.4	13.8	7.8	100.3	3,057,729.0	1,563.0	1.1	0.6
09/19/2021 19:00	9.5	13.9	8.0	92.0	2,827,365.2	1,424.6	1.1	0.6
09/19/2021 20:00	9.3	13.8	7.7	99.9	3,094,303.7	1,559.1	1.1	0.6
09/19/2021 21:00	9.5	13.9	8.0	91.0	2,780,328.4	1,400.9	1.1	0.6
09/19/2021 22:00	9.6	13.9	8.1	88.4	2,707,094.0	1,364.0	1.1	0.5
09/19/2021 23:00	9.6	13.9	8.1	88.4	2,705,307.8	1,363.1	1.1	0.5
Average/Sum#:	9.8	13.8	8.2	91.8	2,784,891.2	1,413.3	1.1	0.5
Minimum:	9.3	13.7	7.7	88.2	2,647,488.6	1,353.3	1.0	0.5
Maximum:	10.5	13.9	8.7	109.2	3,383,260.8	1,729.4	1.1	0.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
09/20/2021 00:00	9.6	13.9	8.1	88.4	2,702,926.2	1,361.9	1.1	0.5
09/20/2021 01:00	9.5	13.8	7.9	96.4	2,974,389.8	1,520.4	1.1	0.6
09/20/2021 02:00	9.4	13.7	7.7	109.1	3,373,087.9	1,724.2	1.1	0.7
09/20/2021 03:00	9.7	13.9	8.2	88.7	2,589,601.4	1,304.8	1.1	0.5
09/20/2021 04:00	9.6	13.8	8.0	94.8	2,916,675.5	1,469.6	1.1	0.6
09/20/2021 05:00	9.6	13.4	7.6	115.2	3,335,601.8	1,899.9	1.1	0.8
09/20/2021 06:00	10.2	13.3	7.9	121.6	3,393,805.6	2,007.4	1.2	1.0
09/20/2021 07:00	10.3	13.7	8.4	100.8	2,920,345.7	1,514.1	1.1	0.6
09/20/2021 08:00	10.0	14.0	8.6	88.4	2,632,718.4	1,307.3	1.1	0.5
09/20/2021 09:00	9.6	14.0	8.2	87.6	2,638,558.6	1,310.2	1.1	0.5
09/20/2021 10:00	9.4	14.0	8.0	87.2	2,642,586.3	1,312.2	1.1	0.5
09/20/2021 11:00	9.2	13.8	7.6	100.7	3,140,677.0	1,605.4	1.0	0.6
09/20/2021 12:00	9.9	13.3	7.7	121.0	3,397,675.5	2,034.5	1.2	1.0
09/20/2021 13:00	10.0	13.3	7.8	122.8	3,397,174.5	2,034.2	1.2	1.0
09/20/2021 14:00	9.7	13.7	7.9	104.6	3,037,079.0	1,596.8	1.1	0.6
09/20/2021 15:00	9.5	13.8	7.9	99.6	3,055,968.3	1,562.1	1.1	0.6
09/20/2021 16:00	10.2	13.2	7.8	133.1	3,389,405.9	2,103.8	1.3	1.1
09/20/2021 17:00	10.4	13.1	7.9	164.1	3,330,906.3	2,286.4	1.7	1.6
09/20/2021 18:00	10.3	13.1	7.8	166.2	3,322,165.3	2,280.4	1.7	1.6
09/20/2021 19:00	10.1	13.1	7.6	154.4	3,338,865.0	2,243.1	1.6	1.3
09/20/2021 20:00	10.1	13.1	7.6	149.5	3,352,959.5	2,203.6	1.5	1.3
09/20/2021 21:00	10.0	13.2	7.7	139.0	3,373,978.4	2,143.5	1.4	1.1
09/20/2021 22:00	9.9	13.3	7.7	120.3	3,414,488.5	1,994.7	1.2	1.0
09/20/2021 23:00	9.9	13.3	7.7	116.8	3,373,117.6	1,945.9	1.1	0.8
Average/Sum#:	9.8	13.5	7.9	115.4	3,126,864.9	1,781.9	1.2	0.9
Minimum:	9.2	13.1	7.6	87.2	2,589,601.4	1,304.8	1.0	0.5
Maximum:	10.4	14.0	8.6	166.2	3,414,488.5	2,286.4	1.7	1.6
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
09/21/2021 00:00	9.8	13.7	8.0	109.1	3,332,200.8	1,703.3	1.1	0.7
09/21/2021 01:00	10.2	13.7	8.4	103.5	3,138,525.1	1,604.3	1.1	0.6
09/21/2021 02:00	9.9	13.3	7.7	116.6	3,452,880.7	1,966.7	1.1	0.8
09/21/2021 03:00	9.9	13.4	7.8	116.0	3,437,957.5	1,958.2	1.1	0.8
09/21/2021 04:00	9.9	13.4	7.8	115.7	3,431,812.6	1,954.7	1.1	0.8
09/21/2021 05:00	10.0	13.4	7.9	118.9	3,414,720.4	1,969.9	1.2	1.0
09/21/2021 06:00	10.3	13.3	8.0	130.1	3,425,191.2	2,101.0	1.3	1.1
09/21/2021 07:00	10.0	13.4	7.9	117.1	3,423,385.4	1,949.9	1.1	0.8
09/21/2021 08:00	10.1	13.8	8.4	97.2	2,920,982.2	1,493.1	1.1	0.6
09/21/2021 09:00	9.5	13.8	7.9	98.8	3,075,449.3	1,549.6	1.0	0.6
09/21/2021 10:00	9.4	13.8	7.8	105.8	3,291,118.1	1,682.3	1.0	0.7
09/21/2021 11:00	9.3	13.8	7.7	103.8	3,281,458.4	1,653.4	1.0	0.7
09/21/2021 12:00	9.9	13.5	7.9	130.4	3,375,794.1	2,070.7	1.3	1.0
09/21/2021 13:00	10.0	13.4	7.9	156.8	3,307,837.1	2,198.1	1.6	1.3
09/21/2021 14:00	10.0	13.4	7.9	154.4	3,312,803.1	2,201.4	1.6	1.3
09/21/2021 15:00	10.0	13.4	7.9	163.4	3,293,763.3	2,212.8	1.7	1.5
09/21/2021 16:00	10.1	13.4	7.9	165.4	3,281,464.8	2,228.5	1.7	1.6
09/21/2021 17:00	10.1	13.4	7.9	166.0	3,291,183.3	2,235.1	1.7	1.6
09/21/2021 18:00	9.9	13.4	7.8	171.3	3,279,480.0	2,251.1	1.8	1.6
09/21/2021 19:00	10.1	13.3	7.8	158.6	3,302,843.2	2,218.9	1.6	1.3
09/21/2021 20:00	10.5	13.1	7.9	158.1	3,330,827.1	2,237.7	1.6	1.3
09/21/2021 21:00	10.3	13.1	7.8	149.4	3,323,136.5	2,184.0	1.5	1.3
09/21/2021 22:00	10.2	13.1	7.7	141.4	3,373,348.7	2,143.1	1.4	1.1
09/21/2021 23:00	10.1	13.2	7.7	131.9	3,365,849.5	2,064.6	1.3	1.0
Average/Sum#:	10.0	13.4	7.9	132.5	3,311,000.5	1,993.0	1.3	1.0
Minimum:	9.3	13.1	7.7	97.2	2,920,982.2	1,493.1	1.0	0.6
Maximum:	10.5	13.8	8.4	171.3	3,452,880.7	2,251.1	1.8	1.6
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
09/22/2021 00:00	10.4	13.7	8.5	115.3	3,179,957.7	1,648.7	1.2	0.8
09/22/2021 01:00	10.1	13.7	8.3	108.5	3,244,764.3	1,682.3	1.1	0.7
09/22/2021 02:00	10.0	13.4	7.9	116.3	3,393,399.0	1,957.6	1.1	0.8
09/22/2021 03:00	10.2	13.3	7.9	116.6	3,432,514.9	1,955.1	1.1	0.8
09/22/2021 04:00	10.3	13.2	7.9	128.9	3,450,949.4	2,066.4	1.2	1.0
09/22/2021 05:00	10.5	13.1	7.9	151.8	3,368,014.6	2,188.9	1.5	1.3
09/22/2021 06:00	10.6	13.2	8.1	135.7	3,362,096.1	2,111.4	1.4	1.1
09/22/2021 07:00	10.3	13.3	8.0	122.4	3,377,104.5	1,948.2	1.2	1.0
09/22/2021 08:00	10.1	13.7	8.3	107.5	3,242,014.4	1,657.2	1.1	0.7
09/22/2021 09:00	9.7	13.7	7.9	111.0	3,385,371.4	1,755.2	1.1	0.7
09/22/2021 10:00	10.5	13.3	8.2	121.3	3,376,487.0	1,972.5	1.2	1.0
09/22/2021 11:00	10.7	13.2	8.2	136.1	3,317,351.0	2,083.3	1.4	1.0
09/22/2021 12:00	10.3	13.7	8.4	107.3	3,207,583.2	1,639.6	1.1	0.7
09/22/2021 13:00	9.6	13.7	7.9	109.5	3,347,760.4	1,735.7	1.1	0.7
09/22/2021 14:00	10.6	13.2	8.1	134.9	3,327,386.4	2,113.9	1.4	1.1
09/22/2021 15:00	10.6	13.1	8.0	153.5	3,276,163.8	2,224.9	1.6	1.3
09/22/2021 16:00	10.6	13.0	7.9	162.3	3,281,373.9	2,252.4	1.7	1.6
09/22/2021 17:00	10.5	13.1	7.9	158.2	3,265,203.1	2,241.3	1.7	1.6
09/22/2021 18:00	10.4	13.1	7.9	159.4	3,309,147.8	2,247.3	1.7	1.6
09/22/2021 19:00	10.0	13.2	7.7	140.0	3,287,863.5	2,112.8	1.4	1.1
09/22/2021 20:00	9.9	13.7	8.1	108.2	3,275,076.2	1,674.1	1.1	0.7
09/22/2021 21:00	9.8	13.5	7.8	113.5	3,420,517.8	1,798.4	1.1	0.7
09/22/2021 22:00	10.2	13.3	7.9	123.7	3,369,279.0	2,042.1	1.2	1.0
09/22/2021 23:00	10.2	13.2	7.8	129.8	3,339,166.2	2,097.0	1.3	1.0
Average/Sum#:	10.3	13.4	8.0	128.0	3,326,522.7	1,966.9	1.3	1.0
Minimum:	9.6	13.0	7.7	107.3	3,179,957.7	1,639.6	1.1	0.7
Maximum:	10.7	13.7	8.5	162.3	3,450,949.4	2,252.4	1.7	1.6
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
09/23/2021 00:00	10.0	13.3	7.8	120.3	3,340,550.2	1,975.9	1.2	1.0
09/23/2021 01:00	10.3	13.7	8.4	103.8	3,099,985.5	1,584.6	1.1	0.6
09/23/2021 02:00	9.9	13.8	8.2	100.5	3,074,258.5	1,549.0	1.1	0.6
09/23/2021 03:00	8.9	13.8	7.4	104.0	3,292,374.1	1,658.9	1.0	0.7
09/23/2021 04:00	9.5	13.7	7.8	102.8	3,145,959.1	1,608.1	1.1	0.6
09/23/2021 05:00	9.9	13.3	7.7	124.4	3,320,612.5	2,061.1	1.3	1.0
09/23/2021 06:00	10.2	13.3	7.9	125.4	3,337,930.7	2,023.1	1.3	1.0
09/23/2021 07:00	9.9	13.7	8.1	108.9	3,296,204.5	1,684.9	1.1	0.7
09/23/2021 08:00	10.4	13.8	8.6	95.3	2,817,441.8	1,419.6	1.1	0.6
09/23/2021 09:00	9.6	13.6	7.8	111.8	3,439,762.6	1,783.4	1.1	0.7
09/23/2021 10:00	9.7	13.6	7.8	112.6	3,394,841.1	1,784.9	1.1	0.7
09/23/2021 11:00	9.9	13.5	7.9	113.2	3,399,025.4	1,787.1	1.1	0.7
09/23/2021 12:00	9.9	13.5	7.9	112.9	3,388,754.8	1,781.7	1.1	0.7
09/23/2021 13:00	9.9	13.5	7.9	112.7	3,385,331.2	1,779.9	1.1	0.7
09/23/2021 14:00	9.8	13.5	7.8	112.6	3,384,380.2	1,779.4	1.1	0.7
09/23/2021 15:00	9.8	13.5	7.8	112.4	3,383,809.6	1,779.1	1.1	0.7
09/23/2021 16:00	9.8	13.5	7.8	112.6	3,381,907.6	1,778.1	1.1	0.7
09/23/2021 17:00	9.8	13.5	7.8	112.7	3,387,423.4	1,781.0	1.1	0.7
09/23/2021 18:00	9.8	13.5	7.8	113.0	3,401,688.2	1,788.5	1.1	0.7
09/23/2021 19:00	9.7	13.5	7.7	112.8	3,412,149.1	1,794.0	1.1	0.7
09/23/2021 20:00	9.8	13.5	7.8	113.2	3,426,033.5	1,801.3	1.1	0.7
09/23/2021 21:00	9.8	13.5	7.8	113.3	3,426,033.5	1,801.3	1.1	0.7
09/23/2021 22:00	9.8	13.5	7.8	113.4	3,421,849.2	1,799.1	1.1	0.7
09/23/2021 23:00	9.8	13.5	7.8	113.4	3,416,713.8	1,796.4	1.1	0.7
Average/Sum#:	9.8	13.5	7.9	111.6	3,323,959.2	1,765.9	1.1	0.7
Minimum:	8.9	13.3	7.4	95.3	2,817,441.8	1,419.6	1.0	0.6
Maximum:	10.4	13.8	8.6	125.4	3,439,762.6	2,061.1	1.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
09/24/2021 00:00	9.8	13.5	7.8	113.4	3,418,806.0	1,797.5	1.1	0.7
09/24/2021 01:00	9.8	13.5	7.8	113.5	3,419,376.6	1,797.8	1.1	0.7
09/24/2021 02:00	9.8	13.5	7.8	113.4	3,421,278.6	1,798.8	1.1	0.7
09/24/2021 03:00	9.8	13.5	7.8	113.6	3,422,990.4	1,799.7	1.1	0.7
09/24/2021 04:00	9.7	13.5	7.7	113.9	3,430,408.1	1,803.6	1.1	0.7
09/24/2021 05:00	9.7	13.5	7.7	114.8	3,422,419.8	1,799.4	1.1	0.7
09/24/2021 06:00	9.9	13.5	7.9	114.7	3,429,076.7	1,802.9	1.1	0.7
09/24/2021 07:00	9.9	13.5	7.9	114.6	3,433,831.6	1,805.4	1.1	0.7
09/24/2021 08:00	9.9	13.5	7.9	114.2	3,428,125.7	1,802.4	1.1	0.7
09/24/2021 09:00	10.0	13.7	8.2	108.6	3,280,749.6	1,677.0	1.1	0.7
09/24/2021 10:00	10.1	13.8	8.4	101.5	3,046,578.0	1,557.3	1.1	0.6
09/24/2021 11:00	9.6	13.8	8.0	104.4	3,235,612.4	1,630.3	1.0	0.7
09/24/2021 12:00	9.7	13.8	8.1	104.6	3,189,585.0	1,630.4	1.1	0.7
09/24/2021 13:00	9.5	13.7	7.8	106.9	3,294,052.5	1,683.8	1.1	0.7
09/24/2021 14:00	9.4	13.7	7.7	108.9	3,368,979.6	1,722.1	1.1	0.7
09/24/2021 15:00	9.7	13.7	7.9	109.3	3,305,327.6	1,713.7	1.1	0.7
09/24/2021 16:00	9.9	13.7	8.1	109.0	3,323,006.1	1,698.6	1.1	0.7
09/24/2021 17:00	10.1	13.6	8.2	111.3	3,312,675.6	1,741.7	1.1	0.7
09/24/2021 18:00	10.0	13.7	8.2	108.5	3,282,705.9	1,678.0	1.1	0.7
09/24/2021 19:00	9.7	13.7	7.9	109.5	3,349,416.4	1,712.1	1.1	0.7
09/24/2021 20:00	10.4	13.7	8.5	108.2	3,239,079.9	1,655.7	1.1	0.7
09/24/2021 21:00	10.7	13.7	8.8	107.8	3,195,454.0	1,633.4	1.1	0.7
09/24/2021 22:00	10.7	13.7	8.8	109.9	3,219,690.3	1,669.3	1.1	0.7
09/24/2021 23:00	10.7	13.7	8.8	110.0	3,257,860.6	1,665.3	1.1	0.7
Average/Sum#:	9.9	13.6	8.1	110.2	3,321,962.0	1,719.8	1.1	0.7
Minimum:	9.4	13.5	7.7	101.5	3,046,578.0	1,557.3	1.0	0.6
Maximum:	10.7	13.8	8.8	114.8	3,433,831.6	1,805.4	1.1	0.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
09/25/2021 00:00	11.0	13.7	9.0	105.9	3,114,071.0	1,591.8	1.1	0.6
09/25/2021 01:00	10.8	13.7	8.9	109.4	3,198,859.6	1,658.5	1.1	0.7
09/25/2021 02:00	10.6	13.7	8.7	110.9	3,253,636.6	1,686.9	1.1	0.7
09/25/2021 03:00	10.4	13.7	8.5	110.2	3,251,322.1	1,685.7	1.1	0.7
09/25/2021 04:00	10.2	13.7	8.4	107.3	3,207,387.5	1,639.5	1.1	0.7
09/25/2021 05:00	10.3	13.7	8.4	105.2	3,171,000.0	1,620.9	1.1	0.6
09/25/2021 06:00	10.1	13.7	8.3	109.2	3,258,447.5	1,665.6	1.1	0.7
09/25/2021 07:00	10.1	13.7	8.3	108.3	3,247,492.1	1,660.0	1.1	0.7
09/25/2021 08:00	10.1	13.8	8.4	101.2	3,038,165.8	1,553.0	1.1	0.6
09/25/2021 09:00	10.3	13.8	8.6	90.7	2,691,613.5	1,356.2	1.1	0.5
09/25/2021 10:00	9.7	13.8	8.1	99.7	3,022,515.2	1,545.0	1.1	0.6
09/25/2021 11:00	9.3	13.8	7.7	106.0	3,276,836.9	1,675.0	1.1	0.7
09/25/2021 12:00	10.0	13.7	8.2	108.9	3,296,987.0	1,685.3	1.1	0.7
09/25/2021 13:00	10.1	13.7	8.3	108.7	3,271,163.6	1,672.1	1.1	0.7
09/25/2021 14:00	9.8	13.7	8.0	109.3	3,334,744.0	1,704.6	1.1	0.7
09/25/2021 15:00	10.0	13.7	8.2	109.5	3,280,832.2	1,701.0	1.1	0.7
09/25/2021 16:00	10.4	13.7	8.5	107.9	3,183,236.6	1,650.4	1.1	0.7
09/25/2021 17:00	10.8	13.8	9.0	92.1	2,667,797.5	1,344.2	1.1	0.5
09/25/2021 18:00	9.5	13.7	7.8	104.7	3,214,234.7	1,643.0	1.1	0.7
09/25/2021 19:00	9.7	13.7	7.9	109.0	3,328,483.8	1,701.4	1.1	0.7
09/25/2021 20:00	10.2	13.7	8.4	108.8	3,257,078.1	1,664.9	1.1	0.7
09/25/2021 21:00	10.4	13.7	8.5	103.1	3,082,378.7	1,575.6	1.1	0.6
09/25/2021 22:00	17.4	15.1	17.7	133.8	2,107,288.8	907.9	2.1	0.7
09/25/2021 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	10.5	13.8	8.8	106.9	3,119,807.5	1,590.8	1.1	0.7
Minimum:	9.3	13.7	7.7	90.7	2,107,288.8	907.9	1.1	0.5
Maximum:	17.4	15.1	17.7	133.8	3,334,744.0	1,704.6	2.1	0.7
%SI	4.17	4.17	4.17	4.17	4.17	4.17	4.17	4.17

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
09/26/2021 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/26/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/26/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/26/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/26/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/26/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/26/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/26/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/26/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/26/2021 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/26/2021 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/26/2021 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/26/2021 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/26/2021 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/26/2021 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/26/2021 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/26/2021 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/26/2021 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/26/2021 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/26/2021 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/26/2021 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/26/2021 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/26/2021 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/26/2021 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
09/27/2021 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/27/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/27/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/27/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/27/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/27/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/27/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/27/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/27/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/27/2021 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/27/2021 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/27/2021 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/27/2021 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/27/2021 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/27/2021 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/27/2021 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/27/2021 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/27/2021 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/27/2021 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/27/2021 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/27/2021 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/27/2021 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/27/2021 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/27/2021 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
09/28/2021 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/28/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/28/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/28/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/28/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/28/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/28/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/28/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/28/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/28/2021 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/28/2021 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/28/2021 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/28/2021 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/28/2021 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/28/2021 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/28/2021 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/28/2021 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/28/2021 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/28/2021 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/28/2021 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/28/2021 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/28/2021 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/28/2021 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/28/2021 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
09/29/2021 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/29/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/29/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/29/2021 03:00	36.2	17.6	64.7	0.0	1,204,637.0	263.9	0.0	0.0
09/29/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/29/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/29/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/29/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/29/2021 08:00	34.1	17.7	62.9	131.3	1,095,050.4	223.9	0.0	0.0
09/29/2021 09:00	44.5	15.2	46.1	259.6	2,158,212.8	866.8	3.9	1.3
09/29/2021 10:00	10.1	13.8	8.4	109.0	3,124,470.7	1,574.3	1.1	0.6
09/29/2021 11:00	10.9	13.8	9.1	100.4	982,447.3	1,499.4	3.6	2.1
09/29/2021 12:00	10.1	13.9	8.5	99.0	974,715.7	1,487.6	3.6	2.1
09/29/2021 13:00	10.0	13.8	8.3	107.3	3,295,549.5	1,660.5	1.1	0.7
09/29/2021 14:00	10.3	13.8	8.6	110.5	3,308,920.6	1,691.4	1.1	0.7
09/29/2021 15:00	10.4	13.8	8.6	111.2	3,325,744.9	1,700.0	1.1	0.7
09/29/2021 16:00	10.5	13.8	8.7	110.8	3,301,486.6	1,687.6	1.1	0.7
09/29/2021 17:00	10.8	13.8	9.0	98.0	2,876,982.0	1,449.6	1.1	0.6
09/29/2021 18:00	10.1	13.9	8.5	91.9	2,831,486.3	1,406.0	1.0	0.6
09/29/2021 19:00	10.4	13.8	8.6	110.6	3,253,752.3	1,663.2	1.1	0.7
09/29/2021 20:00	10.6	13.7	8.7	110.3	3,271,359.2	1,672.2	1.1	0.7
09/29/2021 21:00	10.8	13.7	8.9	109.1	3,212,474.0	1,642.1	1.1	0.7
09/29/2021 22:00	10.7	13.7	8.8	110.8	3,282,510.2	1,677.9	1.1	0.7
09/29/2021 23:00	10.9	13.7	8.9	103.7	3,031,905.6	1,549.8	1.1	0.6
Average/Sum#:	15.4	14.3	17.4	110.2	2,838,302.8	1,395.1	1.1	0.6
Minimum:	10.0	13.7	8.3	0.0	1,095,050.4	223.9	0.0	0.0
Maximum:	44.5	17.7	64.7	259.6	3,325,744.9	1,700.0	3.9	1.3
%SI	29.17	29.17	29.17	29.17	37.50	29.17	37.50	37.50

Daily Summary Report

CT1 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
09/30/2021 00:00	10.0	13.9	8.4	99.7	3,017,695.3	1,520.5	1.1	0.6
09/30/2021 01:00	10.1	14.0	8.6	90.8	2,691,724.5	1,336.6	1.1	0.5
09/30/2021 02:00	9.9	14.0	8.5	89.1	2,638,558.6	1,310.2	1.1	0.5
09/30/2021 03:00	9.4	13.8	7.8	100.2	3,114,745.8	1,569.4	1.0	0.6
09/30/2021 04:00	9.1	13.8	7.6	103.3	3,235,017.0	1,630.0	1.0	0.7
09/30/2021 05:00	9.7	14.0	8.3	97.2	2,733,008.6	1,357.1	1.2	0.7
09/30/2021 06:00	10.5	13.8	8.7	96.9	2,898,019.5	1,460.2	1.1	0.6
09/30/2021 07:00	10.1	13.9	8.5	89.3	2,719,112.9	1,350.2	1.1	0.5
09/30/2021 08:00	9.9	13.9	8.3	88.9	2,715,085.2	1,348.2	1.1	0.5
09/30/2021 09:00	9.6	13.9	8.1	88.3	2,743,077.9	1,362.1	1.0	0.5
09/30/2021 10:00	9.5	13.9	8.0	88.1	2,750,931.9	1,366.0	1.0	0.5
09/30/2021 11:00	9.4	13.9	7.9	87.9	2,751,938.9	1,366.5	1.0	0.5
09/30/2021 12:00	9.3	14.0	8.0	87.7	2,754,154.1	1,367.6	1.0	0.5
09/30/2021 13:00	9.0	14.0	7.7	87.0	2,743,682.0	1,362.4	1.0	0.5
09/30/2021 14:00	9.1	14.0	7.8	88.2	2,791,410.5	1,386.1	1.0	0.6
09/30/2021 15:00	10.0	13.4	7.9	123.0	3,415,240.4	1,970.2	1.2	1.0
09/30/2021 16:00	10.5	13.3	8.2	131.3	3,384,649.3	2,026.7	1.3	1.0
09/30/2021 17:00	10.5	13.3	8.2	128.5	3,376,222.8	1,997.0	1.3	1.0
09/30/2021 18:00	10.5	13.3	8.2	125.5	3,409,693.4	1,967.0	1.2	1.0
09/30/2021 19:00	10.4	13.3	8.1	124.8	3,406,746.5	1,965.3	1.2	1.0
09/30/2021 20:00	10.4	13.3	8.1	123.0	3,380,398.1	1,950.1	1.2	1.0
09/30/2021 21:00	10.4	13.3	8.1	122.0	3,385,425.1	1,953.0	1.2	1.0
09/30/2021 22:00	10.1	13.4	7.9	119.1	3,417,692.0	1,921.7	1.2	1.0
09/30/2021 23:00	10.7	13.8	8.9	95.2	2,798,587.4	1,410.1	1.1	0.6
Average/Sum#:	9.9	13.7	8.2	103.1	3,011,367.4	1,593.9	1.1	0.7
Minimum:	9.0	13.3	7.6	87.0	2,638,558.6	1,310.2	1.0	0.5
Maximum:	10.7	14.0	8.9	131.3	3,417,692.0	2,026.7	1.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/01/2021 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2021 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2021 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2021 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2021 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2021 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2021 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2021 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2021 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2021 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2021 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2021 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2021 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2021 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2021 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/01/2021 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/02/2021 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2021 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2021 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2021 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2021 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2021 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2021 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2021 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2021 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2021 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2021 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2021 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2021 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2021 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2021 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/02/2021 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/03/2021 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/03/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/03/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/03/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/03/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/03/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/03/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/03/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/03/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/03/2021 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/03/2021 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/03/2021 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/03/2021 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/03/2021 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/03/2021 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/03/2021 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/03/2021 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/03/2021 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/03/2021 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/03/2021 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/03/2021 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/03/2021 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/03/2021 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/03/2021 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/04/2021 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2021 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2021 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2021 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2021 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2021 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2021 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2021 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2021 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2021 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2021 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2021 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2021 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2021 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2021 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2021 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/05/2021 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/05/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/05/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/05/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/05/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/05/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/05/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/05/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/05/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/05/2021 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/05/2021 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/05/2021 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/05/2021 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/05/2021 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/05/2021 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/05/2021 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/05/2021 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/05/2021 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/05/2021 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/05/2021 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/05/2021 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/05/2021 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/05/2021 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/05/2021 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/06/2021 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/06/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/06/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/06/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/06/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/06/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/06/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/06/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/06/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/06/2021 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/06/2021 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/06/2021 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/06/2021 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/06/2021 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/06/2021 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/06/2021 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/06/2021 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/06/2021 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/06/2021 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/06/2021 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/06/2021 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/06/2021 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/06/2021 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/06/2021 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/07/2021 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/07/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/07/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/07/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/07/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/07/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/07/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/07/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/07/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/07/2021 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/07/2021 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/07/2021 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/07/2021 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/07/2021 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/07/2021 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/07/2021 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/07/2021 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/07/2021 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/07/2021 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/07/2021 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/07/2021 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/07/2021 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/07/2021 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/07/2021 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/08/2021 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/08/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/08/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/08/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/08/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/08/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/08/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/08/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/08/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/08/2021 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/08/2021 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/08/2021 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/08/2021 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/08/2021 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/08/2021 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/08/2021 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/08/2021 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/08/2021 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/08/2021 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/08/2021 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/08/2021 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/08/2021 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/08/2021 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/08/2021 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/09/2021 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/09/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/09/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/09/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/09/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/09/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/09/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/09/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/09/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/09/2021 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/09/2021 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/09/2021 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/09/2021 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/09/2021 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/09/2021 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/09/2021 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/09/2021 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/09/2021 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/09/2021 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/09/2021 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/09/2021 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/09/2021 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/09/2021 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/09/2021 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/10/2021 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/10/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/10/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/10/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/10/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/10/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/10/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/10/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/10/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/10/2021 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/10/2021 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/10/2021 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/10/2021 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/10/2021 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/10/2021 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/10/2021 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/10/2021 16:00	20.9	17.6	37.4	0.0	853,444.8	174.5	-0.1	0.0
07/10/2021 17:00	25.5	17.5	44.3	0.1	851,533.0	205.2	0.1	0.0
07/10/2021 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/10/2021 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/10/2021 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/10/2021 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/10/2021 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/10/2021 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	23.2	17.6	40.9	0.1	852,488.9	189.9	0.0	0.0
Minimum:	20.9	17.5	37.4	0.0	851,533.0	174.5	-0.1	0.0
Maximum:	25.5	17.6	44.3	0.1	853,444.8	205.2	0.1	0.0
%SI	91.67	91.67	91.67	91.67	91.67	91.67	91.67	91.67

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/11/2021 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/11/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/11/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/11/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/11/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/11/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/11/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/11/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/11/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/11/2021 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/11/2021 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/11/2021 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/11/2021 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/11/2021 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/11/2021 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/11/2021 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/11/2021 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/11/2021 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/11/2021 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/11/2021 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/11/2021 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/11/2021 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/11/2021 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/11/2021 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/12/2021 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/12/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/12/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/12/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/12/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/12/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/12/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/12/2021 07:00	31.7	17.3	52.0	0.0	201,285.7	307.2	-1.1	-0.1
07/12/2021 08:00	32.2	17.0	48.7	227.2	244,858.3	373.7	31.6	4.6
07/12/2021 09:00	30.5	16.0	36.7	252.7	425,832.0	649.9	20.1	5.0
07/12/2021 10:00	8.1	13.7	6.6	97.3	2,619,708.8	1,339.1	1.2	0.7
07/12/2021 11:00	9.8	13.5	7.8	106.4	3,169,837.1	1,666.6	1.0	0.7
07/12/2021 12:00	10.4	13.4	8.2	111.2	3,229,215.3	1,721.4	1.1	0.7
07/12/2021 13:00	10.3	13.4	8.1	111.0	3,225,838.6	1,719.6	1.1	0.7
07/12/2021 14:00	10.2	13.4	8.0	110.6	3,217,584.5	1,715.2	1.1	0.7
07/12/2021 15:00	10.2	13.4	8.0	110.2	3,203,139.9	1,707.5	1.1	0.7
07/12/2021 16:00	9.9	13.6	8.0	100.4	2,982,452.0	1,546.3	1.0	0.6
07/12/2021 17:00	10.2	13.4	8.0	109.5	3,184,380.7	1,697.5	1.1	0.7
07/12/2021 18:00	10.0	13.4	7.9	109.1	3,174,813.5	1,692.4	1.1	0.7
07/12/2021 19:00	9.9	13.5	7.9	108.9	3,218,337.5	1,692.1	1.0	0.7
07/12/2021 20:00	10.1	13.4	7.9	110.6	3,219,460.4	1,716.2	1.1	0.7
07/12/2021 21:00	10.1	13.4	7.9	110.7	3,218,522.5	1,715.7	1.1	0.7
07/12/2021 22:00	10.0	13.5	8.0	109.0	3,203,311.9	1,684.2	1.0	0.7
07/12/2021 23:00	10.2	13.4	8.0	112.6	3,267,484.1	1,741.8	1.1	0.7
Average/Sum#:	13.8	14.0	14.6	117.5	3,152,434.8	1,452.1	1.1	0.7
Minimum:	8.1	13.4	6.6	0.0	2,619,708.8	307.2	1.0	0.6
Maximum:	32.2	17.3	52.0	252.7	3,267,484.1	1,741.8	1.2	0.7
%SI	29.17	29.17	29.17	29.17	41.67	29.17	41.67	41.67

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/13/2021 00:00	10.1	13.4	7.9	112.8	3,277,801.7	1,747.3	1.1	0.7
07/13/2021 01:00	10.1	13.4	7.9	112.8	3,285,117.8	1,751.2	1.1	0.7
07/13/2021 02:00	15.2	14.8	14.7	139.1	2,352,940.5	1,048.1	1.8	0.7
07/13/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/13/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/13/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/13/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/13/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/13/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/13/2021 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/13/2021 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/13/2021 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/13/2021 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/13/2021 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/13/2021 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/13/2021 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/13/2021 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/13/2021 17:00	30.2	17.4	50.9	22.6	1,397,668.8	326.6	0.3	0.0
07/13/2021 18:00	28.9	14.6	27.1	199.2	2,260,919.7	990.6	2.8	1.1
07/13/2021 19:00	9.7	13.5	7.7	106.7	3,185,052.9	1,674.6	1.0	0.7
07/13/2021 20:00	10.6	13.1	8.0	125.2	3,182,474.6	1,882.4	1.2	0.9
07/13/2021 21:00	9.4	13.6	7.6	103.9	2,849,698.1	1,539.9	1.1	0.6
07/13/2021 22:00	8.1	13.8	6.7	84.6	2,565,388.3	1,292.6	1.0	0.5
07/13/2021 23:00	9.8	13.6	7.9	107.8	3,263,859.1	1,692.2	1.0	0.7
Average/Sum#:	14.2	14.1	14.6	111.5	2,762,092.2	1,394.6	1.2	0.7
Minimum:	8.1	13.1	6.7	22.6	1,397,668.8	326.6	0.3	0.0
Maximum:	30.2	17.4	50.9	199.2	3,285,117.8	1,882.4	2.8	1.1
%SI	58.33	58.33	58.33	58.33	58.33	58.33	58.33	58.33

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/14/2021 00:00	9.4	13.7	7.7	101.0	3,030,340.5	1,549.0	1.0	0.6
07/14/2021 01:00	9.6	13.7	7.9	98.8	2,959,913.0	1,513.0	1.0	0.6
07/14/2021 02:00	9.5	13.7	7.8	99.3	2,980,454.4	1,523.5	1.0	0.6
07/14/2021 03:00	9.5	13.7	7.8	104.5	3,146,350.3	1,608.3	1.0	0.6
07/14/2021 04:00	8.7	13.7	7.1	95.1	2,903,179.7	1,484.0	1.0	0.6
07/14/2021 05:00	9.1	13.7	7.5	106.9	3,270,772.3	1,671.9	1.0	0.7
07/14/2021 06:00	9.2	13.8	7.6	100.8	3,132,069.2	1,601.0	1.0	0.6
07/14/2021 07:00	9.4	13.7	7.7	104.7	3,169,156.6	1,643.1	1.0	0.7
07/14/2021 08:00	10.7	13.1	8.1	126.4	3,291,628.6	1,971.0	1.2	1.0
07/14/2021 09:00	10.3	13.1	7.8	122.9	3,227,953.1	1,909.3	1.2	1.0
07/14/2021 10:00	9.4	13.7	7.7	105.7	3,179,803.4	1,625.4	1.0	0.7
07/14/2021 11:00	9.2	13.7	7.5	99.7	3,055,381.4	1,561.8	1.0	0.6
07/14/2021 12:00	10.5	13.0	7.8	126.6	3,252,135.4	1,971.1	1.2	1.0
07/14/2021 13:00	10.6	12.9	7.8	140.3	3,185,312.2	2,046.9	1.4	1.0
07/14/2021 14:00	10.4	12.9	7.7	139.2	3,176,442.1	2,041.2	1.4	1.0
07/14/2021 15:00	10.4	12.9	7.7	138.0	3,198,629.1	2,032.1	1.4	1.0
07/14/2021 16:00	10.4	12.9	7.7	139.1	3,165,860.2	2,034.4	1.4	1.0
07/14/2021 17:00	10.5	12.9	7.7	139.7	3,180,955.0	2,044.1	1.4	1.0
07/14/2021 18:00	10.4	12.9	7.7	138.4	3,209,962.2	2,039.3	1.4	1.0
07/14/2021 19:00	10.4	12.9	7.7	135.4	3,218,465.8	2,021.2	1.3	1.0
07/14/2021 20:00	10.5	12.9	7.7	135.4	3,209,389.4	2,015.5	1.3	1.0
07/14/2021 21:00	10.4	13.0	7.8	132.1	3,245,372.8	1,990.7	1.3	1.0
07/14/2021 22:00	10.4	13.0	7.8	131.5	3,248,959.4	1,992.9	1.3	1.0
07/14/2021 23:00	10.3	13.0	7.7	130.9	3,283,813.7	1,990.3	1.3	1.0
Average/Sum#:	10.0	13.3	7.7	120.5	3,163,429.2	1,828.4	1.2	0.8
Minimum:	8.7	12.9	7.1	95.1	2,903,179.7	1,484.0	1.0	0.6
Maximum:	10.7	13.8	8.1	140.3	3,291,628.6	2,046.9	1.4	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/15/2021 00:00	10.1	13.1	7.6	126.4	3,261,427.9	1,929.1	1.2	1.0
07/15/2021 01:00	8.9	13.7	7.3	99.1	3,001,387.0	1,534.2	1.0	0.6
07/15/2021 02:00	9.2	13.8	7.6	95.3	2,905,331.6	1,485.1	1.0	0.6
07/15/2021 03:00	8.9	13.8	7.4	93.3	2,868,748.5	1,466.4	1.0	0.6
07/15/2021 04:00	9.1	13.7	7.5	106.2	3,275,858.8	1,674.5	1.0	0.7
07/15/2021 05:00	10.3	13.2	7.9	124.0	3,317,473.9	1,913.8	1.2	1.0
07/15/2021 06:00	10.2	13.2	7.8	132.5	3,297,438.7	1,950.4	1.3	1.0
07/15/2021 07:00	9.3	13.7	7.6	108.0	3,144,785.3	1,607.5	1.1	0.6
07/15/2021 08:00	9.2	13.8	7.6	103.8	3,143,220.2	1,606.7	1.0	0.6
07/15/2021 09:00	9.3	13.8	7.7	99.5	3,004,125.8	1,535.6	1.0	0.6
07/15/2021 10:00	9.3	13.8	7.7	105.4	3,200,736.0	1,636.1	1.0	0.7
07/15/2021 11:00	9.1	13.8	7.6	98.5	3,044,091.5	1,533.8	1.0	0.6
07/15/2021 12:00	10.5	13.1	7.9	125.8	3,300,147.8	2,000.2	1.2	1.0
07/15/2021 13:00	10.3	13.0	7.7	131.1	3,261,140.9	2,048.0	1.3	1.0
07/15/2021 14:00	10.2	13.0	7.6	133.3	3,249,313.5	2,064.3	1.3	1.0
07/15/2021 15:00	10.1	13.0	7.5	132.9	3,251,045.0	2,065.4	1.3	1.0
07/15/2021 16:00	10.1	13.0	7.5	133.3	3,220,637.2	2,069.6	1.3	1.0
07/15/2021 17:00	10.1	13.0	7.5	134.9	3,259,859.7	2,071.0	1.3	1.0
07/15/2021 18:00	10.2	12.9	7.5	138.0	3,262,186.7	2,096.3	1.4	1.0
07/15/2021 19:00	10.2	12.9	7.5	140.4	3,233,995.7	2,101.8	1.4	1.1
07/15/2021 20:00	10.2	12.9	7.5	141.5	3,237,534.7	2,104.1	1.4	1.1
07/15/2021 21:00	10.2	13.0	7.6	137.1	3,277,701.3	2,058.4	1.3	1.0
07/15/2021 22:00	10.1	13.1	7.6	130.5	3,286,129.4	2,015.7	1.3	1.0
07/15/2021 23:00	10.1	13.1	7.6	131.2	3,305,692.6	2,027.7	1.3	1.0
Average/Sum#:	9.8	13.3	7.6	120.9	3,192,083.7	1,858.2	1.2	0.9
Minimum:	8.9	12.9	7.3	93.3	2,868,748.5	1,466.4	1.0	0.6
Maximum:	10.5	13.8	7.9	141.5	3,317,473.9	2,104.1	1.4	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/16/2021 00:00	10.0	13.1	7.6	130.9	3,350,140.0	2,030.5	1.2	1.0
07/16/2021 01:00	9.9	13.2	7.6	124.3	3,306,646.4	1,931.7	1.2	1.0
07/16/2021 02:00	9.1	13.7	7.5	103.5	3,133,047.4	1,601.5	1.0	0.6
07/16/2021 03:00	8.8	13.7	7.2	94.7	2,832,165.3	1,447.7	1.0	0.6
07/16/2021 04:00	9.3	13.7	7.6	102.8	3,122,092.0	1,595.9	1.0	0.6
07/16/2021 05:00	9.5	13.5	7.6	112.0	3,289,394.4	1,777.5	1.1	0.7
07/16/2021 06:00	9.8	13.3	7.6	120.1	3,314,907.9	1,839.7	1.1	0.7
07/16/2021 07:00	9.4	13.7	7.7	107.0	3,228,515.8	1,650.3	1.0	0.7
07/16/2021 08:00	9.2	13.7	7.5	105.9	3,221,081.8	1,646.5	1.0	0.7
07/16/2021 09:00	9.4	13.7	7.7	104.6	3,160,827.1	1,615.7	1.0	0.6
07/16/2021 10:00	9.2	13.7	7.5	106.2	3,252,578.5	1,662.6	1.0	0.7
07/16/2021 11:00	9.3	13.7	7.6	99.0	2,918,243.4	1,491.7	1.1	0.6
07/16/2021 12:00	10.3	13.2	7.9	122.0	3,295,579.0	1,949.3	1.2	1.0
07/16/2021 13:00	10.1	13.2	7.7	122.7	3,242,863.7	1,941.8	1.2	1.0
07/16/2021 14:00	9.3	13.7	7.6	105.3	3,184,694.2	1,627.9	1.0	0.7
07/16/2021 15:00	10.1	13.7	8.3	110.3	3,063,402.3	1,565.9	1.1	0.6
07/16/2021 16:00	10.4	13.1	7.9	129.8	3,314,997.0	2,009.2	1.2	1.0
07/16/2021 17:00	10.5	12.9	7.7	146.5	3,265,384.8	2,122.2	1.4	1.1
07/16/2021 18:00	10.4	12.9	7.7	150.6	3,256,491.2	2,140.2	1.5	1.3
07/16/2021 19:00	10.4	12.9	7.7	150.1	3,258,925.7	2,141.8	1.5	1.3
07/16/2021 20:00	10.5	12.9	7.7	150.2	3,273,078.1	2,127.2	1.5	1.3
07/16/2021 21:00	10.4	13.0	7.8	143.2	3,251,293.6	2,089.3	1.4	1.0
07/16/2021 22:00	10.3	13.0	7.7	139.2	3,281,045.3	2,060.5	1.4	1.0
07/16/2021 23:00	10.4	13.1	7.9	134.5	3,268,252.1	2,028.6	1.3	1.0
Average/Sum#:	9.8	13.3	7.7	121.5	3,211,902.0	1,837.3	1.2	0.9
Minimum:	8.8	12.9	7.2	94.7	2,832,165.3	1,447.7	1.0	0.6
Maximum:	10.5	13.7	8.3	150.6	3,350,140.0	2,141.8	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/17/2021 00:00	10.1	13.2	7.7	122.2	3,254,950.6	1,901.5	1.2	1.0
07/17/2021 01:00	9.3	13.7	7.6	105.8	3,181,368.5	1,626.2	1.0	0.7
07/17/2021 02:00	8.1	13.8	6.7	85.0	2,573,922.4	1,296.9	1.0	0.5
07/17/2021 03:00	9.5	13.8	7.9	103.0	3,120,918.2	1,595.3	1.0	0.6
07/17/2021 04:00	9.9	13.4	7.8	113.8	3,259,595.2	1,785.2	1.1	0.7
07/17/2021 05:00	9.8	13.3	7.6	119.4	3,180,751.5	1,811.7	1.2	0.9
07/17/2021 06:00	9.1	13.7	7.5	103.1	3,142,046.4	1,606.1	1.0	0.6
07/17/2021 07:00	9.6	13.8	8.0	104.1	3,148,306.7	1,609.3	1.0	0.6
07/17/2021 08:00	9.5	13.8	7.9	101.9	3,118,516.7	1,571.3	1.0	0.6
07/17/2021 09:00	10.5	13.6	8.5	112.4	3,209,467.9	1,664.0	1.1	0.7
07/17/2021 10:00	9.8	13.8	8.1	104.5	3,105,267.6	1,587.3	1.0	0.6
07/17/2021 11:00	9.6	13.8	8.0	97.7	3,001,619.5	1,512.4	1.0	0.6
07/17/2021 12:00	10.1	13.7	8.3	115.5	3,129,330.3	1,599.6	1.1	0.6
07/17/2021 13:00	10.4	13.1	7.9	128.4	3,260,518.9	2,023.8	1.2	1.0
07/17/2021 14:00	10.3	12.9	7.6	140.7	3,249,382.5	2,111.8	1.4	1.1
07/17/2021 15:00	10.2	12.9	7.5	142.3	3,246,305.1	2,109.8	1.4	1.1
07/17/2021 16:00	10.1	12.9	7.4	141.6	3,224,842.3	2,119.4	1.4	1.1
07/17/2021 17:00	10.0	12.9	7.4	145.3	3,216,943.4	2,137.7	1.5	1.3
07/17/2021 18:00	10.1	12.9	7.4	147.0	3,222,210.4	2,141.2	1.5	1.3
07/17/2021 19:00	10.1	12.9	7.4	147.7	3,220,856.1	2,140.3	1.5	1.3
07/17/2021 20:00	10.1	12.9	7.4	147.0	3,231,385.1	2,123.7	1.5	1.3
07/17/2021 21:00	10.1	13.0	7.5	142.9	3,232,610.9	2,100.9	1.4	1.1
07/17/2021 22:00	10.1	13.0	7.5	137.1	3,268,306.5	2,052.5	1.3	1.0
07/17/2021 23:00	10.1	13.0	7.5	137.2	3,276,109.0	2,057.4	1.3	1.0
Average/Sum#:	9.9	13.3	7.7	122.7	3,169,813.8	1,845.2	1.2	0.9
Minimum:	8.1	12.9	6.7	85.0	2,573,922.4	1,296.9	1.0	0.5
Maximum:	10.5	13.8	8.5	147.7	3,276,109.0	2,141.2	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/18/2021 00:00	10.0	13.1	7.6	129.0	3,264,407.1	1,954.7	1.3	1.0
07/18/2021 01:00	9.2	13.7	7.5	105.7	3,184,303.0	1,627.7	1.0	0.7
07/18/2021 02:00	9.2	13.7	7.5	99.3	3,035,818.2	1,551.8	1.0	0.6
07/18/2021 03:00	10.2	13.1	7.7	122.7	3,304,821.8	1,978.9	1.2	1.0
07/18/2021 04:00	9.8	13.2	7.5	122.6	3,290,337.9	1,946.2	1.2	1.0
07/18/2021 05:00	9.1	13.7	7.5	105.1	3,198,975.4	1,635.2	1.0	0.7
07/18/2021 06:00	9.2	13.7	7.5	106.9	3,199,757.9	1,635.6	1.0	0.7
07/18/2021 07:00	9.5	13.8	7.9	105.6	3,186,846.2	1,629.0	1.0	0.7
07/18/2021 08:00	9.7	13.7	7.9	106.9	3,185,358.3	1,651.5	1.0	0.7
07/18/2021 09:00	9.9	13.8	8.2	116.4	3,170,413.1	1,620.6	1.1	0.6
07/18/2021 10:00	9.8	13.8	8.1	109.1	3,113,753.5	1,568.9	1.1	0.6
07/18/2021 11:00	9.5	13.7	7.8	108.4	3,291,900.6	1,682.7	1.0	0.7
07/18/2021 12:00	10.3	13.1	7.8	126.9	3,281,238.6	2,012.7	1.2	1.0
07/18/2021 13:00	10.1	12.9	7.4	143.1	3,241,731.8	2,130.5	1.4	1.1
07/18/2021 14:00	9.9	12.9	7.3	145.9	3,211,224.9	2,133.9	1.5	1.3
07/18/2021 15:00	9.9	12.9	7.3	144.6	3,208,365.7	2,132.0	1.5	1.3
07/18/2021 16:00	9.8	12.9	7.2	142.7	3,197,530.7	2,124.8	1.4	1.1
07/18/2021 17:00	9.8	12.9	7.2	141.0	3,195,574.4	2,123.5	1.4	1.1
07/18/2021 18:00	9.7	12.9	7.2	137.6	3,200,344.8	2,103.3	1.4	1.1
07/18/2021 19:00	9.9	13.0	7.4	139.0	3,247,870.0	2,087.1	1.4	1.0
07/18/2021 20:00	10.0	13.0	7.5	140.8	3,245,691.4	2,085.7	1.4	1.0
07/18/2021 21:00	9.9	12.9	7.3	143.6	3,261,076.4	2,119.4	1.4	1.1
07/18/2021 22:00	9.9	12.9	7.3	142.1	3,253,075.3	2,114.2	1.4	1.1
07/18/2021 23:00	9.9	12.9	7.3	142.6	3,252,613.7	2,113.9	1.4	1.1
Average/Sum#:	9.8	13.3	7.5	126.2	3,217,626.3	1,906.8	1.2	0.9
Minimum:	9.1	12.9	7.2	99.3	3,035,818.2	1,551.8	1.0	0.6
Maximum:	10.3	13.8	8.2	145.9	3,304,821.8	2,133.9	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/19/2021 00:00	9.8	13.0	7.3	140.3	3,267,788.9	2,099.9	1.4	1.0
07/19/2021 01:00	8.9	13.6	7.2	108.8	3,148,738.1	1,678.5	1.1	0.7
07/19/2021 02:00	9.2	13.7	7.5	105.7	3,237,906.1	1,655.1	1.0	0.7
07/19/2021 03:00	9.4	13.7	7.7	103.8	3,137,155.6	1,603.6	1.0	0.6
07/19/2021 04:00	9.4	13.7	7.7	106.9	3,271,554.9	1,672.3	1.0	0.7
07/19/2021 05:00	10.2	13.1	7.7	127.2	3,357,260.8	2,010.3	1.2	1.0
07/19/2021 06:00	10.0	13.0	7.5	139.4	3,333,805.9	2,020.6	1.3	1.0
07/19/2021 07:00	9.6	13.7	7.9	105.7	3,080,226.7	1,574.5	1.1	0.6
07/19/2021 08:00	9.5	13.7	7.8	103.6	3,121,309.4	1,595.5	1.0	0.6
07/19/2021 09:00	9.3	13.7	7.6	100.3	3,052,642.6	1,560.4	1.0	0.6
07/19/2021 10:00	10.3	13.1	7.8	127.1	3,312,357.1	2,007.6	1.2	1.0
07/19/2021 11:00	10.1	12.9	7.4	147.0	3,225,972.6	2,143.7	1.5	1.3
07/19/2021 12:00	10.0	12.9	7.4	145.6	3,223,263.8	2,141.9	1.5	1.3
07/19/2021 13:00	10.0	12.9	7.4	143.8	3,209,419.1	2,132.7	1.4	1.1
07/19/2021 14:00	10.0	12.9	7.4	144.5	3,216,040.5	2,137.1	1.5	1.3
07/19/2021 15:00	9.9	12.9	7.3	142.7	3,204,453.1	2,129.4	1.4	1.1
07/19/2021 16:00	9.9	12.9	7.3	144.9	3,217,846.3	2,138.3	1.5	1.3
07/19/2021 17:00	10.0	12.9	7.4	146.4	3,251,470.0	2,136.9	1.5	1.3
07/19/2021 18:00	10.1	12.9	7.4	149.7	3,257,404.1	2,140.8	1.5	1.3
07/19/2021 19:00	10.1	12.9	7.4	149.2	3,259,990.8	2,142.5	1.5	1.3
07/19/2021 20:00	10.1	12.9	7.4	148.5	3,256,186.9	2,140.0	1.5	1.3
07/19/2021 21:00	10.0	12.9	7.4	144.6	3,228,950.5	2,122.1	1.4	1.1
07/19/2021 22:00	9.9	13.0	7.4	133.3	3,284,685.2	2,038.8	1.3	1.0
07/19/2021 23:00	9.8	13.1	7.4	129.8	3,265,513.3	2,026.9	1.3	1.0
Average/Sum#:	9.8	13.2	7.5	130.8	3,225,914.3	1,960.4	1.3	1.0
Minimum:	8.9	12.9	7.2	100.3	3,052,642.6	1,560.4	1.0	0.6
Maximum:	10.3	13.7	7.9	149.7	3,357,260.8	2,143.7	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/20/2021 00:00	9.9	13.1	7.5	129.5	3,278,141.1	2,010.8	1.3	1.0
07/20/2021 01:00	9.0	13.7	7.4	105.9	3,182,850.9	1,650.2	1.0	0.7
07/20/2021 02:00	9.2	13.7	7.5	106.6	3,246,709.6	1,659.6	1.0	0.7
07/20/2021 03:00	9.4	13.7	7.7	106.8	3,249,839.7	1,661.2	1.0	0.7
07/20/2021 04:00	10.2	13.1	7.7	124.6	3,342,397.5	2,001.4	1.2	1.0
07/20/2021 05:00	9.9	13.0	7.4	139.7	3,344,739.4	2,100.5	1.3	1.1
07/20/2021 06:00	9.1	13.6	7.4	116.4	3,098,088.2	1,651.5	1.2	0.8
07/20/2021 07:00	9.5	13.7	7.8	105.6	3,165,717.9	1,618.2	1.0	0.6
07/20/2021 08:00	9.5	13.7	7.8	102.4	3,069,271.3	1,568.9	1.0	0.6
07/20/2021 09:00	9.4	13.7	7.7	104.0	3,136,960.0	1,603.5	1.0	0.6
07/20/2021 10:00	9.4	13.7	7.7	105.8	3,206,605.0	1,639.1	1.0	0.7
07/20/2021 11:00	9.5	13.7	7.8	102.2	3,068,880.0	1,568.7	1.0	0.6
07/20/2021 12:00	9.5	13.7	7.8	104.9	3,201,518.6	1,636.5	1.0	0.7
07/20/2021 13:00	10.0	13.1	7.6	122.9	3,304,487.8	1,978.7	1.2	1.0
07/20/2021 14:00	10.0	12.9	7.4	134.1	3,200,760.2	2,080.2	1.3	1.0
07/20/2021 15:00	9.9	12.9	7.3	138.3	3,202,779.3	2,104.9	1.4	1.1
07/20/2021 16:00	9.8	12.9	7.2	141.1	3,202,346.3	2,128.0	1.4	1.1
07/20/2021 17:00	9.7	12.9	7.2	140.9	3,205,807.4	2,130.3	1.4	1.1
07/20/2021 18:00	9.8	12.9	7.2	142.5	3,209,569.6	2,132.8	1.4	1.1
07/20/2021 19:00	9.8	12.9	7.2	142.9	3,203,851.1	2,129.0	1.4	1.1
07/20/2021 20:00	9.7	12.9	7.2	144.0	3,227,327.0	2,144.6	1.4	1.1
07/20/2021 21:00	9.7	12.9	7.2	138.9	3,236,149.8	2,103.2	1.4	1.1
07/20/2021 22:00	9.8	13.0	7.3	139.5	3,285,201.9	2,087.1	1.4	1.0
07/20/2021 23:00	9.7	13.0	7.2	137.0	3,260,331.9	2,071.3	1.4	1.0
Average/Sum#:	9.6	13.3	7.5	124.0	3,213,763.8	1,894.2	1.2	0.9
Minimum:	9.0	12.9	7.2	102.2	3,068,880.0	1,568.7	1.0	0.6
Maximum:	10.2	13.7	7.8	144.0	3,344,739.4	2,144.6	1.4	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/21/2021 00:00	9.6	13.1	7.3	124.7	3,288,956.6	1,969.4	1.2	1.0
07/21/2021 01:00	8.5	13.7	7.0	102.1	3,147,719.8	1,609.0	1.0	0.6
07/21/2021 02:00	8.9	13.7	7.3	102.9	3,199,757.9	1,635.6	1.0	0.7
07/21/2021 03:00	9.7	13.4	7.6	115.4	3,260,671.5	1,809.6	1.1	0.7
07/21/2021 04:00	9.6	13.2	7.4	130.3	3,277,544.0	1,986.5	1.3	1.0
07/21/2021 05:00	8.4	13.8	7.0	101.1	3,123,852.7	1,596.8	1.0	0.6
07/21/2021 06:00	8.3	13.8	6.9	99.6	3,045,012.9	1,556.5	1.0	0.6
07/21/2021 07:00	10.3	13.1	7.8	120.4	3,345,622.1	1,978.9	1.1	0.8
07/21/2021 08:00	9.6	13.2	7.4	119.8	3,283,366.1	1,918.1	1.2	1.0
07/21/2021 09:00	8.8	13.7	7.2	105.8	3,255,317.4	1,664.0	1.0	0.7
07/21/2021 10:00	9.0	13.7	7.4	100.8	3,085,704.4	1,577.3	1.0	0.6
07/21/2021 11:00	10.1	13.1	7.6	125.7	3,304,932.5	2,003.1	1.2	1.0
07/21/2021 12:00	9.9	13.1	7.5	133.0	3,268,147.2	2,052.4	1.3	1.0
07/21/2021 13:00	9.9	13.0	7.4	136.3	3,280,567.6	2,060.2	1.3	1.0
07/21/2021 14:00	9.8	13.0	7.3	135.0	3,222,193.3	2,070.6	1.3	1.0
07/21/2021 15:00	9.9	13.0	7.4	136.9	3,247,714.4	2,087.0	1.4	1.0
07/21/2021 16:00	9.8	12.9	7.2	135.3	3,209,376.8	2,085.8	1.4	1.0
07/21/2021 17:00	10.0	12.9	7.4	140.9	3,234,765.0	2,102.3	1.4	1.1
07/21/2021 18:00	9.9	12.9	7.3	141.4	3,207,914.2	2,131.7	1.4	1.1
07/21/2021 19:00	9.8	12.9	7.2	144.0	3,210,924.0	2,133.7	1.5	1.3
07/21/2021 20:00	9.9	12.9	7.3	146.1	3,223,263.8	2,141.9	1.5	1.3
07/21/2021 21:00	9.9	12.9	7.3	143.3	3,257,075.9	2,116.8	1.4	1.1
07/21/2021 22:00	10.1	13.0	7.5	142.5	3,257,362.6	2,093.2	1.4	1.0
07/21/2021 23:00	10.0	13.0	7.5	135.7	3,294,835.1	2,045.1	1.3	1.0
Average/Sum#:	9.6	13.2	7.3	125.8	3,230,524.9	1,934.4	1.2	0.9
Minimum:	8.3	12.9	6.9	99.6	3,045,012.9	1,556.5	1.0	0.6
Maximum:	10.3	13.8	7.8	146.1	3,345,622.1	2,141.9	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/22/2021 00:00	9.8	13.1	7.4	126.3	3,283,278.5	1,966.0	1.2	1.0
07/22/2021 01:00	9.1	13.7	7.5	105.4	3,201,518.6	1,636.5	1.0	0.7
07/22/2021 02:00	8.9	13.7	7.3	97.7	2,961,814.2	1,535.6	1.0	0.6
07/22/2021 03:00	10.1	13.2	7.7	127.5	3,302,984.8	1,977.8	1.2	1.0
07/22/2021 04:00	9.4	13.3	7.3	126.1	3,291,753.9	1,923.0	1.2	1.0
07/22/2021 05:00	8.4	13.8	7.0	100.5	3,086,095.7	1,577.5	1.0	0.6
07/22/2021 06:00	9.3	13.7	7.6	112.4	3,212,553.9	1,665.6	1.1	0.7
07/22/2021 07:00	10.4	13.2	8.0	123.4	3,305,990.9	1,979.6	1.2	1.0
07/22/2021 08:00	10.0	13.2	7.7	122.0	3,301,682.2	1,928.8	1.2	1.0
07/22/2021 09:00	9.3	13.7	7.6	102.9	3,067,317.7	1,590.3	1.0	0.6
07/22/2021 10:00	9.4	13.7	7.7	104.0	3,155,936.3	1,613.2	1.0	0.6
07/22/2021 11:00	9.6	13.6	7.8	109.5	3,291,753.9	1,730.7	1.0	0.7
07/22/2021 12:00	10.2	13.1	7.7	127.6	3,307,322.9	2,028.7	1.2	1.0
07/22/2021 13:00	10.3	13.0	7.7	145.7	3,275,232.3	2,128.6	1.4	1.1
07/22/2021 14:00	10.1	13.0	7.5	143.2	3,275,258.5	2,104.7	1.4	1.1
07/22/2021 15:00	10.0	13.0	7.5	139.8	3,269,033.9	2,100.7	1.4	1.1
07/22/2021 16:00	9.9	12.9	7.3	144.7	3,241,275.4	2,130.2	1.4	1.1
07/22/2021 17:00	9.9	12.9	7.3	139.3	3,254,921.7	2,115.4	1.4	1.1
07/22/2021 18:00	9.9	12.9	7.3	144.9	3,256,339.0	2,140.1	1.4	1.1
07/22/2021 19:00	9.9	12.9	7.3	142.4	3,246,905.2	2,133.9	1.4	1.1
07/22/2021 20:00	9.8	12.9	7.2	142.2	3,237,014.9	2,127.4	1.4	1.1
07/22/2021 21:00	9.8	13.0	7.3	134.7	3,250,730.2	2,065.2	1.3	1.0
07/22/2021 22:00	9.9	13.0	7.4	132.8	3,271,650.4	2,054.6	1.3	1.0
07/22/2021 23:00	9.8	13.1	7.4	128.3	3,239,177.7	1,986.9	1.3	1.0
Average/Sum#:	9.7	13.2	7.5	126.0	3,232,814.3	1,926.7	1.2	0.9
Minimum:	8.4	12.9	7.0	97.7	2,961,814.2	1,535.6	1.0	0.6
Maximum:	10.4	13.8	8.0	145.7	3,307,322.9	2,140.1	1.4	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/23/2021 00:00	9.0	13.7	7.4	106.2	3,227,537.6	1,649.8	1.0	0.7
07/23/2021 01:00	9.3	13.7	7.6	103.6	3,171,782.5	1,621.3	1.0	0.6
07/23/2021 02:00	10.2	13.1	7.7	124.4	3,348,327.2	1,980.5	1.2	1.0
07/23/2021 03:00	9.8	13.2	7.5	120.1	3,301,179.5	1,904.4	1.1	0.8
07/23/2021 04:00	8.9	13.7	7.3	107.5	3,239,275.6	1,655.8	1.0	0.7
07/23/2021 05:00	9.2	13.7	7.5	106.2	3,175,108.3	1,623.0	1.0	0.6
07/23/2021 06:00	9.1	13.7	7.5	106.4	3,198,388.5	1,634.9	1.0	0.7
07/23/2021 07:00	9.5	13.7	7.8	106.8	3,151,045.5	1,610.7	1.0	0.6
07/23/2021 08:00	9.4	13.7	7.7	108.0	3,224,603.2	1,648.3	1.0	0.7
07/23/2021 09:00	9.5	13.7	7.8	107.4	3,193,693.3	1,632.5	1.0	0.7
07/23/2021 10:00	9.4	13.7	7.7	108.9	3,271,554.9	1,672.3	1.0	0.7
07/23/2021 11:00	9.4	13.6	7.6	109.4	3,246,500.2	1,683.2	1.0	0.7
07/23/2021 12:00	10.2	13.0	7.6	130.9	3,275,949.8	2,057.3	1.3	1.0
07/23/2021 13:00	10.0	12.9	7.4	145.6	3,231,089.1	2,147.1	1.5	1.3
07/23/2021 14:00	9.8	12.9	7.2	145.0	3,226,725.0	2,144.2	1.5	1.3
07/23/2021 15:00	9.8	12.9	7.2	146.9	3,231,089.1	2,147.1	1.5	1.3
07/23/2021 16:00	9.8	12.9	7.2	150.1	3,231,540.6	2,147.4	1.5	1.3
07/23/2021 17:00	9.8	12.9	7.2	147.4	3,236,356.1	2,150.6	1.5	1.3
07/23/2021 18:00	9.7	12.9	7.2	145.0	3,234,851.3	2,149.6	1.5	1.3
07/23/2021 19:00	9.8	12.9	7.2	147.0	3,235,603.7	2,150.1	1.5	1.3
07/23/2021 20:00	9.9	12.9	7.3	147.5	3,260,447.3	2,142.8	1.5	1.3
07/23/2021 21:00	9.9	13.0	7.4	142.8	3,265,143.5	2,098.2	1.4	1.0
07/23/2021 22:00	9.9	13.1	7.5	133.5	3,288,229.6	2,041.0	1.3	1.0
07/23/2021 23:00	9.9	13.1	7.5	133.6	3,282,429.7	2,037.4	1.3	1.0
Average/Sum#:	9.6	13.3	7.5	126.3	3,239,518.8	1,905.4	1.2	1.0
Minimum:	8.9	12.9	7.2	103.6	3,151,045.5	1,610.7	1.0	0.6
Maximum:	10.2	13.7	7.8	150.1	3,348,327.2	2,150.6	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/24/2021 00:00	9.9	13.1	7.5	132.4	3,300,475.8	2,024.5	1.3	1.0
07/24/2021 01:00	9.7	13.2	7.4	121.8	3,259,230.0	1,904.0	1.2	1.0
07/24/2021 02:00	9.1	13.7	7.5	105.2	3,186,259.3	1,628.7	1.0	0.7
07/24/2021 03:00	9.3	13.7	7.6	107.8	3,316,745.9	1,695.4	1.0	0.7
07/24/2021 04:00	10.1	13.2	7.7	122.8	3,339,197.7	1,975.1	1.2	1.0
07/24/2021 05:00	9.7	13.2	7.4	121.4	3,322,500.9	1,916.7	1.2	1.0
07/24/2021 06:00	9.0	13.7	7.4	106.5	3,174,325.7	1,622.6	1.0	0.6
07/24/2021 07:00	9.6	13.7	7.9	105.9	3,095,877.3	1,582.5	1.1	0.6
07/24/2021 08:00	9.5	13.7	7.8	105.3	3,117,983.7	1,593.8	1.0	0.6
07/24/2021 09:00	9.4	13.7	7.7	106.6	3,174,521.4	1,622.7	1.0	0.6
07/24/2021 10:00	9.5	13.7	7.8	104.8	3,106,245.8	1,587.8	1.0	0.6
07/24/2021 11:00	10.3	13.7	8.4	114.5	3,157,110.1	1,613.8	1.1	0.6
07/24/2021 12:00	10.1	13.1	7.6	124.7	3,293,053.2	1,995.9	1.2	1.0
07/24/2021 13:00	10.1	13.0	7.5	134.3	3,227,484.3	2,074.0	1.3	1.0
07/24/2021 14:00	9.9	13.0	7.4	134.0	3,200,990.1	2,033.6	1.3	1.0
07/24/2021 15:00	9.2	13.7	7.5	107.1	3,224,603.2	1,648.3	1.0	0.7
07/24/2021 16:00	9.4	13.7	7.7	107.7	3,267,642.2	1,670.3	1.0	0.7
07/24/2021 17:00	10.1	13.1	7.6	124.6	3,252,872.0	1,995.3	1.2	1.0
07/24/2021 18:00	10.0	13.0	7.5	134.7	3,206,607.2	2,084.0	1.3	1.0
07/24/2021 19:00	10.0	12.9	7.4	146.4	3,216,943.4	2,137.7	1.5	1.3
07/24/2021 20:00	9.9	12.9	7.3	148.1	3,223,414.3	2,142.0	1.5	1.3
07/24/2021 21:00	9.9	12.9	7.3	144.1	3,216,473.6	2,113.9	1.4	1.1
07/24/2021 22:00	9.8	13.0	7.3	133.9	3,243,961.7	2,060.9	1.3	1.0
07/24/2021 23:00	9.9	13.0	7.4	136.8	3,263,637.4	2,073.4	1.3	1.0
Average/Sum#:	9.7	13.3	7.6	122.1	3,224,506.5	1,866.5	1.2	0.9
Minimum:	9.0	12.9	7.3	104.8	3,095,877.3	1,582.5	1.0	0.6
Maximum:	10.3	13.7	8.4	148.1	3,339,197.7	2,142.0	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/25/2021 00:00	9.7	13.2	7.4	122.6	3,248,917.1	1,921.7	1.2	1.0
07/25/2021 01:00	9.1	13.7	7.5	106.4	3,165,913.5	1,618.3	1.0	0.6
07/25/2021 02:00	9.1	13.7	7.5	102.0	3,071,227.6	1,569.9	1.0	0.6
07/25/2021 03:00	10.2	13.2	7.8	127.8	3,277,544.0	1,986.5	1.2	1.0
07/25/2021 04:00	9.6	13.3	7.5	123.2	3,262,653.6	1,906.0	1.2	1.0
07/25/2021 05:00	9.0	13.7	7.4	107.4	3,221,277.4	1,646.6	1.0	0.7
07/25/2021 06:00	9.1	13.7	7.5	106.5	3,199,171.0	1,635.3	1.0	0.7
07/25/2021 07:00	9.5	13.7	7.8	107.2	3,219,908.0	1,645.9	1.0	0.7
07/25/2021 08:00	9.4	13.7	7.7	107.9	3,245,144.5	1,658.8	1.0	0.7
07/25/2021 09:00	9.5	13.7	7.8	107.9	3,232,819.7	1,652.5	1.0	0.7
07/25/2021 10:00	9.5	13.7	7.8	107.8	3,230,863.4	1,651.5	1.0	0.7
07/25/2021 11:00	9.0	13.7	7.4	97.7	2,950,131.4	1,508.0	1.0	0.6
07/25/2021 12:00	10.3	13.1	7.8	128.7	3,275,018.7	2,032.8	1.2	1.0
07/25/2021 13:00	9.9	13.0	7.4	132.5	3,180,332.5	2,043.7	1.3	1.0
07/25/2021 14:00	9.2	13.6	7.4	107.6	3,174,750.1	1,646.0	1.1	0.7
07/25/2021 15:00	9.6	13.6	7.8	109.0	3,192,851.0	1,678.7	1.1	0.7
07/25/2021 16:00	9.6	13.5	7.7	109.3	3,193,421.6	1,679.0	1.1	0.7
07/25/2021 17:00	10.1	13.0	7.5	128.0	3,185,092.2	2,023.5	1.3	1.0
07/25/2021 18:00	9.9	12.9	7.3	137.9	3,179,923.8	2,113.1	1.4	1.1
07/25/2021 19:00	9.8	12.9	7.2	137.1	3,208,761.4	2,085.4	1.4	1.0
07/25/2021 20:00	9.8	13.0	7.3	133.3	3,230,267.5	2,052.2	1.3	1.0
07/25/2021 21:00	9.7	13.0	7.2	128.3	3,214,484.9	2,018.7	1.3	1.0
07/25/2021 22:00	9.8	13.1	7.4	127.1	3,233,452.6	2,007.0	1.3	1.0
07/25/2021 23:00	9.9	13.0	7.4	132.5	3,266,318.8	2,027.4	1.3	1.0
Average/Sum#:	9.6	13.4	7.5	118.2	3,202,510.3	1,825.4	1.2	0.8
Minimum:	9.0	12.9	7.2	97.7	2,950,131.4	1,508.0	1.0	0.6
Maximum:	10.3	13.7	7.8	137.9	3,277,544.0	2,113.1	1.4	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/26/2021 00:00	9.6	13.2	7.4	120.8	3,242,154.5	1,917.7	1.2	1.0
07/26/2021 01:00	9.0	13.7	7.4	102.7	3,102,724.4	1,586.0	1.0	0.6
07/26/2021 02:00	9.3	13.7	7.6	103.5	3,147,328.5	1,608.8	1.0	0.6
07/26/2021 03:00	10.0	13.2	7.7	130.2	3,293,298.6	1,972.0	1.3	1.0
07/26/2021 04:00	9.6	13.1	7.3	136.4	3,249,611.5	1,993.3	1.3	1.0
07/26/2021 05:00	8.5	13.7	7.0	108.2	3,201,367.0	1,659.8	1.1	0.7
07/26/2021 06:00	8.8	13.8	7.3	103.1	3,104,876.3	1,587.1	1.0	0.6
07/26/2021 07:00	9.1	13.8	7.6	98.2	2,943,675.5	1,504.7	1.0	0.6
07/26/2021 08:00	9.3	13.7	7.6	106.0	3,229,298.3	1,650.7	1.0	0.7
07/26/2021 09:00	9.2	13.7	7.5	100.2	2,999,821.9	1,533.4	1.0	0.6
07/26/2021 10:00	9.3	13.7	7.6	106.1	3,167,806.5	1,642.4	1.0	0.7
07/26/2021 11:00	10.2	13.1	7.7	125.5	3,301,137.7	2,000.8	1.2	1.0
07/26/2021 12:00	10.0	12.9	7.4	142.2	3,228,494.1	2,121.8	1.4	1.1
07/26/2021 13:00	9.9	12.9	7.3	141.5	3,260,768.7	2,119.2	1.4	1.1
07/26/2021 14:00	9.9	13.0	7.4	139.9	3,261,097.4	2,095.6	1.4	1.0
07/26/2021 15:00	9.9	12.9	7.3	145.4	3,221,759.0	2,140.9	1.5	1.3
07/26/2021 16:00	9.9	12.9	7.3	145.4	3,223,414.3	2,142.0	1.5	1.3
07/26/2021 17:00	9.8	12.9	7.2	141.8	3,232,450.2	2,124.4	1.4	1.1
07/26/2021 18:00	9.8	12.9	7.2	143.4	3,236,406.3	2,127.0	1.4	1.1
07/26/2021 19:00	9.9	12.9	7.3	143.5	3,235,341.2	2,126.3	1.4	1.1
07/26/2021 20:00	10.0	12.9	7.4	145.5	3,235,341.2	2,126.3	1.5	1.3
07/26/2021 21:00	10.4	12.9	7.7	155.5	3,274,598.0	2,152.1	1.5	1.3
07/26/2021 22:00	10.2	13.0	7.6	145.9	3,276,036.6	2,105.2	1.4	1.1
07/26/2021 23:00	9.8	13.1	7.4	132.1	3,261,209.9	1,976.6	1.3	1.0
Average/Sum#:	9.6	13.2	7.4	127.6	3,205,417.4	1,917.3	1.3	1.0
Minimum:	8.5	12.9	7.0	98.2	2,943,675.5	1,504.7	1.0	0.6
Maximum:	10.4	13.8	7.7	155.5	3,301,137.7	2,152.1	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/27/2021 00:00	9.3	13.7	7.6	105.0	3,113,288.5	1,591.4	1.0	0.6
07/27/2021 01:00	9.3	13.7	7.6	107.1	3,247,100.8	1,659.8	1.0	0.7
07/27/2021 02:00	10.2	13.3	7.9	120.1	3,314,353.7	1,912.0	1.1	0.8
07/27/2021 03:00	10.0	13.3	7.8	121.0	3,266,683.9	1,884.5	1.2	0.9
07/27/2021 04:00	9.3	13.7	7.6	106.4	3,158,479.5	1,614.5	1.0	0.6
07/27/2021 05:00	9.4	13.7	7.7	109.9	3,318,506.5	1,696.3	1.0	0.7
07/27/2021 06:00	10.3	13.2	7.9	134.2	3,331,375.3	1,994.8	1.3	1.0
07/27/2021 07:00	10.4	13.2	8.0	126.1	3,311,439.3	1,934.5	1.2	1.0
07/27/2021 08:00	9.3	13.7	7.6	107.5	3,206,996.3	1,639.3	1.0	0.7
07/27/2021 09:00	9.4	13.7	7.7	107.5	3,235,167.3	1,653.7	1.0	0.7
07/27/2021 10:00	9.3	13.7	7.6	107.6	3,241,623.1	1,657.0	1.0	0.7
07/27/2021 11:00	9.4	13.7	7.7	108.1	3,263,729.6	1,668.3	1.0	0.7
07/27/2021 12:00	10.4	13.2	8.0	128.3	3,327,206.3	2,016.6	1.2	1.0
07/27/2021 13:00	10.4	13.0	7.8	149.5	3,285,387.6	2,135.2	1.5	1.3
07/27/2021 14:00	10.3	13.0	7.7	151.5	3,321,009.7	2,134.1	1.5	1.3
07/27/2021 15:00	10.2	13.0	7.6	150.3	3,314,473.9	2,129.9	1.5	1.3
07/27/2021 16:00	10.2	13.0	7.6	145.3	3,301,572.0	2,097.5	1.4	1.0
07/27/2021 17:00	10.3	13.0	7.7	150.6	3,283,387.3	2,133.9	1.5	1.3
07/27/2021 18:00	10.2	13.0	7.6	151.9	3,298,774.1	2,143.9	1.5	1.3
07/27/2021 19:00	10.2	13.0	7.6	154.2	3,302,928.5	2,146.6	1.5	1.3
07/27/2021 20:00	10.2	13.0	7.6	153.2	3,304,928.8	2,147.9	1.5	1.3
07/27/2021 21:00	10.2	13.0	7.6	154.4	3,302,620.8	2,146.4	1.5	1.3
07/27/2021 22:00	10.1	13.0	7.5	148.9	3,312,139.6	2,128.4	1.4	1.1
07/27/2021 23:00	10.1	13.0	7.5	148.9	3,336,515.9	2,119.7	1.4	1.1
Average/Sum#:	9.9	13.3	7.7	131.1	3,279,153.7	1,932.8	1.3	1.0
Minimum:	9.3	13.0	7.5	105.0	3,113,288.5	1,591.4	1.0	0.6
Maximum:	10.4	13.7	8.0	154.4	3,336,515.9	2,147.9	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/28/2021 00:00	10.1	13.0	7.5	144.6	3,318,465.6	2,084.0	1.4	1.0
07/28/2021 01:00	9.8	13.3	7.6	124.1	3,312,273.6	1,910.8	1.2	1.0
07/28/2021 02:00	9.1	13.7	7.5	107.1	3,225,581.3	1,648.8	1.0	0.7
07/28/2021 03:00	9.4	13.7	7.7	106.2	3,206,213.7	1,638.9	1.0	0.7
07/28/2021 04:00	10.3	13.2	7.9	128.2	3,341,896.5	2,001.1	1.2	1.0
07/28/2021 05:00	10.3	13.0	7.7	147.8	3,335,886.3	2,119.3	1.4	1.1
07/28/2021 06:00	10.1	13.0	7.5	146.1	3,305,790.5	2,051.9	1.4	1.0
07/28/2021 07:00	9.5	13.7	7.8	108.8	3,179,412.2	1,625.2	1.1	0.7
07/28/2021 08:00	9.5	13.7	7.8	108.3	3,257,469.3	1,665.1	1.0	0.7
07/28/2021 09:00	10.4	13.0	7.8	129.9	3,252,382.9	2,042.5	1.3	1.0
07/28/2021 10:00	10.2	12.9	7.5	144.8	3,212,729.8	2,134.9	1.5	1.3
07/28/2021 11:00	10.1	12.9	7.4	146.0	3,219,351.2	2,139.3	1.5	1.3
07/28/2021 12:00	10.0	12.9	7.4	145.4	3,212,278.3	2,134.6	1.5	1.3
07/28/2021 13:00	10.0	12.9	7.4	146.5	3,217,394.9	2,138.0	1.5	1.3
07/28/2021 14:00	10.0	12.9	7.4	146.9	3,214,987.1	2,136.4	1.5	1.3
07/28/2021 15:00	10.0	12.9	7.4	144.5	3,192,564.6	2,121.5	1.5	1.3
07/28/2021 16:00	10.0	12.9	7.4	144.6	3,203,851.1	2,129.0	1.5	1.3
07/28/2021 17:00	10.0	12.9	7.4	145.4	3,197,831.7	2,125.0	1.5	1.3
07/28/2021 18:00	9.9	12.9	7.3	142.8	3,181,428.7	2,114.1	1.5	1.3
07/28/2021 19:00	10.0	12.9	7.4	140.1	3,190,302.3	2,096.7	1.4	1.0
07/28/2021 20:00	9.9	13.0	7.4	139.1	3,204,145.3	2,082.4	1.4	1.0
07/28/2021 21:00	10.1	12.9	7.4	146.8	3,207,312.3	2,131.3	1.5	1.3
07/28/2021 22:00	9.8	13.0	7.3	145.2	3,246,305.1	2,109.8	1.4	1.1
07/28/2021 23:00	10.1	12.9	7.4	144.1	3,226,668.2	2,120.6	1.4	1.1
Average/Sum#:	9.9	13.1	7.5	136.4	3,235,938.4	2,020.9	1.4	1.1
Minimum:	9.1	12.9	7.3	106.2	3,179,412.2	1,625.2	1.0	0.7
Maximum:	10.4	13.7	7.9	147.8	3,341,896.5	2,139.3	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/29/2021 00:00	10.3	12.9	7.6	149.7	3,231,992.0	2,147.7	1.5	1.3
07/29/2021 01:00	10.2	12.9	7.5	146.0	3,227,581.1	2,121.2	1.5	1.3
07/29/2021 02:00	9.4	13.6	7.6	107.8	2,971,088.1	1,583.8	1.1	0.6
07/29/2021 03:00	9.3	13.7	7.6	109.6	3,303,442.9	1,688.6	1.0	0.7
07/29/2021 04:00	10.2	13.1	7.7	127.1	3,314,007.0	2,008.6	1.2	1.0
07/29/2021 05:00	10.1	13.0	7.5	143.7	3,295,177.4	2,117.5	1.4	1.1
07/29/2021 06:00	9.9	13.0	7.4	136.2	3,304,225.4	2,026.8	1.3	1.0
07/29/2021 07:00	9.5	13.7	7.8	108.8	3,163,957.2	1,617.3	1.1	0.6
07/29/2021 08:00	9.5	13.7	7.8	107.1	3,174,557.2	1,645.9	1.0	0.7
07/29/2021 09:00	9.9	13.1	7.5	121.5	3,242,401.0	1,965.2	1.2	1.0
07/29/2021 10:00	10.1	12.9	7.4	142.7	3,207,763.8	2,131.6	1.4	1.1
07/29/2021 11:00	9.9	12.9	7.3	142.9	3,208,817.2	2,132.3	1.4	1.1
07/29/2021 12:00	9.9	12.9	7.3	141.7	3,206,108.4	2,130.5	1.4	1.1
07/29/2021 13:00	9.9	12.9	7.3	141.4	3,166,645.0	2,127.4	1.4	1.1
07/29/2021 14:00	9.9	12.9	7.3	139.9	3,151,908.8	2,117.5	1.4	1.1
07/29/2021 15:00	9.9	12.8	7.2	139.6	3,141,638.2	2,110.6	1.4	1.1
07/29/2021 16:00	9.9	12.9	7.3	138.9	3,136,428.4	2,107.1	1.4	1.1
07/29/2021 17:00	9.9	12.9	7.3	138.7	3,140,447.4	2,109.8	1.4	1.1
07/29/2021 18:00	9.9	12.9	7.3	139.4	3,141,191.6	2,110.3	1.4	1.1
07/29/2021 19:00	10.0	12.9	7.4	138.9	3,143,870.9	2,112.1	1.4	1.1
07/29/2021 20:00	9.9	12.9	7.3	139.1	3,164,122.8	2,102.6	1.4	1.1
07/29/2021 21:00	9.9	12.9	7.3	140.9	3,189,254.0	2,119.3	1.4	1.1
07/29/2021 22:00	9.9	12.9	7.3	141.8	3,222,559.9	2,117.9	1.4	1.1
07/29/2021 23:00	9.9	12.9	7.3	141.7	3,214,799.8	2,112.8	1.4	1.1
Average/Sum#:	9.9	13.1	7.4	134.4	3,194,332.7	2,023.5	1.3	1.0
Minimum:	9.3	12.8	7.2	107.1	2,971,088.1	1,583.8	1.0	0.6
Maximum:	10.3	13.7	7.8	149.7	3,314,007.0	2,147.7	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/30/2021 00:00	9.9	12.9	7.3	138.2	3,232,764.8	2,101.0	1.4	1.1
07/30/2021 01:00	9.8	13.0	7.3	131.7	3,218,776.9	2,044.9	1.3	1.0
07/30/2021 02:00	9.1	13.7	7.5	106.6	3,197,702.4	1,657.9	1.0	0.7
07/30/2021 03:00	9.4	13.6	7.6	108.4	3,276,203.2	1,698.6	1.0	0.7
07/30/2021 04:00	10.1	13.0	7.5	127.6	3,266,963.3	2,027.8	1.2	1.0
07/30/2021 05:00	10.0	12.9	7.4	145.4	3,264,251.3	2,145.3	1.4	1.1
07/30/2021 06:00	9.9	12.9	7.3	151.2	3,237,775.7	2,127.9	1.5	1.3
07/30/2021 07:00	10.4	12.9	7.7	147.8	3,249,796.2	2,135.8	1.5	1.3
07/30/2021 08:00	9.9	12.9	7.3	139.1	3,225,298.7	2,119.7	1.4	1.1
07/30/2021 09:00	9.9	12.9	7.3	144.1	3,221,909.5	2,141.0	1.4	1.1
07/30/2021 10:00	9.9	12.9	7.3	144.2	3,216,191.0	2,137.2	1.4	1.1
07/30/2021 11:00	10.0	12.8	7.3	144.5	3,190,758.8	2,143.6	1.5	1.3
07/30/2021 12:00	10.0	12.8	7.3	144.9	3,187,335.3	2,141.3	1.5	1.3
07/30/2021 13:00	10.0	12.8	7.3	143.5	3,145,994.8	2,136.5	1.5	1.3
07/30/2021 14:00	10.1	12.8	7.4	143.4	3,134,951.1	2,129.0	1.5	1.3
07/30/2021 15:00	10.0	12.8	7.3	142.9	3,162,328.4	2,124.5	1.5	1.3
07/30/2021 16:00	10.0	12.8	7.3	142.2	3,155,927.8	2,120.2	1.5	1.3
07/30/2021 17:00	10.1	12.8	7.4	142.7	3,153,843.9	2,118.8	1.5	1.3
07/30/2021 18:00	10.0	12.9	7.4	142.0	3,151,760.0	2,117.4	1.5	1.3
07/30/2021 19:00	10.1	12.8	7.4	143.8	3,137,601.6	2,130.8	1.5	1.3
07/30/2021 20:00	9.9	12.8	7.2	144.7	3,149,234.3	2,138.7	1.5	1.3
07/30/2021 21:00	10.0	12.9	7.4	143.9	3,166,645.0	2,127.4	1.5	1.3
07/30/2021 22:00	10.1	12.9	7.4	147.4	3,175,724.9	2,133.5	1.5	1.3
07/30/2021 23:00	10.1	12.9	7.4	147.1	3,193,289.3	2,145.3	1.5	1.3
Average/Sum#:	9.9	12.9	7.4	139.9	3,196,376.2	2,085.2	1.4	1.2
Minimum:	9.1	12.8	7.2	106.6	3,134,951.1	1,657.9	1.0	0.7
Maximum:	10.4	13.7	7.7	151.2	3,276,203.2	2,145.3	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/31/2021 00:00	10.3	12.9	7.6	157.2	3,232,288.1	2,171.5	1.6	1.3
07/31/2021 01:00	10.3	12.9	7.6	155.9	3,261,186.4	2,167.1	1.5	1.3
07/31/2021 02:00	10.2	12.9	7.5	149.7	3,285,233.7	2,135.1	1.5	1.3
07/31/2021 03:00	9.2	13.6	7.4	110.0	3,118,160.6	1,662.2	1.1	0.7
07/31/2021 04:00	9.5	13.6	7.7	110.3	3,307,159.9	1,738.8	1.0	0.7
07/31/2021 05:00	10.0	13.3	7.8	117.3	3,310,320.1	1,885.5	1.1	0.8
07/31/2021 06:00	10.0	13.0	7.5	140.8	3,304,179.4	2,050.9	1.4	1.0
07/31/2021 07:00	9.5	13.7	7.8	110.0	3,234,776.0	1,653.5	1.1	0.7
07/31/2021 08:00	9.0	13.7	7.4	98.9	3,045,599.8	1,556.8	1.0	0.6
07/31/2021 09:00	10.3	13.1	7.8	124.3	3,286,453.5	1,991.9	1.2	1.0
07/31/2021 10:00	10.0	13.0	7.5	131.5	3,251,746.0	2,042.1	1.3	1.0
07/31/2021 11:00	10.0	13.0	7.5	134.7	3,268,943.4	2,052.9	1.3	1.0
07/31/2021 12:00	10.1	13.0	7.5	134.3	3,248,211.7	2,063.6	1.3	1.0
07/31/2021 13:00	10.0	13.0	7.5	134.2	3,235,147.1	2,055.3	1.3	1.0
07/31/2021 14:00	10.1	13.0	7.5	133.6	3,241,758.1	2,059.5	1.3	1.0
07/31/2021 15:00	10.1	13.0	7.5	135.5	3,217,680.5	2,067.7	1.3	1.0
07/31/2021 16:00	10.1	12.9	7.4	135.0	3,187,373.7	2,071.5	1.4	1.0
07/31/2021 17:00	10.2	12.9	7.5	139.9	3,196,845.1	2,101.0	1.4	1.1
07/31/2021 18:00	10.2	12.9	7.5	144.5	3,226,363.8	2,120.4	1.4	1.1
07/31/2021 19:00	10.1	12.9	7.4	142.4	3,216,169.2	2,113.7	1.4	1.1
07/31/2021 20:00	10.1	12.9	7.4	145.5	3,233,195.9	2,148.5	1.5	1.3
07/31/2021 21:00	10.1	12.9	7.4	147.6	3,254,665.3	2,139.0	1.5	1.3
07/31/2021 22:00	9.9	12.9	7.3	143.6	3,252,306.0	2,113.7	1.4	1.1
07/31/2021 23:00	10.0	13.0	7.5	138.5	3,276,586.7	2,057.7	1.4	1.0
Average/Sum#:	10.0	13.1	7.5	134.0	3,237,181.3	2,009.2	1.3	1.0
Minimum:	9.0	12.9	7.3	98.9	3,045,599.8	1,556.8	1.0	0.6
Maximum:	10.3	13.7	7.8	157.2	3,310,320.1	2,171.5	1.6	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/01/2021 00:00	9.9	13.2	7.6	124.6	3,256,186.9	1,926.0	1.2	1.0
08/01/2021 01:00	9.2	13.7	7.5	104.9	3,173,934.5	1,622.4	1.0	0.6
08/01/2021 02:00	9.5	13.6	7.7	106.6	3,212,939.6	1,665.8	1.0	0.7
08/01/2021 03:00	10.1	13.2	7.7	124.7	3,319,351.1	1,987.6	1.2	1.0
08/01/2021 04:00	9.7	13.2	7.4	122.6	3,297,438.7	1,950.4	1.2	1.0
08/01/2021 05:00	9.1	13.7	7.5	106.1	3,233,015.3	1,652.6	1.0	0.7
08/01/2021 06:00	9.2	13.7	7.5	103.5	3,135,199.3	1,602.6	1.0	0.6
08/01/2021 07:00	9.7	13.7	7.9	105.2	3,117,788.1	1,593.7	1.0	0.6
08/01/2021 08:00	8.7	13.8	7.2	88.5	2,725,154.5	1,393.0	1.0	0.6
08/01/2021 09:00	8.9	13.7	7.3	97.7	3,011,755.5	1,539.5	1.0	0.6
08/01/2021 10:00	10.3	13.1	7.8	125.5	3,301,137.7	2,000.8	1.2	1.0
08/01/2021 11:00	9.9	13.1	7.5	123.1	3,243,060.9	1,965.6	1.2	1.0
08/01/2021 12:00	9.4	13.7	7.7	103.6	3,126,787.1	1,598.3	1.0	0.6
08/01/2021 13:00	9.6	13.7	7.9	105.0	3,168,963.8	1,643.0	1.0	0.7
08/01/2021 14:00	9.6	13.7	7.9	106.2	3,191,530.3	1,654.7	1.0	0.7
08/01/2021 15:00	9.6	13.6	7.8	107.1	3,227,984.0	1,673.6	1.0	0.7
08/01/2021 16:00	9.9	13.4	7.8	115.1	3,169,595.0	1,782.2	1.1	0.7
08/01/2021 17:00	10.4	12.9	7.7	142.3	3,216,943.4	2,137.7	1.4	1.1
08/01/2021 18:00	10.4	12.9	7.7	153.1	3,230,353.0	2,170.2	1.5	1.3
08/01/2021 19:00	10.3	12.9	7.6	151.5	3,253,361.1	2,161.9	1.5	1.3
08/01/2021 20:00	10.4	12.9	7.7	156.3	3,243,005.3	2,178.7	1.6	1.3
08/01/2021 21:00	10.5	12.9	7.7	159.6	3,252,978.3	2,185.4	1.6	1.3
08/01/2021 22:00	10.5	12.9	7.7	159.7	3,267,958.2	2,171.6	1.6	1.3
08/01/2021 23:00	10.4	12.9	7.7	154.1	3,268,816.0	2,148.3	1.5	1.3
Average/Sum#:	9.8	13.3	7.6	122.8	3,193,551.6	1,850.2	1.2	0.9
Minimum:	8.7	12.9	7.2	88.5	2,725,154.5	1,393.0	1.0	0.6
Maximum:	10.5	13.8	7.9	159.7	3,319,351.1	2,185.4	1.6	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/02/2021 00:00	10.1	12.9	7.4	153.3	3,294,530.8	2,165.2	1.5	1.3
08/02/2021 01:00	10.1	13.0	7.5	150.2	3,323,810.8	2,135.9	1.5	1.3
08/02/2021 02:00	9.2	13.6	7.4	107.7	3,090,524.6	1,624.9	1.1	0.6
08/02/2021 03:00	9.4	13.7	7.7	106.4	3,211,396.6	1,665.0	1.0	0.7
08/02/2021 04:00	10.0	13.1	7.6	128.5	3,351,954.9	2,031.6	1.2	1.0
08/02/2021 05:00	10.3	13.0	7.7	154.6	3,339,549.1	2,170.4	1.5	1.3
08/02/2021 06:00	9.7	13.0	7.2	136.7	3,391,017.0	2,104.8	1.3	1.1
08/02/2021 07:00	9.6	13.6	7.8	112.4	3,126,977.4	1,666.9	1.1	0.7
08/02/2021 08:00	9.0	13.7	7.4	102.3	3,029,513.9	1,570.7	1.1	0.6
08/02/2021 09:00	10.3	13.1	7.8	127.1	3,362,437.9	2,013.4	1.2	1.0
08/02/2021 10:00	10.2	13.0	7.6	145.0	3,286,618.5	2,112.0	1.4	1.1
08/02/2021 11:00	10.0	13.0	7.5	146.6	3,271,539.5	2,126.2	1.4	1.1
08/02/2021 12:00	10.2	13.0	7.6	145.7	3,285,529.2	2,111.3	1.4	1.1
08/02/2021 13:00	10.3	13.0	7.7	146.1	3,282,261.3	2,109.2	1.4	1.1
08/02/2021 14:00	10.3	13.0	7.7	146.1	3,271,679.3	2,102.4	1.4	1.1
08/02/2021 15:00	10.3	13.0	7.7	143.8	3,268,567.0	2,100.4	1.4	1.1
08/02/2021 16:00	10.3	13.0	7.7	143.0	3,268,411.4	2,100.3	1.4	1.1
08/02/2021 17:00	10.3	13.0	7.7	145.0	3,254,921.7	2,115.4	1.4	1.1
08/02/2021 18:00	10.4	12.9	7.7	153.5	3,255,317.4	2,163.2	1.5	1.3
08/02/2021 19:00	10.4	12.9	7.7	156.8	3,237,349.0	2,174.9	1.6	1.3
08/02/2021 20:00	10.5	12.9	7.7	161.9	3,284,060.3	2,182.3	1.6	1.3
08/02/2021 21:00	10.5	12.9	7.7	163.9	3,291,735.1	2,187.4	1.6	1.3
08/02/2021 22:00	10.4	12.9	7.7	163.9	3,295,045.7	2,189.6	1.6	1.3
08/02/2021 23:00	10.4	12.9	7.7	163.1	3,299,861.3	2,192.8	1.6	1.3
Average/Sum#:	10.1	13.1	7.6	141.8	3,265,608.7	2,046.5	1.4	1.1
Minimum:	9.0	12.9	7.2	102.3	3,029,513.9	1,570.7	1.0	0.6
Maximum:	10.5	13.7	7.8	163.9	3,391,017.0	2,192.8	1.6	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/03/2021 00:00	10.3	13.0	7.7	155.3	3,308,929.4	2,150.5	1.5	1.3
08/03/2021 01:00	10.3	13.0	7.7	153.2	3,296,158.3	2,142.2	1.5	1.3
08/03/2021 02:00	9.3	13.6	7.5	114.0	3,200,513.6	1,706.1	1.1	0.7
08/03/2021 03:00	9.3	13.6	7.5	110.0	3,362,611.9	1,743.4	1.0	0.7
08/03/2021 04:00	10.2	13.2	7.8	119.2	3,345,035.7	1,929.7	1.1	0.8
08/03/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/03/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/03/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/03/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/03/2021 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/03/2021 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/03/2021 11:00	38.8	16.2	48.7	171.1	1,842,353.5	578.5	2.8	0.6
08/03/2021 12:00	7.7	13.9	6.5	108.0	2,628,690.7	1,305.3	1.3	0.7
08/03/2021 13:00	9.5	13.6	7.7	106.8	3,242,449.8	1,681.1	1.0	0.7
08/03/2021 14:00	10.5	13.1	7.9	132.6	3,251,905.2	2,042.2	1.3	1.0
08/03/2021 15:00	10.5	13.0	7.8	151.7	3,263,898.5	2,097.4	1.5	1.3
08/03/2021 16:00	10.4	13.0	7.8	146.4	3,235,072.8	2,102.5	1.5	1.3
08/03/2021 17:00	10.3	13.0	7.7	145.0	3,254,152.4	2,114.9	1.4	1.1
08/03/2021 18:00	10.4	12.9	7.7	155.9	3,246,890.2	2,157.6	1.6	1.3
08/03/2021 19:00	10.3	12.9	7.6	155.1	3,223,654.8	2,165.7	1.6	1.3
08/03/2021 20:00	10.3	12.9	7.6	159.3	3,236,307.1	2,174.2	1.6	1.3
08/03/2021 21:00	10.3	12.9	7.6	161.0	3,233,627.8	2,172.4	1.6	1.3
08/03/2021 22:00	10.3	12.9	7.6	158.4	3,262,089.3	2,167.7	1.6	1.3
08/03/2021 23:00	10.2	12.9	7.5	157.2	3,274,293.7	2,151.9	1.6	1.3
Average/Sum#:	11.6	13.3	9.9	142.2	3,150,479.7	1,921.3	1.5	1.1
Minimum:	7.7	12.9	6.5	106.8	1,842,353.5	578.5	1.0	0.6
Maximum:	38.8	16.2	48.7	171.1	3,362,611.9	2,174.2	2.8	1.3
%SI	25.00	25.00	25.00	25.00	25.00	25.00	25.00	25.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/04/2021 00:00	10.0	13.1	7.6	139.9	3,272,279.8	2,031.1	1.4	1.0
08/04/2021 01:00	9.1	13.7	7.5	106.6	3,200,344.8	1,635.9	1.0	0.7
08/04/2021 02:00	9.8	13.5	7.8	111.5	3,311,724.6	1,741.2	1.0	0.7
08/04/2021 03:00	10.2	13.2	7.8	127.8	3,340,059.5	2,000.0	1.2	1.0
08/04/2021 04:00	10.1	13.0	7.5	152.0	3,304,467.2	2,147.6	1.5	1.3
08/04/2021 05:00	9.9	12.9	7.3	156.3	3,300,617.1	2,169.2	1.5	1.3
08/04/2021 06:00	9.8	13.1	7.4	139.9	3,308,368.2	2,053.5	1.4	1.0
08/04/2021 07:00	10.1	13.2	7.7	125.1	3,246,381.1	1,920.2	1.2	1.0
08/04/2021 08:00	9.1	13.7	7.5	104.0	3,145,763.4	1,608.0	1.0	0.6
08/04/2021 09:00	9.5	13.6	7.7	107.9	3,238,399.4	1,679.0	1.0	0.7
08/04/2021 10:00	10.2	13.1	7.7	128.5	3,301,632.7	2,001.1	1.2	1.0
08/04/2021 11:00	10.1	12.9	7.4	144.6	3,227,124.6	2,120.9	1.4	1.1
08/04/2021 12:00	9.9	13.0	7.4	141.3	3,223,840.4	2,095.2	1.4	1.0
08/04/2021 13:00	9.9	13.0	7.4	139.6	3,215,069.9	2,089.5	1.4	1.0
08/04/2021 14:00	9.8	12.9	7.2	139.1	3,213,069.7	2,088.2	1.4	1.0
08/04/2021 15:00	9.8	12.9	7.2	139.2	3,182,085.8	2,091.3	1.4	1.0
08/04/2021 16:00	9.8	12.9	7.2	140.3	3,179,171.4	2,112.6	1.4	1.1
08/04/2021 17:00	9.8	12.9	7.2	142.3	3,194,370.5	2,122.7	1.4	1.1
08/04/2021 18:00	9.8	12.9	7.2	145.7	3,215,589.0	2,136.8	1.5	1.3
08/04/2021 19:00	9.8	12.9	7.2	148.1	3,199,094.4	2,149.2	1.5	1.3
08/04/2021 20:00	9.8	12.9	7.2	152.0	3,219,040.4	2,162.6	1.5	1.3
08/04/2021 21:00	9.8	12.9	7.2	153.9	3,236,604.8	2,174.4	1.5	1.3
08/04/2021 22:00	9.7	12.9	7.2	151.7	3,277,438.9	2,177.9	1.5	1.3
08/04/2021 23:00	9.6	13.0	7.2	141.9	3,286,774.1	2,112.1	1.4	1.1
Average/Sum#:	9.8	13.1	7.4	136.6	3,243,304.7	2,025.8	1.3	1.1
Minimum:	9.1	12.9	7.2	104.0	3,145,763.4	1,608.0	1.0	0.6
Maximum:	10.2	13.7	7.8	156.3	3,340,059.5	2,177.9	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/05/2021 00:00	9.6	13.0	7.2	140.1	3,306,609.0	2,100.7	1.4	1.1
08/05/2021 01:00	9.4	13.0	7.0	139.6	3,336,988.2	2,120.0	1.4	1.1
08/05/2021 02:00	9.5	13.0	7.1	142.3	3,334,941.9	2,118.7	1.4	1.1
08/05/2021 03:00	9.3	13.0	6.9	143.8	3,326,931.9	2,162.2	1.4	1.1
08/05/2021 04:00	9.4	13.0	7.0	145.5	3,340,318.4	2,170.9	1.4	1.1
08/05/2021 05:00	9.2	13.0	6.9	146.5	3,331,855.7	2,165.4	1.4	1.1
08/05/2021 06:00	8.8	13.1	6.7	127.5	3,365,402.7	1,990.6	1.2	1.0
08/05/2021 07:00	8.9	13.7	7.3	105.4	3,190,563.2	1,630.9	1.0	0.7
08/05/2021 08:00	8.7	13.7	7.1	101.6	3,149,284.8	1,609.8	1.0	0.6
08/05/2021 09:00	9.8	13.2	7.5	116.4	3,362,023.5	1,939.5	1.1	0.8
08/05/2021 10:00	9.7	13.1	7.3	130.3	3,271,946.1	2,007.0	1.3	1.0
08/05/2021 11:00	8.9	13.6	7.2	105.2	3,187,672.8	1,652.7	1.0	0.7
08/05/2021 12:00	9.0	13.6	7.3	108.3	3,318,057.4	1,720.3	1.0	0.7
08/05/2021 13:00	9.8	13.1	7.4	123.9	3,272,435.2	2,007.3	1.2	1.0
08/05/2021 14:00	9.8	13.0	7.3	132.1	3,271,968.9	2,054.8	1.3	1.0
08/05/2021 15:00	9.9	13.0	7.4	136.2	3,249,156.1	2,064.2	1.3	1.0
08/05/2021 16:00	10.0	13.0	7.5	142.5	3,257,207.0	2,093.1	1.4	1.0
08/05/2021 17:00	10.0	13.0	7.5	140.1	3,260,331.9	2,071.3	1.4	1.0
08/05/2021 18:00	10.2	12.9	7.5	151.8	3,268,359.5	2,148.0	1.5	1.3
08/05/2021 19:00	10.2	12.9	7.5	155.9	3,253,511.6	2,162.0	1.6	1.3
08/05/2021 20:00	10.1	12.9	7.4	153.3	3,226,631.8	2,167.7	1.5	1.3
08/05/2021 21:00	10.0	12.9	7.4	147.3	3,252,230.8	2,137.4	1.5	1.3
08/05/2021 22:00	9.9	13.0	7.4	140.1	3,243,824.0	2,084.5	1.4	1.0
08/05/2021 23:00	9.9	13.0	7.4	138.2	3,282,478.4	2,061.4	1.4	1.0
Average/Sum#:	9.6	13.1	7.3	133.9	3,277,530.5	2,018.4	1.3	1.0
Minimum:	8.7	12.9	6.7	101.6	3,149,284.8	1,609.8	1.0	0.6
Maximum:	10.2	13.7	7.5	155.9	3,365,402.7	2,170.9	1.6	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/06/2021 00:00	9.9	13.1	7.5	133.7	3,233,291.5	2,006.9	1.3	1.0
08/06/2021 01:00	8.9	13.7	7.3	106.5	3,239,079.9	1,655.7	1.0	0.7
08/06/2021 02:00	9.1	13.7	7.5	105.6	3,228,907.1	1,650.5	1.0	0.7
08/06/2021 03:00	9.4	13.7	7.7	102.5	3,079,276.1	1,596.5	1.0	0.6
08/06/2021 04:00	10.1	13.2	7.7	124.1	3,316,512.1	1,985.9	1.2	1.0
08/06/2021 05:00	9.9	13.1	7.5	134.0	3,269,826.8	2,005.7	1.3	1.0
08/06/2021 06:00	8.7	13.7	7.1	98.7	3,075,727.2	1,572.2	1.0	0.6
08/06/2021 07:00	9.0	13.8	7.5	102.8	3,206,213.7	1,638.9	1.0	0.7
08/06/2021 08:00	9.0	13.7	7.4	103.7	3,197,605.9	1,634.5	1.0	0.7
08/06/2021 09:00	10.0	13.2	7.7	121.1	3,314,683.3	1,960.6	1.1	0.8
08/06/2021 10:00	9.9	13.2	7.6	123.8	3,269,204.9	1,933.7	1.2	1.0
08/06/2021 11:00	9.0	13.7	7.4	104.8	3,190,171.9	1,630.7	1.0	0.7
08/06/2021 12:00	9.0	13.8	7.5	95.7	2,984,948.2	1,504.0	1.0	0.6
08/06/2021 13:00	9.9	13.2	7.6	120.1	3,313,668.9	1,960.0	1.1	0.8
08/06/2021 14:00	10.0	13.0	7.5	134.6	3,265,599.4	2,050.8	1.3	1.0
08/06/2021 15:00	9.9	13.1	7.5	134.7	3,247,128.1	2,039.2	1.3	1.0
08/06/2021 16:00	9.9	13.0	7.4	138.5	3,241,956.6	2,083.3	1.4	1.0
08/06/2021 17:00	9.9	13.0	7.4	141.7	3,222,763.3	2,094.5	1.4	1.0
08/06/2021 18:00	9.9	12.9	7.3	148.9	3,221,157.0	2,140.5	1.5	1.3
08/06/2021 19:00	9.9	13.0	7.4	144.2	3,220,609.2	2,093.1	1.4	1.0
08/06/2021 20:00	9.8	13.0	7.3	141.2	3,212,608.1	2,087.9	1.4	1.0
08/06/2021 21:00	9.8	13.0	7.3	135.2	3,210,366.5	2,063.0	1.4	1.0
08/06/2021 22:00	9.8	13.0	7.3	132.5	3,229,134.5	2,027.9	1.3	1.0
08/06/2021 23:00	9.7	13.2	7.4	123.7	3,201,280.0	1,916.9	1.2	1.0
Average/Sum#:	9.6	13.3	7.5	123.0	3,216,321.7	1,888.9	1.2	0.9
Minimum:	8.7	12.9	7.1	95.7	2,984,948.2	1,504.0	1.0	0.6
Maximum:	10.1	13.8	7.7	148.9	3,316,512.1	2,140.5	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/07/2021 00:00	9.1	13.7	7.5	107.3	3,248,665.9	1,660.6	1.0	0.7
08/07/2021 01:00	9.5	13.6	7.7	102.6	3,058,831.2	1,585.9	1.0	0.6
08/07/2021 02:00	9.8	13.2	7.5	120.4	3,245,873.9	1,919.9	1.2	1.0
08/07/2021 03:00	14.4	14.6	13.5	142.4	2,415,374.1	1,164.1	1.8	0.8
08/07/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/07/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/07/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/07/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/07/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/07/2021 09:00	20.2	18.1	42.6	147.3	1,129,775.1	181.5	3.7	0.3
08/07/2021 10:00	41.1	16.3	52.7	247.7	1,680,435.9	552.2	4.3	0.9
08/07/2021 11:00	36.7	15.9	43.3	250.1	1,636,188.3	597.4	4.8	1.1
08/07/2021 12:00	31.8	15.7	36.1	238.9	2,060,005.5	737.1	3.5	1.0
08/07/2021 13:00	9.8	13.7	8.0	107.2	3,029,558.0	1,548.6	1.1	0.6
08/07/2021 14:00	9.2	13.7	7.5	95.7	2,843,511.9	1,453.5	1.0	0.6
08/07/2021 15:00	9.8	13.7	8.0	108.4	3,169,630.6	1,620.2	1.1	0.6
08/07/2021 16:00	9.4	13.8	7.8	96.2	2,974,627.9	1,498.8	1.0	0.6
08/07/2021 17:00	10.5	13.1	7.9	127.2	3,239,177.7	1,986.9	1.2	1.0
08/07/2021 18:00	10.6	12.9	7.8	137.2	3,188,891.4	2,049.2	1.4	1.0
08/07/2021 19:00	10.3	13.0	7.7	132.2	3,178,997.9	1,973.2	1.3	1.0
08/07/2021 20:00	9.6	13.6	7.8	107.9	3,174,750.1	1,646.0	1.1	0.7
08/07/2021 21:00	9.8	13.6	7.9	105.3	3,111,679.4	1,613.3	1.0	0.6
08/07/2021 22:00	10.2	13.2	7.8	121.5	3,300,312.8	1,928.0	1.2	1.0
08/07/2021 23:00	10.4	13.0	7.8	136.5	3,229,102.7	2,004.3	1.3	1.0
Average/Sum#:	14.9	14.1	15.6	138.5	2,785,020.5	1,459.0	1.8	0.8
Minimum:	9.1	12.9	7.5	95.7	1,129,775.1	181.5	1.0	0.3
Maximum:	41.1	18.1	52.7	250.1	3,300,312.8	2,049.2	4.8	1.1
%SI	20.83	20.83	20.83	20.83	20.83	20.83	20.83	20.83

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/08/2021 00:00	9.6	13.7	7.9	104.5	3,053,816.4	1,561.0	1.1	0.6
08/08/2021 01:00	9.1	13.7	7.5	99.9	2,949,277.2	1,529.1	1.1	0.6
08/08/2021 02:00	10.3	13.2	7.9	121.4	3,308,286.6	1,908.5	1.2	1.0
08/08/2021 03:00	8.7	13.6	7.0	100.3	2,781,643.3	1,462.5	1.1	0.6
08/08/2021 04:00	8.4	13.8	7.0	85.8	2,706,697.1	1,363.8	1.0	0.5
08/08/2021 05:00	8.3	13.8	6.9	84.3	2,679,904.0	1,350.3	1.0	0.5
08/08/2021 06:00	8.3	13.8	6.9	84.8	2,685,064.1	1,352.9	1.0	0.5
08/08/2021 07:00	8.6	13.8	7.1	85.5	2,693,796.7	1,357.3	1.0	0.5
08/08/2021 08:00	8.6	13.8	7.1	85.7	2,702,926.2	1,361.9	1.0	0.5
08/08/2021 09:00	8.7	13.8	7.2	86.1	2,704,712.4	1,362.8	1.0	0.5
08/08/2021 10:00	8.8	13.8	7.3	86.5	2,705,307.8	1,363.1	1.0	0.5
08/08/2021 11:00	8.9	13.8	7.4	87.0	2,713,445.0	1,367.2	1.0	0.5
08/08/2021 12:00	9.0	13.8	7.5	87.4	2,720,589.8	1,370.8	1.0	0.5
08/08/2021 13:00	9.4	13.8	7.8	92.6	2,853,959.8	1,438.0	1.0	0.6
08/08/2021 14:00	9.7	13.7	7.9	112.6	3,059,098.4	1,563.7	1.1	0.6
08/08/2021 15:00	9.3	13.7	7.6	96.4	2,874,421.8	1,469.3	1.0	0.6
08/08/2021 16:00	10.0	13.7	8.2	102.8	3,069,075.7	1,568.8	1.0	0.6
08/08/2021 17:00	10.4	13.4	8.2	119.4	3,104,147.2	1,745.4	1.2	0.9
08/08/2021 18:00	10.4	12.9	7.7	136.4	3,215,813.1	2,066.5	1.4	1.0
08/08/2021 19:00	10.3	12.9	7.6	142.3	3,213,531.3	2,088.5	1.4	1.0
08/08/2021 20:00	10.2	12.9	7.5	147.2	3,231,537.2	2,123.8	1.5	1.3
08/08/2021 21:00	10.0	12.9	7.4	142.2	3,208,453.6	2,085.2	1.4	1.0
08/08/2021 22:00	10.0	13.0	7.5	133.7	3,243,119.2	2,013.0	1.3	1.0
08/08/2021 23:00	9.9	13.2	7.6	126.8	3,219,837.9	1,904.5	1.3	1.0
Average/Sum#:	9.4	13.5	7.5	106.3	2,945,769.2	1,615.7	1.1	0.7
Minimum:	8.3	12.9	6.9	84.3	2,679,904.0	1,350.3	1.0	0.5
Maximum:	10.4	13.8	8.2	147.2	3,308,286.6	2,123.8	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/09/2021 00:00	9.6	13.7	7.9	103.3	3,040,709.0	1,554.3	1.1	0.6
08/09/2021 01:00	9.9	13.6	8.0	110.6	3,286,232.8	1,703.8	1.0	0.7
08/09/2021 02:00	10.4	13.1	7.9	126.7	3,278,435.4	1,963.1	1.2	1.0
08/09/2021 03:00	10.1	13.2	7.7	125.4	3,263,680.7	1,906.6	1.2	1.0
08/09/2021 04:00	9.3	13.7	7.6	108.2	3,232,428.4	1,652.3	1.0	0.7
08/09/2021 05:00	10.0	13.5	8.0	112.6	3,292,514.7	1,731.1	1.1	0.7
08/09/2021 06:00	10.3	13.2	7.9	129.8	3,318,571.8	1,962.9	1.2	1.0
08/09/2021 07:00	10.5	13.1	7.9	130.1	3,233,656.4	1,959.9	1.3	1.0
08/09/2021 08:00	9.7	13.7	7.9	103.6	3,039,144.0	1,553.5	1.1	0.6
08/09/2021 09:00	9.7	13.7	7.9	105.2	3,147,132.9	1,608.7	1.0	0.6
08/09/2021 10:00	9.9	13.6	8.0	107.0	3,165,877.7	1,641.4	1.0	0.7
08/09/2021 11:00	10.2	13.2	7.8	123.1	3,265,409.1	1,955.3	1.2	1.0
08/09/2021 12:00	10.2	13.0	7.6	135.7	3,141,272.8	2,018.6	1.4	1.0
08/09/2021 13:00	9.4	13.6	7.6	108.9	3,239,556.6	1,679.6	1.0	0.7
08/09/2021 14:00	10.0	13.3	7.8	115.8	3,154,478.0	1,773.7	1.2	0.9
08/09/2021 15:00	10.3	12.9	7.6	140.7	3,208,145.9	2,085.0	1.4	1.0
08/09/2021 16:00	10.1	12.9	7.4	143.4	3,185,433.3	2,093.5	1.5	1.3
08/09/2021 17:00	10.1	12.9	7.4	143.4	3,190,758.8	2,097.0	1.5	1.3
08/09/2021 18:00	10.0	12.9	7.4	144.1	3,195,171.4	2,099.9	1.5	1.3
08/09/2021 19:00	10.1	12.9	7.4	151.5	3,181,827.8	2,137.6	1.5	1.3
08/09/2021 20:00	10.2	12.9	7.5	156.1	3,199,987.5	2,149.8	1.6	1.3
08/09/2021 21:00	10.2	12.9	7.5	151.2	3,237,623.6	2,127.8	1.5	1.3
08/09/2021 22:00	10.2	13.0	7.6	142.2	3,262,414.7	2,048.8	1.4	1.0
08/09/2021 23:00	10.3	13.0	7.7	144.3	3,273,879.7	2,056.0	1.4	1.0
Average/Sum#:	10.0	13.2	7.7	127.6	3,209,764.3	1,898.3	1.3	1.0
Minimum:	9.3	12.9	7.4	103.3	3,039,144.0	1,553.5	1.0	0.6
Maximum:	10.5	13.7	8.0	156.1	3,318,571.8	2,149.8	1.6	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/10/2021 00:00	10.1	13.1	7.6	133.9	3,234,316.4	1,960.3	1.3	1.0
08/10/2021 01:00	9.6	13.7	7.9	105.5	3,117,005.5	1,593.3	1.0	0.6
08/10/2021 02:00	9.7	13.7	7.9	104.3	3,122,483.2	1,596.1	1.0	0.6
08/10/2021 03:00	9.9	13.6	8.0	110.1	3,276,203.2	1,698.6	1.0	0.7
08/10/2021 04:00	10.5	13.1	7.9	132.2	3,323,411.5	2,014.3	1.3	1.0
08/10/2021 05:00	10.2	13.1	7.7	142.4	3,256,652.3	2,021.4	1.4	1.0
08/10/2021 06:00	9.4	13.7	7.7	106.8	3,170,413.1	1,620.6	1.0	0.6
08/10/2021 07:00	9.6	13.6	7.8	105.3	3,067,703.5	1,590.5	1.1	0.6
08/10/2021 08:00	10.6	13.1	8.0	131.2	3,299,310.7	1,975.6	1.3	1.0
08/10/2021 09:00	10.2	13.2	7.8	129.8	3,268,987.2	1,909.7	1.3	1.0
08/10/2021 10:00	9.4	13.7	7.7	108.2	3,247,492.1	1,660.0	1.0	0.7
08/10/2021 11:00	9.7	13.6	7.8	108.3	3,231,648.7	1,675.5	1.0	0.7
08/10/2021 12:00	10.3	13.1	7.8	128.1	3,273,739.4	2,008.1	1.2	1.0
08/10/2021 13:00	10.2	12.9	7.5	143.7	3,234,918.9	2,102.4	1.4	1.1
08/10/2021 14:00	10.1	12.9	7.4	144.7	3,199,279.7	2,102.6	1.5	1.3
08/10/2021 15:00	10.2	12.9	7.5	146.1	3,191,215.3	2,097.3	1.5	1.3
08/10/2021 16:00	10.3	12.9	7.6	147.9	3,207,344.1	2,107.9	1.5	1.3
08/10/2021 17:00	10.3	12.9	7.6	146.1	3,179,020.9	2,112.5	1.5	1.3
08/10/2021 18:00	10.4	12.9	7.7	153.6	3,193,140.4	2,145.2	1.6	1.3
08/10/2021 19:00	10.4	12.9	7.7	157.2	3,211,002.5	2,157.2	1.6	1.3
08/10/2021 20:00	10.4	12.9	7.7	156.4	3,214,128.3	2,159.3	1.6	1.3
08/10/2021 21:00	10.4	12.9	7.7	158.4	3,210,704.8	2,157.0	1.6	1.3
08/10/2021 22:00	10.4	12.9	7.7	148.8	3,232,457.0	2,100.8	1.5	1.3
08/10/2021 23:00	10.4	13.0	7.8	147.3	3,247,558.8	2,086.9	1.5	1.3
Average/Sum#:	10.1	13.2	7.7	133.2	3,217,089.1	1,943.9	1.3	1.0
Minimum:	9.4	12.9	7.4	104.3	3,067,703.5	1,590.5	1.0	0.6
Maximum:	10.6	13.7	8.0	158.4	3,323,411.5	2,159.3	1.6	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/11/2021 00:00	10.3	13.0	7.7	139.7	3,236,618.6	2,032.6	1.4	1.0
08/11/2021 01:00	9.5	13.7	7.8	110.0	3,195,195.0	1,656.6	1.1	0.7
08/11/2021 02:00	9.8	13.7	8.0	105.6	3,116,027.4	1,592.8	1.0	0.6
08/11/2021 03:00	9.8	13.7	8.0	104.8	3,092,942.8	1,581.0	1.0	0.6
08/11/2021 04:00	9.6	13.6	7.8	104.1	3,099,142.4	1,606.8	1.0	0.6
08/11/2021 05:00	10.6	13.1	8.0	134.9	3,338,755.6	2,023.6	1.3	1.0
08/11/2021 06:00	10.5	13.0	7.8	145.2	3,321,343.2	2,037.3	1.4	1.0
08/11/2021 07:00	9.8	13.7	8.0	108.6	3,173,347.6	1,622.1	1.1	0.6
08/11/2021 08:00	9.9	13.6	8.0	111.5	3,264,365.4	1,716.3	1.1	0.7
08/11/2021 09:00	10.5	13.1	7.9	129.3	3,274,554.5	2,008.6	1.2	1.0
08/11/2021 10:00	10.3	12.9	7.6	145.6	3,241,073.6	2,106.4	1.4	1.1
08/11/2021 11:00	10.2	12.9	7.5	147.9	3,244,920.3	2,108.9	1.5	1.3
08/11/2021 12:00	10.0	13.0	7.5	141.3	3,227,639.9	2,074.1	1.4	1.0
08/11/2021 13:00	10.2	12.9	7.5	141.8	3,233,708.9	2,078.0	1.4	1.0
08/11/2021 14:00	10.3	12.9	7.6	146.0	3,188,932.9	2,095.8	1.5	1.3
08/11/2021 15:00	10.2	13.0	7.6	137.6	3,170,528.7	2,037.4	1.4	1.0
08/11/2021 16:00	10.3	12.9	7.6	140.5	3,181,372.9	2,067.6	1.4	1.0
08/11/2021 17:00	10.3	12.9	7.6	144.4	3,182,390.1	2,091.5	1.5	1.3
08/11/2021 18:00	10.3	12.9	7.6	152.8	3,176,469.2	2,134.0	1.6	1.3
08/11/2021 19:00	10.3	12.8	7.5	152.3	3,181,678.9	2,137.5	1.6	1.3
08/11/2021 20:00	10.4	12.9	7.7	154.4	3,191,354.2	2,144.0	1.6	1.3
08/11/2021 21:00	10.2	12.9	7.5	149.3	3,186,695.7	2,117.6	1.5	1.3
08/11/2021 22:00	10.3	13.0	7.7	145.0	3,234,642.6	2,078.6	1.4	1.0
08/11/2021 23:00	10.4	13.0	7.8	149.2	3,279,535.3	2,083.5	1.5	1.3
Average/Sum#:	10.2	13.1	7.7	135.1	3,209,718.2	1,968.0	1.3	1.0
Minimum:	9.5	12.8	7.5	104.1	3,092,942.8	1,581.0	1.0	0.6
Maximum:	10.6	13.7	8.0	154.4	3,338,755.6	2,144.0	1.6	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/12/2021 00:00	10.3	13.1	7.8	144.0	3,253,179.1	2,043.0	1.4	1.0
08/12/2021 01:00	9.3	13.7	7.6	108.4	3,232,232.8	1,652.2	1.0	0.7
08/12/2021 02:00	9.6	13.6	7.8	104.0	3,098,178.0	1,606.3	1.0	0.6
08/12/2021 03:00	10.1	13.2	7.7	135.7	3,298,141.7	1,974.9	1.3	1.0
08/12/2021 04:00	9.8	13.1	7.4	133.0	3,258,075.1	1,974.7	1.3	1.0
08/12/2021 05:00	9.3	13.7	7.6	108.0	3,242,992.6	1,657.7	1.0	0.7
08/12/2021 06:00	9.6	13.6	7.8	112.9	3,349,496.3	1,736.6	1.0	0.7
08/12/2021 07:00	10.7	13.1	8.1	128.9	3,308,328.9	1,981.0	1.2	1.0
08/12/2021 08:00	10.1	13.2	7.7	127.3	3,239,111.3	1,915.9	1.2	1.0
08/12/2021 09:00	9.4	13.7	7.7	108.2	3,263,925.2	1,668.4	1.0	0.7
08/12/2021 10:00	9.4	13.7	7.7	108.2	3,286,618.5	1,680.0	1.0	0.7
08/12/2021 11:00	10.2	13.1	7.7	129.0	3,271,783.1	2,006.9	1.2	1.0
08/12/2021 12:00	10.0	13.0	7.5	136.3	3,196,205.4	2,053.9	1.4	1.0
08/12/2021 13:00	9.9	13.0	7.4	136.2	3,216,573.3	2,043.5	1.4	1.0
08/12/2021 14:00	9.9	13.0	7.4	134.9	3,202,564.2	2,034.6	1.4	1.0
08/12/2021 15:00	9.9	13.0	7.4	135.4	3,173,329.8	2,039.2	1.4	1.0
08/12/2021 16:00	9.9	12.9	7.3	135.8	3,197,450.3	2,054.7	1.4	1.0
08/12/2021 17:00	9.9	12.9	7.3	138.2	3,177,218.4	2,064.9	1.4	1.0
08/12/2021 18:00	9.9	12.9	7.3	143.7	3,207,800.5	2,108.2	1.4	1.1
08/12/2021 19:00	9.9	12.9	7.3	145.9	3,186,545.2	2,117.5	1.5	1.3
08/12/2021 20:00	9.8	12.9	7.2	149.1	3,217,244.4	2,137.9	1.5	1.3
08/12/2021 21:00	9.7	12.9	7.2	145.2	3,247,997.7	2,110.9	1.4	1.1
08/12/2021 22:00	9.7	13.0	7.2	140.5	3,246,480.2	2,062.5	1.4	1.0
08/12/2021 23:00	9.7	13.1	7.3	133.1	3,287,107.6	2,016.3	1.3	1.0
Average/Sum#:	9.8	13.2	7.5	130.1	3,235,774.2	1,947.6	1.3	1.0
Minimum:	9.3	12.9	7.2	104.0	3,098,178.0	1,606.3	1.0	0.6
Maximum:	10.7	13.7	8.1	149.1	3,349,496.3	2,137.9	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/13/2021 00:00	9.5	13.2	7.3	125.7	3,290,384.4	1,922.2	1.2	1.0
08/13/2021 01:00	9.2	13.7	7.5	105.0	3,112,643.8	1,613.8	1.1	0.6
08/13/2021 02:00	8.7	13.7	7.1	95.6	2,872,661.1	1,468.4	1.0	0.6
08/13/2021 03:00	10.0	13.2	7.7	126.3	3,302,483.8	1,977.5	1.2	1.0
08/13/2021 04:00	9.7	13.2	7.4	125.1	3,308,980.0	1,908.9	1.2	1.0
08/13/2021 05:00	9.0	13.7	7.4	105.8	3,214,430.3	1,643.1	1.0	0.7
08/13/2021 06:00	9.1	13.7	7.5	105.4	3,152,219.3	1,611.3	1.0	0.6
08/13/2021 07:00	9.1	13.7	7.5	100.5	3,005,690.9	1,536.4	1.0	0.6
08/13/2021 08:00	10.1	13.2	7.7	125.0	3,323,643.7	1,965.9	1.2	1.0
08/13/2021 09:00	9.9	13.2	7.6	127.3	3,218,147.3	1,927.0	1.3	1.0
08/13/2021 10:00	9.1	13.7	7.5	101.9	3,060,076.6	1,564.2	1.0	0.6
08/13/2021 11:00	9.2	13.7	7.5	105.8	3,059,685.3	1,564.0	1.1	0.6
08/13/2021 12:00	10.1	13.1	7.6	125.6	3,243,253.4	1,989.4	1.2	1.0
08/13/2021 13:00	9.8	13.0	7.3	132.1	3,229,134.5	2,027.9	1.3	1.0
08/13/2021 14:00	9.8	13.0	7.3	131.1	3,221,809.7	2,023.3	1.3	1.0
08/13/2021 15:00	9.8	13.0	7.3	130.1	3,220,217.4	2,022.3	1.3	1.0
08/13/2021 16:00	9.8	13.0	7.3	132.1	3,200,045.7	2,033.0	1.3	1.0
08/13/2021 17:00	9.9	12.9	7.3	134.6	3,194,338.0	2,052.7	1.4	1.0
08/13/2021 18:00	9.9	12.9	7.3	141.3	3,221,532.4	2,093.7	1.4	1.0
08/13/2021 19:00	9.9	12.9	7.3	145.4	3,236,558.5	2,127.1	1.5	1.3
08/13/2021 20:00	9.9	12.9	7.3	144.6	3,207,648.4	2,108.1	1.5	1.3
08/13/2021 21:00	9.8	13.0	7.3	136.7	3,230,739.7	2,052.5	1.4	1.0
08/13/2021 22:00	9.9	13.0	7.4	136.2	3,264,644.0	2,050.2	1.3	1.0
08/13/2021 23:00	9.9	13.0	7.4	138.0	3,263,847.9	2,049.7	1.4	1.0
Average/Sum#:	9.6	13.2	7.4	124.1	3,193,950.7	1,888.9	1.2	0.9
Minimum:	8.7	12.9	7.1	95.6	2,872,661.1	1,468.4	1.0	0.6
Maximum:	10.1	13.7	7.7	145.4	3,323,643.7	2,127.1	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/14/2021 00:00	9.8	13.1	7.4	128.3	3,210,557.7	1,945.9	1.3	1.0
08/14/2021 01:00	9.1	13.7	7.5	107.3	3,263,925.2	1,668.4	1.0	0.7
08/14/2021 02:00	9.6	13.6	7.8	108.9	3,280,639.3	1,700.9	1.0	0.7
08/14/2021 03:00	10.1	13.1	7.6	127.1	3,271,604.4	1,982.9	1.2	1.0
08/14/2021 04:00	9.8	13.2	7.5	123.7	3,233,025.0	1,912.3	1.2	1.0
08/14/2021 05:00	9.1	13.7	7.5	108.1	3,278,988.9	1,676.1	1.0	0.7
08/14/2021 06:00	9.5	13.7	7.8	104.1	3,111,723.5	1,590.6	1.0	0.6
08/14/2021 07:00	9.3	13.7	7.6	97.0	2,903,375.3	1,484.1	1.0	0.6
08/14/2021 08:00	8.0	13.8	6.6	83.1	2,558,045.1	1,288.9	1.0	0.5
08/14/2021 09:00	9.6	13.8	8.0	100.2	3,064,771.8	1,566.6	1.0	0.6
08/14/2021 10:00	9.9	13.7	8.1	107.3	3,184,694.2	1,627.9	1.0	0.7
08/14/2021 11:00	9.6	13.7	7.9	106.6	3,222,059.9	1,647.0	1.0	0.7
08/14/2021 12:00	9.5	13.7	7.8	106.2	3,187,094.2	1,652.4	1.0	0.7
08/14/2021 13:00	10.2	13.0	7.6	123.1	3,196,558.7	1,984.1	1.2	1.0
08/14/2021 14:00	10.0	12.9	7.4	130.5	3,141,428.4	2,018.7	1.3	1.0
08/14/2021 15:00	9.3	13.7	7.6	103.5	3,048,338.7	1,558.2	1.1	0.6
08/14/2021 16:00	9.1	13.7	7.5	97.7	2,906,114.2	1,485.5	1.0	0.6
08/14/2021 17:00	10.3	13.0	7.7	127.3	3,166,833.2	2,011.9	1.3	1.0
08/14/2021 18:00	10.0	12.8	7.3	143.1	3,141,489.3	2,110.5	1.5	1.3
08/14/2021 19:00	9.9	12.8	7.2	146.0	3,135,098.3	2,129.1	1.5	1.3
08/14/2021 20:00	9.9	12.8	7.2	146.3	3,199,035.6	2,125.8	1.5	1.3
08/14/2021 21:00	9.8	12.9	7.2	144.0	3,202,018.5	2,104.4	1.5	1.3
08/14/2021 22:00	9.7	12.9	7.2	137.8	3,224,216.3	2,071.9	1.4	1.0
08/14/2021 23:00	9.7	13.0	7.2	137.0	3,250,631.3	2,041.4	1.4	1.0
Average/Sum#:	9.6	13.3	7.5	118.5	3,140,927.8	1,807.7	1.2	0.9
Minimum:	8.0	12.8	6.6	83.1	2,558,045.1	1,288.9	1.0	0.5
Maximum:	10.3	13.8	8.1	146.3	3,280,639.3	2,129.1	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/15/2021 00:00	9.6	13.2	7.4	124.4	3,258,722.8	1,927.5	1.2	1.0
08/15/2021 01:00	8.9	13.7	7.3	107.1	3,257,665.0	1,665.2	1.0	0.7
08/15/2021 02:00	9.3	13.6	7.5	102.8	3,100,878.3	1,607.7	1.0	0.6
08/15/2021 03:00	10.0	13.1	7.6	126.3	3,279,358.9	1,987.6	1.2	1.0
08/15/2021 04:00	9.6	13.2	7.4	124.1	3,229,812.8	1,910.4	1.2	1.0
08/15/2021 05:00	9.0	13.7	7.4	105.9	3,218,734.2	1,645.3	1.0	0.7
08/15/2021 06:00	9.5	13.7	7.8	102.4	3,063,989.2	1,566.2	1.0	0.6
08/15/2021 07:00	9.7	13.7	7.9	105.5	3,211,887.1	1,641.8	1.0	0.7
08/15/2021 08:00	9.7	13.7	7.9	96.4	2,890,268.0	1,477.4	1.0	0.6
08/15/2021 09:00	9.6	13.7	7.9	103.4	3,085,448.2	1,599.7	1.0	0.6
08/15/2021 10:00	9.5	13.7	7.8	106.5	3,195,195.0	1,656.6	1.0	0.7
08/15/2021 11:00	9.3	13.7	7.6	96.5	2,902,005.9	1,483.4	1.0	0.6
08/15/2021 12:00	10.2	13.3	7.9	113.2	3,036,920.9	1,707.6	1.2	0.9
08/15/2021 13:00	10.1	12.9	7.4	130.0	3,128,201.0	2,010.2	1.3	1.0
08/15/2021 14:00	9.2	13.7	7.5	104.6	3,098,178.0	1,606.3	1.1	0.6
08/15/2021 15:00	9.6	13.7	7.9	105.1	3,114,765.4	1,614.9	1.0	0.6
08/15/2021 16:00	10.5	13.0	7.8	128.1	3,151,879.8	2,002.4	1.3	1.0
08/15/2021 17:00	10.3	12.8	7.5	136.1	3,087,976.7	2,052.0	1.4	1.0
08/15/2021 18:00	10.1	12.8	7.4	142.1	3,147,870.2	2,091.8	1.5	1.3
08/15/2021 19:00	10.0	12.9	7.4	142.4	3,169,304.5	2,082.9	1.5	1.2
08/15/2021 20:00	10.0	12.9	7.4	139.6	3,189,835.6	2,073.1	1.4	1.0
08/15/2021 21:00	10.0	12.9	7.4	140.4	3,187,681.5	2,071.7	1.4	1.0
08/15/2021 22:00	10.1	13.0	7.5	138.9	3,193,093.1	2,051.9	1.4	1.0
08/15/2021 23:00	10.0	13.0	7.5	137.3	3,218,776.9	2,044.9	1.4	1.0
Average/Sum#:	9.7	13.3	7.6	119.1	3,142,435.4	1,815.8	1.2	0.9
Minimum:	8.9	12.8	7.3	96.4	2,890,268.0	1,477.4	1.0	0.6
Maximum:	10.5	13.7	7.9	142.4	3,279,358.9	2,091.8	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/16/2021 00:00	9.7	13.1	7.3	124.5	3,183,994.2	1,929.8	1.2	1.0
08/16/2021 01:00	9.4	13.7	7.7	110.8	3,256,491.2	1,664.6	1.1	0.7
08/16/2021 02:00	8.8	13.7	7.2	96.2	2,889,099.7	1,497.9	1.0	0.6
08/16/2021 03:00	10.1	13.1	7.6	125.9	3,231,841.5	1,958.8	1.2	1.0
08/16/2021 04:00	10.0	13.1	7.6	125.8	3,224,493.4	1,930.8	1.2	1.0
08/16/2021 05:00	9.2	13.6	7.4	112.1	3,216,411.4	1,667.6	1.1	0.7
08/16/2021 06:00	9.6	13.6	7.8	109.2	3,274,853.0	1,697.9	1.0	0.7
08/16/2021 07:00	10.5	13.1	7.9	122.3	3,213,692.5	1,947.8	1.2	1.0
08/16/2021 08:00	10.0	13.1	7.6	129.5	3,163,853.7	1,963.8	1.3	1.0
08/16/2021 09:00	9.4	13.6	7.6	107.7	3,182,465.1	1,650.0	1.1	0.7
08/16/2021 10:00	9.7	13.7	7.9	104.3	3,070,018.0	1,591.7	1.1	0.6
08/16/2021 11:00	10.4	13.0	7.8	128.8	3,186,777.9	2,001.3	1.3	1.0
08/16/2021 12:00	10.4	12.9	7.7	138.0	3,142,905.9	2,042.6	1.4	1.0
08/16/2021 13:00	10.4	12.9	7.7	138.2	3,133,520.0	2,036.5	1.4	1.0
08/16/2021 14:00	10.3	13.0	7.7	134.6	3,150,777.9	2,001.7	1.4	1.0
08/16/2021 15:00	10.4	12.9	7.7	141.5	3,134,916.7	2,060.3	1.5	1.2
08/16/2021 16:00	10.4	12.8	7.6	145.8	3,121,986.6	2,074.6	1.5	1.2
08/16/2021 17:00	10.4	12.8	7.6	147.4	3,092,543.1	2,100.2	1.5	1.3
08/16/2021 18:00	10.3	12.8	7.5	150.7	3,126,116.1	2,123.0	1.6	1.3
08/16/2021 19:00	10.3	12.8	7.5	150.7	3,154,737.0	2,119.4	1.5	1.3
08/16/2021 20:00	10.3	12.9	7.6	149.4	3,162,617.9	2,101.6	1.5	1.3
08/16/2021 21:00	10.3	12.9	7.6	151.1	3,176,011.2	2,110.5	1.5	1.3
08/16/2021 22:00	10.2	13.0	7.6	144.0	3,207,876.6	2,061.4	1.4	1.0
08/16/2021 23:00	10.3	13.0	7.7	145.3	3,248,369.1	2,063.7	1.4	1.0
Average/Sum#:	10.0	13.1	7.6	130.6	3,164,432.1	1,933.2	1.3	1.0
Minimum:	8.8	12.8	7.2	96.2	2,889,099.7	1,497.9	1.0	0.6
Maximum:	10.5	13.7	7.9	151.1	3,274,853.0	2,123.0	1.6	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/17/2021 00:00	10.0	13.0	7.5	141.7	3,265,352.2	2,026.8	1.4	1.0
08/17/2021 01:00	9.3	13.7	7.6	111.6	3,175,521.6	1,646.4	1.1	0.7
08/17/2021 02:00	9.6	13.6	7.8	106.5	3,092,777.5	1,603.5	1.1	0.6
08/17/2021 03:00	10.4	13.1	7.9	136.3	3,285,640.4	2,015.4	1.3	1.0
08/17/2021 04:00	10.1	13.0	7.5	149.9	3,252,071.7	2,089.8	1.5	1.3
08/17/2021 05:00	9.9	12.9	7.3	152.5	3,282,156.4	2,133.1	1.5	1.3
08/17/2021 06:00	10.0	13.0	7.5	148.4	3,278,079.8	2,034.7	1.5	1.2
08/17/2021 07:00	9.5	13.7	7.8	109.3	3,176,673.3	1,623.8	1.1	0.6
08/17/2021 08:00	9.2	13.7	7.5	102.3	3,073,770.8	1,571.2	1.0	0.6
08/17/2021 09:00	10.1	13.1	7.6	128.7	3,301,815.8	1,977.1	1.2	1.0
08/17/2021 10:00	9.6	13.2	7.4	126.4	3,222,543.0	1,906.1	1.3	1.0
08/17/2021 11:00	9.2	13.7	7.5	105.5	3,170,608.7	1,620.7	1.0	0.6
08/17/2021 12:00	8.6	13.7	7.0	92.9	2,837,056.1	1,450.2	1.0	0.6
08/17/2021 13:00	9.8	13.6	7.9	113.5	3,277,167.6	1,699.1	1.1	0.7
08/17/2021 14:00	9.8	13.3	7.6	113.9	3,197,425.7	1,774.5	1.1	0.7
08/17/2021 15:00	9.6	13.3	7.5	120.0	3,158,981.1	1,799.3	1.2	0.9
08/17/2021 16:00	9.0	13.7	7.4	100.3	2,982,997.6	1,524.8	1.0	0.6
08/17/2021 17:00	10.0	13.1	7.6	127.9	3,245,209.7	1,990.6	1.3	1.0
08/17/2021 18:00	10.0	12.9	7.4	143.6	3,214,762.2	2,089.3	1.4	1.0
08/17/2021 19:00	9.9	12.9	7.3	151.1	3,207,161.8	2,131.2	1.5	1.3
08/17/2021 20:00	9.8	12.9	7.2	155.0	3,194,926.6	2,146.4	1.6	1.3
08/17/2021 21:00	9.8	12.9	7.2	151.6	3,230,015.6	2,122.8	1.5	1.3
08/17/2021 22:00	9.9	13.0	7.4	150.8	3,280,479.7	2,084.1	1.5	1.3
08/17/2021 23:00	10.0	13.2	7.7	141.5	3,310,287.6	1,958.0	1.4	1.0
Average/Sum#:	9.7	13.3	7.5	128.4	3,196,395.1	1,875.8	1.3	0.9
Minimum:	8.6	12.9	7.0	92.9	2,837,056.1	1,450.2	1.0	0.6
Maximum:	10.4	13.7	7.9	155.0	3,310,287.6	2,146.4	1.6	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/18/2021 00:00	9.3	13.8	7.7	110.5	3,145,959.1	1,608.1	1.1	0.6
08/18/2021 01:00	10.0	13.8	8.3	125.1	3,025,832.5	1,524.6	1.3	0.8
08/18/2021 02:00	10.4	13.2	8.0	133.6	3,384,409.5	1,927.7	1.2	1.0
08/18/2021 03:00	10.3	13.2	7.9	130.8	3,339,288.7	1,902.0	1.2	1.0
08/18/2021 04:00	9.3	13.7	7.6	111.3	3,277,423.8	1,675.3	1.1	0.7
08/18/2021 05:00	9.7	13.7	7.9	111.1	3,191,916.1	1,654.9	1.1	0.7
08/18/2021 06:00	10.4	13.2	8.0	131.6	3,359,026.8	1,962.3	1.2	1.0
08/18/2021 07:00	10.5	13.3	8.2	133.6	3,329,608.0	1,920.8	1.3	1.0
08/18/2021 08:00	8.6	13.8	7.1	91.9	2,801,842.3	1,432.2	1.0	0.6
08/18/2021 09:00	8.9	13.9	7.5	98.1	3,049,053.2	1,536.3	1.0	0.6
08/18/2021 10:00	8.7	13.9	7.3	97.2	988,475.4	1,508.6	3.3	2.0
08/18/2021 11:00	8.3	13.9	7.0	98.0	2,924,929.4	1,452.4	1.1	0.6
08/18/2021 12:00	8.9	13.8	7.4	113.7	2,957,361.3	1,490.1	1.2	0.7
08/18/2021 13:00	10.2	13.1	7.7	182.1	3,389,325.4	2,029.5	1.8	1.4
08/18/2021 14:00	10.2	13.1	7.7	223.1	3,236,674.8	2,009.0	2.3	1.8
08/18/2021 15:00	9.2	13.7	7.5	108.3	3,230,667.8	1,651.4	1.0	0.7
08/18/2021 16:00	9.8	13.8	8.1	119.0	2,987,925.2	1,505.5	1.3	0.8
08/18/2021 17:00	10.3	13.2	7.9	131.3	3,289,290.6	1,969.6	1.3	1.0
08/18/2021 18:00	10.3	13.0	7.7	150.4	3,298,423.9	2,095.5	1.5	1.3
08/18/2021 19:00	10.0	13.2	7.7	134.7	3,268,248.2	1,957.0	1.3	1.0
08/18/2021 20:00	9.3	13.7	7.6	114.5	3,287,596.7	1,680.5	1.1	0.7
08/18/2021 21:00	9.9	13.6	8.0	114.0	3,268,873.9	1,694.8	1.1	0.7
08/18/2021 22:00	10.4	13.2	8.0	132.8	3,336,051.4	1,997.6	1.3	1.0
08/18/2021 23:00	10.0	13.2	7.7	129.6	3,300,139.4	1,903.8	1.2	1.0
Average/Sum#:	9.7	13.5	7.7	126.1	3,203,472.5	1,753.7	1.3	0.9
Minimum:	8.3	13.0	7.0	91.9	2,801,842.3	1,432.2	1.0	0.6
Maximum:	10.5	13.9	8.3	223.1	3,389,325.4	2,095.5	2.3	1.8
%SI	0.00	0.00	0.00	0.00	4.17	0.00	4.17	4.17

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/19/2021 00:00	9.5	13.7	7.8	107.4	3,102,528.8	1,585.9	1.1	0.6
08/19/2021 01:00	9.5	13.7	7.8	105.1	3,167,283.0	1,619.0	1.0	0.6
08/19/2021 02:00	9.7	13.7	7.9	97.3	2,908,853.0	1,486.9	1.0	0.6
08/19/2021 03:00	9.7	13.8	8.1	119.8	2,964,999.4	1,515.6	1.3	0.8
08/19/2021 04:00	10.2	13.1	7.7	131.2	3,334,047.4	1,996.4	1.2	1.0
08/19/2021 05:00	10.2	13.2	7.8	134.8	3,289,699.7	1,921.8	1.3	1.0
08/19/2021 06:00	9.5	13.7	7.8	108.9	3,185,281.1	1,628.2	1.1	0.7
08/19/2021 07:00	9.8	13.7	8.0	108.1	3,242,796.9	1,657.6	1.0	0.7
08/19/2021 08:00	8.1	13.9	6.8	85.4	2,663,828.1	1,342.2	1.0	0.5
08/19/2021 09:00	10.4	13.7	8.5	122.8	3,206,409.4	1,639.0	1.2	0.8
08/19/2021 10:00	9.3	13.8	7.7	113.9	3,203,262.3	1,614.0	1.1	0.6
08/19/2021 11:00	0.0	0.0	0.0	113.2	3,137,768.0	1,581.0	1.3	0.8
08/19/2021 12:00	10.3	13.7	8.4	119.0	3,258,643.1	1,665.7	1.1	0.7
08/19/2021 13:00	10.4	13.2	8.0	134.3	3,270,991.0	2,030.3	1.3	1.0
08/19/2021 14:00	10.8	13.1	8.2	136.6	3,225,809.6	1,978.7	1.3	1.0
08/19/2021 15:00	9.7	13.7	7.9	104.7	3,023,689.0	1,545.6	1.1	0.6
08/19/2021 16:00	9.7	13.7	7.9	105.7	3,158,934.2	1,637.8	1.0	0.7
08/19/2021 17:00	10.6	13.1	8.0	135.8	3,281,401.7	2,012.8	1.3	1.0
08/19/2021 18:00	10.5	13.0	7.8	149.8	3,272,609.5	2,079.1	1.5	1.2
08/19/2021 19:00	10.2	13.1	7.7	142.8	3,223,786.1	2,001.0	1.4	1.0
08/19/2021 20:00	9.3	13.7	7.6	111.5	3,269,402.9	1,671.2	1.1	0.7
08/19/2021 21:00	9.4	13.6	7.6	103.0	3,049,958.8	1,581.3	1.1	0.6
08/19/2021 22:00	10.3	13.1	7.8	129.5	3,293,632.6	1,972.2	1.2	1.0
08/19/2021 23:00	10.0	13.2	7.7	127.0	3,260,257.1	1,904.6	1.2	1.0
Average/Sum#:	9.9	13.5	7.8	118.7	3,166,494.7	1,736.2	1.2	0.8
Minimum:	8.1	13.0	6.8	85.4	2,663,828.1	1,342.2	1.0	0.5
Maximum:	10.8	13.9	8.5	149.8	3,334,047.4	2,079.1	1.5	1.2
%SI	4.17	4.17	4.17	0.00	0.00	0.00	4.17	4.17

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/20/2021 00:00	9.5	13.7	7.8	111.3	3,225,972.6	1,649.0	1.1	0.7
08/20/2021 01:00	9.4	13.7	7.7	106.5	3,223,038.1	1,647.5	1.0	0.7
08/20/2021 02:00	9.8	13.7	8.0	99.3	2,952,479.0	1,509.2	1.0	0.6
08/20/2021 03:00	8.1	13.8	6.7	85.1	2,633,661.1	1,327.0	1.0	0.5
08/20/2021 04:00	9.1	13.7	7.5	102.9	3,157,110.1	1,613.8	1.0	0.6
08/20/2021 05:00	9.2	13.6	7.4	106.0	3,213,012.0	1,689.3	1.0	0.7
08/20/2021 06:00	10.0	13.2	7.7	119.6	3,286,438.3	1,823.9	1.1	0.7
08/20/2021 07:00	9.8	13.7	8.0	107.0	3,170,413.1	1,620.6	1.0	0.6
08/20/2021 08:00	9.3	13.7	7.6	96.5	2,936,828.4	1,501.2	1.0	0.6
08/20/2021 09:00	7.5	13.8	6.2	82.2	2,565,388.3	1,292.6	1.0	0.5
08/20/2021 10:00	7.4	13.8	6.1	81.1	2,540,579.9	1,280.1	1.0	0.5
08/20/2021 11:00	7.5	13.8	6.2	81.4	2,544,747.7	1,282.2	1.0	0.5
08/20/2021 12:00	8.7	13.7	7.1	97.7	2,925,677.4	1,495.5	1.0	0.6
08/20/2021 13:00	10.3	13.1	7.8	127.1	3,286,288.5	1,991.8	1.2	1.0
08/20/2021 14:00	10.0	13.1	7.6	127.8	3,202,968.1	1,941.3	1.3	1.0
08/20/2021 15:00	9.5	13.7	7.8	99.6	2,957,174.1	1,511.6	1.0	0.6
08/20/2021 16:00	9.1	13.7	7.5	100.7	2,971,455.3	1,518.9	1.1	0.6
08/20/2021 17:00	10.3	13.0	7.7	129.7	3,242,152.5	2,012.4	1.3	1.0
08/20/2021 18:00	10.1	13.0	7.5	139.7	3,221,259.6	2,070.0	1.4	1.0
08/20/2021 19:00	10.1	13.0	7.5	141.5	3,207,637.8	2,014.4	1.4	1.0
08/20/2021 20:00	9.5	13.7	7.8	111.5	3,199,562.3	1,635.5	1.1	0.7
08/20/2021 21:00	10.0	13.6	8.1	111.0	3,229,912.8	1,674.6	1.1	0.7
08/20/2021 22:00	10.5	13.1	7.9	130.9	3,281,998.8	1,989.2	1.3	1.0
08/20/2021 23:00	10.1	13.2	7.7	127.4	3,232,355.1	1,888.3	1.3	0.9
Average/Sum#:	9.4	13.5	7.5	109.3	3,058,671.3	1,665.8	1.1	0.7
Minimum:	7.4	13.0	6.1	81.1	2,540,579.9	1,280.1	1.0	0.5
Maximum:	10.5	13.8	8.1	141.5	3,286,438.3	2,070.0	1.4	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/21/2021 00:00	18.7	15.9	22.1	172.1	1,517,735.6	587.4	3.6	0.8
08/21/2021 01:00	27.4	17.2	43.7	225.3	1,710,496.6	399.7	3.8	0.6
08/21/2021 02:00	17.3	14.2	15.2	152.2	2,349,300.2	1,115.1	2.0	0.9
08/21/2021 03:00	7.5	13.8	6.2	78.7	2,404,828.3	1,211.7	1.0	0.5
08/21/2021 04:00	7.7	13.8	6.4	79.3	2,416,537.9	1,217.6	1.0	0.5
08/21/2021 05:00	8.0	13.8	6.6	83.2	2,640,012.1	1,330.2	1.0	0.5
08/21/2021 06:00	8.0	13.8	6.6	83.6	2,641,996.7	1,331.2	1.0	0.5
08/21/2021 07:00	8.4	13.8	7.0	84.1	2,647,553.8	1,334.0	1.0	0.5
08/21/2021 08:00	8.2	13.8	6.8	84.1	2,651,126.2	1,335.8	1.0	0.5
08/21/2021 09:00	8.1	13.8	6.7	83.9	2,659,858.8	1,340.2	1.0	0.5
08/21/2021 10:00	8.1	13.8	6.7	84.0	2,661,248.1	1,340.9	1.0	0.5
08/21/2021 11:00	8.3	13.8	6.9	84.3	2,673,950.0	1,347.3	1.0	0.5
08/21/2021 12:00	8.4	13.8	7.0	84.7	2,677,522.4	1,349.1	1.0	0.5
08/21/2021 13:00	8.4	13.8	7.0	84.7	2,678,117.8	1,349.4	1.0	0.5
08/21/2021 14:00	8.3	13.8	6.9	84.6	2,675,339.2	1,348.0	1.0	0.5
08/21/2021 15:00	11.8	14.5	10.9	109.5	2,377,146.8	1,093.6	1.4	0.5
08/21/2021 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/21/2021 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/21/2021 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/21/2021 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/21/2021 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/21/2021 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/21/2021 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/21/2021 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	10.8	14.2	10.8	103.6	2,461,423.2	1,189.5	1.4	0.6
Minimum:	7.5	13.8	6.2	78.7	1,517,735.6	399.7	1.0	0.5
Maximum:	27.4	17.2	43.7	225.3	2,678,117.8	1,349.4	3.8	0.9
%SI	33.33	33.33	33.33	33.33	33.33	33.33	33.33	33.33

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/22/2021 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/22/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/22/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/22/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/22/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/22/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/22/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/22/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/22/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/22/2021 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/22/2021 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/22/2021 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/22/2021 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/22/2021 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/22/2021 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/22/2021 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/22/2021 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/22/2021 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/22/2021 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/22/2021 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/22/2021 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/22/2021 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/22/2021 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/22/2021 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/23/2021 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/23/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/23/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/23/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/23/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/23/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/23/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/23/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/23/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/23/2021 09:00	29.2	17.3	47.9	0.0	1,352,825.3	326.0	0.0	0.0
08/23/2021 10:00	31.0	17.1	48.1	222.5	1,443,077.2	389.9	4.8	0.7
08/23/2021 11:00	38.0	15.3	40.0	254.6	2,043,231.9	805.7	3.8	1.2
08/23/2021 12:00	12.8	14.7	12.2	128.7	2,403,227.5	1,070.5	1.7	0.7
08/23/2021 13:00	37.6	16.5	50.4	239.5	1,762,791.5	514.9	3.9	0.8
08/23/2021 14:00	20.7	14.3	18.5	163.9	2,360,973.2	1,103.4	2.2	0.9
08/23/2021 15:00	8.9	13.8	7.4	95.4	2,834,510.0	1,428.2	1.0	0.6
08/23/2021 16:00	10.0	13.6	8.1	120.0	3,247,078.8	1,683.5	1.2	0.8
08/23/2021 17:00	10.0	13.7	8.2	110.2	1,055,439.6	1,610.8	3.5	2.1
08/23/2021 18:00	10.8	13.6	8.7	126.5	3,195,387.9	1,656.7	1.2	0.8
08/23/2021 19:00	10.5	13.4	8.3	121.2	3,179,587.2	1,764.6	1.2	0.9
08/23/2021 20:00	10.4	13.3	8.1	131.0	3,204,804.2	1,825.4	1.3	0.9
08/23/2021 21:00	10.2	13.5	8.1	116.2	3,304,306.9	1,737.3	1.1	0.7
08/23/2021 22:00	10.5	13.2	8.0	131.3	3,320,938.7	1,964.3	1.2	1.0
08/23/2021 23:00	10.2	13.2	7.8	130.6	3,270,870.1	1,910.8	1.3	1.0
Average/Sum#:	17.4	14.4	19.3	139.4	2,637,400.7	1,319.5	1.9	0.8
Minimum:	8.9	13.2	7.4	0.0	1,352,825.3	326.0	0.0	0.0
Maximum:	38.0	17.3	50.4	254.6	3,320,938.7	1,964.3	4.8	1.2
%SI	37.50	37.50	37.50	37.50	41.67	37.50	41.67	41.67

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/24/2021 00:00	9.5	13.7	7.8	101.3	2,983,975.7	1,525.3	1.1	0.6
08/24/2021 01:00	9.8	13.7	8.0	103.8	3,112,114.7	1,590.8	1.0	0.6
08/24/2021 02:00	9.9	13.6	8.0	111.9	3,177,643.2	1,647.5	1.1	0.7
08/24/2021 03:00	10.5	13.3	8.2	128.4	3,363,341.4	1,915.7	1.2	1.0
08/24/2021 04:00	10.1	13.3	7.8	130.3	3,332,968.3	1,898.4	1.2	0.9
08/24/2021 05:00	9.4	13.7	7.7	107.4	3,211,495.8	1,641.6	1.0	0.7
08/24/2021 06:00	9.7	13.7	7.9	104.3	3,096,464.2	1,582.8	1.0	0.6
08/24/2021 07:00	9.9	13.7	8.1	106.0	3,166,500.4	1,618.6	1.0	0.6
08/24/2021 08:00	9.9	13.7	8.1	99.6	2,950,131.4	1,508.0	1.0	0.6
08/24/2021 09:00	9.5	13.7	7.8	107.6	3,252,187.3	1,662.4	1.0	0.7
08/24/2021 10:00	9.8	13.7	8.0	107.7	3,216,973.5	1,644.4	1.0	0.7
08/24/2021 11:00	9.8	13.7	8.0	105.7	3,145,567.8	1,607.9	1.0	0.6
08/24/2021 12:00	9.9	13.7	8.1	102.1	3,015,276.9	1,541.3	1.0	0.6
08/24/2021 13:00	10.1	13.7	8.3	116.0	3,145,239.9	1,630.7	1.1	0.7
08/24/2021 14:00	10.9	13.1	8.2	137.9	3,307,572.4	2,004.7	1.3	1.0
08/24/2021 15:00	10.6	13.1	8.0	142.9	3,269,826.8	2,005.7	1.4	1.0
08/24/2021 16:00	9.7	13.7	7.9	111.0	3,291,900.6	1,682.7	1.0	0.7
08/24/2021 17:00	10.4	13.5	8.3	118.8	3,282,434.2	1,725.8	1.1	0.7
08/24/2021 18:00	10.8	13.1	8.2	136.1	3,284,988.3	2,015.0	1.3	1.0
08/24/2021 19:00	10.7	13.0	8.0	157.7	3,218,147.3	2,068.0	1.6	1.2
08/24/2021 20:00	9.7	13.7	7.9	113.5	3,194,084.6	1,632.7	1.1	0.7
08/24/2021 21:00	10.4	13.5	8.3	124.3	3,322,375.7	1,746.8	1.2	0.9
08/24/2021 22:00	10.8	13.1	8.2	136.2	3,329,538.3	1,993.7	1.3	1.0
08/24/2021 23:00	10.8	13.0	8.1	150.7	3,346,228.8	2,077.0	1.4	1.0
Average/Sum#:	10.1	13.5	8.0	119.2	3,209,040.7	1,748.6	1.1	0.8
Minimum:	9.4	13.0	7.7	99.6	2,950,131.4	1,508.0	1.0	0.6
Maximum:	10.9	13.7	8.3	157.7	3,363,341.4	2,077.0	1.6	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/25/2021 00:00	9.8	13.6	7.9	113.0	3,064,847.9	1,611.4	1.2	0.8
08/25/2021 01:00	9.9	13.7	8.1	105.2	3,129,917.2	1,599.9	1.0	0.6
08/25/2021 02:00	9.8	13.7	8.0	101.6	3,033,861.9	1,550.8	1.0	0.6
08/25/2021 03:00	10.0	13.2	7.7	129.5	3,379,910.6	1,974.5	1.2	1.0
08/25/2021 04:00	10.0	13.2	7.7	142.4	3,357,234.6	2,034.8	1.4	1.0
08/25/2021 05:00	9.3	13.3	7.2	123.5	3,332,728.3	1,922.6	1.2	1.0
08/25/2021 06:00	9.4	13.7	7.7	108.1	3,077,683.5	1,573.2	1.1	0.6
08/25/2021 07:00	9.9	13.7	8.1	103.1	2,995,713.7	1,531.3	1.1	0.6
08/25/2021 08:00	9.7	13.7	7.9	111.7	3,104,157.2	1,609.4	1.1	0.6
08/25/2021 09:00	10.6	13.2	8.1	133.4	3,371,694.0	1,969.7	1.2	1.0
08/25/2021 10:00	10.5	13.3	8.2	135.1	3,319,554.0	1,915.0	1.3	1.0
08/25/2021 11:00	9.7	13.7	7.9	107.6	3,162,213.1	1,639.5	1.1	0.7
08/25/2021 12:00	9.7	13.7	7.9	111.6	3,115,344.0	1,615.2	1.1	0.6
08/25/2021 13:00	10.8	13.1	8.2	137.8	3,312,192.1	2,007.5	1.3	1.0
08/25/2021 14:00	10.6	13.1	8.0	144.9	3,254,828.3	1,996.5	1.4	1.0
08/25/2021 15:00	9.6	13.7	7.9	121.6	3,107,419.6	1,588.4	1.2	0.8
08/25/2021 16:00	9.0	13.8	7.5	99.9	2,903,576.6	1,463.0	1.1	0.6
08/25/2021 17:00	10.7	13.1	8.1	132.4	3,289,093.4	1,993.5	1.3	1.0
08/25/2021 18:00	10.8	13.0	8.1	149.4	3,303,497.5	2,074.6	1.4	1.0
08/25/2021 19:00	10.6	13.1	8.0	143.4	3,248,959.4	1,992.9	1.4	1.0
08/25/2021 20:00	9.7	13.7	7.9	115.1	3,175,499.5	1,623.2	1.1	0.6
08/25/2021 21:00	10.2	13.6	8.2	117.1	3,211,203.7	1,664.9	1.1	0.7
08/25/2021 22:00	10.8	13.2	8.3	137.0	3,319,351.1	1,987.6	1.3	1.0
08/25/2021 23:00	10.5	13.2	8.0	138.9	3,295,519.8	1,925.2	1.3	1.0
Average/Sum#:	10.1	13.4	7.9	123.5	3,202,750.0	1,786.0	1.2	0.8
Minimum:	9.0	13.0	7.2	99.9	2,903,576.6	1,463.0	1.0	0.6
Maximum:	10.8	13.8	8.3	149.4	3,379,910.6	2,074.6	1.4	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/26/2021 00:00	9.9	13.7	8.1	114.1	3,186,259.3	1,628.7	1.1	0.7
08/26/2021 01:00	10.0	13.7	8.2	105.7	3,121,309.4	1,595.5	1.0	0.6
08/26/2021 02:00	8.9	13.8	7.4	90.1	2,784,297.8	1,402.9	1.0	0.6
08/26/2021 03:00	9.5	13.7	7.8	108.2	3,051,664.4	1,559.9	1.1	0.6
08/26/2021 04:00	10.6	13.2	8.1	136.7	3,352,584.7	2,007.5	1.3	1.0
08/26/2021 05:00	10.6	13.1	8.0	148.1	3,362,679.3	2,038.1	1.4	1.0
08/26/2021 06:00	10.1	13.3	7.8	155.5	3,321,881.2	1,940.6	1.5	1.2
08/26/2021 07:00	9.9	13.7	8.1	112.9	3,196,159.4	1,657.1	1.1	0.7
08/26/2021 08:00	9.7	13.7	7.9	111.9	2,978,889.3	1,522.7	1.2	0.8
08/26/2021 09:00	10.6	13.4	8.3	130.8	3,263,734.7	1,811.3	1.3	0.9
08/26/2021 10:00	10.4	13.2	8.0	133.5	3,298,429.8	1,926.9	1.3	1.0
08/26/2021 11:00	9.7	13.7	7.9	115.1	3,317,332.8	1,695.7	1.1	0.7
08/26/2021 12:00	9.8	13.7	8.0	108.1	3,280,749.6	1,677.0	1.0	0.7
08/26/2021 13:00	10.8	13.2	8.3	136.7	3,320,019.1	1,988.0	1.3	1.0
08/26/2021 14:00	10.6	13.2	8.1	136.7	3,247,515.7	1,968.3	1.3	1.0
08/26/2021 15:00	9.8	13.6	7.9	113.8	3,261,544.6	1,691.0	1.1	0.7
08/26/2021 16:00	10.3	13.7	8.4	116.0	3,134,824.6	1,625.3	1.1	0.7
08/26/2021 17:00	11.3	13.2	8.7	160.8	3,171,969.0	1,992.0	1.6	1.2
08/26/2021 18:00	11.1	13.1	8.4	185.0	3,143,437.6	2,065.9	1.9	1.4
08/26/2021 19:00	10.6	13.0	7.9	174.0	3,214,234.7	2,135.9	1.8	1.5
08/26/2021 20:00	10.6	12.9	7.8	166.2	3,258,925.7	2,141.8	1.7	1.5
08/26/2021 21:00	10.8	13.0	8.1	164.5	3,282,002.5	2,133.0	1.6	1.3
08/26/2021 22:00	10.8	13.0	8.1	163.1	3,263,538.3	2,121.0	1.6	1.3
08/26/2021 23:00	10.6	13.1	8.0	155.9	3,242,988.0	2,036.6	1.5	1.2
Average/Sum#:	10.3	13.4	8.1	135.1	3,210,707.1	1,848.4	1.3	1.0
Minimum:	8.9	12.9	7.4	90.1	2,784,297.8	1,402.9	1.0	0.6
Maximum:	11.3	13.8	8.7	185.0	3,362,679.3	2,141.8	1.9	1.5
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/27/2021 00:00	9.7	13.7	7.9	113.9	3,266,664.1	1,669.8	1.1	0.7
08/27/2021 01:00	10.5	13.7	8.6	127.9	3,202,888.0	1,637.2	1.2	0.8
08/27/2021 02:00	11.0	13.7	9.0	137.0	3,246,709.6	1,659.6	1.3	0.8
08/27/2021 03:00	10.4	13.6	8.4	126.9	3,266,173.6	1,693.4	1.2	0.8
08/27/2021 04:00	10.7	13.1	8.1	140.6	3,327,206.3	2,016.6	1.3	1.0
08/27/2021 05:00	10.7	13.1	8.1	155.6	3,272,924.3	2,031.5	1.5	1.2
08/27/2021 06:00	9.6	13.7	7.9	111.1	3,070,445.1	1,569.5	1.1	0.6
08/27/2021 07:00	9.9	13.7	8.1	110.4	3,236,732.3	1,654.5	1.1	0.7
08/27/2021 08:00	10.0	13.7	8.2	116.9	2,956,391.6	1,511.2	1.2	0.8
08/27/2021 09:00	10.9	13.3	8.5	136.3	3,291,753.9	1,923.0	1.3	1.0
08/27/2021 10:00	10.6	13.2	8.1	136.8	3,240,859.7	1,940.6	1.3	1.0
08/27/2021 11:00	9.6	13.7	7.9	111.1	3,276,974.7	1,699.0	1.1	0.7
08/27/2021 12:00	9.8	13.6	7.9	109.4	3,267,330.9	1,694.0	1.0	0.7
08/27/2021 13:00	10.7	13.1	8.1	139.1	3,250,046.8	2,017.3	1.4	1.0
08/27/2021 14:00	10.8	12.9	8.0	160.7	3,208,666.7	2,132.2	1.6	1.3
08/27/2021 15:00	10.5	12.9	7.7	155.0	3,198,584.1	2,125.5	1.6	1.3
08/27/2021 16:00	10.5	12.9	7.7	155.3	3,199,336.5	2,126.0	1.6	1.3
08/27/2021 17:00	10.6	12.9	7.8	160.4	3,196,564.0	2,147.5	1.6	1.3
08/27/2021 18:00	10.6	12.9	7.8	165.6	3,208,620.9	2,155.6	1.7	1.5
08/27/2021 19:00	10.6	12.9	7.8	165.0	3,213,979.5	2,159.2	1.7	1.5
08/27/2021 20:00	10.7	12.9	7.9	171.0	3,226,036.4	2,167.3	1.7	1.5
08/27/2021 21:00	10.7	12.9	7.9	171.1	3,233,478.9	2,172.3	1.7	1.5
08/27/2021 22:00	10.6	12.9	7.8	159.3	3,264,923.1	2,121.9	1.6	1.3
08/27/2021 23:00	10.6	13.0	7.9	157.9	3,243,784.2	2,037.1	1.6	1.2
Average/Sum#:	10.4	13.3	8.0	141.4	3,223,628.1	1,919.2	1.4	1.1
Minimum:	9.6	12.9	7.7	109.4	2,956,391.6	1,511.2	1.0	0.6
Maximum:	11.0	13.7	9.0	171.1	3,327,206.3	2,172.3	1.7	1.5
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/28/2021 00:00	9.6	13.7	7.9	114.1	3,241,231.9	1,656.8	1.1	0.7
08/28/2021 01:00	10.3	13.5	8.2	123.5	3,302,214.7	1,736.2	1.2	0.9
08/28/2021 02:00	10.8	13.2	8.3	140.5	3,333,880.4	1,996.3	1.3	1.0
08/28/2021 03:00	10.5	13.3	8.2	140.7	3,301,179.5	1,904.4	1.4	1.0
08/28/2021 04:00	9.8	13.7	8.0	108.9	3,182,737.9	1,626.9	1.1	0.7
08/28/2021 05:00	9.9	13.8	8.2	125.8	3,227,673.7	1,626.3	1.2	0.8
08/28/2021 06:00	10.2	13.8	8.5	149.4	3,195,720.5	1,610.2	1.5	1.0
08/28/2021 07:00	10.9	13.7	8.9	128.6	3,199,562.3	1,635.5	1.3	0.8
08/28/2021 08:00	10.1	13.8	8.4	126.5	3,204,850.0	1,614.8	1.2	0.8
08/28/2021 09:00	10.6	13.7	8.7	130.9	3,195,062.7	1,633.2	1.3	0.8
08/28/2021 10:00	9.5	13.8	7.9	119.4	3,149,480.5	1,609.9	1.2	0.8
08/28/2021 11:00	10.5	13.1	7.9	136.7	3,271,635.4	2,030.7	1.3	1.0
08/28/2021 12:00	10.5	13.0	7.8	149.6	3,180,176.9	2,043.6	1.5	1.2
08/28/2021 13:00	9.5	13.7	7.8	112.2	3,257,273.7	1,665.0	1.1	0.7
08/28/2021 14:00	9.8	13.7	8.0	109.7	3,247,464.6	1,683.7	1.0	0.7
08/28/2021 15:00	10.5	13.1	7.9	132.8	3,267,870.4	2,004.5	1.3	1.0
08/28/2021 16:00	10.6	13.0	7.9	153.0	3,199,584.0	2,102.8	1.5	1.3
08/28/2021 17:00	10.6	12.9	7.8	159.8	3,204,302.6	2,129.3	1.6	1.3
08/28/2021 18:00	10.6	12.9	7.8	165.5	3,204,601.9	2,152.9	1.7	1.5
08/28/2021 19:00	10.6	12.9	7.8	169.7	3,227,078.3	2,168.0	1.7	1.5
08/28/2021 20:00	10.6	12.9	7.8	170.1	3,233,478.9	2,172.3	1.7	1.5
08/28/2021 21:00	10.6	12.9	7.8	167.9	3,215,021.4	2,159.9	1.7	1.5
08/28/2021 22:00	10.6	13.0	7.9	162.0	3,253,383.1	2,114.4	1.6	1.3
08/28/2021 23:00	10.6	13.0	7.9	153.5	3,287,733.2	2,064.7	1.5	1.2
Average/Sum#:	10.3	13.3	8.1	139.6	3,232,633.3	1,880.9	1.4	1.0
Minimum:	9.5	12.9	7.8	108.9	3,149,480.5	1,609.9	1.0	0.7
Maximum:	10.9	13.8	8.9	170.1	3,333,880.4	2,172.3	1.7	1.5
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/29/2021 00:00	10.4	13.2	8.0	143.0	3,238,354.7	1,939.1	1.4	1.0
08/29/2021 01:00	9.7	13.7	7.9	112.1	3,263,142.7	1,668.0	1.1	0.7
08/29/2021 02:00	10.3	13.5	8.2	121.6	3,303,736.3	1,737.0	1.1	0.7
08/29/2021 03:00	10.6	13.1	8.0	135.2	3,296,683.0	1,998.1	1.3	1.0
08/29/2021 04:00	10.5	13.1	7.9	145.3	3,275,369.7	2,009.1	1.4	1.0
08/29/2021 05:00	9.2	13.7	7.5	112.6	3,276,641.3	1,674.9	1.1	0.7
08/29/2021 06:00	9.3	13.8	7.7	184.1	3,193,140.4	1,608.9	1.9	1.1
08/29/2021 07:00	9.2	13.8	7.6	105.9	3,140,745.1	1,582.5	1.0	0.6
08/29/2021 08:00	8.9	13.8	7.4	98.9	2,991,100.7	1,507.1	1.0	0.6
08/29/2021 09:00	8.7	13.9	7.3	95.6	2,896,233.3	1,459.3	1.0	0.6
08/29/2021 10:00	10.4	13.3	8.1	137.6	3,253,361.1	1,829.3	1.3	0.9
08/29/2021 11:00	10.4	13.2	8.0	129.8	3,241,861.7	1,941.2	1.3	1.0
08/29/2021 12:00	9.9	13.6	8.0	117.6	3,216,435.5	1,691.1	1.1	0.7
08/29/2021 13:00	9.8	13.6	7.9	109.1	3,233,770.3	1,676.6	1.0	0.7
08/29/2021 14:00	10.6	13.0	7.9	134.2	3,193,906.9	2,029.1	1.3	1.0
08/29/2021 15:00	10.6	12.9	7.8	146.1	3,181,477.2	2,090.9	1.5	1.3
08/29/2021 16:00	10.5	12.9	7.7	149.8	3,167,433.5	2,104.8	1.5	1.3
08/29/2021 17:00	10.6	12.8	7.7	156.6	3,178,553.1	2,135.4	1.6	1.3
08/29/2021 18:00	10.4	12.8	7.6	156.7	3,189,568.0	2,142.8	1.6	1.3
08/29/2021 19:00	10.4	12.8	7.6	160.0	3,170,585.6	2,153.2	1.6	1.3
08/29/2021 20:00	10.4	12.8	7.6	158.5	3,167,493.3	2,151.1	1.6	1.3
08/29/2021 21:00	10.4	12.9	7.7	158.7	3,203,411.1	2,152.1	1.6	1.3
08/29/2021 22:00	10.4	12.9	7.7	153.6	3,213,126.1	2,111.7	1.5	1.3
08/29/2021 23:00	10.3	13.1	7.8	144.2	3,214,764.0	1,995.4	1.4	1.0
Average/Sum#:	10.1	13.3	7.8	136.1	3,195,870.6	1,891.2	1.3	1.0
Minimum:	8.7	12.8	7.3	95.6	2,896,233.3	1,459.3	1.0	0.6
Maximum:	10.6	13.9	8.2	184.1	3,303,736.3	2,153.2	1.9	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/30/2021 00:00	9.7	13.7	7.9	109.5	3,142,829.0	1,606.5	1.1	0.6
08/30/2021 01:00	10.0	13.7	8.2	112.4	3,226,168.2	1,649.1	1.1	0.7
08/30/2021 02:00	10.6	13.2	8.1	126.9	3,290,726.8	1,922.4	1.2	1.0
08/30/2021 03:00	10.6	13.1	8.0	145.6	3,234,097.1	2,007.4	1.4	1.0
08/30/2021 04:00	9.4	13.7	7.7	107.3	3,159,262.1	1,614.9	1.1	0.6
08/30/2021 05:00	9.5	13.7	7.8	99.0	2,964,216.9	1,515.2	1.0	0.6
08/30/2021 06:00	10.5	13.1	7.9	139.3	3,297,012.9	1,998.3	1.3	1.0
08/30/2021 07:00	10.8	13.1	8.2	141.2	3,252,465.4	1,971.3	1.4	1.0
08/30/2021 08:00	9.7	13.7	7.9	113.5	3,235,362.9	1,653.8	1.1	0.7
08/30/2021 09:00	10.0	13.6	8.1	109.0	3,136,367.6	1,626.1	1.1	0.7
08/30/2021 10:00	10.5	13.2	8.0	127.5	3,215,750.8	1,878.6	1.3	0.9
08/30/2021 11:00	10.6	13.0	7.9	146.8	3,187,610.7	2,025.1	1.5	1.2
08/30/2021 12:00	9.7	13.6	7.8	113.5	3,229,334.1	1,674.3	1.1	0.7
08/30/2021 13:00	9.9	13.6	8.0	111.9	3,201,945.7	1,660.1	1.1	0.7
08/30/2021 14:00	10.6	13.0	7.9	135.9	3,205,397.5	2,036.4	1.4	1.0
08/30/2021 15:00	10.4	12.9	7.7	148.9	3,198,823.2	2,102.3	1.5	1.3
08/30/2021 16:00	10.4	12.9	7.7	151.4	3,171,045.1	2,107.2	1.5	1.3
08/30/2021 17:00	10.5	12.8	7.6	153.3	3,171,557.1	2,130.7	1.6	1.3
08/30/2021 18:00	10.4	12.8	7.6	156.1	3,188,674.9	2,142.2	1.6	1.3
08/30/2021 19:00	10.4	12.9	7.7	159.9	3,210,555.9	2,156.9	1.6	1.3
08/30/2021 20:00	10.4	12.9	7.7	162.8	3,236,902.5	2,174.6	1.6	1.3
08/30/2021 21:00	10.4	12.9	7.7	158.2	3,250,652.3	2,160.1	1.6	1.3
08/30/2021 22:00	10.4	12.9	7.7	154.7	3,254,614.0	2,115.2	1.5	1.3
08/30/2021 23:00	10.3	13.0	7.7	144.5	3,214,484.9	2,018.7	1.4	1.0
Average/Sum#:	10.2	13.2	7.9	134.5	3,203,160.7	1,914.5	1.3	1.0
Minimum:	9.4	12.8	7.6	99.0	2,964,216.9	1,515.2	1.0	0.6
Maximum:	10.8	13.7	8.2	162.8	3,297,012.9	2,174.6	1.6	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/31/2021 00:00	9.6	13.7	7.9	110.0	3,200,540.4	1,636.0	1.1	0.7
08/31/2021 01:00	9.7	13.7	7.9	107.4	3,243,775.1	1,658.1	1.0	0.7
08/31/2021 02:00	7.9	13.8	6.6	84.2	2,580,074.9	1,300.0	1.0	0.5
08/31/2021 03:00	9.8	13.7	8.0	105.4	3,178,434.0	1,624.7	1.0	0.6
08/31/2021 04:00	10.2	13.4	8.0	122.6	3,293,191.8	1,803.6	1.2	0.9
08/31/2021 05:00	10.1	13.3	7.8	127.3	3,274,855.5	1,865.3	1.2	0.9
08/31/2021 06:00	10.2	13.5	8.1	141.7	3,336,450.4	1,754.2	1.3	0.9
08/31/2021 07:00	10.8	13.2	8.3	133.0	3,346,873.2	1,955.2	1.3	1.0
08/31/2021 08:00	10.3	13.0	7.7	143.9	3,273,890.9	2,032.1	1.4	1.0
08/31/2021 09:00	9.4	13.7	7.7	110.9	3,232,819.7	1,652.5	1.1	0.7
08/31/2021 10:00	10.1	13.6	8.2	116.9	3,218,918.8	1,668.9	1.1	0.7
08/31/2021 11:00	10.5	13.2	8.0	130.0	3,267,079.2	1,956.3	1.3	1.0
08/31/2021 12:00	10.4	13.0	7.8	142.9	3,227,223.7	2,026.7	1.4	1.0
08/31/2021 13:00	9.5	13.7	7.8	112.8	3,141,961.0	1,629.0	1.1	0.7
08/31/2021 14:00	9.8	13.6	7.9	113.9	3,249,393.3	1,684.7	1.1	0.7
08/31/2021 15:00	10.3	13.1	7.8	124.9	3,236,626.3	1,961.7	1.2	1.0
08/31/2021 16:00	10.2	12.9	7.5	143.0	3,227,071.6	2,097.3	1.4	1.0
08/31/2021 17:00	10.2	12.9	7.5	148.3	3,211,148.0	2,110.4	1.5	1.3
08/31/2021 18:00	10.2	12.9	7.5	148.5	3,227,581.1	2,121.2	1.5	1.3
08/31/2021 19:00	10.1	13.0	7.5	145.9	3,162,139.4	2,055.1	1.5	1.2
08/31/2021 20:00	9.4	13.7	7.7	109.1	3,179,020.9	1,625.0	1.1	0.7
08/31/2021 21:00	9.9	13.6	8.0	110.1	3,238,785.1	1,679.2	1.1	0.7
08/31/2021 22:00	10.2	13.2	7.8	130.0	3,312,003.0	1,983.2	1.2	1.0
08/31/2021 23:00	10.0	13.1	7.6	138.8	3,306,918.2	2,052.6	1.3	1.0
Average/Sum#:	10.0	13.4	7.8	125.1	3,215,282.3	1,830.5	1.2	0.9
Minimum:	7.9	12.9	6.6	84.2	2,580,074.9	1,300.0	1.0	0.5
Maximum:	10.8	13.8	8.3	148.5	3,346,873.2	2,121.2	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/01/2021 00:00	9.5	13.0	7.1	142.9	3,314,962.4	2,081.8	1.4	1.0
09/01/2021 01:00	9.1	13.3	7.1	128.9	3,305,166.4	1,906.7	1.2	1.0
09/01/2021 02:00	8.7	13.7	7.1	102.5	3,083,356.8	1,576.1	1.0	0.6
09/01/2021 03:00	9.5	13.6	7.7	112.2	3,232,805.9	1,676.1	1.1	0.7
09/01/2021 04:00	10.0	13.2	7.7	132.5	3,342,409.9	1,977.0	1.3	1.0
09/01/2021 05:00	9.7	13.1	7.3	146.8	3,348,806.5	2,078.6	1.4	1.0
09/01/2021 06:00	9.3	13.2	7.1	155.3	3,365,702.8	1,966.2	1.5	1.2
09/01/2021 07:00	9.0	13.7	7.4	107.4	3,250,035.3	1,661.3	1.0	0.7
09/01/2021 08:00	9.2	13.7	7.5	106.3	3,125,417.7	1,597.6	1.1	0.6
09/01/2021 09:00	10.1	13.3	7.8	123.0	3,298,712.1	1,854.8	1.2	0.9
09/01/2021 10:00	10.2	13.2	7.8	133.7	3,338,485.5	1,950.3	1.3	1.0
09/01/2021 11:00	8.4	13.6	6.8	99.8	2,788,490.4	1,466.1	1.1	0.6
09/01/2021 12:00	9.1	13.7	7.5	107.3	2,982,997.6	1,524.8	1.1	0.6
09/01/2021 13:00	10.4	13.2	8.0	128.0	3,290,676.1	1,946.4	1.2	1.0
09/01/2021 14:00	10.2	13.2	7.8	130.1	3,248,374.8	1,945.1	1.3	1.0
09/01/2021 15:00	9.5	13.6	7.7	111.4	3,115,909.5	1,661.0	1.1	0.7
09/01/2021 16:00	9.8	13.7	8.0	111.0	3,216,990.0	1,667.9	1.1	0.7
09/01/2021 17:00	10.5	13.1	7.9	133.9	3,276,510.9	2,009.8	1.3	1.0
09/01/2021 18:00	10.3	13.0	7.7	146.3	3,281,045.3	2,060.5	1.4	1.0
09/01/2021 19:00	10.2	13.0	7.6	146.4	3,261,300.1	2,048.1	1.4	1.0
09/01/2021 20:00	9.3	13.7	7.6	109.9	3,242,601.3	1,657.5	1.1	0.7
09/01/2021 21:00	8.2	13.8	6.8	85.9	2,719,002.0	1,370.0	1.0	0.5
09/01/2021 22:00	9.2	13.7	7.5	103.4	3,158,675.2	1,614.6	1.0	0.6
09/01/2021 23:00	9.0	13.7	7.4	106.5	3,287,009.8	1,680.2	1.0	0.7
Average/Sum#:	9.5	13.4	7.5	121.3	3,203,143.5	1,790.8	1.2	0.8
Minimum:	8.2	13.0	6.8	85.9	2,719,002.0	1,370.0	1.0	0.5
Maximum:	10.5	13.8	8.0	155.3	3,365,702.8	2,081.8	1.5	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/02/2021 00:00	9.7	13.4	7.6	123.7	3,279,591.2	1,820.1	1.2	0.9
09/02/2021 01:00	9.4	13.4	7.4	126.2	3,224,116.6	1,836.4	1.2	0.9
09/02/2021 02:00	7.7	13.8	6.4	83.4	2,678,911.6	1,349.8	1.0	0.5
09/02/2021 03:00	9.3	13.7	7.6	105.3	3,233,015.3	1,652.6	1.0	0.7
09/02/2021 04:00	8.3	13.8	6.9	86.6	2,737,459.5	1,379.3	1.0	0.6
09/02/2021 05:00	9.1	13.7	7.5	104.0	3,185,281.1	1,628.2	1.0	0.7
09/02/2021 06:00	9.4	13.5	7.5	122.5	3,266,898.8	1,789.2	1.2	0.9
09/02/2021 07:00	9.7	13.4	7.6	124.0	3,279,230.8	1,819.9	1.2	0.9
09/02/2021 08:00	7.6	13.8	6.3	83.8	2,670,377.5	1,345.5	1.0	0.5
09/02/2021 09:00	8.9	13.8	7.4	90.8	2,845,028.8	1,433.5	1.0	0.6
09/02/2021 10:00	9.4	13.8	7.8	96.1	2,953,590.4	1,488.2	1.0	0.6
09/02/2021 11:00	9.1	13.8	7.6	91.1	2,795,411.9	1,408.5	1.0	0.6
09/02/2021 12:00	9.8	13.7	8.0	113.4	3,253,948.0	1,663.3	1.1	0.7
09/02/2021 13:00	10.6	13.2	8.1	136.0	3,317,347.1	1,986.4	1.3	1.0
09/02/2021 14:00	10.4	13.2	8.0	138.2	3,253,718.9	1,948.3	1.4	1.0
09/02/2021 15:00	9.7	13.7	7.9	113.3	3,217,951.7	1,644.9	1.1	0.7
09/02/2021 16:00	10.6	13.7	8.7	124.0	3,133,047.4	1,601.5	1.2	0.8
09/02/2021 17:00	10.7	13.1	8.1	140.4	3,276,836.9	2,010.0	1.4	1.0
09/02/2021 18:00	10.6	13.1	8.0	147.7	3,261,459.3	2,048.2	1.4	1.0
09/02/2021 19:00	10.5	13.1	7.9	148.2	3,243,602.5	2,013.3	1.5	1.2
09/02/2021 20:00	9.4	13.7	7.7	104.3	3,034,644.4	1,551.2	1.1	0.6
09/02/2021 21:00	8.5	13.8	7.1	86.9	2,733,490.2	1,377.3	1.0	0.6
09/02/2021 22:00	9.3	13.8	7.7	101.6	3,151,859.2	1,588.1	1.0	0.6
09/02/2021 23:00	10.2	13.4	8.0	132.1	3,280,958.2	1,796.9	1.3	0.9
Average/Sum#:	9.5	13.6	7.6	113.5	3,096,157.4	1,674.2	1.2	0.8
Minimum:	7.6	13.1	6.3	83.4	2,670,377.5	1,345.5	1.0	0.5
Maximum:	10.7	13.8	8.7	148.2	3,317,347.1	2,048.2	1.5	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/03/2021 00:00	10.2	13.3	7.9	135.3	3,223,694.3	1,859.7	1.3	0.9
09/03/2021 01:00	9.4	13.6	7.6	106.8	3,054,587.9	1,583.7	1.1	0.6
09/03/2021 02:00	10.1	13.6	8.2	123.6	3,382,092.5	1,753.5	1.1	0.7
09/03/2021 03:00	10.3	13.3	8.0	133.1	3,389,592.1	1,905.9	1.2	1.0
09/03/2021 04:00	9.5	13.7	7.8	103.2	3,043,839.1	1,555.9	1.1	0.6
09/03/2021 05:00	10.0	13.6	8.1	118.5	3,287,379.3	1,728.4	1.1	0.7
09/03/2021 06:00	10.0	13.2	7.7	136.2	3,372,503.4	1,994.8	1.3	1.0
09/03/2021 07:00	10.1	13.3	7.8	141.8	3,342,955.6	1,928.5	1.4	1.0
09/03/2021 08:00	8.6	13.8	7.1	108.7	3,295,030.7	1,684.3	1.0	0.7
09/03/2021 09:00	8.8	13.8	7.3	95.8	2,979,192.7	1,501.1	1.0	0.6
09/03/2021 10:00	9.1	13.8	7.6	101.3	3,149,279.1	1,586.8	1.0	0.6
09/03/2021 11:00	9.3	13.8	7.7	104.8	3,142,928.2	1,583.6	1.0	0.6
09/03/2021 12:00	9.5	13.8	7.9	103.8	3,159,797.9	1,592.1	1.0	0.6
09/03/2021 13:00	10.4	13.8	8.6	126.2	3,128,156.6	1,599.0	1.3	0.8
09/03/2021 14:00	9.6	13.8	8.0	114.8	3,021,267.7	1,522.3	1.2	0.8
09/03/2021 15:00	10.7	13.1	8.1	134.9	3,284,825.2	2,014.9	1.3	1.0
09/03/2021 16:00	10.8	13.0	8.1	152.7	3,272,924.3	2,079.3	1.5	1.2
09/03/2021 17:00	10.9	12.9	8.0	162.0	3,282,310.2	2,133.2	1.6	1.3
09/03/2021 18:00	10.8	13.0	8.1	164.1	3,282,002.5	2,133.0	1.6	1.3
09/03/2021 19:00	10.7	13.1	8.1	154.3	3,223,184.3	2,047.7	1.5	1.2
09/03/2021 20:00	9.6	13.7	7.9	118.2	3,255,904.3	1,664.3	1.1	0.7
09/03/2021 21:00	10.4	13.5	8.3	122.8	3,321,424.7	1,746.3	1.2	0.9
09/03/2021 22:00	10.7	13.2	8.2	135.0	3,331,420.7	1,970.5	1.3	1.0
09/03/2021 23:00	10.5	13.3	8.2	138.1	3,327,527.9	1,919.6	1.3	1.0
Average/Sum#:	10.0	13.5	7.9	126.5	3,231,409.2	1,795.4	1.2	0.9
Minimum:	8.6	12.9	7.1	95.8	2,979,192.7	1,501.1	1.0	0.6
Maximum:	10.9	13.8	8.6	164.1	3,389,592.1	2,133.2	1.6	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/04/2021 00:00	9.7	13.7	7.9	107.6	3,151,632.4	1,611.0	1.1	0.6
09/04/2021 01:00	10.2	13.6	8.2	113.5	3,145,047.0	1,630.6	1.1	0.7
09/04/2021 02:00	10.8	13.2	8.3	137.9	3,341,902.7	1,976.7	1.3	1.0
09/04/2021 03:00	14.2	14.4	12.9	152.6	2,530,414.3	1,256.5	1.9	0.9
09/04/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/04/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/04/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/04/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/04/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/04/2021 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/04/2021 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/04/2021 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/04/2021 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/04/2021 13:00	31.9	17.4	53.8	59.3	1,564,339.1	342.7	1.0	0.1
09/04/2021 14:00	25.0	14.4	22.7	170.8	2,511,698.2	1,155.5	2.1	0.9
09/04/2021 15:00	9.8	13.7	8.0	108.5	3,310,290.0	1,692.1	1.0	0.7
09/04/2021 16:00	11.1	13.7	9.1	136.6	3,070,836.4	1,569.7	1.4	0.8
09/04/2021 17:00	11.0	13.1	8.3	142.7	3,269,898.8	2,053.5	1.4	1.0
09/04/2021 18:00	11.0	12.9	8.1	163.2	3,239,064.9	2,152.4	1.6	1.3
09/04/2021 19:00	10.9	12.9	8.0	168.1	3,259,230.0	2,165.8	1.7	1.5
09/04/2021 20:00	10.8	13.0	8.1	161.9	3,254,306.3	2,115.0	1.6	1.3
09/04/2021 21:00	10.8	13.0	8.1	153.5	3,271,822.4	2,078.6	1.5	1.2
09/04/2021 22:00	10.8	13.1	8.2	152.4	3,328,027.3	2,041.4	1.5	1.2
09/04/2021 23:00	10.8	13.1	8.2	147.4	3,314,170.0	2,032.9	1.4	1.0
Average/Sum#:	13.3	13.7	12.5	138.4	3,037,512.0	1,725.0	1.4	0.9
Minimum:	9.7	12.9	7.9	59.3	1,564,339.1	342.7	1.0	0.1
Maximum:	31.9	17.4	53.8	170.8	3,341,902.7	2,165.8	2.1	1.5
%SI	37.50	37.50	37.50	37.50	37.50	37.50	37.50	37.50

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/05/2021 00:00	10.6	13.3	8.2	143.2	3,299,628.1	1,927.6	1.4	1.0
09/05/2021 01:00	9.9	13.7	8.1	112.9	3,169,826.2	1,620.3	1.1	0.6
09/05/2021 02:00	10.7	13.7	8.8	132.6	3,180,585.9	1,625.8	1.3	0.8
09/05/2021 03:00	10.8	13.2	8.3	139.6	3,388,640.6	1,979.6	1.3	1.0
09/05/2021 04:00	10.6	13.3	8.2	139.6	3,349,296.0	1,907.7	1.3	1.0
09/05/2021 05:00	10.0	13.7	8.2	109.7	3,151,632.4	1,611.0	1.1	0.6
09/05/2021 06:00	10.0	13.7	8.2	107.0	3,131,286.7	1,600.6	1.1	0.6
09/05/2021 07:00	10.4	13.7	8.5	103.5	3,080,618.0	1,574.7	1.0	0.6
09/05/2021 08:00	10.2	13.7	8.4	106.1	3,140,481.4	1,605.3	1.0	0.6
09/05/2021 09:00	10.2	13.7	8.4	105.9	3,118,961.9	1,594.3	1.0	0.6
09/05/2021 10:00	9.9	13.7	8.1	108.6	3,251,404.8	1,662.0	1.0	0.7
09/05/2021 11:00	9.9	13.7	8.1	109.5	3,302,856.0	1,688.3	1.0	0.7
09/05/2021 12:00	9.8	13.7	8.0	109.1	3,282,705.9	1,678.0	1.0	0.7
09/05/2021 13:00	9.9	13.7	8.1	113.7	3,273,310.0	1,697.1	1.1	0.7
09/05/2021 14:00	10.7	13.2	8.2	132.4	3,235,471.3	1,961.0	1.3	1.0
09/05/2021 15:00	10.9	13.0	8.1	154.6	3,276,970.3	2,105.8	1.5	1.3
09/05/2021 16:00	10.8	13.0	8.1	158.5	3,230,776.4	2,123.3	1.6	1.3
09/05/2021 17:00	10.8	12.9	8.0	161.2	3,236,958.1	2,151.0	1.6	1.3
09/05/2021 18:00	10.8	12.9	8.0	165.0	3,263,490.5	2,144.8	1.6	1.3
09/05/2021 19:00	10.9	12.9	8.0	171.8	3,264,497.1	2,169.3	1.7	1.5
09/05/2021 20:00	10.8	13.0	8.1	163.8	3,255,691.1	2,115.9	1.6	1.3
09/05/2021 21:00	10.8	13.0	8.1	157.0	3,275,600.2	2,081.0	1.5	1.2
09/05/2021 22:00	10.8	13.1	8.2	154.6	3,287,255.5	2,064.4	1.5	1.2
09/05/2021 23:00	10.6	13.2	8.1	146.9	3,280,348.9	1,988.2	1.4	1.0
Average/Sum#:	10.5	13.4	8.2	133.6	3,238,678.9	1,861.5	1.3	0.9
Minimum:	9.8	12.9	8.0	103.5	3,080,618.0	1,574.7	1.0	0.6
Maximum:	10.9	13.7	8.8	171.8	3,388,640.6	2,169.3	1.7	1.5
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/06/2021 00:00	9.8	13.7	8.0	109.7	3,152,610.6	1,611.5	1.1	0.6
09/06/2021 01:00	10.1	13.7	8.3	124.3	3,134,416.8	1,602.2	1.2	0.8
09/06/2021 02:00	10.8	13.2	8.3	135.0	3,340,710.8	1,951.6	1.3	1.0
09/06/2021 03:00	10.7	13.2	8.2	141.9	3,273,769.6	1,936.4	1.4	1.0
09/06/2021 04:00	9.9	13.7	8.1	113.4	3,080,422.3	1,574.6	1.1	0.6
09/06/2021 05:00	9.9	13.7	8.1	106.8	3,209,930.8	1,640.8	1.0	0.7
09/06/2021 06:00	9.8	13.7	8.0	103.3	3,127,374.0	1,598.6	1.0	0.6
09/06/2021 07:00	9.7	13.8	8.1	102.6	3,190,758.8	1,607.7	1.0	0.6
09/06/2021 08:00	9.7	13.8	8.1	114.2	3,327,899.7	1,676.8	1.1	0.7
09/06/2021 09:00	8.8	13.9	7.4	99.7	3,059,770.4	1,541.7	1.0	0.6
09/06/2021 10:00	10.4	13.7	8.5	136.0	3,247,296.5	1,659.9	1.3	0.8
09/06/2021 11:00	10.4	13.8	8.6	132.1	3,227,537.6	1,649.8	1.3	0.8
09/06/2021 12:00	10.6	13.1	8.0	142.0	3,310,462.6	2,054.8	1.4	1.0
09/06/2021 13:00	10.8	13.0	8.1	160.4	3,253,600.2	2,138.3	1.6	1.3
09/06/2021 14:00	10.7	12.9	7.9	160.2	3,246,296.6	2,133.5	1.6	1.3
09/06/2021 15:00	10.8	12.9	8.0	164.4	3,253,752.3	2,138.4	1.6	1.3
09/06/2021 16:00	10.7	12.9	7.9	164.4	3,230,336.7	2,146.6	1.6	1.3
09/06/2021 17:00	10.7	12.9	7.9	163.1	3,216,063.4	2,160.6	1.6	1.3
09/06/2021 18:00	10.8	12.9	8.0	167.0	3,230,055.3	2,170.0	1.7	1.5
09/06/2021 19:00	10.8	12.9	8.0	170.2	3,236,307.1	2,174.2	1.7	1.5
09/06/2021 20:00	10.9	12.9	8.0	175.4	3,247,024.3	2,181.4	1.8	1.5
09/06/2021 21:00	10.8	12.9	8.0	172.0	3,282,053.8	2,157.0	1.7	1.5
09/06/2021 22:00	10.8	13.0	8.1	161.3	3,271,056.9	2,102.0	1.6	1.3
09/06/2021 23:00	10.7	13.1	8.1	150.8	3,269,989.8	2,005.8	1.5	1.2
Average/Sum#:	10.4	13.3	8.1	140.4	3,225,812.4	1,900.6	1.4	1.0
Minimum:	8.8	12.9	7.4	99.7	3,059,770.4	1,541.7	1.0	0.6
Maximum:	10.9	13.9	8.6	175.4	3,340,710.8	2,181.4	1.8	1.5
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/07/2021 00:00	9.6	13.7	7.9	114.2	3,272,728.6	1,672.9	1.1	0.7
09/07/2021 01:00	10.3	13.6	8.3	118.0	3,169,349.5	1,643.2	1.2	0.8
09/07/2021 02:00	10.9	13.2	8.4	142.8	3,300,642.7	2,000.5	1.4	1.0
09/07/2021 03:00	10.6	13.2	8.1	142.6	3,257,201.3	1,926.6	1.4	1.0
09/07/2021 04:00	9.6	13.7	7.9	116.2	3,276,641.3	1,674.9	1.1	0.7
09/07/2021 05:00	10.5	13.5	8.4	125.4	3,330,364.0	1,751.0	1.2	0.9
09/07/2021 06:00	10.6	13.2	8.1	139.1	3,307,827.9	1,980.7	1.3	1.0
09/07/2021 07:00	10.9	13.2	8.4	145.6	3,295,409.9	1,949.2	1.4	1.0
09/07/2021 08:00	9.6	13.7	7.9	109.2	3,255,121.8	1,663.9	1.0	0.7
09/07/2021 09:00	10.0	13.6	8.1	117.8	3,286,811.4	1,704.1	1.1	0.7
09/07/2021 10:00	10.8	13.2	8.3	137.8	3,256,558.0	1,950.0	1.3	1.0
09/07/2021 11:00	10.7	12.9	7.9	158.9	3,219,668.9	2,116.0	1.6	1.3
09/07/2021 12:00	10.7	13.0	8.0	158.9	3,240,458.1	2,106.0	1.6	1.3
09/07/2021 13:00	10.6	13.0	7.9	155.1	3,209,838.4	2,086.1	1.6	1.3
09/07/2021 14:00	10.5	13.0	7.8	153.0	3,193,990.0	2,075.8	1.5	1.2
09/07/2021 15:00	10.6	13.0	7.9	151.7	3,171,282.6	2,084.2	1.5	1.3
09/07/2021 16:00	10.6	12.9	7.8	155.3	3,161,414.0	2,100.8	1.6	1.3
09/07/2021 17:00	10.7	13.0	8.0	161.4	3,193,649.8	2,098.9	1.6	1.3
09/07/2021 18:00	10.8	13.0	8.1	159.3	3,257,341.2	2,069.4	1.6	1.2
09/07/2021 19:00	10.8	13.1	8.2	157.8	3,271,650.4	2,054.6	1.5	1.2
09/07/2021 20:00	10.8	13.1	8.2	157.3	3,275,472.0	2,057.0	1.5	1.2
09/07/2021 21:00	10.9	12.9	8.0	168.3	3,262,729.7	2,144.3	1.7	1.5
09/07/2021 22:00	10.9	12.9	8.0	175.4	3,267,356.3	2,171.2	1.7	1.5
09/07/2021 23:00	10.9	12.9	8.0	176.6	3,267,356.3	2,171.2	1.8	1.5
Average/Sum#:	10.5	13.2	8.1	145.7	3,250,036.0	1,968.9	1.4	1.1
Minimum:	9.6	12.9	7.8	109.2	3,161,414.0	1,643.2	1.0	0.7
Maximum:	10.9	13.7	8.4	176.6	3,330,364.0	2,171.2	1.8	1.5
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/08/2021 00:00	10.9	12.9	8.0	174.8	3,281,749.5	2,156.8	1.7	1.5
09/08/2021 01:00	10.8	13.0	8.1	161.6	3,261,719.9	2,096.0	1.6	1.3
09/08/2021 02:00	10.8	13.1	8.2	157.0	3,265,121.7	2,050.5	1.5	1.2
09/08/2021 03:00	10.8	13.1	8.2	156.5	3,282,000.7	2,061.1	1.5	1.2
09/08/2021 04:00	11.0	12.9	8.1	173.2	3,269,120.3	2,148.5	1.7	1.5
09/08/2021 05:00	10.9	12.9	8.0	178.0	3,262,540.7	2,168.0	1.8	1.5
09/08/2021 06:00	10.9	12.9	8.0	168.7	3,296,312.2	2,142.3	1.7	1.5
09/08/2021 07:00	11.0	13.2	8.4	147.4	3,243,555.9	1,965.9	1.4	1.0
09/08/2021 08:00	9.8	13.7	8.0	112.2	3,278,988.9	1,676.1	1.1	0.7
09/08/2021 09:00	10.0	13.6	8.1	117.0	3,250,936.3	1,685.5	1.1	0.7
09/08/2021 10:00	10.8	13.2	8.3	142.5	3,240,751.1	1,964.2	1.4	1.0
09/08/2021 11:00	10.8	12.9	8.0	158.2	3,211,148.0	2,110.4	1.6	1.3
09/08/2021 12:00	10.7	13.0	8.0	156.5	3,221,378.5	2,093.6	1.6	1.3
09/08/2021 13:00	10.6	12.9	7.8	155.1	3,185,129.0	2,093.3	1.6	1.3
09/08/2021 14:00	10.6	12.9	7.8	153.7	3,151,632.4	2,094.3	1.6	1.3
09/08/2021 15:00	10.5	12.9	7.7	152.8	3,150,880.0	2,093.8	1.6	1.3
09/08/2021 16:00	10.5	12.9	7.7	154.4	3,144,317.5	2,112.4	1.6	1.3
09/08/2021 17:00	10.5	12.8	7.6	159.6	3,138,632.3	2,131.5	1.7	1.5
09/08/2021 18:00	10.5	12.9	7.7	161.3	3,176,022.6	2,133.7	1.6	1.3
09/08/2021 19:00	10.6	12.9	7.8	165.3	3,201,773.7	2,151.0	1.7	1.5
09/08/2021 20:00	10.6	12.9	7.8	167.1	3,222,962.9	2,141.7	1.7	1.5
09/08/2021 21:00	10.6	13.0	7.9	160.2	3,230,764.5	2,099.7	1.6	1.3
09/08/2021 22:00	10.6	13.0	7.9	154.2	3,228,573.6	2,074.7	1.5	1.2
09/08/2021 23:00	10.6	12.9	7.8	163.9	3,220,254.1	2,139.9	1.7	1.5
Average/Sum#:	10.6	13.0	8.0	156.3	3,225,677.8	2,066.0	1.6	1.3
Minimum:	9.8	12.8	7.6	112.2	3,138,632.3	1,676.1	1.1	0.7
Maximum:	11.0	13.7	8.4	178.0	3,296,312.2	2,168.0	1.8	1.5
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/09/2021 00:00	10.6	12.9	7.8	165.4	3,200,880.6	2,150.4	1.7	1.5
09/09/2021 01:00	10.7	12.9	7.9	171.9	3,219,487.0	2,162.9	1.7	1.5
09/09/2021 02:00	10.7	12.9	7.9	173.5	3,268,409.7	2,171.9	1.7	1.5
09/09/2021 03:00	10.5	12.9	7.7	171.2	3,260,885.4	2,166.9	1.7	1.5
09/09/2021 04:00	10.6	12.9	7.8	173.9	3,265,550.5	2,170.0	1.7	1.5
09/09/2021 05:00	10.4	12.9	7.7	170.9	3,263,443.6	2,168.6	1.7	1.5
09/09/2021 06:00	10.6	12.9	7.8	185.9	3,253,662.0	2,162.1	1.9	1.5
09/09/2021 07:00	10.8	12.9	8.0	159.3	3,261,999.7	2,120.0	1.6	1.3
09/09/2021 08:00	10.5	12.9	7.7	159.9	3,245,689.7	2,109.4	1.6	1.3
09/09/2021 09:00	10.3	12.9	7.6	155.7	3,248,459.3	2,111.2	1.6	1.3
09/09/2021 10:00	10.3	12.9	7.6	156.1	3,207,191.9	2,107.8	1.6	1.3
09/09/2021 11:00	10.4	12.9	7.7	151.6	3,188,932.9	2,095.8	1.5	1.3
09/09/2021 12:00	10.4	12.9	7.7	151.4	3,162,153.1	2,078.2	1.5	1.2
09/09/2021 13:00	10.4	12.9	7.7	151.4	3,142,603.2	2,088.3	1.6	1.3
09/09/2021 14:00	10.3	12.9	7.6	148.4	3,157,588.3	2,075.2	1.5	1.2
09/09/2021 15:00	10.3	12.9	7.6	146.3	3,147,545.9	2,068.6	1.5	1.2
09/09/2021 16:00	10.3	12.9	7.6	147.8	3,137,938.2	2,085.2	1.5	1.3
09/09/2021 17:00	10.3	12.9	7.6	151.1	3,153,137.3	2,095.3	1.6	1.3
09/09/2021 18:00	10.3	12.8	7.5	157.8	3,168,133.5	2,128.4	1.6	1.3
09/09/2021 19:00	10.2	12.8	7.4	156.0	3,180,488.1	2,136.7	1.6	1.3
09/09/2021 20:00	10.3	12.9	7.6	159.7	3,194,033.5	2,145.8	1.6	1.3
09/09/2021 21:00	10.2	12.9	7.5	162.2	3,204,155.4	2,152.6	1.6	1.3
09/09/2021 22:00	10.1	12.9	7.4	157.0	3,197,831.7	2,125.0	1.6	1.3
09/09/2021 23:00	10.3	12.9	7.6	159.5	3,217,695.8	2,138.2	1.6	1.3
Average/Sum#:	10.4	12.9	7.7	160.2	3,206,162.3	2,125.6	1.6	1.3
Minimum:	10.1	12.8	7.4	146.3	3,137,938.2	2,068.6	1.5	1.2
Maximum:	10.8	12.9	8.0	185.9	3,268,409.7	2,171.9	1.9	1.5
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/10/2021 00:00	10.1	13.0	7.5	154.5	3,196,983.5	2,054.4	1.6	1.2
09/10/2021 01:00	9.1	13.7	7.5	101.7	3,050,099.4	1,559.1	1.0	0.6
09/10/2021 02:00	10.0	13.5	8.0	118.9	3,262,843.8	1,715.5	1.1	0.7
09/10/2021 03:00	10.4	13.1	7.9	136.4	3,284,173.1	2,014.5	1.3	1.0
09/10/2021 04:00	10.3	12.9	7.6	157.3	3,224,467.7	2,142.7	1.6	1.3
09/10/2021 05:00	10.0	12.9	7.4	151.5	3,242,766.2	2,107.5	1.5	1.3
09/10/2021 06:00	10.1	12.8	7.4	155.4	3,238,011.5	2,151.7	1.6	1.3
09/10/2021 07:00	9.7	13.6	7.8	111.7	2,990,896.9	1,616.2	1.2	0.8
09/10/2021 08:00	9.2	13.7	7.5	96.9	2,914,330.7	1,489.7	1.0	0.6
09/10/2021 09:00	9.1	13.7	7.5	103.1	3,105,700.2	1,610.2	1.0	0.6
09/10/2021 10:00	9.1	13.6	7.4	108.8	3,050,730.3	1,581.7	1.1	0.6
09/10/2021 11:00	10.2	13.1	7.7	130.7	3,235,591.2	1,984.7	1.3	1.0
09/10/2021 12:00	10.1	13.1	7.6	136.1	3,168,686.9	1,966.8	1.4	1.0
09/10/2021 13:00	9.5	13.7	7.8	104.6	3,078,661.6	1,573.7	1.1	0.6
09/10/2021 14:00	9.8	13.6	7.9	109.9	3,255,179.6	1,687.7	1.0	0.7
09/10/2021 15:00	10.4	13.1	7.9	133.6	3,236,513.7	2,008.9	1.3	1.0
09/10/2021 16:00	10.2	13.0	7.6	145.7	3,211,767.0	2,063.9	1.5	1.2
09/10/2021 17:00	10.3	12.9	7.6	156.1	3,214,952.0	2,112.9	1.6	1.3
09/10/2021 18:00	10.2	12.9	7.5	154.8	3,205,205.5	2,129.9	1.6	1.3
09/10/2021 19:00	10.2	12.9	7.5	156.9	3,205,807.4	2,130.3	1.6	1.3
09/10/2021 20:00	10.1	12.9	7.4	157.6	3,204,302.6	2,129.3	1.6	1.3
09/10/2021 21:00	10.2	12.9	7.5	158.2	3,241,427.5	2,130.3	1.6	1.3
09/10/2021 22:00	10.1	13.0	7.5	152.4	3,228,573.6	2,074.7	1.5	1.2
09/10/2021 23:00	10.0	13.1	7.6	141.9	3,242,796.9	2,012.8	1.4	1.0
Average/Sum#:	9.9	13.2	7.6	134.8	3,178,769.5	1,918.7	1.4	1.0
Minimum:	9.1	12.8	7.4	96.9	2,914,330.7	1,489.7	1.0	0.6
Maximum:	10.4	13.7	8.0	158.2	3,284,173.1	2,151.7	1.6	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/11/2021 00:00	9.9	13.2	7.6	131.3	3,241,598.7	1,893.7	1.3	0.9
09/11/2021 01:00	9.4	13.7	7.7	115.1	3,261,186.4	1,667.0	1.1	0.7
09/11/2021 02:00	9.5	13.7	7.8	107.8	3,233,406.6	1,652.8	1.0	0.7
09/11/2021 03:00	9.1	13.6	7.4	106.7	2,981,487.6	1,545.8	1.1	0.6
09/11/2021 04:00	10.3	13.1	7.8	131.3	3,305,990.9	1,979.6	1.3	1.0
09/11/2021 05:00	10.0	13.2	7.7	132.9	3,268,987.2	1,909.7	1.3	1.0
09/11/2021 06:00	9.4	13.7	7.7	116.3	3,194,280.2	1,632.8	1.1	0.7
09/11/2021 07:00	10.0	13.7	8.2	106.5	3,138,525.1	1,604.3	1.0	0.6
09/11/2021 08:00	9.4	13.7	7.7	97.3	2,934,285.2	1,499.9	1.0	0.6
09/11/2021 09:00	9.0	13.8	7.5	101.2	3,092,942.8	1,581.0	1.0	0.6
09/11/2021 10:00	9.5	13.6	7.7	115.1	3,207,732.0	1,663.1	1.1	0.7
09/11/2021 11:00	9.8	13.6	7.9	110.9	3,171,856.9	1,644.5	1.1	0.7
09/11/2021 12:00	10.3	13.0	7.7	131.5	3,308,067.3	2,005.0	1.3	1.0
09/11/2021 13:00	10.1	13.0	7.5	138.3	3,210,253.0	1,992.6	1.4	1.0
09/11/2021 14:00	9.4	13.7	7.7	110.9	3,241,231.9	1,656.8	1.1	0.7
09/11/2021 15:00	10.1	13.5	8.1	117.7	3,221,951.3	1,694.0	1.1	0.7
09/11/2021 16:00	10.4	13.1	7.9	136.6	3,271,946.1	2,007.0	1.3	1.0
09/11/2021 17:00	10.5	12.9	7.7	165.5	3,248,094.1	2,158.4	1.7	1.5
09/11/2021 18:00	10.3	12.9	7.6	163.0	3,214,084.2	2,135.8	1.6	1.3
09/11/2021 19:00	10.2	13.0	7.6	152.7	3,243,357.2	2,084.2	1.5	1.3
09/11/2021 20:00	10.3	12.9	7.6	161.3	3,234,276.1	2,125.6	1.6	1.3
09/11/2021 21:00	10.3	12.9	7.6	165.5	3,261,512.4	2,143.5	1.6	1.3
09/11/2021 22:00	10.3	13.0	7.7	159.5	3,271,523.7	2,102.3	1.6	1.3
09/11/2021 23:00	10.2	13.0	7.6	159.8	3,298,134.1	2,119.4	1.6	1.3
Average/Sum#:	9.9	13.3	7.7	130.6	3,210,696.3	1,854.1	1.3	0.9
Minimum:	9.0	12.9	7.4	97.3	2,934,285.2	1,499.9	1.0	0.6
Maximum:	10.5	13.8	8.2	165.5	3,308,067.3	2,158.4	1.7	1.5
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/12/2021 00:00	9.9	13.1	7.5	143.3	3,241,460.1	1,988.3	1.4	1.0
09/12/2021 01:00	8.9	13.7	7.3	109.7	3,260,990.7	1,666.9	1.1	0.7
09/12/2021 02:00	8.8	13.8	7.3	105.9	3,183,129.2	1,627.1	1.0	0.7
09/12/2021 03:00	9.0	13.7	7.4	118.4	3,118,622.9	1,616.9	1.2	0.8
09/12/2021 04:00	10.1	13.2	7.7	130.7	3,334,971.0	1,972.6	1.2	1.0
09/12/2021 05:00	10.0	13.2	7.7	132.6	3,310,713.5	1,909.9	1.3	1.0
09/12/2021 06:00	9.4	13.7	7.7	117.0	2,932,111.2	1,520.2	1.3	0.8
09/12/2021 07:00	9.3	13.8	7.7	97.7	3,056,946.5	1,562.6	1.0	0.6
09/12/2021 08:00	7.7	13.9	6.5	85.9	2,660,255.7	1,340.4	1.0	0.5
09/12/2021 09:00	7.0	13.9	5.9	80.6	2,534,625.9	1,277.1	1.0	0.5
09/12/2021 10:00	10.0	13.7	8.2	130.3	3,151,990.6	1,634.2	1.3	0.8
09/12/2021 11:00	9.7	13.6	7.8	118.8	3,266,559.3	1,693.6	1.1	0.7
09/12/2021 12:00	10.4	13.1	7.9	136.5	3,262,164.5	2,001.0	1.3	1.0
09/12/2021 13:00	10.4	13.0	7.8	152.8	3,180,488.1	2,043.8	1.6	1.2
09/12/2021 14:00	9.5	13.7	7.8	110.1	3,191,150.1	1,631.2	1.1	0.7
09/12/2021 15:00	9.7	13.6	7.8	112.8	3,119,008.7	1,617.1	1.1	0.6
09/12/2021 16:00	10.6	13.0	7.9	138.6	3,224,357.5	2,024.9	1.4	1.0
09/12/2021 17:00	10.6	12.9	7.8	164.0	3,228,831.8	2,145.6	1.6	1.3
09/12/2021 18:00	10.5	12.9	7.7	164.7	3,224,842.3	2,119.4	1.7	1.5
09/12/2021 19:00	10.4	13.0	7.8	157.6	3,248,648.1	2,087.6	1.6	1.3
09/12/2021 20:00	10.4	13.0	7.8	154.5	3,244,748.8	2,061.4	1.5	1.2
09/12/2021 21:00	10.4	13.1	7.9	152.0	3,255,886.1	2,044.7	1.5	1.2
09/12/2021 22:00	10.3	13.1	7.8	150.0	3,281,301.9	2,036.7	1.5	1.2
09/12/2021 23:00	10.2	13.1	7.7	147.3	3,270,991.0	2,030.3	1.4	1.0
Average/Sum#:	9.7	13.4	7.6	129.7	3,157,699.8	1,818.9	1.3	0.9
Minimum:	7.0	12.9	5.9	80.6	2,534,625.9	1,277.1	1.0	0.5
Maximum:	10.6	13.9	8.2	164.7	3,334,971.0	2,145.6	1.7	1.5
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/13/2021 00:00	10.1	13.2	7.7	135.5	3,258,545.3	1,903.6	1.3	1.0
09/13/2021 01:00	9.5	13.7	7.8	109.0	3,062,619.8	1,565.5	1.1	0.6
09/13/2021 02:00	9.6	13.7	7.9	102.1	3,035,622.6	1,551.7	1.0	0.6
09/13/2021 03:00	9.6	13.7	7.9	106.3	3,178,629.6	1,624.8	1.0	0.6
09/13/2021 04:00	7.9	13.8	6.6	85.3	2,616,592.9	1,318.4	1.0	0.5
09/13/2021 05:00	9.4	13.8	7.8	117.0	3,282,053.8	1,653.7	1.1	0.7
09/13/2021 06:00	10.4	13.5	8.3	137.1	3,139,894.5	1,765.5	1.4	0.9
09/13/2021 07:00	10.4	13.4	8.2	135.7	3,157,649.9	1,821.6	1.4	0.9
09/13/2021 08:00	9.2	13.7	7.5	115.7	2,973,998.5	1,520.2	1.2	0.8
09/13/2021 09:00	10.5	13.2	8.0	132.2	3,284,393.2	1,918.7	1.3	1.0
09/13/2021 10:00	10.2	13.2	7.8	136.7	3,208,127.1	1,921.0	1.4	1.0
09/13/2021 11:00	9.5	13.7	7.8	115.8	3,283,684.0	1,678.5	1.1	0.7
09/13/2021 12:00	10.0	13.6	8.1	116.9	3,192,494.7	1,655.2	1.1	0.7
09/13/2021 13:00	10.5	13.1	7.9	135.5	3,260,385.0	1,976.1	1.3	1.0
09/13/2021 14:00	10.4	12.9	7.7	157.8	3,202,346.3	2,128.0	1.6	1.3
09/13/2021 15:00	10.3	12.9	7.6	158.4	3,183,686.0	2,115.6	1.6	1.3
09/13/2021 16:00	10.4	12.9	7.7	158.8	3,179,472.3	2,112.8	1.6	1.3
09/13/2021 17:00	10.4	12.9	7.7	161.5	3,183,018.6	2,138.4	1.6	1.3
09/13/2021 18:00	10.3	12.9	7.6	165.8	3,191,651.9	2,144.2	1.7	1.5
09/13/2021 19:00	10.3	12.9	7.6	164.0	3,192,098.5	2,144.5	1.7	1.5
09/13/2021 20:00	10.4	12.9	7.7	164.1	3,233,058.8	2,124.8	1.6	1.3
09/13/2021 21:00	10.4	13.0	7.8	159.1	3,238,999.9	2,081.4	1.6	1.2
09/13/2021 22:00	10.2	13.1	7.7	148.9	3,278,724.2	2,035.1	1.5	1.2
09/13/2021 23:00	10.1	13.2	7.7	135.7	3,257,708.5	1,926.9	1.3	1.0
Average/Sum#:	10.0	13.3	7.8	135.6	3,169,810.7	1,867.8	1.4	1.0
Minimum:	7.9	12.9	6.6	85.3	2,616,592.9	1,318.4	1.0	0.5
Maximum:	10.5	13.8	8.3	165.8	3,284,393.2	2,144.5	1.7	1.5
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/14/2021 00:00	10.2	13.2	7.8	135.6	3,262,311.2	1,905.8	1.3	1.0
09/14/2021 01:00	9.6	13.7	7.9	105.2	3,027,601.7	1,547.6	1.1	0.6
09/14/2021 02:00	9.8	13.7	8.0	101.0	2,987,888.4	1,527.3	1.0	0.6
09/14/2021 03:00	9.9	13.7	8.1	101.4	2,987,497.1	1,527.1	1.0	0.6
09/14/2021 04:00	9.9	13.7	8.1	100.0	2,899,658.3	1,482.2	1.1	0.6
09/14/2021 05:00	10.5	13.2	8.0	135.9	3,350,639.1	1,957.4	1.3	1.0
09/14/2021 06:00	10.4	13.2	8.0	138.9	3,314,514.2	1,960.5	1.3	1.0
09/14/2021 07:00	9.9	13.7	8.1	109.6	3,178,238.4	1,624.6	1.1	0.6
09/14/2021 08:00	9.8	13.7	8.0	98.3	2,906,896.7	1,485.9	1.0	0.6
09/14/2021 09:00	9.9	13.8	8.2	95.7	2,851,141.6	1,457.4	1.0	0.6
09/14/2021 10:00	9.8	13.7	8.0	105.8	3,198,584.1	1,635.0	1.0	0.7
09/14/2021 11:00	9.7	13.7	7.9	108.3	3,289,553.0	1,681.5	1.0	0.7
09/14/2021 12:00	10.0	13.7	8.2	121.7	2,971,846.5	1,519.1	1.3	0.8
09/14/2021 13:00	10.2	13.2	7.8	129.3	3,275,763.3	1,961.5	1.3	1.0
09/14/2021 14:00	10.4	13.0	7.8	144.3	3,192,962.5	2,028.5	1.5	1.2
09/14/2021 15:00	9.7	13.6	7.8	116.4	3,203,681.6	1,661.0	1.1	0.7
09/14/2021 16:00	10.1	13.7	8.3	125.8	3,099,007.4	1,584.1	1.3	0.8
09/14/2021 17:00	10.4	13.0	7.8	135.5	3,222,924.4	2,024.0	1.3	1.0
09/14/2021 18:00	10.4	12.9	7.7	156.2	3,217,234.4	2,114.4	1.6	1.3
09/14/2021 19:00	10.1	13.1	7.6	140.1	3,185,281.1	1,977.1	1.4	1.0
09/14/2021 20:00	9.5	13.7	7.8	116.3	3,257,273.7	1,665.0	1.1	0.7
09/14/2021 21:00	10.1	13.6	8.2	120.8	3,302,627.3	1,712.3	1.1	0.7
09/14/2021 22:00	10.5	13.1	7.9	137.0	3,271,769.3	1,983.0	1.3	1.0
09/14/2021 23:00	10.1	13.2	7.7	134.6	3,231,165.3	1,911.2	1.3	1.0
Average/Sum#:	10.0	13.5	7.9	121.4	3,153,585.9	1,747.2	1.2	0.8
Minimum:	9.5	12.9	7.6	95.7	2,851,141.6	1,457.4	1.0	0.6
Maximum:	10.5	13.8	8.3	156.2	3,350,639.1	2,114.4	1.6	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/15/2021 00:00	9.5	13.7	7.8	100.4	2,975,367.9	1,520.9	1.0	0.6
09/15/2021 01:00	9.3	13.6	7.5	110.8	2,971,265.2	1,540.5	1.2	0.8
09/15/2021 02:00	10.5	13.2	8.0	134.5	3,283,278.5	1,966.0	1.3	1.0
09/15/2021 03:00	10.1	13.2	7.7	135.2	3,265,823.6	1,931.7	1.3	1.0
09/15/2021 04:00	9.3	13.7	7.6	107.4	3,200,595.5	1,659.4	1.0	0.7
09/15/2021 05:00	9.1	13.6	7.4	107.9	3,025,077.8	1,568.4	1.1	0.6
09/15/2021 06:00	10.0	13.2	7.7	133.4	3,301,665.3	1,952.9	1.3	1.0
09/15/2021 07:00	10.5	13.2	8.0	138.1	3,325,447.8	1,918.4	1.3	1.0
09/15/2021 08:00	9.0	13.7	7.4	94.9	2,842,338.1	1,452.9	1.0	0.6
09/15/2021 09:00	8.7	13.8	7.2	88.1	2,771,595.9	1,396.5	1.0	0.6
09/15/2021 10:00	9.3	13.8	7.7	97.8	3,028,214.1	1,525.8	1.0	0.6
09/15/2021 11:00	9.8	13.7	8.0	103.6	3,094,703.5	1,581.9	1.0	0.6
09/15/2021 12:00	9.1	13.7	7.5	113.2	2,962,064.9	1,514.1	1.2	0.8
09/15/2021 13:00	10.5	13.1	7.9	135.2	3,280,423.5	2,012.2	1.3	1.0
09/15/2021 14:00	10.2	13.0	7.6	141.1	3,222,765.1	2,023.9	1.4	1.0
09/15/2021 15:00	9.4	13.7	7.7	105.6	2,974,929.8	1,542.4	1.1	0.6
09/15/2021 16:00	9.4	13.6	7.6	107.4	3,006,754.5	1,558.9	1.1	0.6
09/15/2021 17:00	10.4	13.1	7.9	134.0	3,229,102.7	2,004.3	1.3	1.0
09/15/2021 18:00	10.1	13.1	7.6	141.4	3,217,669.6	2,020.7	1.4	1.0
09/15/2021 19:00	9.9	13.2	7.6	133.7	3,237,018.6	1,938.3	1.3	1.0
09/15/2021 20:00	9.4	13.6	7.6	115.3	3,120,411.7	1,663.4	1.2	0.8
09/15/2021 21:00	9.6	13.7	7.9	104.3	3,105,854.5	1,587.6	1.0	0.6
09/15/2021 22:00	10.2	13.2	7.8	130.6	3,305,859.8	1,907.1	1.3	1.0
09/15/2021 23:00	10.0	13.2	7.7	130.2	3,299,446.0	1,903.4	1.3	1.0
Average/Sum#:	9.7	13.4	7.7	118.5	3,126,986.4	1,737.2	1.2	0.8
Minimum:	8.7	13.0	7.2	88.1	2,771,595.9	1,396.5	1.0	0.6
Maximum:	10.5	13.8	8.0	141.4	3,325,447.8	2,023.9	1.4	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/16/2021 00:00	9.5	13.5	7.6	117.4	3,115,255.4	1,683.4	1.2	0.8
09/16/2021 01:00	13.1	14.9	12.9	124.9	2,080,383.9	911.5	1.9	0.6
09/16/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/16/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/16/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/16/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/16/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/16/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/16/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/16/2021 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/16/2021 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/16/2021 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/16/2021 12:00	17.6	18.1	37.1	0.0	1,110,603.2	162.2	-0.4	0.0
09/16/2021 13:00	36.1	15.6	40.2	169.9	2,132,005.8	794.0	2.4	0.7
09/16/2021 14:00	10.2	13.7	8.4	112.6	3,258,251.9	1,665.5	1.1	0.7
09/16/2021 15:00	9.6	13.7	7.9	105.9	3,158,479.5	1,614.5	1.0	0.6
09/16/2021 16:00	9.6	13.7	7.9	121.0	2,952,870.2	1,509.4	1.3	0.8
09/16/2021 17:00	10.8	13.0	8.1	145.6	3,305,629.4	2,051.8	1.4	1.0
09/16/2021 18:00	10.4	13.0	7.8	146.9	3,223,127.0	2,071.2	1.5	1.2
09/16/2021 19:00	10.1	13.2	7.7	136.7	3,276,474.6	1,938.0	1.3	1.0
09/16/2021 20:00	9.5	13.6	7.7	116.9	3,160,931.6	1,685.0	1.2	0.8
09/16/2021 21:00	10.0	13.6	8.1	115.4	3,167,227.9	1,642.1	1.1	0.7
09/16/2021 22:00	10.5	13.1	7.9	136.7	3,290,248.3	1,994.2	1.3	1.0
09/16/2021 23:00	10.1	13.2	7.7	137.0	3,299,628.1	1,927.6	1.3	1.0
Average/Sum#:	12.7	14.0	12.6	120.5	2,895,079.8	1,546.5	1.3	0.8
Minimum:	9.5	13.0	7.6	0.0	1,110,603.2	162.2	-0.4	0.0
Maximum:	36.1	18.1	40.2	169.9	3,305,629.4	2,071.2	2.4	1.2
%SI	41.67	41.67	41.67	41.67	41.67	41.67	41.67	41.67

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/17/2021 00:00	10.1	13.2	7.7	133.0	3,307,073.2	1,907.8	1.3	1.0
09/17/2021 01:00	8.5	13.6	6.9	107.7	2,778,219.7	1,460.7	1.2	0.7
09/17/2021 02:00	23.6	16.9	34.8	198.6	970,380.5	304.7	6.6	0.8
09/17/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/17/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/17/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/17/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/17/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/17/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/17/2021 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/17/2021 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/17/2021 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/17/2021 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/17/2021 13:00	30.7	17.5	53.3	3.2	1,380,285.3	292.3	-0.2	0.0
09/17/2021 14:00	33.5	15.6	37.3	222.0	2,062,997.6	768.3	3.3	1.0
09/17/2021 15:00	8.6	13.8	7.1	99.9	2,926,598.8	1,474.6	1.1	0.6
09/17/2021 16:00	9.6	13.6	7.8	113.0	3,038,964.9	1,575.6	1.2	0.8
09/17/2021 17:00	10.8	13.0	8.1	139.3	3,263,096.6	2,025.4	1.4	1.0
09/17/2021 18:00	10.7	12.9	7.9	140.5	3,237,226.9	2,103.9	1.4	1.1
09/17/2021 19:00	10.4	13.1	7.9	136.7	3,249,330.6	1,969.4	1.3	1.0
09/17/2021 20:00	10.3	13.2	7.9	137.1	3,292,858.9	1,899.6	1.3	0.9
09/17/2021 21:00	10.3	13.2	7.9	136.6	3,292,267.4	1,923.3	1.3	1.0
09/17/2021 22:00	10.3	13.2	7.9	136.5	3,291,069.2	1,922.6	1.3	1.0
09/17/2021 23:00	8.8	13.6	7.1	135.5	2,800,282.7	1,472.3	1.6	0.9
Average/Sum#:	14.0	14.0	15.0	131.4	2,777,903.7	1,507.2	1.7	0.8
Minimum:	8.5	12.9	6.9	3.2	970,380.5	292.3	-0.2	0.0
Maximum:	33.5	17.5	53.3	222.0	3,307,073.2	2,103.9	6.6	1.1
%SI	41.67	41.67	41.67	41.67	41.67	41.67	41.67	41.67

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/18/2021 00:00	24.9	16.9	36.7	132.7	963,466.1	316.6	4.2	0.5
09/18/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/18/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/18/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/18/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/18/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/18/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/18/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/18/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/18/2021 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/18/2021 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/18/2021 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/18/2021 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/18/2021 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/18/2021 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/18/2021 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/18/2021 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/18/2021 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/18/2021 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/18/2021 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/18/2021 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/18/2021 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/18/2021 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/18/2021 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	24.9	16.9	36.7	132.7	963,466.1	316.6	4.2	0.5
Minimum:	24.9	16.9	36.7	132.7	963,466.1	316.6	4.2	0.5
Maximum:	24.9	16.9	36.7	132.7	963,466.1	316.6	4.2	0.5
%SI	95.83	95.83	95.83	95.83	95.83	95.83	95.83	95.83

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/19/2021 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/19/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/19/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/19/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/19/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/19/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/19/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/19/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/19/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/19/2021 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/19/2021 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/19/2021 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/19/2021 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/19/2021 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/19/2021 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/19/2021 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/19/2021 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/19/2021 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/19/2021 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/19/2021 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/19/2021 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/19/2021 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/19/2021 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/19/2021 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/20/2021 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/20/2021 01:00	24.9	17.8	47.4	0.0	1,290,945.8	245.1	-0.2	0.0
09/20/2021 02:00	39.6	16.7	55.6	153.7	1,640,570.4	479.2	2.9	0.5
09/20/2021 03:00	9.5	13.9	8.0	115.6	2,585,392.7	1,283.8	1.5	0.8
09/20/2021 04:00	8.8	13.8	7.3	114.1	2,842,250.2	1,432.1	1.3	0.7
09/20/2021 05:00	10.9	13.4	8.6	131.5	3,338,692.7	1,852.9	1.2	0.9
09/20/2021 06:00	10.9	13.2	8.4	142.6	3,397,905.9	1,960.2	1.3	1.0
09/20/2021 07:00	8.8	13.7	7.2	112.9	2,867,690.4	1,486.8	1.3	0.7
09/20/2021 08:00	7.6	13.9	6.4	82.4	2,586,399.6	1,284.3	1.0	0.5
09/20/2021 09:00	7.4	13.9	6.2	84.3	2,591,031.5	1,286.6	1.0	0.5
09/20/2021 10:00	7.3	14.0	6.2	85.6	2,596,468.9	1,289.3	1.0	0.5
09/20/2021 11:00	9.5	13.8	7.9	122.6	3,073,379.6	1,571.0	1.3	0.8
09/20/2021 12:00	10.8	13.2	8.3	137.7	3,343,620.8	1,953.3	1.3	1.0
09/20/2021 13:00	10.8	13.2	8.3	148.9	3,322,291.2	1,965.1	1.4	1.0
09/20/2021 14:00	9.7	13.7	7.9	111.4	2,971,650.9	1,562.4	1.2	0.8
09/20/2021 15:00	9.0	13.8	7.5	104.7	2,988,670.9	1,527.7	1.1	0.6
09/20/2021 16:00	10.9	13.1	8.2	149.0	3,295,911.0	2,021.7	1.4	1.0
09/20/2021 17:00	11.0	12.9	8.1	178.5	3,271,569.9	2,174.0	1.8	1.5
09/20/2021 18:00	10.8	12.9	8.0	178.6	3,303,203.8	2,170.9	1.8	1.5
09/20/2021 19:00	10.8	12.9	8.0	174.5	3,296,773.8	2,142.6	1.7	1.5
09/20/2021 20:00	10.7	13.0	8.0	167.2	3,283,973.0	2,110.3	1.6	1.3
09/20/2021 21:00	10.6	13.1	8.0	158.6	3,321,418.0	2,061.6	1.5	1.2
09/20/2021 22:00	10.5	13.3	8.2	143.8	3,355,783.1	1,935.9	1.4	1.0
09/20/2021 23:00	10.5	13.3	8.2	143.1	3,324,716.6	1,893.7	1.4	0.9
Average/Sum#:	11.8	13.8	11.6	127.9	2,951,752.6	1,638.7	1.4	0.9
Minimum:	7.3	12.9	6.2	0.0	1,290,945.8	245.1	-0.2	0.0
Maximum:	39.6	17.8	55.6	178.6	3,397,905.9	2,174.0	2.9	1.5
%SI	4.17	4.17	4.17	4.17	4.17	4.17	4.17	4.17

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/21/2021 00:00	9.6	13.7	7.9	110.4	3,251,209.1	1,661.9	1.1	0.7
09/21/2021 01:00	10.0	13.7	8.2	123.4	3,062,424.2	1,565.4	1.3	0.8
09/21/2021 02:00	10.6	13.3	8.2	131.9	3,397,773.1	1,910.5	1.2	1.0
09/21/2021 03:00	10.6	13.3	8.2	142.1	3,383,189.6	1,902.3	1.3	1.0
09/21/2021 04:00	10.5	13.3	8.2	136.8	3,380,699.8	1,900.9	1.3	1.0
09/21/2021 05:00	10.6	13.3	8.2	142.3	3,407,910.4	1,916.2	1.3	1.0
09/21/2021 06:00	10.7	13.1	8.1	165.1	3,409,365.7	2,041.5	1.6	1.2
09/21/2021 07:00	10.9	13.3	8.5	141.5	3,339,113.1	1,901.9	1.3	1.0
09/21/2021 08:00	8.8	13.8	7.3	101.2	2,906,553.6	1,464.5	1.1	0.6
09/21/2021 09:00	9.4	13.9	7.9	97.8	3,023,649.3	1,523.5	1.0	0.6
09/21/2021 10:00	10.9	13.7	8.9	149.6	3,230,863.4	1,651.5	1.5	1.0
09/21/2021 11:00	9.6	13.8	8.0	129.6	3,213,582.6	1,619.2	1.3	0.8
09/21/2021 12:00	10.6	13.2	8.1	138.8	3,329,037.3	1,993.4	1.3	1.0
09/21/2021 13:00	10.8	13.0	8.1	164.7	3,266,769.6	2,123.1	1.6	1.3
09/21/2021 14:00	10.7	13.0	8.0	168.3	3,266,923.4	2,123.2	1.7	1.5
09/21/2021 15:00	10.8	12.9	8.0	168.2	3,251,926.4	2,137.2	1.7	1.5
09/21/2021 16:00	10.8	12.9	8.0	172.9	3,269,576.8	2,148.8	1.7	1.5
09/21/2021 17:00	10.8	12.9	8.0	172.5	3,250,953.3	2,160.3	1.7	1.5
09/21/2021 18:00	10.6	12.9	7.8	174.3	3,269,463.1	2,172.6	1.7	1.5
09/21/2021 19:00	10.6	12.9	7.8	167.6	3,256,034.7	2,139.9	1.7	1.5
09/21/2021 20:00	10.5	12.9	7.7	167.4	3,299,081.8	2,144.1	1.6	1.3
09/21/2021 21:00	10.3	13.0	7.7	161.0	3,314,951.4	2,106.0	1.6	1.3
09/21/2021 22:00	10.3	13.0	7.7	158.7	3,299,198.1	2,071.9	1.6	1.2
09/21/2021 23:00	10.2	13.2	7.8	147.0	3,303,777.6	2,002.4	1.4	1.0
Average/Sum#:	10.4	13.3	8.0	147.2	3,266,001.1	1,932.6	1.4	1.1
Minimum:	8.8	12.9	7.3	97.8	2,906,553.6	1,464.5	1.0	0.6
Maximum:	10.9	13.9	8.9	174.3	3,409,365.7	2,172.6	1.7	1.5
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/22/2021 00:00	9.4	13.7	7.7	107.8	3,099,913.9	1,607.2	1.1	0.6
09/22/2021 01:00	9.9	13.7	8.1	117.2	3,159,898.5	1,638.3	1.2	0.8
09/22/2021 02:00	10.6	13.3	8.2	132.8	3,333,319.4	1,898.6	1.3	0.9
09/22/2021 03:00	10.5	13.3	8.2	138.8	3,326,999.0	1,895.0	1.3	0.9
09/22/2021 04:00	10.6	13.2	8.1	148.6	3,386,028.6	2,002.8	1.4	1.0
09/22/2021 05:00	10.6	13.0	7.9	164.3	3,327,543.8	2,114.0	1.6	1.3
09/22/2021 06:00	10.4	13.1	7.9	153.1	3,376,373.6	2,046.4	1.5	1.2
09/22/2021 07:00	10.7	13.3	8.3	143.3	3,329,456.9	1,896.4	1.4	0.9
09/22/2021 08:00	9.6	13.7	7.9	110.7	3,166,891.7	1,618.8	1.1	0.6
09/22/2021 09:00	10.5	13.6	8.5	134.9	3,303,398.8	1,712.7	1.3	0.9
09/22/2021 10:00	10.7	13.2	8.2	134.1	3,297,539.2	1,902.3	1.3	1.0
09/22/2021 11:00	10.7	13.0	8.0	150.3	3,265,588.1	2,003.1	1.5	1.2
09/22/2021 12:00	9.5	13.7	7.8	109.0	3,137,546.9	1,603.8	1.1	0.6
09/22/2021 13:00	9.8	13.6	7.9	123.2	3,276,588.9	1,698.8	1.2	0.8
09/22/2021 14:00	10.9	13.0	8.1	148.4	3,276,952.0	2,034.0	1.4	1.0
09/22/2021 15:00	10.8	12.9	8.0	167.5	3,244,166.4	2,132.1	1.7	1.5
09/22/2021 16:00	10.7	12.9	7.9	175.5	3,242,074.6	2,154.4	1.8	1.5
09/22/2021 17:00	10.6	12.9	7.8	174.2	3,231,239.6	2,147.2	1.8	1.5
09/22/2021 18:00	10.6	12.9	7.8	172.8	3,278,097.7	2,154.4	1.7	1.5
09/22/2021 19:00	10.3	13.0	7.7	160.4	3,240,599.5	2,035.1	1.6	1.2
09/22/2021 20:00	9.5	13.7	7.8	118.9	3,188,606.9	1,629.9	1.2	0.8
09/22/2021 21:00	10.4	13.5	8.3	134.2	3,312,865.8	1,741.8	1.3	0.9
09/22/2021 22:00	10.6	13.2	8.1	140.9	3,295,636.7	1,973.4	1.4	1.0
09/22/2021 23:00	10.4	13.1	7.9	150.2	3,309,442.3	2,030.0	1.5	1.2
Average/Sum#:	10.3	13.3	8.0	142.1	3,266,948.7	1,902.9	1.4	1.0
Minimum:	9.4	12.9	7.7	107.8	3,099,913.9	1,603.8	1.1	0.6
Maximum:	10.9	13.7	8.5	175.5	3,386,028.6	2,154.4	1.8	1.5
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/23/2021 00:00	10.2	13.2	7.8	145.6	3,278,573.2	1,915.3	1.4	1.0
09/23/2021 01:00	9.6	13.7	7.9	108.5	3,021,732.7	1,544.6	1.1	0.6
09/23/2021 02:00	9.3	13.8	7.7	99.8	3,023,053.9	1,523.2	1.0	0.6
09/23/2021 03:00	9.2	13.8	7.6	107.5	3,221,918.2	1,623.4	1.0	0.6
09/23/2021 04:00	9.4	13.8	7.8	121.5	3,066,141.2	1,567.3	1.3	0.8
09/23/2021 05:00	10.4	13.2	8.0	140.8	3,340,894.5	2,000.5	1.3	1.0
09/23/2021 06:00	10.3	13.2	7.9	145.9	3,316,035.8	1,961.4	1.4	1.0
09/23/2021 07:00	9.8	13.7	8.0	112.4	3,217,560.4	1,644.7	1.1	0.7
09/23/2021 08:00	8.6	13.8	7.1	91.9	2,763,657.2	1,392.5	1.0	0.6
09/23/2021 09:00	10.4	13.6	8.4	138.2	3,302,785.3	1,736.5	1.3	0.9
09/23/2021 10:00	10.5	13.5	8.4	129.1	3,300,122.6	1,735.1	1.2	0.9
09/23/2021 11:00	10.4	13.5	8.3	126.7	3,288,900.9	1,729.2	1.2	0.9
09/23/2021 12:00	10.4	13.5	8.3	128.6	3,283,575.4	1,726.4	1.2	0.9
09/23/2021 13:00	10.5	13.5	8.4	124.7	3,280,342.0	1,724.7	1.2	0.9
09/23/2021 14:00	10.3	13.5	8.2	124.3	3,281,293.0	1,725.2	1.2	0.9
09/23/2021 15:00	10.3	13.5	8.2	125.0	3,279,581.2	1,724.3	1.2	0.9
09/23/2021 16:00	10.4	13.5	8.3	126.8	3,275,967.4	1,722.4	1.2	0.9
09/23/2021 17:00	10.4	13.5	8.3	128.0	3,280,151.8	1,724.6	1.2	0.9
09/23/2021 18:00	10.5	13.6	8.5	127.8	3,337,345.1	1,730.3	1.2	0.9
09/23/2021 19:00	10.4	13.6	8.4	127.7	3,342,167.0	1,732.8	1.2	0.9
09/23/2021 20:00	10.4	13.6	8.4	127.8	3,295,557.8	1,732.7	1.2	0.9
09/23/2021 21:00	10.5	13.6	8.5	128.8	3,342,167.0	1,732.8	1.2	0.9
09/23/2021 22:00	10.4	13.6	8.4	128.3	3,295,748.0	1,732.8	1.2	0.9
09/23/2021 23:00	10.4	13.5	8.3	127.9	3,301,834.3	1,736.0	1.2	0.9
Average/Sum#:	10.1	13.6	8.1	124.7	3,239,046.1	1,713.3	1.2	0.9
Minimum:	8.6	13.2	7.1	91.9	2,763,657.2	1,392.5	1.0	0.6
Maximum:	10.5	13.8	8.5	145.9	3,342,167.0	2,000.5	1.4	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/24/2021 00:00	10.4	13.5	8.3	125.9	3,303,355.9	1,736.8	1.2	0.9
09/24/2021 01:00	10.4	13.5	8.3	127.0	3,304,306.9	1,737.3	1.2	0.9
09/24/2021 02:00	10.4	13.5	8.3	127.0	3,306,208.9	1,738.3	1.2	0.9
09/24/2021 03:00	10.4	13.5	8.3	127.4	3,306,779.5	1,738.6	1.2	0.9
09/24/2021 04:00	10.4	13.5	8.3	126.3	3,319,142.4	1,745.1	1.2	0.9
09/24/2021 05:00	10.3	13.5	8.2	127.6	3,330,744.4	1,751.2	1.2	0.9
09/24/2021 06:00	10.3	13.5	8.2	131.1	3,331,315.0	1,751.5	1.2	0.9
09/24/2021 07:00	10.7	13.5	8.5	127.8	3,324,848.3	1,748.1	1.2	0.9
09/24/2021 08:00	10.5	13.5	8.4	129.7	3,313,816.8	1,742.3	1.2	0.9
09/24/2021 09:00	9.7	13.7	7.9	109.6	3,200,931.7	1,636.2	1.1	0.7
09/24/2021 10:00	9.8	13.8	8.1	122.3	2,965,586.3	1,515.9	1.3	0.8
09/24/2021 11:00	10.4	13.8	8.6	130.8	3,144,119.0	1,584.2	1.3	0.8
09/24/2021 12:00	10.7	13.8	8.9	143.2	3,133,798.7	1,579.0	1.4	0.8
09/24/2021 13:00	9.7	13.7	7.9	113.1	3,210,126.4	1,640.9	1.1	0.7
09/24/2021 14:00	9.7	13.7	7.9	112.0	3,237,627.8	1,678.6	1.1	0.7
09/24/2021 15:00	9.8	13.6	7.9	113.0	3,222,776.3	1,670.9	1.1	0.7
09/24/2021 16:00	9.9	13.6	8.0	119.6	3,196,738.0	1,657.4	1.2	0.8
09/24/2021 17:00	10.2	13.6	8.2	121.7	3,270,609.8	1,695.7	1.2	0.8
09/24/2021 18:00	9.7	13.7	7.9	108.6	3,203,083.6	1,637.3	1.1	0.7
09/24/2021 19:00	9.7	13.7	7.9	110.2	3,270,576.7	1,671.8	1.0	0.7
09/24/2021 20:00	9.7	13.7	7.9	107.6	3,161,022.7	1,615.8	1.1	0.6
09/24/2021 21:00	9.8	13.7	8.0	106.5	3,115,831.7	1,592.7	1.1	0.6
09/24/2021 22:00	9.7	13.7	7.9	108.0	3,184,303.0	1,627.7	1.1	0.7
09/24/2021 23:00	9.7	13.7	7.9	108.2	3,175,890.8	1,623.4	1.1	0.6
Average/Sum#:	10.1	13.6	8.2	120.2	3,230,564.2	1,671.5	1.2	0.8
Minimum:	9.7	13.5	7.9	106.5	2,965,586.3	1,515.9	1.0	0.6
Maximum:	10.7	13.8	8.9	143.2	3,331,315.0	1,751.5	1.4	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/25/2021 00:00	9.8	13.7	8.0	104.1	3,036,796.4	1,552.3	1.1	0.6
09/25/2021 01:00	9.8	13.7	8.0	107.5	3,165,326.6	1,618.0	1.1	0.6
09/25/2021 02:00	9.6	13.7	7.9	109.3	3,221,668.7	1,646.8	1.1	0.7
09/25/2021 03:00	9.6	13.7	7.9	109.0	3,219,908.0	1,645.9	1.0	0.7
09/25/2021 04:00	9.6	13.7	7.9	106.8	3,132,851.7	1,601.4	1.1	0.6
09/25/2021 05:00	9.4	13.7	7.7	104.6	3,094,703.5	1,581.9	1.0	0.6
09/25/2021 06:00	9.1	13.7	7.5	107.7	3,200,540.4	1,636.0	1.0	0.7
09/25/2021 07:00	9.4	13.7	7.7	107.1	3,176,086.4	1,623.5	1.0	0.6
09/25/2021 08:00	9.0	13.8	7.5	99.4	2,975,954.8	1,521.2	1.0	0.6
09/25/2021 09:00	7.7	13.8	6.4	85.3	2,636,638.1	1,328.5	1.0	0.5
09/25/2021 10:00	9.1	13.8	7.6	101.3	2,993,879.3	1,508.5	1.1	0.6
09/25/2021 11:00	9.8	13.7	8.0	130.9	3,202,692.4	1,637.1	1.3	0.8
09/25/2021 12:00	9.7	13.7	7.9	110.0	3,217,560.4	1,644.7	1.1	0.7
09/25/2021 13:00	9.8	13.7	8.0	110.1	3,206,213.7	1,638.9	1.1	0.7
09/25/2021 14:00	9.9	13.7	8.1	111.8	3,261,773.3	1,667.3	1.1	0.7
09/25/2021 15:00	10.0	13.6	8.1	113.6	3,207,346.2	1,662.9	1.1	0.7
09/25/2021 16:00	10.0	13.7	8.2	108.6	3,155,936.3	1,613.2	1.1	0.6
09/25/2021 17:00	8.3	13.8	6.9	87.2	2,613,020.5	1,316.6	1.0	0.5
09/25/2021 18:00	10.4	13.8	8.6	136.9	3,134,808.0	1,602.4	1.4	0.8
09/25/2021 19:00	9.9	13.7	8.1	117.3	3,255,513.0	1,664.1	1.1	0.7
09/25/2021 20:00	9.8	13.7	8.0	108.7	3,208,757.0	1,640.2	1.0	0.7
09/25/2021 21:00	9.6	13.7	7.9	113.1	3,028,775.5	1,548.2	1.2	0.8
09/25/2021 22:00	8.3	13.8	6.9	88.0	2,667,995.9	1,344.3	1.0	0.5
09/25/2021 23:00	7.8	13.8	6.5	83.9	2,600,914.0	1,310.5	1.0	0.5
Average/Sum#:	9.4	13.7	7.7	106.8	3,067,319.2	1,564.8	1.1	0.6
Minimum:	7.7	13.6	6.4	83.9	2,600,914.0	1,310.5	1.0	0.5
Maximum:	10.4	13.8	8.6	136.9	3,261,773.3	1,667.3	1.4	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/26/2021 00:00	7.8	13.8	6.5	83.8	2,606,272.6	1,313.2	1.0	0.5
09/26/2021 01:00	7.7	13.8	6.4	83.8	2,615,997.5	1,318.1	1.0	0.5
09/26/2021 02:00	7.8	13.8	6.5	83.9	2,626,714.7	1,323.5	1.0	0.5
09/26/2021 03:00	7.7	13.8	6.4	83.9	2,623,737.7	1,322.0	1.0	0.5
09/26/2021 04:00	7.7	13.8	6.4	83.8	2,626,119.3	1,323.2	1.0	0.5
09/26/2021 05:00	7.8	13.8	6.5	84.4	2,640,012.1	1,330.2	1.0	0.5
09/26/2021 06:00	8.2	13.8	6.8	92.6	2,724,559.1	1,372.8	1.1	0.5
09/26/2021 07:00	8.4	13.8	7.0	86.7	2,713,048.0	1,367.0	1.0	0.5
09/26/2021 08:00	7.9	13.8	6.6	84.4	2,631,874.9	1,326.1	1.0	0.5
09/26/2021 09:00	7.8	13.8	6.5	84.3	2,637,630.4	1,329.0	1.0	0.5
09/26/2021 10:00	8.0	13.8	6.6	86.0	2,691,613.5	1,356.2	1.0	0.5
09/26/2021 11:00	8.8	13.8	7.3	93.6	2,847,608.8	1,434.8	1.0	0.6
09/26/2021 12:00	7.9	13.8	6.6	84.9	2,638,622.8	1,329.5	1.0	0.5
09/26/2021 13:00	8.5	13.8	7.1	87.8	2,697,964.5	1,359.4	1.0	0.5
09/26/2021 14:00	8.4	13.8	7.0	87.9	2,703,124.7	1,362.0	1.0	0.5
09/26/2021 15:00	9.2	13.8	7.6	119.1	2,844,830.3	1,433.4	1.3	0.7
09/26/2021 16:00	8.7	13.9	7.3	92.1	2,808,312.3	1,415.0	1.0	0.6
09/26/2021 17:00	8.3	13.9	7.0	86.1	2,648,347.7	1,334.4	1.0	0.5
09/26/2021 18:00	8.2	13.8	6.8	85.2	2,627,111.7	1,323.7	1.0	0.5
09/26/2021 19:00	7.9	13.8	6.6	84.4	2,610,242.0	1,315.2	1.0	0.5
09/26/2021 20:00	7.9	13.8	6.6	84.2	2,612,623.6	1,316.4	1.0	0.5
09/26/2021 21:00	7.9	13.8	6.6	84.3	2,613,417.4	1,316.8	1.0	0.5
09/26/2021 22:00	7.9	13.8	6.6	84.5	2,615,402.1	1,317.8	1.0	0.5
09/26/2021 23:00	8.0	13.8	6.6	84.7	2,619,569.9	1,319.9	1.0	0.5
Average/Sum#:	8.1	13.8	6.7	87.4	2,667,698.2	1,344.2	1.0	0.5
Minimum:	7.7	13.8	6.4	83.8	2,606,272.6	1,313.2	1.0	0.5
Maximum:	9.2	13.9	7.6	119.1	2,847,608.8	1,434.8	1.3	0.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/27/2021 00:00	8.0	13.8	6.6	84.7	2,617,982.2	1,319.1	1.0	0.5
09/27/2021 01:00	8.0	13.8	6.6	84.6	2,615,997.5	1,318.1	1.0	0.5
09/27/2021 02:00	7.9	13.8	6.6	84.5	2,620,165.3	1,320.2	1.0	0.5
09/27/2021 03:00	7.9	13.8	6.6	84.4	2,619,966.9	1,320.1	1.0	0.5
09/27/2021 04:00	8.7	13.8	7.2	90.9	2,741,978.9	1,401.6	1.0	0.6
09/27/2021 05:00	9.9	13.6	8.0	120.0	3,201,559.9	1,659.9	1.2	0.8
09/27/2021 06:00	9.7	13.6	7.8	111.3	3,150,067.3	1,610.2	1.1	0.6
09/27/2021 07:00	8.8	13.7	7.2	115.7	2,879,703.8	1,472.0	1.3	0.7
09/27/2021 08:00	7.8	13.8	6.5	84.3	2,619,569.9	1,319.9	1.0	0.5
09/27/2021 09:00	7.8	13.8	6.5	84.4	2,618,379.1	1,319.3	1.0	0.5
09/27/2021 10:00	8.0	13.8	6.6	84.8	2,636,042.7	1,328.2	1.0	0.5
09/27/2021 11:00	8.1	13.8	6.7	85.1	2,644,576.8	1,332.5	1.0	0.5
09/27/2021 12:00	8.2	13.8	6.8	85.4	2,645,966.1	1,333.2	1.0	0.5
09/27/2021 13:00	8.2	13.8	6.8	85.3	2,638,424.3	1,329.4	1.0	0.5
09/27/2021 14:00	8.2	13.8	6.8	85.5	2,642,790.6	1,331.6	1.0	0.5
09/27/2021 15:00	8.0	13.8	6.6	84.7	2,630,882.6	1,325.6	1.0	0.5
09/27/2021 16:00	9.0	13.7	7.4	112.4	2,843,903.2	1,453.7	1.3	0.7
09/27/2021 17:00	8.4	13.8	7.0	89.4	2,708,086.3	1,364.5	1.0	0.5
09/27/2021 18:00	8.9	13.8	7.4	95.0	2,891,470.1	1,456.9	1.0	0.6
09/27/2021 19:00	8.8	13.8	7.3	94.9	2,902,981.2	1,462.7	1.0	0.6
09/27/2021 20:00	9.8	13.7	8.0	125.4	3,074,357.7	1,571.5	1.3	0.8
09/27/2021 21:00	8.6	13.8	7.1	92.7	2,808,709.3	1,415.2	1.0	0.6
09/27/2021 22:00	8.2	13.9	6.9	89.1	2,738,650.3	1,379.9	1.0	0.6
09/27/2021 23:00	7.7	13.9	6.5	83.6	2,619,768.4	1,320.0	1.0	0.5
Average/Sum#:	8.4	13.8	7.0	93.3	2,754,665.9	1,394.4	1.1	0.6
Minimum:	7.7	13.6	6.5	83.6	2,615,997.5	1,318.1	1.0	0.5
Maximum:	9.9	13.9	8.0	125.4	3,201,559.9	1,659.9	1.3	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/28/2021 00:00	7.7	13.9	6.5	83.6	2,623,340.8	1,321.8	1.0	0.5
09/28/2021 01:00	7.6	13.8	6.3	83.6	2,622,546.9	1,321.4	1.0	0.5
09/28/2021 02:00	7.6	13.8	6.3	83.5	2,618,974.5	1,319.6	1.0	0.5
09/28/2021 03:00	7.6	13.8	6.3	83.5	2,615,799.0	1,318.0	1.0	0.5
09/28/2021 04:00	8.7	13.8	7.2	92.5	2,821,014.2	1,421.4	1.0	0.6
09/28/2021 05:00	8.0	13.8	6.6	86.3	2,663,034.3	1,341.8	1.0	0.5
09/28/2021 06:00	9.4	13.8	7.8	99.2	2,985,543.6	1,504.3	1.0	0.6
09/28/2021 07:00	8.3	13.8	6.9	109.2	2,819,625.0	1,420.7	1.2	0.7
09/28/2021 08:00	8.5	13.8	7.1	92.9	2,854,356.7	1,438.2	1.0	0.6
09/28/2021 09:00	7.7	13.9	6.5	84.0	2,652,912.4	1,336.7	1.0	0.5
09/28/2021 10:00	7.8	13.9	6.6	84.3	2,700,182.7	1,340.8	1.0	0.5
09/28/2021 11:00	7.9	13.9	6.7	84.4	2,707,231.2	1,344.3	1.0	0.5
09/28/2021 12:00	7.9	13.9	6.7	84.6	2,707,029.8	1,344.2	1.0	0.5
09/28/2021 13:00	7.9	13.9	6.7	84.5	2,708,439.5	1,344.9	1.0	0.5
09/28/2021 14:00	7.9	13.9	6.7	84.6	2,708,036.7	1,344.7	1.0	0.5
09/28/2021 15:00	7.9	13.9	6.7	84.6	2,705,015.9	1,343.2	1.0	0.5
09/28/2021 16:00	8.9	13.8	7.4	98.1	2,900,996.6	1,461.7	1.1	0.6
09/28/2021 17:00	11.7	13.2	9.0	181.4	3,374,963.1	2,020.9	1.7	1.4
09/28/2021 18:00	12.0	13.0	9.0	200.9	3,320,698.5	2,133.9	2.0	1.7
09/28/2021 19:00	11.4	13.3	8.9	162.9	3,341,915.5	1,927.9	1.6	1.2
09/28/2021 20:00	11.4	13.3	8.9	157.6	3,348,593.8	1,907.3	1.5	1.1
09/28/2021 21:00	11.3	13.3	8.8	157.3	3,315,938.2	1,888.7	1.5	1.1
09/28/2021 22:00	8.3	13.8	6.9	91.6	2,686,651.9	1,353.7	1.1	0.5
09/28/2021 23:00	7.9	13.9	6.7	84.3	2,667,759.5	1,324.7	1.0	0.5
Average/Sum#:	8.8	13.7	7.2	105.8	2,852,941.7	1,492.7	1.2	0.7
Minimum:	7.6	13.0	6.3	83.5	2,615,799.0	1,318.0	1.0	0.5
Maximum:	12.0	13.9	9.0	200.9	3,374,963.1	2,133.9	2.0	1.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/29/2021 00:00	7.7	13.9	6.5	83.5	2,667,960.9	1,324.8	1.0	0.5
09/29/2021 01:00	7.6	13.9	6.4	83.2	2,629,493.3	1,324.9	1.0	0.5
09/29/2021 02:00	7.3	13.9	6.2	82.1	2,627,310.1	1,323.8	1.0	0.5
09/29/2021 03:00	9.0	13.8	7.5	118.9	3,152,610.6	1,611.5	1.2	0.8
09/29/2021 04:00	9.3	13.7	7.6	133.2	3,161,805.3	1,616.2	1.3	0.8
09/29/2021 05:00	10.4	13.6	8.4	154.6	3,344,095.8	1,733.8	1.5	1.0
09/29/2021 06:00	10.6	13.5	8.5	147.0	3,372,207.5	1,773.0	1.4	0.9
09/29/2021 07:00	11.1	13.5	8.9	144.7	3,364,409.4	1,768.9	1.4	0.9
09/29/2021 08:00	10.8	13.5	8.6	143.2	3,345,579.8	1,759.0	1.3	0.9
09/29/2021 09:00	9.1	13.8	7.6	100.3	2,922,156.0	1,493.7	1.1	0.6
09/29/2021 10:00	9.7	13.8	8.1	103.4	3,050,640.9	1,537.1	1.0	0.6
09/29/2021 11:00	9.5	13.8	7.9	98.0	2,863,662.0	1,463.8	1.1	0.6
09/29/2021 12:00	9.2	13.9	7.8	95.7	2,944,463.8	1,462.1	1.0	0.6
09/29/2021 13:00	10.3	13.8	8.6	146.9	3,214,376.4	1,619.6	1.4	0.8
09/29/2021 14:00	9.6	13.8	8.0	110.1	3,229,689.6	1,650.9	1.1	0.7
09/29/2021 15:00	9.7	13.8	8.1	110.2	3,245,340.2	1,658.9	1.0	0.7
09/29/2021 16:00	9.8	13.8	8.1	110.0	3,219,516.7	1,645.7	1.1	0.7
09/29/2021 17:00	9.2	13.8	7.6	107.6	2,808,907.7	1,415.3	1.2	0.7
09/29/2021 18:00	8.7	13.9	7.3	97.4	2,766,237.3	1,373.6	1.1	0.5
09/29/2021 19:00	10.3	13.8	8.6	125.1	3,186,259.3	1,628.7	1.2	0.8
09/29/2021 20:00	9.8	13.8	8.1	108.7	3,216,973.5	1,644.4	1.0	0.7
09/29/2021 21:00	9.9	13.8	8.2	107.3	3,147,524.1	1,608.9	1.0	0.6
09/29/2021 22:00	9.8	13.7	8.0	108.9	3,203,279.3	1,637.4	1.1	0.7
09/29/2021 23:00	9.7	13.8	8.1	101.5	2,962,064.9	1,514.1	1.1	0.6
Average/Sum#:	9.5	13.8	7.9	113.4	3,068,606.9	1,566.3	1.2	0.7
Minimum:	7.3	13.5	6.2	82.1	2,627,310.1	1,323.8	1.0	0.5
Maximum:	11.1	13.9	8.9	154.6	3,372,207.5	1,773.0	1.5	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/30/2021 00:00	9.1	13.9	7.7	98.0	2,961,330.6	1,492.1	1.0	0.6
09/30/2021 01:00	7.5	13.9	6.3	84.4	2,631,510.1	1,306.7	1.0	0.5
09/30/2021 02:00	7.2	13.9	6.1	81.8	2,581,365.0	1,281.8	1.0	0.5
09/30/2021 03:00	8.7	13.9	7.3	109.8	3,045,282.3	1,534.4	1.1	0.6
09/30/2021 04:00	8.8	13.9	7.4	105.2	3,164,164.2	1,594.3	1.0	0.6
09/30/2021 05:00	7.1	13.9	6.0	84.9	2,657,086.1	1,319.4	1.0	0.5
09/30/2021 06:00	23.8	16.8	34.2	189.1	1,018,618.6	349.6	6.0	0.8
09/30/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/30/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/30/2021 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/30/2021 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/30/2021 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/30/2021 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/30/2021 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/30/2021 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/30/2021 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/30/2021 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/30/2021 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/30/2021 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/30/2021 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/30/2021 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/30/2021 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/30/2021 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/30/2021 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	10.3	14.3	10.7	107.6	2,579,908.1	1,268.3	1.7	0.6
Minimum:	7.1	13.9	6.0	81.8	1,018,618.6	349.6	1.0	0.5
Maximum:	23.8	16.8	34.2	189.1	3,164,164.2	1,594.3	6.0	0.8
%SI	70.83	70.83	70.83	70.83	70.83	70.83	70.83	70.83

Excess Emission Report

CT1 - NH3 LbPerHr 1-Hour Block Average

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/04/2021 10:42 **Location:** Maxwell, CA

Tag Name: CT1_NH3slip_LbPerHr_1H
Total Operating Time: 1,776.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 432.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,776.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 - NH3 Ppmvdc 1-Hour Block Average

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/04/2021 10:43 **Location:** Maxwell, CA

Tag Name: CT1_NH3Slip_Ppmvdc_1H
Total Operating Time: 1,776.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 432.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,776.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - NH3 LbPerHr 1-Hour Block Average

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/04/2021 10:44 **Location:** Maxwell, CA

Tag Name: CT2_NH3slip_LbPerHr_1H
Total Operating Time: 1,779.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 429.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,779.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - NH3 Ppmvdc 1-Hour Block Average

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/04/2021 10:45 **Location:** Maxwell, CA

Tag Name: CT2_NH3Slip_Ppmvdc_1H
Total Operating Time: 1,779.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 429.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,779.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

ATTACHMENT 9
Quarterly/Annual Emissions
(Fuel Use, Hours of Operation, and NH_3 Injection)

FCD: AQ-23, 26
Title V: #6, 14

Emissions Limits per AQ-26

Quarterly and Annual Combustion Emissions from CGS Facility					
Pollutant	1st Quarter Emissions (tons)	2nd Quarter Emissions (tons)	3rd Quarter Emissions (tons)	4th Quarter Emissions (tons)	Annual Emissions (tons)
NO_x	45.56	43.58	51.30	44.27	184.7
CO	54.29	52.49	107.15	53.95	267.9
VOC's	12.30	11.63	11.84	11.76	47.5
PM10	25.54	25.78	26.02	26.02	103.4
SO_2	4.07	3.85	3.89	3.89	15.7

Notes

1. Emissions based on CT1 and CT2.
2. VOC Mass Emissions based on Average Source Test Results (lb/MMBtu). CT1 EF = 0.0009 prior to 10/30/2013 and 0.0007 after 10/30/2013. CT2 EF = 0.0007 prior to 11/01/2014 and 0.0003 after 11/01/2014.
3. PM10 based on 2010 lb/MMBtu Source Test Results. CT1 EF = 0.0025; CT2 EF = 0.003

Quarterly Emissions

Cumulative Emissions Report

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/04/2021 10:46 **Location:** Maxwell, CA

Month	PlantWide NOx, Tons 1 Day(s)	PlantWide CO, Tons 1 Day(s)	PlantWide VOC, Tons 1 Day(s)	PlantWide PM10, Tons 1 Day(s)	PlantWide SO2, Tons 1 Day(s)
July	3.3	1.5	0.5	2.5	0.0
August	4.6	1.5	0.6	3.5	0.0
September	3.9	1.3	0.6	3.1	0.0
Quarter 3	11.8	4.3	1.7	9.1	0.0
YTD	11.8	4.3	1.7	9.1	0.0

Cumulative Emissions Report

CT1

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:46 **Location:** Maxwell, CA

Month	Unit CT1 GasFlowCT, 100scf 1 Day(s)	Unit CT1 GasFlowDB, 100scf 1 Day(s)	Unit CT1 GasFlow, Total, 100scf 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)
July	7,736,145	1,100,036	8,836,179.8	478	163.0
August	10,882,081	1,343,974	12,226,050.6	663	147.3
September	10,100,309	872,844	10,973,148.5	635	120.7
Quarter 3	28,718,535	3,316,854	32,035,378.9	1,776	143.7
YTD	28,718,535	3,316,854	32,035,378.9	1,776	143.7

Cumulative Emissions Report

CT2

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:47 **Location:** Maxwell, CA

Month	Unit CT2 GasFlowCT, 100scf 1 Day(s)	Unit CT2 GasFlowDB, 100scf 1 Day(s)	Unit CT2 GasFlow, Total, 100scf 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)
July	7,504,236	979,055	8,483,288.3	461	58,031.5
August	11,084,153	1,248,195	12,332,346.2	692	88,615.5
September	9,814,234	840,047	10,654,281.9	626	79,244.0
Quarter 3	28,402,623	3,067,297	31,469,916.4	1,779	225,891.0
YTD	28,402,623	3,067,297	31,469,916.4	1,779	225,891.0

Monthly Summary By Day Report

VOC PM10

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:48 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 VOC, Lb 1 Day(s)	Unit CT1 PM10, Lb 1 Day(s)	Unit CT2 VOC, Lb 1 Day(s)	Unit CT2 PM10, Lb 1 Day(s)
07/01/2021	0.0	0.0	0.0	0.0
07/02/2021	0.0	0.0	0.0	0.0
07/03/2021	0.0	0.0	0.0	0.0
07/04/2021	0.0	0.0	0.0	0.0
07/05/2021	0.0	0.0	0.0	0.0
07/06/2021	0.0	0.0	0.0	0.0
07/07/2021	0.0	0.0	0.0	0.0
07/08/2021	0.0	0.0	0.0	0.0
07/09/2021	0.0	0.0	0.0	0.0
07/10/2021	9.5	34.2	0.0	0.5
07/11/2021	15.1	54.0	0.0	0.0
07/12/2021	9.1	32.5	7.3	73.6
07/13/2021	8.4	29.8	4.0	39.6
07/14/2021	28.3	100.4	13.3	131.5
07/15/2021	32.7	116.2	13.3	133.7
07/16/2021	32.1	114.8	13.1	132.2
07/17/2021	32.5	115.6	13.1	132.9
07/18/2021	33.7	120.0	13.5	137.4
07/19/2021	34.7	123.4	13.7	141.0
07/20/2021	33.5	118.8	13.4	136.4
07/21/2021	33.8	121.7	13.7	139.4
07/22/2021	33.9	120.8	13.7	138.7
07/23/2021	33.8	119.5	13.4	136.9
07/24/2021	32.7	116.9	13.4	134.4
07/25/2021	32.1	113.5	13.2	131.5
07/26/2021	33.9	120.0	13.6	138.3
07/27/2021	34.2	121.3	13.6	139.1
07/28/2021	35.8	126.5	14.0	145.5
07/29/2021	36.2	127.7	14.0	145.8
07/30/2021	37.3	131.2	14.2	150.2
07/31/2021	35.3	125.8	14.2	144.8
Monthly Avg/Sum*:	648.6 *	2,304.6 *	255.7 *	2,603.4 *
Daily Min:	0.0	0.0	0.0	0.0
Daily Max:	37.3	131.2	14.2	150.2
Jul 2021 - Jul 2021	648.6	2,304.6	255.7	2,603.4
QTD:	648.6 *	2,304.6 *	255.7 *	2,603.4 *
YTD 2021:	2,126.6 *	7,570.3 *	783.0 *	7,908.5 *

Monthly Summary By Day Report

VOC PM10

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:48 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 VOC, Lb 1 Day(s)	Unit CT1 PM10, Lb 1 Day(s)	Unit CT2 VOC, Lb 1 Day(s)	Unit CT2 PM10, Lb 1 Day(s)
08/01/2021	32.2	114.9	13.5	133.3
08/02/2021	35.8	128.2	14.6	147.2
08/03/2021	35.4	126.9	10.0	101.4
08/04/2021	35.6	126.7	14.3	145.8
08/05/2021	35.3	125.6	14.2	145.5
08/06/2021	32.9	116.7	13.6	136.2
08/07/2021	16.6	59.0	8.0	79.8
08/08/2021	16.6	59.2	11.5	116.5
08/09/2021	33.0	117.9	13.5	136.8
08/10/2021	33.7	121.1	13.7	140.0
08/11/2021	34.2	122.0	13.8	141.6
08/12/2021	33.9	121.0	13.8	140.0
08/13/2021	33.1	117.3	13.6	136.1
08/14/2021	31.2	111.7	12.9	130.2
08/15/2021	31.7	112.5	13.0	130.6
08/16/2021	33.7	120.7	13.7	139.3
08/17/2021	32.9	116.7	13.3	135.2
08/18/2021	30.5	108.5	12.8	126.4
08/19/2021	30.2	107.6	12.7	124.8
08/20/2021	28.9	102.9	12.2	119.8
08/21/2021	0.1	0.3	5.3	54.1
08/22/2021	0.0	0.0	0.0	0.0
08/23/2021	8.6	30.8	5.6	57.2
08/24/2021	30.4	107.9	12.8	125.6
08/25/2021	31.0	110.1	13.1	128.6
08/26/2021	32.3	115.4	13.2	133.2
08/27/2021	33.4	119.0	13.7	138.3
08/28/2021	33.1	117.2	13.5	135.4
08/29/2021	33.2	117.9	13.3	136.1
08/30/2021	33.7	119.2	13.7	137.7
08/31/2021	31.8	113.5	13.1	132.1
Monthly Avg/Sum*:	895.0 *	3,188.4 *	376.0 *	3,784.8 *
Daily Min:	0.0	0.0	0.0	0.0
Daily Max:	35.8	128.2	14.6	147.2
Jul 2021 - Aug 2021	1,543.6	5,493.0	631.7	6,388.2
QTD:	1,543.6 *	5,493.0 *	631.7 *	6,388.2 *
YTD 2021:	3,021.6 *	10,758.7 *	1,159.0 *	11,693.3 *

Monthly Summary By Day Report

VOC PM10

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:48 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 VOC, Lb 1 Day(s)	Unit CT1 PM10, Lb 1 Day(s)	Unit CT2 VOC, Lb 1 Day(s)	Unit CT2 PM10, Lb 1 Day(s)
09/01/2021	31.0	110.4	13.0	128.7
09/02/2021	29.1	102.9	11.9	120.5
09/03/2021	31.0	110.7	13.1	129.5
09/04/2021	22.2	78.8	7.3	75.2
09/05/2021	32.4	115.6	13.4	134.0
09/06/2021	33.1	117.2	13.7	136.6
09/07/2021	34.2	122.9	14.0	141.7
09/08/2021	35.8	128.7	14.3	148.8
09/09/2021	36.9	132.0	14.8	153.1
09/10/2021	33.5	119.1	13.5	138.0
09/11/2021	32.5	115.0	13.2	133.5
09/12/2021	31.9	113.0	13.1	131.1
09/13/2021	32.7	116.3	13.3	134.6
09/14/2021	30.2	108.2	12.7	125.8
09/15/2021	30.1	107.1	12.9	125.2
09/16/2021	27.9	98.8	6.3	63.1
09/17/2021	27.8	98.2	6.1	62.1
09/18/2021	23.8	83.5	0.0	0.1
09/19/2021	24.2	84.8	0.0	0.0
09/20/2021	29.9	107.1	11.4	112.8
09/21/2021	33.6	119.7	13.8	139.1
09/22/2021	33.4	118.0	13.6	136.9
09/23/2021	29.6	106.0	12.2	123.5
09/24/2021	29.3	103.3	12.0	120.2
09/25/2021	25.5	90.5	11.6	112.4
09/26/2021	0.0	0.0	9.6	97.0
09/27/2021	0.0	0.0	9.9	100.7
09/28/2021	0.0	0.0	10.7	107.6
09/29/2021	16.5	58.9	11.2	112.7
09/30/2021	26.9	95.7	2.6	25.8
Monthly Avg/Sum*:	805.0 *	2,862.4 *	325.2 *	3,270.3 *
Daily Min:	0.0	0.0	0.0	0.0
Daily Max:	36.9	132.0	14.8	153.1
Jul 2021 - Sep 2021	2,348.6	8,355.4	956.9	9,658.5
QTD:	2,348.6 *	8,355.4 *	956.9 *	9,658.5 *
YTD 2021:	3,826.6 *	13,621.1 *	1,484.2 *	14,963.6 *

Monthly Summary By Day Report

CT1 and CT2 - Pounds

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:48 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)
07/01/2021	0.0	0.00	0.0	0.0	0.00	0.0
07/02/2021	0.0	0.00	0.0	0.0	0.00	0.0
07/03/2021	0.0	0.00	0.0	0.0	0.00	0.0
07/04/2021	0.0	0.00	0.0	0.0	0.00	0.0
07/05/2021	0.0	0.00	0.0	0.0	0.00	0.0
07/06/2021	0.0	0.00	0.0	0.0	0.00	0.0
07/07/2021	0.0	0.00	0.0	0.0	0.00	0.0
07/08/2021	0.0	0.00	0.0	0.0	0.00	0.0
07/09/2021	0.0	0.00	0.0	0.0	0.00	0.0
07/10/2021	222.0	151.73	8.1	43.1	24.99	0.1
07/11/2021	172.2	148.07	12.6	0.0	0.00	0.0
07/12/2021	163.2	108.86	7.8	13.5	86.10	14.4
07/13/2021	1,002.7	127.00	7.1	179.5	113.89	7.9
07/14/2021	251.6	140.44	24.0	21.3	159.90	26.2
07/15/2021	32.9	146.20	27.7	26.5	164.40	26.7
07/16/2021	40.7	148.30	27.7	39.0	160.50	26.8
07/17/2021	27.8	146.70	27.9	25.5	164.60	26.9
07/18/2021	25.3	148.80	28.7	17.8	171.70	27.9
07/19/2021	25.0	156.90	30.1	17.0	178.60	28.4
07/20/2021	26.4	186.80	28.6	16.0	167.10	27.5
07/21/2021	35.2	164.60	29.1	34.0	175.90	28.1
07/22/2021	36.7	148.50	29.0	39.9	178.40	28.0
07/23/2021	25.9	158.00	28.8	18.7	166.40	27.6
07/24/2021	35.1	150.50	28.2	40.2	169.80	27.0
07/25/2021	31.5	148.40	27.3	28.2	160.60	26.3
07/26/2021	33.2	150.50	28.6	26.3	171.50	28.1
07/27/2021	37.0	152.00	29.2	48.7	175.20	28.1
07/28/2021	35.1	155.10	30.0	22.0	189.00	29.4
07/29/2021	35.1	156.80	30.4	15.7	189.20	29.7
07/30/2021	34.1	161.00	31.0	7.2	200.20	30.4
07/31/2021	46.7	157.60	30.2	26.8	189.90	28.7
Monthly Avg/Sum*:	2,375.4 *	3,312.80 *	552.1 *	706.9 *	3,357.88 *	524.2 *
Daily Min:	25.0	108.86	7.1	7.2	24.99	0.1
Daily Max:	1,002.7	186.80	31.0	179.5	200.20	30.4
Jul 2021 - Jul 2021	2,375.4	3,312.80	552.1	706.9	3,357.88	524.2
QTD:	2,375.4 *	3,312.80 *	552.1 *	706.9 *	3,357.88 *	524.2 *
YTD 2021:	9,874.1 *	12,715.21 *	1,809.4 *	4,519.9 *	11,708.34 *	1,584.8 *

Monthly Summary By Day Report

CT1 and CT2 - Pounds

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:48 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)
08/01/2021	35.4	148.20	27.5	26.9	171.60	26.9
08/02/2021	47.5	157.50	30.8	18.5	194.90	29.7
08/03/2021	53.1	160.70	30.6	84.8	173.50	20.4
08/04/2021	42.5	159.10	30.3	9.4	191.40	29.5
08/05/2021	43.5	152.40	30.2	11.9	188.80	29.2
08/06/2021	46.1	148.40	28.0	20.7	170.10	27.5
08/07/2021	144.0	137.01	14.0	215.1	158.57	16.1
08/08/2021	132.6	131.62	14.3	11.8	135.60	23.0
08/09/2021	35.7	152.50	28.4	19.0	182.20	27.5
08/10/2021	37.7	152.20	29.1	14.9	184.90	28.4
08/11/2021	36.2	179.40	29.4	7.9	188.80	28.4
08/12/2021	42.9	159.90	29.0	11.4	187.00	27.9
08/13/2021	46.5	149.10	28.3	21.2	173.50	27.2
08/14/2021	31.5	144.20	26.8	10.8	169.30	26.1
08/15/2021	32.8	146.70	27.1	10.5	171.40	26.1
08/16/2021	44.4	153.20	28.9	12.9	184.10	28.0
08/17/2021	39.4	147.00	28.0	14.6	174.00	27.3
08/18/2021	37.2	128.50	25.8	27.8	149.10	25.4
08/19/2021	47.7	104.30	25.7	17.8	157.40	25.0
08/20/2021	77.0	121.90	24.5	20.9	148.70	24.1
08/21/2021	10.3	2.46	0.1	64.0	60.40	10.8
08/22/2021	0.0	0.00	0.0	0.0	0.00	0.0
08/23/2021	179.3	143.91	7.4	314.5	189.62	11.5
08/24/2021	66.2	116.20	25.9	22.5	167.90	25.0
08/25/2021	80.2	124.10	26.5	21.1	165.50	25.9
08/26/2021	82.5	136.50	27.5	16.6	173.10	26.7
08/27/2021	78.4	132.70	28.4	7.5	182.70	27.7
08/28/2021	71.5	125.20	28.1	7.9	175.60	27.2
08/29/2021	74.9	126.30	28.1	12.8	173.70	27.4
08/30/2021	81.9	141.70	28.6	9.4	183.70	27.8
08/31/2021	78.3	125.50	27.0	15.7	174.10	26.6
Monthly Avg/Sum*:	1,857.2 *	4,108.40 *	764.3 *	1,080.8 *	5,101.19 *	760.3 *
Daily Min:	10.3	2.46	0.1	7.5	60.40	10.8
Daily Max:	179.3	179.40	30.8	314.5	194.90	29.7
Jul 2021 - Aug 2021	4,232.6	7,421.20	1,316.4	1,787.7	8,459.07	1,284.5
QTD:	4,232.6 *	7,421.20 *	1,316.4 *	1,787.7 *	8,459.07 *	1,284.5 *
YTD 2021:	11,731.3 *	16,823.61 *	2,573.7 *	5,600.7 *	16,809.53 *	2,345.1 *

Monthly Summary By Day Report

CT1 and CT2 - Pounds

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:48 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)
09/01/2021	73.7	122.20	26.3	15.0	162.40	25.7
09/02/2021	70.4	121.70	24.7	15.7	146.00	24.2
09/03/2021	75.2	120.00	26.7	19.0	167.60	26.0
09/04/2021	157.7	120.82	18.9	70.7	158.84	15.0
09/05/2021	79.2	137.10	27.7	8.5	178.70	27.0
09/06/2021	71.5	132.40	28.0	4.9	177.50	27.6
09/07/2021	84.5	145.90	29.4	8.9	189.00	28.6
09/08/2021	89.1	152.20	30.8	1.8	196.20	30.1
09/09/2021	84.8	158.00	31.2	0.0	204.10	30.9
09/10/2021	78.3	141.50	28.5	3.1	184.30	27.6
09/11/2021	74.2	136.30	27.4	8.2	174.80	26.8
09/12/2021	79.1	130.70	27.2	9.6	171.00	26.2
09/13/2021	80.3	131.00	27.6	9.2	175.10	27.1
09/14/2021	77.4	126.40	25.8	13.7	164.30	25.2
09/15/2021	82.5	122.30	25.8	22.9	159.30	24.9
09/16/2021	63.3	104.50	23.5	73.5	144.41	12.6
09/17/2021	64.4	104.10	23.6	73.5	135.81	12.5
09/18/2021	43.1	94.40	19.6	4.3	0.77	0.0
09/19/2021	39.7	88.70	19.9	0.0	0.00	0.0
09/20/2021	76.7	115.30	25.7	106.2	219.20	22.6
09/21/2021	93.1	138.70	28.6	37.0	180.90	27.7
09/22/2021	102.5	138.20	28.5	24.9	181.10	27.3
09/23/2021	54.3	91.20	25.9	3.2	158.20	24.0
09/24/2021	46.5	91.00	24.8	0.0	155.80	24.0
09/25/2021	53.2	96.60	21.5	0.0	135.60	22.7
09/26/2021	0.0	0.00	0.0	0.0	97.00	19.4
09/27/2021	0.0	0.00	0.0	0.0	102.30	20.1
09/28/2021	0.0	0.00	0.0	21.9	130.10	21.6
09/29/2021	141.0	163.58	14.0	0.0	136.90	22.8
09/30/2021	49.0	100.50	22.9	3.5	27.74	5.2
Monthly Avg/Sum*:	2,084.7 *	3,325.30 *	684.5 *	559.2 *	4,414.97 *	655.4 *
Daily Min:	39.7	88.70	14.0	0.0	0.77	0.0
Daily Max:	157.7	163.58	31.2	106.2	219.20	30.9
Jul 2021 - Sep 2021	6,317.3	10,746.50	2,000.9	2,346.9	12,874.04	1,939.9
QTD:	6,317.3 *	10,746.50 *	2,000.9 *	2,346.9 *	12,874.04 *	1,939.9 *
YTD 2021:	13,816.0 *	20,148.91 *	3,258.2 *	6,159.9 *	21,224.50 *	3,000.5 *

Monthly Summary By Day Report

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/04/2021 10:52 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 OperatingTime, Hr	Unit CT1 GasFlowCT, 100scf	Unit CT1 DBOn, Hr	Unit CT1 GasFlowDB, 100scf	Unit CT1 GasFlow, Total, 100scf	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 HI, MBtu
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/01/2021	0.00	0.0	0.00	0.0	0.0	0.0	0.000
07/02/2021	0.00	0.0	0.00	0.0	0.0	0.0	0.000
07/03/2021	0.00	0.0	0.00	0.0	0.0	0.0	0.000
07/04/2021	0.00	0.0	0.00	0.0	0.0	0.0	0.000
07/05/2021	0.00	0.0	0.00	0.0	0.0	0.0	0.000
07/06/2021	0.00	0.0	0.00	0.0	0.0	0.0	0.000
07/07/2021	0.00	0.0	0.00	0.0	0.0	0.0	0.000
07/08/2021	0.00	0.0	0.00	0.0	0.0	0.0	0.000
07/09/2021	0.00	0.0	0.00	0.0	0.0	0.0	0.000
07/10/2021	10.23	130,848.3	0.00	0.0	130,848.3	1,650.6	13,647.575
07/11/2021	14.65	206,453.8	0.00	0.0	206,453.8	2,078.4	21,533.135
07/12/2021	8.47	124,265.0	0.00	0.0	124,265.0	1,343.2	12,960.935
07/13/2021	11.47	113,963.1	0.00	0.0	113,963.1	2,477.7	11,886.475
07/14/2021	20.58	336,311.7	13.80	47,990.6	384,302.3	3,498.6	40,082.850
07/15/2021	24.00	396,121.5	14.94	49,561.8	445,683.3	3,601.4	46,485.100
07/16/2021	24.00	396,966.3	13.19	43,353.0	440,319.3	3,615.2	45,925.400
07/17/2021	24.00	393,307.9	13.29	50,554.1	443,862.0	3,703.7	46,294.800
07/18/2021	24.00	400,165.9	15.02	59,180.3	459,346.2	3,857.4	47,909.500
07/19/2021	24.00	403,098.3	17.25	70,686.8	473,785.1	4,152.5	49,415.800
07/20/2021	24.00	399,155.5	14.28	56,469.7	455,625.2	3,628.7	47,521.900
07/21/2021	24.00	403,497.4	17.65	62,525.5	466,022.9	3,763.7	48,606.200
07/22/2021	24.00	403,749.7	17.06	60,061.0	463,810.7	3,831.2	48,375.300
07/23/2021	24.00	402,335.3	14.12	56,649.3	458,984.6	3,892.5	47,872.100
07/24/2021	24.00	399,752.0	14.00	48,099.5	447,851.5	3,730.7	46,710.900
07/25/2021	24.00	396,564.4	12.03	39,692.7	436,257.1	3,591.5	45,501.400
07/26/2021	24.00	399,278.3	16.13	61,385.2	460,663.5	3,888.8	48,047.300
07/27/2021	24.00	407,079.6	16.00	57,031.4	464,111.0	3,888.9	48,406.900
07/28/2021	24.00	406,281.7	20.08	78,616.2	484,897.9	4,295.3	50,574.900
07/29/2021	24.00	403,365.3	20.43	87,063.3	490,428.6	4,411.0	51,151.900
07/30/2021	24.00	405,662.0	22.10	97,796.3	503,458.3	4,546.1	52,510.800
07/31/2021	24.00	407,921.6	20.02	73,318.5	481,240.1	4,132.2	50,193.300
Monthly Avg/Sum*:	473.40 *	7,736,144.6 *	291.39 *	1,100,035.2 *	8,836,179.8 *	77,579.3 *	921,614.470 *
Daily Min:	8.47	113,963.1	0.00	0.0	113,963.1	1,343.2	11,886.475
Daily Max:	24.00	407,921.6	22.10	97,796.3	503,458.3	4,546.1	52,510.800
Jul 2021 - Jul 2021	473.40	7,736,144.6	291.39	1,100,035.2	8,836,179.8	77,579.3	921,614.470
QTD:	473.40 *	7,736,144.6 *	291.39 *	1,100,035.2 *	8,836,179.8 *	77,579.3 *	921,614.470 *
YTD 2021:	1,714.19 *	26,910,946.0 *	727.63 *	2,104,430.5 *	29,015,377.0 *	253,854.1 *	3,027,092.441 *

Monthly Summary By Day Report

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/04/2021 10:52 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 OperatingTime, Hr	Unit CT1 GasFlowCT, 100scf	Unit CT1 DBOn, Hr	Unit CT1 GasFlowDB, 100scf	Unit CT1 GasFlow, Total, 100scf	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 HI, MBtu
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/01/2021	24.00	396,402.7	12.50	44,490.8	440,893.5	3,759.3	45,985.300
08/02/2021	24.00	410,428.8	20.49	80,407.4	490,836.2	4,319.7	51,194.400
08/03/2021	24.00	407,973.7	20.08	79,215.7	487,189.4	4,412.9	50,813.600
08/04/2021	24.00	407,538.4	19.95	77,876.4	485,414.8	4,234.3	50,628.800
08/05/2021	24.00	409,948.2	20.02	71,736.9	481,685.1	4,028.4	50,239.700
08/06/2021	24.00	398,081.0	15.81	49,436.9	447,517.9	3,706.9	46,676.100
08/07/2021	13.68	209,837.5	6.31	16,631.9	226,469.4	2,089.1	23,620.716
08/08/2021	13.40	204,598.5	7.79	23,301.7	227,900.2	2,198.1	23,769.936
08/09/2021	24.00	400,681.9	15.52	51,695.8	452,377.7	3,745.5	47,183.100
08/10/2021	24.00	402,381.1	17.07	61,413.0	463,794.1	3,956.6	48,373.800
08/11/2021	24.00	401,322.2	17.90	66,810.4	468,132.6	3,812.7	48,826.300
08/12/2021	24.00	404,689.4	18.13	59,600.5	464,289.9	3,821.8	48,425.400
08/13/2021	24.00	398,440.4	17.27	51,081.9	449,522.3	3,709.0	46,885.100
08/14/2021	24.00	389,270.5	11.98	39,288.2	428,558.7	3,604.4	44,698.700
08/15/2021	24.00	391,169.8	12.54	40,819.9	431,989.7	3,653.4	45,056.500
08/16/2021	24.00	398,365.5	18.19	64,418.2	462,783.7	3,984.4	48,268.600
08/17/2021	24.00	399,490.8	15.32	48,220.9	447,711.7	3,790.2	46,696.500
08/18/2021	24.00	390,664.5	10.87	25,229.7	415,894.2	3,424.0	43,377.800
08/19/2021	24.00	388,374.1	9.08	23,442.2	411,816.3	3,093.5	42,952.300
08/20/2021	24.00	373,764.7	8.25	20,305.8	394,070.5	2,675.3	41,101.500
08/21/2021	0.23	1,312.7	0.00	0.0	1,312.7	173.8	136.919
08/22/2021	0.00	0.0	0.00	0.0	0.0	0.0	0.000
08/23/2021	7.90	112,332.9	3.20	5,233.0	117,565.9	970.7	12,262.140
08/24/2021	24.00	393,135.2	8.10	20,396.3	413,531.5	2,732.4	43,131.400
08/25/2021	24.00	394,260.1	12.39	28,764.8	423,024.9	2,799.3	44,121.400
08/26/2021	24.00	398,635.8	13.71	43,038.3	441,674.1	3,023.6	46,066.800
08/27/2021	24.00	401,321.6	14.93	55,280.8	456,602.4	3,232.1	47,623.700
08/28/2021	24.00	400,549.0	13.09	48,905.6	449,454.6	3,126.1	46,878.200
08/29/2021	24.00	398,043.5	14.56	53,593.2	451,636.7	3,172.1	47,105.700
08/30/2021	24.00	400,613.4	15.87	57,169.8	457,783.2	3,199.4	47,746.700
08/31/2021	24.00	398,449.6	12.35	36,167.1	434,616.7	2,914.3	45,330.500
Monthly Avg/Sum*:	659.21 *	10,882,077.5 *	403.27 *	1,343,973.1 *	12,226,050.6 *	97,363.3 *	1,275,177.611 *
Daily Min:	0.23	1,312.7	0.00	0.0	1,312.7	173.8	136.919
Daily Max:	24.00	410,428.8	20.49	80,407.4	490,836.2	4,412.9	51,194.400
Jul 2021 - Aug 2021	1,132.61	18,618,222.1	694.66	2,444,008.3	21,062,230.4	174,942.6	2,196,792.081
QTD:	1,132.61 *	18,618,222.1 *	694.66 *	2,444,008.3 *	21,062,230.4 *	174,942.6 *	2,196,792.081 *
YTD 2021:	2,373.40 *	37,793,023.5 *	1,130.90 *	3,448,403.6 *	41,241,427.6 *	351,217.4 *	4,302,270.052 *

Monthly Summary By Day Report

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/04/2021 10:52 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 OperatingTime, Hr	Unit CT1 GasFlowCT, 100scf	Unit CT1 DBOn, Hr	Unit CT1 GasFlowDB, 100scf	Unit CT1 GasFlow, Total, 100scf	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 HI, MBtu
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/01/2021	24.00	394,267.3	12.31	28,815.0	423,082.3	2,788.1	44,127.400
09/02/2021	24.00	378,284.5	8.00	16,660.6	394,945.1	2,609.7	41,192.900
09/03/2021	24.00	396,284.1	10.77	28,457.0	424,741.1	2,831.8	44,300.300
09/04/2021	17.78	273,416.8	8.36	28,228.6	301,645.4	2,546.4	31,461.684
09/05/2021	24.00	400,693.9	12.84	42,717.7	443,411.6	3,077.2	46,247.500
09/06/2021	24.00	397,336.7	14.07	52,409.2	449,745.9	3,236.9	46,908.400
09/07/2021	24.00	407,393.5	17.93	63,380.6	470,774.1	3,351.9	49,101.800
09/08/2021	24.00	407,628.7	22.00	86,077.6	493,706.3	3,683.5	51,493.700
09/09/2021	24.00	407,094.6	24.00	98,176.4	505,271.0	3,861.8	52,700.000
09/10/2021	24.00	398,807.7	16.24	58,244.9	457,052.6	3,229.4	47,670.400
09/11/2021	24.00	397,953.6	13.03	43,201.7	441,155.3	3,101.2	46,012.300
09/12/2021	24.00	391,665.5	13.49	41,230.0	432,895.5	3,000.0	45,150.700
09/13/2021	24.00	395,317.0	15.08	50,305.9	445,622.9	3,068.1	46,478.500
09/14/2021	24.00	388,105.3	9.96	26,462.0	414,567.3	2,788.5	43,239.200
09/15/2021	24.00	385,436.8	11.61	25,125.8	410,562.6	2,712.9	42,821.800
09/16/2021	24.00	365,722.2	5.87	13,846.9	379,569.1	2,540.1	39,589.100
09/17/2021	24.00	360,141.1	7.45	16,306.4	376,447.5	2,513.1	39,263.800
09/18/2021	24.00	320,982.2	0.00	0.0	320,982.2	2,200.2	33,478.500
09/19/2021	24.00	325,209.3	0.00	0.0	325,209.3	2,202.8	33,919.400
09/20/2021	24.00	376,156.5	12.24	33,874.2	410,030.7	2,770.3	42,766.400
09/21/2021	24.00	404,675.4	18.07	53,929.8	458,605.2	3,179.7	47,832.400
09/22/2021	24.00	406,204.1	16.22	46,399.0	452,603.1	3,071.7	47,206.300
09/23/2021	24.00	400,096.0	2.96	6,236.4	406,332.4	2,678.0	42,380.400
09/24/2021	24.00	395,746.5	0.00	0.0	395,746.5	2,644.5	41,276.200
09/25/2021	22.45	346,014.2	0.00	0.0	346,014.2	2,459.8	36,089.155
09/26/2021	0.00	0.0	0.00	0.0	0.0	0.0	0.000
09/27/2021	0.00	0.0	0.00	0.0	0.0	0.0	0.000
09/28/2021	0.00	0.0	0.00	0.0	0.0	0.0	0.000
09/29/2021	16.25	225,658.5	0.00	0.0	225,658.5	1,873.5	23,536.275
09/30/2021	24.00	354,014.3	7.97	12,756.5	366,770.8	2,475.0	38,254.200
Monthly Avg/Sum*:	632.48 *	10,100,306.3 *	280.47 *	872,842.2 *	10,973,148.5 *	76,496.1 *	1,144,498.714 *
Daily Min:	16.25	225,658.5	0.00	0.0	225,658.5	1,873.5	23,536.275
Daily Max:	24.00	407,628.7	24.00	98,176.4	505,271.0	3,861.8	52,700.000
Jul 2021 - Sep 2021	1,765.09	28,718,528.4	975.13	3,316,850.5	32,035,378.9	251,438.7	3,341,290.795
QTD:	1,765.09 *	28,718,528.4 *	975.13 *	3,316,850.5 *	32,035,378.9 *	251,438.7 *	3,341,290.795 *
YTD 2021:	3,005.88 *	47,893,329.8 *	1,411.37 *	4,321,245.8 *	52,214,576.1 *	427,713.5 *	5,446,768.766 *

Monthly Summary By Day Report

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/04/2021 10:52 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT2 OperatingTime, Hr	Unit CT2 GasFlowCT, 100scf	Unit CT2 DBOn, Hr	Unit CT2 GasFlowDB, 100scf	Unit CT2 GasFlow, Total, 100scf	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 HI, MBtu
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/01/2021	0.00	0.0	0.00	0.0	0.0	0.0	0.000
07/02/2021	0.00	0.0	0.00	0.0	0.0	0.0	0.000
07/03/2021	0.00	0.0	0.00	0.0	0.0	0.0	0.000
07/04/2021	0.00	0.0	0.00	0.0	0.0	0.0	0.000
07/05/2021	0.00	0.0	0.00	0.0	0.0	0.0	0.000
07/06/2021	0.00	0.0	0.00	0.0	0.0	0.0	0.000
07/07/2021	0.00	0.0	0.00	0.0	0.0	0.0	0.000
07/08/2021	0.00	0.0	0.00	0.0	0.0	0.0	0.000
07/09/2021	0.00	0.0	0.00	0.0	0.0	0.0	0.000
07/10/2021	0.82	1,539.8	0.00	0.0	1,539.8	0.1	157.519
07/11/2021	0.00	0.0	0.00	0.0	0.0	0.0	0.000
07/12/2021	16.70	240,412.2	0.00	0.0	240,412.2	1,997.4	24,594.240
07/13/2021	9.06	127,664.7	1.00	1,634.7	129,299.4	1,114.7	13,227.241
07/14/2021	24.00	391,046.9	14.10	37,897.4	428,944.3	2,892.4	43,881.000
07/15/2021	24.00	392,213.7	14.97	43,716.3	435,930.0	2,902.0	44,595.700
07/16/2021	24.00	392,995.9	13.15	38,041.6	431,037.5	2,915.4	44,095.200
07/17/2021	24.00	388,882.7	13.29	44,013.9	432,896.6	2,945.6	44,285.300
07/18/2021	24.00	395,554.1	15.07	51,791.9	447,346.0	3,027.6	45,763.800
07/19/2021	24.00	397,960.8	17.29	61,956.1	459,916.9	3,138.8	47,049.400
07/20/2021	24.00	395,260.5	14.28	49,123.1	444,383.6	2,976.5	45,460.200
07/21/2021	24.00	398,727.4	17.60	55,089.1	453,816.5	3,019.0	46,425.500
07/22/2021	24.00	398,903.7	17.06	53,110.8	452,014.5	3,023.3	46,241.000
07/23/2021	24.00	397,383.3	14.13	49,630.6	447,013.9	3,030.2	45,729.500
07/24/2021	24.00	395,118.0	14.05	42,780.0	437,898.0	2,931.4	44,796.900
07/25/2021	24.00	392,549.1	12.05	35,687.7	428,236.8	2,835.7	43,808.500
07/26/2021	24.00	395,065.5	16.13	54,728.3	449,793.8	3,063.0	46,014.100
07/27/2021	24.00	402,678.8	16.02	50,752.1	453,430.9	3,147.5	46,386.200
07/28/2021	24.00	400,985.5	20.08	73,119.4	474,104.9	3,273.3	48,501.200
07/29/2021	24.00	397,556.6	20.33	77,168.8	474,725.4	3,225.1	48,564.400
07/30/2021	24.00	399,342.2	22.10	89,847.7	489,189.9	3,357.3	50,044.100
07/31/2021	24.00	402,392.0	20.02	68,965.4	471,357.4	3,215.2	48,219.900
Monthly Avg/Sum*:	458.58 *	7,504,233.4 *	292.72 *	979,054.9 *	8,483,288.3 *	58,031.5 *	867,840.900 *
Daily Min:	0.82	1,539.8	0.00	0.0	1,539.8	0.1	157.519
Daily Max:	24.00	402,678.8	22.10	89,847.7	489,189.9	3,357.3	50,044.100
Jul 2021 - Jul 2021	458.58	7,504,233.4	292.72	979,054.9	8,483,288.3	58,031.5	867,840.900
QTD:	458.58 *	7,504,233.4 *	292.72 *	979,054.9 *	8,483,288.3 *	58,031.5 *	867,840.900 *
YTD 2021:	1,467.32 *	23,825,977.6 *	734.64 *	1,941,987.4 *	25,767,965.1 *	180,356.3 *	2,636,063.012 *

Monthly Summary By Day Report

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/04/2021 10:52 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT2 OperatingTime, Hr	Unit CT2 GasFlowCT, 100scf	Unit CT2 DBOn, Hr	Unit CT2 GasFlowDB, 100scf	Unit CT2 GasFlow, Total, 100scf	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 HI, MBtu
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/01/2021	24.00	392,652.0	12.54	41,420.4	434,072.4	2,946.6	44,405.600
08/02/2021	24.00	405,205.1	20.47	74,913.3	480,118.4	3,403.6	49,116.200
08/03/2021	17.51	282,055.7	13.00	49,004.6	331,060.3	2,560.2	33,867.451
08/04/2021	24.00	402,657.1	19.95	72,611.5	475,268.6	3,279.2	48,620.200
08/05/2021	24.00	405,681.5	20.02	67,831.3	473,512.8	3,213.9	48,440.400
08/06/2021	24.00	395,923.2	15.86	47,211.4	443,134.6	2,952.3	45,332.900
08/07/2021	17.08	244,110.5	6.28	15,848.5	259,959.1	2,632.0	26,593.631
08/08/2021	24.00	357,121.8	7.77	21,936.0	379,057.8	2,551.6	38,777.900
08/09/2021	24.00	396,747.4	15.58	48,612.1	445,359.5	3,062.9	45,560.200
08/10/2021	24.00	397,796.6	17.06	58,244.3	456,040.9	3,196.3	46,653.100
08/11/2021	24.00	397,246.3	18.04	64,459.0	461,705.3	3,241.8	47,232.600
08/12/2021	24.00	399,876.9	18.11	57,032.4	456,909.3	3,121.9	46,741.700
08/13/2021	24.00	393,958.1	17.27	49,174.0	443,132.1	2,977.2	45,332.600
08/14/2021	24.00	385,618.4	12.07	38,483.5	424,101.9	2,844.2	43,385.500
08/15/2021	24.00	387,320.7	12.52	38,667.0	425,987.7	2,859.1	43,578.500
08/16/2021	24.00	392,987.3	18.22	60,552.6	453,539.9	3,133.8	46,397.500
08/17/2021	24.00	393,985.8	15.32	46,082.0	440,067.8	3,081.2	45,018.900
08/18/2021	24.00	387,179.6	10.85	24,253.1	411,432.7	3,026.3	42,089.500
08/19/2021	24.00	384,889.1	9.08	22,423.3	407,312.4	2,847.6	41,667.900
08/20/2021	24.00	371,392.2	8.25	19,417.6	390,809.8	2,623.5	39,979.900
08/21/2021	14.39	176,837.6	0.00	0.0	176,837.6	1,658.3	18,090.496
08/22/2021	0.00	0.0	0.00	0.0	0.0	0.0	0.000
08/23/2021	13.88	181,099.6	3.18	5,114.4	186,214.0	2,091.6	19,049.742
08/24/2021	24.00	391,020.9	8.08	19,217.2	410,238.1	2,861.2	41,967.500
08/25/2021	24.00	391,682.8	12.39	27,324.9	419,007.7	2,963.3	42,864.600
08/26/2021	24.00	393,111.0	13.76	40,542.3	433,653.3	3,243.4	44,362.700
08/27/2021	24.00	396,496.7	14.93	53,766.6	450,263.3	3,394.3	46,061.800
08/28/2021	24.00	395,585.2	13.09	45,688.8	441,274.0	3,350.8	45,142.300
08/29/2021	24.00	393,192.9	14.89	50,488.6	443,681.5	3,266.8	45,388.700
08/30/2021	24.00	395,766.2	15.88	53,376.7	449,142.9	3,229.1	45,947.400
08/31/2021	24.00	394,953.2	12.31	34,497.3	429,450.5	3,001.5	43,933.000
Monthly Avg/Sum*:	686.86 *	11,084,151.4 *	396.77 *	1,248,194.7 *	12,332,346.2 *	88,615.5 *	1,261,600.420 *
Daily Min:	13.88	176,837.6	0.00	0.0	176,837.6	1,658.3	18,090.496
Daily Max:	24.00	405,681.5	20.47	74,913.3	480,118.4	3,403.6	49,116.200
Jul 2021 - Aug 2021	1,145.44	18,588,384.8	689.49	2,227,249.6	20,815,634.5	146,647.0	2,129,441.320
QTD:	1,145.44 *	18,588,384.8 *	689.49 *	2,227,249.6 *	20,815,634.5 *	146,647.0 *	2,129,441.320 *
YTD 2021:	2,154.18 *	34,910,129.0 *	1,131.41 *	3,190,182.1 *	38,100,311.3 *	268,971.8 *	3,897,663.432 *

Monthly Summary By Day Report

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/04/2021 10:52 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT2 OperatingTime, Hr	Unit CT2 GasFlowCT, 100scf	Unit CT2 DBOn, Hr	Unit CT2 GasFlowDB, 100scf	Unit CT2 GasFlow, Total, 100scf	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 HI, MBtu
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/01/2021	24.00	391,811.4	12.36	28,311.0	420,122.4	2,911.4	42,978.500
09/02/2021	24.00	376,684.0	8.00	16,086.8	392,770.8	2,723.6	40,180.600
09/03/2021	24.00	394,147.1	10.77	27,048.6	421,195.7	3,036.0	43,088.400
09/04/2021	13.95	218,374.3	8.34	26,569.4	244,943.7	2,076.0	25,057.665
09/05/2021	24.00	396,329.4	12.84	40,396.4	436,725.8	3,206.8	44,677.000
09/06/2021	24.00	394,661.1	14.07	51,226.4	445,887.5	3,370.2	45,614.200
09/07/2021	24.00	401,664.6	17.95	60,232.9	461,897.5	3,497.7	47,252.500
09/08/2021	24.00	401,296.6	21.91	83,403.3	484,699.9	3,751.2	49,584.900
09/09/2021	24.00	400,895.0	24.00	97,781.5	498,676.5	3,843.9	51,014.500
09/10/2021	24.00	394,386.4	16.24	55,749.9	450,136.3	3,234.7	46,049.100
09/11/2021	24.00	394,034.5	13.03	40,952.0	434,986.5	3,134.7	44,498.800
09/12/2021	24.00	387,271.7	13.49	39,450.8	426,722.5	3,111.8	43,653.500
09/13/2021	24.00	390,543.9	15.08	47,638.7	438,182.6	3,254.9	44,826.200
09/14/2021	24.00	384,517.2	9.94	25,390.1	409,907.3	2,913.7	41,933.500
09/15/2021	24.00	382,895.0	11.61	24,648.3	407,543.3	2,844.1	41,691.600
09/16/2021	12.65	192,022.3	5.87	13,445.0	205,467.3	1,686.9	21,019.315
09/17/2021	12.57	186,220.1	7.45	15,855.1	202,075.2	1,839.6	20,672.219
09/18/2021	0.15	464.2	0.00	0.0	464.2	132.7	47.490
09/19/2021	0.00	0.0	0.00	0.0	0.0	0.0	0.000
09/20/2021	22.30	334,848.8	12.24	31,904.4	366,753.2	2,941.3	37,518.930
09/21/2021	24.00	400,459.4	18.07	52,934.8	453,394.2	3,533.1	46,382.200
09/22/2021	24.00	402,031.3	16.22	44,405.6	446,436.9	3,411.1	45,670.500
09/23/2021	24.00	395,799.0	2.96	6,143.5	401,942.5	2,993.6	41,118.700
09/24/2021	24.00	392,148.4	0.00	0.0	392,148.4	2,884.2	40,116.700
09/25/2021	24.00	367,101.7	0.00	0.0	367,101.7	2,562.2	37,554.400
09/26/2021	24.00	315,343.5	0.00	0.0	315,343.5	2,096.4	32,259.600
09/27/2021	24.00	327,128.4	0.00	0.0	327,128.4	2,238.1	33,465.300
09/28/2021	24.00	339,720.8	5.02	10,472.1	350,192.9	2,539.4	35,824.800
09/29/2021	24.00	367,450.1	0.00	0.0	367,450.1	2,721.5	37,590.100
09/30/2021	6.18	83,985.1	0.00	0.0	83,985.1	753.2	8,591.628
Monthly Avg/Sum*:	619.80 *	9,814,235.3 *	277.46 *	840,046.6 *	10,654,281.9 *	79,244.0 *	1,089,932.847 *
Daily Min:	0.15	464.2	0.00	0.0	464.2	132.7	47.490
Daily Max:	24.00	402,031.3	24.00	97,781.5	498,676.5	3,843.9	51,014.500
Jul 2021 - Sep 2021	1,765.24	28,402,620.1	966.95	3,067,296.2	31,469,916.4	225,891.0	3,219,374.167
QTD:	1,765.24 *	28,402,620.1 *	966.95 *	3,067,296.2 *	31,469,916.4 *	225,891.0 *	3,219,374.167 *
YTD 2021:	2,773.98 *	44,724,364.3 *	1,408.87 *	4,030,228.7 *	48,754,593.2 *	348,215.8 *	4,987,596.279 *

ATTACHMENT 10
Maximum Emissions

FCD: AQ-25
Title V: #6

AQ-25 Emission Limits

Maximum Emissions Both Turbines (lbs)		
Pollutant	1-Hour Emissions	24-Hour Emissions
NO_x	666.60	2,994.60
CO	967.00	7,659.00
VOC	55.40	630.60
PM10	27.00	648.00
SO_2	14.80	355.20

Monthly Summary By Day Report

AQ-25

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:53 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	PlantWide NOx, Lb 1 Day(s)	PlantWide CO, Lb 1 Day(s)	PlantWide VOC, Lb 1 Day(s)	PlantWide PM10, Lb 1 Day(s)	PlantWide SO2, Lb 1 Day(s)
07/01/2021	0.0	0.0	0.0	0.0	0.0
07/02/2021	0.0	0.0	0.0	0.0	0.0
07/03/2021	0.0	0.0	0.0	0.0	0.0
07/04/2021	0.0	0.0	0.0	0.0	0.0
07/05/2021	0.0	0.0	0.0	0.0	0.0
07/06/2021	0.0	0.0	0.0	0.0	0.0
07/07/2021	0.0	0.0	0.0	0.0	0.0
07/08/2021	0.0	0.0	0.0	0.0	0.0
07/09/2021	0.0	0.0	0.0	0.0	0.0
07/10/2021	176.7	265.1	9.5	34.7	0.1
07/11/2021	148.1	172.2	15.1	54.0	0.0
07/12/2021	195.0	176.7	16.4	106.1	14.4
07/13/2021	240.9	1,182.2	12.4	69.4	7.9
07/14/2021	300.3	272.9	41.6	231.9	26.2
07/15/2021	310.6	59.4	46.0	249.9	26.7
07/16/2021	308.8	79.7	45.2	247.0	26.8
07/17/2021	311.3	53.3	45.6	248.5	26.9
07/18/2021	320.5	43.1	47.2	257.4	27.9
07/19/2021	335.5	42.0	48.4	264.4	28.4
07/20/2021	353.9	42.4	46.9	255.2	27.5
07/21/2021	340.5	69.2	47.5	261.1	28.1
07/22/2021	326.9	76.6	47.6	259.5	28.0
07/23/2021	324.4	44.6	47.2	256.4	27.6
07/24/2021	320.3	75.3	46.1	251.3	27.0
07/25/2021	309.0	59.7	45.3	245.0	26.3
07/26/2021	322.0	59.5	47.5	258.3	28.1
07/27/2021	327.2	85.7	47.8	260.4	28.1
07/28/2021	344.1	57.1	49.8	272.0	29.4
07/29/2021	346.0	50.8	50.2	273.5	29.7
07/30/2021	361.2	41.3	51.5	281.4	30.4
07/31/2021	347.5	73.5	49.5	270.6	28.7
Monthly Avg/Sum*:	6,670.7 *	3,082.3 *	904.3 *	4,908.0 *	- *
Daily Min:	0.0	0.0	0.0	0.0	-
Daily Max:	361.2	1,182.2	51.5	281.4	-
Jul 2021 - Jul 2021	6,670.7	3,082.3	904.3	4,908.0	-
QTD:	6,670.7 *	3,082.3 *	904.3 *	4,908.0 *	0.0 *
YTD 2021:	24,424.4 *	14,394.0 *	2,909.6 *	15,478.8 *	7.7 *

Monthly Summary By Day Report

AQ-25

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:53 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	PlantWide NOx, Lb 1 Day(s)	PlantWide CO, Lb 1 Day(s)	PlantWide VOC, Lb 1 Day(s)	PlantWide PM10, Lb 1 Day(s)	PlantWide SO2, Lb 1 Day(s)
08/01/2021	319.8	62.3	45.7	248.2	26.9
08/02/2021	352.4	66.0	50.4	275.4	29.7
08/03/2021	334.2	137.9	45.4	228.3	20.4
08/04/2021	350.5	51.9	49.9	272.5	29.5
08/05/2021	341.2	55.4	49.5	271.1	29.2
08/06/2021	318.5	66.8	46.5	252.9	27.5
08/07/2021	295.6	359.1	24.6	138.8	16.1
08/08/2021	267.2	144.4	28.1	175.7	23.0
08/09/2021	334.7	54.7	46.5	254.7	27.5
08/10/2021	337.1	52.6	47.4	261.1	28.4
08/11/2021	368.2	44.1	48.0	263.6	28.4
08/12/2021	346.9	54.3	47.7	261.0	27.9
08/13/2021	322.6	67.7	46.7	253.4	27.2
08/14/2021	313.5	42.3	44.1	241.9	26.1
08/15/2021	318.1	43.3	44.7	243.1	26.1
08/16/2021	337.3	57.3	47.4	260.0	28.0
08/17/2021	321.0	54.0	46.2	251.9	27.3
08/18/2021	277.6	65.0	43.3	234.9	25.4
08/19/2021	261.7	65.5	42.9	232.4	25.0
08/20/2021	270.6	97.9	41.1	222.7	24.1
08/21/2021	62.9	74.3	5.4	54.4	10.8
08/22/2021	0.0	0.0	0.0	0.0	0.0
08/23/2021	333.5	493.8	14.2	88.0	11.5
08/24/2021	284.1	88.7	43.2	233.5	25.0
08/25/2021	289.6	101.3	44.1	238.7	25.9
08/26/2021	309.6	99.1	45.5	248.6	26.7
08/27/2021	315.4	85.9	47.1	257.3	27.7
08/28/2021	300.8	79.4	46.6	252.6	27.2
08/29/2021	300.0	87.7	46.5	254.0	27.4
08/30/2021	325.4	91.3	47.4	256.9	27.8
08/31/2021	299.6	94.0	44.9	245.6	26.6
Monthly Avg/Sum*:	9,209.6 *	2,938.0 *	1,271.0 *	6,973.2 *	- *
Daily Min:	0.0	0.0	0.0	0.0	-
Daily Max:	368.2	493.8	50.4	275.4	-
Jul 2021 - Aug 2021	15,880.3	6,020.3	2,175.3	11,881.2	-
QTD:	15,880.3 *	6,020.3 *	2,175.3 *	11,881.2 *	0.0 *
YTD 2021:	33,634.0 *	17,332.0 *	4,180.6 *	22,452.0 *	7.7 *

Monthly Summary By Day Report

AQ-25

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:53 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	PlantWide NOx, Lb 1 Day(s)	PlantWide CO, Lb 1 Day(s)	PlantWide VOC, Lb 1 Day(s)	PlantWide PM10, Lb 1 Day(s)	PlantWide SO2, Lb 1 Day(s)
09/01/2021	284.6	88.7	44.0	239.1	25.7
09/02/2021	267.7	86.1	41.0	223.4	24.2
09/03/2021	287.6	94.2	44.1	240.2	26.0
09/04/2021	279.6	228.4	29.5	154.0	15.0
09/05/2021	315.8	87.7	45.8	249.6	27.0
09/06/2021	309.9	76.4	46.8	253.8	27.6
09/07/2021	334.9	93.4	48.2	264.6	28.6
09/08/2021	348.4	90.9	50.1	277.5	30.1
09/09/2021	362.1	84.8	51.7	285.1	30.9
09/10/2021	325.8	81.4	47.0	257.1	27.6
09/11/2021	311.1	82.4	45.7	248.5	26.8
09/12/2021	301.7	88.7	45.0	244.1	26.2
09/13/2021	306.1	89.5	46.0	250.9	27.1
09/14/2021	290.7	91.1	42.9	234.0	25.2
09/15/2021	281.6	105.4	43.0	232.3	24.9
09/16/2021	248.9	136.8	34.2	161.9	12.6
09/17/2021	239.9	137.9	33.9	160.3	12.5
09/18/2021	95.2	47.4	23.8	83.6	0.0
09/19/2021	88.7	39.7	24.2	84.8	0.0
09/20/2021	334.5	182.9	41.3	219.9	22.6
09/21/2021	319.6	130.1	47.4	258.8	27.7
09/22/2021	319.3	127.4	47.0	254.9	27.3
09/23/2021	249.4	57.5	41.8	229.5	24.0
09/24/2021	246.8	46.5	41.3	223.5	24.0
09/25/2021	232.2	53.2	37.1	202.9	22.7
09/26/2021	97.0	0.0	9.6	97.0	19.4
09/27/2021	102.3	0.0	9.9	100.7	20.1
09/28/2021	130.1	21.9	10.7	107.6	21.6
09/29/2021	300.5	141.0	27.7	171.6	22.8
09/30/2021	128.2	52.5	29.5	121.5	5.2
Monthly Avg/Sum*:	7,740.2 *	2,643.9 *	1,130.2 *	6,132.7 *	- *
Daily Min:	88.7	0.0	9.6	83.6	-
Daily Max:	362.1	228.4	51.7	285.1	-
Jul 2021 - Sep 2021	23,620.5	8,664.2	3,305.5	18,013.9	-
QTD:	23,620.5 *	8,664.2 *	3,305.5 *	18,013.9 *	0.0 *
YTD 2021:	41,374.2 *	19,975.9 *	5,310.8 *	28,584.7 *	7.7 *

Daily Summary Report

AQ-25 Hourly

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
07/01/2021 00:00	0.0	0.0	0.0	0.0	0.0
07/01/2021 01:00	0.0	0.0	0.0	0.0	0.0
07/01/2021 02:00	0.0	0.0	0.0	0.0	0.0
07/01/2021 03:00	0.0	0.0	0.0	0.0	0.0
07/01/2021 04:00	0.0	0.0	0.0	0.0	0.0
07/01/2021 05:00	0.0	0.0	0.0	0.0	0.0
07/01/2021 06:00	0.0	0.0	0.0	0.0	0.0
07/01/2021 07:00	0.0	0.0	0.0	0.0	0.0
07/01/2021 08:00	0.0	0.0	0.0	0.0	0.0
07/01/2021 09:00	0.0	0.0	0.0	0.0	0.0
07/01/2021 10:00	0.0	0.0	0.0	0.0	0.0
07/01/2021 11:00	0.0	0.0	0.0	0.0	0.0
07/01/2021 12:00	0.0	0.0	0.0	0.0	0.0
07/01/2021 13:00	0.0	0.0	0.0	0.0	0.0
07/01/2021 14:00	0.0	0.0	0.0	0.0	0.0
07/01/2021 15:00	0.0	0.0	0.0	0.0	0.0
07/01/2021 16:00	0.0	0.0	0.0	0.0	0.0
07/01/2021 17:00	0.0	0.0	0.0	0.0	0.0
07/01/2021 18:00	0.0	0.0	0.0	0.0	0.0
07/01/2021 19:00	0.0	0.0	0.0	0.0	0.0
07/01/2021 20:00	0.0	0.0	0.0	0.0	0.0
07/01/2021 21:00	0.0	0.0	0.0	0.0	0.0
07/01/2021 22:00	0.0	0.0	0.0	0.0	0.0
07/01/2021 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
07/02/2021 00:00	0.0	0.0	0.0	0.0	0.0
07/02/2021 01:00	0.0	0.0	0.0	0.0	0.0
07/02/2021 02:00	0.0	0.0	0.0	0.0	0.0
07/02/2021 03:00	0.0	0.0	0.0	0.0	0.0
07/02/2021 04:00	0.0	0.0	0.0	0.0	0.0
07/02/2021 05:00	0.0	0.0	0.0	0.0	0.0
07/02/2021 06:00	0.0	0.0	0.0	0.0	0.0
07/02/2021 07:00	0.0	0.0	0.0	0.0	0.0
07/02/2021 08:00	0.0	0.0	0.0	0.0	0.0
07/02/2021 09:00	0.0	0.0	0.0	0.0	0.0
07/02/2021 10:00	0.0	0.0	0.0	0.0	0.0
07/02/2021 11:00	0.0	0.0	0.0	0.0	0.0
07/02/2021 12:00	0.0	0.0	0.0	0.0	0.0
07/02/2021 13:00	0.0	0.0	0.0	0.0	0.0
07/02/2021 14:00	0.0	0.0	0.0	0.0	0.0
07/02/2021 15:00	0.0	0.0	0.0	0.0	0.0
07/02/2021 16:00	0.0	0.0	0.0	0.0	0.0
07/02/2021 17:00	0.0	0.0	0.0	0.0	0.0
07/02/2021 18:00	0.0	0.0	0.0	0.0	0.0
07/02/2021 19:00	0.0	0.0	0.0	0.0	0.0
07/02/2021 20:00	0.0	0.0	0.0	0.0	0.0
07/02/2021 21:00	0.0	0.0	0.0	0.0	0.0
07/02/2021 22:00	0.0	0.0	0.0	0.0	0.0
07/02/2021 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
07/03/2021 00:00	0.0	0.0	0.0	0.0	0.0
07/03/2021 01:00	0.0	0.0	0.0	0.0	0.0
07/03/2021 02:00	0.0	0.0	0.0	0.0	0.0
07/03/2021 03:00	0.0	0.0	0.0	0.0	0.0
07/03/2021 04:00	0.0	0.0	0.0	0.0	0.0
07/03/2021 05:00	0.0	0.0	0.0	0.0	0.0
07/03/2021 06:00	0.0	0.0	0.0	0.0	0.0
07/03/2021 07:00	0.0	0.0	0.0	0.0	0.0
07/03/2021 08:00	0.0	0.0	0.0	0.0	0.0
07/03/2021 09:00	0.0	0.0	0.0	0.0	0.0
07/03/2021 10:00	0.0	0.0	0.0	0.0	0.0
07/03/2021 11:00	0.0	0.0	0.0	0.0	0.0
07/03/2021 12:00	0.0	0.0	0.0	0.0	0.0
07/03/2021 13:00	0.0	0.0	0.0	0.0	0.0
07/03/2021 14:00	0.0	0.0	0.0	0.0	0.0
07/03/2021 15:00	0.0	0.0	0.0	0.0	0.0
07/03/2021 16:00	0.0	0.0	0.0	0.0	0.0
07/03/2021 17:00	0.0	0.0	0.0	0.0	0.0
07/03/2021 18:00	0.0	0.0	0.0	0.0	0.0
07/03/2021 19:00	0.0	0.0	0.0	0.0	0.0
07/03/2021 20:00	0.0	0.0	0.0	0.0	0.0
07/03/2021 21:00	0.0	0.0	0.0	0.0	0.0
07/03/2021 22:00	0.0	0.0	0.0	0.0	0.0
07/03/2021 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
07/04/2021 00:00	0.0	0.0	0.0	0.0	0.0
07/04/2021 01:00	0.0	0.0	0.0	0.0	0.0
07/04/2021 02:00	0.0	0.0	0.0	0.0	0.0
07/04/2021 03:00	0.0	0.0	0.0	0.0	0.0
07/04/2021 04:00	0.0	0.0	0.0	0.0	0.0
07/04/2021 05:00	0.0	0.0	0.0	0.0	0.0
07/04/2021 06:00	0.0	0.0	0.0	0.0	0.0
07/04/2021 07:00	0.0	0.0	0.0	0.0	0.0
07/04/2021 08:00	0.0	0.0	0.0	0.0	0.0
07/04/2021 09:00	0.0	0.0	0.0	0.0	0.0
07/04/2021 10:00	0.0	0.0	0.0	0.0	0.0
07/04/2021 11:00	0.0	0.0	0.0	0.0	0.0
07/04/2021 12:00	0.0	0.0	0.0	0.0	0.0
07/04/2021 13:00	0.0	0.0	0.0	0.0	0.0
07/04/2021 14:00	0.0	0.0	0.0	0.0	0.0
07/04/2021 15:00	0.0	0.0	0.0	0.0	0.0
07/04/2021 16:00	0.0	0.0	0.0	0.0	0.0
07/04/2021 17:00	0.0	0.0	0.0	0.0	0.0
07/04/2021 18:00	0.0	0.0	0.0	0.0	0.0
07/04/2021 19:00	0.0	0.0	0.0	0.0	0.0
07/04/2021 20:00	0.0	0.0	0.0	0.0	0.0
07/04/2021 21:00	0.0	0.0	0.0	0.0	0.0
07/04/2021 22:00	0.0	0.0	0.0	0.0	0.0
07/04/2021 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
07/05/2021 00:00	0.0	0.0	0.0	0.0	0.0
07/05/2021 01:00	0.0	0.0	0.0	0.0	0.0
07/05/2021 02:00	0.0	0.0	0.0	0.0	0.0
07/05/2021 03:00	0.0	0.0	0.0	0.0	0.0
07/05/2021 04:00	0.0	0.0	0.0	0.0	0.0
07/05/2021 05:00	0.0	0.0	0.0	0.0	0.0
07/05/2021 06:00	0.0	0.0	0.0	0.0	0.0
07/05/2021 07:00	0.0	0.0	0.0	0.0	0.0
07/05/2021 08:00	0.0	0.0	0.0	0.0	0.0
07/05/2021 09:00	0.0	0.0	0.0	0.0	0.0
07/05/2021 10:00	0.0	0.0	0.0	0.0	0.0
07/05/2021 11:00	0.0	0.0	0.0	0.0	0.0
07/05/2021 12:00	0.0	0.0	0.0	0.0	0.0
07/05/2021 13:00	0.0	0.0	0.0	0.0	0.0
07/05/2021 14:00	0.0	0.0	0.0	0.0	0.0
07/05/2021 15:00	0.0	0.0	0.0	0.0	0.0
07/05/2021 16:00	0.0	0.0	0.0	0.0	0.0
07/05/2021 17:00	0.0	0.0	0.0	0.0	0.0
07/05/2021 18:00	0.0	0.0	0.0	0.0	0.0
07/05/2021 19:00	0.0	0.0	0.0	0.0	0.0
07/05/2021 20:00	0.0	0.0	0.0	0.0	0.0
07/05/2021 21:00	0.0	0.0	0.0	0.0	0.0
07/05/2021 22:00	0.0	0.0	0.0	0.0	0.0
07/05/2021 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
07/06/2021 00:00	0.0	0.0	0.0	0.0	0.0
07/06/2021 01:00	0.0	0.0	0.0	0.0	0.0
07/06/2021 02:00	0.0	0.0	0.0	0.0	0.0
07/06/2021 03:00	0.0	0.0	0.0	0.0	0.0
07/06/2021 04:00	0.0	0.0	0.0	0.0	0.0
07/06/2021 05:00	0.0	0.0	0.0	0.0	0.0
07/06/2021 06:00	0.0	0.0	0.0	0.0	0.0
07/06/2021 07:00	0.0	0.0	0.0	0.0	0.0
07/06/2021 08:00	0.0	0.0	0.0	0.0	0.0
07/06/2021 09:00	0.0	0.0	0.0	0.0	0.0
07/06/2021 10:00	0.0	0.0	0.0	0.0	0.0
07/06/2021 11:00	0.0	0.0	0.0	0.0	0.0
07/06/2021 12:00	0.0	0.0	0.0	0.0	0.0
07/06/2021 13:00	0.0	0.0	0.0	0.0	0.0
07/06/2021 14:00	0.0	0.0	0.0	0.0	0.0
07/06/2021 15:00	0.0	0.0	0.0	0.0	0.0
07/06/2021 16:00	0.0	0.0	0.0	0.0	0.0
07/06/2021 17:00	0.0	0.0	0.0	0.0	0.0
07/06/2021 18:00	0.0	0.0	0.0	0.0	0.0
07/06/2021 19:00	0.0	0.0	0.0	0.0	0.0
07/06/2021 20:00	0.0	0.0	0.0	0.0	0.0
07/06/2021 21:00	0.0	0.0	0.0	0.0	0.0
07/06/2021 22:00	0.0	0.0	0.0	0.0	0.0
07/06/2021 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
07/07/2021 00:00	0.0	0.0	0.0	0.0	0.0
07/07/2021 01:00	0.0	0.0	0.0	0.0	0.0
07/07/2021 02:00	0.0	0.0	0.0	0.0	0.0
07/07/2021 03:00	0.0	0.0	0.0	0.0	0.0
07/07/2021 04:00	0.0	0.0	0.0	0.0	0.0
07/07/2021 05:00	0.0	0.0	0.0	0.0	0.0
07/07/2021 06:00	0.0	0.0	0.0	0.0	0.0
07/07/2021 07:00	0.0	0.0	0.0	0.0	0.0
07/07/2021 08:00	0.0	0.0	0.0	0.0	0.0
07/07/2021 09:00	0.0	0.0	0.0	0.0	0.0
07/07/2021 10:00	0.0	0.0	0.0	0.0	0.0
07/07/2021 11:00	0.0	0.0	0.0	0.0	0.0
07/07/2021 12:00	0.0	0.0	0.0	0.0	0.0
07/07/2021 13:00	0.0	0.0	0.0	0.0	0.0
07/07/2021 14:00	0.0	0.0	0.0	0.0	0.0
07/07/2021 15:00	0.0	0.0	0.0	0.0	0.0
07/07/2021 16:00	0.0	0.0	0.0	0.0	0.0
07/07/2021 17:00	0.0	0.0	0.0	0.0	0.0
07/07/2021 18:00	0.0	0.0	0.0	0.0	0.0
07/07/2021 19:00	0.0	0.0	0.0	0.0	0.0
07/07/2021 20:00	0.0	0.0	0.0	0.0	0.0
07/07/2021 21:00	0.0	0.0	0.0	0.0	0.0
07/07/2021 22:00	0.0	0.0	0.0	0.0	0.0
07/07/2021 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
07/08/2021 00:00	0.0	0.0	0.0	0.0	0.0
07/08/2021 01:00	0.0	0.0	0.0	0.0	0.0
07/08/2021 02:00	0.0	0.0	0.0	0.0	0.0
07/08/2021 03:00	0.0	0.0	0.0	0.0	0.0
07/08/2021 04:00	0.0	0.0	0.0	0.0	0.0
07/08/2021 05:00	0.0	0.0	0.0	0.0	0.0
07/08/2021 06:00	0.0	0.0	0.0	0.0	0.0
07/08/2021 07:00	0.0	0.0	0.0	0.0	0.0
07/08/2021 08:00	0.0	0.0	0.0	0.0	0.0
07/08/2021 09:00	0.0	0.0	0.0	0.0	0.0
07/08/2021 10:00	0.0	0.0	0.0	0.0	0.0
07/08/2021 11:00	0.0	0.0	0.0	0.0	0.0
07/08/2021 12:00	0.0	0.0	0.0	0.0	0.0
07/08/2021 13:00	0.0	0.0	0.0	0.0	0.0
07/08/2021 14:00	0.0	0.0	0.0	0.0	0.0
07/08/2021 15:00	0.0	0.0	0.0	0.0	0.0
07/08/2021 16:00	0.0	0.0	0.0	0.0	0.0
07/08/2021 17:00	0.0	0.0	0.0	0.0	0.0
07/08/2021 18:00	0.0	0.0	0.0	0.0	0.0
07/08/2021 19:00	0.0	0.0	0.0	0.0	0.0
07/08/2021 20:00	0.0	0.0	0.0	0.0	0.0
07/08/2021 21:00	0.0	0.0	0.0	0.0	0.0
07/08/2021 22:00	0.0	0.0	0.0	0.0	0.0
07/08/2021 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
07/09/2021 00:00	0.0	0.0	0.0	0.0	0.0
07/09/2021 01:00	0.0	0.0	0.0	0.0	0.0
07/09/2021 02:00	0.0	0.0	0.0	0.0	0.0
07/09/2021 03:00	0.0	0.0	0.0	0.0	0.0
07/09/2021 04:00	0.0	0.0	0.0	0.0	0.0
07/09/2021 05:00	0.0	0.0	0.0	0.0	0.0
07/09/2021 06:00	0.0	0.0	0.0	0.0	0.0
07/09/2021 07:00	0.0	0.0	0.0	0.0	0.0
07/09/2021 08:00	0.0	0.0	0.0	0.0	0.0
07/09/2021 09:00	0.0	0.0	0.0	0.0	0.0
07/09/2021 10:00	0.0	0.0	0.0	0.0	0.0
07/09/2021 11:00	0.0	0.0	0.0	0.0	0.0
07/09/2021 12:00	0.0	0.0	0.0	0.0	0.0
07/09/2021 13:00	0.0	0.0	0.0	0.0	0.0
07/09/2021 14:00	0.0	0.0	0.0	0.0	0.0
07/09/2021 15:00	0.0	0.0	0.0	0.0	0.0
07/09/2021 16:00	0.0	0.0	0.0	0.0	0.0
07/09/2021 17:00	0.0	0.0	0.0	0.0	0.0
07/09/2021 18:00	0.0	0.0	0.0	0.0	0.0
07/09/2021 19:00	0.0	0.0	0.0	0.0	0.0
07/09/2021 20:00	0.0	0.0	0.0	0.0	0.0
07/09/2021 21:00	0.0	0.0	0.0	0.0	0.0
07/09/2021 22:00	0.0	0.0	0.0	0.0	0.0
07/09/2021 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
07/10/2021 00:00	0.0	0.0	0.0	0.0	0.0
07/10/2021 01:00	0.0	0.0	0.0	0.0	0.0
07/10/2021 02:00	0.0	0.0	0.0	0.0	0.0
07/10/2021 03:00	0.0	0.0	0.0	0.0	0.0
07/10/2021 04:00	0.0	0.0	0.0	0.0	0.0
07/10/2021 05:00	0.0	0.0	0.0	0.0	0.0
07/10/2021 06:00	0.0	0.0	0.0	0.0	0.0
07/10/2021 07:00	0.0	0.0	0.0	0.0	0.0
07/10/2021 08:00	0.0	0.0	0.0	0.0	0.0
07/10/2021 09:00	0.0	0.0	0.0	0.0	0.0
07/10/2021 10:00	0.0	0.0	0.0	0.0	0.0
07/10/2021 11:00	0.0	0.0	0.0	0.0	0.0
07/10/2021 12:00	0.0	0.0	0.0	0.0	0.0
07/10/2021 13:00	27.5	43.3	0.1	0.4	0.1
07/10/2021 14:00	50.7	24.9	0.3	0.9	0.2
07/10/2021 15:00	23.6	101.5	0.4	1.6	0.4
07/10/2021 16:00	20.4	50.1	0.9	3.4	0.8
07/10/2021 17:00	24.1	15.6	1.2	4.4	1.1
07/10/2021 18:00	5.1	0.6	1.2	4.3	1.0
07/10/2021 19:00	5.1	0.6	1.2	4.3	1.0
07/10/2021 20:00	5.2	0.6	1.2	4.3	1.0
07/10/2021 21:00	5.2	0.6	1.2	4.4	1.0
07/10/2021 22:00	5.2	0.6	1.2	4.4	1.0
07/10/2021 23:00	4.6	26.7	0.6	2.3	0.6
Average/Sum#:	176.7 #	265.1 #	9.5 #	34.7 #	8.2 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	50.7	101.5	1.2	4.4	1.1
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
07/11/2021 00:00	0.0	0.0	0.0	0.0	0.0
07/11/2021 01:00	0.0	0.0	0.0	0.0	0.0
07/11/2021 02:00	0.0	0.0	0.0	0.0	0.0
07/11/2021 03:00	0.0	0.0	0.0	0.0	0.0
07/11/2021 04:00	0.0	0.0	0.0	0.0	0.0
07/11/2021 05:00	0.0	0.0	0.0	0.0	0.0
07/11/2021 06:00	0.0	0.0	0.0	0.0	0.0
07/11/2021 07:00	0.0	0.0	0.0	0.0	0.0
07/11/2021 08:00	0.0	0.0	0.0	0.0	0.0
07/11/2021 09:00	35.2	43.2	0.1	0.5	0.1
07/11/2021 10:00	18.0	36.4	0.3	1.0	0.2
07/11/2021 11:00	19.5	86.9	0.8	2.7	0.6
07/11/2021 12:00	5.5	0.3	1.0	3.5	0.8
07/11/2021 13:00	7.4	0.3	1.0	3.7	0.9
07/11/2021 14:00	6.7	0.3	1.2	4.2	1.0
07/11/2021 15:00	8.1	0.6	1.1	4.1	1.0
07/11/2021 16:00	8.5	0.3	1.2	4.3	1.0
07/11/2021 17:00	5.1	0.3	1.2	4.3	1.0
07/11/2021 18:00	5.1	0.6	1.2	4.3	1.0
07/11/2021 19:00	5.2	0.6	1.2	4.3	1.0
07/11/2021 20:00	5.2	0.6	1.2	4.3	1.0
07/11/2021 21:00	6.8	0.6	1.2	4.3	1.0
07/11/2021 22:00	6.8	0.6	1.2	4.3	1.0
07/11/2021 23:00	5.0	0.6	1.2	4.2	1.0
Average/Sum#:	148.1 #	172.2 #	15.1 #	54.0 #	12.6 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	35.2	86.9	1.2	4.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
07/12/2021 00:00	6.8	0.6	1.2	4.3	1.0
07/12/2021 01:00	0.9	9.2	0.1	0.3	0.1
07/12/2021 02:00	0.0	0.0	0.0	0.0	0.0
07/12/2021 03:00	0.0	0.0	0.0	0.0	0.0
07/12/2021 04:00	0.0	0.0	0.0	0.0	0.0
07/12/2021 05:00	0.0	0.0	0.0	0.0	0.0
07/12/2021 06:00	0.0	0.0	0.0	0.0	0.0
07/12/2021 07:00	0.0	9.0	0.1	0.6	0.1
07/12/2021 08:00	0.0	5.7	0.1	1.1	0.2
07/12/2021 09:00	0.0	12.4	0.2	1.9	0.4
07/12/2021 10:00	2.7	0.8	0.4	4.0	0.8
07/12/2021 11:00	6.7	0.9	0.5	5.0	1.0
07/12/2021 12:00	6.9	0.9	0.5	5.2	1.0
07/12/2021 13:00	6.9	0.9	0.5	5.2	1.0
07/12/2021 14:00	6.9	0.9	0.5	5.1	1.0
07/12/2021 15:00	18.2	45.5	0.6	5.4	1.1
07/12/2021 16:00	59.9	77.6	1.3	7.3	1.6
07/12/2021 17:00	12.0	1.2	1.7	9.5	2.0
07/12/2021 18:00	13.7	1.2	1.7	9.4	2.0
07/12/2021 19:00	12.0	1.2	1.7	9.4	2.0
07/12/2021 20:00	12.2	1.5	1.7	9.5	2.1
07/12/2021 21:00	12.2	1.8	1.7	9.5	2.1
07/12/2021 22:00	10.0	31.2	1.4	8.2	1.7
07/12/2021 23:00	7.0	1.3	0.5	5.2	1.0
Average/Sum#:	195.0 #	176.7 #	16.4 #	106.1 #	22.2 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	59.9	77.6	1.7	9.5	2.1
%SI	12.50	12.50	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
07/13/2021 00:00	7.0	1.3	0.5	5.2	1.0
07/13/2021 01:00	7.0	1.3	0.5	5.3	1.1
07/13/2021 02:00	3.1	13.9	0.1	1.3	0.3
07/13/2021 03:00	0.0	0.0	0.0	0.0	0.0
07/13/2021 04:00	0.0	0.0	0.0	0.0	0.0
07/13/2021 05:00	0.0	0.0	0.0	0.0	0.0
07/13/2021 06:00	0.0	0.0	0.0	0.0	0.0
07/13/2021 07:00	22.1	44.8	0.1	0.5	0.1
07/13/2021 08:00	8.2	47.4	0.3	1.0	0.2
07/13/2021 09:00	5.7	44.4	0.2	0.9	0.2
07/13/2021 10:00	0.0	0.0	0.0	0.0	0.0
07/13/2021 11:00	0.0	0.0	0.0	0.0	0.0
07/13/2021 12:00	7.6	67.2	0.3	0.9	0.2
07/13/2021 13:00	18.6	227.0	0.3	1.1	0.3
07/13/2021 14:00	0.1	7.3	0.1	0.2	0.0
07/13/2021 15:00	18.5	302.1	0.5	1.7	0.4
07/13/2021 16:00	20.3	212.2	0.9	3.2	0.8
07/13/2021 17:00	35.4	54.0	1.3	5.0	1.2
07/13/2021 18:00	43.3	108.1	1.4	6.9	1.5
07/13/2021 19:00	10.2	0.6	1.7	9.3	2.0
07/13/2021 20:00	12.8	1.8	1.8	10.0	2.2
07/13/2021 21:00	11.5	48.8	1.5	7.9	1.7
07/13/2021 22:00	2.6	0.0	0.4	3.9	0.8
07/13/2021 23:00	6.8	0.0	0.5	5.1	1.0
Average/Sum#:	240.8 #	1,182.2 #	12.4 #	69.4 #	15.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	43.3	302.1	1.8	10.0	2.2
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
07/14/2021 00:00	4.6	0.0	0.5	4.6	0.9
07/14/2021 01:00	4.5	0.0	0.5	4.5	0.9
07/14/2021 02:00	4.6	0.0	0.5	4.6	0.9
07/14/2021 03:00	11.6	158.1	0.7	5.6	1.2
07/14/2021 04:00	15.9	68.3	1.4	8.1	1.8
07/14/2021 05:00	11.8	0.3	1.7	9.3	2.0
07/14/2021 06:00	11.4	0.6	1.6	8.9	2.0
07/14/2021 07:00	11.6	2.4	1.7	9.1	2.0
07/14/2021 08:00	13.6	7.9	1.9	10.7	2.3
07/14/2021 09:00	13.6	9.4	2.0	10.7	2.3
07/14/2021 10:00	9.9	0.3	1.7	9.1	2.0
07/14/2021 11:00	9.5	0.9	1.6	8.7	1.9
07/14/2021 12:00	14.2	6.3	2.1	11.1	2.5
07/14/2021 13:00	14.9	1.2	2.2	11.7	2.5
07/14/2021 14:00	14.9	0.9	2.2	11.7	2.5
07/14/2021 15:00	14.8	0.9	2.2	11.6	2.5
07/14/2021 16:00	14.8	0.3	2.2	11.7	2.5
07/14/2021 17:00	14.9	0.6	2.2	11.7	2.5
07/14/2021 18:00	14.9	0.6	2.2	11.7	2.5
07/14/2021 19:00	16.8	1.5	2.1	11.5	2.5
07/14/2021 20:00	14.6	1.8	2.1	11.4	2.5
07/14/2021 21:00	14.3	3.1	2.1	11.3	2.5
07/14/2021 22:00	14.3	3.4	2.1	11.3	2.5
07/14/2021 23:00	14.3	4.1	2.1	11.3	2.5
Average/Sum#:	300.3 #	272.9 #	41.6 #	231.9 #	50.2 #
Minimum:	4.5	0.0	0.5	4.5	0.9
Maximum:	16.8	158.1	2.2	11.7	2.5
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
07/15/2021 00:00	13.7	7.2	2.0	10.8	2.4
07/15/2021 01:00	9.3	0.8	1.6	8.5	1.8
07/15/2021 02:00	10.5	0.6	1.5	8.3	1.8
07/15/2021 03:00	8.9	0.8	1.4	8.1	1.8
07/15/2021 04:00	11.9	0.3	1.7	9.3	2.0
07/15/2021 05:00	15.6	7.3	2.0	10.6	2.3
07/15/2021 06:00	13.9	5.3	2.0	11.0	2.4
07/15/2021 07:00	9.7	0.3	1.7	8.9	2.0
07/15/2021 08:00	11.4	0.3	1.7	8.9	2.0
07/15/2021 09:00	9.3	0.3	1.6	8.5	1.8
07/15/2021 10:00	9.9	0.0	1.7	9.1	2.0
07/15/2021 11:00	9.3	0.9	1.6	8.5	1.8
07/15/2021 12:00	14.3	8.2	2.1	11.3	2.5
07/15/2021 13:00	14.7	3.4	2.1	11.5	2.5
07/15/2021 14:00	14.8	2.4	2.1	11.6	2.5
07/15/2021 15:00	14.8	1.8	2.1	11.7	2.5
07/15/2021 16:00	14.9	1.8	2.1	11.7	2.5
07/15/2021 17:00	14.8	1.8	2.1	11.7	2.5
07/15/2021 18:00	15.1	1.2	2.2	11.8	2.6
07/15/2021 19:00	15.1	1.2	2.2	11.9	2.6
07/15/2021 20:00	15.1	1.2	2.2	11.9	2.6
07/15/2021 21:00	14.7	2.5	2.1	11.6	2.5
07/15/2021 22:00	14.4	4.7	2.1	11.3	2.5
07/15/2021 23:00	14.5	5.1	2.1	11.4	2.5
Average/Sum#:	310.6 #	59.4 #	46.0 #	249.9 #	54.4 #
Minimum:	8.9	0.0	1.4	8.1	1.8
Maximum:	15.6	8.2	2.2	11.9	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
07/16/2021 00:00	14.4	5.1	2.1	11.4	2.5
07/16/2021 01:00	13.7	12.7	2.0	10.8	2.4
07/16/2021 02:00	9.7	0.3	1.6	8.9	2.0
07/16/2021 03:00	8.7	0.8	1.4	8.0	1.8
07/16/2021 04:00	11.3	0.3	1.6	8.9	2.0
07/16/2021 05:00	14.4	11.7	1.8	9.9	2.2
07/16/2021 06:00	13.1	6.5	1.9	10.2	2.2
07/16/2021 07:00	11.7	0.3	1.7	9.2	2.0
07/16/2021 08:00	11.7	0.3	1.7	9.1	2.0
07/16/2021 09:00	9.8	0.3	1.7	8.9	2.0
07/16/2021 10:00	11.8	0.3	1.7	9.3	2.0
07/16/2021 11:00	9.1	0.8	1.5	8.3	1.8
07/16/2021 12:00	16.0	9.4	2.0	10.9	2.4
07/16/2021 13:00	13.9	7.2	2.0	10.9	2.4
07/16/2021 14:00	9.9	0.3	1.7	9.1	2.0
07/16/2021 15:00	9.5	0.9	1.6	8.7	1.9
07/16/2021 16:00	14.4	8.6	2.1	11.3	2.5
07/16/2021 17:00	15.3	1.2	2.2	12.1	2.7
07/16/2021 18:00	15.5	0.9	2.2	12.1	2.7
07/16/2021 19:00	15.4	0.9	2.2	12.1	2.7
07/16/2021 20:00	15.3	1.2	2.2	12.1	2.7
07/16/2021 21:00	15.0	1.8	2.1	11.8	2.6
07/16/2021 22:00	14.7	2.9	2.1	11.6	2.5
07/16/2021 23:00	14.5	5.0	2.1	11.4	2.5
Average/Sum#:	308.8 #	79.7 #	45.2 #	247.0 #	54.5 #
Minimum:	8.7	0.3	1.4	8.0	1.8
Maximum:	16.0	12.7	2.2	12.1	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
07/17/2021 00:00	13.5	11.8	2.0	10.6	2.3
07/17/2021 01:00	11.6	0.6	1.7	9.1	2.0
07/17/2021 02:00	9.2	1.7	1.3	7.2	1.6
07/17/2021 03:00	9.7	0.3	1.6	8.9	2.0
07/17/2021 04:00	12.6	10.3	1.8	10.0	2.2
07/17/2021 05:00	12.8	6.8	1.8	10.1	2.2
07/17/2021 06:00	11.4	0.3	1.7	8.9	2.0
07/17/2021 07:00	9.7	0.3	1.7	8.9	2.0
07/17/2021 08:00	9.5	0.3	1.6	8.7	1.9
07/17/2021 09:00	13.5	0.3	1.7	9.3	2.0
07/17/2021 10:00	11.2	0.3	1.6	8.9	2.0
07/17/2021 11:00	9.1	0.3	1.6	8.3	1.8
07/17/2021 12:00	11.4	0.6	1.6	8.9	2.0
07/17/2021 13:00	14.5	6.9	2.1	11.4	2.5
07/17/2021 14:00	15.1	1.5	2.2	11.9	2.6
07/17/2021 15:00	15.1	0.9	2.2	11.9	2.6
07/17/2021 16:00	15.3	0.9	2.2	12.1	2.7
07/17/2021 17:00	15.4	0.6	2.2	12.1	2.7
07/17/2021 18:00	15.5	0.9	2.2	12.1	2.7
07/17/2021 19:00	15.4	0.9	2.2	12.1	2.7
07/17/2021 20:00	15.3	0.9	2.2	12.0	2.7
07/17/2021 21:00	15.1	0.9	2.2	11.9	2.6
07/17/2021 22:00	14.7	2.5	2.1	11.6	2.5
07/17/2021 23:00	14.7	2.5	2.1	11.6	2.5
Average/Sum#:	311.3 #	53.3 #	45.6 #	248.5 #	54.8 #
Minimum:	9.1	0.3	1.3	7.2	1.6
Maximum:	15.5	11.8	2.2	12.1	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
07/18/2021 00:00	13.9	6.6	2.0	11.0	2.4
07/18/2021 01:00	9.9	0.6	1.7	9.1	2.0
07/18/2021 02:00	11.0	1.1	1.6	8.7	1.9
07/18/2021 03:00	16.1	8.0	2.0	11.1	2.4
07/18/2021 04:00	13.8	8.8	2.0	10.8	2.4
07/18/2021 05:00	9.9	0.6	1.7	9.1	2.0
07/18/2021 06:00	9.9	0.3	1.7	9.1	2.0
07/18/2021 07:00	9.9	0.3	1.7	9.1	2.0
07/18/2021 08:00	11.7	0.3	1.7	9.2	2.0
07/18/2021 09:00	11.5	0.0	1.7	9.1	2.0
07/18/2021 10:00	9.5	0.3	1.6	8.7	1.9
07/18/2021 11:00	11.9	0.6	1.7	9.3	2.0
07/18/2021 12:00	14.5	6.3	2.1	11.3	2.5
07/18/2021 13:00	15.3	0.9	2.2	12.1	2.7
07/18/2021 14:00	15.3	0.6	2.2	12.1	2.7
07/18/2021 15:00	15.3	0.6	2.2	12.1	2.7
07/18/2021 16:00	15.3	0.6	2.2	12.1	2.7
07/18/2021 17:00	15.3	0.6	2.2	12.1	2.7
07/18/2021 18:00	15.1	0.9	2.2	11.9	2.6
07/18/2021 19:00	14.9	0.9	2.1	11.8	2.6
07/18/2021 20:00	14.9	1.2	2.1	11.8	2.6
07/18/2021 21:00	15.2	0.9	2.2	12.0	2.6
07/18/2021 22:00	15.2	1.2	2.2	11.9	2.6
07/18/2021 23:00	15.2	0.9	2.2	11.9	2.6
Average/Sum#:	320.5 #	43.1 #	47.2 #	257.4 #	56.6 #
Minimum:	9.5	0.0	1.6	8.7	1.9
Maximum:	16.1	8.8	2.2	12.1	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
07/19/2021 00:00	15.0	1.2	2.1	11.8	2.6
07/19/2021 01:00	11.9	0.9	1.7	9.3	2.0
07/19/2021 02:00	11.8	0.3	1.7	9.2	2.0
07/19/2021 03:00	11.4	0.6	1.7	8.9	2.0
07/19/2021 04:00	11.9	0.6	1.7	9.3	2.0
07/19/2021 05:00	16.3	9.5	2.1	11.2	2.5
07/19/2021 06:00	14.5	5.1	2.1	11.4	2.5
07/19/2021 07:00	9.5	0.6	1.6	8.7	1.9
07/19/2021 08:00	11.3	0.6	1.6	8.9	2.0
07/19/2021 09:00	9.5	0.9	1.6	8.7	1.9
07/19/2021 10:00	14.3	5.1	2.1	11.2	2.5
07/19/2021 11:00	15.3	0.9	2.2	12.0	2.6
07/19/2021 12:00	15.4	0.9	2.2	12.1	2.7
07/19/2021 13:00	15.3	0.9	2.2	12.1	2.7
07/19/2021 14:00	15.3	0.9	2.2	12.1	2.7
07/19/2021 15:00	15.3	0.9	2.2	12.1	2.7
07/19/2021 16:00	15.4	0.6	2.2	12.1	2.7
07/19/2021 17:00	15.3	0.9	2.2	12.1	2.7
07/19/2021 18:00	15.4	0.9	2.2	12.1	2.7
07/19/2021 19:00	15.5	0.9	2.2	12.1	2.7
07/19/2021 20:00	15.5	0.9	2.2	12.1	2.7
07/19/2021 21:00	15.3	0.9	2.2	12.0	2.7
07/19/2021 22:00	14.6	3.2	2.1	11.5	2.5
07/19/2021 23:00	14.5	3.8	2.1	11.4	2.5
Average/Sum#:	335.5 #	42.0 #	48.4 #	264.4 #	58.5 #
Minimum:	9.5	0.3	1.6	8.7	1.9
Maximum:	16.3	9.5	2.2	12.1	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
07/20/2021 00:00	14.3	5.0	2.1	11.2	2.5
07/20/2021 01:00	13.4	0.6	1.7	9.2	2.0
07/20/2021 02:00	11.8	0.3	1.7	9.3	2.0
07/20/2021 03:00	11.8	0.6	1.7	9.3	2.0
07/20/2021 04:00	14.2	9.6	2.1	11.2	2.4
07/20/2021 05:00	17.2	2.5	2.1	11.8	2.6
07/20/2021 06:00	10.1	1.8	1.7	9.2	2.0
07/20/2021 07:00	11.5	0.3	1.7	9.0	2.0
07/20/2021 08:00	11.1	0.6	1.6	8.7	1.9
07/20/2021 09:00	11.4	0.3	1.7	8.9	2.0
07/20/2021 10:00	11.6	0.3	1.7	9.1	2.0
07/20/2021 11:00	11.1	0.6	1.6	8.7	1.9
07/20/2021 12:00	9.9	0.3	1.7	9.1	2.0
07/20/2021 13:00	14.2	7.2	2.1	11.1	2.5
07/20/2021 14:00	14.9	1.5	2.1	11.7	2.5
07/20/2021 15:00	15.1	0.9	2.2	11.9	2.6
07/20/2021 16:00	15.3	0.6	2.2	12.1	2.7
07/20/2021 17:00	15.3	0.6	2.2	12.1	2.7
07/20/2021 18:00	15.3	0.9	2.2	12.1	2.7
07/20/2021 19:00	17.6	0.9	2.2	12.1	2.7
07/20/2021 20:00	22.3	0.9	2.2	12.1	2.7
07/20/2021 21:00	21.7	1.5	2.2	11.9	2.6
07/20/2021 22:00	21.5	2.1	2.1	11.8	2.6
07/20/2021 23:00	21.3	2.5	2.1	11.6	2.5
Average/Sum#:	353.9 #	42.4 #	46.9 #	255.2 #	56.1 #
Minimum:	9.9	0.3	1.6	8.7	1.9
Maximum:	22.3	9.6	2.2	12.1	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
07/21/2021 00:00	18.2	6.0	2.0	11.0	2.4
07/21/2021 01:00	13.0	0.3	1.7	8.9	2.0
07/21/2021 02:00	11.6	0.0	1.7	9.1	2.0
07/21/2021 03:00	14.7	5.0	1.8	10.1	2.2
07/21/2021 04:00	18.3	4.4	2.0	11.2	2.4
07/21/2021 05:00	9.7	0.3	1.6	8.9	2.0
07/21/2021 06:00	9.5	0.6	1.6	8.7	1.9
07/21/2021 07:00	16.2	7.4	2.0	11.1	2.4
07/21/2021 08:00	13.7	9.4	2.0	10.8	2.4
07/21/2021 09:00	10.1	0.3	1.7	9.3	2.0
07/21/2021 10:00	11.2	0.9	1.6	8.7	1.9
07/21/2021 11:00	14.3	6.0	2.1	11.3	2.5
07/21/2021 12:00	14.7	3.8	2.1	11.6	2.5
07/21/2021 13:00	14.7	3.5	2.1	11.6	2.5
07/21/2021 14:00	14.9	2.7	2.1	11.7	2.5
07/21/2021 15:00	14.9	2.4	2.1	11.8	2.6
07/21/2021 16:00	14.9	2.1	2.1	11.8	2.6
07/21/2021 17:00	15.1	1.8	2.2	11.9	2.6
07/21/2021 18:00	15.3	1.2	2.2	12.1	2.7
07/21/2021 19:00	15.3	1.2	2.2	12.1	2.7
07/21/2021 20:00	15.4	1.2	2.2	12.1	2.7
07/21/2021 21:00	15.2	1.8	2.2	12.0	2.6
07/21/2021 22:00	15.0	2.8	2.1	11.8	2.6
07/21/2021 23:00	14.6	4.1	2.1	11.5	2.5
Average/Sum#:	340.5 #	69.2 #	47.5 #	261.1 #	57.2 #
Minimum:	9.5	0.0	1.6	8.7	1.9
Maximum:	18.3	9.4	2.2	12.1	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
07/22/2021 00:00	14.0	6.9	2.0	11.0	2.4
07/22/2021 01:00	11.5	0.6	1.7	9.1	2.0
07/22/2021 02:00	9.3	1.4	1.6	8.5	1.8
07/22/2021 03:00	14.1	5.7	2.0	11.0	2.4
07/22/2021 04:00	13.7	6.0	2.0	10.8	2.4
07/22/2021 05:00	9.5	0.3	1.6	8.7	1.9
07/22/2021 06:00	10.1	0.3	1.7	9.3	2.0
07/22/2021 07:00	14.1	7.6	2.0	11.1	2.4
07/22/2021 08:00	13.7	10.2	2.0	10.8	2.4
07/22/2021 09:00	11.3	0.9	1.6	8.9	2.0
07/22/2021 10:00	11.4	0.6	1.7	8.9	2.0
07/22/2021 11:00	14.0	0.3	1.7	9.6	2.1
07/22/2021 12:00	14.5	7.6	2.1	11.4	2.5
07/22/2021 13:00	15.3	2.5	2.2	12.0	2.7
07/22/2021 14:00	15.1	2.9	2.2	11.9	2.6
07/22/2021 15:00	15.1	2.8	2.2	11.9	2.6
07/22/2021 16:00	15.3	1.8	2.2	12.1	2.7
07/22/2021 17:00	15.2	1.8	2.2	11.9	2.6
07/22/2021 18:00	15.5	1.5	2.2	12.1	2.7
07/22/2021 19:00	15.3	1.5	2.2	12.1	2.7
07/22/2021 20:00	15.3	1.5	2.2	12.0	2.7
07/22/2021 21:00	14.8	3.1	2.1	11.6	2.5
07/22/2021 22:00	14.7	3.8	2.1	11.6	2.5
07/22/2021 23:00	14.1	5.0	2.1	11.2	2.4
Average/Sum#:	326.9 #	76.6 #	47.6 #	259.5 #	57.0 #
Minimum:	9.3	0.3	1.6	8.5	1.8
Maximum:	15.5	10.2	2.2	12.1	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
07/23/2021 00:00	10.0	0.3	1.7	9.1	2.0
07/23/2021 01:00	11.6	0.6	1.7	9.1	2.0
07/23/2021 02:00	14.1	8.0	2.1	11.1	2.4
07/23/2021 03:00	13.5	8.2	2.0	10.6	2.3
07/23/2021 04:00	10.1	0.3	1.7	9.2	2.0
07/23/2021 05:00	9.9	0.6	1.7	9.1	2.0
07/23/2021 06:00	11.6	0.6	1.7	9.1	2.0
07/23/2021 07:00	11.4	0.6	1.7	8.9	2.0
07/23/2021 08:00	11.7	0.3	1.7	9.1	2.0
07/23/2021 09:00	11.6	0.3	1.7	9.1	2.0
07/23/2021 10:00	11.9	0.3	1.7	9.3	2.0
07/23/2021 11:00	11.9	1.2	1.7	9.3	2.0
07/23/2021 12:00	16.9	5.4	2.1	11.6	2.5
07/23/2021 13:00	15.5	0.9	2.2	12.1	2.7
07/23/2021 14:00	15.5	0.9	2.2	12.1	2.7
07/23/2021 15:00	15.5	0.6	2.2	12.1	2.7
07/23/2021 16:00	15.5	0.6	2.2	12.1	2.7
07/23/2021 17:00	15.5	0.6	2.2	12.2	2.7
07/23/2021 18:00	15.5	0.9	2.2	12.1	2.7
07/23/2021 19:00	15.5	0.9	2.2	12.2	2.7
07/23/2021 20:00	15.5	0.9	2.2	12.1	2.7
07/23/2021 21:00	15.1	2.5	2.2	11.9	2.6
07/23/2021 22:00	14.6	4.4	2.1	11.5	2.5
07/23/2021 23:00	14.5	4.7	2.1	11.4	2.5
Average/Sum#:	324.4 #	44.6 #	47.2 #	256.4 #	56.4 #
Minimum:	9.9	0.3	1.7	8.9	2.0
Maximum:	16.9	8.2	2.2	12.2	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
07/24/2021 00:00	14.5	4.7	2.1	11.4	2.5
07/24/2021 01:00	13.5	8.5	2.0	10.6	2.3
07/24/2021 02:00	11.6	0.6	1.7	9.1	2.0
07/24/2021 03:00	12.0	0.9	1.7	9.4	2.0
07/24/2021 04:00	16.1	9.6	2.0	11.0	2.4
07/24/2021 05:00	13.6	10.5	2.0	10.8	2.4
07/24/2021 06:00	9.9	0.6	1.7	9.1	2.0
07/24/2021 07:00	9.6	0.9	1.6	8.8	1.9
07/24/2021 08:00	11.3	0.6	1.6	8.9	2.0
07/24/2021 09:00	11.6	0.3	1.7	9.1	2.0
07/24/2021 10:00	11.3	0.3	1.6	8.9	2.0
07/24/2021 11:00	11.5	0.0	1.7	9.0	2.0
07/24/2021 12:00	14.3	8.5	2.1	11.2	2.5
07/24/2021 13:00	14.9	3.7	2.1	11.7	2.5
07/24/2021 14:00	14.5	3.7	2.1	11.5	2.5
07/24/2021 15:00	11.7	0.0	1.7	9.1	2.0
07/24/2021 16:00	13.5	0.3	1.7	9.3	2.0
07/24/2021 17:00	14.3	7.5	2.1	11.2	2.5
07/24/2021 18:00	14.9	3.0	2.1	11.8	2.6
07/24/2021 19:00	15.4	1.2	2.2	12.1	2.7
07/24/2021 20:00	15.4	1.2	2.2	12.1	2.7
07/24/2021 21:00	15.3	2.1	2.2	11.9	2.7
07/24/2021 22:00	14.7	3.5	2.1	11.6	2.5
07/24/2021 23:00	14.9	3.1	2.1	11.7	2.5
Average/Sum#:	320.3 #	75.3 #	46.1 #	251.3 #	55.2 #
Minimum:	9.6	0.0	1.6	8.8	1.9
Maximum:	16.1	10.5	2.2	12.1	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
07/25/2021 00:00	13.7	6.9	2.0	10.8	2.4
07/25/2021 01:00	9.9	0.6	1.7	9.1	2.0
07/25/2021 02:00	9.5	0.9	1.6	8.7	1.9
07/25/2021 03:00	14.1	5.7	2.1	11.2	2.4
07/25/2021 04:00	13.5	6.3	2.0	10.6	2.3
07/25/2021 05:00	10.0	0.6	1.7	9.1	2.0
07/25/2021 06:00	11.6	0.6	1.7	9.1	2.0
07/25/2021 07:00	11.6	0.6	1.7	9.1	2.0
07/25/2021 08:00	11.8	0.6	1.7	9.2	2.0
07/25/2021 09:00	11.8	0.6	1.7	9.2	2.0
07/25/2021 10:00	11.8	0.3	1.7	9.2	2.0
07/25/2021 11:00	9.1	1.1	1.6	8.3	1.8
07/25/2021 12:00	14.5	6.6	2.1	11.4	2.5
07/25/2021 13:00	14.6	3.3	2.1	11.4	2.5
07/25/2021 14:00	13.3	0.0	1.7	9.1	2.0
07/25/2021 15:00	13.6	0.0	1.7	9.3	2.0
07/25/2021 16:00	11.9	0.0	1.7	9.3	2.0
07/25/2021 17:00	14.5	5.5	2.1	11.5	2.5
07/25/2021 18:00	15.3	1.5	2.2	11.9	2.7
07/25/2021 19:00	14.9	2.1	2.1	11.8	2.6
07/25/2021 20:00	14.7	3.0	2.1	11.6	2.5
07/25/2021 21:00	14.5	4.1	2.1	11.4	2.5
07/25/2021 22:00	14.3	4.7	2.1	11.3	2.5
07/25/2021 23:00	14.5	4.1	2.1	11.4	2.5
Average/Sum#:	309.0 #	59.7 #	45.3 #	245.0 #	53.6 #
Minimum:	9.1	0.0	1.6	8.3	1.8
Maximum:	15.3	6.9	2.2	11.9	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
07/26/2021 00:00	13.7	8.1	2.0	10.8	2.4
07/26/2021 01:00	11.3	0.6	1.6	8.8	2.0
07/26/2021 02:00	11.4	0.3	1.7	8.9	2.0
07/26/2021 03:00	14.1	5.4	2.0	11.1	2.4
07/26/2021 04:00	14.3	3.8	2.1	11.2	2.5
07/26/2021 05:00	10.1	0.0	1.7	9.2	2.0
07/26/2021 06:00	11.3	0.0	1.6	8.9	2.0
07/26/2021 07:00	9.1	0.8	1.6	8.3	1.8
07/26/2021 08:00	10.0	0.3	1.7	9.2	2.0
07/26/2021 09:00	9.3	0.8	1.6	8.5	1.8
07/26/2021 10:00	11.6	0.3	1.7	9.1	2.0
07/26/2021 11:00	14.3	8.5	2.1	11.3	2.5
07/26/2021 12:00	15.2	2.4	2.2	12.0	2.6
07/26/2021 13:00	15.2	2.1	2.2	12.0	2.6
07/26/2021 14:00	15.0	2.4	2.1	11.8	2.6
07/26/2021 15:00	15.4	1.5	2.2	12.1	2.7
07/26/2021 16:00	15.4	1.5	2.2	12.1	2.7
07/26/2021 17:00	15.2	2.1	2.2	12.0	2.6
07/26/2021 18:00	15.2	1.8	2.2	12.0	2.6
07/26/2021 19:00	15.2	2.1	2.2	12.0	2.6
07/26/2021 20:00	15.2	2.7	2.2	12.0	2.6
07/26/2021 21:00	15.4	2.2	2.2	12.2	2.7
07/26/2021 22:00	15.0	3.2	2.2	11.8	2.6
07/26/2021 23:00	14.1	6.6	2.0	11.0	2.4
Average/Sum#:	322.0 #	59.5 #	47.5 #	258.3 #	56.7 #
Minimum:	9.1	0.0	1.6	8.3	1.8
Maximum:	15.4	8.5	2.2	12.2	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
07/27/2021 00:00	12.9	0.6	1.6	8.9	2.0
07/27/2021 01:00	11.7	0.6	1.7	9.3	2.0
07/27/2021 02:00	13.5	14.0	2.0	10.7	2.3
07/27/2021 03:00	13.4	13.5	2.0	10.6	2.3
07/27/2021 04:00	9.8	0.6	1.7	8.9	2.0
07/27/2021 05:00	13.8	0.3	1.7	9.4	2.0
07/27/2021 06:00	12.2	9.0	2.0	11.2	2.4
07/27/2021 07:00	13.6	8.3	2.0	10.7	2.4
07/27/2021 08:00	11.6	0.0	1.7	9.1	2.0
07/27/2021 09:00	10.1	0.3	1.7	9.3	2.0
07/27/2021 10:00	10.1	0.3	1.7	9.3	2.0
07/27/2021 11:00	11.8	0.3	1.7	9.3	2.0
07/27/2021 12:00	14.5	8.0	2.1	11.3	2.5
07/27/2021 13:00	15.3	3.2	2.2	12.1	2.7
07/27/2021 14:00	15.3	2.6	2.2	12.0	2.7
07/27/2021 15:00	15.3	2.6	2.2	12.0	2.7
07/27/2021 16:00	15.0	3.2	2.2	11.8	2.6
07/27/2021 17:00	15.3	2.5	2.2	12.1	2.7
07/27/2021 18:00	15.4	2.2	2.2	12.1	2.7
07/27/2021 19:00	15.4	2.6	2.2	12.1	2.7
07/27/2021 20:00	15.4	2.6	2.2	12.1	2.7
07/27/2021 21:00	15.4	2.6	2.2	12.1	2.7
07/27/2021 22:00	15.2	2.6	2.2	12.0	2.6
07/27/2021 23:00	15.2	3.2	2.2	12.0	2.6
Average/Sum#:	327.2 #	85.7 #	47.8 #	260.4 #	57.3 #
Minimum:	9.8	0.0	1.6	8.9	2.0
Maximum:	15.4	14.0	2.2	12.1	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
07/28/2021 00:00	14.8	3.5	2.1	11.8	2.6
07/28/2021 01:00	13.5	9.5	2.0	10.6	2.3
07/28/2021 02:00	11.7	0.3	1.7	9.1	2.0
07/28/2021 03:00	11.6	0.6	1.7	9.1	2.0
07/28/2021 04:00	14.3	9.0	2.1	11.2	2.5
07/28/2021 05:00	15.2	2.9	2.2	12.0	2.6
07/28/2021 06:00	14.6	4.8	2.1	11.6	2.5
07/28/2021 07:00	9.9	0.3	1.7	9.1	2.0
07/28/2021 08:00	11.9	0.3	1.7	9.3	2.0
07/28/2021 09:00	14.5	4.6	2.1	11.3	2.5
07/28/2021 10:00	15.3	1.8	2.2	12.0	2.7
07/28/2021 11:00	15.3	1.2	2.2	12.0	2.6
07/28/2021 12:00	15.2	1.2	2.2	12.0	2.6
07/28/2021 13:00	15.3	1.2	2.2	12.0	2.6
07/28/2021 14:00	15.2	1.2	2.2	12.0	2.6
07/28/2021 15:00	15.2	1.2	2.2	12.0	2.6
07/28/2021 16:00	15.2	1.2	2.2	12.0	2.6
07/28/2021 17:00	15.2	1.2	2.2	12.0	2.6
07/28/2021 18:00	15.1	1.2	2.1	11.8	2.6
07/28/2021 19:00	14.9	1.8	2.1	11.8	2.6
07/28/2021 20:00	14.8	2.4	2.1	11.6	2.5
07/28/2021 21:00	15.2	1.5	2.2	12.0	2.6
07/28/2021 22:00	15.0	1.8	2.1	11.8	2.6
07/28/2021 23:00	15.2	2.4	2.2	11.9	2.6
Average/Sum#:	344.1 #	57.1 #	49.8 #	272.0 #	59.4 #
Minimum:	9.9	0.3	1.7	9.1	2.0
Maximum:	15.3	9.5	2.2	12.0	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
07/29/2021 00:00	15.3	2.1	2.2	12.0	2.6
07/29/2021 01:00	15.1	2.4	2.1	11.9	2.6
07/29/2021 02:00	11.2	1.7	1.6	8.9	2.0
07/29/2021 03:00	12.0	0.9	1.7	9.4	2.0
07/29/2021 04:00	14.3	7.3	2.1	11.3	2.5
07/29/2021 05:00	15.2	2.9	2.2	12.0	2.6
07/29/2021 06:00	14.5	4.7	2.1	11.4	2.5
07/29/2021 07:00	9.9	0.3	1.7	9.0	2.0
07/29/2021 08:00	11.7	0.9	1.7	9.1	2.0
07/29/2021 09:00	14.1	8.7	2.0	11.0	2.4
07/29/2021 10:00	15.3	1.8	2.2	12.1	2.7
07/29/2021 11:00	15.3	1.2	2.2	12.1	2.7
07/29/2021 12:00	15.3	1.2	2.2	12.1	2.7
07/29/2021 13:00	15.3	1.2	2.2	12.0	2.7
07/29/2021 14:00	15.3	1.2	2.2	12.0	2.7
07/29/2021 15:00	15.1	0.9	2.2	11.9	2.6
07/29/2021 16:00	15.1	0.9	2.2	11.9	2.6
07/29/2021 17:00	15.1	1.2	2.2	11.9	2.6
07/29/2021 18:00	15.1	1.2	2.2	11.9	2.6
07/29/2021 19:00	15.1	1.2	2.2	11.9	2.6
07/29/2021 20:00	15.1	1.8	2.2	11.8	2.6
07/29/2021 21:00	15.2	1.5	2.2	12.0	2.6
07/29/2021 22:00	15.2	1.8	2.2	12.0	2.6
07/29/2021 23:00	15.2	1.8	2.2	11.9	2.6
Average/Sum#:	346.0 #	50.8 #	50.2 #	273.5 #	60.1 #
Minimum:	9.9	0.3	1.6	8.9	2.0
Maximum:	15.3	8.7	2.2	12.1	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
07/30/2021 00:00	15.0	2.4	2.1	11.8	2.6
07/30/2021 01:00	14.6	3.4	2.1	11.4	2.5
07/30/2021 02:00	13.4	1.2	1.7	9.3	2.0
07/30/2021 03:00	13.8	0.6	1.7	9.5	2.0
07/30/2021 04:00	14.5	6.0	2.1	11.5	2.5
07/30/2021 05:00	15.5	2.1	2.2	12.1	2.7
07/30/2021 06:00	15.2	2.5	2.2	12.0	2.6
07/30/2021 07:00	15.2	2.1	2.2	12.0	2.6
07/30/2021 08:00	15.2	2.1	2.2	11.9	2.6
07/30/2021 09:00	15.3	1.5	2.2	12.0	2.6
07/30/2021 10:00	15.2	1.5	2.2	12.0	2.6
07/30/2021 11:00	15.4	1.2	2.2	12.0	2.7
07/30/2021 12:00	15.4	1.2	2.2	12.0	2.7
07/30/2021 13:00	15.2	1.2	2.2	12.0	2.6
07/30/2021 14:00	15.2	1.2	2.2	12.0	2.6
07/30/2021 15:00	15.2	1.2	2.2	12.0	2.6
07/30/2021 16:00	15.2	1.2	2.2	12.0	2.6
07/30/2021 17:00	15.2	1.2	2.2	12.0	2.6
07/30/2021 18:00	15.2	1.2	2.2	11.9	2.6
07/30/2021 19:00	15.2	1.2	2.2	12.0	2.6
07/30/2021 20:00	15.3	1.2	2.2	12.0	2.6
07/30/2021 21:00	15.2	1.2	2.2	12.0	2.6
07/30/2021 22:00	15.2	1.2	2.2	12.0	2.6
07/30/2021 23:00	15.4	1.5	2.2	12.0	2.7
Average/Sum#:	361.2 #	41.3 #	51.5 #	281.4 #	61.4 #
Minimum:	13.4	0.6	1.7	9.3	2.0
Maximum:	15.5	6.0	2.2	12.1	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
07/31/2021 00:00	15.5	1.5	2.3	12.2	2.7
07/31/2021 01:00	15.5	1.6	2.3	12.2	2.7
07/31/2021 02:00	15.2	2.2	2.2	12.0	2.6
07/31/2021 03:00	11.7	1.2	1.7	9.3	2.0
07/31/2021 04:00	14.1	0.3	1.7	9.7	2.1
07/31/2021 05:00	15.3	8.8	2.0	10.6	2.3
07/31/2021 06:00	14.6	4.7	2.1	11.5	2.5
07/31/2021 07:00	11.8	0.3	1.7	9.2	2.0
07/31/2021 08:00	11.1	1.2	1.6	8.7	1.9
07/31/2021 09:00	14.2	8.3	2.1	11.2	2.4
07/31/2021 10:00	14.6	4.7	2.1	11.4	2.5
07/31/2021 11:00	14.6	4.1	2.1	11.5	2.5
07/31/2021 12:00	14.7	3.8	2.1	11.6	2.5
07/31/2021 13:00	14.6	3.8	2.1	11.6	2.5
07/31/2021 14:00	14.6	3.8	2.1	11.6	2.5
07/31/2021 15:00	14.8	3.3	2.1	11.6	2.5
07/31/2021 16:00	14.8	2.7	2.1	11.6	2.5
07/31/2021 17:00	15.0	2.4	2.1	11.8	2.6
07/31/2021 18:00	15.2	2.1	2.2	12.0	2.6
07/31/2021 19:00	15.2	2.2	2.2	11.8	2.6
07/31/2021 20:00	15.4	1.8	2.2	12.1	2.7
07/31/2021 21:00	15.3	2.1	2.2	12.0	2.6
07/31/2021 22:00	15.1	2.5	2.1	11.8	2.6
07/31/2021 23:00	14.6	4.1	2.1	11.6	2.5
Average/Sum#:	347.5 #	73.5 #	49.5 #	270.6 #	58.9 #
Minimum:	11.1	0.3	1.6	8.7	1.9
Maximum:	15.5	8.8	2.3	12.2	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
08/01/2021 00:00	13.7	8.8	2.0	10.8	2.4
08/01/2021 01:00	13.2	0.6	1.7	9.1	2.0
08/01/2021 02:00	11.8	0.9	1.7	9.3	2.0
08/01/2021 03:00	14.1	8.6	2.0	11.1	2.4
08/01/2021 04:00	13.8	7.6	2.0	10.9	2.4
08/01/2021 05:00	13.4	0.6	1.7	9.2	2.0
08/01/2021 06:00	9.7	0.6	1.6	8.9	2.0
08/01/2021 07:00	9.7	0.6	1.6	8.9	2.0
08/01/2021 08:00	8.5	1.0	1.4	7.7	1.7
08/01/2021 09:00	9.3	0.9	1.6	8.6	1.8
08/01/2021 10:00	14.2	8.2	2.1	11.2	2.4
08/01/2021 11:00	14.0	6.5	2.0	11.0	2.4
08/01/2021 12:00	11.3	0.3	1.6	8.9	2.0
08/01/2021 13:00	13.3	0.3	1.7	9.1	2.0
08/01/2021 14:00	13.4	0.0	1.7	9.2	2.0
08/01/2021 15:00	13.6	0.0	1.7	9.3	2.0
08/01/2021 16:00	14.5	4.6	1.8	9.9	2.2
08/01/2021 17:00	15.3	2.1	2.2	12.0	2.6
08/01/2021 18:00	15.6	1.5	2.3	12.2	2.7
08/01/2021 19:00	15.4	1.5	2.2	12.2	2.7
08/01/2021 20:00	15.6	1.5	2.3	12.2	2.7
08/01/2021 21:00	15.6	1.5	2.3	12.3	2.7
08/01/2021 22:00	15.5	1.9	2.3	12.2	2.7
08/01/2021 23:00	15.3	2.2	2.2	12.0	2.6
Average/Sum#:	319.8 #	62.3 #	45.7 #	248.2 #	54.4 #
Minimum:	8.5	0.0	1.4	7.7	1.7
Maximum:	15.6	8.8	2.3	12.3	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
08/02/2021 00:00	15.5	1.9	2.2	12.1	2.7
08/02/2021 01:00	15.2	2.8	2.2	12.0	2.6
08/02/2021 02:00	11.5	1.8	1.7	9.1	2.0
08/02/2021 03:00	13.5	0.6	1.7	9.3	2.0
08/02/2021 04:00	16.5	7.4	2.1	11.3	2.5
08/02/2021 05:00	15.5	2.8	2.3	12.2	2.7
08/02/2021 06:00	14.9	4.1	2.1	11.7	2.6
08/02/2021 07:00	11.8	1.8	1.7	9.3	2.0
08/02/2021 08:00	9.5	1.2	1.6	8.7	1.9
08/02/2021 09:00	14.4	7.7	2.1	11.2	2.5
08/02/2021 10:00	15.0	3.5	2.1	11.8	2.6
08/02/2021 11:00	15.2	2.5	2.2	12.0	2.6
08/02/2021 12:00	15.0	2.8	2.1	11.8	2.6
08/02/2021 13:00	15.0	3.1	2.1	11.8	2.6
08/02/2021 14:00	15.0	3.1	2.1	11.8	2.6
08/02/2021 15:00	15.0	3.1	2.1	11.8	2.6
08/02/2021 16:00	15.0	3.1	2.1	11.8	2.6
08/02/2021 17:00	15.2	2.5	2.2	11.8	2.6
08/02/2021 18:00	15.5	1.9	2.2	12.2	2.7
08/02/2021 19:00	15.6	1.9	2.3	12.2	2.7
08/02/2021 20:00	15.6	1.6	2.3	12.3	2.7
08/02/2021 21:00	15.6	1.6	2.3	12.4	2.7
08/02/2021 22:00	15.7	1.6	2.3	12.4	2.7
08/02/2021 23:00	15.7	1.6	2.3	12.4	2.7
Average/Sum#:	352.4 #	66.0 #	50.4 #	275.4 #	60.5 #
Minimum:	9.5	0.6	1.6	8.7	1.9
Maximum:	16.5	7.7	2.3	12.4	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
08/03/2021 00:00	15.3	2.2	2.2	12.1	2.6
08/03/2021 01:00	15.3	2.2	2.2	12.0	2.6
08/03/2021 02:00	12.1	1.2	1.7	9.5	2.1
08/03/2021 03:00	14.1	1.0	1.7	9.7	2.1
08/03/2021 04:00	11.5	10.2	1.9	9.1	2.1
08/03/2021 05:00	6.6	4.2	1.5	5.5	1.3
08/03/2021 06:00	8.7	4.1	1.5	5.4	1.3
08/03/2021 07:00	8.7	3.8	1.5	5.5	1.3
08/03/2021 08:00	8.8	3.5	1.5	5.5	1.3
08/03/2021 09:00	6.7	3.1	1.6	5.6	1.3
08/03/2021 10:00	6.8	2.8	1.6	5.7	1.4
08/03/2021 11:00	50.1	79.0	1.6	6.3	1.5
08/03/2021 12:00	6.6	0.5	1.3	7.2	1.6
08/03/2021 13:00	10.2	0.3	1.7	9.3	2.0
08/03/2021 14:00	14.6	4.1	2.1	11.4	2.5
08/03/2021 15:00	15.0	2.2	2.1	11.8	2.6
08/03/2021 16:00	15.0	1.9	2.1	11.8	2.6
08/03/2021 17:00	15.1	1.8	2.1	11.8	2.6
08/03/2021 18:00	15.4	1.9	2.2	12.2	2.7
08/03/2021 19:00	15.5	1.5	2.2	12.2	2.7
08/03/2021 20:00	15.6	1.5	2.3	12.2	2.7
08/03/2021 21:00	15.6	1.5	2.3	12.2	2.7
08/03/2021 22:00	15.5	1.5	2.3	12.2	2.7
08/03/2021 23:00	15.4	1.9	2.2	12.1	2.7
Average/Sum#:	334.2 #	137.9 #	45.4 #	228.3 #	51.0 #
Minimum:	6.6	0.3	1.3	5.4	1.3
Maximum:	50.1	79.0	2.3	12.2	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
08/04/2021 00:00	14.4	2.8	2.1	11.3	2.5
08/04/2021 01:00	11.6	0.3	1.7	9.1	2.0
08/04/2021 02:00	14.1	0.6	1.7	9.7	2.1
08/04/2021 03:00	16.3	7.0	2.1	11.2	2.4
08/04/2021 04:00	15.3	2.2	2.2	12.0	2.6
08/04/2021 05:00	15.5	2.2	2.3	12.2	2.7
08/04/2021 06:00	14.6	3.1	2.1	11.5	2.5
08/04/2021 07:00	13.7	5.9	2.0	10.8	2.4
08/04/2021 08:00	9.7	0.3	1.7	8.9	2.0
08/04/2021 09:00	13.6	0.3	1.7	9.3	2.0
08/04/2021 10:00	14.2	5.3	2.1	11.2	2.4
08/04/2021 11:00	15.2	1.9	2.2	12.0	2.6
08/04/2021 12:00	15.0	1.8	2.1	11.8	2.6
08/04/2021 13:00	14.9	1.8	2.1	11.7	2.6
08/04/2021 14:00	14.9	1.8	2.1	11.7	2.6
08/04/2021 15:00	14.9	1.8	2.1	11.8	2.6
08/04/2021 16:00	15.1	1.5	2.1	11.8	2.6
08/04/2021 17:00	15.2	1.5	2.2	12.0	2.6
08/04/2021 18:00	15.2	1.5	2.2	12.0	2.6
08/04/2021 19:00	15.4	1.5	2.2	12.1	2.7
08/04/2021 20:00	15.5	1.5	2.2	12.2	2.7
08/04/2021 21:00	15.6	1.5	2.3	12.2	2.7
08/04/2021 22:00	15.6	1.6	2.3	12.2	2.7
08/04/2021 23:00	15.0	2.2	2.1	11.8	2.6
Average/Sum#:	350.5 #	51.9 #	49.9 #	272.5 #	59.8 #
Minimum:	9.7	0.3	1.7	8.9	2.0
Maximum:	16.3	7.0	2.3	12.2	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
08/05/2021 00:00	14.9	2.5	2.1	11.7	2.6
08/05/2021 01:00	15.1	2.2	2.1	11.9	2.6
08/05/2021 02:00	15.0	1.6	2.1	11.9	2.6
08/05/2021 03:00	15.3	1.3	2.2	12.1	2.6
08/05/2021 04:00	15.5	1.3	2.3	12.1	2.7
08/05/2021 05:00	15.4	1.3	2.2	12.1	2.6
08/05/2021 06:00	14.1	4.8	2.0	11.1	2.4
08/05/2021 07:00	9.9	0.3	1.7	9.1	2.0
08/05/2021 08:00	9.7	0.6	1.7	8.9	2.0
08/05/2021 09:00	13.8	9.6	2.0	10.8	2.4
08/05/2021 10:00	14.2	3.8	2.1	11.2	2.4
08/05/2021 11:00	11.7	0.3	1.7	9.2	2.0
08/05/2021 12:00	12.2	0.0	1.7	9.6	2.1
08/05/2021 13:00	14.3	5.0	2.1	11.2	2.5
08/05/2021 14:00	14.6	2.2	2.1	11.6	2.5
08/05/2021 15:00	14.8	2.2	2.1	11.6	2.5
08/05/2021 16:00	15.0	2.2	2.1	11.8	2.6
08/05/2021 17:00	14.8	2.2	2.1	11.6	2.5
08/05/2021 18:00	15.4	1.9	2.2	12.0	2.7
08/05/2021 19:00	15.4	1.9	2.2	12.2	2.7
08/05/2021 20:00	15.5	1.6	2.3	12.2	2.7
08/05/2021 21:00	15.2	1.9	2.2	12.0	2.6
08/05/2021 22:00	14.8	2.2	2.1	11.7	2.6
08/05/2021 23:00	14.6	2.5	2.1	11.5	2.5
Average/Sum#:	341.2 #	55.4 #	49.5 #	271.1 #	59.4 #
Minimum:	9.7	0.0	1.7	8.9	2.0
Maximum:	15.5	9.6	2.3	12.2	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
08/06/2021 00:00	14.2	2.8	2.1	11.2	2.4
08/06/2021 01:00	11.8	0.9	1.7	9.2	2.0
08/06/2021 02:00	11.8	0.9	1.7	9.2	2.0
08/06/2021 03:00	11.4	0.9	1.6	8.9	2.0
08/06/2021 04:00	14.1	8.6	2.0	11.1	2.4
08/06/2021 05:00	14.2	4.5	2.1	11.2	2.4
08/06/2021 06:00	9.5	0.3	1.6	8.7	1.9
08/06/2021 07:00	9.9	0.3	1.7	9.1	2.0
08/06/2021 08:00	11.6	0.6	1.7	9.1	2.0
08/06/2021 09:00	13.8	7.6	2.0	10.9	2.4
08/06/2021 10:00	13.7	6.6	2.0	10.8	2.4
08/06/2021 11:00	13.1	0.9	1.7	9.1	2.0
08/06/2021 12:00	9.1	0.6	1.6	8.3	1.8
08/06/2021 13:00	13.9	6.6	2.0	11.0	2.4
08/06/2021 14:00	14.6	2.8	2.1	11.5	2.5
08/06/2021 15:00	14.5	2.8	2.1	11.4	2.5
08/06/2021 16:00	14.8	2.1	2.1	11.6	2.6
08/06/2021 17:00	14.9	1.8	2.1	11.7	2.6
08/06/2021 18:00	15.3	1.5	2.2	12.0	2.6
08/06/2021 19:00	14.9	1.8	2.1	11.7	2.6
08/06/2021 20:00	14.8	1.8	2.1	11.7	2.6
08/06/2021 21:00	14.6	2.1	2.1	11.5	2.5
08/06/2021 22:00	14.4	3.1	2.1	11.3	2.5
08/06/2021 23:00	13.6	4.9	2.0	10.7	2.4
Average/Sum#:	318.5 #	66.8 #	46.5 #	252.9 #	55.5 #
Minimum:	9.1	0.3	1.6	8.3	1.8
Maximum:	15.3	8.6	2.2	12.0	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
08/07/2021 00:00	13.4	0.6	1.7	9.3	2.0
08/07/2021 01:00	12.8	1.2	1.6	8.9	2.0
08/07/2021 02:00	15.7	5.0	2.0	10.8	2.4
08/07/2021 03:00	9.6	27.5	0.5	3.1	0.6
08/07/2021 04:00	0.0	0.0	0.0	0.0	0.0
08/07/2021 05:00	0.0	0.0	0.0	0.0	0.0
08/07/2021 06:00	0.0	0.0	0.0	0.0	0.0
08/07/2021 07:00	0.0	0.0	0.0	0.0	0.0
08/07/2021 08:00	0.0	0.0	0.0	0.0	0.0
08/07/2021 09:00	0.3	2.4	0.0	0.1	0.0
08/07/2021 10:00	24.8	75.2	0.2	1.7	0.3
08/07/2021 11:00	15.4	44.4	0.1	0.8	0.2
08/07/2021 12:00	19.2	71.9	0.2	2.0	0.4
08/07/2021 13:00	6.7	4.6	0.5	4.7	0.9
08/07/2021 14:00	54.8	100.0	1.0	6.4	1.4
08/07/2021 15:00	13.1	0.3	1.7	9.0	2.0
08/07/2021 16:00	10.6	0.8	1.5	8.3	1.8
08/07/2021 17:00	14.1	5.5	2.0	11.2	2.4
08/07/2021 18:00	16.8	2.7	2.1	11.5	2.5
08/07/2021 19:00	14.0	2.7	2.0	11.0	2.4
08/07/2021 20:00	13.4	0.3	1.7	9.1	2.0
08/07/2021 21:00	13.1	0.6	1.7	8.9	2.0
08/07/2021 22:00	13.7	9.8	2.0	10.8	2.4
08/07/2021 23:00	14.2	3.6	2.1	11.2	2.4
Average/Sum#:	295.7 #	359.1 #	24.6 #	138.8 #	30.1 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	54.8	100.0	2.1	11.5	2.5
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
08/08/2021 00:00	12.6	0.6	1.6	8.7	1.9
08/08/2021 01:00	9.3	1.1	1.6	8.5	1.8
08/08/2021 02:00	13.5	9.8	2.0	10.6	2.3
08/08/2021 03:00	8.9	2.1	1.4	8.1	1.8
08/08/2021 04:00	5.2	7.4	0.4	4.2	0.8
08/08/2021 05:00	4.1	0.0	0.4	4.1	0.8
08/08/2021 06:00	4.1	0.0	0.4	4.1	0.8
08/08/2021 07:00	4.1	0.0	0.4	4.1	0.8
08/08/2021 08:00	4.1	0.0	0.4	4.1	0.8
08/08/2021 09:00	4.1	0.0	0.4	4.1	0.8
08/08/2021 10:00	4.1	0.0	0.4	4.1	0.8
08/08/2021 11:00	4.1	0.0	0.4	4.1	0.8
08/08/2021 12:00	4.1	0.0	0.4	4.1	0.8
08/08/2021 13:00	4.3	0.0	0.4	4.3	0.9
08/08/2021 14:00	6.4	5.9	0.5	4.8	0.9
08/08/2021 15:00	63.1	99.4	1.0	6.4	1.4
08/08/2021 16:00	11.1	0.0	1.6	8.7	1.9
08/08/2021 17:00	12.4	3.0	1.8	9.7	2.1
08/08/2021 18:00	14.8	2.4	2.1	11.6	2.5
08/08/2021 19:00	14.9	2.1	2.1	11.8	2.6
08/08/2021 20:00	15.2	1.5	2.2	12.0	2.6
08/08/2021 21:00	14.8	1.8	2.1	11.7	2.6
08/08/2021 22:00	14.4	2.4	2.1	11.2	2.5
08/08/2021 23:00	13.5	4.9	2.0	10.6	2.3
Average/Sum#:	267.2 #	144.4 #	28.1 #	175.7 #	37.3 #
Minimum:	4.1	0.0	0.4	4.1	0.8
Maximum:	63.1	99.4	2.2	12.0	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
08/09/2021 00:00	12.6	0.3	1.6	8.7	1.9
08/09/2021 01:00	13.8	0.6	1.7	9.5	2.1
08/09/2021 02:00	16.1	6.6	2.0	11.0	2.4
08/09/2021 03:00	13.5	6.9	2.0	10.6	2.3
08/09/2021 04:00	13.4	0.3	1.7	9.2	2.0
08/09/2021 05:00	12.2	0.6	1.7	9.6	2.1
08/09/2021 06:00	16.0	7.6	2.0	10.9	2.4
08/09/2021 07:00	13.9	4.7	2.0	11.0	2.4
08/09/2021 08:00	12.6	0.3	1.6	8.7	1.9
08/09/2021 09:00	11.4	0.3	1.7	8.9	2.0
08/09/2021 10:00	11.6	0.3	1.7	9.1	2.0
08/09/2021 11:00	13.8	5.9	2.0	10.9	2.4
08/09/2021 12:00	14.4	2.1	2.1	11.3	2.5
08/09/2021 13:00	11.9	0.0	1.7	9.3	2.0
08/09/2021 14:00	12.6	2.4	1.8	9.9	2.2
08/09/2021 15:00	14.8	1.8	2.1	11.7	2.6
08/09/2021 16:00	15.0	1.5	2.1	11.8	2.6
08/09/2021 17:00	15.0	1.5	2.1	11.8	2.6
08/09/2021 18:00	15.0	1.8	2.1	11.8	2.6
08/09/2021 19:00	15.3	1.5	2.2	12.0	2.6
08/09/2021 20:00	15.4	1.5	2.2	12.1	2.7
08/09/2021 21:00	15.2	1.5	2.2	12.0	2.6
08/09/2021 22:00	14.6	2.2	2.1	11.4	2.5
08/09/2021 23:00	14.6	2.5	2.1	11.5	2.5
Average/Sum#:	334.7 #	54.7 #	46.5 #	254.7 #	55.9 #
Minimum:	11.4	0.0	1.6	8.7	1.9
Maximum:	16.1	7.6	2.2	12.1	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
08/10/2021 00:00	13.9	4.1	2.0	11.0	2.4
08/10/2021 01:00	12.9	0.3	1.6	8.9	2.0
08/10/2021 02:00	11.3	0.3	1.6	8.9	2.0
08/10/2021 03:00	13.8	0.6	1.7	9.5	2.0
08/10/2021 04:00	14.3	5.7	2.1	11.2	2.4
08/10/2021 05:00	14.4	3.4	2.1	11.3	2.5
08/10/2021 06:00	11.5	0.3	1.7	9.1	2.0
08/10/2021 07:00	9.7	0.9	1.6	8.9	2.0
08/10/2021 08:00	16.1	7.0	2.0	11.0	2.4
08/10/2021 09:00	13.5	5.7	2.0	10.6	2.3
08/10/2021 10:00	11.7	0.0	1.7	9.3	2.0
08/10/2021 11:00	13.6	0.3	1.7	9.3	2.0
08/10/2021 12:00	14.3	5.3	2.1	11.2	2.5
08/10/2021 13:00	14.9	1.8	2.1	11.8	2.6
08/10/2021 14:00	14.9	1.5	2.1	11.7	2.6
08/10/2021 15:00	14.9	1.8	2.1	11.8	2.6
08/10/2021 16:00	15.0	1.8	2.1	11.8	2.6
08/10/2021 17:00	15.1	1.8	2.1	11.8	2.6
08/10/2021 18:00	15.4	1.5	2.2	12.0	2.7
08/10/2021 19:00	15.4	1.5	2.2	12.2	2.7
08/10/2021 20:00	15.4	1.5	2.2	12.2	2.7
08/10/2021 21:00	15.4	1.5	2.2	12.1	2.7
08/10/2021 22:00	14.9	1.8	2.1	11.8	2.6
08/10/2021 23:00	14.8	2.2	2.1	11.7	2.6
Average/Sum#:	337.1 #	52.6 #	47.4 #	261.1 #	57.5 #
Minimum:	9.7	0.0	1.6	8.9	2.0
Maximum:	16.1	7.0	2.2	12.2	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
08/11/2021 00:00	14.4	2.8	2.1	11.3	2.5
08/11/2021 01:00	11.7	0.3	1.7	9.2	2.0
08/11/2021 02:00	12.9	0.3	1.6	8.9	2.0
08/11/2021 03:00	12.8	0.6	1.6	8.8	1.9
08/11/2021 04:00	11.3	0.6	1.7	8.9	2.0
08/11/2021 05:00	14.3	6.0	2.0	11.3	2.4
08/11/2021 06:00	14.4	3.5	2.1	11.3	2.5
08/11/2021 07:00	13.2	0.3	1.7	9.1	2.0
08/11/2021 08:00	14.0	0.3	1.7	9.5	2.1
08/11/2021 09:00	14.3	5.6	2.1	11.3	2.5
08/11/2021 10:00	15.0	1.8	2.1	11.8	2.6
08/11/2021 11:00	15.0	1.8	2.1	11.8	2.6
08/11/2021 12:00	14.7	1.8	2.1	11.6	2.5
08/11/2021 13:00	14.7	1.8	2.1	11.6	2.5
08/11/2021 14:00	14.8	1.2	2.1	11.6	2.6
08/11/2021 15:00	16.1	1.8	2.0	11.1	2.4
08/11/2021 16:00	16.9	1.8	2.1	11.6	2.5
08/11/2021 17:00	17.1	1.5	2.1	11.7	2.6
08/11/2021 18:00	17.4	1.2	2.2	12.0	2.6
08/11/2021 19:00	19.8	1.5	2.2	12.0	2.6
08/11/2021 20:00	19.9	1.5	2.2	12.0	2.7
08/11/2021 21:00	19.6	1.8	2.2	11.9	2.6
08/11/2021 22:00	16.9	2.1	2.1	11.6	2.5
08/11/2021 23:00	17.0	2.2	2.1	11.7	2.6
Average/Sum#:	368.2 #	44.1 #	48.0 #	263.6 #	57.8 #
Minimum:	11.3	0.3	1.6	8.8	1.9
Maximum:	19.9	6.0	2.2	12.0	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
08/12/2021 00:00	16.7	3.1	2.1	11.4	2.5
08/12/2021 01:00	13.4	0.6	1.7	9.2	2.0
08/12/2021 02:00	13.0	0.6	1.7	8.9	2.0
08/12/2021 03:00	14.1	3.5	2.0	11.0	2.4
08/12/2021 04:00	16.0	3.8	2.0	11.0	2.4
08/12/2021 05:00	11.7	0.6	1.7	9.2	2.0
08/12/2021 06:00	14.0	0.6	1.7	9.7	2.1
08/12/2021 07:00	16.1	7.3	2.0	11.0	2.4
08/12/2021 08:00	13.6	5.9	2.0	10.6	2.3
08/12/2021 09:00	13.5	0.3	1.7	9.3	2.0
08/12/2021 10:00	13.6	0.3	1.7	9.3	2.0
08/12/2021 11:00	14.3	4.7	2.1	11.2	2.5
08/12/2021 12:00	14.6	2.1	2.1	11.6	2.5
08/12/2021 13:00	14.6	2.1	2.1	11.4	2.5
08/12/2021 14:00	14.4	2.1	2.1	11.4	2.5
08/12/2021 15:00	14.6	2.1	2.1	11.4	2.5
08/12/2021 16:00	14.6	1.8	2.1	11.5	2.5
08/12/2021 17:00	14.7	1.8	2.1	11.6	2.5
08/12/2021 18:00	15.0	1.5	2.1	11.8	2.6
08/12/2021 19:00	15.1	1.5	2.1	11.9	2.6
08/12/2021 20:00	15.3	1.5	2.2	12.0	2.6
08/12/2021 21:00	15.0	1.8	2.1	11.8	2.6
08/12/2021 22:00	14.7	2.2	2.1	11.6	2.5
08/12/2021 23:00	14.3	2.5	2.1	11.2	2.4
Average/Sum#:	346.9 #	54.3 #	47.7 #	261.0 #	56.9 #
Minimum:	11.7	0.3	1.7	8.9	2.0
Maximum:	16.7	7.3	2.2	12.0	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
08/13/2021 00:00	13.6	6.0	2.0	10.8	2.4
08/13/2021 01:00	13.1	1.5	1.7	8.9	2.0
08/13/2021 02:00	8.9	0.8	1.5	8.2	1.8
08/13/2021 03:00	14.0	5.3	2.0	11.0	2.4
08/13/2021 04:00	13.5	7.9	2.0	10.6	2.3
08/13/2021 05:00	11.6	0.3	1.7	9.1	2.0
08/13/2021 06:00	9.8	0.3	1.7	8.9	2.0
08/13/2021 07:00	10.9	1.1	1.6	8.5	1.8
08/13/2021 08:00	16.0	9.5	2.0	11.0	2.4
08/13/2021 09:00	13.7	5.3	2.0	10.8	2.4
08/13/2021 10:00	11.1	0.0	1.6	8.7	1.9
08/13/2021 11:00	11.1	0.0	1.6	8.7	1.9
08/13/2021 12:00	14.2	5.3	2.1	11.2	2.4
08/13/2021 13:00	14.4	2.8	2.1	11.4	2.5
08/13/2021 14:00	14.4	2.5	2.1	11.4	2.5
08/13/2021 15:00	14.4	2.1	2.1	11.4	2.5
08/13/2021 16:00	14.4	2.1	2.1	11.4	2.5
08/13/2021 17:00	14.6	2.1	2.1	11.5	2.5
08/13/2021 18:00	14.9	1.8	2.1	11.7	2.6
08/13/2021 19:00	15.2	1.8	2.2	12.0	2.6
08/13/2021 20:00	15.0	1.8	2.1	11.8	2.6
08/13/2021 21:00	14.6	2.4	2.1	11.5	2.5
08/13/2021 22:00	14.6	2.5	2.1	11.5	2.5
08/13/2021 23:00	14.6	2.5	2.1	11.4	2.5
Average/Sum#:	322.6 #	67.7 #	46.7 #	253.4 #	55.5 #
Minimum:	8.9	0.0	1.5	8.2	1.8
Maximum:	16.0	9.5	2.2	12.0	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
08/14/2021 00:00	13.8	4.2	2.0	10.8	2.4
08/14/2021 01:00	13.5	0.3	1.7	9.3	2.0
08/14/2021 02:00	13.8	0.6	1.7	9.5	2.1
08/14/2021 03:00	14.1	5.9	2.0	11.0	2.4
08/14/2021 04:00	13.5	7.5	2.0	10.6	2.3
08/14/2021 05:00	11.9	0.6	1.7	9.3	2.0
08/14/2021 06:00	12.9	0.9	1.6	8.9	2.0
08/14/2021 07:00	9.1	1.1	1.5	8.3	1.8
08/14/2021 08:00	7.9	0.7	1.3	7.2	1.6
08/14/2021 09:00	12.7	0.0	1.6	8.7	1.9
08/14/2021 10:00	11.5	0.0	1.7	9.1	2.0
08/14/2021 11:00	13.4	0.0	1.7	9.1	2.0
08/14/2021 12:00	13.4	0.0	1.7	9.2	2.0
08/14/2021 13:00	14.0	4.2	2.0	11.1	2.4
08/14/2021 14:00	14.4	2.4	2.1	11.3	2.5
08/14/2021 15:00	11.0	0.0	1.6	8.7	1.9
08/14/2021 16:00	9.0	0.0	1.5	8.3	1.8
08/14/2021 17:00	14.2	3.0	2.1	11.2	2.4
08/14/2021 18:00	15.0	1.5	2.1	11.8	2.6
08/14/2021 19:00	15.1	1.5	2.1	11.9	2.6
08/14/2021 20:00	15.1	1.5	2.1	11.9	2.6
08/14/2021 21:00	14.9	1.8	2.1	11.7	2.6
08/14/2021 22:00	14.7	2.1	2.1	11.6	2.5
08/14/2021 23:00	14.6	2.5	2.1	11.4	2.5
Average/Sum#:	313.5 #	42.3 #	44.1 #	241.9 #	52.9 #
Minimum:	7.9	0.0	1.3	7.2	1.6
Maximum:	15.1	7.5	2.1	11.9	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
08/15/2021 00:00	13.7	5.3	2.0	10.8	2.4
08/15/2021 01:00	13.5	0.3	1.7	9.3	2.0
08/15/2021 02:00	11.3	0.6	1.7	8.9	2.0
08/15/2021 03:00	14.2	5.0	2.0	11.1	2.4
08/15/2021 04:00	13.5	6.8	2.0	10.6	2.3
08/15/2021 05:00	11.7	0.6	1.7	9.1	2.0
08/15/2021 06:00	12.7	0.6	1.6	8.7	1.9
08/15/2021 07:00	13.3	0.3	1.7	9.1	2.0
08/15/2021 08:00	10.5	0.8	1.5	8.2	1.8
08/15/2021 09:00	13.0	0.3	1.6	8.9	2.0
08/15/2021 10:00	13.4	0.3	1.7	9.2	2.0
08/15/2021 11:00	9.1	0.3	1.5	8.3	1.8
08/15/2021 12:00	12.1	1.4	1.7	9.5	2.1
08/15/2021 13:00	14.2	2.7	2.1	11.2	2.4
08/15/2021 14:00	11.3	0.0	1.7	8.9	2.0
08/15/2021 15:00	13.1	0.0	1.7	8.9	2.0
08/15/2021 16:00	14.3	3.6	2.1	11.2	2.5
08/15/2021 17:00	14.6	1.8	2.1	11.6	2.5
08/15/2021 18:00	15.0	1.8	2.1	11.8	2.6
08/15/2021 19:00	14.8	1.8	2.1	11.7	2.5
08/15/2021 20:00	14.8	2.1	2.1	11.6	2.5
08/15/2021 21:00	14.8	2.1	2.1	11.6	2.5
08/15/2021 22:00	14.6	2.4	2.1	11.5	2.5
08/15/2021 23:00	14.6	2.4	2.1	11.4	2.5
Average/Sum#:	318.1 #	43.3 #	44.7 #	243.1 #	53.2 #
Minimum:	9.1	0.0	1.5	8.2	1.8
Maximum:	15.0	6.8	2.1	11.8	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
08/16/2021 00:00	13.7	4.2	2.0	10.8	2.4
08/16/2021 01:00	13.5	0.3	1.7	9.3	2.0
08/16/2021 02:00	10.7	0.8	1.5	8.4	1.8
08/16/2021 03:00	13.9	6.5	2.0	11.0	2.4
08/16/2021 04:00	13.7	5.9	2.0	10.8	2.4
08/16/2021 05:00	13.6	0.6	1.7	9.3	2.0
08/16/2021 06:00	13.8	0.3	1.7	9.5	2.1
08/16/2021 07:00	13.9	5.6	2.0	10.9	2.4
08/16/2021 08:00	14.0	3.6	2.0	11.0	2.4
08/16/2021 09:00	11.7	0.3	1.7	9.2	2.0
08/16/2021 10:00	12.9	0.3	1.6	8.9	2.0
08/16/2021 11:00	14.3	4.5	2.1	11.2	2.5
08/16/2021 12:00	14.6	2.7	2.1	11.4	2.5
08/16/2021 13:00	14.5	2.4	2.1	11.4	2.5
08/16/2021 14:00	14.3	2.7	2.1	11.2	2.5
08/16/2021 15:00	14.7	1.8	2.1	11.6	2.5
08/16/2021 16:00	14.8	1.8	2.1	11.6	2.5
08/16/2021 17:00	15.0	1.5	2.1	11.8	2.6
08/16/2021 18:00	15.2	1.5	2.2	12.0	2.6
08/16/2021 19:00	15.2	1.8	2.2	12.0	2.6
08/16/2021 20:00	15.0	1.8	2.1	11.8	2.6
08/16/2021 21:00	15.0	1.8	2.1	11.8	2.6
08/16/2021 22:00	14.6	2.1	2.1	11.6	2.5
08/16/2021 23:00	14.7	2.5	2.1	11.5	2.5
Average/Sum#:	337.3 #	57.3 #	47.4 #	260.0 #	56.9 #
Minimum:	10.7	0.3	1.5	8.4	1.8
Maximum:	15.2	6.5	2.2	12.0	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
08/17/2021 00:00	14.4	2.8	2.1	11.4	2.5
08/17/2021 01:00	13.4	0.3	1.7	9.1	2.0
08/17/2021 02:00	13.0	0.9	1.7	8.9	2.0
08/17/2021 03:00	14.4	4.7	2.1	11.2	2.5
08/17/2021 04:00	14.9	2.5	2.1	11.7	2.6
08/17/2021 05:00	15.2	1.8	2.2	11.9	2.6
08/17/2021 06:00	14.4	2.7	2.1	11.4	2.5
08/17/2021 07:00	9.9	0.3	1.7	9.1	2.0
08/17/2021 08:00	9.5	0.6	1.6	8.7	1.9
08/17/2021 09:00	14.0	5.3	2.0	11.0	2.4
08/17/2021 10:00	13.5	5.0	2.0	10.6	2.3
08/17/2021 11:00	11.5	0.3	1.7	9.1	2.0
08/17/2021 12:00	8.9	0.8	1.4	8.1	1.8
08/17/2021 13:00	12.1	0.0	1.7	9.5	2.1
08/17/2021 14:00	14.5	3.3	1.8	9.9	2.2
08/17/2021 15:00	12.8	3.9	1.8	10.1	2.2
08/17/2021 16:00	10.9	0.3	1.6	8.5	1.8
08/17/2021 17:00	14.2	5.0	2.1	11.2	2.4
08/17/2021 18:00	15.0	2.1	2.1	11.8	2.6
08/17/2021 19:00	15.2	1.5	2.2	12.0	2.6
08/17/2021 20:00	15.4	1.5	2.2	12.0	2.7
08/17/2021 21:00	15.2	1.5	2.2	12.0	2.6
08/17/2021 22:00	14.8	2.2	2.1	11.7	2.6
08/17/2021 23:00	13.9	4.7	2.0	11.0	2.4
Average/Sum#:	321.0 #	54.0 #	46.2 #	251.9 #	55.3 #
Minimum:	8.9	0.0	1.4	8.1	1.8
Maximum:	15.4	5.3	2.2	12.0	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
08/18/2021 00:00	9.7	0.3	1.7	8.9	2.0
08/18/2021 01:00	9.3	0.6	1.6	8.5	1.8
08/18/2021 02:00	13.7	6.2	2.0	10.8	2.4
08/18/2021 03:00	13.5	7.1	2.0	10.6	2.3
08/18/2021 04:00	13.6	0.6	1.7	9.3	2.0
08/18/2021 05:00	11.7	0.3	1.7	9.2	2.0
08/18/2021 06:00	13.9	7.7	2.0	11.0	2.4
08/18/2021 07:00	13.6	7.0	2.0	10.8	2.4
08/18/2021 08:00	11.5	0.8	1.4	7.9	1.8
08/18/2021 09:00	4.6	0.0	1.6	8.5	1.8
08/18/2021 10:00	4.6	0.3	1.6	8.4	1.8
08/18/2021 11:00	8.8	0.0	1.4	8.1	1.8
08/18/2021 12:00	9.1	0.0	1.5	8.3	1.8
08/18/2021 13:00	14.4	5.2	2.1	11.4	2.5
08/18/2021 14:00	10.3	3.4	2.1	11.2	2.5
08/18/2021 15:00	11.7	0.6	1.7	9.2	2.0
08/18/2021 16:00	9.1	0.3	1.6	8.4	1.8
08/18/2021 17:00	14.0	4.5	2.0	11.0	2.4
08/18/2021 18:00	15.0	2.5	2.1	11.8	2.6
08/18/2021 19:00	13.9	4.1	2.0	11.0	2.4
08/18/2021 20:00	11.9	0.3	1.7	9.3	2.0
08/18/2021 21:00	12.0	0.3	1.7	9.5	2.0
08/18/2021 22:00	14.2	5.9	2.1	11.2	2.4
08/18/2021 23:00	13.5	7.0	2.0	10.6	2.3
Average/Sum#:	268.4 #	64.7 #	43.3 #	234.9 #	51.2 #
Minimum:	8.8	0.0	1.4	7.9	1.8
Maximum:	15.0	7.7	2.1	11.8	2.6
%SI	8.33	8.33	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
08/19/2021 00:00	11.2	0.6	1.6	8.9	2.0
08/19/2021 01:00	11.5	0.3	1.7	9.1	2.0
08/19/2021 02:00	9.1	0.8	1.5	8.3	1.8
08/19/2021 03:00	9.2	0.9	1.6	8.4	1.8
08/19/2021 04:00	14.2	5.8	2.0	11.2	2.4
08/19/2021 05:00	13.7	6.7	2.0	10.8	2.4
08/19/2021 06:00	11.5	0.3	1.7	9.1	2.0
08/19/2021 07:00	11.7	0.3	1.7	9.3	2.0
08/19/2021 08:00	8.1	0.5	1.4	7.4	1.6
08/19/2021 09:00	4.9	0.0	1.7	9.1	2.0
08/19/2021 10:00	4.8	0.0	1.7	8.9	2.0
08/19/2021 11:00	4.7	0.3	1.6	8.8	1.9
08/19/2021 12:00	8.4	1.6	1.7	9.3	2.0
08/19/2021 13:00	8.1	1.9	2.1	11.4	2.5
08/19/2021 14:00	14.1	5.4	2.0	11.0	2.4
08/19/2021 15:00	11.0	2.1	1.6	8.6	1.9
08/19/2021 16:00	11.6	2.2	1.7	9.1	2.0
08/19/2021 17:00	14.4	6.7	2.1	11.2	2.5
08/19/2021 18:00	14.8	4.1	2.1	11.6	2.5
08/19/2021 19:00	14.2	4.4	2.1	11.2	2.4
08/19/2021 20:00	11.8	1.9	1.7	9.3	2.0
08/19/2021 21:00	11.2	2.4	1.6	8.8	1.9
08/19/2021 22:00	14.0	7.7	2.0	11.0	2.4
08/19/2021 23:00	13.5	8.6	2.0	10.6	2.3
Average/Sum#:	248.7 #	63.6 #	42.9 #	232.4 #	50.7 #
Minimum:	4.7	0.0	1.4	7.4	1.6
Maximum:	14.8	8.6	2.1	11.6	2.5
%SI	8.33	8.33	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
08/20/2021 00:00	11.7	2.2	1.7	9.1	2.0
08/20/2021 01:00	11.7	2.2	1.7	9.1	2.0
08/20/2021 02:00	10.6	2.3	1.6	8.4	1.8
08/20/2021 03:00	8.1	2.8	1.3	7.4	1.6
08/20/2021 04:00	9.8	1.9	1.7	8.9	2.0
08/20/2021 05:00	12.0	11.0	1.7	9.4	2.0
08/20/2021 06:00	12.9	10.8	1.8	10.2	2.2
08/20/2021 07:00	11.5	2.2	1.7	9.1	2.0
08/20/2021 08:00	9.1	2.3	1.6	8.3	1.8
08/20/2021 09:00	7.9	2.3	1.3	7.2	1.6
08/20/2021 10:00	7.7	2.0	1.3	7.1	1.6
08/20/2021 11:00	7.7	2.0	1.3	7.1	1.6
08/20/2021 12:00	7.5	2.0	1.5	8.3	1.8
08/20/2021 13:00	14.2	7.3	2.0	11.2	2.4
08/20/2021 14:00	13.8	5.6	2.0	10.8	2.4
08/20/2021 15:00	10.6	2.0	1.6	8.4	1.8
08/20/2021 16:00	9.3	2.3	1.6	8.5	1.8
08/20/2021 17:00	14.3	5.3	2.1	11.2	2.5
08/20/2021 18:00	14.8	4.1	2.1	11.6	2.5
08/20/2021 19:00	14.4	4.4	2.1	11.2	2.5
08/20/2021 20:00	11.5	2.2	1.7	9.1	2.0
08/20/2021 21:00	11.9	2.2	1.7	9.3	2.0
08/20/2021 22:00	14.2	7.3	2.0	11.2	2.4
08/20/2021 23:00	13.4	9.2	2.0	10.6	2.3
Average/Sum#:	270.6 #	97.9 #	41.1 #	222.7 #	48.6 #
Minimum:	7.5	1.9	1.3	7.1	1.6
Maximum:	14.8	11.0	2.1	11.6	2.5
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
08/21/2021 00:00	4.4	17.1	0.1	0.7	0.2
08/21/2021 01:00	0.8	15.5	0.0	0.5	0.1
08/21/2021 02:00	7.8	31.5	0.3	3.3	0.7
08/21/2021 03:00	2.4	0.0	0.4	3.6	0.7
08/21/2021 04:00	2.4	0.0	0.4	3.7	0.7
08/21/2021 05:00	4.0	0.0	0.4	4.0	0.8
08/21/2021 06:00	4.0	0.0	0.4	4.0	0.8
08/21/2021 07:00	4.0	0.0	0.4	4.0	0.8
08/21/2021 08:00	4.0	0.0	0.4	4.0	0.8
08/21/2021 09:00	4.0	0.0	0.4	4.0	0.8
08/21/2021 10:00	4.0	0.0	0.4	4.0	0.8
08/21/2021 11:00	4.0	0.0	0.4	4.0	0.8
08/21/2021 12:00	4.0	0.0	0.4	4.0	0.8
08/21/2021 13:00	4.0	0.0	0.4	4.0	0.8
08/21/2021 14:00	4.0	0.0	0.4	4.0	0.8
08/21/2021 15:00	5.2	10.2	0.2	2.6	0.5
08/21/2021 16:00	0.0	0.0	0.0	0.0	0.0
08/21/2021 17:00	0.0	0.0	0.0	0.0	0.0
08/21/2021 18:00	0.0	0.0	0.0	0.0	0.0
08/21/2021 19:00	0.0	0.0	0.0	0.0	0.0
08/21/2021 20:00	0.0	0.0	0.0	0.0	0.0
08/21/2021 21:00	0.0	0.0	0.0	0.0	0.0
08/21/2021 22:00	0.0	0.0	0.0	0.0	0.0
08/21/2021 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	63.0 #	74.3 #	5.4 #	54.4 #	10.9 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	7.8	31.5	0.4	4.0	0.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
08/22/2021 00:00	0.0	0.0	0.0	0.0	0.0
08/22/2021 01:00	0.0	0.0	0.0	0.0	0.0
08/22/2021 02:00	0.0	0.0	0.0	0.0	0.0
08/22/2021 03:00	0.0	0.0	0.0	0.0	0.0
08/22/2021 04:00	0.0	0.0	0.0	0.0	0.0
08/22/2021 05:00	0.0	0.0	0.0	0.0	0.0
08/22/2021 06:00	0.0	0.0	0.0	0.0	0.0
08/22/2021 07:00	0.0	0.0	0.0	0.0	0.0
08/22/2021 08:00	0.0	0.0	0.0	0.0	0.0
08/22/2021 09:00	0.0	0.0	0.0	0.0	0.0
08/22/2021 10:00	0.0	0.0	0.0	0.0	0.0
08/22/2021 11:00	0.0	0.0	0.0	0.0	0.0
08/22/2021 12:00	0.0	0.0	0.0	0.0	0.0
08/22/2021 13:00	0.0	0.0	0.0	0.0	0.0
08/22/2021 14:00	0.0	0.0	0.0	0.0	0.0
08/22/2021 15:00	0.0	0.0	0.0	0.0	0.0
08/22/2021 16:00	0.0	0.0	0.0	0.0	0.0
08/22/2021 17:00	0.0	0.0	0.0	0.0	0.0
08/22/2021 18:00	0.0	0.0	0.0	0.0	0.0
08/22/2021 19:00	0.0	0.0	0.0	0.0	0.0
08/22/2021 20:00	0.0	0.0	0.0	0.0	0.0
08/22/2021 21:00	0.0	0.0	0.0	0.0	0.0
08/22/2021 22:00	0.0	0.0	0.0	0.0	0.0
08/22/2021 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
08/23/2021 00:00	0.0	0.0	0.0	0.0	0.0
08/23/2021 01:00	0.0	0.0	0.0	0.0	0.0
08/23/2021 02:00	0.0	0.0	0.0	0.0	0.0
08/23/2021 03:00	0.0	0.0	0.0	0.0	0.0
08/23/2021 04:00	0.0	0.0	0.0	0.0	0.0
08/23/2021 05:00	0.0	0.0	0.0	0.0	0.0
08/23/2021 06:00	0.0	0.0	0.0	0.0	0.0
08/23/2021 07:00	0.0	0.0	0.0	0.0	0.0
08/23/2021 08:00	0.0	0.0	0.0	0.0	0.0
08/23/2021 09:00	39.0	75.2	0.1	0.7	0.1
08/23/2021 10:00	25.3	33.1	0.1	1.2	0.2
08/23/2021 11:00	34.6	95.4	0.2	2.4	0.5
08/23/2021 12:00	2.6	11.0	0.2	1.9	0.4
08/23/2021 13:00	8.4	41.3	0.1	0.9	0.2
08/23/2021 14:00	25.4	49.4	0.3	3.3	0.7
08/23/2021 15:00	4.3	0.0	0.4	4.3	0.9
08/23/2021 16:00	70.5	75.3	0.7	5.8	1.2
08/23/2021 17:00	51.7	82.6	1.0	6.8	1.5
08/23/2021 18:00	8.3	1.7	1.7	9.3	2.0
08/23/2021 19:00	10.7	4.5	1.8	9.9	2.2
08/23/2021 20:00	13.0	5.7	1.8	10.2	2.2
08/23/2021 21:00	12.3	2.1	1.8	9.7	2.1
08/23/2021 22:00	14.0	8.6	2.0	11.0	2.4
08/23/2021 23:00	13.5	7.9	2.0	10.6	2.3
Average/Sum#:	281.9 #	411.2 #	14.2 #	88.0 #	18.9 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	70.5	95.4	2.0	11.0	2.4
%SI	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
08/24/2021 00:00	10.8	2.2	1.6	8.5	1.8
08/24/2021 01:00	11.3	1.9	1.6	8.9	2.0
08/24/2021 02:00	10.0	2.0	1.7	9.1	2.0
08/24/2021 03:00	13.5	13.9	2.0	10.6	2.3
08/24/2021 04:00	13.4	12.1	1.9	10.5	2.3
08/24/2021 05:00	11.6	2.0	1.7	9.1	2.0
08/24/2021 06:00	11.1	1.9	1.6	8.7	1.9
08/24/2021 07:00	11.5	1.6	1.7	9.0	2.0
08/24/2021 08:00	9.1	1.5	1.6	8.4	1.8
08/24/2021 09:00	10.0	1.7	1.7	9.3	2.0
08/24/2021 10:00	10.0	1.7	1.7	9.1	2.0
08/24/2021 11:00	9.7	1.6	1.7	8.9	2.0
08/24/2021 12:00	9.4	1.3	1.6	8.6	1.8
08/24/2021 13:00	9.8	1.6	1.7	9.1	2.0
08/24/2021 14:00	14.3	6.6	2.1	11.2	2.5
08/24/2021 15:00	14.2	5.3	2.1	11.2	2.4
08/24/2021 16:00	11.9	1.7	1.7	9.3	2.0
08/24/2021 17:00	10.4	2.0	1.7	9.6	2.1
08/24/2021 18:00	14.4	6.3	2.1	11.2	2.5
08/24/2021 19:00	14.8	3.9	2.1	11.6	2.5
08/24/2021 20:00	11.5	2.0	1.7	9.1	2.0
08/24/2021 21:00	12.4	2.4	1.8	9.7	2.1
08/24/2021 22:00	14.2	6.4	2.0	11.2	2.4
08/24/2021 23:00	14.8	5.1	2.1	11.6	2.5
Average/Sum#:	284.1 #	88.7 #	43.2 #	233.5 #	50.9 #
Minimum:	9.1	1.3	1.6	8.4	1.8
Maximum:	14.8	13.9	2.1	11.6	2.5
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
08/25/2021 00:00	11.4	2.5	1.7	8.9	2.0
08/25/2021 01:00	11.3	2.2	1.6	8.9	2.0
08/25/2021 02:00	11.0	2.2	1.6	8.7	1.9
08/25/2021 03:00	14.0	6.7	2.0	10.9	2.4
08/25/2021 04:00	14.4	4.4	2.1	11.3	2.5
08/25/2021 05:00	11.6	5.1	2.0	10.7	2.4
08/25/2021 06:00	9.5	1.9	1.6	8.7	1.9
08/25/2021 07:00	7.7	1.9	1.6	8.5	1.8
08/25/2021 08:00	8.1	1.9	1.6	8.9	2.0
08/25/2021 09:00	14.0	7.7	2.0	11.0	2.4
08/25/2021 10:00	13.6	9.0	2.0	10.6	2.3
08/25/2021 11:00	11.6	2.9	1.7	9.1	2.0
08/25/2021 12:00	11.5	2.2	1.7	8.9	2.0
08/25/2021 13:00	14.3	6.6	2.1	11.2	2.5
08/25/2021 14:00	14.2	5.2	2.1	11.2	2.4
08/25/2021 15:00	9.7	1.9	1.6	8.9	2.0
08/25/2021 16:00	7.4	2.0	1.4	8.1	1.8
08/25/2021 17:00	14.2	6.7	2.1	11.2	2.4
08/25/2021 18:00	14.8	4.3	2.1	11.6	2.5
08/25/2021 19:00	14.2	4.9	2.1	11.2	2.4
08/25/2021 20:00	11.5	1.9	1.7	9.1	2.0
08/25/2021 21:00	11.8	2.3	1.7	9.3	2.0
08/25/2021 22:00	14.2	7.0	2.0	11.1	2.4
08/25/2021 23:00	13.6	7.9	2.0	10.7	2.4
Average/Sum#:	289.6 #	101.3 #	44.1 #	238.7 #	52.4 #
Minimum:	7.4	1.9	1.4	8.1	1.8
Maximum:	14.8	9.0	2.1	11.6	2.5
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
08/26/2021 00:00	11.5	2.3	1.7	9.1	2.0
08/26/2021 01:00	11.3	2.2	1.6	8.9	2.0
08/26/2021 02:00	8.5	2.5	1.4	7.8	1.7
08/26/2021 03:00	9.5	2.2	1.6	8.7	1.9
08/26/2021 04:00	14.2	7.0	2.0	11.2	2.4
08/26/2021 05:00	14.5	6.1	2.1	11.4	2.5
08/26/2021 06:00	13.7	7.7	2.0	10.8	2.4
08/26/2021 07:00	11.7	2.3	1.7	9.2	2.0
08/26/2021 08:00	7.7	2.4	1.6	8.5	1.8
08/26/2021 09:00	12.8	5.5	1.8	10.1	2.2
08/26/2021 10:00	13.7	7.9	2.0	10.8	2.4
08/26/2021 11:00	12.0	2.3	1.7	9.4	2.0
08/26/2021 12:00	11.8	2.0	1.7	9.3	2.0
08/26/2021 13:00	14.2	6.9	2.0	11.2	2.4
08/26/2021 14:00	14.0	5.9	2.0	11.0	2.4
08/26/2021 15:00	12.0	2.0	1.7	9.4	2.0
08/26/2021 16:00	11.5	1.9	1.7	9.0	2.0
08/26/2021 17:00	14.5	5.2	2.1	11.4	2.5
08/26/2021 18:00	15.1	3.9	2.2	11.9	2.6
08/26/2021 19:00	15.4	3.6	2.2	12.2	2.7
08/26/2021 20:00	15.3	3.6	2.2	12.0	2.6
08/26/2021 21:00	15.2	3.9	2.2	12.0	2.6
08/26/2021 22:00	15.1	3.9	2.2	11.9	2.6
08/26/2021 23:00	14.4	5.9	2.1	11.4	2.5
Average/Sum#:	309.6 #	99.1 #	45.5 #	248.6 #	54.2 #
Minimum:	7.7	1.9	1.4	7.8	1.7
Maximum:	15.4	7.9	2.2	12.2	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
08/27/2021 00:00	11.8	2.0	1.7	9.3	2.0
08/27/2021 01:00	9.9	2.0	1.7	9.1	2.0
08/27/2021 02:00	10.0	1.6	1.7	9.3	2.0
08/27/2021 03:00	10.3	2.0	1.7	9.5	2.1
08/27/2021 04:00	14.4	7.2	2.1	11.2	2.5
08/27/2021 05:00	14.4	5.3	2.1	11.4	2.5
08/27/2021 06:00	11.1	2.2	1.6	8.7	1.9
08/27/2021 07:00	10.0	2.3	1.7	9.2	2.0
08/27/2021 08:00	7.6	2.4	1.6	8.4	1.8
08/27/2021 09:00	13.7	7.1	2.0	10.8	2.4
08/27/2021 10:00	13.8	5.8	2.0	10.8	2.4
08/27/2021 11:00	12.0	1.7	1.7	9.5	2.0
08/27/2021 12:00	10.3	1.7	1.7	9.4	2.0
08/27/2021 13:00	14.4	6.2	2.1	11.3	2.5
08/27/2021 14:00	15.1	3.5	2.1	11.9	2.6
08/27/2021 15:00	15.1	3.5	2.1	11.9	2.6
08/27/2021 16:00	15.1	3.5	2.1	11.9	2.6
08/27/2021 17:00	15.3	3.5	2.2	12.0	2.6
08/27/2021 18:00	15.3	3.5	2.2	12.1	2.6
08/27/2021 19:00	15.3	3.5	2.2	12.1	2.6
08/27/2021 20:00	15.4	3.5	2.3	12.1	2.6
08/27/2021 21:00	15.5	3.5	2.3	12.1	2.7
08/27/2021 22:00	15.1	3.9	2.1	11.9	2.6
08/27/2021 23:00	14.5	4.5	2.1	11.4	2.5
Average/Sum#:	315.4 #	85.9 #	47.1 #	257.3 #	56.1 #
Minimum:	7.6	1.6	1.6	8.4	1.8
Maximum:	15.5	7.2	2.3	12.1	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
08/28/2021 00:00	11.7	2.0	1.7	9.3	2.0
08/28/2021 01:00	10.5	2.3	1.8	9.7	2.1
08/28/2021 02:00	14.2	6.5	2.0	11.2	2.4
08/28/2021 03:00	13.5	6.8	2.0	10.6	2.3
08/28/2021 04:00	11.5	2.2	1.7	9.1	2.0
08/28/2021 05:00	8.2	1.9	1.7	9.1	2.0
08/28/2021 06:00	8.1	1.6	1.7	8.9	2.0
08/28/2021 07:00	9.9	1.6	1.7	9.1	2.0
08/28/2021 08:00	9.8	1.6	1.7	8.9	2.0
08/28/2021 09:00	9.9	1.6	1.7	9.1	2.0
08/28/2021 10:00	8.1	1.6	1.7	8.9	2.0
08/28/2021 11:00	14.4	6.5	2.1	11.4	2.5
08/28/2021 12:00	14.6	4.1	2.1	11.4	2.5
08/28/2021 13:00	10.1	1.6	1.7	9.3	2.0
08/28/2021 14:00	10.1	2.0	1.7	9.4	2.0
08/28/2021 15:00	14.2	7.0	2.1	11.2	2.4
08/28/2021 16:00	15.0	3.8	2.1	11.8	2.6
08/28/2021 17:00	15.2	3.5	2.2	12.0	2.6
08/28/2021 18:00	15.4	3.5	2.2	12.2	2.7
08/28/2021 19:00	15.6	3.2	2.3	12.2	2.7
08/28/2021 20:00	15.6	3.2	2.3	12.2	2.7
08/28/2021 21:00	15.4	3.2	2.2	12.2	2.7
08/28/2021 22:00	15.1	3.9	2.1	11.8	2.6
08/28/2021 23:00	14.7	4.2	2.1	11.6	2.5
Average/Sum#:	300.8 #	79.4 #	46.6 #	252.6 #	55.3 #
Minimum:	8.1	1.6	1.7	8.9	2.0
Maximum:	15.6	7.0	2.3	12.2	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
08/29/2021 00:00	13.8	5.1	2.0	10.8	2.4
08/29/2021 01:00	11.8	1.9	1.7	9.3	2.0
08/29/2021 02:00	10.5	2.3	1.8	9.7	2.1
08/29/2021 03:00	14.2	6.5	2.1	11.2	2.4
08/29/2021 04:00	14.2	5.7	2.1	11.2	2.4
08/29/2021 05:00	8.4	1.6	1.7	9.3	2.0
08/29/2021 06:00	4.8	1.6	1.7	8.9	2.0
08/29/2021 07:00	6.3	1.6	1.6	8.8	1.9
08/29/2021 08:00	7.6	1.5	1.6	8.4	1.8
08/29/2021 09:00	7.4	1.5	1.4	8.1	1.8
08/29/2021 10:00	12.8	10.1	1.8	10.1	2.2
08/29/2021 11:00	13.9	6.4	2.0	10.9	2.4
08/29/2021 12:00	12.0	1.9	1.7	9.4	2.0
08/29/2021 13:00	11.8	2.3	1.7	9.3	2.0
08/29/2021 14:00	14.4	5.7	2.1	11.4	2.5
08/29/2021 15:00	15.0	3.8	2.1	11.8	2.6
08/29/2021 16:00	15.0	3.8	2.1	11.8	2.6
08/29/2021 17:00	15.2	3.4	2.2	12.0	2.6
08/29/2021 18:00	15.4	3.5	2.2	12.0	2.7
08/29/2021 19:00	15.4	3.4	2.2	12.2	2.7
08/29/2021 20:00	15.4	3.1	2.2	12.2	2.7
08/29/2021 21:00	15.4	3.1	2.2	12.2	2.7
08/29/2021 22:00	15.1	3.5	2.2	11.8	2.6
08/29/2021 23:00	14.2	4.4	2.1	11.2	2.4
Average/Sum#:	300.0 #	87.7 #	46.5 #	254.0 #	55.5 #
Minimum:	4.8	1.5	1.4	8.1	1.8
Maximum:	15.4	10.1	2.2	12.2	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
08/30/2021 00:00	11.4	2.2	1.7	8.9	2.0
08/30/2021 01:00	11.7	2.2	1.7	9.1	2.0
08/30/2021 02:00	13.7	8.4	2.0	10.8	2.4
08/30/2021 03:00	14.2	5.4	2.1	11.2	2.4
08/30/2021 04:00	11.5	2.2	1.7	8.9	2.0
08/30/2021 05:00	10.8	2.3	1.6	8.4	1.8
08/30/2021 06:00	14.2	6.2	2.0	11.2	2.4
08/30/2021 07:00	14.0	5.7	2.0	11.0	2.4
08/30/2021 08:00	11.7	2.2	1.7	9.2	2.0
08/30/2021 09:00	11.5	2.2	1.7	9.1	2.0
08/30/2021 10:00	13.4	6.4	2.0	10.5	2.3
08/30/2021 11:00	14.4	4.7	2.1	11.3	2.5
08/30/2021 12:00	11.8	1.9	1.7	9.3	2.0
08/30/2021 13:00	10.0	2.2	1.7	9.3	2.0
08/30/2021 14:00	14.5	5.4	2.1	11.4	2.5
08/30/2021 15:00	15.0	3.7	2.1	11.8	2.6
08/30/2021 16:00	15.0	3.4	2.1	11.8	2.6
08/30/2021 17:00	15.2	3.4	2.2	12.0	2.6
08/30/2021 18:00	15.4	3.1	2.2	12.0	2.7
08/30/2021 19:00	15.4	3.1	2.2	12.2	2.7
08/30/2021 20:00	15.6	3.2	2.3	12.2	2.7
08/30/2021 21:00	15.4	3.5	2.2	12.2	2.7
08/30/2021 22:00	15.2	3.9	2.2	11.8	2.6
08/30/2021 23:00	14.4	4.4	2.1	11.3	2.5
Average/Sum#:	325.4 #	91.3 #	47.4 #	256.9 #	56.4 #
Minimum:	10.0	1.9	1.6	8.4	1.8
Maximum:	15.6	8.4	2.3	12.2	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
08/31/2021 00:00	11.5	2.2	1.7	9.1	2.0
08/31/2021 01:00	11.7	2.2	1.7	9.3	2.0
08/31/2021 02:00	7.9	2.5	1.3	7.2	1.6
08/31/2021 03:00	9.8	1.9	1.7	9.1	2.0
08/31/2021 04:00	10.9	6.5	1.8	10.0	2.2
08/31/2021 05:00	13.2	8.0	1.9	10.4	2.2
08/31/2021 06:00	10.6	2.0	1.8	9.8	2.2
08/31/2021 07:00	13.9	8.2	2.0	10.9	2.4
08/31/2021 08:00	14.4	4.8	2.1	11.3	2.5
08/31/2021 09:00	11.7	2.2	1.7	9.2	2.0
08/31/2021 10:00	10.1	2.2	1.7	9.3	2.0
08/31/2021 11:00	13.9	6.2	2.0	11.0	2.4
08/31/2021 12:00	14.4	4.7	2.1	11.4	2.5
08/31/2021 13:00	9.8	1.9	1.7	9.1	2.0
08/31/2021 14:00	10.2	1.9	1.7	9.4	2.0
08/31/2021 15:00	13.9	6.7	2.0	11.0	2.4
08/31/2021 16:00	15.0	4.1	2.1	11.8	2.6
08/31/2021 17:00	15.0	3.8	2.1	11.8	2.6
08/31/2021 18:00	15.2	3.8	2.2	12.0	2.6
08/31/2021 19:00	14.6	3.7	2.1	11.6	2.5
08/31/2021 20:00	11.5	1.9	1.7	9.1	2.0
08/31/2021 21:00	11.9	2.2	1.7	9.3	2.0
08/31/2021 22:00	14.0	6.8	2.0	11.0	2.4
08/31/2021 23:00	14.5	3.6	2.1	11.5	2.5
Average/Sum#:	299.6 #	94.0 #	44.9 #	245.6 #	53.6 #
Minimum:	7.9	1.9	1.3	7.2	1.6
Maximum:	15.2	8.2	2.2	12.0	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
09/01/2021 00:00	14.7	2.6	2.1	11.5	2.5
09/01/2021 01:00	13.4	3.6	2.0	10.6	2.3
09/01/2021 02:00	7.9	1.5	1.6	8.7	1.9
09/01/2021 03:00	10.1	1.9	1.7	9.3	2.0
09/01/2021 04:00	14.0	5.8	2.0	11.0	2.4
09/01/2021 05:00	14.7	3.9	2.1	11.5	2.5
09/01/2021 06:00	13.9	5.2	2.0	10.9	2.4
09/01/2021 07:00	8.4	1.3	1.7	9.2	2.0
09/01/2021 08:00	8.1	1.5	1.6	8.9	2.0
09/01/2021 09:00	13.1	7.7	1.9	10.4	2.2
09/01/2021 10:00	13.8	7.2	2.0	10.9	2.4
09/01/2021 11:00	10.4	2.8	1.5	8.2	1.8
09/01/2021 12:00	9.3	2.1	1.6	8.5	1.8
09/01/2021 13:00	13.9	7.1	2.0	10.9	2.4
09/01/2021 14:00	13.8	5.7	2.0	10.8	2.4
09/01/2021 15:00	11.7	2.5	1.7	9.3	2.0
09/01/2021 16:00	11.8	2.2	1.7	9.3	2.0
09/01/2021 17:00	14.2	6.5	2.1	11.2	2.4
09/01/2021 18:00	14.6	4.8	2.1	11.5	2.5
09/01/2021 19:00	14.6	4.5	2.1	11.4	2.5
09/01/2021 20:00	11.7	1.9	1.7	9.3	2.0
09/01/2021 21:00	8.3	2.9	1.4	7.6	1.6
09/01/2021 22:00	8.1	1.9	1.7	8.9	2.0
09/01/2021 23:00	10.1	1.6	1.7	9.3	2.0
Average/Sum#:	284.6 #	88.7 #	44.0 #	239.1 #	52.0 #
Minimum:	7.9	1.3	1.4	7.6	1.6
Maximum:	14.7	7.7	2.1	11.5	2.5
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
09/02/2021 00:00	11.0	4.1	1.8	10.1	2.2
09/02/2021 01:00	12.9	3.8	1.9	10.2	2.2
09/02/2021 02:00	8.1	2.6	1.4	7.4	1.6
09/02/2021 03:00	10.0	1.9	1.7	9.2	2.0
09/02/2021 04:00	8.3	2.4	1.4	7.6	1.6
09/02/2021 05:00	9.9	1.9	1.7	9.1	2.0
09/02/2021 06:00	9.1	7.3	1.8	10.0	2.2
09/02/2021 07:00	12.8	6.1	1.8	10.1	2.2
09/02/2021 08:00	8.1	2.1	1.4	7.4	1.6
09/02/2021 09:00	8.7	2.0	1.4	7.9	1.8
09/02/2021 10:00	9.0	1.7	1.5	8.3	1.8
09/02/2021 11:00	8.5	2.2	1.4	7.8	1.7
09/02/2021 12:00	10.1	1.9	1.7	9.3	2.0
09/02/2021 13:00	14.1	6.9	2.0	11.2	2.4
09/02/2021 14:00	15.9	5.4	2.0	10.8	2.4
09/02/2021 15:00	11.7	1.9	1.7	9.1	2.0
09/02/2021 16:00	9.7	2.2	1.7	8.9	2.0
09/02/2021 17:00	16.4	6.5	2.1	11.2	2.5
09/02/2021 18:00	16.7	5.1	2.1	11.4	2.5
09/02/2021 19:00	16.5	5.1	2.1	11.2	2.5
09/02/2021 20:00	9.5	2.1	1.6	8.7	1.9
09/02/2021 21:00	8.3	1.9	1.4	7.6	1.6
09/02/2021 22:00	9.6	1.9	1.6	8.9	2.0
09/02/2021 23:00	12.8	7.1	1.8	10.0	2.2
Average/Sum#:	267.7 #	86.1 #	41.0 #	223.4 #	48.9 #
Minimum:	8.1	1.7	1.4	7.4	1.6
Maximum:	16.7	7.3	2.1	11.4	2.5
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
09/03/2021 00:00	13.1	5.7	1.9	10.4	2.2
09/03/2021 01:00	11.2	2.4	1.6	8.8	2.0
09/03/2021 02:00	10.6	2.0	1.8	9.8	2.2
09/03/2021 03:00	13.4	14.1	1.9	10.5	2.3
09/03/2021 04:00	9.4	1.8	1.6	8.7	1.9
09/03/2021 05:00	10.4	1.9	1.7	9.6	2.1
09/03/2021 06:00	14.1	4.6	2.0	11.1	2.4
09/03/2021 07:00	13.6	3.9	2.0	10.7	2.4
09/03/2021 08:00	8.5	1.6	1.7	9.4	2.0
09/03/2021 09:00	7.6	1.5	1.6	8.3	1.8
09/03/2021 10:00	11.1	1.5	1.6	8.8	2.0
09/03/2021 11:00	9.5	4.3	1.6	8.9	2.0
09/03/2021 12:00	9.7	1.6	1.6	8.9	2.0
09/03/2021 13:00	9.7	1.6	1.7	8.9	2.0
09/03/2021 14:00	7.7	1.8	1.6	8.5	1.8
09/03/2021 15:00	14.4	6.4	2.1	11.2	2.5
09/03/2021 16:00	14.8	4.8	2.1	11.6	2.5
09/03/2021 17:00	15.2	4.2	2.2	12.0	2.6
09/03/2021 18:00	15.2	4.2	2.2	12.0	2.6
09/03/2021 19:00	14.6	4.1	2.1	11.4	2.5
09/03/2021 20:00	11.8	1.9	1.7	9.3	2.0
09/03/2021 21:00	12.4	2.3	1.8	9.7	2.1
09/03/2021 22:00	14.0	8.2	2.0	11.0	2.4
09/03/2021 23:00	15.6	7.8	2.0	10.7	2.4
Average/Sum#:	287.6 #	94.2 #	44.1 #	240.2 #	52.7 #
Minimum:	7.6	1.5	1.6	8.3	1.8
Maximum:	15.6	14.1	2.2	12.0	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
09/04/2021 00:00	11.4	2.2	1.7	8.9	2.0
09/04/2021 01:00	11.5	2.5	1.7	9.1	2.0
09/04/2021 02:00	14.0	9.1	2.0	11.0	2.4
09/04/2021 03:00	10.2	24.6	0.7	3.5	0.8
09/04/2021 04:00	0.0	0.0	0.0	0.0	0.0
09/04/2021 05:00	0.0	0.0	0.0	0.0	0.0
09/04/2021 06:00	0.0	0.0	0.0	0.0	0.0
09/04/2021 07:00	0.0	0.0	0.0	0.0	0.0
09/04/2021 08:00	0.0	0.0	0.0	0.0	0.0
09/04/2021 09:00	0.9	8.5	0.1	0.2	0.0
09/04/2021 10:00	31.8	82.4	0.6	2.2	0.5
09/04/2021 11:00	1.4	1.4	1.0	3.5	0.8
09/04/2021 12:00	2.8	1.3	1.0	3.5	0.8
09/04/2021 13:00	25.3	18.8	1.2	4.7	1.1
09/04/2021 14:00	44.5	40.5	1.3	7.1	1.6
09/04/2021 15:00	10.3	2.0	1.7	9.4	2.0
09/04/2021 16:00	11.2	2.1	1.6	8.8	1.9
09/04/2021 17:00	14.6	5.7	2.1	11.6	2.5
09/04/2021 18:00	15.4	4.1	2.2	12.1	2.7
09/04/2021 19:00	15.5	3.8	2.2	12.2	2.7
09/04/2021 20:00	15.1	4.2	2.1	11.8	2.6
09/04/2021 21:00	14.8	4.5	2.1	11.6	2.5
09/04/2021 22:00	14.5	5.2	2.1	11.4	2.5
09/04/2021 23:00	14.4	5.5	2.1	11.4	2.5
Average/Sum#:	279.6 #	228.4 #	29.5 #	154.0 #	33.9 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	44.5	82.4	2.2	12.2	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
09/05/2021 00:00	13.6	6.4	2.0	10.8	2.4
09/05/2021 01:00	11.5	2.2	1.7	9.1	2.0
09/05/2021 02:00	11.5	2.2	1.7	9.1	2.0
09/05/2021 03:00	14.0	6.9	2.0	11.0	2.4
09/05/2021 04:00	15.5	7.5	2.0	10.6	2.3
09/05/2021 05:00	11.4	2.2	1.7	8.9	2.0
09/05/2021 06:00	11.3	2.2	1.7	8.9	2.0
09/05/2021 07:00	11.1	2.1	1.6	8.7	1.9
09/05/2021 08:00	11.3	2.2	1.7	8.9	2.0
09/05/2021 09:00	11.3	2.2	1.6	8.9	2.0
09/05/2021 10:00	11.7	1.9	1.7	9.3	2.0
09/05/2021 11:00	12.0	2.0	1.7	9.4	2.0
09/05/2021 12:00	10.1	1.9	1.7	9.3	2.0
09/05/2021 13:00	10.3	2.0	1.7	9.4	2.0
09/05/2021 14:00	13.9	6.0	2.0	11.0	2.4
09/05/2021 15:00	15.0	4.5	2.1	11.8	2.6
09/05/2021 16:00	15.2	3.8	2.2	12.0	2.6
09/05/2021 17:00	15.4	3.5	2.2	12.2	2.7
09/05/2021 18:00	15.4	3.8	2.2	12.0	2.7
09/05/2021 19:00	15.5	3.5	2.3	12.2	2.7
09/05/2021 20:00	15.1	4.2	2.1	11.8	2.6
09/05/2021 21:00	14.8	4.5	2.1	11.6	2.5
09/05/2021 22:00	14.7	4.9	2.1	11.6	2.5
09/05/2021 23:00	14.2	5.1	2.0	11.1	2.4
Average/Sum#:	315.8 #	87.7 #	45.8 #	249.6 #	54.7 #
Minimum:	10.1	1.9	1.6	8.7	1.9
Maximum:	15.5	7.5	2.3	12.2	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
09/06/2021 00:00	11.4	2.2	1.7	8.9	2.0
09/06/2021 01:00	9.7	2.1	1.6	8.9	2.0
09/06/2021 02:00	13.7	6.1	2.0	10.8	2.4
09/06/2021 03:00	13.5	4.5	2.0	10.6	2.4
09/06/2021 04:00	7.9	1.5	1.6	8.7	1.9
09/06/2021 05:00	11.6	2.2	1.7	9.1	2.0
09/06/2021 06:00	11.3	2.2	1.6	8.9	2.0
09/06/2021 07:00	11.3	1.9	1.6	8.9	2.0
09/06/2021 08:00	10.1	1.6	1.7	9.3	2.0
09/06/2021 09:00	7.7	1.5	1.6	8.5	1.8
09/06/2021 10:00	10.0	1.3	1.7	9.3	2.0
09/06/2021 11:00	10.0	1.6	1.7	9.1	2.0
09/06/2021 12:00	14.6	6.2	2.1	11.5	2.5
09/06/2021 13:00	15.3	4.1	2.2	12.0	2.6
09/06/2021 14:00	15.1	3.8	2.1	11.9	2.6
09/06/2021 15:00	15.3	3.8	2.2	11.9	2.6
09/06/2021 16:00	15.3	3.5	2.2	12.0	2.6
09/06/2021 17:00	15.3	3.5	2.2	12.1	2.6
09/06/2021 18:00	15.4	3.4	2.3	12.1	2.6
09/06/2021 19:00	15.5	3.5	2.3	12.1	2.7
09/06/2021 20:00	15.5	3.5	2.3	12.2	2.7
09/06/2021 21:00	15.3	3.5	2.2	12.1	2.6
09/06/2021 22:00	14.9	4.1	2.1	11.7	2.6
09/06/2021 23:00	14.2	4.8	2.1	11.2	2.4
Average/Sum#:	309.9 #	76.4 #	46.8 #	253.8 #	55.6 #
Minimum:	7.7	1.3	1.6	8.5	1.8
Maximum:	15.5	6.2	2.3	12.2	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
09/07/2021 00:00	10.1	1.9	1.7	9.3	2.0
09/07/2021 01:00	10.0	1.9	1.7	9.1	2.0
09/07/2021 02:00	14.1	5.6	2.0	11.1	2.4
09/07/2021 03:00	15.5	4.8	2.0	10.7	2.4
09/07/2021 04:00	11.9	2.3	1.7	9.3	2.0
09/07/2021 05:00	12.4	2.7	1.8	9.8	2.2
09/07/2021 06:00	14.0	9.1	2.0	11.0	2.4
09/07/2021 07:00	13.8	6.1	2.0	10.8	2.4
09/07/2021 08:00	11.8	1.9	1.7	9.3	2.0
09/07/2021 09:00	12.1	2.0	1.7	9.5	2.1
09/07/2021 10:00	13.9	6.2	2.0	11.0	2.4
09/07/2021 11:00	15.2	3.8	2.2	11.9	2.6
09/07/2021 12:00	15.0	3.8	2.1	11.8	2.6
09/07/2021 13:00	14.8	3.8	2.1	11.8	2.6
09/07/2021 14:00	14.8	3.8	2.1	11.6	2.5
09/07/2021 15:00	14.8	3.4	2.1	11.8	2.6
09/07/2021 16:00	15.0	3.4	2.1	11.8	2.6
09/07/2021 17:00	15.0	3.5	2.1	11.8	2.6
09/07/2021 18:00	14.8	3.8	2.1	11.6	2.5
09/07/2021 19:00	14.6	4.2	2.1	11.6	2.5
09/07/2021 20:00	14.7	4.5	2.1	11.6	2.5
09/07/2021 21:00	15.4	3.9	2.2	12.0	2.7
09/07/2021 22:00	15.6	3.5	2.3	12.2	2.7
09/07/2021 23:00	15.6	3.5	2.3	12.2	2.7
Average/Sum#:	334.9 #	93.4 #	48.2 #	264.6 #	58.0 #
Minimum:	10.0	1.9	1.7	9.1	2.0
Maximum:	15.6	9.1	2.3	12.2	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
09/08/2021 00:00	15.4	3.5	2.2	12.2	2.7
09/08/2021 01:00	15.0	3.8	2.1	11.8	2.6
09/08/2021 02:00	14.6	4.5	2.1	11.5	2.5
09/08/2021 03:00	14.6	4.9	2.1	11.6	2.5
09/08/2021 04:00	15.4	3.9	2.2	12.0	2.7
09/08/2021 05:00	13.3	3.9	2.3	12.2	2.7
09/08/2021 06:00	13.1	3.9	2.2	12.0	2.6
09/08/2021 07:00	14.0	5.1	2.0	11.0	2.4
09/08/2021 08:00	11.8	1.9	1.7	9.3	2.0
09/08/2021 09:00	11.9	1.9	1.7	9.4	2.0
09/08/2021 10:00	14.2	5.8	2.1	11.1	2.5
09/08/2021 11:00	15.0	4.1	2.1	11.8	2.6
09/08/2021 12:00	14.9	4.1	2.1	11.7	2.6
09/08/2021 13:00	14.9	3.7	2.1	11.7	2.6
09/08/2021 14:00	14.9	3.7	2.1	11.7	2.6
09/08/2021 15:00	14.9	3.4	2.1	11.7	2.6
09/08/2021 16:00	15.0	3.4	2.1	11.8	2.6
09/08/2021 17:00	15.1	3.4	2.1	11.9	2.6
09/08/2021 18:00	15.1	3.4	2.1	11.9	2.6
09/08/2021 19:00	15.3	3.4	2.2	12.1	2.6
09/08/2021 20:00	15.2	3.5	2.1	11.9	2.6
09/08/2021 21:00	14.9	3.8	2.1	11.7	2.6
09/08/2021 22:00	14.7	4.1	2.1	11.6	2.5
09/08/2021 23:00	15.2	3.8	2.1	11.9	2.6
Average/Sum#:	348.4 #	90.9 #	50.1 #	277.5 #	60.9 #
Minimum:	11.8	1.9	1.7	9.3	2.0
Maximum:	15.4	5.8	2.3	12.2	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
09/09/2021 00:00	15.3	3.4	2.2	12.1	2.6
09/09/2021 01:00	15.4	3.5	2.2	12.1	2.6
09/09/2021 02:00	15.4	3.5	2.3	12.1	2.6
09/09/2021 03:00	15.4	3.5	2.3	12.1	2.6
09/09/2021 04:00	15.4	3.5	2.3	12.1	2.6
09/09/2021 05:00	15.4	3.5	2.3	12.1	2.6
09/09/2021 06:00	15.3	3.5	2.2	12.1	2.6
09/09/2021 07:00	15.1	3.8	2.1	11.9	2.6
09/09/2021 08:00	14.9	3.8	2.1	11.8	2.6
09/09/2021 09:00	14.9	3.8	2.1	11.8	2.6
09/09/2021 10:00	14.9	3.8	2.1	11.8	2.6
09/09/2021 11:00	14.9	3.7	2.1	11.7	2.6
09/09/2021 12:00	14.7	3.4	2.1	11.6	2.5
09/09/2021 13:00	14.9	3.4	2.1	11.7	2.6
09/09/2021 14:00	14.7	3.4	2.1	11.6	2.5
09/09/2021 15:00	14.7	3.7	2.1	11.5	2.5
09/09/2021 16:00	14.8	3.4	2.1	11.7	2.6
09/09/2021 17:00	14.9	3.4	2.1	11.7	2.6
09/09/2021 18:00	15.1	3.4	2.1	11.9	2.6
09/09/2021 19:00	15.1	3.4	2.1	11.9	2.6
09/09/2021 20:00	15.3	3.4	2.2	11.9	2.6
09/09/2021 21:00	15.3	3.4	2.2	12.1	2.6
09/09/2021 22:00	15.1	3.4	2.1	11.9	2.6
09/09/2021 23:00	15.2	3.8	2.1	11.9	2.6
Average/Sum#:	362.1 #	84.8 #	51.7 #	285.1 #	62.1 #
Minimum:	14.7	3.4	2.1	11.5	2.5
Maximum:	15.4	3.8	2.3	12.1	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
09/10/2021 00:00	14.6	3.7	2.1	11.5	2.5
09/10/2021 01:00	11.0	1.8	1.6	8.7	1.9
09/10/2021 02:00	12.2	1.9	1.7	9.5	2.1
09/10/2021 03:00	14.3	5.9	2.1	11.2	2.4
09/10/2021 04:00	15.2	3.8	2.1	11.9	2.6
09/10/2021 05:00	14.9	3.8	2.1	11.7	2.6
09/10/2021 06:00	15.3	3.5	2.2	12.0	2.6
09/10/2021 07:00	11.5	2.4	1.7	8.9	2.0
09/10/2021 08:00	10.6	1.7	1.5	8.3	1.8
09/10/2021 09:00	11.3	1.2	1.7	8.9	2.0
09/10/2021 10:00	11.2	1.5	1.6	8.8	1.9
09/10/2021 11:00	14.1	6.0	2.0	11.2	2.4
09/10/2021 12:00	14.0	4.4	2.0	11.0	2.4
09/10/2021 13:00	11.1	1.5	1.6	8.7	1.9
09/10/2021 14:00	10.3	1.6	1.7	9.4	2.0
09/10/2021 15:00	14.3	5.7	2.1	11.2	2.5
09/10/2021 16:00	14.8	4.1	2.1	11.6	2.5
09/10/2021 17:00	15.1	3.8	2.1	11.8	2.6
09/10/2021 18:00	15.2	3.4	2.2	12.0	2.6
09/10/2021 19:00	15.2	3.5	2.2	12.0	2.6
09/10/2021 20:00	15.2	3.8	2.2	12.0	2.6
09/10/2021 21:00	15.2	3.8	2.2	12.0	2.6
09/10/2021 22:00	14.8	4.1	2.1	11.6	2.5
09/10/2021 23:00	14.4	4.5	2.1	11.2	2.5
Average/Sum#:	325.8 #	81.4 #	47.0 #	257.1 #	56.1 #
Minimum:	10.3	1.2	1.5	8.3	1.8
Maximum:	15.3	6.0	2.2	12.0	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
09/11/2021 00:00	13.5	6.4	2.0	10.6	2.3
09/11/2021 01:00	11.8	1.9	1.7	9.3	2.0
09/11/2021 02:00	11.7	1.9	1.7	9.2	2.0
09/11/2021 03:00	9.3	2.7	1.6	8.6	1.8
09/11/2021 04:00	14.0	7.7	2.0	11.0	2.4
09/11/2021 05:00	13.5	7.1	2.0	10.6	2.3
09/11/2021 06:00	11.5	1.9	1.7	9.1	2.0
09/11/2021 07:00	11.3	2.1	1.7	8.9	2.0
09/11/2021 08:00	9.1	1.7	1.5	8.3	1.8
09/11/2021 09:00	11.1	1.5	1.6	8.7	1.9
09/11/2021 10:00	10.1	1.3	1.7	9.3	2.0
09/11/2021 11:00	11.7	1.9	1.7	9.1	2.0
09/11/2021 12:00	14.3	5.1	2.1	11.2	2.5
09/11/2021 13:00	14.2	4.4	2.1	11.2	2.4
09/11/2021 14:00	11.7	1.6	1.7	9.2	2.0
09/11/2021 15:00	12.0	1.6	1.7	9.4	2.0
09/11/2021 16:00	14.3	5.8	2.1	11.2	2.5
09/11/2021 17:00	15.4	3.5	2.2	12.2	2.7
09/11/2021 18:00	15.2	3.5	2.2	12.0	2.6
09/11/2021 19:00	14.8	3.8	2.1	11.7	2.6
09/11/2021 20:00	15.2	3.8	2.2	12.0	2.6
09/11/2021 21:00	15.3	3.5	2.2	12.0	2.6
09/11/2021 22:00	15.0	3.9	2.1	11.8	2.6
09/11/2021 23:00	15.1	3.8	2.1	11.9	2.6
Average/Sum#:	311.1 #	82.4 #	45.7 #	248.5 #	54.2 #
Minimum:	9.1	1.3	1.5	8.3	1.8
Maximum:	15.4	7.7	2.2	12.2	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
09/12/2021 00:00	14.2	4.8	2.0	11.1	2.4
09/12/2021 01:00	10.1	1.6	1.7	9.3	2.0
09/12/2021 02:00	9.8	1.3	1.7	9.1	2.0
09/12/2021 03:00	8.2	5.2	1.7	9.1	2.0
09/12/2021 04:00	16.0	7.5	2.0	11.0	2.4
09/12/2021 05:00	15.5	7.5	2.0	10.6	2.3
09/12/2021 06:00	9.3	3.7	1.6	8.5	1.8
09/12/2021 07:00	11.1	1.8	1.6	8.7	1.9
09/12/2021 08:00	8.1	1.6	1.4	7.4	1.6
09/12/2021 09:00	7.7	1.2	1.3	7.0	1.6
09/12/2021 10:00	9.9	1.3	1.7	9.1	2.0
09/12/2021 11:00	12.0	1.9	1.7	9.5	2.0
09/12/2021 12:00	14.3	6.4	2.1	11.2	2.5
09/12/2021 13:00	14.5	4.0	2.1	11.4	2.5
09/12/2021 14:00	11.5	1.6	1.7	9.1	2.0
09/12/2021 15:00	11.5	2.2	1.7	9.0	2.0
09/12/2021 16:00	14.4	5.4	2.1	11.4	2.5
09/12/2021 17:00	15.4	3.8	2.2	12.0	2.7
09/12/2021 18:00	15.2	3.8	2.2	12.0	2.6
09/12/2021 19:00	14.9	4.1	2.1	11.8	2.6
09/12/2021 20:00	14.7	4.5	2.1	11.6	2.5
09/12/2021 21:00	14.6	4.5	2.1	11.4	2.5
09/12/2021 22:00	14.4	4.5	2.1	11.4	2.5
09/12/2021 23:00	14.4	4.5	2.1	11.4	2.5
Average/Sum#:	301.7 #	88.7 #	45.0 #	244.1 #	53.4 #
Minimum:	7.7	1.2	1.3	7.0	1.6
Maximum:	16.0	7.5	2.2	12.0	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
09/13/2021 00:00	13.5	5.4	2.0	10.6	2.3
09/13/2021 01:00	11.1	1.8	1.6	8.7	1.9
09/13/2021 02:00	11.0	2.1	1.6	8.7	1.9
09/13/2021 03:00	11.5	1.9	1.7	9.1	2.0
09/13/2021 04:00	6.7	1.8	1.3	7.4	1.6
09/13/2021 05:00	8.4	1.6	1.7	9.2	2.0
09/13/2021 06:00	10.8	6.2	1.8	9.9	2.2
09/13/2021 07:00	12.9	5.3	1.8	10.2	2.2
09/13/2021 08:00	9.2	2.0	1.6	8.5	1.8
09/13/2021 09:00	13.7	6.7	2.0	10.8	2.4
09/13/2021 10:00	13.7	5.7	2.0	10.8	2.4
09/13/2021 11:00	10.1	2.0	1.7	9.3	2.0
09/13/2021 12:00	10.0	1.9	1.7	9.2	2.0
09/13/2021 13:00	14.1	6.7	2.0	11.1	2.4
09/13/2021 14:00	15.2	3.8	2.2	12.0	2.6
09/13/2021 15:00	15.1	3.5	2.2	11.8	2.6
09/13/2021 16:00	15.1	3.4	2.1	11.8	2.6
09/13/2021 17:00	15.3	3.4	2.2	12.0	2.6
09/13/2021 18:00	15.3	3.4	2.2	12.0	2.6
09/13/2021 19:00	15.3	3.4	2.2	12.0	2.6
09/13/2021 20:00	15.2	3.8	2.2	12.0	2.6
09/13/2021 21:00	14.8	4.1	2.1	11.6	2.5
09/13/2021 22:00	14.4	4.5	2.1	11.4	2.5
09/13/2021 23:00	13.7	5.1	2.0	10.8	2.4
Average/Sum#:	306.1 #	89.5 #	46.0 #	250.9 #	54.7 #
Minimum:	6.7	1.6	1.3	7.4	1.6
Maximum:	15.3	6.7	2.2	12.0	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
09/14/2021 00:00	13.5	5.8	2.0	10.6	2.3
09/14/2021 01:00	11.0	2.1	1.6	8.6	1.9
09/14/2021 02:00	10.8	2.1	1.6	8.5	1.8
09/14/2021 03:00	10.8	2.1	1.6	8.5	1.8
09/14/2021 04:00	10.4	2.6	1.5	8.2	1.8
09/14/2021 05:00	13.9	9.0	2.0	11.0	2.4
09/14/2021 06:00	13.9	6.7	2.0	11.0	2.4
09/14/2021 07:00	11.5	3.1	1.7	9.1	2.0
09/14/2021 08:00	10.5	2.3	1.5	8.3	1.8
09/14/2021 09:00	10.3	2.2	1.4	8.1	1.8
09/14/2021 10:00	11.5	1.9	1.7	9.1	2.0
09/14/2021 11:00	10.1	1.9	1.7	9.3	2.0
09/14/2021 12:00	7.7	1.8	1.6	8.5	1.8
09/14/2021 13:00	13.9	8.3	2.0	11.0	2.4
09/14/2021 14:00	14.4	4.7	2.1	11.4	2.5
09/14/2021 15:00	11.7	1.9	1.7	9.2	2.0
09/14/2021 16:00	9.7	1.8	1.6	8.9	2.0
09/14/2021 17:00	14.4	6.0	2.1	11.4	2.5
09/14/2021 18:00	15.1	4.0	2.1	11.8	2.6
09/14/2021 19:00	14.1	4.4	2.0	11.0	2.4
09/14/2021 20:00	11.8	1.9	1.7	9.3	2.0
09/14/2021 21:00	12.1	2.0	1.7	9.5	2.1
09/14/2021 22:00	14.1	6.8	2.0	11.1	2.4
09/14/2021 23:00	13.5	5.7	2.0	10.6	2.3
Average/Sum#:	290.7 #	91.1 #	42.9 #	234.0 #	51.0 #
Minimum:	7.7	1.8	1.4	8.1	1.8
Maximum:	15.1	9.0	2.1	11.8	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
09/15/2021 00:00	10.8	2.1	1.6	8.5	1.8
09/15/2021 01:00	9.4	2.4	1.6	8.6	1.9
09/15/2021 02:00	14.0	7.4	2.0	11.0	2.4
09/15/2021 03:00	13.7	7.4	2.0	10.8	2.4
09/15/2021 04:00	11.7	2.5	1.7	9.2	2.0
09/15/2021 05:00	7.9	2.1	1.6	8.7	1.9
09/15/2021 06:00	13.8	9.1	2.0	10.9	2.4
09/15/2021 07:00	13.6	7.7	2.0	10.7	2.4
09/15/2021 08:00	8.8	2.2	1.4	8.1	1.8
09/15/2021 09:00	8.5	1.6	1.4	7.8	1.7
09/15/2021 10:00	10.8	1.5	1.6	8.5	1.8
09/15/2021 11:00	11.2	1.8	1.6	8.7	1.9
09/15/2021 12:00	7.6	2.0	1.6	8.4	1.8
09/15/2021 13:00	14.2	6.4	2.1	11.2	2.4
09/15/2021 14:00	14.4	5.0	2.1	11.3	2.5
09/15/2021 15:00	10.9	2.1	1.6	8.5	1.8
09/15/2021 16:00	9.4	2.7	1.6	8.7	1.9
09/15/2021 17:00	14.2	5.3	2.1	11.2	2.4
09/15/2021 18:00	14.4	4.4	2.1	11.3	2.5
09/15/2021 19:00	13.8	5.0	2.0	10.8	2.4
09/15/2021 20:00	11.8	2.8	1.7	9.3	2.0
09/15/2021 21:00	9.7	2.2	1.6	8.9	2.0
09/15/2021 22:00	13.5	10.0	2.0	10.6	2.3
09/15/2021 23:00	13.5	9.7	2.0	10.6	2.3
Average/Sum#:	281.6 #	105.4 #	43.0 #	232.3 #	50.7 #
Minimum:	7.6	1.5	1.4	7.8	1.7
Maximum:	14.4	10.0	2.1	11.3	2.5
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
09/16/2021 00:00	11.9	6.4	1.7	9.4	2.0
09/16/2021 01:00	6.4	11.0	1.2	5.1	1.1
09/16/2021 02:00	3.6	2.0	1.2	4.4	1.1
09/16/2021 03:00	3.6	2.0	1.2	4.5	1.1
09/16/2021 04:00	2.8	2.2	1.0	3.5	0.8
09/16/2021 05:00	4.0	2.3	0.9	3.3	0.8
09/16/2021 06:00	2.8	2.1	1.0	3.5	0.8
09/16/2021 07:00	4.1	2.3	1.0	3.4	0.8
09/16/2021 08:00	4.1	2.1	1.0	3.4	0.8
09/16/2021 09:00	4.1	1.8	1.0	3.4	0.8
09/16/2021 10:00	4.1	1.6	1.0	3.4	0.8
09/16/2021 11:00	4.1	1.6	1.0	3.4	0.8
09/16/2021 12:00	6.7	5.3	1.1	4.1	1.0
09/16/2021 13:00	66.6	55.5	1.3	6.3	1.4
09/16/2021 14:00	10.1	1.9	1.7	9.3	2.0
09/16/2021 15:00	9.8	1.9	1.7	8.9	2.0
09/16/2021 16:00	7.6	2.3	1.6	8.4	1.8
09/16/2021 17:00	12.6	6.7	2.1	11.5	2.5
09/16/2021 18:00	14.7	4.4	2.1	11.6	2.5
09/16/2021 19:00	13.8	4.8	2.0	10.8	2.4
09/16/2021 20:00	11.9	2.8	1.7	9.4	2.0
09/16/2021 21:00	11.7	2.2	1.7	9.1	2.0
09/16/2021 22:00	14.2	5.8	2.0	11.1	2.4
09/16/2021 23:00	13.6	5.8	2.0	10.7	2.4
Average/Sum#:	248.9 #	136.8 #	34.2 #	161.9 #	36.1 #
Minimum:	2.8	1.6	0.9	3.3	0.8
Maximum:	66.6	55.5	2.1	11.6	2.5
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
09/17/2021 00:00	13.5	7.4	2.0	10.6	2.3
09/17/2021 01:00	8.9	2.8	1.5	8.2	1.8
09/17/2021 02:00	4.1	6.6	1.1	4.0	0.9
09/17/2021 03:00	3.1	2.0	1.1	3.8	0.9
09/17/2021 04:00	3.0	1.7	1.1	3.8	0.9
09/17/2021 05:00	3.1	2.0	1.1	3.9	0.9
09/17/2021 06:00	3.0	2.0	1.0	3.7	0.9
09/17/2021 07:00	4.3	1.9	1.0	3.6	0.9
09/17/2021 08:00	4.1	2.0	0.9	3.4	0.8
09/17/2021 09:00	4.1	1.8	1.0	3.4	0.8
09/17/2021 10:00	4.1	1.6	1.0	3.4	0.8
09/17/2021 11:00	4.1	1.6	1.0	3.4	0.8
09/17/2021 12:00	4.1	1.6	1.0	3.4	0.8
09/17/2021 13:00	20.5	16.0	1.1	4.4	1.1
09/17/2021 14:00	43.0	45.4	1.2	6.0	1.4
09/17/2021 15:00	7.4	1.7	1.5	8.2	1.8
09/17/2021 16:00	7.9	2.1	1.6	8.7	1.9
09/17/2021 17:00	14.4	5.3	2.1	11.4	2.5
09/17/2021 18:00	19.2	4.1	2.1	11.8	2.6
09/17/2021 19:00	15.9	4.5	2.0	11.0	2.4
09/17/2021 20:00	13.5	6.7	2.0	10.6	2.3
09/17/2021 21:00	13.6	6.7	2.0	10.7	2.4
09/17/2021 22:00	13.6	7.0	2.0	10.7	2.4
09/17/2021 23:00	7.4	3.4	1.5	8.2	1.8
Average/Sum#:	239.9 #	137.9 #	33.9 #	160.3 #	36.1 #
Minimum:	3.0	1.6	0.9	3.4	0.8
Maximum:	43.0	45.4	2.1	11.8	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
09/18/2021 00:00	4.9	6.4	1.0	3.5	0.8
09/18/2021 01:00	4.0	2.1	0.9	3.4	0.8
09/18/2021 02:00	4.1	2.1	0.9	3.4	0.8
09/18/2021 03:00	4.1	2.1	0.9	3.4	0.8
09/18/2021 04:00	4.3	1.9	1.0	3.6	0.9
09/18/2021 05:00	4.1	2.1	1.0	3.5	0.8
09/18/2021 06:00	4.2	2.1	1.0	3.5	0.8
09/18/2021 07:00	4.1	2.1	1.0	3.4	0.8
09/18/2021 08:00	4.1	2.1	1.0	3.4	0.8
09/18/2021 09:00	4.1	1.8	1.0	3.4	0.8
09/18/2021 10:00	4.1	1.8	1.0	3.4	0.8
09/18/2021 11:00	4.1	1.6	1.0	3.4	0.8
09/18/2021 12:00	4.1	1.6	1.0	3.4	0.8
09/18/2021 13:00	4.1	1.3	1.0	3.4	0.8
09/18/2021 14:00	4.1	1.6	1.0	3.4	0.8
09/18/2021 15:00	4.1	1.6	1.0	3.4	0.8
09/18/2021 16:00	4.2	1.6	1.0	3.5	0.8
09/18/2021 17:00	4.2	1.6	1.0	3.5	0.8
09/18/2021 18:00	4.2	1.6	1.0	3.5	0.8
09/18/2021 19:00	4.1	1.6	1.0	3.4	0.8
09/18/2021 20:00	3.1	1.5	1.1	3.9	0.9
09/18/2021 21:00	3.0	1.7	1.0	3.7	0.9
09/18/2021 22:00	3.1	1.7	1.1	3.8	0.9
09/18/2021 23:00	2.7	1.8	0.9	3.4	0.8
Average/Sum#:	95.2 #	47.4 #	23.8 #	83.6 #	19.6 #
Minimum:	2.7	1.3	0.9	3.4	0.8
Maximum:	4.9	6.4	1.1	3.9	0.9
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
09/19/2021 00:00	4.1	1.8	1.0	3.4	0.8
09/19/2021 01:00	4.1	2.0	0.9	3.4	0.8
09/19/2021 02:00	4.1	2.0	0.9	3.4	0.8
09/19/2021 03:00	4.1	2.1	1.0	3.4	0.8
09/19/2021 04:00	4.2	1.9	1.0	3.5	0.8
09/19/2021 05:00	4.3	2.1	1.0	3.6	0.9
09/19/2021 06:00	4.1	2.1	1.0	3.4	0.8
09/19/2021 07:00	4.1	2.1	1.0	3.4	0.8
09/19/2021 08:00	4.1	2.0	0.9	3.4	0.8
09/19/2021 09:00	4.1	1.8	1.0	3.4	0.8
09/19/2021 10:00	4.2	1.6	1.0	3.5	0.8
09/19/2021 11:00	4.1	1.3	1.0	3.4	0.8
09/19/2021 12:00	4.1	1.3	1.0	3.4	0.8
09/19/2021 13:00	4.1	1.3	1.0	3.4	0.8
09/19/2021 14:00	2.8	1.3	1.0	3.5	0.8
09/19/2021 15:00	2.7	1.3	1.0	3.4	0.8
09/19/2021 16:00	4.7	1.5	1.1	3.9	0.9
09/19/2021 17:00	3.5	1.6	1.2	4.3	1.0
09/19/2021 18:00	3.1	1.5	1.1	3.9	0.9
09/19/2021 19:00	2.8	1.4	1.0	3.6	0.9
09/19/2021 20:00	3.1	1.5	1.1	3.9	0.9
09/19/2021 21:00	2.8	1.3	1.0	3.5	0.8
09/19/2021 22:00	2.7	1.3	1.0	3.4	0.8
09/19/2021 23:00	2.7	1.6	1.0	3.4	0.8
Average/Sum#:	88.7 #	39.7 #	24.2 #	84.8 #	19.9 #
Minimum:	2.7	1.3	0.9	3.4	0.8
Maximum:	4.7	2.1	1.2	4.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
09/20/2021 00:00	2.7	1.6	1.0	3.4	0.8
09/20/2021 01:00	13.8	42.8	1.1	4.0	0.9
09/20/2021 02:00	67.1	46.9	1.3	5.7	1.3
09/20/2021 03:00	12.9	2.0	1.3	7.2	1.6
09/20/2021 04:00	8.7	1.4	1.4	8.0	1.8
09/20/2021 05:00	13.1	14.5	1.9	10.3	2.2
09/20/2021 06:00	13.8	9.5	2.0	10.9	2.4
09/20/2021 07:00	9.0	3.4	1.5	8.3	1.8
09/20/2021 08:00	6.5	1.3	1.3	7.2	1.6
09/20/2021 09:00	6.5	1.3	1.3	7.2	1.6
09/20/2021 10:00	6.5	1.0	1.3	7.2	1.6
09/20/2021 11:00	7.9	1.5	1.6	8.7	1.9
09/20/2021 12:00	13.9	6.8	2.0	11.0	2.4
09/20/2021 13:00	14.0	5.2	2.0	11.0	2.4
09/20/2021 14:00	9.4	2.1	1.6	8.7	1.9
09/20/2021 15:00	9.2	1.5	1.6	8.5	1.8
09/20/2021 16:00	14.4	7.2	2.1	11.4	2.5
09/20/2021 17:00	15.6	3.5	2.3	12.2	2.7
09/20/2021 18:00	15.5	3.5	2.3	12.2	2.7
09/20/2021 19:00	15.3	3.5	2.2	12.0	2.6
09/20/2021 20:00	15.0	3.9	2.1	11.8	2.6
09/20/2021 21:00	14.6	4.2	2.1	11.6	2.5
09/20/2021 22:00	15.7	6.2	2.0	10.8	2.4
09/20/2021 23:00	13.4	8.1	2.0	10.6	2.3
Average/Sum#:	334.5 #	182.9 #	41.3 #	219.9 #	48.3 #
Minimum:	2.7	1.0	1.0	3.4	0.8
Maximum:	67.1	46.9	2.3	12.2	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
09/21/2021 00:00	11.7	1.9	1.7	9.3	2.0
09/21/2021 01:00	9.5	2.4	1.6	8.7	1.9
09/21/2021 02:00	13.5	17.1	2.0	10.6	2.3
09/21/2021 03:00	13.5	12.1	2.0	10.6	2.3
09/21/2021 04:00	13.5	13.2	2.0	10.6	2.3
09/21/2021 05:00	13.6	11.5	2.0	10.6	2.3
09/21/2021 06:00	14.5	5.3	2.1	11.4	2.5
09/21/2021 07:00	13.4	10.8	2.0	10.6	2.3
09/21/2021 08:00	8.9	2.0	1.4	8.1	1.8
09/21/2021 09:00	9.2	1.5	1.6	8.5	1.8
09/21/2021 10:00	10.0	1.3	1.7	9.2	2.0
09/21/2021 11:00	8.2	1.6	1.7	9.0	2.0
09/21/2021 12:00	14.2	7.4	2.0	11.2	2.4
09/21/2021 13:00	15.1	4.1	2.1	11.9	2.6
09/21/2021 14:00	15.1	3.8	2.1	11.9	2.6
09/21/2021 15:00	15.1	3.8	2.1	11.9	2.6
09/21/2021 16:00	15.3	3.5	2.2	12.0	2.6
09/21/2021 17:00	15.3	3.5	2.2	12.1	2.6
09/21/2021 18:00	15.5	3.5	2.3	12.1	2.7
09/21/2021 19:00	15.3	3.5	2.2	11.9	2.6
09/21/2021 20:00	15.3	3.5	2.2	12.0	2.6
09/21/2021 21:00	15.0	3.8	2.1	11.8	2.6
09/21/2021 22:00	14.7	4.2	2.1	11.6	2.5
09/21/2021 23:00	14.2	4.8	2.0	11.2	2.4
Average/Sum#:	319.6 #	130.1 #	47.4 #	258.8 #	56.3 #
Minimum:	8.2	1.3	1.4	8.1	1.8
Maximum:	15.5	17.1	2.3	12.1	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
09/22/2021 00:00	11.3	2.5	1.7	8.9	2.0
09/22/2021 01:00	11.6	2.2	1.7	9.1	2.0
09/22/2021 02:00	13.5	17.9	2.0	10.6	2.3
09/22/2021 03:00	13.5	17.0	2.0	10.6	2.3
09/22/2021 04:00	14.2	9.6	2.0	11.2	2.4
09/22/2021 05:00	15.1	4.5	2.1	11.8	2.6
09/22/2021 06:00	14.5	4.8	2.1	11.4	2.5
09/22/2021 07:00	13.4	9.7	2.0	10.6	2.3
09/22/2021 08:00	11.5	2.2	1.7	9.0	2.0
09/22/2021 09:00	10.4	2.0	1.7	9.5	2.1
09/22/2021 10:00	13.5	6.8	2.0	10.6	2.3
09/22/2021 11:00	14.2	5.1	2.1	11.2	2.5
09/22/2021 12:00	11.3	1.9	1.6	8.9	2.0
09/22/2021 13:00	10.3	1.9	1.7	9.4	2.0
09/22/2021 14:00	14.4	5.7	2.1	11.4	2.5
09/22/2021 15:00	15.2	3.8	2.2	12.0	2.6
09/22/2021 16:00	15.4	3.2	2.2	12.1	2.7
09/22/2021 17:00	15.3	3.5	2.2	12.0	2.6
09/22/2021 18:00	15.3	3.5	2.2	12.1	2.6
09/22/2021 19:00	14.4	3.8	2.1	11.4	2.5
09/22/2021 20:00	9.9	1.9	1.7	9.1	2.0
09/22/2021 21:00	10.6	2.3	1.8	9.7	2.1
09/22/2021 22:00	14.0	6.8	2.0	11.0	2.4
09/22/2021 23:00	16.5	4.8	2.1	11.3	2.5
Average/Sum#:	319.3 #	127.4 #	47.0 #	254.9 #	55.8 #
Minimum:	9.9	1.9	1.6	8.9	2.0
Maximum:	16.5	17.9	2.2	12.1	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
09/23/2021 00:00	13.6	5.4	2.0	10.6	2.3
09/23/2021 01:00	9.4	2.1	1.6	8.6	1.9
09/23/2021 02:00	7.7	1.8	1.6	8.5	1.8
09/23/2021 03:00	8.2	1.6	1.7	9.0	2.0
09/23/2021 04:00	7.9	1.5	1.6	8.7	1.9
09/23/2021 05:00	14.2	6.1	2.0	11.2	2.4
09/23/2021 06:00	13.9	5.8	2.0	11.0	2.4
09/23/2021 07:00	10.0	1.9	1.7	9.1	2.0
09/23/2021 08:00	7.0	1.9	1.4	7.7	1.7
09/23/2021 09:00	10.5	2.0	1.7	9.7	2.1
09/23/2021 10:00	10.5	2.0	1.7	9.7	2.1
09/23/2021 11:00	10.5	2.0	1.8	9.7	2.1
09/23/2021 12:00	10.5	2.0	1.7	9.7	2.1
09/23/2021 13:00	10.5	2.0	1.7	9.6	2.1
09/23/2021 14:00	10.5	1.6	1.7	9.6	2.1
09/23/2021 15:00	10.5	1.6	1.7	9.6	2.1
09/23/2021 16:00	10.5	1.6	1.7	9.6	2.1
09/23/2021 17:00	10.5	2.0	1.7	9.7	2.1
09/23/2021 18:00	10.5	2.0	1.8	9.7	2.1
09/23/2021 19:00	10.5	2.3	1.8	9.7	2.1
09/23/2021 20:00	10.5	2.3	1.8	9.7	2.1
09/23/2021 21:00	10.5	2.0	1.8	9.7	2.1
09/23/2021 22:00	10.5	2.0	1.8	9.7	2.1
09/23/2021 23:00	10.5	2.0	1.8	9.7	2.1
Average/Sum#:	249.4 #	57.5 #	41.8 #	229.5 #	49.9 #
Minimum:	7.0	1.5	1.4	7.7	1.7
Maximum:	14.2	6.1	2.0	11.2	2.4
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
09/24/2021 00:00	10.5	2.0	1.8	9.7	2.1
09/24/2021 01:00	10.5	2.0	1.8	9.7	2.1
09/24/2021 02:00	10.6	2.0	1.8	9.7	2.1
09/24/2021 03:00	10.6	2.0	1.8	9.7	2.1
09/24/2021 04:00	10.6	2.0	1.8	9.7	2.1
09/24/2021 05:00	10.6	2.3	1.8	9.8	2.2
09/24/2021 06:00	10.6	2.3	1.8	9.8	2.2
09/24/2021 07:00	10.6	2.3	1.8	9.7	2.1
09/24/2021 08:00	10.6	2.0	1.8	9.7	2.1
09/24/2021 09:00	9.9	1.9	1.7	9.1	2.0
09/24/2021 10:00	7.6	1.8	1.6	8.4	1.8
09/24/2021 11:00	8.1	1.2	1.6	8.9	2.0
09/24/2021 12:00	8.0	1.2	1.6	8.8	1.9
09/24/2021 13:00	10.0	1.6	1.7	9.1	2.0
09/24/2021 14:00	10.1	1.6	1.7	9.3	2.0
09/24/2021 15:00	10.1	1.9	1.7	9.3	2.0
09/24/2021 16:00	10.0	1.9	1.7	9.2	2.0
09/24/2021 17:00	12.0	1.9	1.7	9.5	2.0
09/24/2021 18:00	9.9	1.9	1.7	9.1	2.0
09/24/2021 19:00	10.1	1.9	1.7	9.3	2.0
09/24/2021 20:00	11.5	2.2	1.7	8.9	2.0
09/24/2021 21:00	11.3	2.2	1.6	8.9	2.0
09/24/2021 22:00	11.5	2.2	1.7	9.1	2.0
09/24/2021 23:00	11.5	2.2	1.7	9.1	2.0
Average/Sum#:	246.8 #	46.5 #	41.3 #	223.5 #	48.8 #
Minimum:	7.6	1.2	1.6	8.4	1.8
Maximum:	12.0	2.3	1.8	9.8	2.2
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
09/25/2021 00:00	11.0	2.1	1.6	8.7	1.9
09/25/2021 01:00	11.5	2.2	1.7	9.0	2.0
09/25/2021 02:00	11.7	2.2	1.7	9.1	2.0
09/25/2021 03:00	11.7	2.2	1.7	9.1	2.0
09/25/2021 04:00	11.3	1.9	1.6	8.9	2.0
09/25/2021 05:00	9.5	1.8	1.6	8.8	1.9
09/25/2021 06:00	9.8	1.9	1.7	9.1	2.0
09/25/2021 07:00	9.9	1.9	1.7	9.1	2.0
09/25/2021 08:00	9.3	1.8	1.6	8.5	1.8
09/25/2021 09:00	8.1	1.8	1.3	7.4	1.6
09/25/2021 10:00	7.6	1.5	1.6	8.4	1.8
09/25/2021 11:00	8.3	1.6	1.7	9.1	2.0
09/25/2021 12:00	11.7	1.9	1.7	9.1	2.0
09/25/2021 13:00	11.6	1.9	1.7	9.1	2.0
09/25/2021 14:00	10.1	1.9	1.7	9.3	2.0
09/25/2021 15:00	10.1	1.9	1.7	9.3	2.0
09/25/2021 16:00	11.5	1.8	1.7	8.9	2.0
09/25/2021 17:00	7.9	2.1	1.3	7.3	1.6
09/25/2021 18:00	8.1	1.9	1.7	8.9	2.0
09/25/2021 19:00	10.1	1.9	1.7	9.3	2.0
09/25/2021 20:00	11.6	2.2	1.7	9.1	2.0
09/25/2021 21:00	7.8	2.4	1.6	8.5	1.8
09/25/2021 22:00	8.1	10.4	0.7	5.0	1.0
09/25/2021 23:00	3.9	0.0	0.4	3.9	0.8
Average/Sum#:	232.2 #	53.2 #	37.1 #	202.9 #	44.2 #
Minimum:	3.9	0.0	0.4	3.9	0.8
Maximum:	11.7	10.4	1.7	9.3	2.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
09/26/2021 00:00	3.9	0.0	0.4	3.9	0.8
09/26/2021 01:00	4.0	0.0	0.4	4.0	0.8
09/26/2021 02:00	4.0	0.0	0.4	4.0	0.8
09/26/2021 03:00	4.0	0.0	0.4	4.0	0.8
09/26/2021 04:00	4.0	0.0	0.4	4.0	0.8
09/26/2021 05:00	4.0	0.0	0.4	4.0	0.8
09/26/2021 06:00	4.1	0.0	0.4	4.1	0.8
09/26/2021 07:00	4.1	0.0	0.4	4.1	0.8
09/26/2021 08:00	4.0	0.0	0.4	4.0	0.8
09/26/2021 09:00	4.0	0.0	0.4	4.0	0.8
09/26/2021 10:00	4.1	0.0	0.4	4.1	0.8
09/26/2021 11:00	4.3	0.0	0.4	4.3	0.9
09/26/2021 12:00	4.0	0.0	0.4	4.0	0.8
09/26/2021 13:00	4.1	0.0	0.4	4.1	0.8
09/26/2021 14:00	4.1	0.0	0.4	4.1	0.8
09/26/2021 15:00	4.3	0.0	0.4	4.3	0.9
09/26/2021 16:00	4.2	0.0	0.4	4.2	0.8
09/26/2021 17:00	4.0	0.0	0.4	4.0	0.8
09/26/2021 18:00	4.0	0.0	0.4	4.0	0.8
09/26/2021 19:00	3.9	0.0	0.4	3.9	0.8
09/26/2021 20:00	3.9	0.0	0.4	3.9	0.8
09/26/2021 21:00	4.0	0.0	0.4	4.0	0.8
09/26/2021 22:00	4.0	0.0	0.4	4.0	0.8
09/26/2021 23:00	4.0	0.0	0.4	4.0	0.8
Average/Sum#:	97.0 #	0.0 #	9.6 #	97.0 #	19.4 #
Minimum:	3.9	0.0	0.4	3.9	0.8
Maximum:	4.3	0.0	0.4	4.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
09/27/2021 00:00	4.0	0.0	0.4	4.0	0.8
09/27/2021 01:00	4.0	0.0	0.4	4.0	0.8
09/27/2021 02:00	4.0	0.0	0.4	4.0	0.8
09/27/2021 03:00	4.0	0.0	0.4	4.0	0.8
09/27/2021 04:00	4.2	0.0	0.4	4.2	0.8
09/27/2021 05:00	6.6	0.0	0.5	5.0	1.0
09/27/2021 06:00	4.8	0.0	0.5	4.8	1.0
09/27/2021 07:00	4.4	0.0	0.4	4.4	0.9
09/27/2021 08:00	4.0	0.0	0.4	4.0	0.8
09/27/2021 09:00	4.0	0.0	0.4	4.0	0.8
09/27/2021 10:00	4.0	0.0	0.4	4.0	0.8
09/27/2021 11:00	4.0	0.0	0.4	4.0	0.8
09/27/2021 12:00	4.0	0.0	0.4	4.0	0.8
09/27/2021 13:00	4.0	0.0	0.4	4.0	0.8
09/27/2021 14:00	4.0	0.0	0.4	4.0	0.8
09/27/2021 15:00	4.0	0.0	0.4	4.0	0.8
09/27/2021 16:00	4.4	0.0	0.4	4.4	0.9
09/27/2021 17:00	4.1	0.0	0.4	4.1	0.8
09/27/2021 18:00	4.4	0.0	0.4	4.4	0.9
09/27/2021 19:00	4.4	0.0	0.4	4.4	0.9
09/27/2021 20:00	4.7	0.0	0.5	4.7	0.9
09/27/2021 21:00	4.2	0.0	0.4	4.2	0.8
09/27/2021 22:00	4.1	0.0	0.4	4.1	0.8
09/27/2021 23:00	4.0	0.0	0.4	4.0	0.8
Average/Sum#:	102.3 #	0.0 #	9.9 #	100.7 #	20.1 #
Minimum:	4.0	0.0	0.4	4.0	0.8
Maximum:	6.6	0.0	0.5	5.0	1.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
09/28/2021 00:00	4.0	0.0	0.4	4.0	0.8
09/28/2021 01:00	4.0	0.0	0.4	4.0	0.8
09/28/2021 02:00	4.0	0.0	0.4	4.0	0.8
09/28/2021 03:00	4.0	0.0	0.4	4.0	0.8
09/28/2021 04:00	5.7	0.0	0.4	4.3	0.9
09/28/2021 05:00	4.0	0.0	0.4	4.0	0.8
09/28/2021 06:00	6.0	0.0	0.5	4.5	0.9
09/28/2021 07:00	4.3	0.0	0.4	4.3	0.9
09/28/2021 08:00	4.3	0.0	0.4	4.3	0.9
09/28/2021 09:00	4.0	0.0	0.4	4.0	0.8
09/28/2021 10:00	5.4	0.0	0.4	4.0	0.8
09/28/2021 11:00	5.4	0.0	0.4	4.0	0.8
09/28/2021 12:00	5.4	0.0	0.4	4.0	0.8
09/28/2021 13:00	5.4	0.0	0.4	4.0	0.8
09/28/2021 14:00	5.4	0.0	0.4	4.0	0.8
09/28/2021 15:00	5.4	0.0	0.4	4.0	0.8
09/28/2021 16:00	5.8	0.0	0.4	4.4	0.9
09/28/2021 17:00	8.1	4.2	0.6	6.1	1.2
09/28/2021 18:00	8.5	0.6	0.6	6.4	1.3
09/28/2021 19:00	7.7	3.9	0.6	5.8	1.2
09/28/2021 20:00	7.6	6.5	0.6	5.7	1.1
09/28/2021 21:00	7.6	6.7	0.6	5.7	1.1
09/28/2021 22:00	4.1	0.0	0.4	4.1	0.8
09/28/2021 23:00	4.0	0.0	0.4	4.0	0.8
Average/Sum#:	130.1 #	21.9 #	10.7 #	107.6 #	21.6 #
Minimum:	4.0	0.0	0.4	4.0	0.8
Maximum:	8.5	6.7	0.6	6.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
09/29/2021 00:00	5.3	0.0	0.4	4.0	0.8
09/29/2021 01:00	4.0	0.0	0.4	4.0	0.8
09/29/2021 02:00	4.0	0.0	0.4	4.0	0.8
09/29/2021 03:00	48.7	50.5	0.6	5.3	1.1
09/29/2021 04:00	4.8	0.0	0.5	4.8	1.0
09/29/2021 05:00	6.9	0.0	0.5	5.2	1.0
09/29/2021 06:00	7.1	0.0	0.5	5.3	1.1
09/29/2021 07:00	7.1	0.0	0.5	5.3	1.1
09/29/2021 08:00	21.3	9.1	0.6	5.6	1.2
09/29/2021 09:00	56.5	69.9	1.0	6.7	1.4
09/29/2021 10:00	9.2	0.9	1.6	8.5	1.8
09/29/2021 11:00	4.4	0.4	1.4	8.1	1.8
09/29/2021 12:00	5.8	0.3	1.4	8.1	1.8
09/29/2021 13:00	9.9	0.6	1.7	9.1	2.0
09/29/2021 14:00	11.7	1.0	1.7	9.2	2.0
09/29/2021 15:00	11.7	1.0	1.7	9.3	2.0
09/29/2021 16:00	11.7	1.0	1.7	9.1	2.0
09/29/2021 17:00	8.5	1.1	1.4	7.8	1.7
09/29/2021 18:00	6.9	0.8	1.4	7.6	1.6
09/29/2021 19:00	9.9	0.9	1.7	9.1	2.0
09/29/2021 20:00	11.6	0.9	1.7	9.1	2.0
09/29/2021 21:00	11.3	1.2	1.6	8.9	2.0
09/29/2021 22:00	11.5	0.9	1.7	9.1	2.0
09/29/2021 23:00	10.7	1.2	1.6	8.4	1.8
Average/Sum#:	290.3 #	141.0 #	27.7 #	171.6 #	36.8 #
Minimum:	4.0	0.0	0.4	4.0	0.8
Maximum:	56.5	69.9	1.7	9.3	2.0
%SI	8.33	8.33	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 10:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
09/30/2021 00:00	7.5	0.9	1.5	8.3	1.8
09/30/2021 01:00	6.6	0.5	1.3	7.2	1.6
09/30/2021 02:00	7.7	0.5	1.3	7.1	1.6
09/30/2021 03:00	7.7	0.6	1.6	8.5	1.8
09/30/2021 04:00	8.1	0.6	1.6	8.9	2.0
09/30/2021 05:00	6.7	0.5	1.3	7.4	1.6
09/30/2021 06:00	6.5	4.6	1.0	3.9	0.9
09/30/2021 07:00	4.1	0.8	0.9	3.4	0.8
09/30/2021 08:00	4.0	0.5	0.9	3.4	0.8
09/30/2021 09:00	4.1	0.5	1.0	3.4	0.8
09/30/2021 10:00	2.7	0.5	1.0	3.4	0.8
09/30/2021 11:00	2.7	0.5	1.0	3.4	0.8
09/30/2021 12:00	2.7	0.3	1.0	3.4	0.8
09/30/2021 13:00	2.7	0.3	1.0	3.4	0.8
09/30/2021 14:00	2.8	0.5	1.0	3.5	0.8
09/30/2021 15:00	5.9	6.3	1.4	4.9	1.2
09/30/2021 16:00	6.1	4.6	1.4	5.1	1.2
09/30/2021 17:00	6.0	4.2	1.4	5.0	1.2
09/30/2021 18:00	5.9	4.6	1.4	4.9	1.2
09/30/2021 19:00	5.9	4.6	1.4	4.9	1.2
09/30/2021 20:00	5.9	4.6	1.4	4.9	1.2
09/30/2021 21:00	5.9	4.9	1.4	4.9	1.2
09/30/2021 22:00	5.8	5.3	1.3	4.8	1.2
09/30/2021 23:00	4.2	1.3	1.0	3.5	0.8
Average/Sum#:	128.2 #	52.5 #	29.5 #	121.5 #	28.1 #
Minimum:	2.7	0.3	0.9	3.4	0.8
Maximum:	8.1	6.3	1.6	8.9	2.0
%SI	0.00	0.00	0.00	0.00	0.00

Excess Emission Report

CT1 and CT2 CO Lb/Day

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/04/2021 10:54 **Location:** Maxwell, CA

Tag Name: ALL_CO_Lb_1D
Total Operating Time: 82.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 10.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**82.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 and CT2 CO Lb/Hr

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/04/2021 10:55 **Location:** Maxwell, CA

Tag Name: ALL_CO_Lb_1H
Total Operating Time: 1,908.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 300.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,908.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 and CT2 NOx Lb/Day

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/04/2021 10:56 **Location:** Maxwell, CA

Tag Name: ALL_NOx_Lb_1D
Total Operating Time: 82.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 10.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**82.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 and CT2 NOx Lb/Hr

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/04/2021 10:57 **Location:** Maxwell, CA

Tag Name: ALL_NOx_Lb_1H
Total Operating Time: 1,908.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 300.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,908.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 and CT2 PM10 Lb/Day

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/04/2021 10:58 **Location:** Maxwell, CA

Tag Name: ALL_PM10_Lb_1D
Total Operating Time: 82.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 10.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**82.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 and CT2 PM10 Lb/Hr

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/04/2021 10:59 **Location:** Maxwell, CA

Tag Name: ALL_PM10_Lb_1H
Total Operating Time: 1,908.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 300.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,908.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 and CT2 SO2 Lb/Day

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/04/2021 10:59 **Location:** Maxwell, CA

Tag Name: ALL_SO2_Lb_1D
Total Operating Time: 82.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 10.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**82.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 and CT2 SO2 Lb/Hr

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/04/2021 11:00 **Location:** Maxwell, CA

Tag Name: ALL_SO2_Lb_1H
Total Operating Time: 1,908.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 300.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,908.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 and CT2 VOC Lb/Day

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/04/2021 11:00 **Location:** Maxwell, CA

Tag Name: ALL_VOC_Lb_1D
Total Operating Time: 82.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 10.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**82.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 and CT2 VOC Lb/Hr

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/04/2021 11:01 **Location:** Maxwell, CA

Tag Name: ALL_VOC_Lb_1H
Total Operating Time: 1,908.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 300.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,908.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

ATTACHMENT 11
Linearity

FCD: AQ-19
Title V: #13

Linearity Report

ORIS Code: 56298
Facility Name: COLUSA GENERATION
EDR Site ID: CT2
Component ID: A21
ReasonForTest: QA
Component Type: NOXA
Grace Period: 0
Instrument Name: CT2_NOXDualRg_P_Instrume
Test End Date/Time: 08/18/2021
Scale: High
Performance Spec: 5 %
Test No.: 106
Highest Error: 1.7
Status (Pass/Fail): **Passed**

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
08/18/2021	0956	L	200.0	50.3	49.9		25.2 %
08/18/2021	1002	M	200.0	110.4	110.8		55.2 %
08/18/2021	1008	H	200.0	179.6	182.4		89.8 %
08/18/2021	1017	L	200.0	50.3	50.3		25.2 %
08/18/2021	1023	M	200.0	110.4	111.7		55.2 %
08/18/2021	1029	H	200.0	179.6	181.3		89.8 %
08/18/2021	1037	L	200.0	50.3	49.9		25.2 %
08/18/2021	1043	M	200.0	110.4	112.5		55.2 %
08/18/2021	1049	H	200.0	179.6	184.4		89.8 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	50.300	50.033	No	**0.5**
M	110.400	111.667	No	**1.1**
H	179.600	182.700	No	**1.7**

Linearity Report

ORIS Code:	56298	Facility Name:	COLUSA GENERATION		
EDR Site ID:	CT2	Component ID:	A22	ReasonForTest:	QA
		Component Type:	O2D	Grace Period:	0
Instrument Name:	CT2_O2D_P_Instrument	Test End Date/Time:	08/18/2021	Scale:	High
Performance Spec:	5 %	Test No.:	107	Highest Error:	1.8
		Status (Pass/Fail):	**Passed**		

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
08/18/2021	0834	L	25.0	5.5	5.6		22.0 %
08/18/2021	0840	M	25.0	13.0	13.0		52.0 %
08/18/2021	0846	H	25.0	21.1	21.1		84.4 %
08/18/2021	0855	L	25.0	5.5	5.6		22.0 %
08/18/2021	0901	M	25.0	13.0	13.0		52.0 %
08/18/2021	0907	H	25.0	21.1	21.1		84.4 %
08/18/2021	0915	L	25.0	5.5	5.6		22.0 %
08/18/2021	0921	M	25.0	13.0	13.1		52.0 %
08/18/2021	0927	H	25.0	21.1	21.1		84.4 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	5.500	5.600	No	**1.8**
M	13.000	13.033	No	**0.3**
H	21.100	21.100	No	**0.0**

Cylinder Gas Audit

Facility: COLUSA GENERATION
Unit/Stack: CT2
Parameter/Scale: NOX / High
Test Date: 08/19/2021
Test Result: **Pass**
Instrument Name: CT2_NOXInlet_P_Instrum
Performance Spec: 15 Pct
Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
08/19/2021	13:18	L	200	50.300	46.900	25.2 %
08/19/2021	13:24	M	200	110.400	106.200	55.2 %
08/19/2021	13:33	L	200	50.300	47.400	25.2 %
08/19/2021	13:39	M	200	110.400	106.400	55.2 %
08/19/2021	13:47	L	200	50.300	47.500	25.2 %
08/19/2021	13:53	M	200	110.400	106.500	55.2 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	50.300	47.267	Std	**6.0**
M	110.400	106.367	Std	**3.7**

Cylinder Gas Audit

Facility: COLUSA GENERATION
Unit/Stack: CT2
Parameter/Scale: O2D / High
Test Date: 08/19/2021
Test Result: **Pass**
Instrument Name: CT2_O2DInlet_P_Instrum
Performance Spec: 15 Pct
Alternate Spec: 0 Pct

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
08/19/2021	11:05	L	25	5.500	5.200	22.0 %
08/19/2021	11:11	M	25	13.000	12.900	52.0 %
08/19/2021	11:20	L	25	5.500	5.200	22.0 %
08/19/2021	11:26	M	25	13.000	12.900	52.0 %
08/19/2021	11:34	L	25	5.500	5.200	22.0 %
08/19/2021	11:40	M	25	13.000	12.900	52.0 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	5.500	5.200	Std	**5.5**
M	13.000	12.900	Std	**0.8**

Cylinder Gas Audit

Facility: COLUSA GENERATION
Unit/Stack: CT2
Parameter/Scale: CO / Low
Test Date: 08/19/2021
Test Result: **Pass**
Instrument Name: CT2_CODualRg_P_Instrum
Performance Spec: 15 Pct
Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
08/19/2021	09:03	L	20	4.600	4.200	23.0 %
08/19/2021	09:09	M	20	11.300	11.200	56.5 %
08/19/2021	09:18	L	20	4.600	4.200	23.0 %
08/19/2021	09:24	M	20	11.300	11.200	56.5 %
08/19/2021	09:32	L	20	4.600	4.200	23.0 %
08/19/2021	09:38	M	20	11.300	11.200	56.5 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	4.600	4.200	Std	**8.7**
M	11.300	11.200	Std	**0.9**

Cylinder Gas Audit

Facility: COLUSA GENERATION
Unit/Stack: CT2
Parameter/Scale: CO / High
Test Date: 08/18/2021
Test Result: **Pass**
Instrument Name: CT2_CODualRg_P_Instrum
Performance Spec: 15 Pct
Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
08/18/2021	14:55	L	2000	511.100	506.900	25.6 %
08/18/2021	15:01	M	2000	1157.000	1156.900	57.9 %
08/18/2021	15:10	L	2000	511.100	506.700	25.6 %
08/18/2021	15:16	M	2000	1157.000	1158.100	57.9 %
08/18/2021	15:24	L	2000	511.100	507.200	25.6 %
08/18/2021	15:30	M	2000	1157.000	1157.200	57.9 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	511.100	506.933	Std	**0.8**
M	1157.000	1157.400	Std	**0.0**

Cylinder Gas Audit

Facility: COLUSA GENERATION
Unit/Stack: CT2
Parameter/Scale: NOX / Low
Test Date: 08/18/2021
Test Result: **Pass**
Instrument Name: CT2_NOXDualRg_P_Instru
Performance Spec: 15 Pct
Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
08/18/2021	13:43	L	10	2.500	2.100	25.0 %
08/18/2021	13:49	M	10	5.500	5.200	55.0 %
08/18/2021	13:58	L	10	2.500	2.000	25.0 %
08/18/2021	14:04	M	10	5.500	5.200	55.0 %
08/18/2021	14:12	L	10	2.500	2.000	25.0 %
08/18/2021	14:18	M	10	5.500	5.100	55.0 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	2.500	2.033	Alt	**0.5**
M	5.500	5.167	Std	**6.1**

Airgas
an Air Liquide company

In Service 2/24/21
Out of service 8/24/2021

Airgas USA, LLC
525 North Industrial Loop Road
Tooele, UT 84074
Airgas.com

CT 2
CV 1

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E03NI99E15A42D0	Reference Number:	153-401995003-1
Cylinder Number:	CC102815	Cylinder Volume:	144.4 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72021	Valve Outlet:	660
Gas Code:	CO,NO,NOX,BALN	Certification Date:	Jan 05, 2021

Expiration Date: Jan 05, 2029

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	180.0 PPM	179.6 PPM	G1	+/- 0.9% NIST Traceable	12/29/2020, 01/05/2021
NITRIC OXIDE	180.0 PPM	179.4 PPM	G1	+/- 0.9% NIST Traceable	12/29/2020, 01/05/2021
CARBON MONOXIDE	1150 PPM	1157 PPM	G1	+/- 1.4% NIST Traceable	12/29/2020
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	13010322	KAL003863	243.4 PPM NITRIC OXIDE/NITROGEN	0.5%	May 04, 2026
PRM	12386	D685025	9.91 PPM NITROGEN DIOXIDE/AIR	2.0%	Feb 20, 2020
GMIS	401203436105	CC513880	4.732 PPM NITROGEN DIOXIDE/NITROGEN	2.1%	May 02, 2022
NTRM	08012251	KAL004695	2466 PPM CARBON MONOXIDE/NITROGEN	0.5%	May 09, 2024

The SRM, PRM or RGM noted above is only in reference to the GMIS used in the assay and not part of the analysis.

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Nicolet 6700 AHR0801550 CO HCO	FTIR	Dec 23, 2020
Nicolet 6700 AHR0801550 NO MNO	FTIR	Dec 29, 2020
Nicolet 6700 AHR0801550 NO2 impurity	FTIR NO2 impurity	Dec 30, 2020

Triad Data Available Upon Request

Approved for Release

In service 8/6/21

Airgas
an Air Liquide company

Airgas Specialty Gases
Airgas USA, LLC
525 North Industrial Loop Road
Tooele, UT 84074
Airgas.com

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E02NI79E15AC046	Reference Number:	153-401967816-1	CT2
Cylinder Number:	CC15548	Cylinder Volume:	146.2 CF	CV2
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG	
PGVP Number:	B72020	Valve Outlet:	590	
		Certification Date:	Nov 24, 2020	

Expiration Date: Nov 24, 2028

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100.psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
OXYGEN	21.00 %	21.05 %	G1	+/- 1.0% NIST Traceable	11/24/2020
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	12062008	CC367433	22.883 % OXYGEN/NITROGEN	0.2%	May 14, 2024

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Horiba MPA-510 W603MM58 O2	O2 Paramagnetic (Mason)	Dec 01, 2020

Triad Data Available Upon Request

PERMANENT NOTES:-NA-

Signature on file

Approved for Release

In Service 7/14/2021

Airgas
an Air Liquide company

Airgas Specialty Gases
Airgas USA, LLC
525 North Industrial Loop Road
Tooele, UT 84074
Airgas.com

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E03NI99E15A7635	Reference Number:	153-402016171-1
Cylinder Number:	CC503668	Cylinder Volume:	144.3 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72021	Valve Outlet:	660
Gas Code:	CO,NO,NOX,BALN	Certification Date:	Feb 09, 2021

CT2
CV3

Expiration Date: Feb 09, 2024

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	9.000 PPM	9.192 PPM	G1	+/- 1.0% NIST Traceable	01/29/2021, 02/09/2021
NITRIC OXIDE	9.000 PPM	9.054 PPM	G1	+/- 1.1% NIST Traceable	01/29/2021, 02/09/2021
CARBON MONOXIDE	11.00 PPM	11.33 PPM	G1	+/- 0.7% NIST Traceable	01/29/2021
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	120102	AAL073426	10.04 PPM NITRIC OXIDE/NITROGEN	1.0%	Oct 16, 2022
NTRM	120102	AAL073426-NOX	10.04 PPM NOx/NITROGEN	1.0%	Oct 16, 2022
NTRM	08011130	KAL004049	9.855 PPM CARBON MONOXIDE/NITROGEN	0.5%	Jun 05, 2024

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Thermo 48i-TLE 1163640031 CO	CO NDIR (Mason)	Dec 31, 2020
Thermo 42i-LS 1123749327 NO	Chemiluminescence (Mason)	Jan 22, 2021
Thermo 42i-LS 1123749327 NOx	Chemiluminescence (Mason)	Jan 22, 2021

Triad Data Available Upon Request

Approved for Release

IN SERVICE 03 APR 2020

Airgas
an Air Liquide company

Airgas Specialty Gases
Airgas USA, LLC
525 North Industrial Loop Road
Tooele, UT 84074
Airgas.com

CT2 - CV4

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E02NI99E15A0093	Reference Number:	153-400996726-1
Cylinder Number:	CC205834	Cylinder Volume:	144.3 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72017	Valve Outlet:	660
Gas Code:	NO,NOX,BALN	Certification Date:	Sep 19, 2017

Expiration Date: Sep 19, 2025

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	110.0 PPM	110.4 PPM	G1	+/- 1.0% NIST Traceable	09/12/2017, 09/19/2017
NITRIC OXIDE	110.0 PPM	110.2 PPM	G1	+/- 1.0% NIST Traceable	09/12/2017, 09/19/2017
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	13010428	KAL004053	97.6 PPM NITRIC OXIDE/NITROGEN	0.8	May 09, 2019
PRM	12367	APEX1099237	10.00 PPM NITROGEN DIOXIDE/NITROGEN	1.6%	May 29, 2016
GMIS	1114201604	CC507567	4.955 PPM NITROGEN DIOXIDE/NITROGEN	2.0%	Nov 14, 2019

The SRM, PRM or RGM noted above is only in reference to the GMIS used in the assay and not part of the analysis.

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Nicolet 6700 AHR0801550 NO LNO	FTIR	Sep 07, 2017
Nicolet 6700 AHR0801550 NO2 impurity	FTIR NO2 impurity	Sep 07, 2017

Triad Data Available Upon Request

Approved for Release

Airgas
an Air Liquide company

In Service 8/17/2021

Airgas USA, LLC
525 North Industrial Loop Road
Tooele, UT 84074
Airgas.com

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

CT2
CV5

Part Number:	E02NI99E15A0147	Reference Number:	153-401144292-1
Cylinder Number:	CC215825	Cylinder Volume:	144.3 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72018	Valve Outlet:	660
Gas Code:	NO,NOX,BALN	Certification Date:	Mar 13, 2018

Expiration Date: Mar 13, 2026

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	50.00 PPM	50.34 PPM	G1	+/- 1.4% NIST Traceable	03/06/2018, 03/13/2018
NITRIC OXIDE	50.00 PPM	50.31 PPM	G1	+/- 1.4% NIST Traceable	03/06/2018, 03/13/2018
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	16060619	CC442576	50.42 PPM NITRIC OXIDE/NITROGEN	0.8%	Jun 27, 2020
PRM	12367	APEX1099237	9.82 PPM NITROGEN DIOXIDE/NITROGEN	1.6%	May 29, 2016
GMIS	1114201604	CC507567	4.955 PPM NITROGEN DIOXIDE/NITROGEN	2.0%	Nov 14, 2019

The SRM, PRM or RGM noted above is only in reference to the GMIS used in the assay and not part of the analysis.

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Nicolet 6700 AHR0801550 NO LNO	FTIR	Mar 07, 2018
Nicolet 6700 AHR0801550 NO2 impurity	FTIR NO2 impurity	Mar 07, 2018

Triad Data Available Upon Request

Approved for Release

In service 6/1/2021

Airgas
an Air Liquide company

Airgas Specialty Gases
Airgas USA, LLC
11711 S. Alameda Street
Los Angeles, CA 90059
Airgas.com

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

CTZ
CVG

Part Number:	E03NI99E15A42C9	Reference Number:	48-401707982-1
Cylinder Number:	EB0102482	Cylinder Volume:	144.3 CF
Laboratory:	124 - Los Angeles (SAP) - CA	Cylinder Pressure:	2015 PSIG
PGVP Number:	B32020	Valve Outlet:	660
Gas Code:	CO,NO,NOX,BALN	Certification Date:	Feb 12, 2020

Expiration Date: Feb 12, 2023

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	5.500 PPM	5.476 PPM	G1	+/- 1.2% NIST Traceable	02/03/2020, 02/12/2020
NITRIC OXIDE	5.500 PPM	5.410 PPM	G1	+/- 1.1% NIST Traceable	02/03/2020, 02/12/2020
CARBON MONOXIDE	500.0 PPM	511.1 PPM	G1	+/- 0.6% NIST Traceable	02/04/2020
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	08012106A	KAL004222	5.08 PPM NITRIC OXIDE/NITROGEN	+/- 1.0%	Jul 05, 2021
NTRM	08012106A	KAL004222-NOx	5.08 PPM NOx/NITROGEN	+/- 1.0%	Jul 05, 2021
NTRM	15060524	CC450548	491.9 PPM CARBON MONOXIDE/NITROGEN	+/- 0.6%	Jan 08, 2021

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
SIEMENS 6E CO HIGH	NDIR	Jan 15, 2020
Thermo 42-iLS 1115848421 NO	Chemiluminescence	Feb 02, 2020
Thermo 42-iLS 1115848421 NOx	Chemiluminescence	Feb 02, 2020

Triad Data Available Upon Request

Approved for Release

IN SERVICE: 03 APR 2020

Airgas
an Air Liquide company

Airgas USA, LLC
525 North Industrial Loop Road
Tooele, UT 84074
Airgas.com

< T 2
< V 7

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E03NI99E15A73F4	Reference Number:	153-401707981-1
Cylinder Number:	CC472917	Cylinder Volume:	144.3 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72020	Valve Outlet:	660
Gas Code:	CO,NO,NOX,BALN	Certification Date:	Jan 28, 2020

Expiration Date: Jan 28, 2023

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	2.500 PPM	2.507 PPM	G1	+/- 1.3% NIST Traceable	01/21/2020, 01/28/2020
NITRIC OXIDE	2.500 PPM	2.502 PPM	G1	+/- 1.4% NIST Traceable	01/21/2020, 01/28/2020
CARBON MONOXIDE	4.750 PPM	4.637 PPM	G1	+/- 0.6% NIST Traceable	01/21/2020
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	08012121A	KAL004278	5.08 PPM NITRIC OXIDE/NITROGEN	1.0%	Jun 05, 2021
NTRM	08012126	KAL004291	5.08 PPM NITRIC OXIDE/NITROGEN	1.0%	Jul 05, 2021
NTRM	08012121A	KAL004278-NOX	5.08 PPM NOx/NITROGEN	1.0%	Jun 05, 2021
NTRM	08012126	KAL004291-NOX	5.08 PPM NOx/NITROGEN	1.0%	Jul 05, 2021
NTRM	08011130	KAL004049	9.855 PPM CARBON MONOXIDE/NITROGEN	0.5%	Jun 05, 2024

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Thermo 48i-TLE 1163640031 CO	CO NDIR (Mason)	Jan 06, 2020
Thermo 42i-LS 1123749327 NO	Chemiluminescence (Mason)	Jan 16, 2020
Thermo 42i-LS 1123749327 NOx	Chemiluminescence (Mason)	Jan 16, 2020

Triad Data Available Upon Request

Approved for Release

Airgas
an Air Liquide company

In Service 8/17/2021

Airgas USA, LLC
525 North Industrial Loop Road
Tooele, UT 84074
Airgas.com

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

CTZ
CV8

Part Number:	E02NI87E15A0080	Reference Number:	153-402028995-1
Cylinder Number:	CC203622	Cylinder Volume:	145.5 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72021	Valve Outlet:	590
Gas Code:	O2,BALN	Certification Date:	Feb 15, 2021

Expiration Date: Feb 15, 2029

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
OXYGEN	13.00 %	13.02 %	G1	+/- 0.7% NIST Traceable	02/15/2021
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	98051010	SG9161286BAL	12.05 % OXYGEN/NITROGEN	0.7%	Dec 14, 2023

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Horiba MPA-510 W603MM58 O2	O2 Paramagnetic (Mason)	Feb 01, 2021

Triad Data Available Upon Request

Approved for Release

IN SERVICE 03 APR 2020

Airgas
an Air Liquide company

Airgas USA, LLC
525 North Industrial Loop Road
Tooele, UT 84074
Airgas.com

CT.2
CV.9

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E02NI94E15AC040	Reference Number:	153-401707983-1
Cylinder Number:	CC54718	Cylinder Volume:	144.8 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72020	Valve Outlet:	590
Gas Code:	O2,BALN	Certification Date:	Jan 21, 2020

Expiration Date: Jan 21, 2028

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
OXYGEN	5.500 %	5.507 %	G1	+/- 0.6% NIST Traceable	01/21/2020
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	11060717	CC338451	4.861 % OXYGEN/NITROGEN	0.4%	Dec 13, 2022

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Horiba MPA-510 W603MM58 O2	O2 Paramagnetic (Mason)	Dec 30, 2019

Triad Data Available Upon Request

PERMANENT NOTES:-NA-

NOTES:NO: 0.001 PPM
CO: 0.001 PPM
CO2: 0.001 PPM

Approved for Release

Linearity Report

ORIS Code:	56298	Facility Name:	COLUSA GENERATION		
EDR Site ID:	CT1	Component ID:	A11	ReasonForTest:	QA
		Component Type:	NOXA	Grace Period:	0
Instrument Name:	CT1_NOXDualRg_P_Instrume	Test End Date/Time:	08/18/2021	Scale:	High
Performance Spec:	5 %	Test No.:	105	Highest Error:	3.2
		Status (Pass/Fail):	**Passed**		

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
08/18/2021	0923	L	200.0	50.2	51.1		25.1 %
08/18/2021	0929	M	200.0	111.4	112.6		55.7 %
08/18/2021	0935	H	200.0	182.8	185.1		91.4 %
08/18/2021	0943	L	200.0	50.2	51.9		25.1 %
08/18/2021	0949	M	200.0	111.4	113.2		55.7 %
08/18/2021	0955	H	200.0	182.8	183.9		91.4 %
08/18/2021	1003	L	200.0	50.2	52.4		25.1 %
08/18/2021	1009	M	200.0	111.4	112.1		55.7 %
08/18/2021	1015	H	200.0	182.8	185.6		91.4 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	50.200	51.800	No	**3.2**
M	111.400	112.633	No	**1.1**
H	182.800	184.867	No	**1.1**

Linearity Report

ORIS Code: 56298
EDR Site ID: CT1
Instrument Name: CT1_O2D_P_Instrument
Performance Spec: 5 %

Facility Name: COLUSA GENERATION
Component ID: A12
Component Type: O2D
Test End Date/Time: 08/19/2021
Test No.: 106
Status (Pass/Fail): **Passed**

ReasonForTest: QA
Grace Period: 0
Scale: High
Highest Error: 2.4

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
08/19/2021	1316	L	25.0	5.5	5.4		22.0 %
08/19/2021	1322	M	25.0	13.0	12.9		52.0 %
08/19/2021	1328	H	25.0	21.1	21.0		84.4 %
08/19/2021	1337	L	25.0	5.5	5.4		22.0 %
08/19/2021	1343	M	25.0	13.0	12.9		52.0 %
08/19/2021	1349	H	25.0	21.1	21.0		84.4 %
08/19/2021	1357	L	25.0	5.5	5.3		22.0 %
08/19/2021	1403	M	25.0	13.0	12.9		52.0 %
08/19/2021	1409	H	25.0	21.1	21.0		84.4 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	5.500	5.367	No	**2.4**
M	13.000	12.900	No	**0.8**
H	21.100	21.000	No	**0.5**

Cylinder Gas Audit

Facility: COLUSA GENERATION
Unit/Stack: CT1
Parameter/Scale: NOX / Low
Test Date: 08/19/2021
Test Result: **Pass**
Instrument Name: CT1_NOXDualRg_P_Instru
Performance Spec: 15 Pct
Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
08/19/2021	14:41	L	10	2.600	2.600	26.0 %
08/19/2021	14:47	M	10	5.500	5.500	55.0 %
08/19/2021	14:56	L	10	2.600	2.600	26.0 %
08/19/2021	15:02	M	10	5.500	5.600	55.0 %
08/19/2021	15:10	L	10	2.600	2.600	26.0 %
08/19/2021	15:16	M	10	5.500	5.600	55.0 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	2.600	2.600	Std	**0.0**
M	5.500	5.567	Std	**1.2**

Cylinder Gas Audit

Facility: COLUSA GENERATION
Unit/Stack: CT1
Parameter/Scale: O2D / High
Test Date: 08/20/2021
Test Result: **Pass**
Instrument Name: CT1_O2DInlet_P_Instrum
Performance Spec: 15 Pct
Alternate Spec: 0 Pct

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
08/20/2021	09:15	L	25	5.500	5.400	22.0 %
08/20/2021	09:21	M	25	13.000	12.900	52.0 %
08/20/2021	09:30	L	25	5.500	5.400	22.0 %
08/20/2021	09:36	M	25	13.000	12.900	52.0 %
08/20/2021	09:44	L	25	5.500	5.400	22.0 %
08/20/2021	09:50	M	25	13.000	12.900	52.0 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	5.500	5.400	Std	**1.8**
M	13.000	12.900	Std	**0.8**

Cylinder Gas Audit

Facility: COLUSA GENERATION
Unit/Stack: CT1
Parameter/Scale: NOX / High
Test Date: 08/20/2021
Test Result: **Pass**
Instrument Name: CT1_NOXInlet_P_Instrum
Performance Spec: 15 Pct
Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
08/20/2021	08:24	L	200	50.200	48.600	25.1 %
08/20/2021	08:30	M	200	111.400	108.800	55.7 %
08/20/2021	08:39	L	200	50.200	49.100	25.1 %
08/20/2021	08:45	M	200	111.400	109.200	55.7 %
08/20/2021	08:53	L	200	50.200	49.200	25.1 %
08/20/2021	08:59	M	200	111.400	109.400	55.7 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	50.200	48.967	Std	**2.5**
M	111.400	109.133	Std	**2.0**

Cylinder Gas Audit

Facility: COLUSA GENERATION
Unit/Stack: CT1
Parameter/Scale: CO / Low
Test Date: 08/20/2021
Test Result: **Pass**
Instrument Name: CT1_CODualRg_P_Instrum
Performance Spec: 15 Pct
Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
08/20/2021	07:04	L	20	4.700	4.900	23.5 %
08/20/2021	07:10	M	20	11.000	10.700	55.0 %
08/20/2021	07:19	L	20	4.700	4.800	23.5 %
08/20/2021	07:25	M	20	11.000	10.800	55.0 %
08/20/2021	07:33	L	20	4.700	4.800	23.5 %
08/20/2021	07:39	M	20	11.000	10.700	55.0 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	4.700	4.833	Std	**2.8**
M	11.000	10.733	Std	**2.4**

Cylinder Gas Audit

Facility: COLUSA GENERATION
Unit/Stack: CT1
Parameter/Scale: CO / High
Test Date: 08/18/2021
Test Result: **Pass**
Instrument Name: CT1_CODualRg_P_Instrum
Performance Spec: 15 Pct
Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
08/18/2021	14:53	L	2000	499.400	474.400	25.0 %
08/18/2021	14:59	M	2000	1159.000	1153.900	58.0 %
08/18/2021	15:08	L	2000	499.400	474.400	25.0 %
08/18/2021	15:14	M	2000	1159.000	1153.900	58.0 %
08/18/2021	15:22	L	2000	499.400	474.400	25.0 %
08/18/2021	15:28	M	2000	1159.000	1152.800	58.0 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	499.400	474.400	Std	**5.0**
M	1159.000	1153.533	Std	**0.5**

Airgas
an Air Liquide company

In service 8/6/2021

Airgas USA, LLC
525 North Industrial Loop Road
Tooele, UT 84074
Airgas.com

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

CT1
CV1

Part Number:	E03NI99E15A42D0	Reference Number:	153-402066788-1
Cylinder Number:	CC263806	Cylinder Volume:	144.4 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72021	Valve Outlet:	660
Gas Code:	CO,NO,NOX,BALN	Certification Date:	Mar 31, 2021

Expiration Date: Mar 31, 2029

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	180.0 PPM	182.8 PPM	G1	+/- 0.6% NIST Traceable	03/24/2021, 03/31/2021
NITRIC OXIDE	180.0 PPM	182.6 PPM	G1	+/- 0.6% NIST Traceable	03/24/2021, 03/31/2021
CARBON MONOXIDE	1150 PPM	1159 PPM	G1	+/- 0.5% NIST Traceable	03/24/2021
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	18060115	KAL004110	249.9 PPM NITRIC OXIDE/NITROGEN	0.4%	Nov 08, 2023
PRM	12386	D685025	9.91 PPM NITROGEN DIOXIDE/AIR	2.0%	Feb 20, 2020
GMIS	401648675102	CC500959	5.074 PPM NITROGEN DIOXIDE/NITROGEN	2.1%	Feb 01, 2023
NTRM	09010335	KAL004570	970.0 PPM CARBON MONOXIDE/NITROGEN	0.4%	May 14, 2021

The SRM, PRM or RGM noted above is only in reference to the GMIS used in the assay and not part of the analysis.

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Nicolet iS50 AUP2010228 CO HCO	FTIR	Mar 18, 2021
Nicolet iS50 AUP2010228 NO MNO	FTIR	Mar 17, 2021
Nicolet iS50 AUP2010228 NO2 impurity	FTIR NO2 impurity	Mar 18, 2021

Triad Data Available Upon Request

Approved for Release

Airgas
an Air Liquide company

In Service 02NI79E15AC046

Airgas USA, LLC
525 North Industrial Loop Road
Tooele, UT 84074
Airgas.com

CT 1
CV 2

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E02NI79E15AC046	Reference Number:	153-401964351-1
Cylinder Number:	CC81990	Cylinder Volume:	146.2 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72020	Valve Outlet:	590
		Certification Date:	Nov 23, 2020

Expiration Date: Nov 23, 2028

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
OXYGEN	21.00 %	21.08 %	G1	+/- 0.4% NIST Traceable	11/23/2020
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	12062008	CC367433	22.883 % OXYGEN/NITROGEN	0.2%	May 14, 2024

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Horiba MPA-510 W603MM58 O2	O2 Paramagnetic (Mason)	Nov 05, 2020

Triad Data Available Upon Request

PERMANENT NOTES:-NA-

NOTES:NO: 0.01 PPM
CO: 0.01 PPM
CO2: 0.00 PPM

Approved for Release

In Service 08Jul 21-S

Airgas
an Air Liquide company

Airgas Specialty Gases
Airgas USA, LLC
525 North Industrial Loop Road
Tooele, UT 84074
Airgas.com

CT 1
CV 3

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E03NI99E15A7635	Reference Number:	153-401938029-1
Cylinder Number:	CC735989	Cylinder Volume:	144.3 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72020	Valve Outlet:	660
Gas Code:	CO,NO,NOX,BALN	Certification Date:	Nov 03, 2020

Expiration Date: Nov 03, 2023

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	9.000 PPM	8.955 PPM	G1	+/- 1.4% NIST Traceable	10/27/2020, 11/03/2020
NITRIC OXIDE	9.000 PPM	8.892 PPM	G1	+/- 1.1% NIST Traceable	10/27/2020, 11/03/2020
CARBON MONOXIDE	11.00 PPM	11.04 PPM	G1	+/- 0.8% NIST Traceable	10/27/2020
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	120102	AAL073426	10.04 PPM NITRIC OXIDE/NITROGEN	1.0%	Oct 16, 2022
NTRM	120102	AAL073426-NOX	10.04 PPM NOx/NITROGEN	1.0%	Oct 16, 2022
NTRM	08011130	KAL004049	9.855 PPM CARBON MONOXIDE/NITROGEN	0.5%	Jun 05, 2024

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Thermo 48i-TLE 1163640031 CO	CO NDIR (Mason)	Oct 27, 2020
Thermo 42i-LS 1123749327 NO	Chemiluminescence (Mason)	Oct 19, 2020
Thermo 42i-LS 1123749327 NOx	Chemiluminescence (Mason)	Oct 19, 2020

Triad Data Available Upon Request

Approved for Release

Airgas
an Air Liquide company

In Service 8/17/2021

Airgas USA, LLC
525 North Industrial Loop Road
Tooele, UT 84074
Airgas.com

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

CTI
CV4

Part Number:	E02NI99E15A0093	Reference Number:	153-401144291-1
Cylinder Number:	CC476209	Cylinder Volume:	144.3 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72018	Valve Outlet:	660
Gas Code:	NO,NOX,BALN	Certification Date:	Mar 12, 2018

Expiration Date: Mar 12, 2026

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	110.0 PPM	111.4 PPM	G1	+/- 1.1% NIST Traceable	03/05/2018, 03/12/2018
NITRIC OXIDE	110.0 PPM	111.1 PPM	G1	+/- 1.1% NIST Traceable	03/05/2018, 03/12/2018
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	13010413	KAL004013	97.6 PPM NITRIC OXIDE/NITROGEN	0.8%	May 09, 2019
PRM	12367	APEX1099237	9.82 PPM NITROGEN DIOXIDE/NITROGEN	1.6%	May 29, 2016
GMIS	1114201604	CC507567	4.955 PPM NITROGEN DIOXIDE/NITROGEN	2.0%	Nov 14, 2019

The SRM, PRM or RGM noted above is only in reference to the GMIS used in the assay and not part of the analysis.

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Nicolet 6700 AHR0801550 NO LNO	FTIR	Mar 07, 2018
Nicolet 6700 AHR0801550 NO2 impurity	FTIR NO2 impurity	Mar 07, 2018

Triad Data Available Upon Request

Approved for Release

Airgas
an Air Liquide company

In service 6/1/2021

Airgas USA, LLC
525 North Industrial Loop Road
Tooele, UT 84074
Airgas.com

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

CTI
CVS

Part Number:	E02NI99E15A0147	Reference Number:	153-401707980-1
Cylinder Number:	CC178727	Cylinder Volume:	144.3 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72020	Valve Outlet:	660
Gas Code:	NO,NOX,BALN	Certification Date:	Jan 28, 2020

Expiration Date: Jan 28, 2028

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	50.00 PPM	50.17 PPM	G1	+/- 1.0% NIST Traceable	01/21/2020, 01/28/2020
NITRIC OXIDE	50.00 PPM	50.17 PPM	G1	+/- 1.0% NIST Traceable	01/21/2020, 01/28/2020
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	12010719	KAL004397	50.03 PPM NITRIC OXIDE/NITROGEN	0.8%	Mar 12, 2024
PRM	12376	D562879	10.01 PPM NITROGEN DIOXIDE/NITROGEN	2.0%	Aug 17, 2018
GMIS	7301017103	CC506597	4.451 PPM NITROGEN DIOXIDE/NITROGEN	2.0%	Dec 18, 2020

The SRM, PRM or RGM noted above is only in reference to the GMIS used in the assay and not part of the analysis.

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Nicolet 6700 AMP0900119 NO LNO	FTIR	Jan 22, 2020
Nicolet 6700 AMP0900119 NO2 impurity	FTIR NO2 impurity	Jan 22, 2020

Triad Data Available Upon Request

mlg

Approved for Release

Airgas
an Air Liquide company

IN SERVICE 11/JUN 21 5

Airgas USA, LLC
525 North Industrial Loop Road
Tooele, UT 84074
Airgas.com

CT/
CV 8

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E02NI87E15A0080	Reference Number:	153-402028995-1
Cylinder Number:	EB0088907	Cylinder Volume:	145.5 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72021	Valve Outlet:	590
Gas Code:	O2,BALN	Certification Date:	Feb 15, 2021

Expiration Date: Feb 15, 2029

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
OXYGEN	13.00 %	13.03 %	G1	+/- 0.8% NIST Traceable	02/15/2021
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	98051010	SG9161286BAL	12.05 % OXYGEN/NITROGEN	0.7%	Dec 14, 2023

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Horiba MPA-510 W603MM58 O2	O2 Paramagnetic (Mason)	Feb 01, 2021

Triad Data Available Upon Request

Approved for Release

Airgas
an Air Liquide company

IN SERVICE 14 JUN 21 8

Airgas USA, LLC
525 North Industrial Loop Road
Tooele, UT 84074
Airgas.com

CTI
CV 9

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E02NI94E15AC040	Reference Number:	153-402028994-1
Cylinder Number:	ALM047993	Cylinder Volume:	144.8 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72021	Valve Outlet:	590
Gas Code:	O2,BALN	Certification Date:	Feb 16, 2021

Expiration Date: Feb 16, 2029

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
OXYGEN	5.500 %	5.513 %	G1	+/- 0.5% NIST Traceable	02/16/2021
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	11060717	CC338451	4.861 % OXYGEN/NITROGEN	0.4%	Dec 13, 2022

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Horiba MPA-510 W603MM58 O2	O2 Paramagnetic (Mason)	Feb 01, 2021

Triad Data Available Upon Request

PERMANENT NOTES:-NA-

NOTES:NO: 0.01PPM
CO: 0.02PPM
CO2: 0.01PPM

Approved for Release

ATTACHMENT 12
Startup/Shutdown Emissions

FCD: AQ-22
Title V: #13, #14

100scf Per Event Report

CT1 - GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:01 **Location:** Maxwell, CA

Tag Name: CT1_GasFlowTot_Event_100scf_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,765.08 Hours

Non-Operating Time: 442.92 Hours Report Time: 2,208.00 Hours

Unit Operation and Excess Events

Event Period			Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Code - Description	Code - Description
07/10/2021 13:28 07/10/2021 16:14 Cold Start - Gas	167	227.4		
07/10/2021 23:36 07/10/2021 23:41 Shut Down - Gas	6	0.8		
07/11/2021 09:21 07/11/2021 11:35 Warm Start - Gas	135	183.8		
07/12/2021 01:07 07/12/2021 01:11 Shut Down - Gas	5	0.2		
07/12/2021 15:38 07/12/2021 16:36 Warm Start - Gas	59	91.2		
07/12/2021 22:48 07/12/2021 22:53 Shut Down - Gas	6	0.8		
07/13/2021 07:23 07/13/2021 09:51 Warm Start - Gas	149	148.3		
07/13/2021 09:52 07/13/2021 09:57 Shut Down - Gas	6	0.3		
07/13/2021 12:04 07/13/2021 13:36 Warm Start - Gas	93	129.4		
07/13/2021 13:39 07/13/2021 13:44 Shut Down - Gas	6	0.3		
07/13/2021 14:45 07/13/2021 16:29 Warm Start - Gas	105	187.1		
07/13/2021 21:51 07/13/2021 21:56 Shut Down - Gas	6	0.3		
07/14/2021 03:25 07/14/2021 04:15 Hot Start - Gas	51	98.3		

100scf Per Event Report

CT1 - GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/04/2021 11:01 **Location:** Maxwell, CA
Tag Name: CT1_GasFlowTot_Event_100scf_1M SI = SampleInvalid, * = Excess Emission
Total Operating Time: 1,765.08 Hours
Non-Operating Time: 442.92 Hours Report Time: 2,208.00 Hours

Event Period			Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Code - Description	Code - Description
08/07/2021 03:23 08/07/2021 03:28 Shut Down - Gas	6	0.8		
08/07/2021 13:48 08/07/2021 14:50 Warm Start - Gas	63	102.3		
08/08/2021 04:04 08/08/2021 04:10 Shut Down - Gas	7	1.2		
08/08/2021 14:47 08/08/2021 15:50 Warm Start - Gas	64	101.1		
08/21/2021 00:08 08/21/2021 00:13 Shut Down - Gas	6	0.9		
08/23/2021 16:06 08/23/2021 17:55 Warm Start - Gas	110	155.6		
09/04/2021 03:24 09/04/2021 03:29 Shut Down - Gas	6	1.1		
09/04/2021 09:43 09/04/2021 10:47 Hot Start - Gas	65	104.9		
09/25/2021 22:21 09/25/2021 22:26 Shut Down - Gas	6	0.4		
09/29/2021 03:18 09/29/2021 03:53 Cold Start - Gas	36	28.9		
09/29/2021 03:54 09/29/2021 03:59 Shut Down - Gas	6	0.6		
09/29/2021 08:27 09/29/2021 09:51 Cold Start - Gas	85	127.9		

No excess emissions were found in the reporting period.

100scf Per Event Report

CT1 - GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:01 **Location:** Maxwell, CA

Tag Name: CT1_GasFlowTot_Event_100scf_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,765.08 Hours

Non-Operating Time: 442.92 Hours Report Time: 2,208.00 Hours

Event Invalid Information

No invalid events were found in the reporting period.

100scf Per Event Report

CT1 - GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:01 **Location:** Maxwell, CA

Tag Name: CT1_GasFlowTot_Event_100scf_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,765.08 Hours

Non-Operating Time: 442.92 Hours Report Time: 2,208.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary	
1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime in Minute(s)	0
3. Total Downtime as a percentage of operating time	0.00
4. Total Availability as a percentage of operating time	100.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/01/2021 00:00	0.0	0	0	0	0	0
07/01/2021 01:00	0.0	0	0	0	0	0
07/01/2021 02:00	0.0	0	0	0	0	0
07/01/2021 03:00	0.0	0	0	0	0	0
07/01/2021 04:00	0.0	0	0	0	0	0
07/01/2021 05:00	0.0	0	0	0	0	0
07/01/2021 06:00	0.0	0	0	0	0	0
07/01/2021 07:00	0.0	0	0	0	0	0
07/01/2021 08:00	0.0	0	0	0	0	0
07/01/2021 09:00	0.0	0	0	0	0	0
07/01/2021 10:00	0.0	0	0	0	0	0
07/01/2021 11:00	0.0	0	0	0	0	0
07/01/2021 12:00	0.0	0	0	0	0	0
07/01/2021 13:00	0.0	0	0	0	0	0
07/01/2021 14:00	0.0	0	0	0	0	0
07/01/2021 15:00	0.0	0	0	0	0	0
07/01/2021 16:00	0.0	0	0	0	0	0
07/01/2021 17:00	0.0	0	0	0	0	0
07/01/2021 18:00	0.0	0	0	0	0	0
07/01/2021 19:00	0.0	0	0	0	0	0
07/01/2021 20:00	0.0	0	0	0	0	0
07/01/2021 21:00	0.0	0	0	0	0	0
07/01/2021 22:00	0.0	0	0	0	0	0
07/01/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/02/2021 00:00	0.0	0	0	0	0	0
07/02/2021 01:00	0.0	0	0	0	0	0
07/02/2021 02:00	0.0	0	0	0	0	0
07/02/2021 03:00	0.0	0	0	0	0	0
07/02/2021 04:00	0.0	0	0	0	0	0
07/02/2021 05:00	0.0	0	0	0	0	0
07/02/2021 06:00	0.0	0	0	0	0	0
07/02/2021 07:00	0.0	0	0	0	0	0
07/02/2021 08:00	0.0	0	0	0	0	0
07/02/2021 09:00	0.0	0	0	0	0	0
07/02/2021 10:00	0.0	0	0	0	0	0
07/02/2021 11:00	0.0	0	0	0	0	0
07/02/2021 12:00	0.0	0	0	0	0	0
07/02/2021 13:00	0.0	0	0	0	0	0
07/02/2021 14:00	0.0	0	0	0	0	0
07/02/2021 15:00	0.0	0	0	0	0	0
07/02/2021 16:00	0.0	0	0	0	0	0
07/02/2021 17:00	0.0	0	0	0	0	0
07/02/2021 18:00	0.0	0	0	0	0	0
07/02/2021 19:00	0.0	0	0	0	0	0
07/02/2021 20:00	0.0	0	0	0	0	0
07/02/2021 21:00	0.0	0	0	0	0	0
07/02/2021 22:00	0.0	0	0	0	0	0
07/02/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/03/2021 00:00	0.0	0	0	0	0	0
07/03/2021 01:00	0.0	0	0	0	0	0
07/03/2021 02:00	0.0	0	0	0	0	0
07/03/2021 03:00	0.0	0	0	0	0	0
07/03/2021 04:00	0.0	0	0	0	0	0
07/03/2021 05:00	0.0	0	0	0	0	0
07/03/2021 06:00	0.0	0	0	0	0	0
07/03/2021 07:00	0.0	0	0	0	0	0
07/03/2021 08:00	0.0	0	0	0	0	0
07/03/2021 09:00	0.0	0	0	0	0	0
07/03/2021 10:00	0.0	0	0	0	0	0
07/03/2021 11:00	0.0	0	0	0	0	0
07/03/2021 12:00	0.0	0	0	0	0	0
07/03/2021 13:00	0.0	0	0	0	0	0
07/03/2021 14:00	0.0	0	0	0	0	0
07/03/2021 15:00	0.0	0	0	0	0	0
07/03/2021 16:00	0.0	0	0	0	0	0
07/03/2021 17:00	0.0	0	0	0	0	0
07/03/2021 18:00	0.0	0	0	0	0	0
07/03/2021 19:00	0.0	0	0	0	0	0
07/03/2021 20:00	0.0	0	0	0	0	0
07/03/2021 21:00	0.0	0	0	0	0	0
07/03/2021 22:00	0.0	0	0	0	0	0
07/03/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/04/2021 00:00	0.0	0	0	0	0	0
07/04/2021 01:00	0.0	0	0	0	0	0
07/04/2021 02:00	0.0	0	0	0	0	0
07/04/2021 03:00	0.0	0	0	0	0	0
07/04/2021 04:00	0.0	0	0	0	0	0
07/04/2021 05:00	0.0	0	0	0	0	0
07/04/2021 06:00	0.0	0	0	0	0	0
07/04/2021 07:00	0.0	0	0	0	0	0
07/04/2021 08:00	0.0	0	0	0	0	0
07/04/2021 09:00	0.0	0	0	0	0	0
07/04/2021 10:00	0.0	0	0	0	0	0
07/04/2021 11:00	0.0	0	0	0	0	0
07/04/2021 12:00	0.0	0	0	0	0	0
07/04/2021 13:00	0.0	0	0	0	0	0
07/04/2021 14:00	0.0	0	0	0	0	0
07/04/2021 15:00	0.0	0	0	0	0	0
07/04/2021 16:00	0.0	0	0	0	0	0
07/04/2021 17:00	0.0	0	0	0	0	0
07/04/2021 18:00	0.0	0	0	0	0	0
07/04/2021 19:00	0.0	0	0	0	0	0
07/04/2021 20:00	0.0	0	0	0	0	0
07/04/2021 21:00	0.0	0	0	0	0	0
07/04/2021 22:00	0.0	0	0	0	0	0
07/04/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/05/2021 00:00	0.0	0	0	0	0	0
07/05/2021 01:00	0.0	0	0	0	0	0
07/05/2021 02:00	0.0	0	0	0	0	0
07/05/2021 03:00	0.0	0	0	0	0	0
07/05/2021 04:00	0.0	0	0	0	0	0
07/05/2021 05:00	0.0	0	0	0	0	0
07/05/2021 06:00	0.0	0	0	0	0	0
07/05/2021 07:00	0.0	0	0	0	0	0
07/05/2021 08:00	0.0	0	0	0	0	0
07/05/2021 09:00	0.0	0	0	0	0	0
07/05/2021 10:00	0.0	0	0	0	0	0
07/05/2021 11:00	0.0	0	0	0	0	0
07/05/2021 12:00	0.0	0	0	0	0	0
07/05/2021 13:00	0.0	0	0	0	0	0
07/05/2021 14:00	0.0	0	0	0	0	0
07/05/2021 15:00	0.0	0	0	0	0	0
07/05/2021 16:00	0.0	0	0	0	0	0
07/05/2021 17:00	0.0	0	0	0	0	0
07/05/2021 18:00	0.0	0	0	0	0	0
07/05/2021 19:00	0.0	0	0	0	0	0
07/05/2021 20:00	0.0	0	0	0	0	0
07/05/2021 21:00	0.0	0	0	0	0	0
07/05/2021 22:00	0.0	0	0	0	0	0
07/05/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/06/2021 00:00	0.0	0	0	0	0	0
07/06/2021 01:00	0.0	0	0	0	0	0
07/06/2021 02:00	0.0	0	0	0	0	0
07/06/2021 03:00	0.0	0	0	0	0	0
07/06/2021 04:00	0.0	0	0	0	0	0
07/06/2021 05:00	0.0	0	0	0	0	0
07/06/2021 06:00	0.0	0	0	0	0	0
07/06/2021 07:00	0.0	0	0	0	0	0
07/06/2021 08:00	0.0	0	0	0	0	0
07/06/2021 09:00	0.0	0	0	0	0	0
07/06/2021 10:00	0.0	0	0	0	0	0
07/06/2021 11:00	0.0	0	0	0	0	0
07/06/2021 12:00	0.0	0	0	0	0	0
07/06/2021 13:00	0.0	0	0	0	0	0
07/06/2021 14:00	0.0	0	0	0	0	0
07/06/2021 15:00	0.0	0	0	0	0	0
07/06/2021 16:00	0.0	0	0	0	0	0
07/06/2021 17:00	0.0	0	0	0	0	0
07/06/2021 18:00	0.0	0	0	0	0	0
07/06/2021 19:00	0.0	0	0	0	0	0
07/06/2021 20:00	0.0	0	0	0	0	0
07/06/2021 21:00	0.0	0	0	0	0	0
07/06/2021 22:00	0.0	0	0	0	0	0
07/06/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/07/2021 00:00	0.0	0	0	0	0	0
07/07/2021 01:00	0.0	0	0	0	0	0
07/07/2021 02:00	0.0	0	0	0	0	0
07/07/2021 03:00	0.0	0	0	0	0	0
07/07/2021 04:00	0.0	0	0	0	0	0
07/07/2021 05:00	0.0	0	0	0	0	0
07/07/2021 06:00	0.0	0	0	0	0	0
07/07/2021 07:00	0.0	0	0	0	0	0
07/07/2021 08:00	0.0	0	0	0	0	0
07/07/2021 09:00	0.0	0	0	0	0	0
07/07/2021 10:00	0.0	0	0	0	0	0
07/07/2021 11:00	0.0	0	0	0	0	0
07/07/2021 12:00	0.0	0	0	0	0	0
07/07/2021 13:00	0.0	0	0	0	0	0
07/07/2021 14:00	0.0	0	0	0	0	0
07/07/2021 15:00	0.0	0	0	0	0	0
07/07/2021 16:00	0.0	0	0	0	0	0
07/07/2021 17:00	0.0	0	0	0	0	0
07/07/2021 18:00	0.0	0	0	0	0	0
07/07/2021 19:00	0.0	0	0	0	0	0
07/07/2021 20:00	0.0	0	0	0	0	0
07/07/2021 21:00	0.0	0	0	0	0	0
07/07/2021 22:00	0.0	0	0	0	0	0
07/07/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/08/2021 00:00	0.0	0	0	0	0	0
07/08/2021 01:00	0.0	0	0	0	0	0
07/08/2021 02:00	0.0	0	0	0	0	0
07/08/2021 03:00	0.0	0	0	0	0	0
07/08/2021 04:00	0.0	0	0	0	0	0
07/08/2021 05:00	0.0	0	0	0	0	0
07/08/2021 06:00	0.0	0	0	0	0	0
07/08/2021 07:00	0.0	0	0	0	0	0
07/08/2021 08:00	0.0	0	0	0	0	0
07/08/2021 09:00	0.0	0	0	0	0	0
07/08/2021 10:00	0.0	0	0	0	0	0
07/08/2021 11:00	0.0	0	0	0	0	0
07/08/2021 12:00	0.0	0	0	0	0	0
07/08/2021 13:00	0.0	0	0	0	0	0
07/08/2021 14:00	0.0	0	0	0	0	0
07/08/2021 15:00	0.0	0	0	0	0	0
07/08/2021 16:00	0.0	0	0	0	0	0
07/08/2021 17:00	0.0	0	0	0	0	0
07/08/2021 18:00	0.0	0	0	0	0	0
07/08/2021 19:00	0.0	0	0	0	0	0
07/08/2021 20:00	0.0	0	0	0	0	0
07/08/2021 21:00	0.0	0	0	0	0	0
07/08/2021 22:00	0.0	0	0	0	0	0
07/08/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/09/2021 00:00	0.0	0	0	0	0	0
07/09/2021 01:00	0.0	0	0	0	0	0
07/09/2021 02:00	0.0	0	0	0	0	0
07/09/2021 03:00	0.0	0	0	0	0	0
07/09/2021 04:00	0.0	0	0	0	0	0
07/09/2021 05:00	0.0	0	0	0	0	0
07/09/2021 06:00	0.0	0	0	0	0	0
07/09/2021 07:00	0.0	0	0	0	0	0
07/09/2021 08:00	0.0	0	0	0	0	0
07/09/2021 09:00	0.0	0	0	0	0	0
07/09/2021 10:00	0.0	0	0	0	0	0
07/09/2021 11:00	0.0	0	0	0	0	0
07/09/2021 12:00	0.0	0	0	0	0	0
07/09/2021 13:00	0.0	0	0	0	0	0
07/09/2021 14:00	0.0	0	0	0	0	0
07/09/2021 15:00	0.0	0	0	0	0	0
07/09/2021 16:00	0.0	0	0	0	0	0
07/09/2021 17:00	0.0	0	0	0	0	0
07/09/2021 18:00	0.0	0	0	0	0	0
07/09/2021 19:00	0.0	0	0	0	0	0
07/09/2021 20:00	0.0	0	0	0	0	0
07/09/2021 21:00	0.0	0	0	0	0	0
07/09/2021 22:00	0.0	0	0	0	0	0
07/09/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/10/2021 00:00	0.0	0	0	0	0	0
07/10/2021 01:00	0.0	0	0	0	0	0
07/10/2021 02:00	0.0	0	0	0	0	0
07/10/2021 03:00	0.0	0	0	0	0	0
07/10/2021 04:00	0.0	0	0	0	0	0
07/10/2021 05:00	0.0	0	0	0	0	0
07/10/2021 06:00	0.0	0	0	0	0	0
07/10/2021 07:00	0.0	0	0	0	0	0
07/10/2021 08:00	0.0	0	0	0	0	0
07/10/2021 09:00	0.0	0	0	0	0	0
07/10/2021 10:00	0.0	0	0	0	0	0
07/10/2021 11:00	0.0	0	0	0	0	0
07/10/2021 12:00	0.0	0	0	0	0	0
07/10/2021 13:00	43.3	1	0	0	0	0
07/10/2021 14:00	24.9	1	0	0	0	0
07/10/2021 15:00	101.5	1	0	0	0	0
07/10/2021 16:00	5.6	1	0	0	0	0
07/10/2021 17:00	0.0	0	0	0	0	1
07/10/2021 18:00	0.0	0	0	0	0	1
07/10/2021 19:00	0.0	0	0	0	0	1
07/10/2021 20:00	0.0	0	0	0	0	1
07/10/2021 21:00	0.0	0	0	0	0	1
07/10/2021 22:00	0.0	0	0	0	0	1
07/10/2021 23:00	3.8	0	0	0	1	0
Average/Sum#:	179.1 #	4 #	0 #	0 #	1 #	6 #
Minimum:	0.0	0	0	0	0	0
Maximum:	101.5	1	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/11/2021 00:00	0.0	0	0	0	0	0
07/11/2021 01:00	0.0	0	0	0	0	0
07/11/2021 02:00	0.0	0	0	0	0	0
07/11/2021 03:00	0.0	0	0	0	0	0
07/11/2021 04:00	0.0	0	0	0	0	0
07/11/2021 05:00	0.0	0	0	0	0	0
07/11/2021 06:00	0.0	0	0	0	0	0
07/11/2021 07:00	0.0	0	0	0	0	0
07/11/2021 08:00	0.0	0	0	0	0	0
07/11/2021 09:00	43.2	0	1	0	0	0
07/11/2021 10:00	36.4	0	1	0	0	0
07/11/2021 11:00	52.1	0	1	0	0	0
07/11/2021 12:00	0.0	0	0	0	0	1
07/11/2021 13:00	0.0	0	0	0	0	1
07/11/2021 14:00	0.0	0	0	0	0	1
07/11/2021 15:00	0.0	0	0	0	0	1
07/11/2021 16:00	0.0	0	0	0	0	1
07/11/2021 17:00	0.0	0	0	0	0	1
07/11/2021 18:00	0.0	0	0	0	0	1
07/11/2021 19:00	0.0	0	0	0	0	1
07/11/2021 20:00	0.0	0	0	0	0	1
07/11/2021 21:00	0.0	0	0	0	0	1
07/11/2021 22:00	0.0	0	0	0	0	1
07/11/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	131.7 #	0 #	3 #	0 #	0 #	12 #
Minimum:	0.0	0	0	0	0	0
Maximum:	52.1	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/12/2021 00:00	0.0	0	0	0	0	1
07/12/2021 01:00	3.7	0	0	0	1	0
07/12/2021 02:00	0.0	0	0	0	0	0
07/12/2021 03:00	0.0	0	0	0	0	0
07/12/2021 04:00	0.0	0	0	0	0	0
07/12/2021 05:00	0.0	0	0	0	0	0
07/12/2021 06:00	0.0	0	0	0	0	0
07/12/2021 07:00	0.0	0	0	0	0	0
07/12/2021 08:00	0.0	0	0	0	0	0
07/12/2021 09:00	0.0	0	0	0	0	0
07/12/2021 10:00	0.0	0	0	0	0	0
07/12/2021 11:00	0.0	0	0	0	0	0
07/12/2021 12:00	0.0	0	0	0	0	0
07/12/2021 13:00	0.0	0	0	0	0	0
07/12/2021 14:00	0.0	0	0	0	0	0
07/12/2021 15:00	44.6	0	1	0	0	0
07/12/2021 16:00	47.6	0	1	0	0	0
07/12/2021 17:00	0.0	0	0	0	0	1
07/12/2021 18:00	0.0	0	0	0	0	1
07/12/2021 19:00	0.0	0	0	0	0	1
07/12/2021 20:00	0.0	0	0	0	0	1
07/12/2021 21:00	0.0	0	0	0	0	1
07/12/2021 22:00	3.3	0	0	0	1	0
07/12/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	99.2 #	0 #	2 #	0 #	2 #	6 #
Minimum:	0.0	0	0	0	0	0
Maximum:	47.6	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/13/2021 00:00	0.0	0	0	0	0	0
07/13/2021 01:00	0.0	0	0	0	0	0
07/13/2021 02:00	0.0	0	0	0	0	0
07/13/2021 03:00	0.0	0	0	0	0	0
07/13/2021 04:00	0.0	0	0	0	0	0
07/13/2021 05:00	0.0	0	0	0	0	0
07/13/2021 06:00	0.0	0	0	0	0	0
07/13/2021 07:00	44.8	0	1	0	0	0
07/13/2021 08:00	47.4	0	1	0	0	0
07/13/2021 09:00	4.6	0	1	0	1	0
07/13/2021 10:00	0.0	0	0	0	0	0
07/13/2021 11:00	0.0	0	0	0	0	0
07/13/2021 12:00	67.2	0	1	0	0	0
07/13/2021 13:00	30.3	0	1	0	1	0
07/13/2021 14:00	7.3	0	1	0	0	0
07/13/2021 15:00	302.1	0	1	0	0	0
07/13/2021 16:00	106.1	0	1	0	0	0
07/13/2021 17:00	0.0	0	0	0	0	1
07/13/2021 18:00	0.0	0	0	0	0	1
07/13/2021 19:00	0.0	0	0	0	0	1
07/13/2021 20:00	0.0	0	0	0	0	1
07/13/2021 21:00	5.1	0	0	0	1	0
07/13/2021 22:00	0.0	0	0	0	0	0
07/13/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	614.9 #	0 #	8 #	0 #	3 #	4 #
Minimum:	0.0	0	0	0	0	0
Maximum:	302.1	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/14/2021 00:00	0.0	0	0	0	0	0
07/14/2021 01:00	0.0	0	0	0	0	0
07/14/2021 02:00	0.0	0	0	0	0	0
07/14/2021 03:00	158.1	0	0	1	0	0
07/14/2021 04:00	18.4	0	0	1	0	0
07/14/2021 05:00	0.0	0	0	0	0	1
07/14/2021 06:00	0.0	0	0	0	0	1
07/14/2021 07:00	0.0	0	0	0	0	1
07/14/2021 08:00	0.0	0	0	0	0	1
07/14/2021 09:00	0.0	0	0	0	0	1
07/14/2021 10:00	0.0	0	0	0	0	1
07/14/2021 11:00	0.0	0	0	0	0	1
07/14/2021 12:00	0.0	0	0	0	0	1
07/14/2021 13:00	0.0	0	0	0	0	1
07/14/2021 14:00	0.0	0	0	0	0	1
07/14/2021 15:00	0.0	0	0	0	0	1
07/14/2021 16:00	0.0	0	0	0	0	1
07/14/2021 17:00	0.0	0	0	0	0	1
07/14/2021 18:00	0.0	0	0	0	0	1
07/14/2021 19:00	0.0	0	0	0	0	1
07/14/2021 20:00	0.0	0	0	0	0	1
07/14/2021 21:00	0.0	0	0	0	0	1
07/14/2021 22:00	0.0	0	0	0	0	1
07/14/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	176.5 #	0 #	0 #	2 #	0 #	19 #
Minimum:	0.0	0	0	0	0	0
Maximum:	158.1	0	0	1	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/15/2021 00:00	0.0	0	0	0	0	1
07/15/2021 01:00	0.0	0	0	0	0	1
07/15/2021 02:00	0.0	0	0	0	0	1
07/15/2021 03:00	0.0	0	0	0	0	1
07/15/2021 04:00	0.0	0	0	0	0	1
07/15/2021 05:00	0.0	0	0	0	0	1
07/15/2021 06:00	0.0	0	0	0	0	1
07/15/2021 07:00	0.0	0	0	0	0	1
07/15/2021 08:00	0.0	0	0	0	0	1
07/15/2021 09:00	0.0	0	0	0	0	1
07/15/2021 10:00	0.0	0	0	0	0	1
07/15/2021 11:00	0.0	0	0	0	0	1
07/15/2021 12:00	0.0	0	0	0	0	1
07/15/2021 13:00	0.0	0	0	0	0	1
07/15/2021 14:00	0.0	0	0	0	0	1
07/15/2021 15:00	0.0	0	0	0	0	1
07/15/2021 16:00	0.0	0	0	0	0	1
07/15/2021 17:00	0.0	0	0	0	0	1
07/15/2021 18:00	0.0	0	0	0	0	1
07/15/2021 19:00	0.0	0	0	0	0	1
07/15/2021 20:00	0.0	0	0	0	0	1
07/15/2021 21:00	0.0	0	0	0	0	1
07/15/2021 22:00	0.0	0	0	0	0	1
07/15/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/16/2021 00:00	0.0	0	0	0	0	1
07/16/2021 01:00	0.0	0	0	0	0	1
07/16/2021 02:00	0.0	0	0	0	0	1
07/16/2021 03:00	0.0	0	0	0	0	1
07/16/2021 04:00	0.0	0	0	0	0	1
07/16/2021 05:00	0.0	0	0	0	0	1
07/16/2021 06:00	0.0	0	0	0	0	1
07/16/2021 07:00	0.0	0	0	0	0	1
07/16/2021 08:00	0.0	0	0	0	0	1
07/16/2021 09:00	0.0	0	0	0	0	1
07/16/2021 10:00	0.0	0	0	0	0	1
07/16/2021 11:00	0.0	0	0	0	0	1
07/16/2021 12:00	0.0	0	0	0	0	1
07/16/2021 13:00	0.0	0	0	0	0	1
07/16/2021 14:00	0.0	0	0	0	0	1
07/16/2021 15:00	0.0	0	0	0	0	1
07/16/2021 16:00	0.0	0	0	0	0	1
07/16/2021 17:00	0.0	0	0	0	0	1
07/16/2021 18:00	0.0	0	0	0	0	1
07/16/2021 19:00	0.0	0	0	0	0	1
07/16/2021 20:00	0.0	0	0	0	0	1
07/16/2021 21:00	0.0	0	0	0	0	1
07/16/2021 22:00	0.0	0	0	0	0	1
07/16/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/17/2021 00:00	0.0	0	0	0	0	1
07/17/2021 01:00	0.0	0	0	0	0	1
07/17/2021 02:00	0.0	0	0	0	0	1
07/17/2021 03:00	0.0	0	0	0	0	1
07/17/2021 04:00	0.0	0	0	0	0	1
07/17/2021 05:00	0.0	0	0	0	0	1
07/17/2021 06:00	0.0	0	0	0	0	1
07/17/2021 07:00	0.0	0	0	0	0	1
07/17/2021 08:00	0.0	0	0	0	0	1
07/17/2021 09:00	0.0	0	0	0	0	1
07/17/2021 10:00	0.0	0	0	0	0	1
07/17/2021 11:00	0.0	0	0	0	0	1
07/17/2021 12:00	0.0	0	0	0	0	1
07/17/2021 13:00	0.0	0	0	0	0	1
07/17/2021 14:00	0.0	0	0	0	0	1
07/17/2021 15:00	0.0	0	0	0	0	1
07/17/2021 16:00	0.0	0	0	0	0	1
07/17/2021 17:00	0.0	0	0	0	0	1
07/17/2021 18:00	0.0	0	0	0	0	1
07/17/2021 19:00	0.0	0	0	0	0	1
07/17/2021 20:00	0.0	0	0	0	0	1
07/17/2021 21:00	0.0	0	0	0	0	1
07/17/2021 22:00	0.0	0	0	0	0	1
07/17/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/18/2021 00:00	0.0	0	0	0	0	1
07/18/2021 01:00	0.0	0	0	0	0	1
07/18/2021 02:00	0.0	0	0	0	0	1
07/18/2021 03:00	0.0	0	0	0	0	1
07/18/2021 04:00	0.0	0	0	0	0	1
07/18/2021 05:00	0.0	0	0	0	0	1
07/18/2021 06:00	0.0	0	0	0	0	1
07/18/2021 07:00	0.0	0	0	0	0	1
07/18/2021 08:00	0.0	0	0	0	0	1
07/18/2021 09:00	0.0	0	0	0	0	1
07/18/2021 10:00	0.0	0	0	0	0	1
07/18/2021 11:00	0.0	0	0	0	0	1
07/18/2021 12:00	0.0	0	0	0	0	1
07/18/2021 13:00	0.0	0	0	0	0	1
07/18/2021 14:00	0.0	0	0	0	0	1
07/18/2021 15:00	0.0	0	0	0	0	1
07/18/2021 16:00	0.0	0	0	0	0	1
07/18/2021 17:00	0.0	0	0	0	0	1
07/18/2021 18:00	0.0	0	0	0	0	1
07/18/2021 19:00	0.0	0	0	0	0	1
07/18/2021 20:00	0.0	0	0	0	0	1
07/18/2021 21:00	0.0	0	0	0	0	1
07/18/2021 22:00	0.0	0	0	0	0	1
07/18/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/19/2021 00:00	0.0	0	0	0	0	1
07/19/2021 01:00	0.0	0	0	0	0	1
07/19/2021 02:00	0.0	0	0	0	0	1
07/19/2021 03:00	0.0	0	0	0	0	1
07/19/2021 04:00	0.0	0	0	0	0	1
07/19/2021 05:00	0.0	0	0	0	0	1
07/19/2021 06:00	0.0	0	0	0	0	1
07/19/2021 07:00	0.0	0	0	0	0	1
07/19/2021 08:00	0.0	0	0	0	0	1
07/19/2021 09:00	0.0	0	0	0	0	1
07/19/2021 10:00	0.0	0	0	0	0	1
07/19/2021 11:00	0.0	0	0	0	0	1
07/19/2021 12:00	0.0	0	0	0	0	1
07/19/2021 13:00	0.0	0	0	0	0	1
07/19/2021 14:00	0.0	0	0	0	0	1
07/19/2021 15:00	0.0	0	0	0	0	1
07/19/2021 16:00	0.0	0	0	0	0	1
07/19/2021 17:00	0.0	0	0	0	0	1
07/19/2021 18:00	0.0	0	0	0	0	1
07/19/2021 19:00	0.0	0	0	0	0	1
07/19/2021 20:00	0.0	0	0	0	0	1
07/19/2021 21:00	0.0	0	0	0	0	1
07/19/2021 22:00	0.0	0	0	0	0	1
07/19/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/20/2021 00:00	0.0	0	0	0	0	1
07/20/2021 01:00	0.0	0	0	0	0	1
07/20/2021 02:00	0.0	0	0	0	0	1
07/20/2021 03:00	0.0	0	0	0	0	1
07/20/2021 04:00	0.0	0	0	0	0	1
07/20/2021 05:00	0.0	0	0	0	0	1
07/20/2021 06:00	0.0	0	0	0	0	1
07/20/2021 07:00	0.0	0	0	0	0	1
07/20/2021 08:00	0.0	0	0	0	0	1
07/20/2021 09:00	0.0	0	0	0	0	1
07/20/2021 10:00	0.0	0	0	0	0	1
07/20/2021 11:00	0.0	0	0	0	0	1
07/20/2021 12:00	0.0	0	0	0	0	1
07/20/2021 13:00	0.0	0	0	0	0	1
07/20/2021 14:00	0.0	0	0	0	0	1
07/20/2021 15:00	0.0	0	0	0	0	1
07/20/2021 16:00	0.0	0	0	0	0	1
07/20/2021 17:00	0.0	0	0	0	0	1
07/20/2021 18:00	0.0	0	0	0	0	1
07/20/2021 19:00	0.0	0	0	0	0	1
07/20/2021 20:00	0.0	0	0	0	0	1
07/20/2021 21:00	0.0	0	0	0	0	1
07/20/2021 22:00	0.0	0	0	0	0	1
07/20/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/21/2021 00:00	0.0	0	0	0	0	1
07/21/2021 01:00	0.0	0	0	0	0	1
07/21/2021 02:00	0.0	0	0	0	0	1
07/21/2021 03:00	0.0	0	0	0	0	1
07/21/2021 04:00	0.0	0	0	0	0	1
07/21/2021 05:00	0.0	0	0	0	0	1
07/21/2021 06:00	0.0	0	0	0	0	1
07/21/2021 07:00	0.0	0	0	0	0	1
07/21/2021 08:00	0.0	0	0	0	0	1
07/21/2021 09:00	0.0	0	0	0	0	1
07/21/2021 10:00	0.0	0	0	0	0	1
07/21/2021 11:00	0.0	0	0	0	0	1
07/21/2021 12:00	0.0	0	0	0	0	1
07/21/2021 13:00	0.0	0	0	0	0	1
07/21/2021 14:00	0.0	0	0	0	0	1
07/21/2021 15:00	0.0	0	0	0	0	1
07/21/2021 16:00	0.0	0	0	0	0	1
07/21/2021 17:00	0.0	0	0	0	0	1
07/21/2021 18:00	0.0	0	0	0	0	1
07/21/2021 19:00	0.0	0	0	0	0	1
07/21/2021 20:00	0.0	0	0	0	0	1
07/21/2021 21:00	0.0	0	0	0	0	1
07/21/2021 22:00	0.0	0	0	0	0	1
07/21/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/22/2021 00:00	0.0	0	0	0	0	1
07/22/2021 01:00	0.0	0	0	0	0	1
07/22/2021 02:00	0.0	0	0	0	0	1
07/22/2021 03:00	0.0	0	0	0	0	1
07/22/2021 04:00	0.0	0	0	0	0	1
07/22/2021 05:00	0.0	0	0	0	0	1
07/22/2021 06:00	0.0	0	0	0	0	1
07/22/2021 07:00	0.0	0	0	0	0	1
07/22/2021 08:00	0.0	0	0	0	0	1
07/22/2021 09:00	0.0	0	0	0	0	1
07/22/2021 10:00	0.0	0	0	0	0	1
07/22/2021 11:00	0.0	0	0	0	0	1
07/22/2021 12:00	0.0	0	0	0	0	1
07/22/2021 13:00	0.0	0	0	0	0	1
07/22/2021 14:00	0.0	0	0	0	0	1
07/22/2021 15:00	0.0	0	0	0	0	1
07/22/2021 16:00	0.0	0	0	0	0	1
07/22/2021 17:00	0.0	0	0	0	0	1
07/22/2021 18:00	0.0	0	0	0	0	1
07/22/2021 19:00	0.0	0	0	0	0	1
07/22/2021 20:00	0.0	0	0	0	0	1
07/22/2021 21:00	0.0	0	0	0	0	1
07/22/2021 22:00	0.0	0	0	0	0	1
07/22/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/23/2021 00:00	0.0	0	0	0	0	1
07/23/2021 01:00	0.0	0	0	0	0	1
07/23/2021 02:00	0.0	0	0	0	0	1
07/23/2021 03:00	0.0	0	0	0	0	1
07/23/2021 04:00	0.0	0	0	0	0	1
07/23/2021 05:00	0.0	0	0	0	0	1
07/23/2021 06:00	0.0	0	0	0	0	1
07/23/2021 07:00	0.0	0	0	0	0	1
07/23/2021 08:00	0.0	0	0	0	0	1
07/23/2021 09:00	0.0	0	0	0	0	1
07/23/2021 10:00	0.0	0	0	0	0	1
07/23/2021 11:00	0.0	0	0	0	0	1
07/23/2021 12:00	0.0	0	0	0	0	1
07/23/2021 13:00	0.0	0	0	0	0	1
07/23/2021 14:00	0.0	0	0	0	0	1
07/23/2021 15:00	0.0	0	0	0	0	1
07/23/2021 16:00	0.0	0	0	0	0	1
07/23/2021 17:00	0.0	0	0	0	0	1
07/23/2021 18:00	0.0	0	0	0	0	1
07/23/2021 19:00	0.0	0	0	0	0	1
07/23/2021 20:00	0.0	0	0	0	0	1
07/23/2021 21:00	0.0	0	0	0	0	1
07/23/2021 22:00	0.0	0	0	0	0	1
07/23/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/24/2021 00:00	0.0	0	0	0	0	1
07/24/2021 01:00	0.0	0	0	0	0	1
07/24/2021 02:00	0.0	0	0	0	0	1
07/24/2021 03:00	0.0	0	0	0	0	1
07/24/2021 04:00	0.0	0	0	0	0	1
07/24/2021 05:00	0.0	0	0	0	0	1
07/24/2021 06:00	0.0	0	0	0	0	1
07/24/2021 07:00	0.0	0	0	0	0	1
07/24/2021 08:00	0.0	0	0	0	0	1
07/24/2021 09:00	0.0	0	0	0	0	1
07/24/2021 10:00	0.0	0	0	0	0	1
07/24/2021 11:00	0.0	0	0	0	0	1
07/24/2021 12:00	0.0	0	0	0	0	1
07/24/2021 13:00	0.0	0	0	0	0	1
07/24/2021 14:00	0.0	0	0	0	0	1
07/24/2021 15:00	0.0	0	0	0	0	1
07/24/2021 16:00	0.0	0	0	0	0	1
07/24/2021 17:00	0.0	0	0	0	0	1
07/24/2021 18:00	0.0	0	0	0	0	1
07/24/2021 19:00	0.0	0	0	0	0	1
07/24/2021 20:00	0.0	0	0	0	0	1
07/24/2021 21:00	0.0	0	0	0	0	1
07/24/2021 22:00	0.0	0	0	0	0	1
07/24/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/25/2021 00:00	0.0	0	0	0	0	1
07/25/2021 01:00	0.0	0	0	0	0	1
07/25/2021 02:00	0.0	0	0	0	0	1
07/25/2021 03:00	0.0	0	0	0	0	1
07/25/2021 04:00	0.0	0	0	0	0	1
07/25/2021 05:00	0.0	0	0	0	0	1
07/25/2021 06:00	0.0	0	0	0	0	1
07/25/2021 07:00	0.0	0	0	0	0	1
07/25/2021 08:00	0.0	0	0	0	0	1
07/25/2021 09:00	0.0	0	0	0	0	1
07/25/2021 10:00	0.0	0	0	0	0	1
07/25/2021 11:00	0.0	0	0	0	0	1
07/25/2021 12:00	0.0	0	0	0	0	1
07/25/2021 13:00	0.0	0	0	0	0	1
07/25/2021 14:00	0.0	0	0	0	0	1
07/25/2021 15:00	0.0	0	0	0	0	1
07/25/2021 16:00	0.0	0	0	0	0	1
07/25/2021 17:00	0.0	0	0	0	0	1
07/25/2021 18:00	0.0	0	0	0	0	1
07/25/2021 19:00	0.0	0	0	0	0	1
07/25/2021 20:00	0.0	0	0	0	0	1
07/25/2021 21:00	0.0	0	0	0	0	1
07/25/2021 22:00	0.0	0	0	0	0	1
07/25/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/26/2021 00:00	0.0	0	0	0	0	1
07/26/2021 01:00	0.0	0	0	0	0	1
07/26/2021 02:00	0.0	0	0	0	0	1
07/26/2021 03:00	0.0	0	0	0	0	1
07/26/2021 04:00	0.0	0	0	0	0	1
07/26/2021 05:00	0.0	0	0	0	0	1
07/26/2021 06:00	0.0	0	0	0	0	1
07/26/2021 07:00	0.0	0	0	0	0	1
07/26/2021 08:00	0.0	0	0	0	0	1
07/26/2021 09:00	0.0	0	0	0	0	1
07/26/2021 10:00	0.0	0	0	0	0	1
07/26/2021 11:00	0.0	0	0	0	0	1
07/26/2021 12:00	0.0	0	0	0	0	1
07/26/2021 13:00	0.0	0	0	0	0	1
07/26/2021 14:00	0.0	0	0	0	0	1
07/26/2021 15:00	0.0	0	0	0	0	1
07/26/2021 16:00	0.0	0	0	0	0	1
07/26/2021 17:00	0.0	0	0	0	0	1
07/26/2021 18:00	0.0	0	0	0	0	1
07/26/2021 19:00	0.0	0	0	0	0	1
07/26/2021 20:00	0.0	0	0	0	0	1
07/26/2021 21:00	0.0	0	0	0	0	1
07/26/2021 22:00	0.0	0	0	0	0	1
07/26/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/27/2021 00:00	0.0	0	0	0	0	1
07/27/2021 01:00	0.0	0	0	0	0	1
07/27/2021 02:00	0.0	0	0	0	0	1
07/27/2021 03:00	0.0	0	0	0	0	1
07/27/2021 04:00	0.0	0	0	0	0	1
07/27/2021 05:00	0.0	0	0	0	0	1
07/27/2021 06:00	0.0	0	0	0	0	1
07/27/2021 07:00	0.0	0	0	0	0	1
07/27/2021 08:00	0.0	0	0	0	0	1
07/27/2021 09:00	0.0	0	0	0	0	1
07/27/2021 10:00	0.0	0	0	0	0	1
07/27/2021 11:00	0.0	0	0	0	0	1
07/27/2021 12:00	0.0	0	0	0	0	1
07/27/2021 13:00	0.0	0	0	0	0	1
07/27/2021 14:00	0.0	0	0	0	0	1
07/27/2021 15:00	0.0	0	0	0	0	1
07/27/2021 16:00	0.0	0	0	0	0	1
07/27/2021 17:00	0.0	0	0	0	0	1
07/27/2021 18:00	0.0	0	0	0	0	1
07/27/2021 19:00	0.0	0	0	0	0	1
07/27/2021 20:00	0.0	0	0	0	0	1
07/27/2021 21:00	0.0	0	0	0	0	1
07/27/2021 22:00	0.0	0	0	0	0	1
07/27/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/28/2021 00:00	0.0	0	0	0	0	1
07/28/2021 01:00	0.0	0	0	0	0	1
07/28/2021 02:00	0.0	0	0	0	0	1
07/28/2021 03:00	0.0	0	0	0	0	1
07/28/2021 04:00	0.0	0	0	0	0	1
07/28/2021 05:00	0.0	0	0	0	0	1
07/28/2021 06:00	0.0	0	0	0	0	1
07/28/2021 07:00	0.0	0	0	0	0	1
07/28/2021 08:00	0.0	0	0	0	0	1
07/28/2021 09:00	0.0	0	0	0	0	1
07/28/2021 10:00	0.0	0	0	0	0	1
07/28/2021 11:00	0.0	0	0	0	0	1
07/28/2021 12:00	0.0	0	0	0	0	1
07/28/2021 13:00	0.0	0	0	0	0	1
07/28/2021 14:00	0.0	0	0	0	0	1
07/28/2021 15:00	0.0	0	0	0	0	1
07/28/2021 16:00	0.0	0	0	0	0	1
07/28/2021 17:00	0.0	0	0	0	0	1
07/28/2021 18:00	0.0	0	0	0	0	1
07/28/2021 19:00	0.0	0	0	0	0	1
07/28/2021 20:00	0.0	0	0	0	0	1
07/28/2021 21:00	0.0	0	0	0	0	1
07/28/2021 22:00	0.0	0	0	0	0	1
07/28/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/29/2021 00:00	0.0	0	0	0	0	1
07/29/2021 01:00	0.0	0	0	0	0	1
07/29/2021 02:00	0.0	0	0	0	0	1
07/29/2021 03:00	0.0	0	0	0	0	1
07/29/2021 04:00	0.0	0	0	0	0	1
07/29/2021 05:00	0.0	0	0	0	0	1
07/29/2021 06:00	0.0	0	0	0	0	1
07/29/2021 07:00	0.0	0	0	0	0	1
07/29/2021 08:00	0.0	0	0	0	0	1
07/29/2021 09:00	0.0	0	0	0	0	1
07/29/2021 10:00	0.0	0	0	0	0	1
07/29/2021 11:00	0.0	0	0	0	0	1
07/29/2021 12:00	0.0	0	0	0	0	1
07/29/2021 13:00	0.0	0	0	0	0	1
07/29/2021 14:00	0.0	0	0	0	0	1
07/29/2021 15:00	0.0	0	0	0	0	1
07/29/2021 16:00	0.0	0	0	0	0	1
07/29/2021 17:00	0.0	0	0	0	0	1
07/29/2021 18:00	0.0	0	0	0	0	1
07/29/2021 19:00	0.0	0	0	0	0	1
07/29/2021 20:00	0.0	0	0	0	0	1
07/29/2021 21:00	0.0	0	0	0	0	1
07/29/2021 22:00	0.0	0	0	0	0	1
07/29/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/30/2021 00:00	0.0	0	0	0	0	1
07/30/2021 01:00	0.0	0	0	0	0	1
07/30/2021 02:00	0.0	0	0	0	0	1
07/30/2021 03:00	0.0	0	0	0	0	1
07/30/2021 04:00	0.0	0	0	0	0	1
07/30/2021 05:00	0.0	0	0	0	0	1
07/30/2021 06:00	0.0	0	0	0	0	1
07/30/2021 07:00	0.0	0	0	0	0	1
07/30/2021 08:00	0.0	0	0	0	0	1
07/30/2021 09:00	0.0	0	0	0	0	1
07/30/2021 10:00	0.0	0	0	0	0	1
07/30/2021 11:00	0.0	0	0	0	0	1
07/30/2021 12:00	0.0	0	0	0	0	1
07/30/2021 13:00	0.0	0	0	0	0	1
07/30/2021 14:00	0.0	0	0	0	0	1
07/30/2021 15:00	0.0	0	0	0	0	1
07/30/2021 16:00	0.0	0	0	0	0	1
07/30/2021 17:00	0.0	0	0	0	0	1
07/30/2021 18:00	0.0	0	0	0	0	1
07/30/2021 19:00	0.0	0	0	0	0	1
07/30/2021 20:00	0.0	0	0	0	0	1
07/30/2021 21:00	0.0	0	0	0	0	1
07/30/2021 22:00	0.0	0	0	0	0	1
07/30/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/31/2021 00:00	0.0	0	0	0	0	1
07/31/2021 01:00	0.0	0	0	0	0	1
07/31/2021 02:00	0.0	0	0	0	0	1
07/31/2021 03:00	0.0	0	0	0	0	1
07/31/2021 04:00	0.0	0	0	0	0	1
07/31/2021 05:00	0.0	0	0	0	0	1
07/31/2021 06:00	0.0	0	0	0	0	1
07/31/2021 07:00	0.0	0	0	0	0	1
07/31/2021 08:00	0.0	0	0	0	0	1
07/31/2021 09:00	0.0	0	0	0	0	1
07/31/2021 10:00	0.0	0	0	0	0	1
07/31/2021 11:00	0.0	0	0	0	0	1
07/31/2021 12:00	0.0	0	0	0	0	1
07/31/2021 13:00	0.0	0	0	0	0	1
07/31/2021 14:00	0.0	0	0	0	0	1
07/31/2021 15:00	0.0	0	0	0	0	1
07/31/2021 16:00	0.0	0	0	0	0	1
07/31/2021 17:00	0.0	0	0	0	0	1
07/31/2021 18:00	0.0	0	0	0	0	1
07/31/2021 19:00	0.0	0	0	0	0	1
07/31/2021 20:00	0.0	0	0	0	0	1
07/31/2021 21:00	0.0	0	0	0	0	1
07/31/2021 22:00	0.0	0	0	0	0	1
07/31/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/01/2021 00:00	0.0	0	0	0	0	1
08/01/2021 01:00	0.0	0	0	0	0	1
08/01/2021 02:00	0.0	0	0	0	0	1
08/01/2021 03:00	0.0	0	0	0	0	1
08/01/2021 04:00	0.0	0	0	0	0	1
08/01/2021 05:00	0.0	0	0	0	0	1
08/01/2021 06:00	0.0	0	0	0	0	1
08/01/2021 07:00	0.0	0	0	0	0	1
08/01/2021 08:00	0.0	0	0	0	0	1
08/01/2021 09:00	0.0	0	0	0	0	1
08/01/2021 10:00	0.0	0	0	0	0	1
08/01/2021 11:00	0.0	0	0	0	0	1
08/01/2021 12:00	0.0	0	0	0	0	1
08/01/2021 13:00	0.0	0	0	0	0	1
08/01/2021 14:00	0.0	0	0	0	0	1
08/01/2021 15:00	0.0	0	0	0	0	1
08/01/2021 16:00	0.0	0	0	0	0	1
08/01/2021 17:00	0.0	0	0	0	0	1
08/01/2021 18:00	0.0	0	0	0	0	1
08/01/2021 19:00	0.0	0	0	0	0	1
08/01/2021 20:00	0.0	0	0	0	0	1
08/01/2021 21:00	0.0	0	0	0	0	1
08/01/2021 22:00	0.0	0	0	0	0	1
08/01/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/02/2021 00:00	0.0	0	0	0	0	1
08/02/2021 01:00	0.0	0	0	0	0	1
08/02/2021 02:00	0.0	0	0	0	0	1
08/02/2021 03:00	0.0	0	0	0	0	1
08/02/2021 04:00	0.0	0	0	0	0	1
08/02/2021 05:00	0.0	0	0	0	0	1
08/02/2021 06:00	0.0	0	0	0	0	1
08/02/2021 07:00	0.0	0	0	0	0	1
08/02/2021 08:00	0.0	0	0	0	0	1
08/02/2021 09:00	0.0	0	0	0	0	1
08/02/2021 10:00	0.0	0	0	0	0	1
08/02/2021 11:00	0.0	0	0	0	0	1
08/02/2021 12:00	0.0	0	0	0	0	1
08/02/2021 13:00	0.0	0	0	0	0	1
08/02/2021 14:00	0.0	0	0	0	0	1
08/02/2021 15:00	0.0	0	0	0	0	1
08/02/2021 16:00	0.0	0	0	0	0	1
08/02/2021 17:00	0.0	0	0	0	0	1
08/02/2021 18:00	0.0	0	0	0	0	1
08/02/2021 19:00	0.0	0	0	0	0	1
08/02/2021 20:00	0.0	0	0	0	0	1
08/02/2021 21:00	0.0	0	0	0	0	1
08/02/2021 22:00	0.0	0	0	0	0	1
08/02/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/03/2021 00:00	0.0	0	0	0	0	1
08/03/2021 01:00	0.0	0	0	0	0	1
08/03/2021 02:00	0.0	0	0	0	0	1
08/03/2021 03:00	0.0	0	0	0	0	1
08/03/2021 04:00	0.0	0	0	0	0	1
08/03/2021 05:00	0.0	0	0	0	0	1
08/03/2021 06:00	0.0	0	0	0	0	1
08/03/2021 07:00	0.0	0	0	0	0	1
08/03/2021 08:00	0.0	0	0	0	0	1
08/03/2021 09:00	0.0	0	0	0	0	1
08/03/2021 10:00	0.0	0	0	0	0	1
08/03/2021 11:00	0.0	0	0	0	0	1
08/03/2021 12:00	0.0	0	0	0	0	1
08/03/2021 13:00	0.0	0	0	0	0	1
08/03/2021 14:00	0.0	0	0	0	0	1
08/03/2021 15:00	0.0	0	0	0	0	1
08/03/2021 16:00	0.0	0	0	0	0	1
08/03/2021 17:00	0.0	0	0	0	0	1
08/03/2021 18:00	0.0	0	0	0	0	1
08/03/2021 19:00	0.0	0	0	0	0	1
08/03/2021 20:00	0.0	0	0	0	0	1
08/03/2021 21:00	0.0	0	0	0	0	1
08/03/2021 22:00	0.0	0	0	0	0	1
08/03/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/04/2021 00:00	0.0	0	0	0	0	1
08/04/2021 01:00	0.0	0	0	0	0	1
08/04/2021 02:00	0.0	0	0	0	0	1
08/04/2021 03:00	0.0	0	0	0	0	1
08/04/2021 04:00	0.0	0	0	0	0	1
08/04/2021 05:00	0.0	0	0	0	0	1
08/04/2021 06:00	0.0	0	0	0	0	1
08/04/2021 07:00	0.0	0	0	0	0	1
08/04/2021 08:00	0.0	0	0	0	0	1
08/04/2021 09:00	0.0	0	0	0	0	1
08/04/2021 10:00	0.0	0	0	0	0	1
08/04/2021 11:00	0.0	0	0	0	0	1
08/04/2021 12:00	0.0	0	0	0	0	1
08/04/2021 13:00	0.0	0	0	0	0	1
08/04/2021 14:00	0.0	0	0	0	0	1
08/04/2021 15:00	0.0	0	0	0	0	1
08/04/2021 16:00	0.0	0	0	0	0	1
08/04/2021 17:00	0.0	0	0	0	0	1
08/04/2021 18:00	0.0	0	0	0	0	1
08/04/2021 19:00	0.0	0	0	0	0	1
08/04/2021 20:00	0.0	0	0	0	0	1
08/04/2021 21:00	0.0	0	0	0	0	1
08/04/2021 22:00	0.0	0	0	0	0	1
08/04/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/05/2021 00:00	0.0	0	0	0	0	1
08/05/2021 01:00	0.0	0	0	0	0	1
08/05/2021 02:00	0.0	0	0	0	0	1
08/05/2021 03:00	0.0	0	0	0	0	1
08/05/2021 04:00	0.0	0	0	0	0	1
08/05/2021 05:00	0.0	0	0	0	0	1
08/05/2021 06:00	0.0	0	0	0	0	1
08/05/2021 07:00	0.0	0	0	0	0	1
08/05/2021 08:00	0.0	0	0	0	0	1
08/05/2021 09:00	0.0	0	0	0	0	1
08/05/2021 10:00	0.0	0	0	0	0	1
08/05/2021 11:00	0.0	0	0	0	0	1
08/05/2021 12:00	0.0	0	0	0	0	1
08/05/2021 13:00	0.0	0	0	0	0	1
08/05/2021 14:00	0.0	0	0	0	0	1
08/05/2021 15:00	0.0	0	0	0	0	1
08/05/2021 16:00	0.0	0	0	0	0	1
08/05/2021 17:00	0.0	0	0	0	0	1
08/05/2021 18:00	0.0	0	0	0	0	1
08/05/2021 19:00	0.0	0	0	0	0	1
08/05/2021 20:00	0.0	0	0	0	0	1
08/05/2021 21:00	0.0	0	0	0	0	1
08/05/2021 22:00	0.0	0	0	0	0	1
08/05/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/06/2021 00:00	0.0	0	0	0	0	1
08/06/2021 01:00	0.0	0	0	0	0	1
08/06/2021 02:00	0.0	0	0	0	0	1
08/06/2021 03:00	0.0	0	0	0	0	1
08/06/2021 04:00	0.0	0	0	0	0	1
08/06/2021 05:00	0.0	0	0	0	0	1
08/06/2021 06:00	0.0	0	0	0	0	1
08/06/2021 07:00	0.0	0	0	0	0	1
08/06/2021 08:00	0.0	0	0	0	0	1
08/06/2021 09:00	0.0	0	0	0	0	1
08/06/2021 10:00	0.0	0	0	0	0	1
08/06/2021 11:00	0.0	0	0	0	0	1
08/06/2021 12:00	0.0	0	0	0	0	1
08/06/2021 13:00	0.0	0	0	0	0	1
08/06/2021 14:00	0.0	0	0	0	0	1
08/06/2021 15:00	0.0	0	0	0	0	1
08/06/2021 16:00	0.0	0	0	0	0	1
08/06/2021 17:00	0.0	0	0	0	0	1
08/06/2021 18:00	0.0	0	0	0	0	1
08/06/2021 19:00	0.0	0	0	0	0	1
08/06/2021 20:00	0.0	0	0	0	0	1
08/06/2021 21:00	0.0	0	0	0	0	1
08/06/2021 22:00	0.0	0	0	0	0	1
08/06/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/04/2021 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/07/2021 00:00	0.0	0	0	0	0	1
08/07/2021 01:00	0.0	0	0	0	0	1
08/07/2021 02:00	0.0	0	0	0	0	1
08/07/2021 03:00	3.5	0	0	0	1	0
08/07/2021 04:00	0.0	0	0	0	0	0
08/07/2021 05:00	0.0	0	0	0	0	0
08/07/2021 06:00	0.0	0	0	0	0	0
08/07/2021 07:00	0.0	0	0	0	0	0
08/07/2021 08:00	0.0	0	0	0	0	0
08/07/2021 09:00	0.0	0	0	0	0	0
08/07/2021 10:00	0.0	0	0	0	0	0
08/07/2021 11:00	0.0	0	0	0	0	0
08/07/2021 12:00	0.0	0	0	0	0	0
08/07/2021 13:00	4.6	0	1	0	0	0
08/07/2021 14:00	85.0	0	1	0	0	0
08/07/2021 15:00	0.0	0	0	0	0	1
08/07/2021 16:00	0.0	0	0	0	0	1
08/07/2021 17:00	0.0	0	0	0	0	1
08/07/2021 18:00	0.0	0	0	0	0	1
08/07/2021 19:00	0.0	0	0	0	0	1
08/07/2021 20:00	0.0	0	0	0	0	1
08/07/2021 21:00	0.0	0	0	0	0	1
08/07/2021 22:00	0.0	0	0	0	0	1
08/07/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	93.1 #	0 #	2 #	0 #	1 #	12 #
Minimum:	0.0	0	0	0	0	0
Maximum:	85.0	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/08/2021 00:00	0.0	0	0	0	0	1
08/08/2021 01:00	0.0	0	0	0	0	1
08/08/2021 02:00	0.0	0	0	0	0	1
08/08/2021 03:00	0.0	0	0	0	0	1
08/08/2021 04:00	4.9	0	0	0	1	0
08/08/2021 05:00	0.0	0	0	0	0	0
08/08/2021 06:00	0.0	0	0	0	0	0
08/08/2021 07:00	0.0	0	0	0	0	0
08/08/2021 08:00	0.0	0	0	0	0	0
08/08/2021 09:00	0.0	0	0	0	0	0
08/08/2021 10:00	0.0	0	0	0	0	0
08/08/2021 11:00	0.0	0	0	0	0	0
08/08/2021 12:00	0.0	0	0	0	0	0
08/08/2021 13:00	0.0	0	0	0	0	0
08/08/2021 14:00	5.9	0	1	0	0	0
08/08/2021 15:00	84.5	0	1	0	0	0
08/08/2021 16:00	0.0	0	0	0	0	1
08/08/2021 17:00	0.0	0	0	0	0	1
08/08/2021 18:00	0.0	0	0	0	0	1
08/08/2021 19:00	0.0	0	0	0	0	1
08/08/2021 20:00	0.0	0	0	0	0	1
08/08/2021 21:00	0.0	0	0	0	0	1
08/08/2021 22:00	0.0	0	0	0	0	1
08/08/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	95.3 #	0 #	2 #	0 #	1 #	12 #
Minimum:	0.0	0	0	0	0	0
Maximum:	84.5	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/09/2021 00:00	0.0	0	0	0	0	1
08/09/2021 01:00	0.0	0	0	0	0	1
08/09/2021 02:00	0.0	0	0	0	0	1
08/09/2021 03:00	0.0	0	0	0	0	1
08/09/2021 04:00	0.0	0	0	0	0	1
08/09/2021 05:00	0.0	0	0	0	0	1
08/09/2021 06:00	0.0	0	0	0	0	1
08/09/2021 07:00	0.0	0	0	0	0	1
08/09/2021 08:00	0.0	0	0	0	0	1
08/09/2021 09:00	0.0	0	0	0	0	1
08/09/2021 10:00	0.0	0	0	0	0	1
08/09/2021 11:00	0.0	0	0	0	0	1
08/09/2021 12:00	0.0	0	0	0	0	1
08/09/2021 13:00	0.0	0	0	0	0	1
08/09/2021 14:00	0.0	0	0	0	0	1
08/09/2021 15:00	0.0	0	0	0	0	1
08/09/2021 16:00	0.0	0	0	0	0	1
08/09/2021 17:00	0.0	0	0	0	0	1
08/09/2021 18:00	0.0	0	0	0	0	1
08/09/2021 19:00	0.0	0	0	0	0	1
08/09/2021 20:00	0.0	0	0	0	0	1
08/09/2021 21:00	0.0	0	0	0	0	1
08/09/2021 22:00	0.0	0	0	0	0	1
08/09/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/10/2021 00:00	0.0	0	0	0	0	1
08/10/2021 01:00	0.0	0	0	0	0	1
08/10/2021 02:00	0.0	0	0	0	0	1
08/10/2021 03:00	0.0	0	0	0	0	1
08/10/2021 04:00	0.0	0	0	0	0	1
08/10/2021 05:00	0.0	0	0	0	0	1
08/10/2021 06:00	0.0	0	0	0	0	1
08/10/2021 07:00	0.0	0	0	0	0	1
08/10/2021 08:00	0.0	0	0	0	0	1
08/10/2021 09:00	0.0	0	0	0	0	1
08/10/2021 10:00	0.0	0	0	0	0	1
08/10/2021 11:00	0.0	0	0	0	0	1
08/10/2021 12:00	0.0	0	0	0	0	1
08/10/2021 13:00	0.0	0	0	0	0	1
08/10/2021 14:00	0.0	0	0	0	0	1
08/10/2021 15:00	0.0	0	0	0	0	1
08/10/2021 16:00	0.0	0	0	0	0	1
08/10/2021 17:00	0.0	0	0	0	0	1
08/10/2021 18:00	0.0	0	0	0	0	1
08/10/2021 19:00	0.0	0	0	0	0	1
08/10/2021 20:00	0.0	0	0	0	0	1
08/10/2021 21:00	0.0	0	0	0	0	1
08/10/2021 22:00	0.0	0	0	0	0	1
08/10/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/11/2021 00:00	0.0	0	0	0	0	1
08/11/2021 01:00	0.0	0	0	0	0	1
08/11/2021 02:00	0.0	0	0	0	0	1
08/11/2021 03:00	0.0	0	0	0	0	1
08/11/2021 04:00	0.0	0	0	0	0	1
08/11/2021 05:00	0.0	0	0	0	0	1
08/11/2021 06:00	0.0	0	0	0	0	1
08/11/2021 07:00	0.0	0	0	0	0	1
08/11/2021 08:00	0.0	0	0	0	0	1
08/11/2021 09:00	0.0	0	0	0	0	1
08/11/2021 10:00	0.0	0	0	0	0	1
08/11/2021 11:00	0.0	0	0	0	0	1
08/11/2021 12:00	0.0	0	0	0	0	1
08/11/2021 13:00	0.0	0	0	0	0	1
08/11/2021 14:00	0.0	0	0	0	0	1
08/11/2021 15:00	0.0	0	0	0	0	1
08/11/2021 16:00	0.0	0	0	0	0	1
08/11/2021 17:00	0.0	0	0	0	0	1
08/11/2021 18:00	0.0	0	0	0	0	1
08/11/2021 19:00	0.0	0	0	0	0	1
08/11/2021 20:00	0.0	0	0	0	0	1
08/11/2021 21:00	0.0	0	0	0	0	1
08/11/2021 22:00	0.0	0	0	0	0	1
08/11/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/12/2021 00:00	0.0	0	0	0	0	1
08/12/2021 01:00	0.0	0	0	0	0	1
08/12/2021 02:00	0.0	0	0	0	0	1
08/12/2021 03:00	0.0	0	0	0	0	1
08/12/2021 04:00	0.0	0	0	0	0	1
08/12/2021 05:00	0.0	0	0	0	0	1
08/12/2021 06:00	0.0	0	0	0	0	1
08/12/2021 07:00	0.0	0	0	0	0	1
08/12/2021 08:00	0.0	0	0	0	0	1
08/12/2021 09:00	0.0	0	0	0	0	1
08/12/2021 10:00	0.0	0	0	0	0	1
08/12/2021 11:00	0.0	0	0	0	0	1
08/12/2021 12:00	0.0	0	0	0	0	1
08/12/2021 13:00	0.0	0	0	0	0	1
08/12/2021 14:00	0.0	0	0	0	0	1
08/12/2021 15:00	0.0	0	0	0	0	1
08/12/2021 16:00	0.0	0	0	0	0	1
08/12/2021 17:00	0.0	0	0	0	0	1
08/12/2021 18:00	0.0	0	0	0	0	1
08/12/2021 19:00	0.0	0	0	0	0	1
08/12/2021 20:00	0.0	0	0	0	0	1
08/12/2021 21:00	0.0	0	0	0	0	1
08/12/2021 22:00	0.0	0	0	0	0	1
08/12/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/13/2021 00:00	0.0	0	0	0	0	1
08/13/2021 01:00	0.0	0	0	0	0	1
08/13/2021 02:00	0.0	0	0	0	0	1
08/13/2021 03:00	0.0	0	0	0	0	1
08/13/2021 04:00	0.0	0	0	0	0	1
08/13/2021 05:00	0.0	0	0	0	0	1
08/13/2021 06:00	0.0	0	0	0	0	1
08/13/2021 07:00	0.0	0	0	0	0	1
08/13/2021 08:00	0.0	0	0	0	0	1
08/13/2021 09:00	0.0	0	0	0	0	1
08/13/2021 10:00	0.0	0	0	0	0	1
08/13/2021 11:00	0.0	0	0	0	0	1
08/13/2021 12:00	0.0	0	0	0	0	1
08/13/2021 13:00	0.0	0	0	0	0	1
08/13/2021 14:00	0.0	0	0	0	0	1
08/13/2021 15:00	0.0	0	0	0	0	1
08/13/2021 16:00	0.0	0	0	0	0	1
08/13/2021 17:00	0.0	0	0	0	0	1
08/13/2021 18:00	0.0	0	0	0	0	1
08/13/2021 19:00	0.0	0	0	0	0	1
08/13/2021 20:00	0.0	0	0	0	0	1
08/13/2021 21:00	0.0	0	0	0	0	1
08/13/2021 22:00	0.0	0	0	0	0	1
08/13/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/14/2021 00:00	0.0	0	0	0	0	1
08/14/2021 01:00	0.0	0	0	0	0	1
08/14/2021 02:00	0.0	0	0	0	0	1
08/14/2021 03:00	0.0	0	0	0	0	1
08/14/2021 04:00	0.0	0	0	0	0	1
08/14/2021 05:00	0.0	0	0	0	0	1
08/14/2021 06:00	0.0	0	0	0	0	1
08/14/2021 07:00	0.0	0	0	0	0	1
08/14/2021 08:00	0.0	0	0	0	0	1
08/14/2021 09:00	0.0	0	0	0	0	1
08/14/2021 10:00	0.0	0	0	0	0	1
08/14/2021 11:00	0.0	0	0	0	0	1
08/14/2021 12:00	0.0	0	0	0	0	1
08/14/2021 13:00	0.0	0	0	0	0	1
08/14/2021 14:00	0.0	0	0	0	0	1
08/14/2021 15:00	0.0	0	0	0	0	1
08/14/2021 16:00	0.0	0	0	0	0	1
08/14/2021 17:00	0.0	0	0	0	0	1
08/14/2021 18:00	0.0	0	0	0	0	1
08/14/2021 19:00	0.0	0	0	0	0	1
08/14/2021 20:00	0.0	0	0	0	0	1
08/14/2021 21:00	0.0	0	0	0	0	1
08/14/2021 22:00	0.0	0	0	0	0	1
08/14/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/15/2021 00:00	0.0	0	0	0	0	1
08/15/2021 01:00	0.0	0	0	0	0	1
08/15/2021 02:00	0.0	0	0	0	0	1
08/15/2021 03:00	0.0	0	0	0	0	1
08/15/2021 04:00	0.0	0	0	0	0	1
08/15/2021 05:00	0.0	0	0	0	0	1
08/15/2021 06:00	0.0	0	0	0	0	1
08/15/2021 07:00	0.0	0	0	0	0	1
08/15/2021 08:00	0.0	0	0	0	0	1
08/15/2021 09:00	0.0	0	0	0	0	1
08/15/2021 10:00	0.0	0	0	0	0	1
08/15/2021 11:00	0.0	0	0	0	0	1
08/15/2021 12:00	0.0	0	0	0	0	1
08/15/2021 13:00	0.0	0	0	0	0	1
08/15/2021 14:00	0.0	0	0	0	0	1
08/15/2021 15:00	0.0	0	0	0	0	1
08/15/2021 16:00	0.0	0	0	0	0	1
08/15/2021 17:00	0.0	0	0	0	0	1
08/15/2021 18:00	0.0	0	0	0	0	1
08/15/2021 19:00	0.0	0	0	0	0	1
08/15/2021 20:00	0.0	0	0	0	0	1
08/15/2021 21:00	0.0	0	0	0	0	1
08/15/2021 22:00	0.0	0	0	0	0	1
08/15/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/16/2021 00:00	0.0	0	0	0	0	1
08/16/2021 01:00	0.0	0	0	0	0	1
08/16/2021 02:00	0.0	0	0	0	0	1
08/16/2021 03:00	0.0	0	0	0	0	1
08/16/2021 04:00	0.0	0	0	0	0	1
08/16/2021 05:00	0.0	0	0	0	0	1
08/16/2021 06:00	0.0	0	0	0	0	1
08/16/2021 07:00	0.0	0	0	0	0	1
08/16/2021 08:00	0.0	0	0	0	0	1
08/16/2021 09:00	0.0	0	0	0	0	1
08/16/2021 10:00	0.0	0	0	0	0	1
08/16/2021 11:00	0.0	0	0	0	0	1
08/16/2021 12:00	0.0	0	0	0	0	1
08/16/2021 13:00	0.0	0	0	0	0	1
08/16/2021 14:00	0.0	0	0	0	0	1
08/16/2021 15:00	0.0	0	0	0	0	1
08/16/2021 16:00	0.0	0	0	0	0	1
08/16/2021 17:00	0.0	0	0	0	0	1
08/16/2021 18:00	0.0	0	0	0	0	1
08/16/2021 19:00	0.0	0	0	0	0	1
08/16/2021 20:00	0.0	0	0	0	0	1
08/16/2021 21:00	0.0	0	0	0	0	1
08/16/2021 22:00	0.0	0	0	0	0	1
08/16/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/17/2021 00:00	0.0	0	0	0	0	1
08/17/2021 01:00	0.0	0	0	0	0	1
08/17/2021 02:00	0.0	0	0	0	0	1
08/17/2021 03:00	0.0	0	0	0	0	1
08/17/2021 04:00	0.0	0	0	0	0	1
08/17/2021 05:00	0.0	0	0	0	0	1
08/17/2021 06:00	0.0	0	0	0	0	1
08/17/2021 07:00	0.0	0	0	0	0	1
08/17/2021 08:00	0.0	0	0	0	0	1
08/17/2021 09:00	0.0	0	0	0	0	1
08/17/2021 10:00	0.0	0	0	0	0	1
08/17/2021 11:00	0.0	0	0	0	0	1
08/17/2021 12:00	0.0	0	0	0	0	1
08/17/2021 13:00	0.0	0	0	0	0	1
08/17/2021 14:00	0.0	0	0	0	0	1
08/17/2021 15:00	0.0	0	0	0	0	1
08/17/2021 16:00	0.0	0	0	0	0	1
08/17/2021 17:00	0.0	0	0	0	0	1
08/17/2021 18:00	0.0	0	0	0	0	1
08/17/2021 19:00	0.0	0	0	0	0	1
08/17/2021 20:00	0.0	0	0	0	0	1
08/17/2021 21:00	0.0	0	0	0	0	1
08/17/2021 22:00	0.0	0	0	0	0	1
08/17/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/18/2021 00:00	0.0	0	0	0	0	1
08/18/2021 01:00	0.0	0	0	0	0	1
08/18/2021 02:00	0.0	0	0	0	0	1
08/18/2021 03:00	0.0	0	0	0	0	1
08/18/2021 04:00	0.0	0	0	0	0	1
08/18/2021 05:00	0.0	0	0	0	0	1
08/18/2021 06:00	0.0	0	0	0	0	1
08/18/2021 07:00	0.0	0	0	0	0	1
08/18/2021 08:00	0.0	0	0	0	0	1
08/18/2021 09:00	0.0	0	0	0	0	1
08/18/2021 10:00	0.0	0	0	0	0	1
08/18/2021 11:00	0.0	0	0	0	0	1
08/18/2021 12:00	0.0	0	0	0	0	1
08/18/2021 13:00	0.0	0	0	0	0	1
08/18/2021 14:00	0.0	0	0	0	0	1
08/18/2021 15:00	0.0	0	0	0	0	1
08/18/2021 16:00	0.0	0	0	0	0	1
08/18/2021 17:00	0.0	0	0	0	0	1
08/18/2021 18:00	0.0	0	0	0	0	1
08/18/2021 19:00	0.0	0	0	0	0	1
08/18/2021 20:00	0.0	0	0	0	0	1
08/18/2021 21:00	0.0	0	0	0	0	1
08/18/2021 22:00	0.0	0	0	0	0	1
08/18/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/19/2021 00:00	0.0	0	0	0	0	1
08/19/2021 01:00	0.0	0	0	0	0	1
08/19/2021 02:00	0.0	0	0	0	0	1
08/19/2021 03:00	0.0	0	0	0	0	1
08/19/2021 04:00	0.0	0	0	0	0	1
08/19/2021 05:00	0.0	0	0	0	0	1
08/19/2021 06:00	0.0	0	0	0	0	1
08/19/2021 07:00	0.0	0	0	0	0	1
08/19/2021 08:00	0.0	0	0	0	0	1
08/19/2021 09:00	0.0	0	0	0	0	1
08/19/2021 10:00	0.0	0	0	0	0	1
08/19/2021 11:00	0.0	0	0	0	0	1
08/19/2021 12:00	0.0	0	0	0	0	1
08/19/2021 13:00	0.0	0	0	0	0	1
08/19/2021 14:00	0.0	0	0	0	0	1
08/19/2021 15:00	0.0	0	0	0	0	1
08/19/2021 16:00	0.0	0	0	0	0	1
08/19/2021 17:00	0.0	0	0	0	0	1
08/19/2021 18:00	0.0	0	0	0	0	1
08/19/2021 19:00	0.0	0	0	0	0	1
08/19/2021 20:00	0.0	0	0	0	0	1
08/19/2021 21:00	0.0	0	0	0	0	1
08/19/2021 22:00	0.0	0	0	0	0	1
08/19/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/20/2021 00:00	0.0	0	0	0	0	1
08/20/2021 01:00	0.0	0	0	0	0	1
08/20/2021 02:00	0.0	0	0	0	0	1
08/20/2021 03:00	0.0	0	0	0	0	1
08/20/2021 04:00	0.0	0	0	0	0	1
08/20/2021 05:00	0.0	0	0	0	0	1
08/20/2021 06:00	0.0	0	0	0	0	1
08/20/2021 07:00	0.0	0	0	0	0	1
08/20/2021 08:00	0.0	0	0	0	0	1
08/20/2021 09:00	0.0	0	0	0	0	1
08/20/2021 10:00	0.0	0	0	0	0	1
08/20/2021 11:00	0.0	0	0	0	0	1
08/20/2021 12:00	0.0	0	0	0	0	1
08/20/2021 13:00	0.0	0	0	0	0	1
08/20/2021 14:00	0.0	0	0	0	0	1
08/20/2021 15:00	0.0	0	0	0	0	1
08/20/2021 16:00	0.0	0	0	0	0	1
08/20/2021 17:00	0.0	0	0	0	0	1
08/20/2021 18:00	0.0	0	0	0	0	1
08/20/2021 19:00	0.0	0	0	0	0	1
08/20/2021 20:00	0.0	0	0	0	0	1
08/20/2021 21:00	0.0	0	0	0	0	1
08/20/2021 22:00	0.0	0	0	0	0	1
08/20/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/21/2021 00:00	4.5	0	0	0	1	0
08/21/2021 01:00	0.0	0	0	0	0	0
08/21/2021 02:00	0.0	0	0	0	0	0
08/21/2021 03:00	0.0	0	0	0	0	0
08/21/2021 04:00	0.0	0	0	0	0	0
08/21/2021 05:00	0.0	0	0	0	0	0
08/21/2021 06:00	0.0	0	0	0	0	0
08/21/2021 07:00	0.0	0	0	0	0	0
08/21/2021 08:00	0.0	0	0	0	0	0
08/21/2021 09:00	0.0	0	0	0	0	0
08/21/2021 10:00	0.0	0	0	0	0	0
08/21/2021 11:00	0.0	0	0	0	0	0
08/21/2021 12:00	0.0	0	0	0	0	0
08/21/2021 13:00	0.0	0	0	0	0	0
08/21/2021 14:00	0.0	0	0	0	0	0
08/21/2021 15:00	0.0	0	0	0	0	0
08/21/2021 16:00	0.0	0	0	0	0	0
08/21/2021 17:00	0.0	0	0	0	0	0
08/21/2021 18:00	0.0	0	0	0	0	0
08/21/2021 19:00	0.0	0	0	0	0	0
08/21/2021 20:00	0.0	0	0	0	0	0
08/21/2021 21:00	0.0	0	0	0	0	0
08/21/2021 22:00	0.0	0	0	0	0	0
08/21/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	4.5 #	0 #	0 #	0 #	1 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	4.5	0	0	0	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/22/2021 00:00	0.0	0	0	0	0	0
08/22/2021 01:00	0.0	0	0	0	0	0
08/22/2021 02:00	0.0	0	0	0	0	0
08/22/2021 03:00	0.0	0	0	0	0	0
08/22/2021 04:00	0.0	0	0	0	0	0
08/22/2021 05:00	0.0	0	0	0	0	0
08/22/2021 06:00	0.0	0	0	0	0	0
08/22/2021 07:00	0.0	0	0	0	0	0
08/22/2021 08:00	0.0	0	0	0	0	0
08/22/2021 09:00	0.0	0	0	0	0	0
08/22/2021 10:00	0.0	0	0	0	0	0
08/22/2021 11:00	0.0	0	0	0	0	0
08/22/2021 12:00	0.0	0	0	0	0	0
08/22/2021 13:00	0.0	0	0	0	0	0
08/22/2021 14:00	0.0	0	0	0	0	0
08/22/2021 15:00	0.0	0	0	0	0	0
08/22/2021 16:00	0.0	0	0	0	0	0
08/22/2021 17:00	0.0	0	0	0	0	0
08/22/2021 18:00	0.0	0	0	0	0	0
08/22/2021 19:00	0.0	0	0	0	0	0
08/22/2021 20:00	0.0	0	0	0	0	0
08/22/2021 21:00	0.0	0	0	0	0	0
08/22/2021 22:00	0.0	0	0	0	0	0
08/22/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/23/2021 00:00	0.0	0	0	0	0	0
08/23/2021 01:00	0.0	0	0	0	0	0
08/23/2021 02:00	0.0	0	0	0	0	0
08/23/2021 03:00	0.0	0	0	0	0	0
08/23/2021 04:00	0.0	0	0	0	0	0
08/23/2021 05:00	0.0	0	0	0	0	0
08/23/2021 06:00	0.0	0	0	0	0	0
08/23/2021 07:00	0.0	0	0	0	0	0
08/23/2021 08:00	0.0	0	0	0	0	0
08/23/2021 09:00	0.0	0	0	0	0	0
08/23/2021 10:00	0.0	0	0	0	0	0
08/23/2021 11:00	0.0	0	0	0	0	0
08/23/2021 12:00	0.0	0	0	0	0	0
08/23/2021 13:00	0.0	0	0	0	0	0
08/23/2021 14:00	0.0	0	0	0	0	0
08/23/2021 15:00	0.0	0	0	0	0	0
08/23/2021 16:00	75.3	0	1	0	0	0
08/23/2021 17:00	76.8	0	1	0	0	0
08/23/2021 18:00	0.0	0	0	0	0	1
08/23/2021 19:00	0.0	0	0	0	0	1
08/23/2021 20:00	0.0	0	0	0	0	1
08/23/2021 21:00	0.0	0	0	0	0	1
08/23/2021 22:00	0.0	0	0	0	0	1
08/23/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	152.1 #	0 #	2 #	0 #	0 #	6 #
Minimum:	0.0	0	0	0	0	0
Maximum:	76.8	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/24/2021 00:00	0.0	0	0	0	0	1
08/24/2021 01:00	0.0	0	0	0	0	1
08/24/2021 02:00	0.0	0	0	0	0	1
08/24/2021 03:00	0.0	0	0	0	0	1
08/24/2021 04:00	0.0	0	0	0	0	1
08/24/2021 05:00	0.0	0	0	0	0	1
08/24/2021 06:00	0.0	0	0	0	0	1
08/24/2021 07:00	0.0	0	0	0	0	1
08/24/2021 08:00	0.0	0	0	0	0	1
08/24/2021 09:00	0.0	0	0	0	0	1
08/24/2021 10:00	0.0	0	0	0	0	1
08/24/2021 11:00	0.0	0	0	0	0	1
08/24/2021 12:00	0.0	0	0	0	0	1
08/24/2021 13:00	0.0	0	0	0	0	1
08/24/2021 14:00	0.0	0	0	0	0	1
08/24/2021 15:00	0.0	0	0	0	0	1
08/24/2021 16:00	0.0	0	0	0	0	1
08/24/2021 17:00	0.0	0	0	0	0	1
08/24/2021 18:00	0.0	0	0	0	0	1
08/24/2021 19:00	0.0	0	0	0	0	1
08/24/2021 20:00	0.0	0	0	0	0	1
08/24/2021 21:00	0.0	0	0	0	0	1
08/24/2021 22:00	0.0	0	0	0	0	1
08/24/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/25/2021 00:00	0.0	0	0	0	0	1
08/25/2021 01:00	0.0	0	0	0	0	1
08/25/2021 02:00	0.0	0	0	0	0	1
08/25/2021 03:00	0.0	0	0	0	0	1
08/25/2021 04:00	0.0	0	0	0	0	1
08/25/2021 05:00	0.0	0	0	0	0	1
08/25/2021 06:00	0.0	0	0	0	0	1
08/25/2021 07:00	0.0	0	0	0	0	1
08/25/2021 08:00	0.0	0	0	0	0	1
08/25/2021 09:00	0.0	0	0	0	0	1
08/25/2021 10:00	0.0	0	0	0	0	1
08/25/2021 11:00	0.0	0	0	0	0	1
08/25/2021 12:00	0.0	0	0	0	0	1
08/25/2021 13:00	0.0	0	0	0	0	1
08/25/2021 14:00	0.0	0	0	0	0	1
08/25/2021 15:00	0.0	0	0	0	0	1
08/25/2021 16:00	0.0	0	0	0	0	1
08/25/2021 17:00	0.0	0	0	0	0	1
08/25/2021 18:00	0.0	0	0	0	0	1
08/25/2021 19:00	0.0	0	0	0	0	1
08/25/2021 20:00	0.0	0	0	0	0	1
08/25/2021 21:00	0.0	0	0	0	0	1
08/25/2021 22:00	0.0	0	0	0	0	1
08/25/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/26/2021 00:00	0.0	0	0	0	0	1
08/26/2021 01:00	0.0	0	0	0	0	1
08/26/2021 02:00	0.0	0	0	0	0	1
08/26/2021 03:00	0.0	0	0	0	0	1
08/26/2021 04:00	0.0	0	0	0	0	1
08/26/2021 05:00	0.0	0	0	0	0	1
08/26/2021 06:00	0.0	0	0	0	0	1
08/26/2021 07:00	0.0	0	0	0	0	1
08/26/2021 08:00	0.0	0	0	0	0	1
08/26/2021 09:00	0.0	0	0	0	0	1
08/26/2021 10:00	0.0	0	0	0	0	1
08/26/2021 11:00	0.0	0	0	0	0	1
08/26/2021 12:00	0.0	0	0	0	0	1
08/26/2021 13:00	0.0	0	0	0	0	1
08/26/2021 14:00	0.0	0	0	0	0	1
08/26/2021 15:00	0.0	0	0	0	0	1
08/26/2021 16:00	0.0	0	0	0	0	1
08/26/2021 17:00	0.0	0	0	0	0	1
08/26/2021 18:00	0.0	0	0	0	0	1
08/26/2021 19:00	0.0	0	0	0	0	1
08/26/2021 20:00	0.0	0	0	0	0	1
08/26/2021 21:00	0.0	0	0	0	0	1
08/26/2021 22:00	0.0	0	0	0	0	1
08/26/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/27/2021 00:00	0.0	0	0	0	0	1
08/27/2021 01:00	0.0	0	0	0	0	1
08/27/2021 02:00	0.0	0	0	0	0	1
08/27/2021 03:00	0.0	0	0	0	0	1
08/27/2021 04:00	0.0	0	0	0	0	1
08/27/2021 05:00	0.0	0	0	0	0	1
08/27/2021 06:00	0.0	0	0	0	0	1
08/27/2021 07:00	0.0	0	0	0	0	1
08/27/2021 08:00	0.0	0	0	0	0	1
08/27/2021 09:00	0.0	0	0	0	0	1
08/27/2021 10:00	0.0	0	0	0	0	1
08/27/2021 11:00	0.0	0	0	0	0	1
08/27/2021 12:00	0.0	0	0	0	0	1
08/27/2021 13:00	0.0	0	0	0	0	1
08/27/2021 14:00	0.0	0	0	0	0	1
08/27/2021 15:00	0.0	0	0	0	0	1
08/27/2021 16:00	0.0	0	0	0	0	1
08/27/2021 17:00	0.0	0	0	0	0	1
08/27/2021 18:00	0.0	0	0	0	0	1
08/27/2021 19:00	0.0	0	0	0	0	1
08/27/2021 20:00	0.0	0	0	0	0	1
08/27/2021 21:00	0.0	0	0	0	0	1
08/27/2021 22:00	0.0	0	0	0	0	1
08/27/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/28/2021 00:00	0.0	0	0	0	0	1
08/28/2021 01:00	0.0	0	0	0	0	1
08/28/2021 02:00	0.0	0	0	0	0	1
08/28/2021 03:00	0.0	0	0	0	0	1
08/28/2021 04:00	0.0	0	0	0	0	1
08/28/2021 05:00	0.0	0	0	0	0	1
08/28/2021 06:00	0.0	0	0	0	0	1
08/28/2021 07:00	0.0	0	0	0	0	1
08/28/2021 08:00	0.0	0	0	0	0	1
08/28/2021 09:00	0.0	0	0	0	0	1
08/28/2021 10:00	0.0	0	0	0	0	1
08/28/2021 11:00	0.0	0	0	0	0	1
08/28/2021 12:00	0.0	0	0	0	0	1
08/28/2021 13:00	0.0	0	0	0	0	1
08/28/2021 14:00	0.0	0	0	0	0	1
08/28/2021 15:00	0.0	0	0	0	0	1
08/28/2021 16:00	0.0	0	0	0	0	1
08/28/2021 17:00	0.0	0	0	0	0	1
08/28/2021 18:00	0.0	0	0	0	0	1
08/28/2021 19:00	0.0	0	0	0	0	1
08/28/2021 20:00	0.0	0	0	0	0	1
08/28/2021 21:00	0.0	0	0	0	0	1
08/28/2021 22:00	0.0	0	0	0	0	1
08/28/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/29/2021 00:00	0.0	0	0	0	0	1
08/29/2021 01:00	0.0	0	0	0	0	1
08/29/2021 02:00	0.0	0	0	0	0	1
08/29/2021 03:00	0.0	0	0	0	0	1
08/29/2021 04:00	0.0	0	0	0	0	1
08/29/2021 05:00	0.0	0	0	0	0	1
08/29/2021 06:00	0.0	0	0	0	0	1
08/29/2021 07:00	0.0	0	0	0	0	1
08/29/2021 08:00	0.0	0	0	0	0	1
08/29/2021 09:00	0.0	0	0	0	0	1
08/29/2021 10:00	0.0	0	0	0	0	1
08/29/2021 11:00	0.0	0	0	0	0	1
08/29/2021 12:00	0.0	0	0	0	0	1
08/29/2021 13:00	0.0	0	0	0	0	1
08/29/2021 14:00	0.0	0	0	0	0	1
08/29/2021 15:00	0.0	0	0	0	0	1
08/29/2021 16:00	0.0	0	0	0	0	1
08/29/2021 17:00	0.0	0	0	0	0	1
08/29/2021 18:00	0.0	0	0	0	0	1
08/29/2021 19:00	0.0	0	0	0	0	1
08/29/2021 20:00	0.0	0	0	0	0	1
08/29/2021 21:00	0.0	0	0	0	0	1
08/29/2021 22:00	0.0	0	0	0	0	1
08/29/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/30/2021 00:00	0.0	0	0	0	0	1
08/30/2021 01:00	0.0	0	0	0	0	1
08/30/2021 02:00	0.0	0	0	0	0	1
08/30/2021 03:00	0.0	0	0	0	0	1
08/30/2021 04:00	0.0	0	0	0	0	1
08/30/2021 05:00	0.0	0	0	0	0	1
08/30/2021 06:00	0.0	0	0	0	0	1
08/30/2021 07:00	0.0	0	0	0	0	1
08/30/2021 08:00	0.0	0	0	0	0	1
08/30/2021 09:00	0.0	0	0	0	0	1
08/30/2021 10:00	0.0	0	0	0	0	1
08/30/2021 11:00	0.0	0	0	0	0	1
08/30/2021 12:00	0.0	0	0	0	0	1
08/30/2021 13:00	0.0	0	0	0	0	1
08/30/2021 14:00	0.0	0	0	0	0	1
08/30/2021 15:00	0.0	0	0	0	0	1
08/30/2021 16:00	0.0	0	0	0	0	1
08/30/2021 17:00	0.0	0	0	0	0	1
08/30/2021 18:00	0.0	0	0	0	0	1
08/30/2021 19:00	0.0	0	0	0	0	1
08/30/2021 20:00	0.0	0	0	0	0	1
08/30/2021 21:00	0.0	0	0	0	0	1
08/30/2021 22:00	0.0	0	0	0	0	1
08/30/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/31/2021 00:00	0.0	0	0	0	0	1
08/31/2021 01:00	0.0	0	0	0	0	1
08/31/2021 02:00	0.0	0	0	0	0	1
08/31/2021 03:00	0.0	0	0	0	0	1
08/31/2021 04:00	0.0	0	0	0	0	1
08/31/2021 05:00	0.0	0	0	0	0	1
08/31/2021 06:00	0.0	0	0	0	0	1
08/31/2021 07:00	0.0	0	0	0	0	1
08/31/2021 08:00	0.0	0	0	0	0	1
08/31/2021 09:00	0.0	0	0	0	0	1
08/31/2021 10:00	0.0	0	0	0	0	1
08/31/2021 11:00	0.0	0	0	0	0	1
08/31/2021 12:00	0.0	0	0	0	0	1
08/31/2021 13:00	0.0	0	0	0	0	1
08/31/2021 14:00	0.0	0	0	0	0	1
08/31/2021 15:00	0.0	0	0	0	0	1
08/31/2021 16:00	0.0	0	0	0	0	1
08/31/2021 17:00	0.0	0	0	0	0	1
08/31/2021 18:00	0.0	0	0	0	0	1
08/31/2021 19:00	0.0	0	0	0	0	1
08/31/2021 20:00	0.0	0	0	0	0	1
08/31/2021 21:00	0.0	0	0	0	0	1
08/31/2021 22:00	0.0	0	0	0	0	1
08/31/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/01/2021 00:00	0.0	0	0	0	0	1
09/01/2021 01:00	0.0	0	0	0	0	1
09/01/2021 02:00	0.0	0	0	0	0	1
09/01/2021 03:00	0.0	0	0	0	0	1
09/01/2021 04:00	0.0	0	0	0	0	1
09/01/2021 05:00	0.0	0	0	0	0	1
09/01/2021 06:00	0.0	0	0	0	0	1
09/01/2021 07:00	0.0	0	0	0	0	1
09/01/2021 08:00	0.0	0	0	0	0	1
09/01/2021 09:00	0.0	0	0	0	0	1
09/01/2021 10:00	0.0	0	0	0	0	1
09/01/2021 11:00	0.0	0	0	0	0	1
09/01/2021 12:00	0.0	0	0	0	0	1
09/01/2021 13:00	0.0	0	0	0	0	1
09/01/2021 14:00	0.0	0	0	0	0	1
09/01/2021 15:00	0.0	0	0	0	0	1
09/01/2021 16:00	0.0	0	0	0	0	1
09/01/2021 17:00	0.0	0	0	0	0	1
09/01/2021 18:00	0.0	0	0	0	0	1
09/01/2021 19:00	0.0	0	0	0	0	1
09/01/2021 20:00	0.0	0	0	0	0	1
09/01/2021 21:00	0.0	0	0	0	0	1
09/01/2021 22:00	0.0	0	0	0	0	1
09/01/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/02/2021 00:00	0.0	0	0	0	0	1
09/02/2021 01:00	0.0	0	0	0	0	1
09/02/2021 02:00	0.0	0	0	0	0	1
09/02/2021 03:00	0.0	0	0	0	0	1
09/02/2021 04:00	0.0	0	0	0	0	1
09/02/2021 05:00	0.0	0	0	0	0	1
09/02/2021 06:00	0.0	0	0	0	0	1
09/02/2021 07:00	0.0	0	0	0	0	1
09/02/2021 08:00	0.0	0	0	0	0	1
09/02/2021 09:00	0.0	0	0	0	0	1
09/02/2021 10:00	0.0	0	0	0	0	1
09/02/2021 11:00	0.0	0	0	0	0	1
09/02/2021 12:00	0.0	0	0	0	0	1
09/02/2021 13:00	0.0	0	0	0	0	1
09/02/2021 14:00	0.0	0	0	0	0	1
09/02/2021 15:00	0.0	0	0	0	0	1
09/02/2021 16:00	0.0	0	0	0	0	1
09/02/2021 17:00	0.0	0	0	0	0	1
09/02/2021 18:00	0.0	0	0	0	0	1
09/02/2021 19:00	0.0	0	0	0	0	1
09/02/2021 20:00	0.0	0	0	0	0	1
09/02/2021 21:00	0.0	0	0	0	0	1
09/02/2021 22:00	0.0	0	0	0	0	1
09/02/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/03/2021 00:00	0.0	0	0	0	0	1
09/03/2021 01:00	0.0	0	0	0	0	1
09/03/2021 02:00	0.0	0	0	0	0	1
09/03/2021 03:00	0.0	0	0	0	0	1
09/03/2021 04:00	0.0	0	0	0	0	1
09/03/2021 05:00	0.0	0	0	0	0	1
09/03/2021 06:00	0.0	0	0	0	0	1
09/03/2021 07:00	0.0	0	0	0	0	1
09/03/2021 08:00	0.0	0	0	0	0	1
09/03/2021 09:00	0.0	0	0	0	0	1
09/03/2021 10:00	0.0	0	0	0	0	1
09/03/2021 11:00	0.0	0	0	0	0	1
09/03/2021 12:00	0.0	0	0	0	0	1
09/03/2021 13:00	0.0	0	0	0	0	1
09/03/2021 14:00	0.0	0	0	0	0	1
09/03/2021 15:00	0.0	0	0	0	0	1
09/03/2021 16:00	0.0	0	0	0	0	1
09/03/2021 17:00	0.0	0	0	0	0	1
09/03/2021 18:00	0.0	0	0	0	0	1
09/03/2021 19:00	0.0	0	0	0	0	1
09/03/2021 20:00	0.0	0	0	0	0	1
09/03/2021 21:00	0.0	0	0	0	0	1
09/03/2021 22:00	0.0	0	0	0	0	1
09/03/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/04/2021 00:00	0.0	0	0	0	0	1
09/04/2021 01:00	0.0	0	0	0	0	1
09/04/2021 02:00	0.0	0	0	0	0	1
09/04/2021 03:00	2.9	0	0	0	1	0
09/04/2021 04:00	0.0	0	0	0	0	0
09/04/2021 05:00	0.0	0	0	0	0	0
09/04/2021 06:00	0.0	0	0	0	0	0
09/04/2021 07:00	0.0	0	0	0	0	0
09/04/2021 08:00	0.0	0	0	0	0	0
09/04/2021 09:00	8.5	0	0	1	0	0
09/04/2021 10:00	65.9	0	0	1	0	0
09/04/2021 11:00	0.0	0	0	0	0	1
09/04/2021 12:00	0.0	0	0	0	0	1
09/04/2021 13:00	0.0	0	0	0	0	1
09/04/2021 14:00	0.0	0	0	0	0	1
09/04/2021 15:00	0.0	0	0	0	0	1
09/04/2021 16:00	0.0	0	0	0	0	1
09/04/2021 17:00	0.0	0	0	0	0	1
09/04/2021 18:00	0.0	0	0	0	0	1
09/04/2021 19:00	0.0	0	0	0	0	1
09/04/2021 20:00	0.0	0	0	0	0	1
09/04/2021 21:00	0.0	0	0	0	0	1
09/04/2021 22:00	0.0	0	0	0	0	1
09/04/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	77.3 #	0 #	0 #	2 #	1 #	16 #
Minimum:	0.0	0	0	0	0	0
Maximum:	65.9	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/05/2021 00:00	0.0	0	0	0	0	1
09/05/2021 01:00	0.0	0	0	0	0	1
09/05/2021 02:00	0.0	0	0	0	0	1
09/05/2021 03:00	0.0	0	0	0	0	1
09/05/2021 04:00	0.0	0	0	0	0	1
09/05/2021 05:00	0.0	0	0	0	0	1
09/05/2021 06:00	0.0	0	0	0	0	1
09/05/2021 07:00	0.0	0	0	0	0	1
09/05/2021 08:00	0.0	0	0	0	0	1
09/05/2021 09:00	0.0	0	0	0	0	1
09/05/2021 10:00	0.0	0	0	0	0	1
09/05/2021 11:00	0.0	0	0	0	0	1
09/05/2021 12:00	0.0	0	0	0	0	1
09/05/2021 13:00	0.0	0	0	0	0	1
09/05/2021 14:00	0.0	0	0	0	0	1
09/05/2021 15:00	0.0	0	0	0	0	1
09/05/2021 16:00	0.0	0	0	0	0	1
09/05/2021 17:00	0.0	0	0	0	0	1
09/05/2021 18:00	0.0	0	0	0	0	1
09/05/2021 19:00	0.0	0	0	0	0	1
09/05/2021 20:00	0.0	0	0	0	0	1
09/05/2021 21:00	0.0	0	0	0	0	1
09/05/2021 22:00	0.0	0	0	0	0	1
09/05/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/06/2021 00:00	0.0	0	0	0	0	1
09/06/2021 01:00	0.0	0	0	0	0	1
09/06/2021 02:00	0.0	0	0	0	0	1
09/06/2021 03:00	0.0	0	0	0	0	1
09/06/2021 04:00	0.0	0	0	0	0	1
09/06/2021 05:00	0.0	0	0	0	0	1
09/06/2021 06:00	0.0	0	0	0	0	1
09/06/2021 07:00	0.0	0	0	0	0	1
09/06/2021 08:00	0.0	0	0	0	0	1
09/06/2021 09:00	0.0	0	0	0	0	1
09/06/2021 10:00	0.0	0	0	0	0	1
09/06/2021 11:00	0.0	0	0	0	0	1
09/06/2021 12:00	0.0	0	0	0	0	1
09/06/2021 13:00	0.0	0	0	0	0	1
09/06/2021 14:00	0.0	0	0	0	0	1
09/06/2021 15:00	0.0	0	0	0	0	1
09/06/2021 16:00	0.0	0	0	0	0	1
09/06/2021 17:00	0.0	0	0	0	0	1
09/06/2021 18:00	0.0	0	0	0	0	1
09/06/2021 19:00	0.0	0	0	0	0	1
09/06/2021 20:00	0.0	0	0	0	0	1
09/06/2021 21:00	0.0	0	0	0	0	1
09/06/2021 22:00	0.0	0	0	0	0	1
09/06/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/07/2021 00:00	0.0	0	0	0	0	1
09/07/2021 01:00	0.0	0	0	0	0	1
09/07/2021 02:00	0.0	0	0	0	0	1
09/07/2021 03:00	0.0	0	0	0	0	1
09/07/2021 04:00	0.0	0	0	0	0	1
09/07/2021 05:00	0.0	0	0	0	0	1
09/07/2021 06:00	0.0	0	0	0	0	1
09/07/2021 07:00	0.0	0	0	0	0	1
09/07/2021 08:00	0.0	0	0	0	0	1
09/07/2021 09:00	0.0	0	0	0	0	1
09/07/2021 10:00	0.0	0	0	0	0	1
09/07/2021 11:00	0.0	0	0	0	0	1
09/07/2021 12:00	0.0	0	0	0	0	1
09/07/2021 13:00	0.0	0	0	0	0	1
09/07/2021 14:00	0.0	0	0	0	0	1
09/07/2021 15:00	0.0	0	0	0	0	1
09/07/2021 16:00	0.0	0	0	0	0	1
09/07/2021 17:00	0.0	0	0	0	0	1
09/07/2021 18:00	0.0	0	0	0	0	1
09/07/2021 19:00	0.0	0	0	0	0	1
09/07/2021 20:00	0.0	0	0	0	0	1
09/07/2021 21:00	0.0	0	0	0	0	1
09/07/2021 22:00	0.0	0	0	0	0	1
09/07/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/08/2021 00:00	0.0	0	0	0	0	1
09/08/2021 01:00	0.0	0	0	0	0	1
09/08/2021 02:00	0.0	0	0	0	0	1
09/08/2021 03:00	0.0	0	0	0	0	1
09/08/2021 04:00	0.0	0	0	0	0	1
09/08/2021 05:00	0.0	0	0	0	0	1
09/08/2021 06:00	0.0	0	0	0	0	1
09/08/2021 07:00	0.0	0	0	0	0	1
09/08/2021 08:00	0.0	0	0	0	0	1
09/08/2021 09:00	0.0	0	0	0	0	1
09/08/2021 10:00	0.0	0	0	0	0	1
09/08/2021 11:00	0.0	0	0	0	0	1
09/08/2021 12:00	0.0	0	0	0	0	1
09/08/2021 13:00	0.0	0	0	0	0	1
09/08/2021 14:00	0.0	0	0	0	0	1
09/08/2021 15:00	0.0	0	0	0	0	1
09/08/2021 16:00	0.0	0	0	0	0	1
09/08/2021 17:00	0.0	0	0	0	0	1
09/08/2021 18:00	0.0	0	0	0	0	1
09/08/2021 19:00	0.0	0	0	0	0	1
09/08/2021 20:00	0.0	0	0	0	0	1
09/08/2021 21:00	0.0	0	0	0	0	1
09/08/2021 22:00	0.0	0	0	0	0	1
09/08/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/09/2021 00:00	0.0	0	0	0	0	1
09/09/2021 01:00	0.0	0	0	0	0	1
09/09/2021 02:00	0.0	0	0	0	0	1
09/09/2021 03:00	0.0	0	0	0	0	1
09/09/2021 04:00	0.0	0	0	0	0	1
09/09/2021 05:00	0.0	0	0	0	0	1
09/09/2021 06:00	0.0	0	0	0	0	1
09/09/2021 07:00	0.0	0	0	0	0	1
09/09/2021 08:00	0.0	0	0	0	0	1
09/09/2021 09:00	0.0	0	0	0	0	1
09/09/2021 10:00	0.0	0	0	0	0	1
09/09/2021 11:00	0.0	0	0	0	0	1
09/09/2021 12:00	0.0	0	0	0	0	1
09/09/2021 13:00	0.0	0	0	0	0	1
09/09/2021 14:00	0.0	0	0	0	0	1
09/09/2021 15:00	0.0	0	0	0	0	1
09/09/2021 16:00	0.0	0	0	0	0	1
09/09/2021 17:00	0.0	0	0	0	0	1
09/09/2021 18:00	0.0	0	0	0	0	1
09/09/2021 19:00	0.0	0	0	0	0	1
09/09/2021 20:00	0.0	0	0	0	0	1
09/09/2021 21:00	0.0	0	0	0	0	1
09/09/2021 22:00	0.0	0	0	0	0	1
09/09/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/10/2021 00:00	0.0	0	0	0	0	1
09/10/2021 01:00	0.0	0	0	0	0	1
09/10/2021 02:00	0.0	0	0	0	0	1
09/10/2021 03:00	0.0	0	0	0	0	1
09/10/2021 04:00	0.0	0	0	0	0	1
09/10/2021 05:00	0.0	0	0	0	0	1
09/10/2021 06:00	0.0	0	0	0	0	1
09/10/2021 07:00	0.0	0	0	0	0	1
09/10/2021 08:00	0.0	0	0	0	0	1
09/10/2021 09:00	0.0	0	0	0	0	1
09/10/2021 10:00	0.0	0	0	0	0	1
09/10/2021 11:00	0.0	0	0	0	0	1
09/10/2021 12:00	0.0	0	0	0	0	1
09/10/2021 13:00	0.0	0	0	0	0	1
09/10/2021 14:00	0.0	0	0	0	0	1
09/10/2021 15:00	0.0	0	0	0	0	1
09/10/2021 16:00	0.0	0	0	0	0	1
09/10/2021 17:00	0.0	0	0	0	0	1
09/10/2021 18:00	0.0	0	0	0	0	1
09/10/2021 19:00	0.0	0	0	0	0	1
09/10/2021 20:00	0.0	0	0	0	0	1
09/10/2021 21:00	0.0	0	0	0	0	1
09/10/2021 22:00	0.0	0	0	0	0	1
09/10/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/11/2021 00:00	0.0	0	0	0	0	1
09/11/2021 01:00	0.0	0	0	0	0	1
09/11/2021 02:00	0.0	0	0	0	0	1
09/11/2021 03:00	0.0	0	0	0	0	1
09/11/2021 04:00	0.0	0	0	0	0	1
09/11/2021 05:00	0.0	0	0	0	0	1
09/11/2021 06:00	0.0	0	0	0	0	1
09/11/2021 07:00	0.0	0	0	0	0	1
09/11/2021 08:00	0.0	0	0	0	0	1
09/11/2021 09:00	0.0	0	0	0	0	1
09/11/2021 10:00	0.0	0	0	0	0	1
09/11/2021 11:00	0.0	0	0	0	0	1
09/11/2021 12:00	0.0	0	0	0	0	1
09/11/2021 13:00	0.0	0	0	0	0	1
09/11/2021 14:00	0.0	0	0	0	0	1
09/11/2021 15:00	0.0	0	0	0	0	1
09/11/2021 16:00	0.0	0	0	0	0	1
09/11/2021 17:00	0.0	0	0	0	0	1
09/11/2021 18:00	0.0	0	0	0	0	1
09/11/2021 19:00	0.0	0	0	0	0	1
09/11/2021 20:00	0.0	0	0	0	0	1
09/11/2021 21:00	0.0	0	0	0	0	1
09/11/2021 22:00	0.0	0	0	0	0	1
09/11/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/12/2021 00:00	0.0	0	0	0	0	1
09/12/2021 01:00	0.0	0	0	0	0	1
09/12/2021 02:00	0.0	0	0	0	0	1
09/12/2021 03:00	0.0	0	0	0	0	1
09/12/2021 04:00	0.0	0	0	0	0	1
09/12/2021 05:00	0.0	0	0	0	0	1
09/12/2021 06:00	0.0	0	0	0	0	1
09/12/2021 07:00	0.0	0	0	0	0	1
09/12/2021 08:00	0.0	0	0	0	0	1
09/12/2021 09:00	0.0	0	0	0	0	1
09/12/2021 10:00	0.0	0	0	0	0	1
09/12/2021 11:00	0.0	0	0	0	0	1
09/12/2021 12:00	0.0	0	0	0	0	1
09/12/2021 13:00	0.0	0	0	0	0	1
09/12/2021 14:00	0.0	0	0	0	0	1
09/12/2021 15:00	0.0	0	0	0	0	1
09/12/2021 16:00	0.0	0	0	0	0	1
09/12/2021 17:00	0.0	0	0	0	0	1
09/12/2021 18:00	0.0	0	0	0	0	1
09/12/2021 19:00	0.0	0	0	0	0	1
09/12/2021 20:00	0.0	0	0	0	0	1
09/12/2021 21:00	0.0	0	0	0	0	1
09/12/2021 22:00	0.0	0	0	0	0	1
09/12/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/13/2021 00:00	0.0	0	0	0	0	1
09/13/2021 01:00	0.0	0	0	0	0	1
09/13/2021 02:00	0.0	0	0	0	0	1
09/13/2021 03:00	0.0	0	0	0	0	1
09/13/2021 04:00	0.0	0	0	0	0	1
09/13/2021 05:00	0.0	0	0	0	0	1
09/13/2021 06:00	0.0	0	0	0	0	1
09/13/2021 07:00	0.0	0	0	0	0	1
09/13/2021 08:00	0.0	0	0	0	0	1
09/13/2021 09:00	0.0	0	0	0	0	1
09/13/2021 10:00	0.0	0	0	0	0	1
09/13/2021 11:00	0.0	0	0	0	0	1
09/13/2021 12:00	0.0	0	0	0	0	1
09/13/2021 13:00	0.0	0	0	0	0	1
09/13/2021 14:00	0.0	0	0	0	0	1
09/13/2021 15:00	0.0	0	0	0	0	1
09/13/2021 16:00	0.0	0	0	0	0	1
09/13/2021 17:00	0.0	0	0	0	0	1
09/13/2021 18:00	0.0	0	0	0	0	1
09/13/2021 19:00	0.0	0	0	0	0	1
09/13/2021 20:00	0.0	0	0	0	0	1
09/13/2021 21:00	0.0	0	0	0	0	1
09/13/2021 22:00	0.0	0	0	0	0	1
09/13/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/14/2021 00:00	0.0	0	0	0	0	1
09/14/2021 01:00	0.0	0	0	0	0	1
09/14/2021 02:00	0.0	0	0	0	0	1
09/14/2021 03:00	0.0	0	0	0	0	1
09/14/2021 04:00	0.0	0	0	0	0	1
09/14/2021 05:00	0.0	0	0	0	0	1
09/14/2021 06:00	0.0	0	0	0	0	1
09/14/2021 07:00	0.0	0	0	0	0	1
09/14/2021 08:00	0.0	0	0	0	0	1
09/14/2021 09:00	0.0	0	0	0	0	1
09/14/2021 10:00	0.0	0	0	0	0	1
09/14/2021 11:00	0.0	0	0	0	0	1
09/14/2021 12:00	0.0	0	0	0	0	1
09/14/2021 13:00	0.0	0	0	0	0	1
09/14/2021 14:00	0.0	0	0	0	0	1
09/14/2021 15:00	0.0	0	0	0	0	1
09/14/2021 16:00	0.0	0	0	0	0	1
09/14/2021 17:00	0.0	0	0	0	0	1
09/14/2021 18:00	0.0	0	0	0	0	1
09/14/2021 19:00	0.0	0	0	0	0	1
09/14/2021 20:00	0.0	0	0	0	0	1
09/14/2021 21:00	0.0	0	0	0	0	1
09/14/2021 22:00	0.0	0	0	0	0	1
09/14/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/15/2021 00:00	0.0	0	0	0	0	1
09/15/2021 01:00	0.0	0	0	0	0	1
09/15/2021 02:00	0.0	0	0	0	0	1
09/15/2021 03:00	0.0	0	0	0	0	1
09/15/2021 04:00	0.0	0	0	0	0	1
09/15/2021 05:00	0.0	0	0	0	0	1
09/15/2021 06:00	0.0	0	0	0	0	1
09/15/2021 07:00	0.0	0	0	0	0	1
09/15/2021 08:00	0.0	0	0	0	0	1
09/15/2021 09:00	0.0	0	0	0	0	1
09/15/2021 10:00	0.0	0	0	0	0	1
09/15/2021 11:00	0.0	0	0	0	0	1
09/15/2021 12:00	0.0	0	0	0	0	1
09/15/2021 13:00	0.0	0	0	0	0	1
09/15/2021 14:00	0.0	0	0	0	0	1
09/15/2021 15:00	0.0	0	0	0	0	1
09/15/2021 16:00	0.0	0	0	0	0	1
09/15/2021 17:00	0.0	0	0	0	0	1
09/15/2021 18:00	0.0	0	0	0	0	1
09/15/2021 19:00	0.0	0	0	0	0	1
09/15/2021 20:00	0.0	0	0	0	0	1
09/15/2021 21:00	0.0	0	0	0	0	1
09/15/2021 22:00	0.0	0	0	0	0	1
09/15/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/16/2021 00:00	0.0	0	0	0	0	1
09/16/2021 01:00	0.0	0	0	0	0	1
09/16/2021 02:00	0.0	0	0	0	0	1
09/16/2021 03:00	0.0	0	0	0	0	1
09/16/2021 04:00	0.0	0	0	0	0	1
09/16/2021 05:00	0.0	0	0	0	0	1
09/16/2021 06:00	0.0	0	0	0	0	1
09/16/2021 07:00	0.0	0	0	0	0	1
09/16/2021 08:00	0.0	0	0	0	0	1
09/16/2021 09:00	0.0	0	0	0	0	1
09/16/2021 10:00	0.0	0	0	0	0	1
09/16/2021 11:00	0.0	0	0	0	0	1
09/16/2021 12:00	0.0	0	0	0	0	1
09/16/2021 13:00	0.0	0	0	0	0	1
09/16/2021 14:00	0.0	0	0	0	0	1
09/16/2021 15:00	0.0	0	0	0	0	1
09/16/2021 16:00	0.0	0	0	0	0	1
09/16/2021 17:00	0.0	0	0	0	0	1
09/16/2021 18:00	0.0	0	0	0	0	1
09/16/2021 19:00	0.0	0	0	0	0	1
09/16/2021 20:00	0.0	0	0	0	0	1
09/16/2021 21:00	0.0	0	0	0	0	1
09/16/2021 22:00	0.0	0	0	0	0	1
09/16/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/17/2021 00:00	0.0	0	0	0	0	1
09/17/2021 01:00	0.0	0	0	0	0	1
09/17/2021 02:00	0.0	0	0	0	0	1
09/17/2021 03:00	0.0	0	0	0	0	1
09/17/2021 04:00	0.0	0	0	0	0	1
09/17/2021 05:00	0.0	0	0	0	0	1
09/17/2021 06:00	0.0	0	0	0	0	1
09/17/2021 07:00	0.0	0	0	0	0	1
09/17/2021 08:00	0.0	0	0	0	0	1
09/17/2021 09:00	0.0	0	0	0	0	1
09/17/2021 10:00	0.0	0	0	0	0	1
09/17/2021 11:00	0.0	0	0	0	0	1
09/17/2021 12:00	0.0	0	0	0	0	1
09/17/2021 13:00	0.0	0	0	0	0	1
09/17/2021 14:00	0.0	0	0	0	0	1
09/17/2021 15:00	0.0	0	0	0	0	1
09/17/2021 16:00	0.0	0	0	0	0	1
09/17/2021 17:00	0.0	0	0	0	0	1
09/17/2021 18:00	0.0	0	0	0	0	1
09/17/2021 19:00	0.0	0	0	0	0	1
09/17/2021 20:00	0.0	0	0	0	0	1
09/17/2021 21:00	0.0	0	0	0	0	1
09/17/2021 22:00	0.0	0	0	0	0	1
09/17/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/18/2021 00:00	0.0	0	0	0	0	1
09/18/2021 01:00	0.0	0	0	0	0	1
09/18/2021 02:00	0.0	0	0	0	0	1
09/18/2021 03:00	0.0	0	0	0	0	1
09/18/2021 04:00	0.0	0	0	0	0	1
09/18/2021 05:00	0.0	0	0	0	0	1
09/18/2021 06:00	0.0	0	0	0	0	1
09/18/2021 07:00	0.0	0	0	0	0	1
09/18/2021 08:00	0.0	0	0	0	0	1
09/18/2021 09:00	0.0	0	0	0	0	1
09/18/2021 10:00	0.0	0	0	0	0	1
09/18/2021 11:00	0.0	0	0	0	0	1
09/18/2021 12:00	0.0	0	0	0	0	1
09/18/2021 13:00	0.0	0	0	0	0	1
09/18/2021 14:00	0.0	0	0	0	0	1
09/18/2021 15:00	0.0	0	0	0	0	1
09/18/2021 16:00	0.0	0	0	0	0	1
09/18/2021 17:00	0.0	0	0	0	0	1
09/18/2021 18:00	0.0	0	0	0	0	1
09/18/2021 19:00	0.0	0	0	0	0	1
09/18/2021 20:00	0.0	0	0	0	0	1
09/18/2021 21:00	0.0	0	0	0	0	1
09/18/2021 22:00	0.0	0	0	0	0	1
09/18/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/19/2021 00:00	0.0	0	0	0	0	1
09/19/2021 01:00	0.0	0	0	0	0	1
09/19/2021 02:00	0.0	0	0	0	0	1
09/19/2021 03:00	0.0	0	0	0	0	1
09/19/2021 04:00	0.0	0	0	0	0	1
09/19/2021 05:00	0.0	0	0	0	0	1
09/19/2021 06:00	0.0	0	0	0	0	1
09/19/2021 07:00	0.0	0	0	0	0	1
09/19/2021 08:00	0.0	0	0	0	0	1
09/19/2021 09:00	0.0	0	0	0	0	1
09/19/2021 10:00	0.0	0	0	0	0	1
09/19/2021 11:00	0.0	0	0	0	0	1
09/19/2021 12:00	0.0	0	0	0	0	1
09/19/2021 13:00	0.0	0	0	0	0	1
09/19/2021 14:00	0.0	0	0	0	0	1
09/19/2021 15:00	0.0	0	0	0	0	1
09/19/2021 16:00	0.0	0	0	0	0	1
09/19/2021 17:00	0.0	0	0	0	0	1
09/19/2021 18:00	0.0	0	0	0	0	1
09/19/2021 19:00	0.0	0	0	0	0	1
09/19/2021 20:00	0.0	0	0	0	0	1
09/19/2021 21:00	0.0	0	0	0	0	1
09/19/2021 22:00	0.0	0	0	0	0	1
09/19/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/20/2021 00:00	0.0	0	0	0	0	1
09/20/2021 01:00	0.0	0	0	0	0	1
09/20/2021 02:00	0.0	0	0	0	0	1
09/20/2021 03:00	0.0	0	0	0	0	1
09/20/2021 04:00	0.0	0	0	0	0	1
09/20/2021 05:00	0.0	0	0	0	0	1
09/20/2021 06:00	0.0	0	0	0	0	1
09/20/2021 07:00	0.0	0	0	0	0	1
09/20/2021 08:00	0.0	0	0	0	0	1
09/20/2021 09:00	0.0	0	0	0	0	1
09/20/2021 10:00	0.0	0	0	0	0	1
09/20/2021 11:00	0.0	0	0	0	0	1
09/20/2021 12:00	0.0	0	0	0	0	1
09/20/2021 13:00	0.0	0	0	0	0	1
09/20/2021 14:00	0.0	0	0	0	0	1
09/20/2021 15:00	0.0	0	0	0	0	1
09/20/2021 16:00	0.0	0	0	0	0	1
09/20/2021 17:00	0.0	0	0	0	0	1
09/20/2021 18:00	0.0	0	0	0	0	1
09/20/2021 19:00	0.0	0	0	0	0	1
09/20/2021 20:00	0.0	0	0	0	0	1
09/20/2021 21:00	0.0	0	0	0	0	1
09/20/2021 22:00	0.0	0	0	0	0	1
09/20/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/21/2021 00:00	0.0	0	0	0	0	1
09/21/2021 01:00	0.0	0	0	0	0	1
09/21/2021 02:00	0.0	0	0	0	0	1
09/21/2021 03:00	0.0	0	0	0	0	1
09/21/2021 04:00	0.0	0	0	0	0	1
09/21/2021 05:00	0.0	0	0	0	0	1
09/21/2021 06:00	0.0	0	0	0	0	1
09/21/2021 07:00	0.0	0	0	0	0	1
09/21/2021 08:00	0.0	0	0	0	0	1
09/21/2021 09:00	0.0	0	0	0	0	1
09/21/2021 10:00	0.0	0	0	0	0	1
09/21/2021 11:00	0.0	0	0	0	0	1
09/21/2021 12:00	0.0	0	0	0	0	1
09/21/2021 13:00	0.0	0	0	0	0	1
09/21/2021 14:00	0.0	0	0	0	0	1
09/21/2021 15:00	0.0	0	0	0	0	1
09/21/2021 16:00	0.0	0	0	0	0	1
09/21/2021 17:00	0.0	0	0	0	0	1
09/21/2021 18:00	0.0	0	0	0	0	1
09/21/2021 19:00	0.0	0	0	0	0	1
09/21/2021 20:00	0.0	0	0	0	0	1
09/21/2021 21:00	0.0	0	0	0	0	1
09/21/2021 22:00	0.0	0	0	0	0	1
09/21/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/22/2021 00:00	0.0	0	0	0	0	1
09/22/2021 01:00	0.0	0	0	0	0	1
09/22/2021 02:00	0.0	0	0	0	0	1
09/22/2021 03:00	0.0	0	0	0	0	1
09/22/2021 04:00	0.0	0	0	0	0	1
09/22/2021 05:00	0.0	0	0	0	0	1
09/22/2021 06:00	0.0	0	0	0	0	1
09/22/2021 07:00	0.0	0	0	0	0	1
09/22/2021 08:00	0.0	0	0	0	0	1
09/22/2021 09:00	0.0	0	0	0	0	1
09/22/2021 10:00	0.0	0	0	0	0	1
09/22/2021 11:00	0.0	0	0	0	0	1
09/22/2021 12:00	0.0	0	0	0	0	1
09/22/2021 13:00	0.0	0	0	0	0	1
09/22/2021 14:00	0.0	0	0	0	0	1
09/22/2021 15:00	0.0	0	0	0	0	1
09/22/2021 16:00	0.0	0	0	0	0	1
09/22/2021 17:00	0.0	0	0	0	0	1
09/22/2021 18:00	0.0	0	0	0	0	1
09/22/2021 19:00	0.0	0	0	0	0	1
09/22/2021 20:00	0.0	0	0	0	0	1
09/22/2021 21:00	0.0	0	0	0	0	1
09/22/2021 22:00	0.0	0	0	0	0	1
09/22/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/23/2021 00:00	0.0	0	0	0	0	1
09/23/2021 01:00	0.0	0	0	0	0	1
09/23/2021 02:00	0.0	0	0	0	0	1
09/23/2021 03:00	0.0	0	0	0	0	1
09/23/2021 04:00	0.0	0	0	0	0	1
09/23/2021 05:00	0.0	0	0	0	0	1
09/23/2021 06:00	0.0	0	0	0	0	1
09/23/2021 07:00	0.0	0	0	0	0	1
09/23/2021 08:00	0.0	0	0	0	0	1
09/23/2021 09:00	0.0	0	0	0	0	1
09/23/2021 10:00	0.0	0	0	0	0	1
09/23/2021 11:00	0.0	0	0	0	0	1
09/23/2021 12:00	0.0	0	0	0	0	1
09/23/2021 13:00	0.0	0	0	0	0	1
09/23/2021 14:00	0.0	0	0	0	0	1
09/23/2021 15:00	0.0	0	0	0	0	1
09/23/2021 16:00	0.0	0	0	0	0	1
09/23/2021 17:00	0.0	0	0	0	0	1
09/23/2021 18:00	0.0	0	0	0	0	1
09/23/2021 19:00	0.0	0	0	0	0	1
09/23/2021 20:00	0.0	0	0	0	0	1
09/23/2021 21:00	0.0	0	0	0	0	1
09/23/2021 22:00	0.0	0	0	0	0	1
09/23/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/24/2021 00:00	0.0	0	0	0	0	1
09/24/2021 01:00	0.0	0	0	0	0	1
09/24/2021 02:00	0.0	0	0	0	0	1
09/24/2021 03:00	0.0	0	0	0	0	1
09/24/2021 04:00	0.0	0	0	0	0	1
09/24/2021 05:00	0.0	0	0	0	0	1
09/24/2021 06:00	0.0	0	0	0	0	1
09/24/2021 07:00	0.0	0	0	0	0	1
09/24/2021 08:00	0.0	0	0	0	0	1
09/24/2021 09:00	0.0	0	0	0	0	1
09/24/2021 10:00	0.0	0	0	0	0	1
09/24/2021 11:00	0.0	0	0	0	0	1
09/24/2021 12:00	0.0	0	0	0	0	1
09/24/2021 13:00	0.0	0	0	0	0	1
09/24/2021 14:00	0.0	0	0	0	0	1
09/24/2021 15:00	0.0	0	0	0	0	1
09/24/2021 16:00	0.0	0	0	0	0	1
09/24/2021 17:00	0.0	0	0	0	0	1
09/24/2021 18:00	0.0	0	0	0	0	1
09/24/2021 19:00	0.0	0	0	0	0	1
09/24/2021 20:00	0.0	0	0	0	0	1
09/24/2021 21:00	0.0	0	0	0	0	1
09/24/2021 22:00	0.0	0	0	0	0	1
09/24/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/25/2021 00:00	0.0	0	0	0	0	1
09/25/2021 01:00	0.0	0	0	0	0	1
09/25/2021 02:00	0.0	0	0	0	0	1
09/25/2021 03:00	0.0	0	0	0	0	1
09/25/2021 04:00	0.0	0	0	0	0	1
09/25/2021 05:00	0.0	0	0	0	0	1
09/25/2021 06:00	0.0	0	0	0	0	1
09/25/2021 07:00	0.0	0	0	0	0	1
09/25/2021 08:00	0.0	0	0	0	0	1
09/25/2021 09:00	0.0	0	0	0	0	1
09/25/2021 10:00	0.0	0	0	0	0	1
09/25/2021 11:00	0.0	0	0	0	0	1
09/25/2021 12:00	0.0	0	0	0	0	1
09/25/2021 13:00	0.0	0	0	0	0	1
09/25/2021 14:00	0.0	0	0	0	0	1
09/25/2021 15:00	0.0	0	0	0	0	1
09/25/2021 16:00	0.0	0	0	0	0	1
09/25/2021 17:00	0.0	0	0	0	0	1
09/25/2021 18:00	0.0	0	0	0	0	1
09/25/2021 19:00	0.0	0	0	0	0	1
09/25/2021 20:00	0.0	0	0	0	0	1
09/25/2021 21:00	0.0	0	0	0	0	1
09/25/2021 22:00	2.3	0	0	0	1	0
09/25/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	2.3 #	0 #	0 #	0 #	1 #	22 #
Minimum:	0.0	0	0	0	0	0
Maximum:	2.3	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/26/2021 00:00	0.0	0	0	0	0	0
09/26/2021 01:00	0.0	0	0	0	0	0
09/26/2021 02:00	0.0	0	0	0	0	0
09/26/2021 03:00	0.0	0	0	0	0	0
09/26/2021 04:00	0.0	0	0	0	0	0
09/26/2021 05:00	0.0	0	0	0	0	0
09/26/2021 06:00	0.0	0	0	0	0	0
09/26/2021 07:00	0.0	0	0	0	0	0
09/26/2021 08:00	0.0	0	0	0	0	0
09/26/2021 09:00	0.0	0	0	0	0	0
09/26/2021 10:00	0.0	0	0	0	0	0
09/26/2021 11:00	0.0	0	0	0	0	0
09/26/2021 12:00	0.0	0	0	0	0	0
09/26/2021 13:00	0.0	0	0	0	0	0
09/26/2021 14:00	0.0	0	0	0	0	0
09/26/2021 15:00	0.0	0	0	0	0	0
09/26/2021 16:00	0.0	0	0	0	0	0
09/26/2021 17:00	0.0	0	0	0	0	0
09/26/2021 18:00	0.0	0	0	0	0	0
09/26/2021 19:00	0.0	0	0	0	0	0
09/26/2021 20:00	0.0	0	0	0	0	0
09/26/2021 21:00	0.0	0	0	0	0	0
09/26/2021 22:00	0.0	0	0	0	0	0
09/26/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/27/2021 00:00	0.0	0	0	0	0	0
09/27/2021 01:00	0.0	0	0	0	0	0
09/27/2021 02:00	0.0	0	0	0	0	0
09/27/2021 03:00	0.0	0	0	0	0	0
09/27/2021 04:00	0.0	0	0	0	0	0
09/27/2021 05:00	0.0	0	0	0	0	0
09/27/2021 06:00	0.0	0	0	0	0	0
09/27/2021 07:00	0.0	0	0	0	0	0
09/27/2021 08:00	0.0	0	0	0	0	0
09/27/2021 09:00	0.0	0	0	0	0	0
09/27/2021 10:00	0.0	0	0	0	0	0
09/27/2021 11:00	0.0	0	0	0	0	0
09/27/2021 12:00	0.0	0	0	0	0	0
09/27/2021 13:00	0.0	0	0	0	0	0
09/27/2021 14:00	0.0	0	0	0	0	0
09/27/2021 15:00	0.0	0	0	0	0	0
09/27/2021 16:00	0.0	0	0	0	0	0
09/27/2021 17:00	0.0	0	0	0	0	0
09/27/2021 18:00	0.0	0	0	0	0	0
09/27/2021 19:00	0.0	0	0	0	0	0
09/27/2021 20:00	0.0	0	0	0	0	0
09/27/2021 21:00	0.0	0	0	0	0	0
09/27/2021 22:00	0.0	0	0	0	0	0
09/27/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/28/2021 00:00	0.0	0	0	0	0	0
09/28/2021 01:00	0.0	0	0	0	0	0
09/28/2021 02:00	0.0	0	0	0	0	0
09/28/2021 03:00	0.0	0	0	0	0	0
09/28/2021 04:00	0.0	0	0	0	0	0
09/28/2021 05:00	0.0	0	0	0	0	0
09/28/2021 06:00	0.0	0	0	0	0	0
09/28/2021 07:00	0.0	0	0	0	0	0
09/28/2021 08:00	0.0	0	0	0	0	0
09/28/2021 09:00	0.0	0	0	0	0	0
09/28/2021 10:00	0.0	0	0	0	0	0
09/28/2021 11:00	0.0	0	0	0	0	0
09/28/2021 12:00	0.0	0	0	0	0	0
09/28/2021 13:00	0.0	0	0	0	0	0
09/28/2021 14:00	0.0	0	0	0	0	0
09/28/2021 15:00	0.0	0	0	0	0	0
09/28/2021 16:00	0.0	0	0	0	0	0
09/28/2021 17:00	0.0	0	0	0	0	0
09/28/2021 18:00	0.0	0	0	0	0	0
09/28/2021 19:00	0.0	0	0	0	0	0
09/28/2021 20:00	0.0	0	0	0	0	0
09/28/2021 21:00	0.0	0	0	0	0	0
09/28/2021 22:00	0.0	0	0	0	0	0
09/28/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/29/2021 00:00	0.0	0	0	0	0	0
09/29/2021 01:00	0.0	0	0	0	0	0
09/29/2021 02:00	0.0	0	0	0	0	0
09/29/2021 03:00	7.2	1	0	0	1	0
09/29/2021 04:00	0.0	0	0	0	0	0
09/29/2021 05:00	0.0	0	0	0	0	0
09/29/2021 06:00	0.0	0	0	0	0	0
09/29/2021 07:00	0.0	0	0	0	0	0
09/29/2021 08:00	9.1	1	0	0	0	0
09/29/2021 09:00	60.8	1	0	0	0	0
09/29/2021 10:00	0.0	0	0	0	0	1
09/29/2021 11:00	0.0	0	0	0	0	1
09/29/2021 12:00	0.0	0	0	0	0	1
09/29/2021 13:00	0.0	0	0	0	0	1
09/29/2021 14:00	0.0	0	0	0	0	1
09/29/2021 15:00	0.0	0	0	0	0	1
09/29/2021 16:00	0.0	0	0	0	0	1
09/29/2021 17:00	0.0	0	0	0	0	1
09/29/2021 18:00	0.0	0	0	0	0	1
09/29/2021 19:00	0.0	0	0	0	0	1
09/29/2021 20:00	0.0	0	0	0	0	1
09/29/2021 21:00	0.0	0	0	0	0	1
09/29/2021 22:00	0.0	0	0	0	0	1
09/29/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	77.1 #	3 #	0 #	0 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	60.8	1	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/30/2021 00:00	0.0	0	0	0	0	1
09/30/2021 01:00	0.0	0	0	0	0	1
09/30/2021 02:00	0.0	0	0	0	0	1
09/30/2021 03:00	0.0	0	0	0	0	1
09/30/2021 04:00	0.0	0	0	0	0	1
09/30/2021 05:00	0.0	0	0	0	0	1
09/30/2021 06:00	0.0	0	0	0	0	1
09/30/2021 07:00	0.0	0	0	0	0	1
09/30/2021 08:00	0.0	0	0	0	0	1
09/30/2021 09:00	0.0	0	0	0	0	1
09/30/2021 10:00	0.0	0	0	0	0	1
09/30/2021 11:00	0.0	0	0	0	0	1
09/30/2021 12:00	0.0	0	0	0	0	1
09/30/2021 13:00	0.0	0	0	0	0	1
09/30/2021 14:00	0.0	0	0	0	0	1
09/30/2021 15:00	0.0	0	0	0	0	1
09/30/2021 16:00	0.0	0	0	0	0	1
09/30/2021 17:00	0.0	0	0	0	0	1
09/30/2021 18:00	0.0	0	0	0	0	1
09/30/2021 19:00	0.0	0	0	0	0	1
09/30/2021 20:00	0.0	0	0	0	0	1
09/30/2021 21:00	0.0	0	0	0	0	1
09/30/2021 22:00	0.0	0	0	0	0	1
09/30/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/01/2021 00:00	0.0	0	0	0	0	0
07/01/2021 01:00	0.0	0	0	0	0	0
07/01/2021 02:00	0.0	0	0	0	0	0
07/01/2021 03:00	0.0	0	0	0	0	0
07/01/2021 04:00	0.0	0	0	0	0	0
07/01/2021 05:00	0.0	0	0	0	0	0
07/01/2021 06:00	0.0	0	0	0	0	0
07/01/2021 07:00	0.0	0	0	0	0	0
07/01/2021 08:00	0.0	0	0	0	0	0
07/01/2021 09:00	0.0	0	0	0	0	0
07/01/2021 10:00	0.0	0	0	0	0	0
07/01/2021 11:00	0.0	0	0	0	0	0
07/01/2021 12:00	0.0	0	0	0	0	0
07/01/2021 13:00	0.0	0	0	0	0	0
07/01/2021 14:00	0.0	0	0	0	0	0
07/01/2021 15:00	0.0	0	0	0	0	0
07/01/2021 16:00	0.0	0	0	0	0	0
07/01/2021 17:00	0.0	0	0	0	0	0
07/01/2021 18:00	0.0	0	0	0	0	0
07/01/2021 19:00	0.0	0	0	0	0	0
07/01/2021 20:00	0.0	0	0	0	0	0
07/01/2021 21:00	0.0	0	0	0	0	0
07/01/2021 22:00	0.0	0	0	0	0	0
07/01/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/02/2021 00:00	0.0	0	0	0	0	0
07/02/2021 01:00	0.0	0	0	0	0	0
07/02/2021 02:00	0.0	0	0	0	0	0
07/02/2021 03:00	0.0	0	0	0	0	0
07/02/2021 04:00	0.0	0	0	0	0	0
07/02/2021 05:00	0.0	0	0	0	0	0
07/02/2021 06:00	0.0	0	0	0	0	0
07/02/2021 07:00	0.0	0	0	0	0	0
07/02/2021 08:00	0.0	0	0	0	0	0
07/02/2021 09:00	0.0	0	0	0	0	0
07/02/2021 10:00	0.0	0	0	0	0	0
07/02/2021 11:00	0.0	0	0	0	0	0
07/02/2021 12:00	0.0	0	0	0	0	0
07/02/2021 13:00	0.0	0	0	0	0	0
07/02/2021 14:00	0.0	0	0	0	0	0
07/02/2021 15:00	0.0	0	0	0	0	0
07/02/2021 16:00	0.0	0	0	0	0	0
07/02/2021 17:00	0.0	0	0	0	0	0
07/02/2021 18:00	0.0	0	0	0	0	0
07/02/2021 19:00	0.0	0	0	0	0	0
07/02/2021 20:00	0.0	0	0	0	0	0
07/02/2021 21:00	0.0	0	0	0	0	0
07/02/2021 22:00	0.0	0	0	0	0	0
07/02/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/03/2021 00:00	0.0	0	0	0	0	0
07/03/2021 01:00	0.0	0	0	0	0	0
07/03/2021 02:00	0.0	0	0	0	0	0
07/03/2021 03:00	0.0	0	0	0	0	0
07/03/2021 04:00	0.0	0	0	0	0	0
07/03/2021 05:00	0.0	0	0	0	0	0
07/03/2021 06:00	0.0	0	0	0	0	0
07/03/2021 07:00	0.0	0	0	0	0	0
07/03/2021 08:00	0.0	0	0	0	0	0
07/03/2021 09:00	0.0	0	0	0	0	0
07/03/2021 10:00	0.0	0	0	0	0	0
07/03/2021 11:00	0.0	0	0	0	0	0
07/03/2021 12:00	0.0	0	0	0	0	0
07/03/2021 13:00	0.0	0	0	0	0	0
07/03/2021 14:00	0.0	0	0	0	0	0
07/03/2021 15:00	0.0	0	0	0	0	0
07/03/2021 16:00	0.0	0	0	0	0	0
07/03/2021 17:00	0.0	0	0	0	0	0
07/03/2021 18:00	0.0	0	0	0	0	0
07/03/2021 19:00	0.0	0	0	0	0	0
07/03/2021 20:00	0.0	0	0	0	0	0
07/03/2021 21:00	0.0	0	0	0	0	0
07/03/2021 22:00	0.0	0	0	0	0	0
07/03/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/04/2021 00:00	0.0	0	0	0	0	0
07/04/2021 01:00	0.0	0	0	0	0	0
07/04/2021 02:00	0.0	0	0	0	0	0
07/04/2021 03:00	0.0	0	0	0	0	0
07/04/2021 04:00	0.0	0	0	0	0	0
07/04/2021 05:00	0.0	0	0	0	0	0
07/04/2021 06:00	0.0	0	0	0	0	0
07/04/2021 07:00	0.0	0	0	0	0	0
07/04/2021 08:00	0.0	0	0	0	0	0
07/04/2021 09:00	0.0	0	0	0	0	0
07/04/2021 10:00	0.0	0	0	0	0	0
07/04/2021 11:00	0.0	0	0	0	0	0
07/04/2021 12:00	0.0	0	0	0	0	0
07/04/2021 13:00	0.0	0	0	0	0	0
07/04/2021 14:00	0.0	0	0	0	0	0
07/04/2021 15:00	0.0	0	0	0	0	0
07/04/2021 16:00	0.0	0	0	0	0	0
07/04/2021 17:00	0.0	0	0	0	0	0
07/04/2021 18:00	0.0	0	0	0	0	0
07/04/2021 19:00	0.0	0	0	0	0	0
07/04/2021 20:00	0.0	0	0	0	0	0
07/04/2021 21:00	0.0	0	0	0	0	0
07/04/2021 22:00	0.0	0	0	0	0	0
07/04/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/05/2021 00:00	0.0	0	0	0	0	0
07/05/2021 01:00	0.0	0	0	0	0	0
07/05/2021 02:00	0.0	0	0	0	0	0
07/05/2021 03:00	0.0	0	0	0	0	0
07/05/2021 04:00	0.0	0	0	0	0	0
07/05/2021 05:00	0.0	0	0	0	0	0
07/05/2021 06:00	0.0	0	0	0	0	0
07/05/2021 07:00	0.0	0	0	0	0	0
07/05/2021 08:00	0.0	0	0	0	0	0
07/05/2021 09:00	0.0	0	0	0	0	0
07/05/2021 10:00	0.0	0	0	0	0	0
07/05/2021 11:00	0.0	0	0	0	0	0
07/05/2021 12:00	0.0	0	0	0	0	0
07/05/2021 13:00	0.0	0	0	0	0	0
07/05/2021 14:00	0.0	0	0	0	0	0
07/05/2021 15:00	0.0	0	0	0	0	0
07/05/2021 16:00	0.0	0	0	0	0	0
07/05/2021 17:00	0.0	0	0	0	0	0
07/05/2021 18:00	0.0	0	0	0	0	0
07/05/2021 19:00	0.0	0	0	0	0	0
07/05/2021 20:00	0.0	0	0	0	0	0
07/05/2021 21:00	0.0	0	0	0	0	0
07/05/2021 22:00	0.0	0	0	0	0	0
07/05/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/06/2021 00:00	0.0	0	0	0	0	0
07/06/2021 01:00	0.0	0	0	0	0	0
07/06/2021 02:00	0.0	0	0	0	0	0
07/06/2021 03:00	0.0	0	0	0	0	0
07/06/2021 04:00	0.0	0	0	0	0	0
07/06/2021 05:00	0.0	0	0	0	0	0
07/06/2021 06:00	0.0	0	0	0	0	0
07/06/2021 07:00	0.0	0	0	0	0	0
07/06/2021 08:00	0.0	0	0	0	0	0
07/06/2021 09:00	0.0	0	0	0	0	0
07/06/2021 10:00	0.0	0	0	0	0	0
07/06/2021 11:00	0.0	0	0	0	0	0
07/06/2021 12:00	0.0	0	0	0	0	0
07/06/2021 13:00	0.0	0	0	0	0	0
07/06/2021 14:00	0.0	0	0	0	0	0
07/06/2021 15:00	0.0	0	0	0	0	0
07/06/2021 16:00	0.0	0	0	0	0	0
07/06/2021 17:00	0.0	0	0	0	0	0
07/06/2021 18:00	0.0	0	0	0	0	0
07/06/2021 19:00	0.0	0	0	0	0	0
07/06/2021 20:00	0.0	0	0	0	0	0
07/06/2021 21:00	0.0	0	0	0	0	0
07/06/2021 22:00	0.0	0	0	0	0	0
07/06/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/07/2021 00:00	0.0	0	0	0	0	0
07/07/2021 01:00	0.0	0	0	0	0	0
07/07/2021 02:00	0.0	0	0	0	0	0
07/07/2021 03:00	0.0	0	0	0	0	0
07/07/2021 04:00	0.0	0	0	0	0	0
07/07/2021 05:00	0.0	0	0	0	0	0
07/07/2021 06:00	0.0	0	0	0	0	0
07/07/2021 07:00	0.0	0	0	0	0	0
07/07/2021 08:00	0.0	0	0	0	0	0
07/07/2021 09:00	0.0	0	0	0	0	0
07/07/2021 10:00	0.0	0	0	0	0	0
07/07/2021 11:00	0.0	0	0	0	0	0
07/07/2021 12:00	0.0	0	0	0	0	0
07/07/2021 13:00	0.0	0	0	0	0	0
07/07/2021 14:00	0.0	0	0	0	0	0
07/07/2021 15:00	0.0	0	0	0	0	0
07/07/2021 16:00	0.0	0	0	0	0	0
07/07/2021 17:00	0.0	0	0	0	0	0
07/07/2021 18:00	0.0	0	0	0	0	0
07/07/2021 19:00	0.0	0	0	0	0	0
07/07/2021 20:00	0.0	0	0	0	0	0
07/07/2021 21:00	0.0	0	0	0	0	0
07/07/2021 22:00	0.0	0	0	0	0	0
07/07/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/08/2021 00:00	0.0	0	0	0	0	0
07/08/2021 01:00	0.0	0	0	0	0	0
07/08/2021 02:00	0.0	0	0	0	0	0
07/08/2021 03:00	0.0	0	0	0	0	0
07/08/2021 04:00	0.0	0	0	0	0	0
07/08/2021 05:00	0.0	0	0	0	0	0
07/08/2021 06:00	0.0	0	0	0	0	0
07/08/2021 07:00	0.0	0	0	0	0	0
07/08/2021 08:00	0.0	0	0	0	0	0
07/08/2021 09:00	0.0	0	0	0	0	0
07/08/2021 10:00	0.0	0	0	0	0	0
07/08/2021 11:00	0.0	0	0	0	0	0
07/08/2021 12:00	0.0	0	0	0	0	0
07/08/2021 13:00	0.0	0	0	0	0	0
07/08/2021 14:00	0.0	0	0	0	0	0
07/08/2021 15:00	0.0	0	0	0	0	0
07/08/2021 16:00	0.0	0	0	0	0	0
07/08/2021 17:00	0.0	0	0	0	0	0
07/08/2021 18:00	0.0	0	0	0	0	0
07/08/2021 19:00	0.0	0	0	0	0	0
07/08/2021 20:00	0.0	0	0	0	0	0
07/08/2021 21:00	0.0	0	0	0	0	0
07/08/2021 22:00	0.0	0	0	0	0	0
07/08/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/09/2021 00:00	0.0	0	0	0	0	0
07/09/2021 01:00	0.0	0	0	0	0	0
07/09/2021 02:00	0.0	0	0	0	0	0
07/09/2021 03:00	0.0	0	0	0	0	0
07/09/2021 04:00	0.0	0	0	0	0	0
07/09/2021 05:00	0.0	0	0	0	0	0
07/09/2021 06:00	0.0	0	0	0	0	0
07/09/2021 07:00	0.0	0	0	0	0	0
07/09/2021 08:00	0.0	0	0	0	0	0
07/09/2021 09:00	0.0	0	0	0	0	0
07/09/2021 10:00	0.0	0	0	0	0	0
07/09/2021 11:00	0.0	0	0	0	0	0
07/09/2021 12:00	0.0	0	0	0	0	0
07/09/2021 13:00	0.0	0	0	0	0	0
07/09/2021 14:00	0.0	0	0	0	0	0
07/09/2021 15:00	0.0	0	0	0	0	0
07/09/2021 16:00	0.0	0	0	0	0	0
07/09/2021 17:00	0.0	0	0	0	0	0
07/09/2021 18:00	0.0	0	0	0	0	0
07/09/2021 19:00	0.0	0	0	0	0	0
07/09/2021 20:00	0.0	0	0	0	0	0
07/09/2021 21:00	0.0	0	0	0	0	0
07/09/2021 22:00	0.0	0	0	0	0	0
07/09/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/10/2021 00:00	0.0	0	0	0	0	0
07/10/2021 01:00	0.0	0	0	0	0	0
07/10/2021 02:00	0.0	0	0	0	0	0
07/10/2021 03:00	0.0	0	0	0	0	0
07/10/2021 04:00	0.0	0	0	0	0	0
07/10/2021 05:00	0.0	0	0	0	0	0
07/10/2021 06:00	0.0	0	0	0	0	0
07/10/2021 07:00	0.0	0	0	0	0	0
07/10/2021 08:00	0.0	0	0	0	0	0
07/10/2021 09:00	0.0	0	0	0	0	0
07/10/2021 10:00	0.0	0	0	0	0	0
07/10/2021 11:00	0.0	0	0	0	0	0
07/10/2021 12:00	0.0	0	0	0	0	0
07/10/2021 13:00	1,418.7	1	0	0	0	0
07/10/2021 14:00	3,495.1	1	0	0	0	0
07/10/2021 15:00	6,104.4	1	0	0	0	0
07/10/2021 16:00	2,622.9	1	0	0	0	0
07/10/2021 17:00	0.0	0	0	0	0	1
07/10/2021 18:00	0.0	0	0	0	0	1
07/10/2021 19:00	0.0	0	0	0	0	1
07/10/2021 20:00	0.0	0	0	0	0	1
07/10/2021 21:00	0.0	0	0	0	0	1
07/10/2021 22:00	0.0	0	0	0	0	1
07/10/2021 23:00	45.4	0	0	0	1	0
Average/Sum#:	13,686.5 #	4 #	0 #	0 #	1 #	6 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,104.4	1	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/11/2021 00:00	0.0	0	0	0	0	0
07/11/2021 01:00	0.0	0	0	0	0	0
07/11/2021 02:00	0.0	0	0	0	0	0
07/11/2021 03:00	0.0	0	0	0	0	0
07/11/2021 04:00	0.0	0	0	0	0	0
07/11/2021 05:00	0.0	0	0	0	0	0
07/11/2021 06:00	0.0	0	0	0	0	0
07/11/2021 07:00	0.0	0	0	0	0	0
07/11/2021 08:00	0.0	0	0	0	0	0
07/11/2021 09:00	1,993.5	0	1	0	0	0
07/11/2021 10:00	3,917.8	0	1	0	0	0
07/11/2021 11:00	5,113.9	0	1	0	0	0
07/11/2021 12:00	0.0	0	0	0	0	1
07/11/2021 13:00	0.0	0	0	0	0	1
07/11/2021 14:00	0.0	0	0	0	0	1
07/11/2021 15:00	0.0	0	0	0	0	1
07/11/2021 16:00	0.0	0	0	0	0	1
07/11/2021 17:00	0.0	0	0	0	0	1
07/11/2021 18:00	0.0	0	0	0	0	1
07/11/2021 19:00	0.0	0	0	0	0	1
07/11/2021 20:00	0.0	0	0	0	0	1
07/11/2021 21:00	0.0	0	0	0	0	1
07/11/2021 22:00	0.0	0	0	0	0	1
07/11/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	11,025.2 #	0 #	3 #	0 #	0 #	12 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,113.9	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/12/2021 00:00	0.0	0	0	0	0	1
07/12/2021 01:00	13.3	0	0	0	1	0
07/12/2021 02:00	0.0	0	0	0	0	0
07/12/2021 03:00	0.0	0	0	0	0	0
07/12/2021 04:00	0.0	0	0	0	0	0
07/12/2021 05:00	0.0	0	0	0	0	0
07/12/2021 06:00	0.0	0	0	0	0	0
07/12/2021 07:00	0.0	0	0	0	0	0
07/12/2021 08:00	0.0	0	0	0	0	0
07/12/2021 09:00	0.0	0	0	0	0	0
07/12/2021 10:00	0.0	0	0	0	0	0
07/12/2021 11:00	0.0	0	0	0	0	0
07/12/2021 12:00	0.0	0	0	0	0	0
07/12/2021 13:00	0.0	0	0	0	0	0
07/12/2021 14:00	0.0	0	0	0	0	0
07/12/2021 15:00	975.7	0	1	0	0	0
07/12/2021 16:00	4,495.6	0	1	0	0	0
07/12/2021 17:00	0.0	0	0	0	0	1
07/12/2021 18:00	0.0	0	0	0	0	1
07/12/2021 19:00	0.0	0	0	0	0	1
07/12/2021 20:00	0.0	0	0	0	0	1
07/12/2021 21:00	0.0	0	0	0	0	1
07/12/2021 22:00	50.2	0	0	0	1	0
07/12/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	5,534.8 #	0 #	2 #	0 #	2 #	6 #
Minimum:	0.0	0	0	0	0	0
Maximum:	4,495.6	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/13/2021 00:00	0.0	0	0	0	0	0
07/13/2021 01:00	0.0	0	0	0	0	0
07/13/2021 02:00	0.0	0	0	0	0	0
07/13/2021 03:00	0.0	0	0	0	0	0
07/13/2021 04:00	0.0	0	0	0	0	0
07/13/2021 05:00	0.0	0	0	0	0	0
07/13/2021 06:00	0.0	0	0	0	0	0
07/13/2021 07:00	1,972.4	0	1	0	0	0
07/13/2021 08:00	3,741.2	0	1	0	0	0
07/13/2021 09:00	3,202.1	0	1	0	1	0
07/13/2021 10:00	0.0	0	0	0	0	0
07/13/2021 11:00	0.0	0	0	0	0	0
07/13/2021 12:00	3,490.9	0	1	0	0	0
07/13/2021 13:00	4,293.2	0	1	0	1	0
07/13/2021 14:00	529.2	0	1	0	0	0
07/13/2021 15:00	6,339.3	0	1	0	0	0
07/13/2021 16:00	4,357.4	0	1	0	0	0
07/13/2021 17:00	0.0	0	0	0	0	1
07/13/2021 18:00	0.0	0	0	0	0	1
07/13/2021 19:00	0.0	0	0	0	0	1
07/13/2021 20:00	0.0	0	0	0	0	1
07/13/2021 21:00	18.3	0	0	0	1	0
07/13/2021 22:00	0.0	0	0	0	0	0
07/13/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	27,944.0 #	0 #	8 #	0 #	3 #	4 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,339.3	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/14/2021 00:00	0.0	0	0	0	0	0
07/14/2021 01:00	0.0	0	0	0	0	0
07/14/2021 02:00	0.0	0	0	0	0	0
07/14/2021 03:00	3,145.8	0	0	1	0	0
07/14/2021 04:00	2,750.2	0	0	1	0	0
07/14/2021 05:00	0.0	0	0	0	0	1
07/14/2021 06:00	0.0	0	0	0	0	1
07/14/2021 07:00	0.0	0	0	0	0	1
07/14/2021 08:00	0.0	0	0	0	0	1
07/14/2021 09:00	0.0	0	0	0	0	1
07/14/2021 10:00	0.0	0	0	0	0	1
07/14/2021 11:00	0.0	0	0	0	0	1
07/14/2021 12:00	0.0	0	0	0	0	1
07/14/2021 13:00	0.0	0	0	0	0	1
07/14/2021 14:00	0.0	0	0	0	0	1
07/14/2021 15:00	0.0	0	0	0	0	1
07/14/2021 16:00	0.0	0	0	0	0	1
07/14/2021 17:00	0.0	0	0	0	0	1
07/14/2021 18:00	0.0	0	0	0	0	1
07/14/2021 19:00	0.0	0	0	0	0	1
07/14/2021 20:00	0.0	0	0	0	0	1
07/14/2021 21:00	0.0	0	0	0	0	1
07/14/2021 22:00	0.0	0	0	0	0	1
07/14/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	5,896.0 #	0 #	0 #	2 #	0 #	19 #
Minimum:	0.0	0	0	0	0	0
Maximum:	3,145.8	0	0	1	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/15/2021 00:00	0.0	0	0	0	0	1
07/15/2021 01:00	0.0	0	0	0	0	1
07/15/2021 02:00	0.0	0	0	0	0	1
07/15/2021 03:00	0.0	0	0	0	0	1
07/15/2021 04:00	0.0	0	0	0	0	1
07/15/2021 05:00	0.0	0	0	0	0	1
07/15/2021 06:00	0.0	0	0	0	0	1
07/15/2021 07:00	0.0	0	0	0	0	1
07/15/2021 08:00	0.0	0	0	0	0	1
07/15/2021 09:00	0.0	0	0	0	0	1
07/15/2021 10:00	0.0	0	0	0	0	1
07/15/2021 11:00	0.0	0	0	0	0	1
07/15/2021 12:00	0.0	0	0	0	0	1
07/15/2021 13:00	0.0	0	0	0	0	1
07/15/2021 14:00	0.0	0	0	0	0	1
07/15/2021 15:00	0.0	0	0	0	0	1
07/15/2021 16:00	0.0	0	0	0	0	1
07/15/2021 17:00	0.0	0	0	0	0	1
07/15/2021 18:00	0.0	0	0	0	0	1
07/15/2021 19:00	0.0	0	0	0	0	1
07/15/2021 20:00	0.0	0	0	0	0	1
07/15/2021 21:00	0.0	0	0	0	0	1
07/15/2021 22:00	0.0	0	0	0	0	1
07/15/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/16/2021 00:00	0.0	0	0	0	0	1
07/16/2021 01:00	0.0	0	0	0	0	1
07/16/2021 02:00	0.0	0	0	0	0	1
07/16/2021 03:00	0.0	0	0	0	0	1
07/16/2021 04:00	0.0	0	0	0	0	1
07/16/2021 05:00	0.0	0	0	0	0	1
07/16/2021 06:00	0.0	0	0	0	0	1
07/16/2021 07:00	0.0	0	0	0	0	1
07/16/2021 08:00	0.0	0	0	0	0	1
07/16/2021 09:00	0.0	0	0	0	0	1
07/16/2021 10:00	0.0	0	0	0	0	1
07/16/2021 11:00	0.0	0	0	0	0	1
07/16/2021 12:00	0.0	0	0	0	0	1
07/16/2021 13:00	0.0	0	0	0	0	1
07/16/2021 14:00	0.0	0	0	0	0	1
07/16/2021 15:00	0.0	0	0	0	0	1
07/16/2021 16:00	0.0	0	0	0	0	1
07/16/2021 17:00	0.0	0	0	0	0	1
07/16/2021 18:00	0.0	0	0	0	0	1
07/16/2021 19:00	0.0	0	0	0	0	1
07/16/2021 20:00	0.0	0	0	0	0	1
07/16/2021 21:00	0.0	0	0	0	0	1
07/16/2021 22:00	0.0	0	0	0	0	1
07/16/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/17/2021 00:00	0.0	0	0	0	0	1
07/17/2021 01:00	0.0	0	0	0	0	1
07/17/2021 02:00	0.0	0	0	0	0	1
07/17/2021 03:00	0.0	0	0	0	0	1
07/17/2021 04:00	0.0	0	0	0	0	1
07/17/2021 05:00	0.0	0	0	0	0	1
07/17/2021 06:00	0.0	0	0	0	0	1
07/17/2021 07:00	0.0	0	0	0	0	1
07/17/2021 08:00	0.0	0	0	0	0	1
07/17/2021 09:00	0.0	0	0	0	0	1
07/17/2021 10:00	0.0	0	0	0	0	1
07/17/2021 11:00	0.0	0	0	0	0	1
07/17/2021 12:00	0.0	0	0	0	0	1
07/17/2021 13:00	0.0	0	0	0	0	1
07/17/2021 14:00	0.0	0	0	0	0	1
07/17/2021 15:00	0.0	0	0	0	0	1
07/17/2021 16:00	0.0	0	0	0	0	1
07/17/2021 17:00	0.0	0	0	0	0	1
07/17/2021 18:00	0.0	0	0	0	0	1
07/17/2021 19:00	0.0	0	0	0	0	1
07/17/2021 20:00	0.0	0	0	0	0	1
07/17/2021 21:00	0.0	0	0	0	0	1
07/17/2021 22:00	0.0	0	0	0	0	1
07/17/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/18/2021 00:00	0.0	0	0	0	0	1
07/18/2021 01:00	0.0	0	0	0	0	1
07/18/2021 02:00	0.0	0	0	0	0	1
07/18/2021 03:00	0.0	0	0	0	0	1
07/18/2021 04:00	0.0	0	0	0	0	1
07/18/2021 05:00	0.0	0	0	0	0	1
07/18/2021 06:00	0.0	0	0	0	0	1
07/18/2021 07:00	0.0	0	0	0	0	1
07/18/2021 08:00	0.0	0	0	0	0	1
07/18/2021 09:00	0.0	0	0	0	0	1
07/18/2021 10:00	0.0	0	0	0	0	1
07/18/2021 11:00	0.0	0	0	0	0	1
07/18/2021 12:00	0.0	0	0	0	0	1
07/18/2021 13:00	0.0	0	0	0	0	1
07/18/2021 14:00	0.0	0	0	0	0	1
07/18/2021 15:00	0.0	0	0	0	0	1
07/18/2021 16:00	0.0	0	0	0	0	1
07/18/2021 17:00	0.0	0	0	0	0	1
07/18/2021 18:00	0.0	0	0	0	0	1
07/18/2021 19:00	0.0	0	0	0	0	1
07/18/2021 20:00	0.0	0	0	0	0	1
07/18/2021 21:00	0.0	0	0	0	0	1
07/18/2021 22:00	0.0	0	0	0	0	1
07/18/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/19/2021 00:00	0.0	0	0	0	0	1
07/19/2021 01:00	0.0	0	0	0	0	1
07/19/2021 02:00	0.0	0	0	0	0	1
07/19/2021 03:00	0.0	0	0	0	0	1
07/19/2021 04:00	0.0	0	0	0	0	1
07/19/2021 05:00	0.0	0	0	0	0	1
07/19/2021 06:00	0.0	0	0	0	0	1
07/19/2021 07:00	0.0	0	0	0	0	1
07/19/2021 08:00	0.0	0	0	0	0	1
07/19/2021 09:00	0.0	0	0	0	0	1
07/19/2021 10:00	0.0	0	0	0	0	1
07/19/2021 11:00	0.0	0	0	0	0	1
07/19/2021 12:00	0.0	0	0	0	0	1
07/19/2021 13:00	0.0	0	0	0	0	1
07/19/2021 14:00	0.0	0	0	0	0	1
07/19/2021 15:00	0.0	0	0	0	0	1
07/19/2021 16:00	0.0	0	0	0	0	1
07/19/2021 17:00	0.0	0	0	0	0	1
07/19/2021 18:00	0.0	0	0	0	0	1
07/19/2021 19:00	0.0	0	0	0	0	1
07/19/2021 20:00	0.0	0	0	0	0	1
07/19/2021 21:00	0.0	0	0	0	0	1
07/19/2021 22:00	0.0	0	0	0	0	1
07/19/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/20/2021 00:00	0.0	0	0	0	0	1
07/20/2021 01:00	0.0	0	0	0	0	1
07/20/2021 02:00	0.0	0	0	0	0	1
07/20/2021 03:00	0.0	0	0	0	0	1
07/20/2021 04:00	0.0	0	0	0	0	1
07/20/2021 05:00	0.0	0	0	0	0	1
07/20/2021 06:00	0.0	0	0	0	0	1
07/20/2021 07:00	0.0	0	0	0	0	1
07/20/2021 08:00	0.0	0	0	0	0	1
07/20/2021 09:00	0.0	0	0	0	0	1
07/20/2021 10:00	0.0	0	0	0	0	1
07/20/2021 11:00	0.0	0	0	0	0	1
07/20/2021 12:00	0.0	0	0	0	0	1
07/20/2021 13:00	0.0	0	0	0	0	1
07/20/2021 14:00	0.0	0	0	0	0	1
07/20/2021 15:00	0.0	0	0	0	0	1
07/20/2021 16:00	0.0	0	0	0	0	1
07/20/2021 17:00	0.0	0	0	0	0	1
07/20/2021 18:00	0.0	0	0	0	0	1
07/20/2021 19:00	0.0	0	0	0	0	1
07/20/2021 20:00	0.0	0	0	0	0	1
07/20/2021 21:00	0.0	0	0	0	0	1
07/20/2021 22:00	0.0	0	0	0	0	1
07/20/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/21/2021 00:00	0.0	0	0	0	0	1
07/21/2021 01:00	0.0	0	0	0	0	1
07/21/2021 02:00	0.0	0	0	0	0	1
07/21/2021 03:00	0.0	0	0	0	0	1
07/21/2021 04:00	0.0	0	0	0	0	1
07/21/2021 05:00	0.0	0	0	0	0	1
07/21/2021 06:00	0.0	0	0	0	0	1
07/21/2021 07:00	0.0	0	0	0	0	1
07/21/2021 08:00	0.0	0	0	0	0	1
07/21/2021 09:00	0.0	0	0	0	0	1
07/21/2021 10:00	0.0	0	0	0	0	1
07/21/2021 11:00	0.0	0	0	0	0	1
07/21/2021 12:00	0.0	0	0	0	0	1
07/21/2021 13:00	0.0	0	0	0	0	1
07/21/2021 14:00	0.0	0	0	0	0	1
07/21/2021 15:00	0.0	0	0	0	0	1
07/21/2021 16:00	0.0	0	0	0	0	1
07/21/2021 17:00	0.0	0	0	0	0	1
07/21/2021 18:00	0.0	0	0	0	0	1
07/21/2021 19:00	0.0	0	0	0	0	1
07/21/2021 20:00	0.0	0	0	0	0	1
07/21/2021 21:00	0.0	0	0	0	0	1
07/21/2021 22:00	0.0	0	0	0	0	1
07/21/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/22/2021 00:00	0.0	0	0	0	0	1
07/22/2021 01:00	0.0	0	0	0	0	1
07/22/2021 02:00	0.0	0	0	0	0	1
07/22/2021 03:00	0.0	0	0	0	0	1
07/22/2021 04:00	0.0	0	0	0	0	1
07/22/2021 05:00	0.0	0	0	0	0	1
07/22/2021 06:00	0.0	0	0	0	0	1
07/22/2021 07:00	0.0	0	0	0	0	1
07/22/2021 08:00	0.0	0	0	0	0	1
07/22/2021 09:00	0.0	0	0	0	0	1
07/22/2021 10:00	0.0	0	0	0	0	1
07/22/2021 11:00	0.0	0	0	0	0	1
07/22/2021 12:00	0.0	0	0	0	0	1
07/22/2021 13:00	0.0	0	0	0	0	1
07/22/2021 14:00	0.0	0	0	0	0	1
07/22/2021 15:00	0.0	0	0	0	0	1
07/22/2021 16:00	0.0	0	0	0	0	1
07/22/2021 17:00	0.0	0	0	0	0	1
07/22/2021 18:00	0.0	0	0	0	0	1
07/22/2021 19:00	0.0	0	0	0	0	1
07/22/2021 20:00	0.0	0	0	0	0	1
07/22/2021 21:00	0.0	0	0	0	0	1
07/22/2021 22:00	0.0	0	0	0	0	1
07/22/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/23/2021 00:00	0.0	0	0	0	0	1
07/23/2021 01:00	0.0	0	0	0	0	1
07/23/2021 02:00	0.0	0	0	0	0	1
07/23/2021 03:00	0.0	0	0	0	0	1
07/23/2021 04:00	0.0	0	0	0	0	1
07/23/2021 05:00	0.0	0	0	0	0	1
07/23/2021 06:00	0.0	0	0	0	0	1
07/23/2021 07:00	0.0	0	0	0	0	1
07/23/2021 08:00	0.0	0	0	0	0	1
07/23/2021 09:00	0.0	0	0	0	0	1
07/23/2021 10:00	0.0	0	0	0	0	1
07/23/2021 11:00	0.0	0	0	0	0	1
07/23/2021 12:00	0.0	0	0	0	0	1
07/23/2021 13:00	0.0	0	0	0	0	1
07/23/2021 14:00	0.0	0	0	0	0	1
07/23/2021 15:00	0.0	0	0	0	0	1
07/23/2021 16:00	0.0	0	0	0	0	1
07/23/2021 17:00	0.0	0	0	0	0	1
07/23/2021 18:00	0.0	0	0	0	0	1
07/23/2021 19:00	0.0	0	0	0	0	1
07/23/2021 20:00	0.0	0	0	0	0	1
07/23/2021 21:00	0.0	0	0	0	0	1
07/23/2021 22:00	0.0	0	0	0	0	1
07/23/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/24/2021 00:00	0.0	0	0	0	0	1
07/24/2021 01:00	0.0	0	0	0	0	1
07/24/2021 02:00	0.0	0	0	0	0	1
07/24/2021 03:00	0.0	0	0	0	0	1
07/24/2021 04:00	0.0	0	0	0	0	1
07/24/2021 05:00	0.0	0	0	0	0	1
07/24/2021 06:00	0.0	0	0	0	0	1
07/24/2021 07:00	0.0	0	0	0	0	1
07/24/2021 08:00	0.0	0	0	0	0	1
07/24/2021 09:00	0.0	0	0	0	0	1
07/24/2021 10:00	0.0	0	0	0	0	1
07/24/2021 11:00	0.0	0	0	0	0	1
07/24/2021 12:00	0.0	0	0	0	0	1
07/24/2021 13:00	0.0	0	0	0	0	1
07/24/2021 14:00	0.0	0	0	0	0	1
07/24/2021 15:00	0.0	0	0	0	0	1
07/24/2021 16:00	0.0	0	0	0	0	1
07/24/2021 17:00	0.0	0	0	0	0	1
07/24/2021 18:00	0.0	0	0	0	0	1
07/24/2021 19:00	0.0	0	0	0	0	1
07/24/2021 20:00	0.0	0	0	0	0	1
07/24/2021 21:00	0.0	0	0	0	0	1
07/24/2021 22:00	0.0	0	0	0	0	1
07/24/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/25/2021 00:00	0.0	0	0	0	0	1
07/25/2021 01:00	0.0	0	0	0	0	1
07/25/2021 02:00	0.0	0	0	0	0	1
07/25/2021 03:00	0.0	0	0	0	0	1
07/25/2021 04:00	0.0	0	0	0	0	1
07/25/2021 05:00	0.0	0	0	0	0	1
07/25/2021 06:00	0.0	0	0	0	0	1
07/25/2021 07:00	0.0	0	0	0	0	1
07/25/2021 08:00	0.0	0	0	0	0	1
07/25/2021 09:00	0.0	0	0	0	0	1
07/25/2021 10:00	0.0	0	0	0	0	1
07/25/2021 11:00	0.0	0	0	0	0	1
07/25/2021 12:00	0.0	0	0	0	0	1
07/25/2021 13:00	0.0	0	0	0	0	1
07/25/2021 14:00	0.0	0	0	0	0	1
07/25/2021 15:00	0.0	0	0	0	0	1
07/25/2021 16:00	0.0	0	0	0	0	1
07/25/2021 17:00	0.0	0	0	0	0	1
07/25/2021 18:00	0.0	0	0	0	0	1
07/25/2021 19:00	0.0	0	0	0	0	1
07/25/2021 20:00	0.0	0	0	0	0	1
07/25/2021 21:00	0.0	0	0	0	0	1
07/25/2021 22:00	0.0	0	0	0	0	1
07/25/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/26/2021 00:00	0.0	0	0	0	0	1
07/26/2021 01:00	0.0	0	0	0	0	1
07/26/2021 02:00	0.0	0	0	0	0	1
07/26/2021 03:00	0.0	0	0	0	0	1
07/26/2021 04:00	0.0	0	0	0	0	1
07/26/2021 05:00	0.0	0	0	0	0	1
07/26/2021 06:00	0.0	0	0	0	0	1
07/26/2021 07:00	0.0	0	0	0	0	1
07/26/2021 08:00	0.0	0	0	0	0	1
07/26/2021 09:00	0.0	0	0	0	0	1
07/26/2021 10:00	0.0	0	0	0	0	1
07/26/2021 11:00	0.0	0	0	0	0	1
07/26/2021 12:00	0.0	0	0	0	0	1
07/26/2021 13:00	0.0	0	0	0	0	1
07/26/2021 14:00	0.0	0	0	0	0	1
07/26/2021 15:00	0.0	0	0	0	0	1
07/26/2021 16:00	0.0	0	0	0	0	1
07/26/2021 17:00	0.0	0	0	0	0	1
07/26/2021 18:00	0.0	0	0	0	0	1
07/26/2021 19:00	0.0	0	0	0	0	1
07/26/2021 20:00	0.0	0	0	0	0	1
07/26/2021 21:00	0.0	0	0	0	0	1
07/26/2021 22:00	0.0	0	0	0	0	1
07/26/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/27/2021 00:00	0.0	0	0	0	0	1
07/27/2021 01:00	0.0	0	0	0	0	1
07/27/2021 02:00	0.0	0	0	0	0	1
07/27/2021 03:00	0.0	0	0	0	0	1
07/27/2021 04:00	0.0	0	0	0	0	1
07/27/2021 05:00	0.0	0	0	0	0	1
07/27/2021 06:00	0.0	0	0	0	0	1
07/27/2021 07:00	0.0	0	0	0	0	1
07/27/2021 08:00	0.0	0	0	0	0	1
07/27/2021 09:00	0.0	0	0	0	0	1
07/27/2021 10:00	0.0	0	0	0	0	1
07/27/2021 11:00	0.0	0	0	0	0	1
07/27/2021 12:00	0.0	0	0	0	0	1
07/27/2021 13:00	0.0	0	0	0	0	1
07/27/2021 14:00	0.0	0	0	0	0	1
07/27/2021 15:00	0.0	0	0	0	0	1
07/27/2021 16:00	0.0	0	0	0	0	1
07/27/2021 17:00	0.0	0	0	0	0	1
07/27/2021 18:00	0.0	0	0	0	0	1
07/27/2021 19:00	0.0	0	0	0	0	1
07/27/2021 20:00	0.0	0	0	0	0	1
07/27/2021 21:00	0.0	0	0	0	0	1
07/27/2021 22:00	0.0	0	0	0	0	1
07/27/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/28/2021 00:00	0.0	0	0	0	0	1
07/28/2021 01:00	0.0	0	0	0	0	1
07/28/2021 02:00	0.0	0	0	0	0	1
07/28/2021 03:00	0.0	0	0	0	0	1
07/28/2021 04:00	0.0	0	0	0	0	1
07/28/2021 05:00	0.0	0	0	0	0	1
07/28/2021 06:00	0.0	0	0	0	0	1
07/28/2021 07:00	0.0	0	0	0	0	1
07/28/2021 08:00	0.0	0	0	0	0	1
07/28/2021 09:00	0.0	0	0	0	0	1
07/28/2021 10:00	0.0	0	0	0	0	1
07/28/2021 11:00	0.0	0	0	0	0	1
07/28/2021 12:00	0.0	0	0	0	0	1
07/28/2021 13:00	0.0	0	0	0	0	1
07/28/2021 14:00	0.0	0	0	0	0	1
07/28/2021 15:00	0.0	0	0	0	0	1
07/28/2021 16:00	0.0	0	0	0	0	1
07/28/2021 17:00	0.0	0	0	0	0	1
07/28/2021 18:00	0.0	0	0	0	0	1
07/28/2021 19:00	0.0	0	0	0	0	1
07/28/2021 20:00	0.0	0	0	0	0	1
07/28/2021 21:00	0.0	0	0	0	0	1
07/28/2021 22:00	0.0	0	0	0	0	1
07/28/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/29/2021 00:00	0.0	0	0	0	0	1
07/29/2021 01:00	0.0	0	0	0	0	1
07/29/2021 02:00	0.0	0	0	0	0	1
07/29/2021 03:00	0.0	0	0	0	0	1
07/29/2021 04:00	0.0	0	0	0	0	1
07/29/2021 05:00	0.0	0	0	0	0	1
07/29/2021 06:00	0.0	0	0	0	0	1
07/29/2021 07:00	0.0	0	0	0	0	1
07/29/2021 08:00	0.0	0	0	0	0	1
07/29/2021 09:00	0.0	0	0	0	0	1
07/29/2021 10:00	0.0	0	0	0	0	1
07/29/2021 11:00	0.0	0	0	0	0	1
07/29/2021 12:00	0.0	0	0	0	0	1
07/29/2021 13:00	0.0	0	0	0	0	1
07/29/2021 14:00	0.0	0	0	0	0	1
07/29/2021 15:00	0.0	0	0	0	0	1
07/29/2021 16:00	0.0	0	0	0	0	1
07/29/2021 17:00	0.0	0	0	0	0	1
07/29/2021 18:00	0.0	0	0	0	0	1
07/29/2021 19:00	0.0	0	0	0	0	1
07/29/2021 20:00	0.0	0	0	0	0	1
07/29/2021 21:00	0.0	0	0	0	0	1
07/29/2021 22:00	0.0	0	0	0	0	1
07/29/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/30/2021 00:00	0.0	0	0	0	0	1
07/30/2021 01:00	0.0	0	0	0	0	1
07/30/2021 02:00	0.0	0	0	0	0	1
07/30/2021 03:00	0.0	0	0	0	0	1
07/30/2021 04:00	0.0	0	0	0	0	1
07/30/2021 05:00	0.0	0	0	0	0	1
07/30/2021 06:00	0.0	0	0	0	0	1
07/30/2021 07:00	0.0	0	0	0	0	1
07/30/2021 08:00	0.0	0	0	0	0	1
07/30/2021 09:00	0.0	0	0	0	0	1
07/30/2021 10:00	0.0	0	0	0	0	1
07/30/2021 11:00	0.0	0	0	0	0	1
07/30/2021 12:00	0.0	0	0	0	0	1
07/30/2021 13:00	0.0	0	0	0	0	1
07/30/2021 14:00	0.0	0	0	0	0	1
07/30/2021 15:00	0.0	0	0	0	0	1
07/30/2021 16:00	0.0	0	0	0	0	1
07/30/2021 17:00	0.0	0	0	0	0	1
07/30/2021 18:00	0.0	0	0	0	0	1
07/30/2021 19:00	0.0	0	0	0	0	1
07/30/2021 20:00	0.0	0	0	0	0	1
07/30/2021 21:00	0.0	0	0	0	0	1
07/30/2021 22:00	0.0	0	0	0	0	1
07/30/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/31/2021 00:00	0.0	0	0	0	0	1
07/31/2021 01:00	0.0	0	0	0	0	1
07/31/2021 02:00	0.0	0	0	0	0	1
07/31/2021 03:00	0.0	0	0	0	0	1
07/31/2021 04:00	0.0	0	0	0	0	1
07/31/2021 05:00	0.0	0	0	0	0	1
07/31/2021 06:00	0.0	0	0	0	0	1
07/31/2021 07:00	0.0	0	0	0	0	1
07/31/2021 08:00	0.0	0	0	0	0	1
07/31/2021 09:00	0.0	0	0	0	0	1
07/31/2021 10:00	0.0	0	0	0	0	1
07/31/2021 11:00	0.0	0	0	0	0	1
07/31/2021 12:00	0.0	0	0	0	0	1
07/31/2021 13:00	0.0	0	0	0	0	1
07/31/2021 14:00	0.0	0	0	0	0	1
07/31/2021 15:00	0.0	0	0	0	0	1
07/31/2021 16:00	0.0	0	0	0	0	1
07/31/2021 17:00	0.0	0	0	0	0	1
07/31/2021 18:00	0.0	0	0	0	0	1
07/31/2021 19:00	0.0	0	0	0	0	1
07/31/2021 20:00	0.0	0	0	0	0	1
07/31/2021 21:00	0.0	0	0	0	0	1
07/31/2021 22:00	0.0	0	0	0	0	1
07/31/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/01/2021 00:00	0.0	0	0	0	0	1
08/01/2021 01:00	0.0	0	0	0	0	1
08/01/2021 02:00	0.0	0	0	0	0	1
08/01/2021 03:00	0.0	0	0	0	0	1
08/01/2021 04:00	0.0	0	0	0	0	1
08/01/2021 05:00	0.0	0	0	0	0	1
08/01/2021 06:00	0.0	0	0	0	0	1
08/01/2021 07:00	0.0	0	0	0	0	1
08/01/2021 08:00	0.0	0	0	0	0	1
08/01/2021 09:00	0.0	0	0	0	0	1
08/01/2021 10:00	0.0	0	0	0	0	1
08/01/2021 11:00	0.0	0	0	0	0	1
08/01/2021 12:00	0.0	0	0	0	0	1
08/01/2021 13:00	0.0	0	0	0	0	1
08/01/2021 14:00	0.0	0	0	0	0	1
08/01/2021 15:00	0.0	0	0	0	0	1
08/01/2021 16:00	0.0	0	0	0	0	1
08/01/2021 17:00	0.0	0	0	0	0	1
08/01/2021 18:00	0.0	0	0	0	0	1
08/01/2021 19:00	0.0	0	0	0	0	1
08/01/2021 20:00	0.0	0	0	0	0	1
08/01/2021 21:00	0.0	0	0	0	0	1
08/01/2021 22:00	0.0	0	0	0	0	1
08/01/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/02/2021 00:00	0.0	0	0	0	0	1
08/02/2021 01:00	0.0	0	0	0	0	1
08/02/2021 02:00	0.0	0	0	0	0	1
08/02/2021 03:00	0.0	0	0	0	0	1
08/02/2021 04:00	0.0	0	0	0	0	1
08/02/2021 05:00	0.0	0	0	0	0	1
08/02/2021 06:00	0.0	0	0	0	0	1
08/02/2021 07:00	0.0	0	0	0	0	1
08/02/2021 08:00	0.0	0	0	0	0	1
08/02/2021 09:00	0.0	0	0	0	0	1
08/02/2021 10:00	0.0	0	0	0	0	1
08/02/2021 11:00	0.0	0	0	0	0	1
08/02/2021 12:00	0.0	0	0	0	0	1
08/02/2021 13:00	0.0	0	0	0	0	1
08/02/2021 14:00	0.0	0	0	0	0	1
08/02/2021 15:00	0.0	0	0	0	0	1
08/02/2021 16:00	0.0	0	0	0	0	1
08/02/2021 17:00	0.0	0	0	0	0	1
08/02/2021 18:00	0.0	0	0	0	0	1
08/02/2021 19:00	0.0	0	0	0	0	1
08/02/2021 20:00	0.0	0	0	0	0	1
08/02/2021 21:00	0.0	0	0	0	0	1
08/02/2021 22:00	0.0	0	0	0	0	1
08/02/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/03/2021 00:00	0.0	0	0	0	0	1
08/03/2021 01:00	0.0	0	0	0	0	1
08/03/2021 02:00	0.0	0	0	0	0	1
08/03/2021 03:00	0.0	0	0	0	0	1
08/03/2021 04:00	0.0	0	0	0	0	1
08/03/2021 05:00	0.0	0	0	0	0	1
08/03/2021 06:00	0.0	0	0	0	0	1
08/03/2021 07:00	0.0	0	0	0	0	1
08/03/2021 08:00	0.0	0	0	0	0	1
08/03/2021 09:00	0.0	0	0	0	0	1
08/03/2021 10:00	0.0	0	0	0	0	1
08/03/2021 11:00	0.0	0	0	0	0	1
08/03/2021 12:00	0.0	0	0	0	0	1
08/03/2021 13:00	0.0	0	0	0	0	1
08/03/2021 14:00	0.0	0	0	0	0	1
08/03/2021 15:00	0.0	0	0	0	0	1
08/03/2021 16:00	0.0	0	0	0	0	1
08/03/2021 17:00	0.0	0	0	0	0	1
08/03/2021 18:00	0.0	0	0	0	0	1
08/03/2021 19:00	0.0	0	0	0	0	1
08/03/2021 20:00	0.0	0	0	0	0	1
08/03/2021 21:00	0.0	0	0	0	0	1
08/03/2021 22:00	0.0	0	0	0	0	1
08/03/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/04/2021 00:00	0.0	0	0	0	0	1
08/04/2021 01:00	0.0	0	0	0	0	1
08/04/2021 02:00	0.0	0	0	0	0	1
08/04/2021 03:00	0.0	0	0	0	0	1
08/04/2021 04:00	0.0	0	0	0	0	1
08/04/2021 05:00	0.0	0	0	0	0	1
08/04/2021 06:00	0.0	0	0	0	0	1
08/04/2021 07:00	0.0	0	0	0	0	1
08/04/2021 08:00	0.0	0	0	0	0	1
08/04/2021 09:00	0.0	0	0	0	0	1
08/04/2021 10:00	0.0	0	0	0	0	1
08/04/2021 11:00	0.0	0	0	0	0	1
08/04/2021 12:00	0.0	0	0	0	0	1
08/04/2021 13:00	0.0	0	0	0	0	1
08/04/2021 14:00	0.0	0	0	0	0	1
08/04/2021 15:00	0.0	0	0	0	0	1
08/04/2021 16:00	0.0	0	0	0	0	1
08/04/2021 17:00	0.0	0	0	0	0	1
08/04/2021 18:00	0.0	0	0	0	0	1
08/04/2021 19:00	0.0	0	0	0	0	1
08/04/2021 20:00	0.0	0	0	0	0	1
08/04/2021 21:00	0.0	0	0	0	0	1
08/04/2021 22:00	0.0	0	0	0	0	1
08/04/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/05/2021 00:00	0.0	0	0	0	0	1
08/05/2021 01:00	0.0	0	0	0	0	1
08/05/2021 02:00	0.0	0	0	0	0	1
08/05/2021 03:00	0.0	0	0	0	0	1
08/05/2021 04:00	0.0	0	0	0	0	1
08/05/2021 05:00	0.0	0	0	0	0	1
08/05/2021 06:00	0.0	0	0	0	0	1
08/05/2021 07:00	0.0	0	0	0	0	1
08/05/2021 08:00	0.0	0	0	0	0	1
08/05/2021 09:00	0.0	0	0	0	0	1
08/05/2021 10:00	0.0	0	0	0	0	1
08/05/2021 11:00	0.0	0	0	0	0	1
08/05/2021 12:00	0.0	0	0	0	0	1
08/05/2021 13:00	0.0	0	0	0	0	1
08/05/2021 14:00	0.0	0	0	0	0	1
08/05/2021 15:00	0.0	0	0	0	0	1
08/05/2021 16:00	0.0	0	0	0	0	1
08/05/2021 17:00	0.0	0	0	0	0	1
08/05/2021 18:00	0.0	0	0	0	0	1
08/05/2021 19:00	0.0	0	0	0	0	1
08/05/2021 20:00	0.0	0	0	0	0	1
08/05/2021 21:00	0.0	0	0	0	0	1
08/05/2021 22:00	0.0	0	0	0	0	1
08/05/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/06/2021 00:00	0.0	0	0	0	0	1
08/06/2021 01:00	0.0	0	0	0	0	1
08/06/2021 02:00	0.0	0	0	0	0	1
08/06/2021 03:00	0.0	0	0	0	0	1
08/06/2021 04:00	0.0	0	0	0	0	1
08/06/2021 05:00	0.0	0	0	0	0	1
08/06/2021 06:00	0.0	0	0	0	0	1
08/06/2021 07:00	0.0	0	0	0	0	1
08/06/2021 08:00	0.0	0	0	0	0	1
08/06/2021 09:00	0.0	0	0	0	0	1
08/06/2021 10:00	0.0	0	0	0	0	1
08/06/2021 11:00	0.0	0	0	0	0	1
08/06/2021 12:00	0.0	0	0	0	0	1
08/06/2021 13:00	0.0	0	0	0	0	1
08/06/2021 14:00	0.0	0	0	0	0	1
08/06/2021 15:00	0.0	0	0	0	0	1
08/06/2021 16:00	0.0	0	0	0	0	1
08/06/2021 17:00	0.0	0	0	0	0	1
08/06/2021 18:00	0.0	0	0	0	0	1
08/06/2021 19:00	0.0	0	0	0	0	1
08/06/2021 20:00	0.0	0	0	0	0	1
08/06/2021 21:00	0.0	0	0	0	0	1
08/06/2021 22:00	0.0	0	0	0	0	1
08/06/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/07/2021 00:00	0.0	0	0	0	0	1
08/07/2021 01:00	0.0	0	0	0	0	1
08/07/2021 02:00	0.0	0	0	0	0	1
08/07/2021 03:00	47.0	0	0	0	1	0
08/07/2021 04:00	0.0	0	0	0	0	0
08/07/2021 05:00	0.0	0	0	0	0	0
08/07/2021 06:00	0.0	0	0	0	0	0
08/07/2021 07:00	0.0	0	0	0	0	0
08/07/2021 08:00	0.0	0	0	0	0	0
08/07/2021 09:00	0.0	0	0	0	0	0
08/07/2021 10:00	0.0	0	0	0	0	0
08/07/2021 11:00	0.0	0	0	0	0	0
08/07/2021 12:00	0.0	0	0	0	0	0
08/07/2021 13:00	331.2	0	1	0	0	0
08/07/2021 14:00	5,806.3	0	1	0	0	0
08/07/2021 15:00	0.0	0	0	0	0	1
08/07/2021 16:00	0.0	0	0	0	0	1
08/07/2021 17:00	0.0	0	0	0	0	1
08/07/2021 18:00	0.0	0	0	0	0	1
08/07/2021 19:00	0.0	0	0	0	0	1
08/07/2021 20:00	0.0	0	0	0	0	1
08/07/2021 21:00	0.0	0	0	0	0	1
08/07/2021 22:00	0.0	0	0	0	0	1
08/07/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	6,184.5 #	0 #	2 #	0 #	1 #	12 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,806.3	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/08/2021 00:00	0.0	0	0	0	0	1
08/08/2021 01:00	0.0	0	0	0	0	1
08/08/2021 02:00	0.0	0	0	0	0	1
08/08/2021 03:00	0.0	0	0	0	0	1
08/08/2021 04:00	69.8	0	0	0	1	0
08/08/2021 05:00	0.0	0	0	0	0	0
08/08/2021 06:00	0.0	0	0	0	0	0
08/08/2021 07:00	0.0	0	0	0	0	0
08/08/2021 08:00	0.0	0	0	0	0	0
08/08/2021 09:00	0.0	0	0	0	0	0
08/08/2021 10:00	0.0	0	0	0	0	0
08/08/2021 11:00	0.0	0	0	0	0	0
08/08/2021 12:00	0.0	0	0	0	0	0
08/08/2021 13:00	0.0	0	0	0	0	0
08/08/2021 14:00	344.0	0	1	0	0	0
08/08/2021 15:00	5,724.3	0	1	0	0	0
08/08/2021 16:00	0.0	0	0	0	0	1
08/08/2021 17:00	0.0	0	0	0	0	1
08/08/2021 18:00	0.0	0	0	0	0	1
08/08/2021 19:00	0.0	0	0	0	0	1
08/08/2021 20:00	0.0	0	0	0	0	1
08/08/2021 21:00	0.0	0	0	0	0	1
08/08/2021 22:00	0.0	0	0	0	0	1
08/08/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	6,138.1 #	0 #	2 #	0 #	1 #	12 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,724.3	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/09/2021 00:00	0.0	0	0	0	0	1
08/09/2021 01:00	0.0	0	0	0	0	1
08/09/2021 02:00	0.0	0	0	0	0	1
08/09/2021 03:00	0.0	0	0	0	0	1
08/09/2021 04:00	0.0	0	0	0	0	1
08/09/2021 05:00	0.0	0	0	0	0	1
08/09/2021 06:00	0.0	0	0	0	0	1
08/09/2021 07:00	0.0	0	0	0	0	1
08/09/2021 08:00	0.0	0	0	0	0	1
08/09/2021 09:00	0.0	0	0	0	0	1
08/09/2021 10:00	0.0	0	0	0	0	1
08/09/2021 11:00	0.0	0	0	0	0	1
08/09/2021 12:00	0.0	0	0	0	0	1
08/09/2021 13:00	0.0	0	0	0	0	1
08/09/2021 14:00	0.0	0	0	0	0	1
08/09/2021 15:00	0.0	0	0	0	0	1
08/09/2021 16:00	0.0	0	0	0	0	1
08/09/2021 17:00	0.0	0	0	0	0	1
08/09/2021 18:00	0.0	0	0	0	0	1
08/09/2021 19:00	0.0	0	0	0	0	1
08/09/2021 20:00	0.0	0	0	0	0	1
08/09/2021 21:00	0.0	0	0	0	0	1
08/09/2021 22:00	0.0	0	0	0	0	1
08/09/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/10/2021 00:00	0.0	0	0	0	0	1
08/10/2021 01:00	0.0	0	0	0	0	1
08/10/2021 02:00	0.0	0	0	0	0	1
08/10/2021 03:00	0.0	0	0	0	0	1
08/10/2021 04:00	0.0	0	0	0	0	1
08/10/2021 05:00	0.0	0	0	0	0	1
08/10/2021 06:00	0.0	0	0	0	0	1
08/10/2021 07:00	0.0	0	0	0	0	1
08/10/2021 08:00	0.0	0	0	0	0	1
08/10/2021 09:00	0.0	0	0	0	0	1
08/10/2021 10:00	0.0	0	0	0	0	1
08/10/2021 11:00	0.0	0	0	0	0	1
08/10/2021 12:00	0.0	0	0	0	0	1
08/10/2021 13:00	0.0	0	0	0	0	1
08/10/2021 14:00	0.0	0	0	0	0	1
08/10/2021 15:00	0.0	0	0	0	0	1
08/10/2021 16:00	0.0	0	0	0	0	1
08/10/2021 17:00	0.0	0	0	0	0	1
08/10/2021 18:00	0.0	0	0	0	0	1
08/10/2021 19:00	0.0	0	0	0	0	1
08/10/2021 20:00	0.0	0	0	0	0	1
08/10/2021 21:00	0.0	0	0	0	0	1
08/10/2021 22:00	0.0	0	0	0	0	1
08/10/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/11/2021 00:00	0.0	0	0	0	0	1
08/11/2021 01:00	0.0	0	0	0	0	1
08/11/2021 02:00	0.0	0	0	0	0	1
08/11/2021 03:00	0.0	0	0	0	0	1
08/11/2021 04:00	0.0	0	0	0	0	1
08/11/2021 05:00	0.0	0	0	0	0	1
08/11/2021 06:00	0.0	0	0	0	0	1
08/11/2021 07:00	0.0	0	0	0	0	1
08/11/2021 08:00	0.0	0	0	0	0	1
08/11/2021 09:00	0.0	0	0	0	0	1
08/11/2021 10:00	0.0	0	0	0	0	1
08/11/2021 11:00	0.0	0	0	0	0	1
08/11/2021 12:00	0.0	0	0	0	0	1
08/11/2021 13:00	0.0	0	0	0	0	1
08/11/2021 14:00	0.0	0	0	0	0	1
08/11/2021 15:00	0.0	0	0	0	0	1
08/11/2021 16:00	0.0	0	0	0	0	1
08/11/2021 17:00	0.0	0	0	0	0	1
08/11/2021 18:00	0.0	0	0	0	0	1
08/11/2021 19:00	0.0	0	0	0	0	1
08/11/2021 20:00	0.0	0	0	0	0	1
08/11/2021 21:00	0.0	0	0	0	0	1
08/11/2021 22:00	0.0	0	0	0	0	1
08/11/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/12/2021 00:00	0.0	0	0	0	0	1
08/12/2021 01:00	0.0	0	0	0	0	1
08/12/2021 02:00	0.0	0	0	0	0	1
08/12/2021 03:00	0.0	0	0	0	0	1
08/12/2021 04:00	0.0	0	0	0	0	1
08/12/2021 05:00	0.0	0	0	0	0	1
08/12/2021 06:00	0.0	0	0	0	0	1
08/12/2021 07:00	0.0	0	0	0	0	1
08/12/2021 08:00	0.0	0	0	0	0	1
08/12/2021 09:00	0.0	0	0	0	0	1
08/12/2021 10:00	0.0	0	0	0	0	1
08/12/2021 11:00	0.0	0	0	0	0	1
08/12/2021 12:00	0.0	0	0	0	0	1
08/12/2021 13:00	0.0	0	0	0	0	1
08/12/2021 14:00	0.0	0	0	0	0	1
08/12/2021 15:00	0.0	0	0	0	0	1
08/12/2021 16:00	0.0	0	0	0	0	1
08/12/2021 17:00	0.0	0	0	0	0	1
08/12/2021 18:00	0.0	0	0	0	0	1
08/12/2021 19:00	0.0	0	0	0	0	1
08/12/2021 20:00	0.0	0	0	0	0	1
08/12/2021 21:00	0.0	0	0	0	0	1
08/12/2021 22:00	0.0	0	0	0	0	1
08/12/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/13/2021 00:00	0.0	0	0	0	0	1
08/13/2021 01:00	0.0	0	0	0	0	1
08/13/2021 02:00	0.0	0	0	0	0	1
08/13/2021 03:00	0.0	0	0	0	0	1
08/13/2021 04:00	0.0	0	0	0	0	1
08/13/2021 05:00	0.0	0	0	0	0	1
08/13/2021 06:00	0.0	0	0	0	0	1
08/13/2021 07:00	0.0	0	0	0	0	1
08/13/2021 08:00	0.0	0	0	0	0	1
08/13/2021 09:00	0.0	0	0	0	0	1
08/13/2021 10:00	0.0	0	0	0	0	1
08/13/2021 11:00	0.0	0	0	0	0	1
08/13/2021 12:00	0.0	0	0	0	0	1
08/13/2021 13:00	0.0	0	0	0	0	1
08/13/2021 14:00	0.0	0	0	0	0	1
08/13/2021 15:00	0.0	0	0	0	0	1
08/13/2021 16:00	0.0	0	0	0	0	1
08/13/2021 17:00	0.0	0	0	0	0	1
08/13/2021 18:00	0.0	0	0	0	0	1
08/13/2021 19:00	0.0	0	0	0	0	1
08/13/2021 20:00	0.0	0	0	0	0	1
08/13/2021 21:00	0.0	0	0	0	0	1
08/13/2021 22:00	0.0	0	0	0	0	1
08/13/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/14/2021 00:00	0.0	0	0	0	0	1
08/14/2021 01:00	0.0	0	0	0	0	1
08/14/2021 02:00	0.0	0	0	0	0	1
08/14/2021 03:00	0.0	0	0	0	0	1
08/14/2021 04:00	0.0	0	0	0	0	1
08/14/2021 05:00	0.0	0	0	0	0	1
08/14/2021 06:00	0.0	0	0	0	0	1
08/14/2021 07:00	0.0	0	0	0	0	1
08/14/2021 08:00	0.0	0	0	0	0	1
08/14/2021 09:00	0.0	0	0	0	0	1
08/14/2021 10:00	0.0	0	0	0	0	1
08/14/2021 11:00	0.0	0	0	0	0	1
08/14/2021 12:00	0.0	0	0	0	0	1
08/14/2021 13:00	0.0	0	0	0	0	1
08/14/2021 14:00	0.0	0	0	0	0	1
08/14/2021 15:00	0.0	0	0	0	0	1
08/14/2021 16:00	0.0	0	0	0	0	1
08/14/2021 17:00	0.0	0	0	0	0	1
08/14/2021 18:00	0.0	0	0	0	0	1
08/14/2021 19:00	0.0	0	0	0	0	1
08/14/2021 20:00	0.0	0	0	0	0	1
08/14/2021 21:00	0.0	0	0	0	0	1
08/14/2021 22:00	0.0	0	0	0	0	1
08/14/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/15/2021 00:00	0.0	0	0	0	0	1
08/15/2021 01:00	0.0	0	0	0	0	1
08/15/2021 02:00	0.0	0	0	0	0	1
08/15/2021 03:00	0.0	0	0	0	0	1
08/15/2021 04:00	0.0	0	0	0	0	1
08/15/2021 05:00	0.0	0	0	0	0	1
08/15/2021 06:00	0.0	0	0	0	0	1
08/15/2021 07:00	0.0	0	0	0	0	1
08/15/2021 08:00	0.0	0	0	0	0	1
08/15/2021 09:00	0.0	0	0	0	0	1
08/15/2021 10:00	0.0	0	0	0	0	1
08/15/2021 11:00	0.0	0	0	0	0	1
08/15/2021 12:00	0.0	0	0	0	0	1
08/15/2021 13:00	0.0	0	0	0	0	1
08/15/2021 14:00	0.0	0	0	0	0	1
08/15/2021 15:00	0.0	0	0	0	0	1
08/15/2021 16:00	0.0	0	0	0	0	1
08/15/2021 17:00	0.0	0	0	0	0	1
08/15/2021 18:00	0.0	0	0	0	0	1
08/15/2021 19:00	0.0	0	0	0	0	1
08/15/2021 20:00	0.0	0	0	0	0	1
08/15/2021 21:00	0.0	0	0	0	0	1
08/15/2021 22:00	0.0	0	0	0	0	1
08/15/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/16/2021 00:00	0.0	0	0	0	0	1
08/16/2021 01:00	0.0	0	0	0	0	1
08/16/2021 02:00	0.0	0	0	0	0	1
08/16/2021 03:00	0.0	0	0	0	0	1
08/16/2021 04:00	0.0	0	0	0	0	1
08/16/2021 05:00	0.0	0	0	0	0	1
08/16/2021 06:00	0.0	0	0	0	0	1
08/16/2021 07:00	0.0	0	0	0	0	1
08/16/2021 08:00	0.0	0	0	0	0	1
08/16/2021 09:00	0.0	0	0	0	0	1
08/16/2021 10:00	0.0	0	0	0	0	1
08/16/2021 11:00	0.0	0	0	0	0	1
08/16/2021 12:00	0.0	0	0	0	0	1
08/16/2021 13:00	0.0	0	0	0	0	1
08/16/2021 14:00	0.0	0	0	0	0	1
08/16/2021 15:00	0.0	0	0	0	0	1
08/16/2021 16:00	0.0	0	0	0	0	1
08/16/2021 17:00	0.0	0	0	0	0	1
08/16/2021 18:00	0.0	0	0	0	0	1
08/16/2021 19:00	0.0	0	0	0	0	1
08/16/2021 20:00	0.0	0	0	0	0	1
08/16/2021 21:00	0.0	0	0	0	0	1
08/16/2021 22:00	0.0	0	0	0	0	1
08/16/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/17/2021 00:00	0.0	0	0	0	0	1
08/17/2021 01:00	0.0	0	0	0	0	1
08/17/2021 02:00	0.0	0	0	0	0	1
08/17/2021 03:00	0.0	0	0	0	0	1
08/17/2021 04:00	0.0	0	0	0	0	1
08/17/2021 05:00	0.0	0	0	0	0	1
08/17/2021 06:00	0.0	0	0	0	0	1
08/17/2021 07:00	0.0	0	0	0	0	1
08/17/2021 08:00	0.0	0	0	0	0	1
08/17/2021 09:00	0.0	0	0	0	0	1
08/17/2021 10:00	0.0	0	0	0	0	1
08/17/2021 11:00	0.0	0	0	0	0	1
08/17/2021 12:00	0.0	0	0	0	0	1
08/17/2021 13:00	0.0	0	0	0	0	1
08/17/2021 14:00	0.0	0	0	0	0	1
08/17/2021 15:00	0.0	0	0	0	0	1
08/17/2021 16:00	0.0	0	0	0	0	1
08/17/2021 17:00	0.0	0	0	0	0	1
08/17/2021 18:00	0.0	0	0	0	0	1
08/17/2021 19:00	0.0	0	0	0	0	1
08/17/2021 20:00	0.0	0	0	0	0	1
08/17/2021 21:00	0.0	0	0	0	0	1
08/17/2021 22:00	0.0	0	0	0	0	1
08/17/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/18/2021 00:00	0.0	0	0	0	0	1
08/18/2021 01:00	0.0	0	0	0	0	1
08/18/2021 02:00	0.0	0	0	0	0	1
08/18/2021 03:00	0.0	0	0	0	0	1
08/18/2021 04:00	0.0	0	0	0	0	1
08/18/2021 05:00	0.0	0	0	0	0	1
08/18/2021 06:00	0.0	0	0	0	0	1
08/18/2021 07:00	0.0	0	0	0	0	1
08/18/2021 08:00	0.0	0	0	0	0	1
08/18/2021 09:00	0.0	0	0	0	0	1
08/18/2021 10:00	0.0	0	0	0	0	1
08/18/2021 11:00	0.0	0	0	0	0	1
08/18/2021 12:00	0.0	0	0	0	0	1
08/18/2021 13:00	0.0	0	0	0	0	1
08/18/2021 14:00	0.0	0	0	0	0	1
08/18/2021 15:00	0.0	0	0	0	0	1
08/18/2021 16:00	0.0	0	0	0	0	1
08/18/2021 17:00	0.0	0	0	0	0	1
08/18/2021 18:00	0.0	0	0	0	0	1
08/18/2021 19:00	0.0	0	0	0	0	1
08/18/2021 20:00	0.0	0	0	0	0	1
08/18/2021 21:00	0.0	0	0	0	0	1
08/18/2021 22:00	0.0	0	0	0	0	1
08/18/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/19/2021 00:00	0.0	0	0	0	0	1
08/19/2021 01:00	0.0	0	0	0	0	1
08/19/2021 02:00	0.0	0	0	0	0	1
08/19/2021 03:00	0.0	0	0	0	0	1
08/19/2021 04:00	0.0	0	0	0	0	1
08/19/2021 05:00	0.0	0	0	0	0	1
08/19/2021 06:00	0.0	0	0	0	0	1
08/19/2021 07:00	0.0	0	0	0	0	1
08/19/2021 08:00	0.0	0	0	0	0	1
08/19/2021 09:00	0.0	0	0	0	0	1
08/19/2021 10:00	0.0	0	0	0	0	1
08/19/2021 11:00	0.0	0	0	0	0	1
08/19/2021 12:00	0.0	0	0	0	0	1
08/19/2021 13:00	0.0	0	0	0	0	1
08/19/2021 14:00	0.0	0	0	0	0	1
08/19/2021 15:00	0.0	0	0	0	0	1
08/19/2021 16:00	0.0	0	0	0	0	1
08/19/2021 17:00	0.0	0	0	0	0	1
08/19/2021 18:00	0.0	0	0	0	0	1
08/19/2021 19:00	0.0	0	0	0	0	1
08/19/2021 20:00	0.0	0	0	0	0	1
08/19/2021 21:00	0.0	0	0	0	0	1
08/19/2021 22:00	0.0	0	0	0	0	1
08/19/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/20/2021 00:00	0.0	0	0	0	0	1
08/20/2021 01:00	0.0	0	0	0	0	1
08/20/2021 02:00	0.0	0	0	0	0	1
08/20/2021 03:00	0.0	0	0	0	0	1
08/20/2021 04:00	0.0	0	0	0	0	1
08/20/2021 05:00	0.0	0	0	0	0	1
08/20/2021 06:00	0.0	0	0	0	0	1
08/20/2021 07:00	0.0	0	0	0	0	1
08/20/2021 08:00	0.0	0	0	0	0	1
08/20/2021 09:00	0.0	0	0	0	0	1
08/20/2021 10:00	0.0	0	0	0	0	1
08/20/2021 11:00	0.0	0	0	0	0	1
08/20/2021 12:00	0.0	0	0	0	0	1
08/20/2021 13:00	0.0	0	0	0	0	1
08/20/2021 14:00	0.0	0	0	0	0	1
08/20/2021 15:00	0.0	0	0	0	0	1
08/20/2021 16:00	0.0	0	0	0	0	1
08/20/2021 17:00	0.0	0	0	0	0	1
08/20/2021 18:00	0.0	0	0	0	0	1
08/20/2021 19:00	0.0	0	0	0	0	1
08/20/2021 20:00	0.0	0	0	0	0	1
08/20/2021 21:00	0.0	0	0	0	0	1
08/20/2021 22:00	0.0	0	0	0	0	1
08/20/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/21/2021 00:00	51.9	0	0	0	1	0
08/21/2021 01:00	0.0	0	0	0	0	0
08/21/2021 02:00	0.0	0	0	0	0	0
08/21/2021 03:00	0.0	0	0	0	0	0
08/21/2021 04:00	0.0	0	0	0	0	0
08/21/2021 05:00	0.0	0	0	0	0	0
08/21/2021 06:00	0.0	0	0	0	0	0
08/21/2021 07:00	0.0	0	0	0	0	0
08/21/2021 08:00	0.0	0	0	0	0	0
08/21/2021 09:00	0.0	0	0	0	0	0
08/21/2021 10:00	0.0	0	0	0	0	0
08/21/2021 11:00	0.0	0	0	0	0	0
08/21/2021 12:00	0.0	0	0	0	0	0
08/21/2021 13:00	0.0	0	0	0	0	0
08/21/2021 14:00	0.0	0	0	0	0	0
08/21/2021 15:00	0.0	0	0	0	0	0
08/21/2021 16:00	0.0	0	0	0	0	0
08/21/2021 17:00	0.0	0	0	0	0	0
08/21/2021 18:00	0.0	0	0	0	0	0
08/21/2021 19:00	0.0	0	0	0	0	0
08/21/2021 20:00	0.0	0	0	0	0	0
08/21/2021 21:00	0.0	0	0	0	0	0
08/21/2021 22:00	0.0	0	0	0	0	0
08/21/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	51.9 #	0 #	0 #	0 #	1 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	51.9	0	0	0	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/22/2021 00:00	0.0	0	0	0	0	0
08/22/2021 01:00	0.0	0	0	0	0	0
08/22/2021 02:00	0.0	0	0	0	0	0
08/22/2021 03:00	0.0	0	0	0	0	0
08/22/2021 04:00	0.0	0	0	0	0	0
08/22/2021 05:00	0.0	0	0	0	0	0
08/22/2021 06:00	0.0	0	0	0	0	0
08/22/2021 07:00	0.0	0	0	0	0	0
08/22/2021 08:00	0.0	0	0	0	0	0
08/22/2021 09:00	0.0	0	0	0	0	0
08/22/2021 10:00	0.0	0	0	0	0	0
08/22/2021 11:00	0.0	0	0	0	0	0
08/22/2021 12:00	0.0	0	0	0	0	0
08/22/2021 13:00	0.0	0	0	0	0	0
08/22/2021 14:00	0.0	0	0	0	0	0
08/22/2021 15:00	0.0	0	0	0	0	0
08/22/2021 16:00	0.0	0	0	0	0	0
08/22/2021 17:00	0.0	0	0	0	0	0
08/22/2021 18:00	0.0	0	0	0	0	0
08/22/2021 19:00	0.0	0	0	0	0	0
08/22/2021 20:00	0.0	0	0	0	0	0
08/22/2021 21:00	0.0	0	0	0	0	0
08/22/2021 22:00	0.0	0	0	0	0	0
08/22/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/23/2021 00:00	0.0	0	0	0	0	0
08/23/2021 01:00	0.0	0	0	0	0	0
08/23/2021 02:00	0.0	0	0	0	0	0
08/23/2021 03:00	0.0	0	0	0	0	0
08/23/2021 04:00	0.0	0	0	0	0	0
08/23/2021 05:00	0.0	0	0	0	0	0
08/23/2021 06:00	0.0	0	0	0	0	0
08/23/2021 07:00	0.0	0	0	0	0	0
08/23/2021 08:00	0.0	0	0	0	0	0
08/23/2021 09:00	0.0	0	0	0	0	0
08/23/2021 10:00	0.0	0	0	0	0	0
08/23/2021 11:00	0.0	0	0	0	0	0
08/23/2021 12:00	0.0	0	0	0	0	0
08/23/2021 13:00	0.0	0	0	0	0	0
08/23/2021 14:00	0.0	0	0	0	0	0
08/23/2021 15:00	0.0	0	0	0	0	0
08/23/2021 16:00	2,766.8	0	1	0	0	0
08/23/2021 17:00	6,571.7	0	1	0	0	0
08/23/2021 18:00	0.0	0	0	0	0	1
08/23/2021 19:00	0.0	0	0	0	0	1
08/23/2021 20:00	0.0	0	0	0	0	1
08/23/2021 21:00	0.0	0	0	0	0	1
08/23/2021 22:00	0.0	0	0	0	0	1
08/23/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	9,338.5 #	0 #	2 #	0 #	0 #	6 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,571.7	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/24/2021 00:00	0.0	0	0	0	0	1
08/24/2021 01:00	0.0	0	0	0	0	1
08/24/2021 02:00	0.0	0	0	0	0	1
08/24/2021 03:00	0.0	0	0	0	0	1
08/24/2021 04:00	0.0	0	0	0	0	1
08/24/2021 05:00	0.0	0	0	0	0	1
08/24/2021 06:00	0.0	0	0	0	0	1
08/24/2021 07:00	0.0	0	0	0	0	1
08/24/2021 08:00	0.0	0	0	0	0	1
08/24/2021 09:00	0.0	0	0	0	0	1
08/24/2021 10:00	0.0	0	0	0	0	1
08/24/2021 11:00	0.0	0	0	0	0	1
08/24/2021 12:00	0.0	0	0	0	0	1
08/24/2021 13:00	0.0	0	0	0	0	1
08/24/2021 14:00	0.0	0	0	0	0	1
08/24/2021 15:00	0.0	0	0	0	0	1
08/24/2021 16:00	0.0	0	0	0	0	1
08/24/2021 17:00	0.0	0	0	0	0	1
08/24/2021 18:00	0.0	0	0	0	0	1
08/24/2021 19:00	0.0	0	0	0	0	1
08/24/2021 20:00	0.0	0	0	0	0	1
08/24/2021 21:00	0.0	0	0	0	0	1
08/24/2021 22:00	0.0	0	0	0	0	1
08/24/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/25/2021 00:00	0.0	0	0	0	0	1
08/25/2021 01:00	0.0	0	0	0	0	1
08/25/2021 02:00	0.0	0	0	0	0	1
08/25/2021 03:00	0.0	0	0	0	0	1
08/25/2021 04:00	0.0	0	0	0	0	1
08/25/2021 05:00	0.0	0	0	0	0	1
08/25/2021 06:00	0.0	0	0	0	0	1
08/25/2021 07:00	0.0	0	0	0	0	1
08/25/2021 08:00	0.0	0	0	0	0	1
08/25/2021 09:00	0.0	0	0	0	0	1
08/25/2021 10:00	0.0	0	0	0	0	1
08/25/2021 11:00	0.0	0	0	0	0	1
08/25/2021 12:00	0.0	0	0	0	0	1
08/25/2021 13:00	0.0	0	0	0	0	1
08/25/2021 14:00	0.0	0	0	0	0	1
08/25/2021 15:00	0.0	0	0	0	0	1
08/25/2021 16:00	0.0	0	0	0	0	1
08/25/2021 17:00	0.0	0	0	0	0	1
08/25/2021 18:00	0.0	0	0	0	0	1
08/25/2021 19:00	0.0	0	0	0	0	1
08/25/2021 20:00	0.0	0	0	0	0	1
08/25/2021 21:00	0.0	0	0	0	0	1
08/25/2021 22:00	0.0	0	0	0	0	1
08/25/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/26/2021 00:00	0.0	0	0	0	0	1
08/26/2021 01:00	0.0	0	0	0	0	1
08/26/2021 02:00	0.0	0	0	0	0	1
08/26/2021 03:00	0.0	0	0	0	0	1
08/26/2021 04:00	0.0	0	0	0	0	1
08/26/2021 05:00	0.0	0	0	0	0	1
08/26/2021 06:00	0.0	0	0	0	0	1
08/26/2021 07:00	0.0	0	0	0	0	1
08/26/2021 08:00	0.0	0	0	0	0	1
08/26/2021 09:00	0.0	0	0	0	0	1
08/26/2021 10:00	0.0	0	0	0	0	1
08/26/2021 11:00	0.0	0	0	0	0	1
08/26/2021 12:00	0.0	0	0	0	0	1
08/26/2021 13:00	0.0	0	0	0	0	1
08/26/2021 14:00	0.0	0	0	0	0	1
08/26/2021 15:00	0.0	0	0	0	0	1
08/26/2021 16:00	0.0	0	0	0	0	1
08/26/2021 17:00	0.0	0	0	0	0	1
08/26/2021 18:00	0.0	0	0	0	0	1
08/26/2021 19:00	0.0	0	0	0	0	1
08/26/2021 20:00	0.0	0	0	0	0	1
08/26/2021 21:00	0.0	0	0	0	0	1
08/26/2021 22:00	0.0	0	0	0	0	1
08/26/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/27/2021 00:00	0.0	0	0	0	0	1
08/27/2021 01:00	0.0	0	0	0	0	1
08/27/2021 02:00	0.0	0	0	0	0	1
08/27/2021 03:00	0.0	0	0	0	0	1
08/27/2021 04:00	0.0	0	0	0	0	1
08/27/2021 05:00	0.0	0	0	0	0	1
08/27/2021 06:00	0.0	0	0	0	0	1
08/27/2021 07:00	0.0	0	0	0	0	1
08/27/2021 08:00	0.0	0	0	0	0	1
08/27/2021 09:00	0.0	0	0	0	0	1
08/27/2021 10:00	0.0	0	0	0	0	1
08/27/2021 11:00	0.0	0	0	0	0	1
08/27/2021 12:00	0.0	0	0	0	0	1
08/27/2021 13:00	0.0	0	0	0	0	1
08/27/2021 14:00	0.0	0	0	0	0	1
08/27/2021 15:00	0.0	0	0	0	0	1
08/27/2021 16:00	0.0	0	0	0	0	1
08/27/2021 17:00	0.0	0	0	0	0	1
08/27/2021 18:00	0.0	0	0	0	0	1
08/27/2021 19:00	0.0	0	0	0	0	1
08/27/2021 20:00	0.0	0	0	0	0	1
08/27/2021 21:00	0.0	0	0	0	0	1
08/27/2021 22:00	0.0	0	0	0	0	1
08/27/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/28/2021 00:00	0.0	0	0	0	0	1
08/28/2021 01:00	0.0	0	0	0	0	1
08/28/2021 02:00	0.0	0	0	0	0	1
08/28/2021 03:00	0.0	0	0	0	0	1
08/28/2021 04:00	0.0	0	0	0	0	1
08/28/2021 05:00	0.0	0	0	0	0	1
08/28/2021 06:00	0.0	0	0	0	0	1
08/28/2021 07:00	0.0	0	0	0	0	1
08/28/2021 08:00	0.0	0	0	0	0	1
08/28/2021 09:00	0.0	0	0	0	0	1
08/28/2021 10:00	0.0	0	0	0	0	1
08/28/2021 11:00	0.0	0	0	0	0	1
08/28/2021 12:00	0.0	0	0	0	0	1
08/28/2021 13:00	0.0	0	0	0	0	1
08/28/2021 14:00	0.0	0	0	0	0	1
08/28/2021 15:00	0.0	0	0	0	0	1
08/28/2021 16:00	0.0	0	0	0	0	1
08/28/2021 17:00	0.0	0	0	0	0	1
08/28/2021 18:00	0.0	0	0	0	0	1
08/28/2021 19:00	0.0	0	0	0	0	1
08/28/2021 20:00	0.0	0	0	0	0	1
08/28/2021 21:00	0.0	0	0	0	0	1
08/28/2021 22:00	0.0	0	0	0	0	1
08/28/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/29/2021 00:00	0.0	0	0	0	0	1
08/29/2021 01:00	0.0	0	0	0	0	1
08/29/2021 02:00	0.0	0	0	0	0	1
08/29/2021 03:00	0.0	0	0	0	0	1
08/29/2021 04:00	0.0	0	0	0	0	1
08/29/2021 05:00	0.0	0	0	0	0	1
08/29/2021 06:00	0.0	0	0	0	0	1
08/29/2021 07:00	0.0	0	0	0	0	1
08/29/2021 08:00	0.0	0	0	0	0	1
08/29/2021 09:00	0.0	0	0	0	0	1
08/29/2021 10:00	0.0	0	0	0	0	1
08/29/2021 11:00	0.0	0	0	0	0	1
08/29/2021 12:00	0.0	0	0	0	0	1
08/29/2021 13:00	0.0	0	0	0	0	1
08/29/2021 14:00	0.0	0	0	0	0	1
08/29/2021 15:00	0.0	0	0	0	0	1
08/29/2021 16:00	0.0	0	0	0	0	1
08/29/2021 17:00	0.0	0	0	0	0	1
08/29/2021 18:00	0.0	0	0	0	0	1
08/29/2021 19:00	0.0	0	0	0	0	1
08/29/2021 20:00	0.0	0	0	0	0	1
08/29/2021 21:00	0.0	0	0	0	0	1
08/29/2021 22:00	0.0	0	0	0	0	1
08/29/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/30/2021 00:00	0.0	0	0	0	0	1
08/30/2021 01:00	0.0	0	0	0	0	1
08/30/2021 02:00	0.0	0	0	0	0	1
08/30/2021 03:00	0.0	0	0	0	0	1
08/30/2021 04:00	0.0	0	0	0	0	1
08/30/2021 05:00	0.0	0	0	0	0	1
08/30/2021 06:00	0.0	0	0	0	0	1
08/30/2021 07:00	0.0	0	0	0	0	1
08/30/2021 08:00	0.0	0	0	0	0	1
08/30/2021 09:00	0.0	0	0	0	0	1
08/30/2021 10:00	0.0	0	0	0	0	1
08/30/2021 11:00	0.0	0	0	0	0	1
08/30/2021 12:00	0.0	0	0	0	0	1
08/30/2021 13:00	0.0	0	0	0	0	1
08/30/2021 14:00	0.0	0	0	0	0	1
08/30/2021 15:00	0.0	0	0	0	0	1
08/30/2021 16:00	0.0	0	0	0	0	1
08/30/2021 17:00	0.0	0	0	0	0	1
08/30/2021 18:00	0.0	0	0	0	0	1
08/30/2021 19:00	0.0	0	0	0	0	1
08/30/2021 20:00	0.0	0	0	0	0	1
08/30/2021 21:00	0.0	0	0	0	0	1
08/30/2021 22:00	0.0	0	0	0	0	1
08/30/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/31/2021 00:00	0.0	0	0	0	0	1
08/31/2021 01:00	0.0	0	0	0	0	1
08/31/2021 02:00	0.0	0	0	0	0	1
08/31/2021 03:00	0.0	0	0	0	0	1
08/31/2021 04:00	0.0	0	0	0	0	1
08/31/2021 05:00	0.0	0	0	0	0	1
08/31/2021 06:00	0.0	0	0	0	0	1
08/31/2021 07:00	0.0	0	0	0	0	1
08/31/2021 08:00	0.0	0	0	0	0	1
08/31/2021 09:00	0.0	0	0	0	0	1
08/31/2021 10:00	0.0	0	0	0	0	1
08/31/2021 11:00	0.0	0	0	0	0	1
08/31/2021 12:00	0.0	0	0	0	0	1
08/31/2021 13:00	0.0	0	0	0	0	1
08/31/2021 14:00	0.0	0	0	0	0	1
08/31/2021 15:00	0.0	0	0	0	0	1
08/31/2021 16:00	0.0	0	0	0	0	1
08/31/2021 17:00	0.0	0	0	0	0	1
08/31/2021 18:00	0.0	0	0	0	0	1
08/31/2021 19:00	0.0	0	0	0	0	1
08/31/2021 20:00	0.0	0	0	0	0	1
08/31/2021 21:00	0.0	0	0	0	0	1
08/31/2021 22:00	0.0	0	0	0	0	1
08/31/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/01/2021 00:00	0.0	0	0	0	0	1
09/01/2021 01:00	0.0	0	0	0	0	1
09/01/2021 02:00	0.0	0	0	0	0	1
09/01/2021 03:00	0.0	0	0	0	0	1
09/01/2021 04:00	0.0	0	0	0	0	1
09/01/2021 05:00	0.0	0	0	0	0	1
09/01/2021 06:00	0.0	0	0	0	0	1
09/01/2021 07:00	0.0	0	0	0	0	1
09/01/2021 08:00	0.0	0	0	0	0	1
09/01/2021 09:00	0.0	0	0	0	0	1
09/01/2021 10:00	0.0	0	0	0	0	1
09/01/2021 11:00	0.0	0	0	0	0	1
09/01/2021 12:00	0.0	0	0	0	0	1
09/01/2021 13:00	0.0	0	0	0	0	1
09/01/2021 14:00	0.0	0	0	0	0	1
09/01/2021 15:00	0.0	0	0	0	0	1
09/01/2021 16:00	0.0	0	0	0	0	1
09/01/2021 17:00	0.0	0	0	0	0	1
09/01/2021 18:00	0.0	0	0	0	0	1
09/01/2021 19:00	0.0	0	0	0	0	1
09/01/2021 20:00	0.0	0	0	0	0	1
09/01/2021 21:00	0.0	0	0	0	0	1
09/01/2021 22:00	0.0	0	0	0	0	1
09/01/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/02/2021 00:00	0.0	0	0	0	0	1
09/02/2021 01:00	0.0	0	0	0	0	1
09/02/2021 02:00	0.0	0	0	0	0	1
09/02/2021 03:00	0.0	0	0	0	0	1
09/02/2021 04:00	0.0	0	0	0	0	1
09/02/2021 05:00	0.0	0	0	0	0	1
09/02/2021 06:00	0.0	0	0	0	0	1
09/02/2021 07:00	0.0	0	0	0	0	1
09/02/2021 08:00	0.0	0	0	0	0	1
09/02/2021 09:00	0.0	0	0	0	0	1
09/02/2021 10:00	0.0	0	0	0	0	1
09/02/2021 11:00	0.0	0	0	0	0	1
09/02/2021 12:00	0.0	0	0	0	0	1
09/02/2021 13:00	0.0	0	0	0	0	1
09/02/2021 14:00	0.0	0	0	0	0	1
09/02/2021 15:00	0.0	0	0	0	0	1
09/02/2021 16:00	0.0	0	0	0	0	1
09/02/2021 17:00	0.0	0	0	0	0	1
09/02/2021 18:00	0.0	0	0	0	0	1
09/02/2021 19:00	0.0	0	0	0	0	1
09/02/2021 20:00	0.0	0	0	0	0	1
09/02/2021 21:00	0.0	0	0	0	0	1
09/02/2021 22:00	0.0	0	0	0	0	1
09/02/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/03/2021 00:00	0.0	0	0	0	0	1
09/03/2021 01:00	0.0	0	0	0	0	1
09/03/2021 02:00	0.0	0	0	0	0	1
09/03/2021 03:00	0.0	0	0	0	0	1
09/03/2021 04:00	0.0	0	0	0	0	1
09/03/2021 05:00	0.0	0	0	0	0	1
09/03/2021 06:00	0.0	0	0	0	0	1
09/03/2021 07:00	0.0	0	0	0	0	1
09/03/2021 08:00	0.0	0	0	0	0	1
09/03/2021 09:00	0.0	0	0	0	0	1
09/03/2021 10:00	0.0	0	0	0	0	1
09/03/2021 11:00	0.0	0	0	0	0	1
09/03/2021 12:00	0.0	0	0	0	0	1
09/03/2021 13:00	0.0	0	0	0	0	1
09/03/2021 14:00	0.0	0	0	0	0	1
09/03/2021 15:00	0.0	0	0	0	0	1
09/03/2021 16:00	0.0	0	0	0	0	1
09/03/2021 17:00	0.0	0	0	0	0	1
09/03/2021 18:00	0.0	0	0	0	0	1
09/03/2021 19:00	0.0	0	0	0	0	1
09/03/2021 20:00	0.0	0	0	0	0	1
09/03/2021 21:00	0.0	0	0	0	0	1
09/03/2021 22:00	0.0	0	0	0	0	1
09/03/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/04/2021 00:00	0.0	0	0	0	0	1
09/04/2021 01:00	0.0	0	0	0	0	1
09/04/2021 02:00	0.0	0	0	0	0	1
09/04/2021 03:00	68.7	0	0	0	1	0
09/04/2021 04:00	0.0	0	0	0	0	0
09/04/2021 05:00	0.0	0	0	0	0	0
09/04/2021 06:00	0.0	0	0	0	0	0
09/04/2021 07:00	0.0	0	0	0	0	0
09/04/2021 08:00	0.0	0	0	0	0	0
09/04/2021 09:00	686.6	0	0	1	0	0
09/04/2021 10:00	5,604.4	0	0	1	0	0
09/04/2021 11:00	0.0	0	0	0	0	1
09/04/2021 12:00	0.0	0	0	0	0	1
09/04/2021 13:00	0.0	0	0	0	0	1
09/04/2021 14:00	0.0	0	0	0	0	1
09/04/2021 15:00	0.0	0	0	0	0	1
09/04/2021 16:00	0.0	0	0	0	0	1
09/04/2021 17:00	0.0	0	0	0	0	1
09/04/2021 18:00	0.0	0	0	0	0	1
09/04/2021 19:00	0.0	0	0	0	0	1
09/04/2021 20:00	0.0	0	0	0	0	1
09/04/2021 21:00	0.0	0	0	0	0	1
09/04/2021 22:00	0.0	0	0	0	0	1
09/04/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	6,359.7 #	0 #	0 #	2 #	1 #	16 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,604.4	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/05/2021 00:00	0.0	0	0	0	0	1
09/05/2021 01:00	0.0	0	0	0	0	1
09/05/2021 02:00	0.0	0	0	0	0	1
09/05/2021 03:00	0.0	0	0	0	0	1
09/05/2021 04:00	0.0	0	0	0	0	1
09/05/2021 05:00	0.0	0	0	0	0	1
09/05/2021 06:00	0.0	0	0	0	0	1
09/05/2021 07:00	0.0	0	0	0	0	1
09/05/2021 08:00	0.0	0	0	0	0	1
09/05/2021 09:00	0.0	0	0	0	0	1
09/05/2021 10:00	0.0	0	0	0	0	1
09/05/2021 11:00	0.0	0	0	0	0	1
09/05/2021 12:00	0.0	0	0	0	0	1
09/05/2021 13:00	0.0	0	0	0	0	1
09/05/2021 14:00	0.0	0	0	0	0	1
09/05/2021 15:00	0.0	0	0	0	0	1
09/05/2021 16:00	0.0	0	0	0	0	1
09/05/2021 17:00	0.0	0	0	0	0	1
09/05/2021 18:00	0.0	0	0	0	0	1
09/05/2021 19:00	0.0	0	0	0	0	1
09/05/2021 20:00	0.0	0	0	0	0	1
09/05/2021 21:00	0.0	0	0	0	0	1
09/05/2021 22:00	0.0	0	0	0	0	1
09/05/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/06/2021 00:00	0.0	0	0	0	0	1
09/06/2021 01:00	0.0	0	0	0	0	1
09/06/2021 02:00	0.0	0	0	0	0	1
09/06/2021 03:00	0.0	0	0	0	0	1
09/06/2021 04:00	0.0	0	0	0	0	1
09/06/2021 05:00	0.0	0	0	0	0	1
09/06/2021 06:00	0.0	0	0	0	0	1
09/06/2021 07:00	0.0	0	0	0	0	1
09/06/2021 08:00	0.0	0	0	0	0	1
09/06/2021 09:00	0.0	0	0	0	0	1
09/06/2021 10:00	0.0	0	0	0	0	1
09/06/2021 11:00	0.0	0	0	0	0	1
09/06/2021 12:00	0.0	0	0	0	0	1
09/06/2021 13:00	0.0	0	0	0	0	1
09/06/2021 14:00	0.0	0	0	0	0	1
09/06/2021 15:00	0.0	0	0	0	0	1
09/06/2021 16:00	0.0	0	0	0	0	1
09/06/2021 17:00	0.0	0	0	0	0	1
09/06/2021 18:00	0.0	0	0	0	0	1
09/06/2021 19:00	0.0	0	0	0	0	1
09/06/2021 20:00	0.0	0	0	0	0	1
09/06/2021 21:00	0.0	0	0	0	0	1
09/06/2021 22:00	0.0	0	0	0	0	1
09/06/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/07/2021 00:00	0.0	0	0	0	0	1
09/07/2021 01:00	0.0	0	0	0	0	1
09/07/2021 02:00	0.0	0	0	0	0	1
09/07/2021 03:00	0.0	0	0	0	0	1
09/07/2021 04:00	0.0	0	0	0	0	1
09/07/2021 05:00	0.0	0	0	0	0	1
09/07/2021 06:00	0.0	0	0	0	0	1
09/07/2021 07:00	0.0	0	0	0	0	1
09/07/2021 08:00	0.0	0	0	0	0	1
09/07/2021 09:00	0.0	0	0	0	0	1
09/07/2021 10:00	0.0	0	0	0	0	1
09/07/2021 11:00	0.0	0	0	0	0	1
09/07/2021 12:00	0.0	0	0	0	0	1
09/07/2021 13:00	0.0	0	0	0	0	1
09/07/2021 14:00	0.0	0	0	0	0	1
09/07/2021 15:00	0.0	0	0	0	0	1
09/07/2021 16:00	0.0	0	0	0	0	1
09/07/2021 17:00	0.0	0	0	0	0	1
09/07/2021 18:00	0.0	0	0	0	0	1
09/07/2021 19:00	0.0	0	0	0	0	1
09/07/2021 20:00	0.0	0	0	0	0	1
09/07/2021 21:00	0.0	0	0	0	0	1
09/07/2021 22:00	0.0	0	0	0	0	1
09/07/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/08/2021 00:00	0.0	0	0	0	0	1
09/08/2021 01:00	0.0	0	0	0	0	1
09/08/2021 02:00	0.0	0	0	0	0	1
09/08/2021 03:00	0.0	0	0	0	0	1
09/08/2021 04:00	0.0	0	0	0	0	1
09/08/2021 05:00	0.0	0	0	0	0	1
09/08/2021 06:00	0.0	0	0	0	0	1
09/08/2021 07:00	0.0	0	0	0	0	1
09/08/2021 08:00	0.0	0	0	0	0	1
09/08/2021 09:00	0.0	0	0	0	0	1
09/08/2021 10:00	0.0	0	0	0	0	1
09/08/2021 11:00	0.0	0	0	0	0	1
09/08/2021 12:00	0.0	0	0	0	0	1
09/08/2021 13:00	0.0	0	0	0	0	1
09/08/2021 14:00	0.0	0	0	0	0	1
09/08/2021 15:00	0.0	0	0	0	0	1
09/08/2021 16:00	0.0	0	0	0	0	1
09/08/2021 17:00	0.0	0	0	0	0	1
09/08/2021 18:00	0.0	0	0	0	0	1
09/08/2021 19:00	0.0	0	0	0	0	1
09/08/2021 20:00	0.0	0	0	0	0	1
09/08/2021 21:00	0.0	0	0	0	0	1
09/08/2021 22:00	0.0	0	0	0	0	1
09/08/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/09/2021 00:00	0.0	0	0	0	0	1
09/09/2021 01:00	0.0	0	0	0	0	1
09/09/2021 02:00	0.0	0	0	0	0	1
09/09/2021 03:00	0.0	0	0	0	0	1
09/09/2021 04:00	0.0	0	0	0	0	1
09/09/2021 05:00	0.0	0	0	0	0	1
09/09/2021 06:00	0.0	0	0	0	0	1
09/09/2021 07:00	0.0	0	0	0	0	1
09/09/2021 08:00	0.0	0	0	0	0	1
09/09/2021 09:00	0.0	0	0	0	0	1
09/09/2021 10:00	0.0	0	0	0	0	1
09/09/2021 11:00	0.0	0	0	0	0	1
09/09/2021 12:00	0.0	0	0	0	0	1
09/09/2021 13:00	0.0	0	0	0	0	1
09/09/2021 14:00	0.0	0	0	0	0	1
09/09/2021 15:00	0.0	0	0	0	0	1
09/09/2021 16:00	0.0	0	0	0	0	1
09/09/2021 17:00	0.0	0	0	0	0	1
09/09/2021 18:00	0.0	0	0	0	0	1
09/09/2021 19:00	0.0	0	0	0	0	1
09/09/2021 20:00	0.0	0	0	0	0	1
09/09/2021 21:00	0.0	0	0	0	0	1
09/09/2021 22:00	0.0	0	0	0	0	1
09/09/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/10/2021 00:00	0.0	0	0	0	0	1
09/10/2021 01:00	0.0	0	0	0	0	1
09/10/2021 02:00	0.0	0	0	0	0	1
09/10/2021 03:00	0.0	0	0	0	0	1
09/10/2021 04:00	0.0	0	0	0	0	1
09/10/2021 05:00	0.0	0	0	0	0	1
09/10/2021 06:00	0.0	0	0	0	0	1
09/10/2021 07:00	0.0	0	0	0	0	1
09/10/2021 08:00	0.0	0	0	0	0	1
09/10/2021 09:00	0.0	0	0	0	0	1
09/10/2021 10:00	0.0	0	0	0	0	1
09/10/2021 11:00	0.0	0	0	0	0	1
09/10/2021 12:00	0.0	0	0	0	0	1
09/10/2021 13:00	0.0	0	0	0	0	1
09/10/2021 14:00	0.0	0	0	0	0	1
09/10/2021 15:00	0.0	0	0	0	0	1
09/10/2021 16:00	0.0	0	0	0	0	1
09/10/2021 17:00	0.0	0	0	0	0	1
09/10/2021 18:00	0.0	0	0	0	0	1
09/10/2021 19:00	0.0	0	0	0	0	1
09/10/2021 20:00	0.0	0	0	0	0	1
09/10/2021 21:00	0.0	0	0	0	0	1
09/10/2021 22:00	0.0	0	0	0	0	1
09/10/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/11/2021 00:00	0.0	0	0	0	0	1
09/11/2021 01:00	0.0	0	0	0	0	1
09/11/2021 02:00	0.0	0	0	0	0	1
09/11/2021 03:00	0.0	0	0	0	0	1
09/11/2021 04:00	0.0	0	0	0	0	1
09/11/2021 05:00	0.0	0	0	0	0	1
09/11/2021 06:00	0.0	0	0	0	0	1
09/11/2021 07:00	0.0	0	0	0	0	1
09/11/2021 08:00	0.0	0	0	0	0	1
09/11/2021 09:00	0.0	0	0	0	0	1
09/11/2021 10:00	0.0	0	0	0	0	1
09/11/2021 11:00	0.0	0	0	0	0	1
09/11/2021 12:00	0.0	0	0	0	0	1
09/11/2021 13:00	0.0	0	0	0	0	1
09/11/2021 14:00	0.0	0	0	0	0	1
09/11/2021 15:00	0.0	0	0	0	0	1
09/11/2021 16:00	0.0	0	0	0	0	1
09/11/2021 17:00	0.0	0	0	0	0	1
09/11/2021 18:00	0.0	0	0	0	0	1
09/11/2021 19:00	0.0	0	0	0	0	1
09/11/2021 20:00	0.0	0	0	0	0	1
09/11/2021 21:00	0.0	0	0	0	0	1
09/11/2021 22:00	0.0	0	0	0	0	1
09/11/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/12/2021 00:00	0.0	0	0	0	0	1
09/12/2021 01:00	0.0	0	0	0	0	1
09/12/2021 02:00	0.0	0	0	0	0	1
09/12/2021 03:00	0.0	0	0	0	0	1
09/12/2021 04:00	0.0	0	0	0	0	1
09/12/2021 05:00	0.0	0	0	0	0	1
09/12/2021 06:00	0.0	0	0	0	0	1
09/12/2021 07:00	0.0	0	0	0	0	1
09/12/2021 08:00	0.0	0	0	0	0	1
09/12/2021 09:00	0.0	0	0	0	0	1
09/12/2021 10:00	0.0	0	0	0	0	1
09/12/2021 11:00	0.0	0	0	0	0	1
09/12/2021 12:00	0.0	0	0	0	0	1
09/12/2021 13:00	0.0	0	0	0	0	1
09/12/2021 14:00	0.0	0	0	0	0	1
09/12/2021 15:00	0.0	0	0	0	0	1
09/12/2021 16:00	0.0	0	0	0	0	1
09/12/2021 17:00	0.0	0	0	0	0	1
09/12/2021 18:00	0.0	0	0	0	0	1
09/12/2021 19:00	0.0	0	0	0	0	1
09/12/2021 20:00	0.0	0	0	0	0	1
09/12/2021 21:00	0.0	0	0	0	0	1
09/12/2021 22:00	0.0	0	0	0	0	1
09/12/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/13/2021 00:00	0.0	0	0	0	0	1
09/13/2021 01:00	0.0	0	0	0	0	1
09/13/2021 02:00	0.0	0	0	0	0	1
09/13/2021 03:00	0.0	0	0	0	0	1
09/13/2021 04:00	0.0	0	0	0	0	1
09/13/2021 05:00	0.0	0	0	0	0	1
09/13/2021 06:00	0.0	0	0	0	0	1
09/13/2021 07:00	0.0	0	0	0	0	1
09/13/2021 08:00	0.0	0	0	0	0	1
09/13/2021 09:00	0.0	0	0	0	0	1
09/13/2021 10:00	0.0	0	0	0	0	1
09/13/2021 11:00	0.0	0	0	0	0	1
09/13/2021 12:00	0.0	0	0	0	0	1
09/13/2021 13:00	0.0	0	0	0	0	1
09/13/2021 14:00	0.0	0	0	0	0	1
09/13/2021 15:00	0.0	0	0	0	0	1
09/13/2021 16:00	0.0	0	0	0	0	1
09/13/2021 17:00	0.0	0	0	0	0	1
09/13/2021 18:00	0.0	0	0	0	0	1
09/13/2021 19:00	0.0	0	0	0	0	1
09/13/2021 20:00	0.0	0	0	0	0	1
09/13/2021 21:00	0.0	0	0	0	0	1
09/13/2021 22:00	0.0	0	0	0	0	1
09/13/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/14/2021 00:00	0.0	0	0	0	0	1
09/14/2021 01:00	0.0	0	0	0	0	1
09/14/2021 02:00	0.0	0	0	0	0	1
09/14/2021 03:00	0.0	0	0	0	0	1
09/14/2021 04:00	0.0	0	0	0	0	1
09/14/2021 05:00	0.0	0	0	0	0	1
09/14/2021 06:00	0.0	0	0	0	0	1
09/14/2021 07:00	0.0	0	0	0	0	1
09/14/2021 08:00	0.0	0	0	0	0	1
09/14/2021 09:00	0.0	0	0	0	0	1
09/14/2021 10:00	0.0	0	0	0	0	1
09/14/2021 11:00	0.0	0	0	0	0	1
09/14/2021 12:00	0.0	0	0	0	0	1
09/14/2021 13:00	0.0	0	0	0	0	1
09/14/2021 14:00	0.0	0	0	0	0	1
09/14/2021 15:00	0.0	0	0	0	0	1
09/14/2021 16:00	0.0	0	0	0	0	1
09/14/2021 17:00	0.0	0	0	0	0	1
09/14/2021 18:00	0.0	0	0	0	0	1
09/14/2021 19:00	0.0	0	0	0	0	1
09/14/2021 20:00	0.0	0	0	0	0	1
09/14/2021 21:00	0.0	0	0	0	0	1
09/14/2021 22:00	0.0	0	0	0	0	1
09/14/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/15/2021 00:00	0.0	0	0	0	0	1
09/15/2021 01:00	0.0	0	0	0	0	1
09/15/2021 02:00	0.0	0	0	0	0	1
09/15/2021 03:00	0.0	0	0	0	0	1
09/15/2021 04:00	0.0	0	0	0	0	1
09/15/2021 05:00	0.0	0	0	0	0	1
09/15/2021 06:00	0.0	0	0	0	0	1
09/15/2021 07:00	0.0	0	0	0	0	1
09/15/2021 08:00	0.0	0	0	0	0	1
09/15/2021 09:00	0.0	0	0	0	0	1
09/15/2021 10:00	0.0	0	0	0	0	1
09/15/2021 11:00	0.0	0	0	0	0	1
09/15/2021 12:00	0.0	0	0	0	0	1
09/15/2021 13:00	0.0	0	0	0	0	1
09/15/2021 14:00	0.0	0	0	0	0	1
09/15/2021 15:00	0.0	0	0	0	0	1
09/15/2021 16:00	0.0	0	0	0	0	1
09/15/2021 17:00	0.0	0	0	0	0	1
09/15/2021 18:00	0.0	0	0	0	0	1
09/15/2021 19:00	0.0	0	0	0	0	1
09/15/2021 20:00	0.0	0	0	0	0	1
09/15/2021 21:00	0.0	0	0	0	0	1
09/15/2021 22:00	0.0	0	0	0	0	1
09/15/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/16/2021 00:00	0.0	0	0	0	0	1
09/16/2021 01:00	0.0	0	0	0	0	1
09/16/2021 02:00	0.0	0	0	0	0	1
09/16/2021 03:00	0.0	0	0	0	0	1
09/16/2021 04:00	0.0	0	0	0	0	1
09/16/2021 05:00	0.0	0	0	0	0	1
09/16/2021 06:00	0.0	0	0	0	0	1
09/16/2021 07:00	0.0	0	0	0	0	1
09/16/2021 08:00	0.0	0	0	0	0	1
09/16/2021 09:00	0.0	0	0	0	0	1
09/16/2021 10:00	0.0	0	0	0	0	1
09/16/2021 11:00	0.0	0	0	0	0	1
09/16/2021 12:00	0.0	0	0	0	0	1
09/16/2021 13:00	0.0	0	0	0	0	1
09/16/2021 14:00	0.0	0	0	0	0	1
09/16/2021 15:00	0.0	0	0	0	0	1
09/16/2021 16:00	0.0	0	0	0	0	1
09/16/2021 17:00	0.0	0	0	0	0	1
09/16/2021 18:00	0.0	0	0	0	0	1
09/16/2021 19:00	0.0	0	0	0	0	1
09/16/2021 20:00	0.0	0	0	0	0	1
09/16/2021 21:00	0.0	0	0	0	0	1
09/16/2021 22:00	0.0	0	0	0	0	1
09/16/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/17/2021 00:00	0.0	0	0	0	0	1
09/17/2021 01:00	0.0	0	0	0	0	1
09/17/2021 02:00	0.0	0	0	0	0	1
09/17/2021 03:00	0.0	0	0	0	0	1
09/17/2021 04:00	0.0	0	0	0	0	1
09/17/2021 05:00	0.0	0	0	0	0	1
09/17/2021 06:00	0.0	0	0	0	0	1
09/17/2021 07:00	0.0	0	0	0	0	1
09/17/2021 08:00	0.0	0	0	0	0	1
09/17/2021 09:00	0.0	0	0	0	0	1
09/17/2021 10:00	0.0	0	0	0	0	1
09/17/2021 11:00	0.0	0	0	0	0	1
09/17/2021 12:00	0.0	0	0	0	0	1
09/17/2021 13:00	0.0	0	0	0	0	1
09/17/2021 14:00	0.0	0	0	0	0	1
09/17/2021 15:00	0.0	0	0	0	0	1
09/17/2021 16:00	0.0	0	0	0	0	1
09/17/2021 17:00	0.0	0	0	0	0	1
09/17/2021 18:00	0.0	0	0	0	0	1
09/17/2021 19:00	0.0	0	0	0	0	1
09/17/2021 20:00	0.0	0	0	0	0	1
09/17/2021 21:00	0.0	0	0	0	0	1
09/17/2021 22:00	0.0	0	0	0	0	1
09/17/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/18/2021 00:00	0.0	0	0	0	0	1
09/18/2021 01:00	0.0	0	0	0	0	1
09/18/2021 02:00	0.0	0	0	0	0	1
09/18/2021 03:00	0.0	0	0	0	0	1
09/18/2021 04:00	0.0	0	0	0	0	1
09/18/2021 05:00	0.0	0	0	0	0	1
09/18/2021 06:00	0.0	0	0	0	0	1
09/18/2021 07:00	0.0	0	0	0	0	1
09/18/2021 08:00	0.0	0	0	0	0	1
09/18/2021 09:00	0.0	0	0	0	0	1
09/18/2021 10:00	0.0	0	0	0	0	1
09/18/2021 11:00	0.0	0	0	0	0	1
09/18/2021 12:00	0.0	0	0	0	0	1
09/18/2021 13:00	0.0	0	0	0	0	1
09/18/2021 14:00	0.0	0	0	0	0	1
09/18/2021 15:00	0.0	0	0	0	0	1
09/18/2021 16:00	0.0	0	0	0	0	1
09/18/2021 17:00	0.0	0	0	0	0	1
09/18/2021 18:00	0.0	0	0	0	0	1
09/18/2021 19:00	0.0	0	0	0	0	1
09/18/2021 20:00	0.0	0	0	0	0	1
09/18/2021 21:00	0.0	0	0	0	0	1
09/18/2021 22:00	0.0	0	0	0	0	1
09/18/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/19/2021 00:00	0.0	0	0	0	0	1
09/19/2021 01:00	0.0	0	0	0	0	1
09/19/2021 02:00	0.0	0	0	0	0	1
09/19/2021 03:00	0.0	0	0	0	0	1
09/19/2021 04:00	0.0	0	0	0	0	1
09/19/2021 05:00	0.0	0	0	0	0	1
09/19/2021 06:00	0.0	0	0	0	0	1
09/19/2021 07:00	0.0	0	0	0	0	1
09/19/2021 08:00	0.0	0	0	0	0	1
09/19/2021 09:00	0.0	0	0	0	0	1
09/19/2021 10:00	0.0	0	0	0	0	1
09/19/2021 11:00	0.0	0	0	0	0	1
09/19/2021 12:00	0.0	0	0	0	0	1
09/19/2021 13:00	0.0	0	0	0	0	1
09/19/2021 14:00	0.0	0	0	0	0	1
09/19/2021 15:00	0.0	0	0	0	0	1
09/19/2021 16:00	0.0	0	0	0	0	1
09/19/2021 17:00	0.0	0	0	0	0	1
09/19/2021 18:00	0.0	0	0	0	0	1
09/19/2021 19:00	0.0	0	0	0	0	1
09/19/2021 20:00	0.0	0	0	0	0	1
09/19/2021 21:00	0.0	0	0	0	0	1
09/19/2021 22:00	0.0	0	0	0	0	1
09/19/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/20/2021 00:00	0.0	0	0	0	0	1
09/20/2021 01:00	0.0	0	0	0	0	1
09/20/2021 02:00	0.0	0	0	0	0	1
09/20/2021 03:00	0.0	0	0	0	0	1
09/20/2021 04:00	0.0	0	0	0	0	1
09/20/2021 05:00	0.0	0	0	0	0	1
09/20/2021 06:00	0.0	0	0	0	0	1
09/20/2021 07:00	0.0	0	0	0	0	1
09/20/2021 08:00	0.0	0	0	0	0	1
09/20/2021 09:00	0.0	0	0	0	0	1
09/20/2021 10:00	0.0	0	0	0	0	1
09/20/2021 11:00	0.0	0	0	0	0	1
09/20/2021 12:00	0.0	0	0	0	0	1
09/20/2021 13:00	0.0	0	0	0	0	1
09/20/2021 14:00	0.0	0	0	0	0	1
09/20/2021 15:00	0.0	0	0	0	0	1
09/20/2021 16:00	0.0	0	0	0	0	1
09/20/2021 17:00	0.0	0	0	0	0	1
09/20/2021 18:00	0.0	0	0	0	0	1
09/20/2021 19:00	0.0	0	0	0	0	1
09/20/2021 20:00	0.0	0	0	0	0	1
09/20/2021 21:00	0.0	0	0	0	0	1
09/20/2021 22:00	0.0	0	0	0	0	1
09/20/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/21/2021 00:00	0.0	0	0	0	0	1
09/21/2021 01:00	0.0	0	0	0	0	1
09/21/2021 02:00	0.0	0	0	0	0	1
09/21/2021 03:00	0.0	0	0	0	0	1
09/21/2021 04:00	0.0	0	0	0	0	1
09/21/2021 05:00	0.0	0	0	0	0	1
09/21/2021 06:00	0.0	0	0	0	0	1
09/21/2021 07:00	0.0	0	0	0	0	1
09/21/2021 08:00	0.0	0	0	0	0	1
09/21/2021 09:00	0.0	0	0	0	0	1
09/21/2021 10:00	0.0	0	0	0	0	1
09/21/2021 11:00	0.0	0	0	0	0	1
09/21/2021 12:00	0.0	0	0	0	0	1
09/21/2021 13:00	0.0	0	0	0	0	1
09/21/2021 14:00	0.0	0	0	0	0	1
09/21/2021 15:00	0.0	0	0	0	0	1
09/21/2021 16:00	0.0	0	0	0	0	1
09/21/2021 17:00	0.0	0	0	0	0	1
09/21/2021 18:00	0.0	0	0	0	0	1
09/21/2021 19:00	0.0	0	0	0	0	1
09/21/2021 20:00	0.0	0	0	0	0	1
09/21/2021 21:00	0.0	0	0	0	0	1
09/21/2021 22:00	0.0	0	0	0	0	1
09/21/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/22/2021 00:00	0.0	0	0	0	0	1
09/22/2021 01:00	0.0	0	0	0	0	1
09/22/2021 02:00	0.0	0	0	0	0	1
09/22/2021 03:00	0.0	0	0	0	0	1
09/22/2021 04:00	0.0	0	0	0	0	1
09/22/2021 05:00	0.0	0	0	0	0	1
09/22/2021 06:00	0.0	0	0	0	0	1
09/22/2021 07:00	0.0	0	0	0	0	1
09/22/2021 08:00	0.0	0	0	0	0	1
09/22/2021 09:00	0.0	0	0	0	0	1
09/22/2021 10:00	0.0	0	0	0	0	1
09/22/2021 11:00	0.0	0	0	0	0	1
09/22/2021 12:00	0.0	0	0	0	0	1
09/22/2021 13:00	0.0	0	0	0	0	1
09/22/2021 14:00	0.0	0	0	0	0	1
09/22/2021 15:00	0.0	0	0	0	0	1
09/22/2021 16:00	0.0	0	0	0	0	1
09/22/2021 17:00	0.0	0	0	0	0	1
09/22/2021 18:00	0.0	0	0	0	0	1
09/22/2021 19:00	0.0	0	0	0	0	1
09/22/2021 20:00	0.0	0	0	0	0	1
09/22/2021 21:00	0.0	0	0	0	0	1
09/22/2021 22:00	0.0	0	0	0	0	1
09/22/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/23/2021 00:00	0.0	0	0	0	0	1
09/23/2021 01:00	0.0	0	0	0	0	1
09/23/2021 02:00	0.0	0	0	0	0	1
09/23/2021 03:00	0.0	0	0	0	0	1
09/23/2021 04:00	0.0	0	0	0	0	1
09/23/2021 05:00	0.0	0	0	0	0	1
09/23/2021 06:00	0.0	0	0	0	0	1
09/23/2021 07:00	0.0	0	0	0	0	1
09/23/2021 08:00	0.0	0	0	0	0	1
09/23/2021 09:00	0.0	0	0	0	0	1
09/23/2021 10:00	0.0	0	0	0	0	1
09/23/2021 11:00	0.0	0	0	0	0	1
09/23/2021 12:00	0.0	0	0	0	0	1
09/23/2021 13:00	0.0	0	0	0	0	1
09/23/2021 14:00	0.0	0	0	0	0	1
09/23/2021 15:00	0.0	0	0	0	0	1
09/23/2021 16:00	0.0	0	0	0	0	1
09/23/2021 17:00	0.0	0	0	0	0	1
09/23/2021 18:00	0.0	0	0	0	0	1
09/23/2021 19:00	0.0	0	0	0	0	1
09/23/2021 20:00	0.0	0	0	0	0	1
09/23/2021 21:00	0.0	0	0	0	0	1
09/23/2021 22:00	0.0	0	0	0	0	1
09/23/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/24/2021 00:00	0.0	0	0	0	0	1
09/24/2021 01:00	0.0	0	0	0	0	1
09/24/2021 02:00	0.0	0	0	0	0	1
09/24/2021 03:00	0.0	0	0	0	0	1
09/24/2021 04:00	0.0	0	0	0	0	1
09/24/2021 05:00	0.0	0	0	0	0	1
09/24/2021 06:00	0.0	0	0	0	0	1
09/24/2021 07:00	0.0	0	0	0	0	1
09/24/2021 08:00	0.0	0	0	0	0	1
09/24/2021 09:00	0.0	0	0	0	0	1
09/24/2021 10:00	0.0	0	0	0	0	1
09/24/2021 11:00	0.0	0	0	0	0	1
09/24/2021 12:00	0.0	0	0	0	0	1
09/24/2021 13:00	0.0	0	0	0	0	1
09/24/2021 14:00	0.0	0	0	0	0	1
09/24/2021 15:00	0.0	0	0	0	0	1
09/24/2021 16:00	0.0	0	0	0	0	1
09/24/2021 17:00	0.0	0	0	0	0	1
09/24/2021 18:00	0.0	0	0	0	0	1
09/24/2021 19:00	0.0	0	0	0	0	1
09/24/2021 20:00	0.0	0	0	0	0	1
09/24/2021 21:00	0.0	0	0	0	0	1
09/24/2021 22:00	0.0	0	0	0	0	1
09/24/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/25/2021 00:00	0.0	0	0	0	0	1
09/25/2021 01:00	0.0	0	0	0	0	1
09/25/2021 02:00	0.0	0	0	0	0	1
09/25/2021 03:00	0.0	0	0	0	0	1
09/25/2021 04:00	0.0	0	0	0	0	1
09/25/2021 05:00	0.0	0	0	0	0	1
09/25/2021 06:00	0.0	0	0	0	0	1
09/25/2021 07:00	0.0	0	0	0	0	1
09/25/2021 08:00	0.0	0	0	0	0	1
09/25/2021 09:00	0.0	0	0	0	0	1
09/25/2021 10:00	0.0	0	0	0	0	1
09/25/2021 11:00	0.0	0	0	0	0	1
09/25/2021 12:00	0.0	0	0	0	0	1
09/25/2021 13:00	0.0	0	0	0	0	1
09/25/2021 14:00	0.0	0	0	0	0	1
09/25/2021 15:00	0.0	0	0	0	0	1
09/25/2021 16:00	0.0	0	0	0	0	1
09/25/2021 17:00	0.0	0	0	0	0	1
09/25/2021 18:00	0.0	0	0	0	0	1
09/25/2021 19:00	0.0	0	0	0	0	1
09/25/2021 20:00	0.0	0	0	0	0	1
09/25/2021 21:00	0.0	0	0	0	0	1
09/25/2021 22:00	25.7	0	0	0	1	0
09/25/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	25.7 #	0 #	0 #	0 #	1 #	22 #
Minimum:	0.0	0	0	0	0	0
Maximum:	25.7	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/26/2021 00:00	0.0	0	0	0	0	0
09/26/2021 01:00	0.0	0	0	0	0	0
09/26/2021 02:00	0.0	0	0	0	0	0
09/26/2021 03:00	0.0	0	0	0	0	0
09/26/2021 04:00	0.0	0	0	0	0	0
09/26/2021 05:00	0.0	0	0	0	0	0
09/26/2021 06:00	0.0	0	0	0	0	0
09/26/2021 07:00	0.0	0	0	0	0	0
09/26/2021 08:00	0.0	0	0	0	0	0
09/26/2021 09:00	0.0	0	0	0	0	0
09/26/2021 10:00	0.0	0	0	0	0	0
09/26/2021 11:00	0.0	0	0	0	0	0
09/26/2021 12:00	0.0	0	0	0	0	0
09/26/2021 13:00	0.0	0	0	0	0	0
09/26/2021 14:00	0.0	0	0	0	0	0
09/26/2021 15:00	0.0	0	0	0	0	0
09/26/2021 16:00	0.0	0	0	0	0	0
09/26/2021 17:00	0.0	0	0	0	0	0
09/26/2021 18:00	0.0	0	0	0	0	0
09/26/2021 19:00	0.0	0	0	0	0	0
09/26/2021 20:00	0.0	0	0	0	0	0
09/26/2021 21:00	0.0	0	0	0	0	0
09/26/2021 22:00	0.0	0	0	0	0	0
09/26/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/27/2021 00:00	0.0	0	0	0	0	0
09/27/2021 01:00	0.0	0	0	0	0	0
09/27/2021 02:00	0.0	0	0	0	0	0
09/27/2021 03:00	0.0	0	0	0	0	0
09/27/2021 04:00	0.0	0	0	0	0	0
09/27/2021 05:00	0.0	0	0	0	0	0
09/27/2021 06:00	0.0	0	0	0	0	0
09/27/2021 07:00	0.0	0	0	0	0	0
09/27/2021 08:00	0.0	0	0	0	0	0
09/27/2021 09:00	0.0	0	0	0	0	0
09/27/2021 10:00	0.0	0	0	0	0	0
09/27/2021 11:00	0.0	0	0	0	0	0
09/27/2021 12:00	0.0	0	0	0	0	0
09/27/2021 13:00	0.0	0	0	0	0	0
09/27/2021 14:00	0.0	0	0	0	0	0
09/27/2021 15:00	0.0	0	0	0	0	0
09/27/2021 16:00	0.0	0	0	0	0	0
09/27/2021 17:00	0.0	0	0	0	0	0
09/27/2021 18:00	0.0	0	0	0	0	0
09/27/2021 19:00	0.0	0	0	0	0	0
09/27/2021 20:00	0.0	0	0	0	0	0
09/27/2021 21:00	0.0	0	0	0	0	0
09/27/2021 22:00	0.0	0	0	0	0	0
09/27/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/28/2021 00:00	0.0	0	0	0	0	0
09/28/2021 01:00	0.0	0	0	0	0	0
09/28/2021 02:00	0.0	0	0	0	0	0
09/28/2021 03:00	0.0	0	0	0	0	0
09/28/2021 04:00	0.0	0	0	0	0	0
09/28/2021 05:00	0.0	0	0	0	0	0
09/28/2021 06:00	0.0	0	0	0	0	0
09/28/2021 07:00	0.0	0	0	0	0	0
09/28/2021 08:00	0.0	0	0	0	0	0
09/28/2021 09:00	0.0	0	0	0	0	0
09/28/2021 10:00	0.0	0	0	0	0	0
09/28/2021 11:00	0.0	0	0	0	0	0
09/28/2021 12:00	0.0	0	0	0	0	0
09/28/2021 13:00	0.0	0	0	0	0	0
09/28/2021 14:00	0.0	0	0	0	0	0
09/28/2021 15:00	0.0	0	0	0	0	0
09/28/2021 16:00	0.0	0	0	0	0	0
09/28/2021 17:00	0.0	0	0	0	0	0
09/28/2021 18:00	0.0	0	0	0	0	0
09/28/2021 19:00	0.0	0	0	0	0	0
09/28/2021 20:00	0.0	0	0	0	0	0
09/28/2021 21:00	0.0	0	0	0	0	0
09/28/2021 22:00	0.0	0	0	0	0	0
09/28/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/29/2021 00:00	0.0	0	0	0	0	0
09/29/2021 01:00	0.0	0	0	0	0	0
09/29/2021 02:00	0.0	0	0	0	0	0
09/29/2021 03:00	1,771.2	1	0	0	1	0
09/29/2021 04:00	0.0	0	0	0	0	0
09/29/2021 05:00	0.0	0	0	0	0	0
09/29/2021 06:00	0.0	0	0	0	0	0
09/29/2021 07:00	0.0	0	0	0	0	0
09/29/2021 08:00	1,180.6	1	0	0	0	0
09/29/2021 09:00	6,495.7	1	0	0	0	0
09/29/2021 10:00	0.0	0	0	0	0	1
09/29/2021 11:00	0.0	0	0	0	0	1
09/29/2021 12:00	0.0	0	0	0	0	1
09/29/2021 13:00	0.0	0	0	0	0	1
09/29/2021 14:00	0.0	0	0	0	0	1
09/29/2021 15:00	0.0	0	0	0	0	1
09/29/2021 16:00	0.0	0	0	0	0	1
09/29/2021 17:00	0.0	0	0	0	0	1
09/29/2021 18:00	0.0	0	0	0	0	1
09/29/2021 19:00	0.0	0	0	0	0	1
09/29/2021 20:00	0.0	0	0	0	0	1
09/29/2021 21:00	0.0	0	0	0	0	1
09/29/2021 22:00	0.0	0	0	0	0	1
09/29/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	9,447.5 #	3 #	0 #	0 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,495.7	1	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/30/2021 00:00	0.0	0	0	0	0	1
09/30/2021 01:00	0.0	0	0	0	0	1
09/30/2021 02:00	0.0	0	0	0	0	1
09/30/2021 03:00	0.0	0	0	0	0	1
09/30/2021 04:00	0.0	0	0	0	0	1
09/30/2021 05:00	0.0	0	0	0	0	1
09/30/2021 06:00	0.0	0	0	0	0	1
09/30/2021 07:00	0.0	0	0	0	0	1
09/30/2021 08:00	0.0	0	0	0	0	1
09/30/2021 09:00	0.0	0	0	0	0	1
09/30/2021 10:00	0.0	0	0	0	0	1
09/30/2021 11:00	0.0	0	0	0	0	1
09/30/2021 12:00	0.0	0	0	0	0	1
09/30/2021 13:00	0.0	0	0	0	0	1
09/30/2021 14:00	0.0	0	0	0	0	1
09/30/2021 15:00	0.0	0	0	0	0	1
09/30/2021 16:00	0.0	0	0	0	0	1
09/30/2021 17:00	0.0	0	0	0	0	1
09/30/2021 18:00	0.0	0	0	0	0	1
09/30/2021 19:00	0.0	0	0	0	0	1
09/30/2021 20:00	0.0	0	0	0	0	1
09/30/2021 21:00	0.0	0	0	0	0	1
09/30/2021 22:00	0.0	0	0	0	0	1
09/30/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:05 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/01/2021 00:00	0.0	0	0	0	0	0
07/01/2021 01:00	0.0	0	0	0	0	0
07/01/2021 02:00	0.0	0	0	0	0	0
07/01/2021 03:00	0.0	0	0	0	0	0
07/01/2021 04:00	0.0	0	0	0	0	0
07/01/2021 05:00	0.0	0	0	0	0	0
07/01/2021 06:00	0.0	0	0	0	0	0
07/01/2021 07:00	0.0	0	0	0	0	0
07/01/2021 08:00	0.0	0	0	0	0	0
07/01/2021 09:00	0.0	0	0	0	0	0
07/01/2021 10:00	0.0	0	0	0	0	0
07/01/2021 11:00	0.0	0	0	0	0	0
07/01/2021 12:00	0.0	0	0	0	0	0
07/01/2021 13:00	0.0	0	0	0	0	0
07/01/2021 14:00	0.0	0	0	0	0	0
07/01/2021 15:00	0.0	0	0	0	0	0
07/01/2021 16:00	0.0	0	0	0	0	0
07/01/2021 17:00	0.0	0	0	0	0	0
07/01/2021 18:00	0.0	0	0	0	0	0
07/01/2021 19:00	0.0	0	0	0	0	0
07/01/2021 20:00	0.0	0	0	0	0	0
07/01/2021 21:00	0.0	0	0	0	0	0
07/01/2021 22:00	0.0	0	0	0	0	0
07/01/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:05 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/02/2021 00:00	0.0	0	0	0	0	0
07/02/2021 01:00	0.0	0	0	0	0	0
07/02/2021 02:00	0.0	0	0	0	0	0
07/02/2021 03:00	0.0	0	0	0	0	0
07/02/2021 04:00	0.0	0	0	0	0	0
07/02/2021 05:00	0.0	0	0	0	0	0
07/02/2021 06:00	0.0	0	0	0	0	0
07/02/2021 07:00	0.0	0	0	0	0	0
07/02/2021 08:00	0.0	0	0	0	0	0
07/02/2021 09:00	0.0	0	0	0	0	0
07/02/2021 10:00	0.0	0	0	0	0	0
07/02/2021 11:00	0.0	0	0	0	0	0
07/02/2021 12:00	0.0	0	0	0	0	0
07/02/2021 13:00	0.0	0	0	0	0	0
07/02/2021 14:00	0.0	0	0	0	0	0
07/02/2021 15:00	0.0	0	0	0	0	0
07/02/2021 16:00	0.0	0	0	0	0	0
07/02/2021 17:00	0.0	0	0	0	0	0
07/02/2021 18:00	0.0	0	0	0	0	0
07/02/2021 19:00	0.0	0	0	0	0	0
07/02/2021 20:00	0.0	0	0	0	0	0
07/02/2021 21:00	0.0	0	0	0	0	0
07/02/2021 22:00	0.0	0	0	0	0	0
07/02/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:05 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/03/2021 00:00	0.0	0	0	0	0	0
07/03/2021 01:00	0.0	0	0	0	0	0
07/03/2021 02:00	0.0	0	0	0	0	0
07/03/2021 03:00	0.0	0	0	0	0	0
07/03/2021 04:00	0.0	0	0	0	0	0
07/03/2021 05:00	0.0	0	0	0	0	0
07/03/2021 06:00	0.0	0	0	0	0	0
07/03/2021 07:00	0.0	0	0	0	0	0
07/03/2021 08:00	0.0	0	0	0	0	0
07/03/2021 09:00	0.0	0	0	0	0	0
07/03/2021 10:00	0.0	0	0	0	0	0
07/03/2021 11:00	0.0	0	0	0	0	0
07/03/2021 12:00	0.0	0	0	0	0	0
07/03/2021 13:00	0.0	0	0	0	0	0
07/03/2021 14:00	0.0	0	0	0	0	0
07/03/2021 15:00	0.0	0	0	0	0	0
07/03/2021 16:00	0.0	0	0	0	0	0
07/03/2021 17:00	0.0	0	0	0	0	0
07/03/2021 18:00	0.0	0	0	0	0	0
07/03/2021 19:00	0.0	0	0	0	0	0
07/03/2021 20:00	0.0	0	0	0	0	0
07/03/2021 21:00	0.0	0	0	0	0	0
07/03/2021 22:00	0.0	0	0	0	0	0
07/03/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:05 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/04/2021 00:00	0.0	0	0	0	0	0
07/04/2021 01:00	0.0	0	0	0	0	0
07/04/2021 02:00	0.0	0	0	0	0	0
07/04/2021 03:00	0.0	0	0	0	0	0
07/04/2021 04:00	0.0	0	0	0	0	0
07/04/2021 05:00	0.0	0	0	0	0	0
07/04/2021 06:00	0.0	0	0	0	0	0
07/04/2021 07:00	0.0	0	0	0	0	0
07/04/2021 08:00	0.0	0	0	0	0	0
07/04/2021 09:00	0.0	0	0	0	0	0
07/04/2021 10:00	0.0	0	0	0	0	0
07/04/2021 11:00	0.0	0	0	0	0	0
07/04/2021 12:00	0.0	0	0	0	0	0
07/04/2021 13:00	0.0	0	0	0	0	0
07/04/2021 14:00	0.0	0	0	0	0	0
07/04/2021 15:00	0.0	0	0	0	0	0
07/04/2021 16:00	0.0	0	0	0	0	0
07/04/2021 17:00	0.0	0	0	0	0	0
07/04/2021 18:00	0.0	0	0	0	0	0
07/04/2021 19:00	0.0	0	0	0	0	0
07/04/2021 20:00	0.0	0	0	0	0	0
07/04/2021 21:00	0.0	0	0	0	0	0
07/04/2021 22:00	0.0	0	0	0	0	0
07/04/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:05 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/05/2021 00:00	0.0	0	0	0	0	0
07/05/2021 01:00	0.0	0	0	0	0	0
07/05/2021 02:00	0.0	0	0	0	0	0
07/05/2021 03:00	0.0	0	0	0	0	0
07/05/2021 04:00	0.0	0	0	0	0	0
07/05/2021 05:00	0.0	0	0	0	0	0
07/05/2021 06:00	0.0	0	0	0	0	0
07/05/2021 07:00	0.0	0	0	0	0	0
07/05/2021 08:00	0.0	0	0	0	0	0
07/05/2021 09:00	0.0	0	0	0	0	0
07/05/2021 10:00	0.0	0	0	0	0	0
07/05/2021 11:00	0.0	0	0	0	0	0
07/05/2021 12:00	0.0	0	0	0	0	0
07/05/2021 13:00	0.0	0	0	0	0	0
07/05/2021 14:00	0.0	0	0	0	0	0
07/05/2021 15:00	0.0	0	0	0	0	0
07/05/2021 16:00	0.0	0	0	0	0	0
07/05/2021 17:00	0.0	0	0	0	0	0
07/05/2021 18:00	0.0	0	0	0	0	0
07/05/2021 19:00	0.0	0	0	0	0	0
07/05/2021 20:00	0.0	0	0	0	0	0
07/05/2021 21:00	0.0	0	0	0	0	0
07/05/2021 22:00	0.0	0	0	0	0	0
07/05/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:05 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/06/2021 00:00	0.0	0	0	0	0	0
07/06/2021 01:00	0.0	0	0	0	0	0
07/06/2021 02:00	0.0	0	0	0	0	0
07/06/2021 03:00	0.0	0	0	0	0	0
07/06/2021 04:00	0.0	0	0	0	0	0
07/06/2021 05:00	0.0	0	0	0	0	0
07/06/2021 06:00	0.0	0	0	0	0	0
07/06/2021 07:00	0.0	0	0	0	0	0
07/06/2021 08:00	0.0	0	0	0	0	0
07/06/2021 09:00	0.0	0	0	0	0	0
07/06/2021 10:00	0.0	0	0	0	0	0
07/06/2021 11:00	0.0	0	0	0	0	0
07/06/2021 12:00	0.0	0	0	0	0	0
07/06/2021 13:00	0.0	0	0	0	0	0
07/06/2021 14:00	0.0	0	0	0	0	0
07/06/2021 15:00	0.0	0	0	0	0	0
07/06/2021 16:00	0.0	0	0	0	0	0
07/06/2021 17:00	0.0	0	0	0	0	0
07/06/2021 18:00	0.0	0	0	0	0	0
07/06/2021 19:00	0.0	0	0	0	0	0
07/06/2021 20:00	0.0	0	0	0	0	0
07/06/2021 21:00	0.0	0	0	0	0	0
07/06/2021 22:00	0.0	0	0	0	0	0
07/06/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:05 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/07/2021 00:00	0.0	0	0	0	0	0
07/07/2021 01:00	0.0	0	0	0	0	0
07/07/2021 02:00	0.0	0	0	0	0	0
07/07/2021 03:00	0.0	0	0	0	0	0
07/07/2021 04:00	0.0	0	0	0	0	0
07/07/2021 05:00	0.0	0	0	0	0	0
07/07/2021 06:00	0.0	0	0	0	0	0
07/07/2021 07:00	0.0	0	0	0	0	0
07/07/2021 08:00	0.0	0	0	0	0	0
07/07/2021 09:00	0.0	0	0	0	0	0
07/07/2021 10:00	0.0	0	0	0	0	0
07/07/2021 11:00	0.0	0	0	0	0	0
07/07/2021 12:00	0.0	0	0	0	0	0
07/07/2021 13:00	0.0	0	0	0	0	0
07/07/2021 14:00	0.0	0	0	0	0	0
07/07/2021 15:00	0.0	0	0	0	0	0
07/07/2021 16:00	0.0	0	0	0	0	0
07/07/2021 17:00	0.0	0	0	0	0	0
07/07/2021 18:00	0.0	0	0	0	0	0
07/07/2021 19:00	0.0	0	0	0	0	0
07/07/2021 20:00	0.0	0	0	0	0	0
07/07/2021 21:00	0.0	0	0	0	0	0
07/07/2021 22:00	0.0	0	0	0	0	0
07/07/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:05 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/08/2021 00:00	0.0	0	0	0	0	0
07/08/2021 01:00	0.0	0	0	0	0	0
07/08/2021 02:00	0.0	0	0	0	0	0
07/08/2021 03:00	0.0	0	0	0	0	0
07/08/2021 04:00	0.0	0	0	0	0	0
07/08/2021 05:00	0.0	0	0	0	0	0
07/08/2021 06:00	0.0	0	0	0	0	0
07/08/2021 07:00	0.0	0	0	0	0	0
07/08/2021 08:00	0.0	0	0	0	0	0
07/08/2021 09:00	0.0	0	0	0	0	0
07/08/2021 10:00	0.0	0	0	0	0	0
07/08/2021 11:00	0.0	0	0	0	0	0
07/08/2021 12:00	0.0	0	0	0	0	0
07/08/2021 13:00	0.0	0	0	0	0	0
07/08/2021 14:00	0.0	0	0	0	0	0
07/08/2021 15:00	0.0	0	0	0	0	0
07/08/2021 16:00	0.0	0	0	0	0	0
07/08/2021 17:00	0.0	0	0	0	0	0
07/08/2021 18:00	0.0	0	0	0	0	0
07/08/2021 19:00	0.0	0	0	0	0	0
07/08/2021 20:00	0.0	0	0	0	0	0
07/08/2021 21:00	0.0	0	0	0	0	0
07/08/2021 22:00	0.0	0	0	0	0	0
07/08/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:05 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/09/2021 00:00	0.0	0	0	0	0	0
07/09/2021 01:00	0.0	0	0	0	0	0
07/09/2021 02:00	0.0	0	0	0	0	0
07/09/2021 03:00	0.0	0	0	0	0	0
07/09/2021 04:00	0.0	0	0	0	0	0
07/09/2021 05:00	0.0	0	0	0	0	0
07/09/2021 06:00	0.0	0	0	0	0	0
07/09/2021 07:00	0.0	0	0	0	0	0
07/09/2021 08:00	0.0	0	0	0	0	0
07/09/2021 09:00	0.0	0	0	0	0	0
07/09/2021 10:00	0.0	0	0	0	0	0
07/09/2021 11:00	0.0	0	0	0	0	0
07/09/2021 12:00	0.0	0	0	0	0	0
07/09/2021 13:00	0.0	0	0	0	0	0
07/09/2021 14:00	0.0	0	0	0	0	0
07/09/2021 15:00	0.0	0	0	0	0	0
07/09/2021 16:00	0.0	0	0	0	0	0
07/09/2021 17:00	0.0	0	0	0	0	0
07/09/2021 18:00	0.0	0	0	0	0	0
07/09/2021 19:00	0.0	0	0	0	0	0
07/09/2021 20:00	0.0	0	0	0	0	0
07/09/2021 21:00	0.0	0	0	0	0	0
07/09/2021 22:00	0.0	0	0	0	0	0
07/09/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:05 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/10/2021 00:00	0.0	0	0	0	0	0
07/10/2021 01:00	0.0	0	0	0	0	0
07/10/2021 02:00	0.0	0	0	0	0	0
07/10/2021 03:00	0.0	0	0	0	0	0
07/10/2021 04:00	0.0	0	0	0	0	0
07/10/2021 05:00	0.0	0	0	0	0	0
07/10/2021 06:00	0.0	0	0	0	0	0
07/10/2021 07:00	0.0	0	0	0	0	0
07/10/2021 08:00	0.0	0	0	0	0	0
07/10/2021 09:00	0.0	0	0	0	0	0
07/10/2021 10:00	0.0	0	0	0	0	0
07/10/2021 11:00	0.0	0	0	0	0	0
07/10/2021 12:00	0.0	0	0	0	0	0
07/10/2021 13:00	27.5	1	0	0	0	0
07/10/2021 14:00	50.7	1	0	0	0	0
07/10/2021 15:00	23.6	1	0	0	0	0
07/10/2021 16:00	3.2	1	0	0	0	0
07/10/2021 17:00	0.0	0	0	0	0	1
07/10/2021 18:00	0.0	0	0	0	0	1
07/10/2021 19:00	0.0	0	0	0	0	1
07/10/2021 20:00	0.0	0	0	0	0	1
07/10/2021 21:00	0.0	0	0	0	0	1
07/10/2021 22:00	0.0	0	0	0	0	1
07/10/2021 23:00	0.7	0	0	0	1	0
Average/Sum#:	105.7 #	4 #	0 #	0 #	1 #	6 #
Minimum:	0.0	0	0	0	0	0
Maximum:	50.7	1	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:05 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/11/2021 00:00	0.0	0	0	0	0	0
07/11/2021 01:00	0.0	0	0	0	0	0
07/11/2021 02:00	0.0	0	0	0	0	0
07/11/2021 03:00	0.0	0	0	0	0	0
07/11/2021 04:00	0.0	0	0	0	0	0
07/11/2021 05:00	0.0	0	0	0	0	0
07/11/2021 06:00	0.0	0	0	0	0	0
07/11/2021 07:00	0.0	0	0	0	0	0
07/11/2021 08:00	0.0	0	0	0	0	0
07/11/2021 09:00	35.2	0	1	0	0	0
07/11/2021 10:00	18.0	0	1	0	0	0
07/11/2021 11:00	11.7	0	1	0	0	0
07/11/2021 12:00	0.0	0	0	0	0	1
07/11/2021 13:00	0.0	0	0	0	0	1
07/11/2021 14:00	0.0	0	0	0	0	1
07/11/2021 15:00	0.0	0	0	0	0	1
07/11/2021 16:00	0.0	0	0	0	0	1
07/11/2021 17:00	0.0	0	0	0	0	1
07/11/2021 18:00	0.0	0	0	0	0	1
07/11/2021 19:00	0.0	0	0	0	0	1
07/11/2021 20:00	0.0	0	0	0	0	1
07/11/2021 21:00	0.0	0	0	0	0	1
07/11/2021 22:00	0.0	0	0	0	0	1
07/11/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	64.9 #	0 #	3 #	0 #	0 #	12 #
Minimum:	0.0	0	0	0	0	0
Maximum:	35.2	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:05 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/12/2021 00:00	0.0	0	0	0	0	1
07/12/2021 01:00	0.4	0	0	0	1	0
07/12/2021 02:00	0.0	0	0	0	0	0
07/12/2021 03:00	0.0	0	0	0	0	0
07/12/2021 04:00	0.0	0	0	0	0	0
07/12/2021 05:00	0.0	0	0	0	0	0
07/12/2021 06:00	0.0	0	0	0	0	0
07/12/2021 07:00	0.0	0	0	0	0	0
07/12/2021 08:00	0.0	0	0	0	0	0
07/12/2021 09:00	0.0	0	0	0	0	0
07/12/2021 10:00	0.0	0	0	0	0	0
07/12/2021 11:00	0.0	0	0	0	0	0
07/12/2021 12:00	0.0	0	0	0	0	0
07/12/2021 13:00	0.0	0	0	0	0	0
07/12/2021 14:00	0.0	0	0	0	0	0
07/12/2021 15:00	11.4	0	1	0	0	0
07/12/2021 16:00	34.3	0	1	0	0	0
07/12/2021 17:00	0.0	0	0	0	0	1
07/12/2021 18:00	0.0	0	0	0	0	1
07/12/2021 19:00	0.0	0	0	0	0	1
07/12/2021 20:00	0.0	0	0	0	0	1
07/12/2021 21:00	0.0	0	0	0	0	1
07/12/2021 22:00	0.5	0	0	0	1	0
07/12/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	46.6 #	0 #	2 #	0 #	2 #	6 #
Minimum:	0.0	0	0	0	0	0
Maximum:	34.3	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:05 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/13/2021 00:00	0.0	0	0	0	0	0
07/13/2021 01:00	0.0	0	0	0	0	0
07/13/2021 02:00	0.0	0	0	0	0	0
07/13/2021 03:00	0.0	0	0	0	0	0
07/13/2021 04:00	0.0	0	0	0	0	0
07/13/2021 05:00	0.0	0	0	0	0	0
07/13/2021 06:00	0.0	0	0	0	0	0
07/13/2021 07:00	22.1	0	1	0	0	0
07/13/2021 08:00	8.2	0	1	0	0	0
07/13/2021 09:00	0.6	0	1	0	1	0
07/13/2021 10:00	0.0	0	0	0	0	0
07/13/2021 11:00	0.0	0	0	0	0	0
07/13/2021 12:00	7.6	0	1	0	0	0
07/13/2021 13:00	2.5	0	1	0	1	0
07/13/2021 14:00	0.1	0	1	0	0	0
07/13/2021 15:00	18.5	0	1	0	0	0
07/13/2021 16:00	10.2	0	1	0	0	0
07/13/2021 17:00	0.0	0	0	0	0	1
07/13/2021 18:00	0.0	0	0	0	0	1
07/13/2021 19:00	0.0	0	0	0	0	1
07/13/2021 20:00	0.0	0	0	0	0	1
07/13/2021 21:00	0.6	0	0	0	1	0
07/13/2021 22:00	0.0	0	0	0	0	0
07/13/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	70.4 #	0 #	8 #	0 #	3 #	4 #
Minimum:	0.0	0	0	0	0	0
Maximum:	22.1	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:05 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/14/2021 00:00	0.0	0	0	0	0	0
07/14/2021 01:00	0.0	0	0	0	0	0
07/14/2021 02:00	0.0	0	0	0	0	0
07/14/2021 03:00	6.8	0	0	1	0	0
07/14/2021 04:00	3.1	0	0	1	0	0
07/14/2021 05:00	0.0	0	0	0	0	1
07/14/2021 06:00	0.0	0	0	0	0	1
07/14/2021 07:00	0.0	0	0	0	0	1
07/14/2021 08:00	0.0	0	0	0	0	1
07/14/2021 09:00	0.0	0	0	0	0	1
07/14/2021 10:00	0.0	0	0	0	0	1
07/14/2021 11:00	0.0	0	0	0	0	1
07/14/2021 12:00	0.0	0	0	0	0	1
07/14/2021 13:00	0.0	0	0	0	0	1
07/14/2021 14:00	0.0	0	0	0	0	1
07/14/2021 15:00	0.0	0	0	0	0	1
07/14/2021 16:00	0.0	0	0	0	0	1
07/14/2021 17:00	0.0	0	0	0	0	1
07/14/2021 18:00	0.0	0	0	0	0	1
07/14/2021 19:00	0.0	0	0	0	0	1
07/14/2021 20:00	0.0	0	0	0	0	1
07/14/2021 21:00	0.0	0	0	0	0	1
07/14/2021 22:00	0.0	0	0	0	0	1
07/14/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	9.9 #	0 #	0 #	2 #	0 #	19 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6.8	0	0	1	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:05 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/15/2021 00:00	0.0	0	0	0	0	1
07/15/2021 01:00	0.0	0	0	0	0	1
07/15/2021 02:00	0.0	0	0	0	0	1
07/15/2021 03:00	0.0	0	0	0	0	1
07/15/2021 04:00	0.0	0	0	0	0	1
07/15/2021 05:00	0.0	0	0	0	0	1
07/15/2021 06:00	0.0	0	0	0	0	1
07/15/2021 07:00	0.0	0	0	0	0	1
07/15/2021 08:00	0.0	0	0	0	0	1
07/15/2021 09:00	0.0	0	0	0	0	1
07/15/2021 10:00	0.0	0	0	0	0	1
07/15/2021 11:00	0.0	0	0	0	0	1
07/15/2021 12:00	0.0	0	0	0	0	1
07/15/2021 13:00	0.0	0	0	0	0	1
07/15/2021 14:00	0.0	0	0	0	0	1
07/15/2021 15:00	0.0	0	0	0	0	1
07/15/2021 16:00	0.0	0	0	0	0	1
07/15/2021 17:00	0.0	0	0	0	0	1
07/15/2021 18:00	0.0	0	0	0	0	1
07/15/2021 19:00	0.0	0	0	0	0	1
07/15/2021 20:00	0.0	0	0	0	0	1
07/15/2021 21:00	0.0	0	0	0	0	1
07/15/2021 22:00	0.0	0	0	0	0	1
07/15/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:05 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/16/2021 00:00	0.0	0	0	0	0	1
07/16/2021 01:00	0.0	0	0	0	0	1
07/16/2021 02:00	0.0	0	0	0	0	1
07/16/2021 03:00	0.0	0	0	0	0	1
07/16/2021 04:00	0.0	0	0	0	0	1
07/16/2021 05:00	0.0	0	0	0	0	1
07/16/2021 06:00	0.0	0	0	0	0	1
07/16/2021 07:00	0.0	0	0	0	0	1
07/16/2021 08:00	0.0	0	0	0	0	1
07/16/2021 09:00	0.0	0	0	0	0	1
07/16/2021 10:00	0.0	0	0	0	0	1
07/16/2021 11:00	0.0	0	0	0	0	1
07/16/2021 12:00	0.0	0	0	0	0	1
07/16/2021 13:00	0.0	0	0	0	0	1
07/16/2021 14:00	0.0	0	0	0	0	1
07/16/2021 15:00	0.0	0	0	0	0	1
07/16/2021 16:00	0.0	0	0	0	0	1
07/16/2021 17:00	0.0	0	0	0	0	1
07/16/2021 18:00	0.0	0	0	0	0	1
07/16/2021 19:00	0.0	0	0	0	0	1
07/16/2021 20:00	0.0	0	0	0	0	1
07/16/2021 21:00	0.0	0	0	0	0	1
07/16/2021 22:00	0.0	0	0	0	0	1
07/16/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:05 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/17/2021 00:00	0.0	0	0	0	0	1
07/17/2021 01:00	0.0	0	0	0	0	1
07/17/2021 02:00	0.0	0	0	0	0	1
07/17/2021 03:00	0.0	0	0	0	0	1
07/17/2021 04:00	0.0	0	0	0	0	1
07/17/2021 05:00	0.0	0	0	0	0	1
07/17/2021 06:00	0.0	0	0	0	0	1
07/17/2021 07:00	0.0	0	0	0	0	1
07/17/2021 08:00	0.0	0	0	0	0	1
07/17/2021 09:00	0.0	0	0	0	0	1
07/17/2021 10:00	0.0	0	0	0	0	1
07/17/2021 11:00	0.0	0	0	0	0	1
07/17/2021 12:00	0.0	0	0	0	0	1
07/17/2021 13:00	0.0	0	0	0	0	1
07/17/2021 14:00	0.0	0	0	0	0	1
07/17/2021 15:00	0.0	0	0	0	0	1
07/17/2021 16:00	0.0	0	0	0	0	1
07/17/2021 17:00	0.0	0	0	0	0	1
07/17/2021 18:00	0.0	0	0	0	0	1
07/17/2021 19:00	0.0	0	0	0	0	1
07/17/2021 20:00	0.0	0	0	0	0	1
07/17/2021 21:00	0.0	0	0	0	0	1
07/17/2021 22:00	0.0	0	0	0	0	1
07/17/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:05 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/18/2021 00:00	0.0	0	0	0	0	1
07/18/2021 01:00	0.0	0	0	0	0	1
07/18/2021 02:00	0.0	0	0	0	0	1
07/18/2021 03:00	0.0	0	0	0	0	1
07/18/2021 04:00	0.0	0	0	0	0	1
07/18/2021 05:00	0.0	0	0	0	0	1
07/18/2021 06:00	0.0	0	0	0	0	1
07/18/2021 07:00	0.0	0	0	0	0	1
07/18/2021 08:00	0.0	0	0	0	0	1
07/18/2021 09:00	0.0	0	0	0	0	1
07/18/2021 10:00	0.0	0	0	0	0	1
07/18/2021 11:00	0.0	0	0	0	0	1
07/18/2021 12:00	0.0	0	0	0	0	1
07/18/2021 13:00	0.0	0	0	0	0	1
07/18/2021 14:00	0.0	0	0	0	0	1
07/18/2021 15:00	0.0	0	0	0	0	1
07/18/2021 16:00	0.0	0	0	0	0	1
07/18/2021 17:00	0.0	0	0	0	0	1
07/18/2021 18:00	0.0	0	0	0	0	1
07/18/2021 19:00	0.0	0	0	0	0	1
07/18/2021 20:00	0.0	0	0	0	0	1
07/18/2021 21:00	0.0	0	0	0	0	1
07/18/2021 22:00	0.0	0	0	0	0	1
07/18/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:05 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/19/2021 00:00	0.0	0	0	0	0	1
07/19/2021 01:00	0.0	0	0	0	0	1
07/19/2021 02:00	0.0	0	0	0	0	1
07/19/2021 03:00	0.0	0	0	0	0	1
07/19/2021 04:00	0.0	0	0	0	0	1
07/19/2021 05:00	0.0	0	0	0	0	1
07/19/2021 06:00	0.0	0	0	0	0	1
07/19/2021 07:00	0.0	0	0	0	0	1
07/19/2021 08:00	0.0	0	0	0	0	1
07/19/2021 09:00	0.0	0	0	0	0	1
07/19/2021 10:00	0.0	0	0	0	0	1
07/19/2021 11:00	0.0	0	0	0	0	1
07/19/2021 12:00	0.0	0	0	0	0	1
07/19/2021 13:00	0.0	0	0	0	0	1
07/19/2021 14:00	0.0	0	0	0	0	1
07/19/2021 15:00	0.0	0	0	0	0	1
07/19/2021 16:00	0.0	0	0	0	0	1
07/19/2021 17:00	0.0	0	0	0	0	1
07/19/2021 18:00	0.0	0	0	0	0	1
07/19/2021 19:00	0.0	0	0	0	0	1
07/19/2021 20:00	0.0	0	0	0	0	1
07/19/2021 21:00	0.0	0	0	0	0	1
07/19/2021 22:00	0.0	0	0	0	0	1
07/19/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:05 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/20/2021 00:00	0.0	0	0	0	0	1
07/20/2021 01:00	0.0	0	0	0	0	1
07/20/2021 02:00	0.0	0	0	0	0	1
07/20/2021 03:00	0.0	0	0	0	0	1
07/20/2021 04:00	0.0	0	0	0	0	1
07/20/2021 05:00	0.0	0	0	0	0	1
07/20/2021 06:00	0.0	0	0	0	0	1
07/20/2021 07:00	0.0	0	0	0	0	1
07/20/2021 08:00	0.0	0	0	0	0	1
07/20/2021 09:00	0.0	0	0	0	0	1
07/20/2021 10:00	0.0	0	0	0	0	1
07/20/2021 11:00	0.0	0	0	0	0	1
07/20/2021 12:00	0.0	0	0	0	0	1
07/20/2021 13:00	0.0	0	0	0	0	1
07/20/2021 14:00	0.0	0	0	0	0	1
07/20/2021 15:00	0.0	0	0	0	0	1
07/20/2021 16:00	0.0	0	0	0	0	1
07/20/2021 17:00	0.0	0	0	0	0	1
07/20/2021 18:00	0.0	0	0	0	0	1
07/20/2021 19:00	0.0	0	0	0	0	1
07/20/2021 20:00	0.0	0	0	0	0	1
07/20/2021 21:00	0.0	0	0	0	0	1
07/20/2021 22:00	0.0	0	0	0	0	1
07/20/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:05 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/21/2021 00:00	0.0	0	0	0	0	1
07/21/2021 01:00	0.0	0	0	0	0	1
07/21/2021 02:00	0.0	0	0	0	0	1
07/21/2021 03:00	0.0	0	0	0	0	1
07/21/2021 04:00	0.0	0	0	0	0	1
07/21/2021 05:00	0.0	0	0	0	0	1
07/21/2021 06:00	0.0	0	0	0	0	1
07/21/2021 07:00	0.0	0	0	0	0	1
07/21/2021 08:00	0.0	0	0	0	0	1
07/21/2021 09:00	0.0	0	0	0	0	1
07/21/2021 10:00	0.0	0	0	0	0	1
07/21/2021 11:00	0.0	0	0	0	0	1
07/21/2021 12:00	0.0	0	0	0	0	1
07/21/2021 13:00	0.0	0	0	0	0	1
07/21/2021 14:00	0.0	0	0	0	0	1
07/21/2021 15:00	0.0	0	0	0	0	1
07/21/2021 16:00	0.0	0	0	0	0	1
07/21/2021 17:00	0.0	0	0	0	0	1
07/21/2021 18:00	0.0	0	0	0	0	1
07/21/2021 19:00	0.0	0	0	0	0	1
07/21/2021 20:00	0.0	0	0	0	0	1
07/21/2021 21:00	0.0	0	0	0	0	1
07/21/2021 22:00	0.0	0	0	0	0	1
07/21/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:05 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/22/2021 00:00	0.0	0	0	0	0	1
07/22/2021 01:00	0.0	0	0	0	0	1
07/22/2021 02:00	0.0	0	0	0	0	1
07/22/2021 03:00	0.0	0	0	0	0	1
07/22/2021 04:00	0.0	0	0	0	0	1
07/22/2021 05:00	0.0	0	0	0	0	1
07/22/2021 06:00	0.0	0	0	0	0	1
07/22/2021 07:00	0.0	0	0	0	0	1
07/22/2021 08:00	0.0	0	0	0	0	1
07/22/2021 09:00	0.0	0	0	0	0	1
07/22/2021 10:00	0.0	0	0	0	0	1
07/22/2021 11:00	0.0	0	0	0	0	1
07/22/2021 12:00	0.0	0	0	0	0	1
07/22/2021 13:00	0.0	0	0	0	0	1
07/22/2021 14:00	0.0	0	0	0	0	1
07/22/2021 15:00	0.0	0	0	0	0	1
07/22/2021 16:00	0.0	0	0	0	0	1
07/22/2021 17:00	0.0	0	0	0	0	1
07/22/2021 18:00	0.0	0	0	0	0	1
07/22/2021 19:00	0.0	0	0	0	0	1
07/22/2021 20:00	0.0	0	0	0	0	1
07/22/2021 21:00	0.0	0	0	0	0	1
07/22/2021 22:00	0.0	0	0	0	0	1
07/22/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:05 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/23/2021 00:00	0.0	0	0	0	0	1
07/23/2021 01:00	0.0	0	0	0	0	1
07/23/2021 02:00	0.0	0	0	0	0	1
07/23/2021 03:00	0.0	0	0	0	0	1
07/23/2021 04:00	0.0	0	0	0	0	1
07/23/2021 05:00	0.0	0	0	0	0	1
07/23/2021 06:00	0.0	0	0	0	0	1
07/23/2021 07:00	0.0	0	0	0	0	1
07/23/2021 08:00	0.0	0	0	0	0	1
07/23/2021 09:00	0.0	0	0	0	0	1
07/23/2021 10:00	0.0	0	0	0	0	1
07/23/2021 11:00	0.0	0	0	0	0	1
07/23/2021 12:00	0.0	0	0	0	0	1
07/23/2021 13:00	0.0	0	0	0	0	1
07/23/2021 14:00	0.0	0	0	0	0	1
07/23/2021 15:00	0.0	0	0	0	0	1
07/23/2021 16:00	0.0	0	0	0	0	1
07/23/2021 17:00	0.0	0	0	0	0	1
07/23/2021 18:00	0.0	0	0	0	0	1
07/23/2021 19:00	0.0	0	0	0	0	1
07/23/2021 20:00	0.0	0	0	0	0	1
07/23/2021 21:00	0.0	0	0	0	0	1
07/23/2021 22:00	0.0	0	0	0	0	1
07/23/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:05 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/24/2021 00:00	0.0	0	0	0	0	1
07/24/2021 01:00	0.0	0	0	0	0	1
07/24/2021 02:00	0.0	0	0	0	0	1
07/24/2021 03:00	0.0	0	0	0	0	1
07/24/2021 04:00	0.0	0	0	0	0	1
07/24/2021 05:00	0.0	0	0	0	0	1
07/24/2021 06:00	0.0	0	0	0	0	1
07/24/2021 07:00	0.0	0	0	0	0	1
07/24/2021 08:00	0.0	0	0	0	0	1
07/24/2021 09:00	0.0	0	0	0	0	1
07/24/2021 10:00	0.0	0	0	0	0	1
07/24/2021 11:00	0.0	0	0	0	0	1
07/24/2021 12:00	0.0	0	0	0	0	1
07/24/2021 13:00	0.0	0	0	0	0	1
07/24/2021 14:00	0.0	0	0	0	0	1
07/24/2021 15:00	0.0	0	0	0	0	1
07/24/2021 16:00	0.0	0	0	0	0	1
07/24/2021 17:00	0.0	0	0	0	0	1
07/24/2021 18:00	0.0	0	0	0	0	1
07/24/2021 19:00	0.0	0	0	0	0	1
07/24/2021 20:00	0.0	0	0	0	0	1
07/24/2021 21:00	0.0	0	0	0	0	1
07/24/2021 22:00	0.0	0	0	0	0	1
07/24/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:05 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/25/2021 00:00	0.0	0	0	0	0	1
07/25/2021 01:00	0.0	0	0	0	0	1
07/25/2021 02:00	0.0	0	0	0	0	1
07/25/2021 03:00	0.0	0	0	0	0	1
07/25/2021 04:00	0.0	0	0	0	0	1
07/25/2021 05:00	0.0	0	0	0	0	1
07/25/2021 06:00	0.0	0	0	0	0	1
07/25/2021 07:00	0.0	0	0	0	0	1
07/25/2021 08:00	0.0	0	0	0	0	1
07/25/2021 09:00	0.0	0	0	0	0	1
07/25/2021 10:00	0.0	0	0	0	0	1
07/25/2021 11:00	0.0	0	0	0	0	1
07/25/2021 12:00	0.0	0	0	0	0	1
07/25/2021 13:00	0.0	0	0	0	0	1
07/25/2021 14:00	0.0	0	0	0	0	1
07/25/2021 15:00	0.0	0	0	0	0	1
07/25/2021 16:00	0.0	0	0	0	0	1
07/25/2021 17:00	0.0	0	0	0	0	1
07/25/2021 18:00	0.0	0	0	0	0	1
07/25/2021 19:00	0.0	0	0	0	0	1
07/25/2021 20:00	0.0	0	0	0	0	1
07/25/2021 21:00	0.0	0	0	0	0	1
07/25/2021 22:00	0.0	0	0	0	0	1
07/25/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:05 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/26/2021 00:00	0.0	0	0	0	0	1
07/26/2021 01:00	0.0	0	0	0	0	1
07/26/2021 02:00	0.0	0	0	0	0	1
07/26/2021 03:00	0.0	0	0	0	0	1
07/26/2021 04:00	0.0	0	0	0	0	1
07/26/2021 05:00	0.0	0	0	0	0	1
07/26/2021 06:00	0.0	0	0	0	0	1
07/26/2021 07:00	0.0	0	0	0	0	1
07/26/2021 08:00	0.0	0	0	0	0	1
07/26/2021 09:00	0.0	0	0	0	0	1
07/26/2021 10:00	0.0	0	0	0	0	1
07/26/2021 11:00	0.0	0	0	0	0	1
07/26/2021 12:00	0.0	0	0	0	0	1
07/26/2021 13:00	0.0	0	0	0	0	1
07/26/2021 14:00	0.0	0	0	0	0	1
07/26/2021 15:00	0.0	0	0	0	0	1
07/26/2021 16:00	0.0	0	0	0	0	1
07/26/2021 17:00	0.0	0	0	0	0	1
07/26/2021 18:00	0.0	0	0	0	0	1
07/26/2021 19:00	0.0	0	0	0	0	1
07/26/2021 20:00	0.0	0	0	0	0	1
07/26/2021 21:00	0.0	0	0	0	0	1
07/26/2021 22:00	0.0	0	0	0	0	1
07/26/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:05 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/27/2021 00:00	0.0	0	0	0	0	1
07/27/2021 01:00	0.0	0	0	0	0	1
07/27/2021 02:00	0.0	0	0	0	0	1
07/27/2021 03:00	0.0	0	0	0	0	1
07/27/2021 04:00	0.0	0	0	0	0	1
07/27/2021 05:00	0.0	0	0	0	0	1
07/27/2021 06:00	0.0	0	0	0	0	1
07/27/2021 07:00	0.0	0	0	0	0	1
07/27/2021 08:00	0.0	0	0	0	0	1
07/27/2021 09:00	0.0	0	0	0	0	1
07/27/2021 10:00	0.0	0	0	0	0	1
07/27/2021 11:00	0.0	0	0	0	0	1
07/27/2021 12:00	0.0	0	0	0	0	1
07/27/2021 13:00	0.0	0	0	0	0	1
07/27/2021 14:00	0.0	0	0	0	0	1
07/27/2021 15:00	0.0	0	0	0	0	1
07/27/2021 16:00	0.0	0	0	0	0	1
07/27/2021 17:00	0.0	0	0	0	0	1
07/27/2021 18:00	0.0	0	0	0	0	1
07/27/2021 19:00	0.0	0	0	0	0	1
07/27/2021 20:00	0.0	0	0	0	0	1
07/27/2021 21:00	0.0	0	0	0	0	1
07/27/2021 22:00	0.0	0	0	0	0	1
07/27/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:05 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/28/2021 00:00	0.0	0	0	0	0	1
07/28/2021 01:00	0.0	0	0	0	0	1
07/28/2021 02:00	0.0	0	0	0	0	1
07/28/2021 03:00	0.0	0	0	0	0	1
07/28/2021 04:00	0.0	0	0	0	0	1
07/28/2021 05:00	0.0	0	0	0	0	1
07/28/2021 06:00	0.0	0	0	0	0	1
07/28/2021 07:00	0.0	0	0	0	0	1
07/28/2021 08:00	0.0	0	0	0	0	1
07/28/2021 09:00	0.0	0	0	0	0	1
07/28/2021 10:00	0.0	0	0	0	0	1
07/28/2021 11:00	0.0	0	0	0	0	1
07/28/2021 12:00	0.0	0	0	0	0	1
07/28/2021 13:00	0.0	0	0	0	0	1
07/28/2021 14:00	0.0	0	0	0	0	1
07/28/2021 15:00	0.0	0	0	0	0	1
07/28/2021 16:00	0.0	0	0	0	0	1
07/28/2021 17:00	0.0	0	0	0	0	1
07/28/2021 18:00	0.0	0	0	0	0	1
07/28/2021 19:00	0.0	0	0	0	0	1
07/28/2021 20:00	0.0	0	0	0	0	1
07/28/2021 21:00	0.0	0	0	0	0	1
07/28/2021 22:00	0.0	0	0	0	0	1
07/28/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:05 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/29/2021 00:00	0.0	0	0	0	0	1
07/29/2021 01:00	0.0	0	0	0	0	1
07/29/2021 02:00	0.0	0	0	0	0	1
07/29/2021 03:00	0.0	0	0	0	0	1
07/29/2021 04:00	0.0	0	0	0	0	1
07/29/2021 05:00	0.0	0	0	0	0	1
07/29/2021 06:00	0.0	0	0	0	0	1
07/29/2021 07:00	0.0	0	0	0	0	1
07/29/2021 08:00	0.0	0	0	0	0	1
07/29/2021 09:00	0.0	0	0	0	0	1
07/29/2021 10:00	0.0	0	0	0	0	1
07/29/2021 11:00	0.0	0	0	0	0	1
07/29/2021 12:00	0.0	0	0	0	0	1
07/29/2021 13:00	0.0	0	0	0	0	1
07/29/2021 14:00	0.0	0	0	0	0	1
07/29/2021 15:00	0.0	0	0	0	0	1
07/29/2021 16:00	0.0	0	0	0	0	1
07/29/2021 17:00	0.0	0	0	0	0	1
07/29/2021 18:00	0.0	0	0	0	0	1
07/29/2021 19:00	0.0	0	0	0	0	1
07/29/2021 20:00	0.0	0	0	0	0	1
07/29/2021 21:00	0.0	0	0	0	0	1
07/29/2021 22:00	0.0	0	0	0	0	1
07/29/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:05 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/30/2021 00:00	0.0	0	0	0	0	1
07/30/2021 01:00	0.0	0	0	0	0	1
07/30/2021 02:00	0.0	0	0	0	0	1
07/30/2021 03:00	0.0	0	0	0	0	1
07/30/2021 04:00	0.0	0	0	0	0	1
07/30/2021 05:00	0.0	0	0	0	0	1
07/30/2021 06:00	0.0	0	0	0	0	1
07/30/2021 07:00	0.0	0	0	0	0	1
07/30/2021 08:00	0.0	0	0	0	0	1
07/30/2021 09:00	0.0	0	0	0	0	1
07/30/2021 10:00	0.0	0	0	0	0	1
07/30/2021 11:00	0.0	0	0	0	0	1
07/30/2021 12:00	0.0	0	0	0	0	1
07/30/2021 13:00	0.0	0	0	0	0	1
07/30/2021 14:00	0.0	0	0	0	0	1
07/30/2021 15:00	0.0	0	0	0	0	1
07/30/2021 16:00	0.0	0	0	0	0	1
07/30/2021 17:00	0.0	0	0	0	0	1
07/30/2021 18:00	0.0	0	0	0	0	1
07/30/2021 19:00	0.0	0	0	0	0	1
07/30/2021 20:00	0.0	0	0	0	0	1
07/30/2021 21:00	0.0	0	0	0	0	1
07/30/2021 22:00	0.0	0	0	0	0	1
07/30/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:05 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/31/2021 00:00	0.0	0	0	0	0	1
07/31/2021 01:00	0.0	0	0	0	0	1
07/31/2021 02:00	0.0	0	0	0	0	1
07/31/2021 03:00	0.0	0	0	0	0	1
07/31/2021 04:00	0.0	0	0	0	0	1
07/31/2021 05:00	0.0	0	0	0	0	1
07/31/2021 06:00	0.0	0	0	0	0	1
07/31/2021 07:00	0.0	0	0	0	0	1
07/31/2021 08:00	0.0	0	0	0	0	1
07/31/2021 09:00	0.0	0	0	0	0	1
07/31/2021 10:00	0.0	0	0	0	0	1
07/31/2021 11:00	0.0	0	0	0	0	1
07/31/2021 12:00	0.0	0	0	0	0	1
07/31/2021 13:00	0.0	0	0	0	0	1
07/31/2021 14:00	0.0	0	0	0	0	1
07/31/2021 15:00	0.0	0	0	0	0	1
07/31/2021 16:00	0.0	0	0	0	0	1
07/31/2021 17:00	0.0	0	0	0	0	1
07/31/2021 18:00	0.0	0	0	0	0	1
07/31/2021 19:00	0.0	0	0	0	0	1
07/31/2021 20:00	0.0	0	0	0	0	1
07/31/2021 21:00	0.0	0	0	0	0	1
07/31/2021 22:00	0.0	0	0	0	0	1
07/31/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:05 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/01/2021 00:00	0.0	0	0	0	0	1
08/01/2021 01:00	0.0	0	0	0	0	1
08/01/2021 02:00	0.0	0	0	0	0	1
08/01/2021 03:00	0.0	0	0	0	0	1
08/01/2021 04:00	0.0	0	0	0	0	1
08/01/2021 05:00	0.0	0	0	0	0	1
08/01/2021 06:00	0.0	0	0	0	0	1
08/01/2021 07:00	0.0	0	0	0	0	1
08/01/2021 08:00	0.0	0	0	0	0	1
08/01/2021 09:00	0.0	0	0	0	0	1
08/01/2021 10:00	0.0	0	0	0	0	1
08/01/2021 11:00	0.0	0	0	0	0	1
08/01/2021 12:00	0.0	0	0	0	0	1
08/01/2021 13:00	0.0	0	0	0	0	1
08/01/2021 14:00	0.0	0	0	0	0	1
08/01/2021 15:00	0.0	0	0	0	0	1
08/01/2021 16:00	0.0	0	0	0	0	1
08/01/2021 17:00	0.0	0	0	0	0	1
08/01/2021 18:00	0.0	0	0	0	0	1
08/01/2021 19:00	0.0	0	0	0	0	1
08/01/2021 20:00	0.0	0	0	0	0	1
08/01/2021 21:00	0.0	0	0	0	0	1
08/01/2021 22:00	0.0	0	0	0	0	1
08/01/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:05 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/02/2021 00:00	0.0	0	0	0	0	1
08/02/2021 01:00	0.0	0	0	0	0	1
08/02/2021 02:00	0.0	0	0	0	0	1
08/02/2021 03:00	0.0	0	0	0	0	1
08/02/2021 04:00	0.0	0	0	0	0	1
08/02/2021 05:00	0.0	0	0	0	0	1
08/02/2021 06:00	0.0	0	0	0	0	1
08/02/2021 07:00	0.0	0	0	0	0	1
08/02/2021 08:00	0.0	0	0	0	0	1
08/02/2021 09:00	0.0	0	0	0	0	1
08/02/2021 10:00	0.0	0	0	0	0	1
08/02/2021 11:00	0.0	0	0	0	0	1
08/02/2021 12:00	0.0	0	0	0	0	1
08/02/2021 13:00	0.0	0	0	0	0	1
08/02/2021 14:00	0.0	0	0	0	0	1
08/02/2021 15:00	0.0	0	0	0	0	1
08/02/2021 16:00	0.0	0	0	0	0	1
08/02/2021 17:00	0.0	0	0	0	0	1
08/02/2021 18:00	0.0	0	0	0	0	1
08/02/2021 19:00	0.0	0	0	0	0	1
08/02/2021 20:00	0.0	0	0	0	0	1
08/02/2021 21:00	0.0	0	0	0	0	1
08/02/2021 22:00	0.0	0	0	0	0	1
08/02/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:05 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/03/2021 00:00	0.0	0	0	0	0	1
08/03/2021 01:00	0.0	0	0	0	0	1
08/03/2021 02:00	0.0	0	0	0	0	1
08/03/2021 03:00	0.0	0	0	0	0	1
08/03/2021 04:00	0.0	0	0	0	0	1
08/03/2021 05:00	0.0	0	0	0	0	1
08/03/2021 06:00	0.0	0	0	0	0	1
08/03/2021 07:00	0.0	0	0	0	0	1
08/03/2021 08:00	0.0	0	0	0	0	1
08/03/2021 09:00	0.0	0	0	0	0	1
08/03/2021 10:00	0.0	0	0	0	0	1
08/03/2021 11:00	0.0	0	0	0	0	1
08/03/2021 12:00	0.0	0	0	0	0	1
08/03/2021 13:00	0.0	0	0	0	0	1
08/03/2021 14:00	0.0	0	0	0	0	1
08/03/2021 15:00	0.0	0	0	0	0	1
08/03/2021 16:00	0.0	0	0	0	0	1
08/03/2021 17:00	0.0	0	0	0	0	1
08/03/2021 18:00	0.0	0	0	0	0	1
08/03/2021 19:00	0.0	0	0	0	0	1
08/03/2021 20:00	0.0	0	0	0	0	1
08/03/2021 21:00	0.0	0	0	0	0	1
08/03/2021 22:00	0.0	0	0	0	0	1
08/03/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:05 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/04/2021 00:00	0.0	0	0	0	0	1
08/04/2021 01:00	0.0	0	0	0	0	1
08/04/2021 02:00	0.0	0	0	0	0	1
08/04/2021 03:00	0.0	0	0	0	0	1
08/04/2021 04:00	0.0	0	0	0	0	1
08/04/2021 05:00	0.0	0	0	0	0	1
08/04/2021 06:00	0.0	0	0	0	0	1
08/04/2021 07:00	0.0	0	0	0	0	1
08/04/2021 08:00	0.0	0	0	0	0	1
08/04/2021 09:00	0.0	0	0	0	0	1
08/04/2021 10:00	0.0	0	0	0	0	1
08/04/2021 11:00	0.0	0	0	0	0	1
08/04/2021 12:00	0.0	0	0	0	0	1
08/04/2021 13:00	0.0	0	0	0	0	1
08/04/2021 14:00	0.0	0	0	0	0	1
08/04/2021 15:00	0.0	0	0	0	0	1
08/04/2021 16:00	0.0	0	0	0	0	1
08/04/2021 17:00	0.0	0	0	0	0	1
08/04/2021 18:00	0.0	0	0	0	0	1
08/04/2021 19:00	0.0	0	0	0	0	1
08/04/2021 20:00	0.0	0	0	0	0	1
08/04/2021 21:00	0.0	0	0	0	0	1
08/04/2021 22:00	0.0	0	0	0	0	1
08/04/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:05 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/05/2021 00:00	0.0	0	0	0	0	1
08/05/2021 01:00	0.0	0	0	0	0	1
08/05/2021 02:00	0.0	0	0	0	0	1
08/05/2021 03:00	0.0	0	0	0	0	1
08/05/2021 04:00	0.0	0	0	0	0	1
08/05/2021 05:00	0.0	0	0	0	0	1
08/05/2021 06:00	0.0	0	0	0	0	1
08/05/2021 07:00	0.0	0	0	0	0	1
08/05/2021 08:00	0.0	0	0	0	0	1
08/05/2021 09:00	0.0	0	0	0	0	1
08/05/2021 10:00	0.0	0	0	0	0	1
08/05/2021 11:00	0.0	0	0	0	0	1
08/05/2021 12:00	0.0	0	0	0	0	1
08/05/2021 13:00	0.0	0	0	0	0	1
08/05/2021 14:00	0.0	0	0	0	0	1
08/05/2021 15:00	0.0	0	0	0	0	1
08/05/2021 16:00	0.0	0	0	0	0	1
08/05/2021 17:00	0.0	0	0	0	0	1
08/05/2021 18:00	0.0	0	0	0	0	1
08/05/2021 19:00	0.0	0	0	0	0	1
08/05/2021 20:00	0.0	0	0	0	0	1
08/05/2021 21:00	0.0	0	0	0	0	1
08/05/2021 22:00	0.0	0	0	0	0	1
08/05/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:05 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/06/2021 00:00	0.0	0	0	0	0	1
08/06/2021 01:00	0.0	0	0	0	0	1
08/06/2021 02:00	0.0	0	0	0	0	1
08/06/2021 03:00	0.0	0	0	0	0	1
08/06/2021 04:00	0.0	0	0	0	0	1
08/06/2021 05:00	0.0	0	0	0	0	1
08/06/2021 06:00	0.0	0	0	0	0	1
08/06/2021 07:00	0.0	0	0	0	0	1
08/06/2021 08:00	0.0	0	0	0	0	1
08/06/2021 09:00	0.0	0	0	0	0	1
08/06/2021 10:00	0.0	0	0	0	0	1
08/06/2021 11:00	0.0	0	0	0	0	1
08/06/2021 12:00	0.0	0	0	0	0	1
08/06/2021 13:00	0.0	0	0	0	0	1
08/06/2021 14:00	0.0	0	0	0	0	1
08/06/2021 15:00	0.0	0	0	0	0	1
08/06/2021 16:00	0.0	0	0	0	0	1
08/06/2021 17:00	0.0	0	0	0	0	1
08/06/2021 18:00	0.0	0	0	0	0	1
08/06/2021 19:00	0.0	0	0	0	0	1
08/06/2021 20:00	0.0	0	0	0	0	1
08/06/2021 21:00	0.0	0	0	0	0	1
08/06/2021 22:00	0.0	0	0	0	0	1
08/06/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:05 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/07/2021 00:00	0.0	0	0	0	0	1
08/07/2021 01:00	0.0	0	0	0	0	1
08/07/2021 02:00	0.0	0	0	0	0	1
08/07/2021 03:00	0.8	0	0	0	1	0
08/07/2021 04:00	0.0	0	0	0	0	0
08/07/2021 05:00	0.0	0	0	0	0	0
08/07/2021 06:00	0.0	0	0	0	0	0
08/07/2021 07:00	0.0	0	0	0	0	0
08/07/2021 08:00	0.0	0	0	0	0	0
08/07/2021 09:00	0.0	0	0	0	0	0
08/07/2021 10:00	0.0	0	0	0	0	0
08/07/2021 11:00	0.0	0	0	0	0	0
08/07/2021 12:00	0.0	0	0	0	0	0
08/07/2021 13:00	2.1	0	1	0	0	0
08/07/2021 14:00	42.8	0	1	0	0	0
08/07/2021 15:00	0.0	0	0	0	0	1
08/07/2021 16:00	0.0	0	0	0	0	1
08/07/2021 17:00	0.0	0	0	0	0	1
08/07/2021 18:00	0.0	0	0	0	0	1
08/07/2021 19:00	0.0	0	0	0	0	1
08/07/2021 20:00	0.0	0	0	0	0	1
08/07/2021 21:00	0.0	0	0	0	0	1
08/07/2021 22:00	0.0	0	0	0	0	1
08/07/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	45.7 #	0 #	2 #	0 #	1 #	12 #
Minimum:	0.0	0	0	0	0	0
Maximum:	42.8	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:05 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/08/2021 00:00	0.0	0	0	0	0	1
08/08/2021 01:00	0.0	0	0	0	0	1
08/08/2021 02:00	0.0	0	0	0	0	1
08/08/2021 03:00	0.0	0	0	0	0	1
08/08/2021 04:00	0.7	0	0	0	1	0
08/08/2021 05:00	0.0	0	0	0	0	0
08/08/2021 06:00	0.0	0	0	0	0	0
08/08/2021 07:00	0.0	0	0	0	0	0
08/08/2021 08:00	0.0	0	0	0	0	0
08/08/2021 09:00	0.0	0	0	0	0	0
08/08/2021 10:00	0.0	0	0	0	0	0
08/08/2021 11:00	0.0	0	0	0	0	0
08/08/2021 12:00	0.0	0	0	0	0	0
08/08/2021 13:00	0.0	0	0	0	0	0
08/08/2021 14:00	1.7	0	1	0	0	0
08/08/2021 15:00	49.9	0	1	0	0	0
08/08/2021 16:00	0.0	0	0	0	0	1
08/08/2021 17:00	0.0	0	0	0	0	1
08/08/2021 18:00	0.0	0	0	0	0	1
08/08/2021 19:00	0.0	0	0	0	0	1
08/08/2021 20:00	0.0	0	0	0	0	1
08/08/2021 21:00	0.0	0	0	0	0	1
08/08/2021 22:00	0.0	0	0	0	0	1
08/08/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	52.3 #	0 #	2 #	0 #	1 #	12 #
Minimum:	0.0	0	0	0	0	0
Maximum:	49.9	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:05 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/09/2021 00:00	0.0	0	0	0	0	1
08/09/2021 01:00	0.0	0	0	0	0	1
08/09/2021 02:00	0.0	0	0	0	0	1
08/09/2021 03:00	0.0	0	0	0	0	1
08/09/2021 04:00	0.0	0	0	0	0	1
08/09/2021 05:00	0.0	0	0	0	0	1
08/09/2021 06:00	0.0	0	0	0	0	1
08/09/2021 07:00	0.0	0	0	0	0	1
08/09/2021 08:00	0.0	0	0	0	0	1
08/09/2021 09:00	0.0	0	0	0	0	1
08/09/2021 10:00	0.0	0	0	0	0	1
08/09/2021 11:00	0.0	0	0	0	0	1
08/09/2021 12:00	0.0	0	0	0	0	1
08/09/2021 13:00	0.0	0	0	0	0	1
08/09/2021 14:00	0.0	0	0	0	0	1
08/09/2021 15:00	0.0	0	0	0	0	1
08/09/2021 16:00	0.0	0	0	0	0	1
08/09/2021 17:00	0.0	0	0	0	0	1
08/09/2021 18:00	0.0	0	0	0	0	1
08/09/2021 19:00	0.0	0	0	0	0	1
08/09/2021 20:00	0.0	0	0	0	0	1
08/09/2021 21:00	0.0	0	0	0	0	1
08/09/2021 22:00	0.0	0	0	0	0	1
08/09/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:05 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/10/2021 00:00	0.0	0	0	0	0	1
08/10/2021 01:00	0.0	0	0	0	0	1
08/10/2021 02:00	0.0	0	0	0	0	1
08/10/2021 03:00	0.0	0	0	0	0	1
08/10/2021 04:00	0.0	0	0	0	0	1
08/10/2021 05:00	0.0	0	0	0	0	1
08/10/2021 06:00	0.0	0	0	0	0	1
08/10/2021 07:00	0.0	0	0	0	0	1
08/10/2021 08:00	0.0	0	0	0	0	1
08/10/2021 09:00	0.0	0	0	0	0	1
08/10/2021 10:00	0.0	0	0	0	0	1
08/10/2021 11:00	0.0	0	0	0	0	1
08/10/2021 12:00	0.0	0	0	0	0	1
08/10/2021 13:00	0.0	0	0	0	0	1
08/10/2021 14:00	0.0	0	0	0	0	1
08/10/2021 15:00	0.0	0	0	0	0	1
08/10/2021 16:00	0.0	0	0	0	0	1
08/10/2021 17:00	0.0	0	0	0	0	1
08/10/2021 18:00	0.0	0	0	0	0	1
08/10/2021 19:00	0.0	0	0	0	0	1
08/10/2021 20:00	0.0	0	0	0	0	1
08/10/2021 21:00	0.0	0	0	0	0	1
08/10/2021 22:00	0.0	0	0	0	0	1
08/10/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:05 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/11/2021 00:00	0.0	0	0	0	0	1
08/11/2021 01:00	0.0	0	0	0	0	1
08/11/2021 02:00	0.0	0	0	0	0	1
08/11/2021 03:00	0.0	0	0	0	0	1
08/11/2021 04:00	0.0	0	0	0	0	1
08/11/2021 05:00	0.0	0	0	0	0	1
08/11/2021 06:00	0.0	0	0	0	0	1
08/11/2021 07:00	0.0	0	0	0	0	1
08/11/2021 08:00	0.0	0	0	0	0	1
08/11/2021 09:00	0.0	0	0	0	0	1
08/11/2021 10:00	0.0	0	0	0	0	1
08/11/2021 11:00	0.0	0	0	0	0	1
08/11/2021 12:00	0.0	0	0	0	0	1
08/11/2021 13:00	0.0	0	0	0	0	1
08/11/2021 14:00	0.0	0	0	0	0	1
08/11/2021 15:00	0.0	0	0	0	0	1
08/11/2021 16:00	0.0	0	0	0	0	1
08/11/2021 17:00	0.0	0	0	0	0	1
08/11/2021 18:00	0.0	0	0	0	0	1
08/11/2021 19:00	0.0	0	0	0	0	1
08/11/2021 20:00	0.0	0	0	0	0	1
08/11/2021 21:00	0.0	0	0	0	0	1
08/11/2021 22:00	0.0	0	0	0	0	1
08/11/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:05 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/12/2021 00:00	0.0	0	0	0	0	1
08/12/2021 01:00	0.0	0	0	0	0	1
08/12/2021 02:00	0.0	0	0	0	0	1
08/12/2021 03:00	0.0	0	0	0	0	1
08/12/2021 04:00	0.0	0	0	0	0	1
08/12/2021 05:00	0.0	0	0	0	0	1
08/12/2021 06:00	0.0	0	0	0	0	1
08/12/2021 07:00	0.0	0	0	0	0	1
08/12/2021 08:00	0.0	0	0	0	0	1
08/12/2021 09:00	0.0	0	0	0	0	1
08/12/2021 10:00	0.0	0	0	0	0	1
08/12/2021 11:00	0.0	0	0	0	0	1
08/12/2021 12:00	0.0	0	0	0	0	1
08/12/2021 13:00	0.0	0	0	0	0	1
08/12/2021 14:00	0.0	0	0	0	0	1
08/12/2021 15:00	0.0	0	0	0	0	1
08/12/2021 16:00	0.0	0	0	0	0	1
08/12/2021 17:00	0.0	0	0	0	0	1
08/12/2021 18:00	0.0	0	0	0	0	1
08/12/2021 19:00	0.0	0	0	0	0	1
08/12/2021 20:00	0.0	0	0	0	0	1
08/12/2021 21:00	0.0	0	0	0	0	1
08/12/2021 22:00	0.0	0	0	0	0	1
08/12/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:05 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/13/2021 00:00	0.0	0	0	0	0	1
08/13/2021 01:00	0.0	0	0	0	0	1
08/13/2021 02:00	0.0	0	0	0	0	1
08/13/2021 03:00	0.0	0	0	0	0	1
08/13/2021 04:00	0.0	0	0	0	0	1
08/13/2021 05:00	0.0	0	0	0	0	1
08/13/2021 06:00	0.0	0	0	0	0	1
08/13/2021 07:00	0.0	0	0	0	0	1
08/13/2021 08:00	0.0	0	0	0	0	1
08/13/2021 09:00	0.0	0	0	0	0	1
08/13/2021 10:00	0.0	0	0	0	0	1
08/13/2021 11:00	0.0	0	0	0	0	1
08/13/2021 12:00	0.0	0	0	0	0	1
08/13/2021 13:00	0.0	0	0	0	0	1
08/13/2021 14:00	0.0	0	0	0	0	1
08/13/2021 15:00	0.0	0	0	0	0	1
08/13/2021 16:00	0.0	0	0	0	0	1
08/13/2021 17:00	0.0	0	0	0	0	1
08/13/2021 18:00	0.0	0	0	0	0	1
08/13/2021 19:00	0.0	0	0	0	0	1
08/13/2021 20:00	0.0	0	0	0	0	1
08/13/2021 21:00	0.0	0	0	0	0	1
08/13/2021 22:00	0.0	0	0	0	0	1
08/13/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:05 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/14/2021 00:00	0.0	0	0	0	0	1
08/14/2021 01:00	0.0	0	0	0	0	1
08/14/2021 02:00	0.0	0	0	0	0	1
08/14/2021 03:00	0.0	0	0	0	0	1
08/14/2021 04:00	0.0	0	0	0	0	1
08/14/2021 05:00	0.0	0	0	0	0	1
08/14/2021 06:00	0.0	0	0	0	0	1
08/14/2021 07:00	0.0	0	0	0	0	1
08/14/2021 08:00	0.0	0	0	0	0	1
08/14/2021 09:00	0.0	0	0	0	0	1
08/14/2021 10:00	0.0	0	0	0	0	1
08/14/2021 11:00	0.0	0	0	0	0	1
08/14/2021 12:00	0.0	0	0	0	0	1
08/14/2021 13:00	0.0	0	0	0	0	1
08/14/2021 14:00	0.0	0	0	0	0	1
08/14/2021 15:00	0.0	0	0	0	0	1
08/14/2021 16:00	0.0	0	0	0	0	1
08/14/2021 17:00	0.0	0	0	0	0	1
08/14/2021 18:00	0.0	0	0	0	0	1
08/14/2021 19:00	0.0	0	0	0	0	1
08/14/2021 20:00	0.0	0	0	0	0	1
08/14/2021 21:00	0.0	0	0	0	0	1
08/14/2021 22:00	0.0	0	0	0	0	1
08/14/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:05 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/15/2021 00:00	0.0	0	0	0	0	1
08/15/2021 01:00	0.0	0	0	0	0	1
08/15/2021 02:00	0.0	0	0	0	0	1
08/15/2021 03:00	0.0	0	0	0	0	1
08/15/2021 04:00	0.0	0	0	0	0	1
08/15/2021 05:00	0.0	0	0	0	0	1
08/15/2021 06:00	0.0	0	0	0	0	1
08/15/2021 07:00	0.0	0	0	0	0	1
08/15/2021 08:00	0.0	0	0	0	0	1
08/15/2021 09:00	0.0	0	0	0	0	1
08/15/2021 10:00	0.0	0	0	0	0	1
08/15/2021 11:00	0.0	0	0	0	0	1
08/15/2021 12:00	0.0	0	0	0	0	1
08/15/2021 13:00	0.0	0	0	0	0	1
08/15/2021 14:00	0.0	0	0	0	0	1
08/15/2021 15:00	0.0	0	0	0	0	1
08/15/2021 16:00	0.0	0	0	0	0	1
08/15/2021 17:00	0.0	0	0	0	0	1
08/15/2021 18:00	0.0	0	0	0	0	1
08/15/2021 19:00	0.0	0	0	0	0	1
08/15/2021 20:00	0.0	0	0	0	0	1
08/15/2021 21:00	0.0	0	0	0	0	1
08/15/2021 22:00	0.0	0	0	0	0	1
08/15/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:05 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/16/2021 00:00	0.0	0	0	0	0	1
08/16/2021 01:00	0.0	0	0	0	0	1
08/16/2021 02:00	0.0	0	0	0	0	1
08/16/2021 03:00	0.0	0	0	0	0	1
08/16/2021 04:00	0.0	0	0	0	0	1
08/16/2021 05:00	0.0	0	0	0	0	1
08/16/2021 06:00	0.0	0	0	0	0	1
08/16/2021 07:00	0.0	0	0	0	0	1
08/16/2021 08:00	0.0	0	0	0	0	1
08/16/2021 09:00	0.0	0	0	0	0	1
08/16/2021 10:00	0.0	0	0	0	0	1
08/16/2021 11:00	0.0	0	0	0	0	1
08/16/2021 12:00	0.0	0	0	0	0	1
08/16/2021 13:00	0.0	0	0	0	0	1
08/16/2021 14:00	0.0	0	0	0	0	1
08/16/2021 15:00	0.0	0	0	0	0	1
08/16/2021 16:00	0.0	0	0	0	0	1
08/16/2021 17:00	0.0	0	0	0	0	1
08/16/2021 18:00	0.0	0	0	0	0	1
08/16/2021 19:00	0.0	0	0	0	0	1
08/16/2021 20:00	0.0	0	0	0	0	1
08/16/2021 21:00	0.0	0	0	0	0	1
08/16/2021 22:00	0.0	0	0	0	0	1
08/16/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:05 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/17/2021 00:00	0.0	0	0	0	0	1
08/17/2021 01:00	0.0	0	0	0	0	1
08/17/2021 02:00	0.0	0	0	0	0	1
08/17/2021 03:00	0.0	0	0	0	0	1
08/17/2021 04:00	0.0	0	0	0	0	1
08/17/2021 05:00	0.0	0	0	0	0	1
08/17/2021 06:00	0.0	0	0	0	0	1
08/17/2021 07:00	0.0	0	0	0	0	1
08/17/2021 08:00	0.0	0	0	0	0	1
08/17/2021 09:00	0.0	0	0	0	0	1
08/17/2021 10:00	0.0	0	0	0	0	1
08/17/2021 11:00	0.0	0	0	0	0	1
08/17/2021 12:00	0.0	0	0	0	0	1
08/17/2021 13:00	0.0	0	0	0	0	1
08/17/2021 14:00	0.0	0	0	0	0	1
08/17/2021 15:00	0.0	0	0	0	0	1
08/17/2021 16:00	0.0	0	0	0	0	1
08/17/2021 17:00	0.0	0	0	0	0	1
08/17/2021 18:00	0.0	0	0	0	0	1
08/17/2021 19:00	0.0	0	0	0	0	1
08/17/2021 20:00	0.0	0	0	0	0	1
08/17/2021 21:00	0.0	0	0	0	0	1
08/17/2021 22:00	0.0	0	0	0	0	1
08/17/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:05 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/18/2021 00:00	0.0	0	0	0	0	1
08/18/2021 01:00	0.0	0	0	0	0	1
08/18/2021 02:00	0.0	0	0	0	0	1
08/18/2021 03:00	0.0	0	0	0	0	1
08/18/2021 04:00	0.0	0	0	0	0	1
08/18/2021 05:00	0.0	0	0	0	0	1
08/18/2021 06:00	0.0	0	0	0	0	1
08/18/2021 07:00	0.0	0	0	0	0	1
08/18/2021 08:00	0.0	0	0	0	0	1
08/18/2021 09:00	0.0	0	0	0	0	1
08/18/2021 10:00	0.0	0	0	0	0	1
08/18/2021 11:00	0.0	0	0	0	0	1
08/18/2021 12:00	0.0	0	0	0	0	1
08/18/2021 13:00	0.0	0	0	0	0	1
08/18/2021 14:00	0.0	0	0	0	0	1
08/18/2021 15:00	0.0	0	0	0	0	1
08/18/2021 16:00	0.0	0	0	0	0	1
08/18/2021 17:00	0.0	0	0	0	0	1
08/18/2021 18:00	0.0	0	0	0	0	1
08/18/2021 19:00	0.0	0	0	0	0	1
08/18/2021 20:00	0.0	0	0	0	0	1
08/18/2021 21:00	0.0	0	0	0	0	1
08/18/2021 22:00	0.0	0	0	0	0	1
08/18/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:05 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/19/2021 00:00	0.0	0	0	0	0	1
08/19/2021 01:00	0.0	0	0	0	0	1
08/19/2021 02:00	0.0	0	0	0	0	1
08/19/2021 03:00	0.0	0	0	0	0	1
08/19/2021 04:00	0.0	0	0	0	0	1
08/19/2021 05:00	0.0	0	0	0	0	1
08/19/2021 06:00	0.0	0	0	0	0	1
08/19/2021 07:00	0.0	0	0	0	0	1
08/19/2021 08:00	0.0	0	0	0	0	1
08/19/2021 09:00	0.0	0	0	0	0	1
08/19/2021 10:00	0.0	0	0	0	0	1
08/19/2021 11:00	0.0	0	0	0	0	1
08/19/2021 12:00	0.0	0	0	0	0	1
08/19/2021 13:00	0.0	0	0	0	0	1
08/19/2021 14:00	0.0	0	0	0	0	1
08/19/2021 15:00	0.0	0	0	0	0	1
08/19/2021 16:00	0.0	0	0	0	0	1
08/19/2021 17:00	0.0	0	0	0	0	1
08/19/2021 18:00	0.0	0	0	0	0	1
08/19/2021 19:00	0.0	0	0	0	0	1
08/19/2021 20:00	0.0	0	0	0	0	1
08/19/2021 21:00	0.0	0	0	0	0	1
08/19/2021 22:00	0.0	0	0	0	0	1
08/19/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:05 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/20/2021 00:00	0.0	0	0	0	0	1
08/20/2021 01:00	0.0	0	0	0	0	1
08/20/2021 02:00	0.0	0	0	0	0	1
08/20/2021 03:00	0.0	0	0	0	0	1
08/20/2021 04:00	0.0	0	0	0	0	1
08/20/2021 05:00	0.0	0	0	0	0	1
08/20/2021 06:00	0.0	0	0	0	0	1
08/20/2021 07:00	0.0	0	0	0	0	1
08/20/2021 08:00	0.0	0	0	0	0	1
08/20/2021 09:00	0.0	0	0	0	0	1
08/20/2021 10:00	0.0	0	0	0	0	1
08/20/2021 11:00	0.0	0	0	0	0	1
08/20/2021 12:00	0.0	0	0	0	0	1
08/20/2021 13:00	0.0	0	0	0	0	1
08/20/2021 14:00	0.0	0	0	0	0	1
08/20/2021 15:00	0.0	0	0	0	0	1
08/20/2021 16:00	0.0	0	0	0	0	1
08/20/2021 17:00	0.0	0	0	0	0	1
08/20/2021 18:00	0.0	0	0	0	0	1
08/20/2021 19:00	0.0	0	0	0	0	1
08/20/2021 20:00	0.0	0	0	0	0	1
08/20/2021 21:00	0.0	0	0	0	0	1
08/20/2021 22:00	0.0	0	0	0	0	1
08/20/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:05 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/21/2021 00:00	1.1	0	0	0	1	0
08/21/2021 01:00	0.0	0	0	0	0	0
08/21/2021 02:00	0.0	0	0	0	0	0
08/21/2021 03:00	0.0	0	0	0	0	0
08/21/2021 04:00	0.0	0	0	0	0	0
08/21/2021 05:00	0.0	0	0	0	0	0
08/21/2021 06:00	0.0	0	0	0	0	0
08/21/2021 07:00	0.0	0	0	0	0	0
08/21/2021 08:00	0.0	0	0	0	0	0
08/21/2021 09:00	0.0	0	0	0	0	0
08/21/2021 10:00	0.0	0	0	0	0	0
08/21/2021 11:00	0.0	0	0	0	0	0
08/21/2021 12:00	0.0	0	0	0	0	0
08/21/2021 13:00	0.0	0	0	0	0	0
08/21/2021 14:00	0.0	0	0	0	0	0
08/21/2021 15:00	0.0	0	0	0	0	0
08/21/2021 16:00	0.0	0	0	0	0	0
08/21/2021 17:00	0.0	0	0	0	0	0
08/21/2021 18:00	0.0	0	0	0	0	0
08/21/2021 19:00	0.0	0	0	0	0	0
08/21/2021 20:00	0.0	0	0	0	0	0
08/21/2021 21:00	0.0	0	0	0	0	0
08/21/2021 22:00	0.0	0	0	0	0	0
08/21/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	1.1 #	0 #	0 #	0 #	1 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.1	0	0	0	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:05 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/22/2021 00:00	0.0	0	0	0	0	0
08/22/2021 01:00	0.0	0	0	0	0	0
08/22/2021 02:00	0.0	0	0	0	0	0
08/22/2021 03:00	0.0	0	0	0	0	0
08/22/2021 04:00	0.0	0	0	0	0	0
08/22/2021 05:00	0.0	0	0	0	0	0
08/22/2021 06:00	0.0	0	0	0	0	0
08/22/2021 07:00	0.0	0	0	0	0	0
08/22/2021 08:00	0.0	0	0	0	0	0
08/22/2021 09:00	0.0	0	0	0	0	0
08/22/2021 10:00	0.0	0	0	0	0	0
08/22/2021 11:00	0.0	0	0	0	0	0
08/22/2021 12:00	0.0	0	0	0	0	0
08/22/2021 13:00	0.0	0	0	0	0	0
08/22/2021 14:00	0.0	0	0	0	0	0
08/22/2021 15:00	0.0	0	0	0	0	0
08/22/2021 16:00	0.0	0	0	0	0	0
08/22/2021 17:00	0.0	0	0	0	0	0
08/22/2021 18:00	0.0	0	0	0	0	0
08/22/2021 19:00	0.0	0	0	0	0	0
08/22/2021 20:00	0.0	0	0	0	0	0
08/22/2021 21:00	0.0	0	0	0	0	0
08/22/2021 22:00	0.0	0	0	0	0	0
08/22/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:05 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/23/2021 00:00	0.0	0	0	0	0	0
08/23/2021 01:00	0.0	0	0	0	0	0
08/23/2021 02:00	0.0	0	0	0	0	0
08/23/2021 03:00	0.0	0	0	0	0	0
08/23/2021 04:00	0.0	0	0	0	0	0
08/23/2021 05:00	0.0	0	0	0	0	0
08/23/2021 06:00	0.0	0	0	0	0	0
08/23/2021 07:00	0.0	0	0	0	0	0
08/23/2021 08:00	0.0	0	0	0	0	0
08/23/2021 09:00	0.0	0	0	0	0	0
08/23/2021 10:00	0.0	0	0	0	0	0
08/23/2021 11:00	0.0	0	0	0	0	0
08/23/2021 12:00	0.0	0	0	0	0	0
08/23/2021 13:00	0.0	0	0	0	0	0
08/23/2021 14:00	0.0	0	0	0	0	0
08/23/2021 15:00	0.0	0	0	0	0	0
08/23/2021 16:00	63.8	0	1	0	0	0
08/23/2021 17:00	48.1	0	1	0	0	0
08/23/2021 18:00	0.0	0	0	0	0	1
08/23/2021 19:00	0.0	0	0	0	0	1
08/23/2021 20:00	0.0	0	0	0	0	1
08/23/2021 21:00	0.0	0	0	0	0	1
08/23/2021 22:00	0.0	0	0	0	0	1
08/23/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	111.9 #	0 #	2 #	0 #	0 #	6 #
Minimum:	0.0	0	0	0	0	0
Maximum:	63.8	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:05 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/24/2021 00:00	0.0	0	0	0	0	1
08/24/2021 01:00	0.0	0	0	0	0	1
08/24/2021 02:00	0.0	0	0	0	0	1
08/24/2021 03:00	0.0	0	0	0	0	1
08/24/2021 04:00	0.0	0	0	0	0	1
08/24/2021 05:00	0.0	0	0	0	0	1
08/24/2021 06:00	0.0	0	0	0	0	1
08/24/2021 07:00	0.0	0	0	0	0	1
08/24/2021 08:00	0.0	0	0	0	0	1
08/24/2021 09:00	0.0	0	0	0	0	1
08/24/2021 10:00	0.0	0	0	0	0	1
08/24/2021 11:00	0.0	0	0	0	0	1
08/24/2021 12:00	0.0	0	0	0	0	1
08/24/2021 13:00	0.0	0	0	0	0	1
08/24/2021 14:00	0.0	0	0	0	0	1
08/24/2021 15:00	0.0	0	0	0	0	1
08/24/2021 16:00	0.0	0	0	0	0	1
08/24/2021 17:00	0.0	0	0	0	0	1
08/24/2021 18:00	0.0	0	0	0	0	1
08/24/2021 19:00	0.0	0	0	0	0	1
08/24/2021 20:00	0.0	0	0	0	0	1
08/24/2021 21:00	0.0	0	0	0	0	1
08/24/2021 22:00	0.0	0	0	0	0	1
08/24/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:05 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/25/2021 00:00	0.0	0	0	0	0	1
08/25/2021 01:00	0.0	0	0	0	0	1
08/25/2021 02:00	0.0	0	0	0	0	1
08/25/2021 03:00	0.0	0	0	0	0	1
08/25/2021 04:00	0.0	0	0	0	0	1
08/25/2021 05:00	0.0	0	0	0	0	1
08/25/2021 06:00	0.0	0	0	0	0	1
08/25/2021 07:00	0.0	0	0	0	0	1
08/25/2021 08:00	0.0	0	0	0	0	1
08/25/2021 09:00	0.0	0	0	0	0	1
08/25/2021 10:00	0.0	0	0	0	0	1
08/25/2021 11:00	0.0	0	0	0	0	1
08/25/2021 12:00	0.0	0	0	0	0	1
08/25/2021 13:00	0.0	0	0	0	0	1
08/25/2021 14:00	0.0	0	0	0	0	1
08/25/2021 15:00	0.0	0	0	0	0	1
08/25/2021 16:00	0.0	0	0	0	0	1
08/25/2021 17:00	0.0	0	0	0	0	1
08/25/2021 18:00	0.0	0	0	0	0	1
08/25/2021 19:00	0.0	0	0	0	0	1
08/25/2021 20:00	0.0	0	0	0	0	1
08/25/2021 21:00	0.0	0	0	0	0	1
08/25/2021 22:00	0.0	0	0	0	0	1
08/25/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:05 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/26/2021 00:00	0.0	0	0	0	0	1
08/26/2021 01:00	0.0	0	0	0	0	1
08/26/2021 02:00	0.0	0	0	0	0	1
08/26/2021 03:00	0.0	0	0	0	0	1
08/26/2021 04:00	0.0	0	0	0	0	1
08/26/2021 05:00	0.0	0	0	0	0	1
08/26/2021 06:00	0.0	0	0	0	0	1
08/26/2021 07:00	0.0	0	0	0	0	1
08/26/2021 08:00	0.0	0	0	0	0	1
08/26/2021 09:00	0.0	0	0	0	0	1
08/26/2021 10:00	0.0	0	0	0	0	1
08/26/2021 11:00	0.0	0	0	0	0	1
08/26/2021 12:00	0.0	0	0	0	0	1
08/26/2021 13:00	0.0	0	0	0	0	1
08/26/2021 14:00	0.0	0	0	0	0	1
08/26/2021 15:00	0.0	0	0	0	0	1
08/26/2021 16:00	0.0	0	0	0	0	1
08/26/2021 17:00	0.0	0	0	0	0	1
08/26/2021 18:00	0.0	0	0	0	0	1
08/26/2021 19:00	0.0	0	0	0	0	1
08/26/2021 20:00	0.0	0	0	0	0	1
08/26/2021 21:00	0.0	0	0	0	0	1
08/26/2021 22:00	0.0	0	0	0	0	1
08/26/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:05 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/27/2021 00:00	0.0	0	0	0	0	1
08/27/2021 01:00	0.0	0	0	0	0	1
08/27/2021 02:00	0.0	0	0	0	0	1
08/27/2021 03:00	0.0	0	0	0	0	1
08/27/2021 04:00	0.0	0	0	0	0	1
08/27/2021 05:00	0.0	0	0	0	0	1
08/27/2021 06:00	0.0	0	0	0	0	1
08/27/2021 07:00	0.0	0	0	0	0	1
08/27/2021 08:00	0.0	0	0	0	0	1
08/27/2021 09:00	0.0	0	0	0	0	1
08/27/2021 10:00	0.0	0	0	0	0	1
08/27/2021 11:00	0.0	0	0	0	0	1
08/27/2021 12:00	0.0	0	0	0	0	1
08/27/2021 13:00	0.0	0	0	0	0	1
08/27/2021 14:00	0.0	0	0	0	0	1
08/27/2021 15:00	0.0	0	0	0	0	1
08/27/2021 16:00	0.0	0	0	0	0	1
08/27/2021 17:00	0.0	0	0	0	0	1
08/27/2021 18:00	0.0	0	0	0	0	1
08/27/2021 19:00	0.0	0	0	0	0	1
08/27/2021 20:00	0.0	0	0	0	0	1
08/27/2021 21:00	0.0	0	0	0	0	1
08/27/2021 22:00	0.0	0	0	0	0	1
08/27/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:05 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/28/2021 00:00	0.0	0	0	0	0	1
08/28/2021 01:00	0.0	0	0	0	0	1
08/28/2021 02:00	0.0	0	0	0	0	1
08/28/2021 03:00	0.0	0	0	0	0	1
08/28/2021 04:00	0.0	0	0	0	0	1
08/28/2021 05:00	0.0	0	0	0	0	1
08/28/2021 06:00	0.0	0	0	0	0	1
08/28/2021 07:00	0.0	0	0	0	0	1
08/28/2021 08:00	0.0	0	0	0	0	1
08/28/2021 09:00	0.0	0	0	0	0	1
08/28/2021 10:00	0.0	0	0	0	0	1
08/28/2021 11:00	0.0	0	0	0	0	1
08/28/2021 12:00	0.0	0	0	0	0	1
08/28/2021 13:00	0.0	0	0	0	0	1
08/28/2021 14:00	0.0	0	0	0	0	1
08/28/2021 15:00	0.0	0	0	0	0	1
08/28/2021 16:00	0.0	0	0	0	0	1
08/28/2021 17:00	0.0	0	0	0	0	1
08/28/2021 18:00	0.0	0	0	0	0	1
08/28/2021 19:00	0.0	0	0	0	0	1
08/28/2021 20:00	0.0	0	0	0	0	1
08/28/2021 21:00	0.0	0	0	0	0	1
08/28/2021 22:00	0.0	0	0	0	0	1
08/28/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:05 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/29/2021 00:00	0.0	0	0	0	0	1
08/29/2021 01:00	0.0	0	0	0	0	1
08/29/2021 02:00	0.0	0	0	0	0	1
08/29/2021 03:00	0.0	0	0	0	0	1
08/29/2021 04:00	0.0	0	0	0	0	1
08/29/2021 05:00	0.0	0	0	0	0	1
08/29/2021 06:00	0.0	0	0	0	0	1
08/29/2021 07:00	0.0	0	0	0	0	1
08/29/2021 08:00	0.0	0	0	0	0	1
08/29/2021 09:00	0.0	0	0	0	0	1
08/29/2021 10:00	0.0	0	0	0	0	1
08/29/2021 11:00	0.0	0	0	0	0	1
08/29/2021 12:00	0.0	0	0	0	0	1
08/29/2021 13:00	0.0	0	0	0	0	1
08/29/2021 14:00	0.0	0	0	0	0	1
08/29/2021 15:00	0.0	0	0	0	0	1
08/29/2021 16:00	0.0	0	0	0	0	1
08/29/2021 17:00	0.0	0	0	0	0	1
08/29/2021 18:00	0.0	0	0	0	0	1
08/29/2021 19:00	0.0	0	0	0	0	1
08/29/2021 20:00	0.0	0	0	0	0	1
08/29/2021 21:00	0.0	0	0	0	0	1
08/29/2021 22:00	0.0	0	0	0	0	1
08/29/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:05 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/30/2021 00:00	0.0	0	0	0	0	1
08/30/2021 01:00	0.0	0	0	0	0	1
08/30/2021 02:00	0.0	0	0	0	0	1
08/30/2021 03:00	0.0	0	0	0	0	1
08/30/2021 04:00	0.0	0	0	0	0	1
08/30/2021 05:00	0.0	0	0	0	0	1
08/30/2021 06:00	0.0	0	0	0	0	1
08/30/2021 07:00	0.0	0	0	0	0	1
08/30/2021 08:00	0.0	0	0	0	0	1
08/30/2021 09:00	0.0	0	0	0	0	1
08/30/2021 10:00	0.0	0	0	0	0	1
08/30/2021 11:00	0.0	0	0	0	0	1
08/30/2021 12:00	0.0	0	0	0	0	1
08/30/2021 13:00	0.0	0	0	0	0	1
08/30/2021 14:00	0.0	0	0	0	0	1
08/30/2021 15:00	0.0	0	0	0	0	1
08/30/2021 16:00	0.0	0	0	0	0	1
08/30/2021 17:00	0.0	0	0	0	0	1
08/30/2021 18:00	0.0	0	0	0	0	1
08/30/2021 19:00	0.0	0	0	0	0	1
08/30/2021 20:00	0.0	0	0	0	0	1
08/30/2021 21:00	0.0	0	0	0	0	1
08/30/2021 22:00	0.0	0	0	0	0	1
08/30/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:05 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/31/2021 00:00	0.0	0	0	0	0	1
08/31/2021 01:00	0.0	0	0	0	0	1
08/31/2021 02:00	0.0	0	0	0	0	1
08/31/2021 03:00	0.0	0	0	0	0	1
08/31/2021 04:00	0.0	0	0	0	0	1
08/31/2021 05:00	0.0	0	0	0	0	1
08/31/2021 06:00	0.0	0	0	0	0	1
08/31/2021 07:00	0.0	0	0	0	0	1
08/31/2021 08:00	0.0	0	0	0	0	1
08/31/2021 09:00	0.0	0	0	0	0	1
08/31/2021 10:00	0.0	0	0	0	0	1
08/31/2021 11:00	0.0	0	0	0	0	1
08/31/2021 12:00	0.0	0	0	0	0	1
08/31/2021 13:00	0.0	0	0	0	0	1
08/31/2021 14:00	0.0	0	0	0	0	1
08/31/2021 15:00	0.0	0	0	0	0	1
08/31/2021 16:00	0.0	0	0	0	0	1
08/31/2021 17:00	0.0	0	0	0	0	1
08/31/2021 18:00	0.0	0	0	0	0	1
08/31/2021 19:00	0.0	0	0	0	0	1
08/31/2021 20:00	0.0	0	0	0	0	1
08/31/2021 21:00	0.0	0	0	0	0	1
08/31/2021 22:00	0.0	0	0	0	0	1
08/31/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:05 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/01/2021 00:00	0.0	0	0	0	0	1
09/01/2021 01:00	0.0	0	0	0	0	1
09/01/2021 02:00	0.0	0	0	0	0	1
09/01/2021 03:00	0.0	0	0	0	0	1
09/01/2021 04:00	0.0	0	0	0	0	1
09/01/2021 05:00	0.0	0	0	0	0	1
09/01/2021 06:00	0.0	0	0	0	0	1
09/01/2021 07:00	0.0	0	0	0	0	1
09/01/2021 08:00	0.0	0	0	0	0	1
09/01/2021 09:00	0.0	0	0	0	0	1
09/01/2021 10:00	0.0	0	0	0	0	1
09/01/2021 11:00	0.0	0	0	0	0	1
09/01/2021 12:00	0.0	0	0	0	0	1
09/01/2021 13:00	0.0	0	0	0	0	1
09/01/2021 14:00	0.0	0	0	0	0	1
09/01/2021 15:00	0.0	0	0	0	0	1
09/01/2021 16:00	0.0	0	0	0	0	1
09/01/2021 17:00	0.0	0	0	0	0	1
09/01/2021 18:00	0.0	0	0	0	0	1
09/01/2021 19:00	0.0	0	0	0	0	1
09/01/2021 20:00	0.0	0	0	0	0	1
09/01/2021 21:00	0.0	0	0	0	0	1
09/01/2021 22:00	0.0	0	0	0	0	1
09/01/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:05 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/02/2021 00:00	0.0	0	0	0	0	1
09/02/2021 01:00	0.0	0	0	0	0	1
09/02/2021 02:00	0.0	0	0	0	0	1
09/02/2021 03:00	0.0	0	0	0	0	1
09/02/2021 04:00	0.0	0	0	0	0	1
09/02/2021 05:00	0.0	0	0	0	0	1
09/02/2021 06:00	0.0	0	0	0	0	1
09/02/2021 07:00	0.0	0	0	0	0	1
09/02/2021 08:00	0.0	0	0	0	0	1
09/02/2021 09:00	0.0	0	0	0	0	1
09/02/2021 10:00	0.0	0	0	0	0	1
09/02/2021 11:00	0.0	0	0	0	0	1
09/02/2021 12:00	0.0	0	0	0	0	1
09/02/2021 13:00	0.0	0	0	0	0	1
09/02/2021 14:00	0.0	0	0	0	0	1
09/02/2021 15:00	0.0	0	0	0	0	1
09/02/2021 16:00	0.0	0	0	0	0	1
09/02/2021 17:00	0.0	0	0	0	0	1
09/02/2021 18:00	0.0	0	0	0	0	1
09/02/2021 19:00	0.0	0	0	0	0	1
09/02/2021 20:00	0.0	0	0	0	0	1
09/02/2021 21:00	0.0	0	0	0	0	1
09/02/2021 22:00	0.0	0	0	0	0	1
09/02/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:05 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/03/2021 00:00	0.0	0	0	0	0	1
09/03/2021 01:00	0.0	0	0	0	0	1
09/03/2021 02:00	0.0	0	0	0	0	1
09/03/2021 03:00	0.0	0	0	0	0	1
09/03/2021 04:00	0.0	0	0	0	0	1
09/03/2021 05:00	0.0	0	0	0	0	1
09/03/2021 06:00	0.0	0	0	0	0	1
09/03/2021 07:00	0.0	0	0	0	0	1
09/03/2021 08:00	0.0	0	0	0	0	1
09/03/2021 09:00	0.0	0	0	0	0	1
09/03/2021 10:00	0.0	0	0	0	0	1
09/03/2021 11:00	0.0	0	0	0	0	1
09/03/2021 12:00	0.0	0	0	0	0	1
09/03/2021 13:00	0.0	0	0	0	0	1
09/03/2021 14:00	0.0	0	0	0	0	1
09/03/2021 15:00	0.0	0	0	0	0	1
09/03/2021 16:00	0.0	0	0	0	0	1
09/03/2021 17:00	0.0	0	0	0	0	1
09/03/2021 18:00	0.0	0	0	0	0	1
09/03/2021 19:00	0.0	0	0	0	0	1
09/03/2021 20:00	0.0	0	0	0	0	1
09/03/2021 21:00	0.0	0	0	0	0	1
09/03/2021 22:00	0.0	0	0	0	0	1
09/03/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:05 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/04/2021 00:00	0.0	0	0	0	0	1
09/04/2021 01:00	0.0	0	0	0	0	1
09/04/2021 02:00	0.0	0	0	0	0	1
09/04/2021 03:00	1.2	0	0	0	1	0
09/04/2021 04:00	0.0	0	0	0	0	0
09/04/2021 05:00	0.0	0	0	0	0	0
09/04/2021 06:00	0.0	0	0	0	0	0
09/04/2021 07:00	0.0	0	0	0	0	0
09/04/2021 08:00	0.0	0	0	0	0	0
09/04/2021 09:00	0.9	0	0	1	0	0
09/04/2021 10:00	25.4	0	0	1	0	0
09/04/2021 11:00	0.0	0	0	0	0	1
09/04/2021 12:00	0.0	0	0	0	0	1
09/04/2021 13:00	0.0	0	0	0	0	1
09/04/2021 14:00	0.0	0	0	0	0	1
09/04/2021 15:00	0.0	0	0	0	0	1
09/04/2021 16:00	0.0	0	0	0	0	1
09/04/2021 17:00	0.0	0	0	0	0	1
09/04/2021 18:00	0.0	0	0	0	0	1
09/04/2021 19:00	0.0	0	0	0	0	1
09/04/2021 20:00	0.0	0	0	0	0	1
09/04/2021 21:00	0.0	0	0	0	0	1
09/04/2021 22:00	0.0	0	0	0	0	1
09/04/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	27.5 #	0 #	0 #	2 #	1 #	16 #
Minimum:	0.0	0	0	0	0	0
Maximum:	25.4	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:05 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/05/2021 00:00	0.0	0	0	0	0	1
09/05/2021 01:00	0.0	0	0	0	0	1
09/05/2021 02:00	0.0	0	0	0	0	1
09/05/2021 03:00	0.0	0	0	0	0	1
09/05/2021 04:00	0.0	0	0	0	0	1
09/05/2021 05:00	0.0	0	0	0	0	1
09/05/2021 06:00	0.0	0	0	0	0	1
09/05/2021 07:00	0.0	0	0	0	0	1
09/05/2021 08:00	0.0	0	0	0	0	1
09/05/2021 09:00	0.0	0	0	0	0	1
09/05/2021 10:00	0.0	0	0	0	0	1
09/05/2021 11:00	0.0	0	0	0	0	1
09/05/2021 12:00	0.0	0	0	0	0	1
09/05/2021 13:00	0.0	0	0	0	0	1
09/05/2021 14:00	0.0	0	0	0	0	1
09/05/2021 15:00	0.0	0	0	0	0	1
09/05/2021 16:00	0.0	0	0	0	0	1
09/05/2021 17:00	0.0	0	0	0	0	1
09/05/2021 18:00	0.0	0	0	0	0	1
09/05/2021 19:00	0.0	0	0	0	0	1
09/05/2021 20:00	0.0	0	0	0	0	1
09/05/2021 21:00	0.0	0	0	0	0	1
09/05/2021 22:00	0.0	0	0	0	0	1
09/05/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:05 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/06/2021 00:00	0.0	0	0	0	0	1
09/06/2021 01:00	0.0	0	0	0	0	1
09/06/2021 02:00	0.0	0	0	0	0	1
09/06/2021 03:00	0.0	0	0	0	0	1
09/06/2021 04:00	0.0	0	0	0	0	1
09/06/2021 05:00	0.0	0	0	0	0	1
09/06/2021 06:00	0.0	0	0	0	0	1
09/06/2021 07:00	0.0	0	0	0	0	1
09/06/2021 08:00	0.0	0	0	0	0	1
09/06/2021 09:00	0.0	0	0	0	0	1
09/06/2021 10:00	0.0	0	0	0	0	1
09/06/2021 11:00	0.0	0	0	0	0	1
09/06/2021 12:00	0.0	0	0	0	0	1
09/06/2021 13:00	0.0	0	0	0	0	1
09/06/2021 14:00	0.0	0	0	0	0	1
09/06/2021 15:00	0.0	0	0	0	0	1
09/06/2021 16:00	0.0	0	0	0	0	1
09/06/2021 17:00	0.0	0	0	0	0	1
09/06/2021 18:00	0.0	0	0	0	0	1
09/06/2021 19:00	0.0	0	0	0	0	1
09/06/2021 20:00	0.0	0	0	0	0	1
09/06/2021 21:00	0.0	0	0	0	0	1
09/06/2021 22:00	0.0	0	0	0	0	1
09/06/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:05 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/07/2021 00:00	0.0	0	0	0	0	1
09/07/2021 01:00	0.0	0	0	0	0	1
09/07/2021 02:00	0.0	0	0	0	0	1
09/07/2021 03:00	0.0	0	0	0	0	1
09/07/2021 04:00	0.0	0	0	0	0	1
09/07/2021 05:00	0.0	0	0	0	0	1
09/07/2021 06:00	0.0	0	0	0	0	1
09/07/2021 07:00	0.0	0	0	0	0	1
09/07/2021 08:00	0.0	0	0	0	0	1
09/07/2021 09:00	0.0	0	0	0	0	1
09/07/2021 10:00	0.0	0	0	0	0	1
09/07/2021 11:00	0.0	0	0	0	0	1
09/07/2021 12:00	0.0	0	0	0	0	1
09/07/2021 13:00	0.0	0	0	0	0	1
09/07/2021 14:00	0.0	0	0	0	0	1
09/07/2021 15:00	0.0	0	0	0	0	1
09/07/2021 16:00	0.0	0	0	0	0	1
09/07/2021 17:00	0.0	0	0	0	0	1
09/07/2021 18:00	0.0	0	0	0	0	1
09/07/2021 19:00	0.0	0	0	0	0	1
09/07/2021 20:00	0.0	0	0	0	0	1
09/07/2021 21:00	0.0	0	0	0	0	1
09/07/2021 22:00	0.0	0	0	0	0	1
09/07/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:05 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/08/2021 00:00	0.0	0	0	0	0	1
09/08/2021 01:00	0.0	0	0	0	0	1
09/08/2021 02:00	0.0	0	0	0	0	1
09/08/2021 03:00	0.0	0	0	0	0	1
09/08/2021 04:00	0.0	0	0	0	0	1
09/08/2021 05:00	0.0	0	0	0	0	1
09/08/2021 06:00	0.0	0	0	0	0	1
09/08/2021 07:00	0.0	0	0	0	0	1
09/08/2021 08:00	0.0	0	0	0	0	1
09/08/2021 09:00	0.0	0	0	0	0	1
09/08/2021 10:00	0.0	0	0	0	0	1
09/08/2021 11:00	0.0	0	0	0	0	1
09/08/2021 12:00	0.0	0	0	0	0	1
09/08/2021 13:00	0.0	0	0	0	0	1
09/08/2021 14:00	0.0	0	0	0	0	1
09/08/2021 15:00	0.0	0	0	0	0	1
09/08/2021 16:00	0.0	0	0	0	0	1
09/08/2021 17:00	0.0	0	0	0	0	1
09/08/2021 18:00	0.0	0	0	0	0	1
09/08/2021 19:00	0.0	0	0	0	0	1
09/08/2021 20:00	0.0	0	0	0	0	1
09/08/2021 21:00	0.0	0	0	0	0	1
09/08/2021 22:00	0.0	0	0	0	0	1
09/08/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:05 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/09/2021 00:00	0.0	0	0	0	0	1
09/09/2021 01:00	0.0	0	0	0	0	1
09/09/2021 02:00	0.0	0	0	0	0	1
09/09/2021 03:00	0.0	0	0	0	0	1
09/09/2021 04:00	0.0	0	0	0	0	1
09/09/2021 05:00	0.0	0	0	0	0	1
09/09/2021 06:00	0.0	0	0	0	0	1
09/09/2021 07:00	0.0	0	0	0	0	1
09/09/2021 08:00	0.0	0	0	0	0	1
09/09/2021 09:00	0.0	0	0	0	0	1
09/09/2021 10:00	0.0	0	0	0	0	1
09/09/2021 11:00	0.0	0	0	0	0	1
09/09/2021 12:00	0.0	0	0	0	0	1
09/09/2021 13:00	0.0	0	0	0	0	1
09/09/2021 14:00	0.0	0	0	0	0	1
09/09/2021 15:00	0.0	0	0	0	0	1
09/09/2021 16:00	0.0	0	0	0	0	1
09/09/2021 17:00	0.0	0	0	0	0	1
09/09/2021 18:00	0.0	0	0	0	0	1
09/09/2021 19:00	0.0	0	0	0	0	1
09/09/2021 20:00	0.0	0	0	0	0	1
09/09/2021 21:00	0.0	0	0	0	0	1
09/09/2021 22:00	0.0	0	0	0	0	1
09/09/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:05 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/10/2021 00:00	0.0	0	0	0	0	1
09/10/2021 01:00	0.0	0	0	0	0	1
09/10/2021 02:00	0.0	0	0	0	0	1
09/10/2021 03:00	0.0	0	0	0	0	1
09/10/2021 04:00	0.0	0	0	0	0	1
09/10/2021 05:00	0.0	0	0	0	0	1
09/10/2021 06:00	0.0	0	0	0	0	1
09/10/2021 07:00	0.0	0	0	0	0	1
09/10/2021 08:00	0.0	0	0	0	0	1
09/10/2021 09:00	0.0	0	0	0	0	1
09/10/2021 10:00	0.0	0	0	0	0	1
09/10/2021 11:00	0.0	0	0	0	0	1
09/10/2021 12:00	0.0	0	0	0	0	1
09/10/2021 13:00	0.0	0	0	0	0	1
09/10/2021 14:00	0.0	0	0	0	0	1
09/10/2021 15:00	0.0	0	0	0	0	1
09/10/2021 16:00	0.0	0	0	0	0	1
09/10/2021 17:00	0.0	0	0	0	0	1
09/10/2021 18:00	0.0	0	0	0	0	1
09/10/2021 19:00	0.0	0	0	0	0	1
09/10/2021 20:00	0.0	0	0	0	0	1
09/10/2021 21:00	0.0	0	0	0	0	1
09/10/2021 22:00	0.0	0	0	0	0	1
09/10/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:05 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/11/2021 00:00	0.0	0	0	0	0	1
09/11/2021 01:00	0.0	0	0	0	0	1
09/11/2021 02:00	0.0	0	0	0	0	1
09/11/2021 03:00	0.0	0	0	0	0	1
09/11/2021 04:00	0.0	0	0	0	0	1
09/11/2021 05:00	0.0	0	0	0	0	1
09/11/2021 06:00	0.0	0	0	0	0	1
09/11/2021 07:00	0.0	0	0	0	0	1
09/11/2021 08:00	0.0	0	0	0	0	1
09/11/2021 09:00	0.0	0	0	0	0	1
09/11/2021 10:00	0.0	0	0	0	0	1
09/11/2021 11:00	0.0	0	0	0	0	1
09/11/2021 12:00	0.0	0	0	0	0	1
09/11/2021 13:00	0.0	0	0	0	0	1
09/11/2021 14:00	0.0	0	0	0	0	1
09/11/2021 15:00	0.0	0	0	0	0	1
09/11/2021 16:00	0.0	0	0	0	0	1
09/11/2021 17:00	0.0	0	0	0	0	1
09/11/2021 18:00	0.0	0	0	0	0	1
09/11/2021 19:00	0.0	0	0	0	0	1
09/11/2021 20:00	0.0	0	0	0	0	1
09/11/2021 21:00	0.0	0	0	0	0	1
09/11/2021 22:00	0.0	0	0	0	0	1
09/11/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:05 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/12/2021 00:00	0.0	0	0	0	0	1
09/12/2021 01:00	0.0	0	0	0	0	1
09/12/2021 02:00	0.0	0	0	0	0	1
09/12/2021 03:00	0.0	0	0	0	0	1
09/12/2021 04:00	0.0	0	0	0	0	1
09/12/2021 05:00	0.0	0	0	0	0	1
09/12/2021 06:00	0.0	0	0	0	0	1
09/12/2021 07:00	0.0	0	0	0	0	1
09/12/2021 08:00	0.0	0	0	0	0	1
09/12/2021 09:00	0.0	0	0	0	0	1
09/12/2021 10:00	0.0	0	0	0	0	1
09/12/2021 11:00	0.0	0	0	0	0	1
09/12/2021 12:00	0.0	0	0	0	0	1
09/12/2021 13:00	0.0	0	0	0	0	1
09/12/2021 14:00	0.0	0	0	0	0	1
09/12/2021 15:00	0.0	0	0	0	0	1
09/12/2021 16:00	0.0	0	0	0	0	1
09/12/2021 17:00	0.0	0	0	0	0	1
09/12/2021 18:00	0.0	0	0	0	0	1
09/12/2021 19:00	0.0	0	0	0	0	1
09/12/2021 20:00	0.0	0	0	0	0	1
09/12/2021 21:00	0.0	0	0	0	0	1
09/12/2021 22:00	0.0	0	0	0	0	1
09/12/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:05 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/13/2021 00:00	0.0	0	0	0	0	1
09/13/2021 01:00	0.0	0	0	0	0	1
09/13/2021 02:00	0.0	0	0	0	0	1
09/13/2021 03:00	0.0	0	0	0	0	1
09/13/2021 04:00	0.0	0	0	0	0	1
09/13/2021 05:00	0.0	0	0	0	0	1
09/13/2021 06:00	0.0	0	0	0	0	1
09/13/2021 07:00	0.0	0	0	0	0	1
09/13/2021 08:00	0.0	0	0	0	0	1
09/13/2021 09:00	0.0	0	0	0	0	1
09/13/2021 10:00	0.0	0	0	0	0	1
09/13/2021 11:00	0.0	0	0	0	0	1
09/13/2021 12:00	0.0	0	0	0	0	1
09/13/2021 13:00	0.0	0	0	0	0	1
09/13/2021 14:00	0.0	0	0	0	0	1
09/13/2021 15:00	0.0	0	0	0	0	1
09/13/2021 16:00	0.0	0	0	0	0	1
09/13/2021 17:00	0.0	0	0	0	0	1
09/13/2021 18:00	0.0	0	0	0	0	1
09/13/2021 19:00	0.0	0	0	0	0	1
09/13/2021 20:00	0.0	0	0	0	0	1
09/13/2021 21:00	0.0	0	0	0	0	1
09/13/2021 22:00	0.0	0	0	0	0	1
09/13/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:05 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/14/2021 00:00	0.0	0	0	0	0	1
09/14/2021 01:00	0.0	0	0	0	0	1
09/14/2021 02:00	0.0	0	0	0	0	1
09/14/2021 03:00	0.0	0	0	0	0	1
09/14/2021 04:00	0.0	0	0	0	0	1
09/14/2021 05:00	0.0	0	0	0	0	1
09/14/2021 06:00	0.0	0	0	0	0	1
09/14/2021 07:00	0.0	0	0	0	0	1
09/14/2021 08:00	0.0	0	0	0	0	1
09/14/2021 09:00	0.0	0	0	0	0	1
09/14/2021 10:00	0.0	0	0	0	0	1
09/14/2021 11:00	0.0	0	0	0	0	1
09/14/2021 12:00	0.0	0	0	0	0	1
09/14/2021 13:00	0.0	0	0	0	0	1
09/14/2021 14:00	0.0	0	0	0	0	1
09/14/2021 15:00	0.0	0	0	0	0	1
09/14/2021 16:00	0.0	0	0	0	0	1
09/14/2021 17:00	0.0	0	0	0	0	1
09/14/2021 18:00	0.0	0	0	0	0	1
09/14/2021 19:00	0.0	0	0	0	0	1
09/14/2021 20:00	0.0	0	0	0	0	1
09/14/2021 21:00	0.0	0	0	0	0	1
09/14/2021 22:00	0.0	0	0	0	0	1
09/14/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:05 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/15/2021 00:00	0.0	0	0	0	0	1
09/15/2021 01:00	0.0	0	0	0	0	1
09/15/2021 02:00	0.0	0	0	0	0	1
09/15/2021 03:00	0.0	0	0	0	0	1
09/15/2021 04:00	0.0	0	0	0	0	1
09/15/2021 05:00	0.0	0	0	0	0	1
09/15/2021 06:00	0.0	0	0	0	0	1
09/15/2021 07:00	0.0	0	0	0	0	1
09/15/2021 08:00	0.0	0	0	0	0	1
09/15/2021 09:00	0.0	0	0	0	0	1
09/15/2021 10:00	0.0	0	0	0	0	1
09/15/2021 11:00	0.0	0	0	0	0	1
09/15/2021 12:00	0.0	0	0	0	0	1
09/15/2021 13:00	0.0	0	0	0	0	1
09/15/2021 14:00	0.0	0	0	0	0	1
09/15/2021 15:00	0.0	0	0	0	0	1
09/15/2021 16:00	0.0	0	0	0	0	1
09/15/2021 17:00	0.0	0	0	0	0	1
09/15/2021 18:00	0.0	0	0	0	0	1
09/15/2021 19:00	0.0	0	0	0	0	1
09/15/2021 20:00	0.0	0	0	0	0	1
09/15/2021 21:00	0.0	0	0	0	0	1
09/15/2021 22:00	0.0	0	0	0	0	1
09/15/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:05 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/16/2021 00:00	0.0	0	0	0	0	1
09/16/2021 01:00	0.0	0	0	0	0	1
09/16/2021 02:00	0.0	0	0	0	0	1
09/16/2021 03:00	0.0	0	0	0	0	1
09/16/2021 04:00	0.0	0	0	0	0	1
09/16/2021 05:00	0.0	0	0	0	0	1
09/16/2021 06:00	0.0	0	0	0	0	1
09/16/2021 07:00	0.0	0	0	0	0	1
09/16/2021 08:00	0.0	0	0	0	0	1
09/16/2021 09:00	0.0	0	0	0	0	1
09/16/2021 10:00	0.0	0	0	0	0	1
09/16/2021 11:00	0.0	0	0	0	0	1
09/16/2021 12:00	0.0	0	0	0	0	1
09/16/2021 13:00	0.0	0	0	0	0	1
09/16/2021 14:00	0.0	0	0	0	0	1
09/16/2021 15:00	0.0	0	0	0	0	1
09/16/2021 16:00	0.0	0	0	0	0	1
09/16/2021 17:00	0.0	0	0	0	0	1
09/16/2021 18:00	0.0	0	0	0	0	1
09/16/2021 19:00	0.0	0	0	0	0	1
09/16/2021 20:00	0.0	0	0	0	0	1
09/16/2021 21:00	0.0	0	0	0	0	1
09/16/2021 22:00	0.0	0	0	0	0	1
09/16/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:05 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/17/2021 00:00	0.0	0	0	0	0	1
09/17/2021 01:00	0.0	0	0	0	0	1
09/17/2021 02:00	0.0	0	0	0	0	1
09/17/2021 03:00	0.0	0	0	0	0	1
09/17/2021 04:00	0.0	0	0	0	0	1
09/17/2021 05:00	0.0	0	0	0	0	1
09/17/2021 06:00	0.0	0	0	0	0	1
09/17/2021 07:00	0.0	0	0	0	0	1
09/17/2021 08:00	0.0	0	0	0	0	1
09/17/2021 09:00	0.0	0	0	0	0	1
09/17/2021 10:00	0.0	0	0	0	0	1
09/17/2021 11:00	0.0	0	0	0	0	1
09/17/2021 12:00	0.0	0	0	0	0	1
09/17/2021 13:00	0.0	0	0	0	0	1
09/17/2021 14:00	0.0	0	0	0	0	1
09/17/2021 15:00	0.0	0	0	0	0	1
09/17/2021 16:00	0.0	0	0	0	0	1
09/17/2021 17:00	0.0	0	0	0	0	1
09/17/2021 18:00	0.0	0	0	0	0	1
09/17/2021 19:00	0.0	0	0	0	0	1
09/17/2021 20:00	0.0	0	0	0	0	1
09/17/2021 21:00	0.0	0	0	0	0	1
09/17/2021 22:00	0.0	0	0	0	0	1
09/17/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:05 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/18/2021 00:00	0.0	0	0	0	0	1
09/18/2021 01:00	0.0	0	0	0	0	1
09/18/2021 02:00	0.0	0	0	0	0	1
09/18/2021 03:00	0.0	0	0	0	0	1
09/18/2021 04:00	0.0	0	0	0	0	1
09/18/2021 05:00	0.0	0	0	0	0	1
09/18/2021 06:00	0.0	0	0	0	0	1
09/18/2021 07:00	0.0	0	0	0	0	1
09/18/2021 08:00	0.0	0	0	0	0	1
09/18/2021 09:00	0.0	0	0	0	0	1
09/18/2021 10:00	0.0	0	0	0	0	1
09/18/2021 11:00	0.0	0	0	0	0	1
09/18/2021 12:00	0.0	0	0	0	0	1
09/18/2021 13:00	0.0	0	0	0	0	1
09/18/2021 14:00	0.0	0	0	0	0	1
09/18/2021 15:00	0.0	0	0	0	0	1
09/18/2021 16:00	0.0	0	0	0	0	1
09/18/2021 17:00	0.0	0	0	0	0	1
09/18/2021 18:00	0.0	0	0	0	0	1
09/18/2021 19:00	0.0	0	0	0	0	1
09/18/2021 20:00	0.0	0	0	0	0	1
09/18/2021 21:00	0.0	0	0	0	0	1
09/18/2021 22:00	0.0	0	0	0	0	1
09/18/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:05 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/19/2021 00:00	0.0	0	0	0	0	1
09/19/2021 01:00	0.0	0	0	0	0	1
09/19/2021 02:00	0.0	0	0	0	0	1
09/19/2021 03:00	0.0	0	0	0	0	1
09/19/2021 04:00	0.0	0	0	0	0	1
09/19/2021 05:00	0.0	0	0	0	0	1
09/19/2021 06:00	0.0	0	0	0	0	1
09/19/2021 07:00	0.0	0	0	0	0	1
09/19/2021 08:00	0.0	0	0	0	0	1
09/19/2021 09:00	0.0	0	0	0	0	1
09/19/2021 10:00	0.0	0	0	0	0	1
09/19/2021 11:00	0.0	0	0	0	0	1
09/19/2021 12:00	0.0	0	0	0	0	1
09/19/2021 13:00	0.0	0	0	0	0	1
09/19/2021 14:00	0.0	0	0	0	0	1
09/19/2021 15:00	0.0	0	0	0	0	1
09/19/2021 16:00	0.0	0	0	0	0	1
09/19/2021 17:00	0.0	0	0	0	0	1
09/19/2021 18:00	0.0	0	0	0	0	1
09/19/2021 19:00	0.0	0	0	0	0	1
09/19/2021 20:00	0.0	0	0	0	0	1
09/19/2021 21:00	0.0	0	0	0	0	1
09/19/2021 22:00	0.0	0	0	0	0	1
09/19/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:05 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/20/2021 00:00	0.0	0	0	0	0	1
09/20/2021 01:00	0.0	0	0	0	0	1
09/20/2021 02:00	0.0	0	0	0	0	1
09/20/2021 03:00	0.0	0	0	0	0	1
09/20/2021 04:00	0.0	0	0	0	0	1
09/20/2021 05:00	0.0	0	0	0	0	1
09/20/2021 06:00	0.0	0	0	0	0	1
09/20/2021 07:00	0.0	0	0	0	0	1
09/20/2021 08:00	0.0	0	0	0	0	1
09/20/2021 09:00	0.0	0	0	0	0	1
09/20/2021 10:00	0.0	0	0	0	0	1
09/20/2021 11:00	0.0	0	0	0	0	1
09/20/2021 12:00	0.0	0	0	0	0	1
09/20/2021 13:00	0.0	0	0	0	0	1
09/20/2021 14:00	0.0	0	0	0	0	1
09/20/2021 15:00	0.0	0	0	0	0	1
09/20/2021 16:00	0.0	0	0	0	0	1
09/20/2021 17:00	0.0	0	0	0	0	1
09/20/2021 18:00	0.0	0	0	0	0	1
09/20/2021 19:00	0.0	0	0	0	0	1
09/20/2021 20:00	0.0	0	0	0	0	1
09/20/2021 21:00	0.0	0	0	0	0	1
09/20/2021 22:00	0.0	0	0	0	0	1
09/20/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:05 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/21/2021 00:00	0.0	0	0	0	0	1
09/21/2021 01:00	0.0	0	0	0	0	1
09/21/2021 02:00	0.0	0	0	0	0	1
09/21/2021 03:00	0.0	0	0	0	0	1
09/21/2021 04:00	0.0	0	0	0	0	1
09/21/2021 05:00	0.0	0	0	0	0	1
09/21/2021 06:00	0.0	0	0	0	0	1
09/21/2021 07:00	0.0	0	0	0	0	1
09/21/2021 08:00	0.0	0	0	0	0	1
09/21/2021 09:00	0.0	0	0	0	0	1
09/21/2021 10:00	0.0	0	0	0	0	1
09/21/2021 11:00	0.0	0	0	0	0	1
09/21/2021 12:00	0.0	0	0	0	0	1
09/21/2021 13:00	0.0	0	0	0	0	1
09/21/2021 14:00	0.0	0	0	0	0	1
09/21/2021 15:00	0.0	0	0	0	0	1
09/21/2021 16:00	0.0	0	0	0	0	1
09/21/2021 17:00	0.0	0	0	0	0	1
09/21/2021 18:00	0.0	0	0	0	0	1
09/21/2021 19:00	0.0	0	0	0	0	1
09/21/2021 20:00	0.0	0	0	0	0	1
09/21/2021 21:00	0.0	0	0	0	0	1
09/21/2021 22:00	0.0	0	0	0	0	1
09/21/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:05 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/22/2021 00:00	0.0	0	0	0	0	1
09/22/2021 01:00	0.0	0	0	0	0	1
09/22/2021 02:00	0.0	0	0	0	0	1
09/22/2021 03:00	0.0	0	0	0	0	1
09/22/2021 04:00	0.0	0	0	0	0	1
09/22/2021 05:00	0.0	0	0	0	0	1
09/22/2021 06:00	0.0	0	0	0	0	1
09/22/2021 07:00	0.0	0	0	0	0	1
09/22/2021 08:00	0.0	0	0	0	0	1
09/22/2021 09:00	0.0	0	0	0	0	1
09/22/2021 10:00	0.0	0	0	0	0	1
09/22/2021 11:00	0.0	0	0	0	0	1
09/22/2021 12:00	0.0	0	0	0	0	1
09/22/2021 13:00	0.0	0	0	0	0	1
09/22/2021 14:00	0.0	0	0	0	0	1
09/22/2021 15:00	0.0	0	0	0	0	1
09/22/2021 16:00	0.0	0	0	0	0	1
09/22/2021 17:00	0.0	0	0	0	0	1
09/22/2021 18:00	0.0	0	0	0	0	1
09/22/2021 19:00	0.0	0	0	0	0	1
09/22/2021 20:00	0.0	0	0	0	0	1
09/22/2021 21:00	0.0	0	0	0	0	1
09/22/2021 22:00	0.0	0	0	0	0	1
09/22/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:05 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/23/2021 00:00	0.0	0	0	0	0	1
09/23/2021 01:00	0.0	0	0	0	0	1
09/23/2021 02:00	0.0	0	0	0	0	1
09/23/2021 03:00	0.0	0	0	0	0	1
09/23/2021 04:00	0.0	0	0	0	0	1
09/23/2021 05:00	0.0	0	0	0	0	1
09/23/2021 06:00	0.0	0	0	0	0	1
09/23/2021 07:00	0.0	0	0	0	0	1
09/23/2021 08:00	0.0	0	0	0	0	1
09/23/2021 09:00	0.0	0	0	0	0	1
09/23/2021 10:00	0.0	0	0	0	0	1
09/23/2021 11:00	0.0	0	0	0	0	1
09/23/2021 12:00	0.0	0	0	0	0	1
09/23/2021 13:00	0.0	0	0	0	0	1
09/23/2021 14:00	0.0	0	0	0	0	1
09/23/2021 15:00	0.0	0	0	0	0	1
09/23/2021 16:00	0.0	0	0	0	0	1
09/23/2021 17:00	0.0	0	0	0	0	1
09/23/2021 18:00	0.0	0	0	0	0	1
09/23/2021 19:00	0.0	0	0	0	0	1
09/23/2021 20:00	0.0	0	0	0	0	1
09/23/2021 21:00	0.0	0	0	0	0	1
09/23/2021 22:00	0.0	0	0	0	0	1
09/23/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:05 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/24/2021 00:00	0.0	0	0	0	0	1
09/24/2021 01:00	0.0	0	0	0	0	1
09/24/2021 02:00	0.0	0	0	0	0	1
09/24/2021 03:00	0.0	0	0	0	0	1
09/24/2021 04:00	0.0	0	0	0	0	1
09/24/2021 05:00	0.0	0	0	0	0	1
09/24/2021 06:00	0.0	0	0	0	0	1
09/24/2021 07:00	0.0	0	0	0	0	1
09/24/2021 08:00	0.0	0	0	0	0	1
09/24/2021 09:00	0.0	0	0	0	0	1
09/24/2021 10:00	0.0	0	0	0	0	1
09/24/2021 11:00	0.0	0	0	0	0	1
09/24/2021 12:00	0.0	0	0	0	0	1
09/24/2021 13:00	0.0	0	0	0	0	1
09/24/2021 14:00	0.0	0	0	0	0	1
09/24/2021 15:00	0.0	0	0	0	0	1
09/24/2021 16:00	0.0	0	0	0	0	1
09/24/2021 17:00	0.0	0	0	0	0	1
09/24/2021 18:00	0.0	0	0	0	0	1
09/24/2021 19:00	0.0	0	0	0	0	1
09/24/2021 20:00	0.0	0	0	0	0	1
09/24/2021 21:00	0.0	0	0	0	0	1
09/24/2021 22:00	0.0	0	0	0	0	1
09/24/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:05 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/25/2021 00:00	0.0	0	0	0	0	1
09/25/2021 01:00	0.0	0	0	0	0	1
09/25/2021 02:00	0.0	0	0	0	0	1
09/25/2021 03:00	0.0	0	0	0	0	1
09/25/2021 04:00	0.0	0	0	0	0	1
09/25/2021 05:00	0.0	0	0	0	0	1
09/25/2021 06:00	0.0	0	0	0	0	1
09/25/2021 07:00	0.0	0	0	0	0	1
09/25/2021 08:00	0.0	0	0	0	0	1
09/25/2021 09:00	0.0	0	0	0	0	1
09/25/2021 10:00	0.0	0	0	0	0	1
09/25/2021 11:00	0.0	0	0	0	0	1
09/25/2021 12:00	0.0	0	0	0	0	1
09/25/2021 13:00	0.0	0	0	0	0	1
09/25/2021 14:00	0.0	0	0	0	0	1
09/25/2021 15:00	0.0	0	0	0	0	1
09/25/2021 16:00	0.0	0	0	0	0	1
09/25/2021 17:00	0.0	0	0	0	0	1
09/25/2021 18:00	0.0	0	0	0	0	1
09/25/2021 19:00	0.0	0	0	0	0	1
09/25/2021 20:00	0.0	0	0	0	0	1
09/25/2021 21:00	0.0	0	0	0	0	1
09/25/2021 22:00	0.9	0	0	0	1	0
09/25/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.9 #	0 #	0 #	0 #	1 #	22 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.9	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:05 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/26/2021 00:00	0.0	0	0	0	0	0
09/26/2021 01:00	0.0	0	0	0	0	0
09/26/2021 02:00	0.0	0	0	0	0	0
09/26/2021 03:00	0.0	0	0	0	0	0
09/26/2021 04:00	0.0	0	0	0	0	0
09/26/2021 05:00	0.0	0	0	0	0	0
09/26/2021 06:00	0.0	0	0	0	0	0
09/26/2021 07:00	0.0	0	0	0	0	0
09/26/2021 08:00	0.0	0	0	0	0	0
09/26/2021 09:00	0.0	0	0	0	0	0
09/26/2021 10:00	0.0	0	0	0	0	0
09/26/2021 11:00	0.0	0	0	0	0	0
09/26/2021 12:00	0.0	0	0	0	0	0
09/26/2021 13:00	0.0	0	0	0	0	0
09/26/2021 14:00	0.0	0	0	0	0	0
09/26/2021 15:00	0.0	0	0	0	0	0
09/26/2021 16:00	0.0	0	0	0	0	0
09/26/2021 17:00	0.0	0	0	0	0	0
09/26/2021 18:00	0.0	0	0	0	0	0
09/26/2021 19:00	0.0	0	0	0	0	0
09/26/2021 20:00	0.0	0	0	0	0	0
09/26/2021 21:00	0.0	0	0	0	0	0
09/26/2021 22:00	0.0	0	0	0	0	0
09/26/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:05 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/27/2021 00:00	0.0	0	0	0	0	0
09/27/2021 01:00	0.0	0	0	0	0	0
09/27/2021 02:00	0.0	0	0	0	0	0
09/27/2021 03:00	0.0	0	0	0	0	0
09/27/2021 04:00	0.0	0	0	0	0	0
09/27/2021 05:00	0.0	0	0	0	0	0
09/27/2021 06:00	0.0	0	0	0	0	0
09/27/2021 07:00	0.0	0	0	0	0	0
09/27/2021 08:00	0.0	0	0	0	0	0
09/27/2021 09:00	0.0	0	0	0	0	0
09/27/2021 10:00	0.0	0	0	0	0	0
09/27/2021 11:00	0.0	0	0	0	0	0
09/27/2021 12:00	0.0	0	0	0	0	0
09/27/2021 13:00	0.0	0	0	0	0	0
09/27/2021 14:00	0.0	0	0	0	0	0
09/27/2021 15:00	0.0	0	0	0	0	0
09/27/2021 16:00	0.0	0	0	0	0	0
09/27/2021 17:00	0.0	0	0	0	0	0
09/27/2021 18:00	0.0	0	0	0	0	0
09/27/2021 19:00	0.0	0	0	0	0	0
09/27/2021 20:00	0.0	0	0	0	0	0
09/27/2021 21:00	0.0	0	0	0	0	0
09/27/2021 22:00	0.0	0	0	0	0	0
09/27/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:05 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/28/2021 00:00	0.0	0	0	0	0	0
09/28/2021 01:00	0.0	0	0	0	0	0
09/28/2021 02:00	0.0	0	0	0	0	0
09/28/2021 03:00	0.0	0	0	0	0	0
09/28/2021 04:00	0.0	0	0	0	0	0
09/28/2021 05:00	0.0	0	0	0	0	0
09/28/2021 06:00	0.0	0	0	0	0	0
09/28/2021 07:00	0.0	0	0	0	0	0
09/28/2021 08:00	0.0	0	0	0	0	0
09/28/2021 09:00	0.0	0	0	0	0	0
09/28/2021 10:00	0.0	0	0	0	0	0
09/28/2021 11:00	0.0	0	0	0	0	0
09/28/2021 12:00	0.0	0	0	0	0	0
09/28/2021 13:00	0.0	0	0	0	0	0
09/28/2021 14:00	0.0	0	0	0	0	0
09/28/2021 15:00	0.0	0	0	0	0	0
09/28/2021 16:00	0.0	0	0	0	0	0
09/28/2021 17:00	0.0	0	0	0	0	0
09/28/2021 18:00	0.0	0	0	0	0	0
09/28/2021 19:00	0.0	0	0	0	0	0
09/28/2021 20:00	0.0	0	0	0	0	0
09/28/2021 21:00	0.0	0	0	0	0	0
09/28/2021 22:00	0.0	0	0	0	0	0
09/28/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:05 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/29/2021 00:00	0.0	0	0	0	0	0
09/29/2021 01:00	0.0	0	0	0	0	0
09/29/2021 02:00	0.0	0	0	0	0	0
09/29/2021 03:00	6.0	1	0	0	1	0
09/29/2021 04:00	0.0	0	0	0	0	0
09/29/2021 05:00	0.0	0	0	0	0	0
09/29/2021 06:00	0.0	0	0	0	0	0
09/29/2021 07:00	0.0	0	0	0	0	0
09/29/2021 08:00	14.3	1	0	0	0	0
09/29/2021 09:00	45.2	1	0	0	0	0
09/29/2021 10:00	0.0	0	0	0	0	1
09/29/2021 11:00	0.0	0	0	0	0	1
09/29/2021 12:00	0.0	0	0	0	0	1
09/29/2021 13:00	0.0	0	0	0	0	1
09/29/2021 14:00	0.0	0	0	0	0	1
09/29/2021 15:00	0.0	0	0	0	0	1
09/29/2021 16:00	0.0	0	0	0	0	1
09/29/2021 17:00	0.0	0	0	0	0	1
09/29/2021 18:00	0.0	0	0	0	0	1
09/29/2021 19:00	0.0	0	0	0	0	1
09/29/2021 20:00	0.0	0	0	0	0	1
09/29/2021 21:00	0.0	0	0	0	0	1
09/29/2021 22:00	0.0	0	0	0	0	1
09/29/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	65.5 #	3 #	0 #	0 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	45.2	1	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:05 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/30/2021 00:00	0.0	0	0	0	0	1
09/30/2021 01:00	0.0	0	0	0	0	1
09/30/2021 02:00	0.0	0	0	0	0	1
09/30/2021 03:00	0.0	0	0	0	0	1
09/30/2021 04:00	0.0	0	0	0	0	1
09/30/2021 05:00	0.0	0	0	0	0	1
09/30/2021 06:00	0.0	0	0	0	0	1
09/30/2021 07:00	0.0	0	0	0	0	1
09/30/2021 08:00	0.0	0	0	0	0	1
09/30/2021 09:00	0.0	0	0	0	0	1
09/30/2021 10:00	0.0	0	0	0	0	1
09/30/2021 11:00	0.0	0	0	0	0	1
09/30/2021 12:00	0.0	0	0	0	0	1
09/30/2021 13:00	0.0	0	0	0	0	1
09/30/2021 14:00	0.0	0	0	0	0	1
09/30/2021 15:00	0.0	0	0	0	0	1
09/30/2021 16:00	0.0	0	0	0	0	1
09/30/2021 17:00	0.0	0	0	0	0	1
09/30/2021 18:00	0.0	0	0	0	0	1
09/30/2021 19:00	0.0	0	0	0	0	1
09/30/2021 20:00	0.0	0	0	0	0	1
09/30/2021 21:00	0.0	0	0	0	0	1
09/30/2021 22:00	0.0	0	0	0	0	1
09/30/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Pound Per Event Report

CT1 - CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:06 **Location:** Maxwell, CA

Tag Name: CT1_CO_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,765.08 Hours

Non-Operating Time: 442.92 Hours Report Time: 2,208.00 Hours

Unit Operation and Excess Events

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
07/10/2021 13:28 07/10/2021 16:14 Cold Start - Gas	167	179.2	1,355.6		
07/10/2021 23:36 07/10/2021 23:41 Shut Down - Gas	6	2.0	483.5		
07/11/2021 09:21 07/11/2021 11:35 Warm Start - Gas	135	140.4	790.5		
07/12/2021 01:07 07/12/2021 01:11 Shut Down - Gas	5	0.4	483.5		
07/12/2021 15:38 07/12/2021 16:36 Warm Start - Gas	59	89.1	790.5		
07/12/2021 22:48 07/12/2021 22:53 Shut Down - Gas	6	2.6	483.5		
07/13/2021 07:23 07/13/2021 09:51 Warm Start - Gas	149	129.4	790.5		
07/13/2021 09:52 07/13/2021 09:57 Shut Down - Gas	6	0.3	483.5		
07/13/2021 12:04 07/13/2021 13:36 Warm Start - Gas	93	288.5	790.5		
07/13/2021 13:39 07/13/2021 13:44 Shut Down - Gas	6	1.3	483.5		
07/13/2021 14:45 07/13/2021 16:29 Warm Start - Gas	105	474.1	790.5		
07/13/2021 21:51 07/13/2021 21:56 Shut Down - Gas	6	1.2	483.5		
07/14/2021 03:25 07/14/2021 04:15 Hot Start - Gas	51	214.4	679.6		

Pound Per Event Report

CT1 - CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:06 **Location:** Maxwell, CA

Tag Name: CT1_CO_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,765.08 Hours

Non-Operating Time: 442.92 Hours Report Time: 2,208.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
08/07/2021 03:23 08/07/2021 03:28 Shut Down - Gas	6	1.6	483.5		
08/07/2021 13:48 08/07/2021 14:50 Warm Start - Gas	63	90.3	790.5		
08/08/2021 04:04 08/08/2021 04:10 Shut Down - Gas	7	2.3	483.5		
08/08/2021 14:47 08/08/2021 15:50 Warm Start - Gas	64	90.9	790.5		
08/21/2021 00:08 08/21/2021 00:13 Shut Down - Gas	6	1.5	483.5		
08/23/2021 16:06 08/23/2021 17:55 Warm Start - Gas	110	135.4	790.5		
09/04/2021 03:24 09/04/2021 03:29 Shut Down - Gas	6	1.5	483.5		
09/04/2021 09:43 09/04/2021 10:47 Hot Start - Gas	65	79.0	679.6		
09/25/2021 22:21 09/25/2021 22:26 Shut Down - Gas	6	0.5	483.5		
09/29/2021 03:18 09/29/2021 03:53 Cold Start - Gas	36	41.6	1,355.6		
09/29/2021 03:54 09/29/2021 03:59 Shut Down - Gas	6	0.3	483.5		
09/29/2021 08:27 09/29/2021 09:51 Cold Start - Gas	85	70.9	1,355.6		

No excess emissions were found in the reporting period.

Pound Per Event Report

CT1 - CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:06 **Location:** Maxwell, CA

Tag Name: CT1_CO_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,765.08 Hours

Non-Operating Time: 442.92 Hours Report Time: 2,208.00 Hours

Event Invalid Information

No invalid events were found in the reporting period.

Pound Per Event Report

CT1 - CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:06 **Location:** Maxwell, CA

Tag Name: CT1_CO_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,765.08 Hours

Non-Operating Time: 442.92 Hours Report Time: 2,208.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary	
1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime in Minute(s)	0
3. Total Downtime as a percentage of operating time	0.00
4. Total Availability as a percentage of operating time	100.00

Pound Per Event Report

CT1 - NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/04/2021 11:07 **Location:** Maxwell, CA
Tag Name: CT1_NOx_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission
Total Operating Time: 1,765.08 Hours
Non-Operating Time: 442.92 Hours Report Time: 2,208.00 Hours

Unit Operation and Excess Events

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
07/10/2021 13:28 07/10/2021 16:14 Cold Start - Gas	167	112.48	779.10		
07/10/2021 23:36 07/10/2021 23:41 Shut Down - Gas	6	0.08	115.00		
07/11/2021 09:21 07/11/2021 11:35 Warm Start - Gas	135	70.44	456.20		
07/12/2021 01:07 07/12/2021 01:11 Shut Down - Gas	5	0.02	115.00		
07/12/2021 15:38 07/12/2021 16:36 Warm Start - Gas	59	48.94	456.20		
07/12/2021 22:48 07/12/2021 22:53 Shut Down - Gas	6	0.12	115.00		
07/13/2021 07:23 07/13/2021 09:51 Warm Start - Gas	149	37.33	456.20		
07/13/2021 09:52 07/13/2021 09:57 Shut Down - Gas	6	0.04	115.00		
07/13/2021 12:04 07/13/2021 13:36 Warm Start - Gas	93	26.97	456.20		
07/13/2021 13:39 07/13/2021 13:44 Shut Down - Gas	6	0.04	115.00		
07/13/2021 14:45 07/13/2021 16:29 Warm Start - Gas	105	34.38	456.20		
07/13/2021 21:51 07/13/2021 21:56 Shut Down - Gas	6	0.03	115.00		
07/14/2021 03:25 07/14/2021 04:15 Hot Start - Gas	51	14.04	259.90		

Pound Per Event Report

CT1 - NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/04/2021 11:07 **Location:** Maxwell, CA
Tag Name: CT1_NOx_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission
Total Operating Time: 1,765.08 Hours
Non-Operating Time: 442.92 Hours Report Time: 2,208.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
08/07/2021 03:23 08/07/2021 03:28 Shut Down - Gas	6	0.19	115.00		
08/07/2021 13:48 08/07/2021 14:50 Warm Start - Gas	63	44.28	456.20		
08/08/2021 04:04 08/08/2021 04:10 Shut Down - Gas	7	0.23	115.00		
08/08/2021 14:47 08/08/2021 15:50 Warm Start - Gas	64	50.26	456.20		
08/21/2021 00:08 08/21/2021 00:13 Shut Down - Gas	6	0.26	115.00		
08/23/2021 16:06 08/23/2021 17:55 Warm Start - Gas	110	110.81	456.20		
09/04/2021 03:24 09/04/2021 03:29 Shut Down - Gas	6	0.39	115.00		
09/04/2021 09:43 09/04/2021 10:47 Hot Start - Gas	65	30.01	259.90		
09/25/2021 22:21 09/25/2021 22:26 Shut Down - Gas	6	0.14	115.00		
09/29/2021 03:18 09/29/2021 03:53 Cold Start - Gas	36	43.07	779.10		
09/29/2021 03:54 09/29/2021 03:59 Shut Down - Gas	6	1.03	115.00		
09/29/2021 08:27 09/29/2021 09:51 Cold Start - Gas	85	62.35	779.10		

No excess emissions were found in the reporting period.

Pound Per Event Report

CT1 - NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:07 **Location:** Maxwell, CA

Tag Name: CT1_NOx_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,765.08 Hours

Non-Operating Time: 442.92 Hours Report Time: 2,208.00 Hours

Event Invalid Information

No invalid events were found in the reporting period.

Pound Per Event Report

CT1 - NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:07 **Location:** Maxwell, CA

Tag Name: CT1_NOx_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,765.08 Hours

Non-Operating Time: 442.92 Hours Report Time: 2,208.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary	
1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime in Minute(s)	0
3. Total Downtime as a percentage of operating time	0.00
4. Total Availability as a percentage of operating time	100.00

100scf Per Event Report

CT2 - GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:08 **Location:** Maxwell, CA

Tag Name: CT2_GasFlowTot_Event_100scf_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,765.25 Hours

Non-Operating Time: 442.75 Hours Report Time: 2,208.00 Hours

Unit Operation and Excess Events

Event Period			Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Code - Description	Code - Description
07/10/2021 16:39 07/10/2021 17:21 Cold Start - Gas	43	25.2		
07/10/2021 17:22 07/10/2021 17:27 Shut Down - Gas	6	0.4		
07/12/2021 07:18 07/12/2021 09:56 Warm Start - Gas	159	190.7		
07/13/2021 02:20 07/13/2021 02:25 Shut Down - Gas	6	0.5		
07/13/2021 17:22 07/13/2021 18:38 Warm Start - Gas	77	122.2		
08/03/2021 04:40 08/03/2021 04:40 Shut Down - Gas	1	2.8		
08/03/2021 11:10 08/03/2021 12:05 Hot Start - Gas	56	100.5		
08/07/2021 03:23 08/07/2021 03:28 Shut Down - Gas	6	0.8		
08/07/2021 09:47 08/07/2021 11:15 Hot Start - Gas	89	128.8		
08/07/2021 11:21 08/07/2021 11:26 Shut Down - Gas	6	0.6		
08/07/2021 12:04 08/07/2021 12:54 Hot Start - Gas	51	92.8		
08/21/2021 00:08 08/21/2021 00:13 Shut Down - Gas	6	1.0		
08/21/2021 01:37 08/21/2021 02:21 Hot Start - Gas	45	80.4		

100scf Per Event Report

CT2 - GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:08 **Location:** Maxwell, CA

Tag Name: CT2_GasFlowTot_Event_100scf_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,765.25 Hours

Non-Operating Time: 442.75 Hours Report Time: 2,208.00 Hours

Event Period			Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Code - Description	Code - Description
08/21/2021 15:41 08/21/2021 15:46 Shut Down - Gas	6	0.3		
08/23/2021 09:18 08/23/2021 11:56 Warm Start - Gas	159	221.5		
08/23/2021 12:30 08/23/2021 12:35 Shut Down - Gas	6	0.2		
08/23/2021 13:25 08/23/2021 14:25 Hot Start - Gas	61	112.7		
09/04/2021 03:25 09/04/2021 03:29 Shut Down - Gas	5	0.2		
09/04/2021 13:33 09/04/2021 14:28 Warm Start - Gas	56	97.1		
09/16/2021 01:21 09/16/2021 01:26 Shut Down - Gas	6	1.0		
09/16/2021 12:48 09/16/2021 13:51 Warm Start - Gas	64	104.8		
09/17/2021 02:04 09/17/2021 02:09 Shut Down - Gas	6	0.6		
09/17/2021 13:36 09/17/2021 14:50 Warm Start - Gas	75	113.2		
09/18/2021 00:04 09/18/2021 00:08 Shut Down - Gas	5	0.4		
09/20/2021 01:42 09/20/2021 03:08 Warm Start - Gas	87	120.5		
09/30/2021 06:05 09/30/2021 06:10 Shut Down - Gas	6	0.4		

No excess emissions were found in the reporting period.

100scf Per Event Report

CT2 - GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:08 **Location:** Maxwell, CA

Tag Name: CT2_GasFlowTot_Event_100scf_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,765.25 Hours

Non-Operating Time: 442.75 Hours Report Time: 2,208.00 Hours

Event Invalid Information

No invalid events were found in the reporting period.

100scf Per Event Report

CT2 - GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:08 **Location:** Maxwell, CA

Tag Name: CT2_GasFlowTot_Event_100scf_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,765.25 Hours

Non-Operating Time: 442.75 Hours Report Time: 2,208.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary	
1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime in Minute(s)	0
3. Total Downtime as a percentage of operating time	0.00
4. Total Availability as a percentage of operating time	100.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/01/2021 00:00	0.0	0	0	0	0	0
07/01/2021 01:00	0.0	0	0	0	0	0
07/01/2021 02:00	0.0	0	0	0	0	0
07/01/2021 03:00	0.0	0	0	0	0	0
07/01/2021 04:00	0.0	0	0	0	0	0
07/01/2021 05:00	0.0	0	0	0	0	0
07/01/2021 06:00	0.0	0	0	0	0	0
07/01/2021 07:00	0.0	0	0	0	0	0
07/01/2021 08:00	0.0	0	0	0	0	0
07/01/2021 09:00	0.0	0	0	0	0	0
07/01/2021 10:00	0.0	0	0	0	0	0
07/01/2021 11:00	0.0	0	0	0	0	0
07/01/2021 12:00	0.0	0	0	0	0	0
07/01/2021 13:00	0.0	0	0	0	0	0
07/01/2021 14:00	0.0	0	0	0	0	0
07/01/2021 15:00	0.0	0	0	0	0	0
07/01/2021 16:00	0.0	0	0	0	0	0
07/01/2021 17:00	0.0	0	0	0	0	0
07/01/2021 18:00	0.0	0	0	0	0	0
07/01/2021 19:00	0.0	0	0	0	0	0
07/01/2021 20:00	0.0	0	0	0	0	0
07/01/2021 21:00	0.0	0	0	0	0	0
07/01/2021 22:00	0.0	0	0	0	0	0
07/01/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/02/2021 00:00	0.0	0	0	0	0	0
07/02/2021 01:00	0.0	0	0	0	0	0
07/02/2021 02:00	0.0	0	0	0	0	0
07/02/2021 03:00	0.0	0	0	0	0	0
07/02/2021 04:00	0.0	0	0	0	0	0
07/02/2021 05:00	0.0	0	0	0	0	0
07/02/2021 06:00	0.0	0	0	0	0	0
07/02/2021 07:00	0.0	0	0	0	0	0
07/02/2021 08:00	0.0	0	0	0	0	0
07/02/2021 09:00	0.0	0	0	0	0	0
07/02/2021 10:00	0.0	0	0	0	0	0
07/02/2021 11:00	0.0	0	0	0	0	0
07/02/2021 12:00	0.0	0	0	0	0	0
07/02/2021 13:00	0.0	0	0	0	0	0
07/02/2021 14:00	0.0	0	0	0	0	0
07/02/2021 15:00	0.0	0	0	0	0	0
07/02/2021 16:00	0.0	0	0	0	0	0
07/02/2021 17:00	0.0	0	0	0	0	0
07/02/2021 18:00	0.0	0	0	0	0	0
07/02/2021 19:00	0.0	0	0	0	0	0
07/02/2021 20:00	0.0	0	0	0	0	0
07/02/2021 21:00	0.0	0	0	0	0	0
07/02/2021 22:00	0.0	0	0	0	0	0
07/02/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/03/2021 00:00	0.0	0	0	0	0	0
07/03/2021 01:00	0.0	0	0	0	0	0
07/03/2021 02:00	0.0	0	0	0	0	0
07/03/2021 03:00	0.0	0	0	0	0	0
07/03/2021 04:00	0.0	0	0	0	0	0
07/03/2021 05:00	0.0	0	0	0	0	0
07/03/2021 06:00	0.0	0	0	0	0	0
07/03/2021 07:00	0.0	0	0	0	0	0
07/03/2021 08:00	0.0	0	0	0	0	0
07/03/2021 09:00	0.0	0	0	0	0	0
07/03/2021 10:00	0.0	0	0	0	0	0
07/03/2021 11:00	0.0	0	0	0	0	0
07/03/2021 12:00	0.0	0	0	0	0	0
07/03/2021 13:00	0.0	0	0	0	0	0
07/03/2021 14:00	0.0	0	0	0	0	0
07/03/2021 15:00	0.0	0	0	0	0	0
07/03/2021 16:00	0.0	0	0	0	0	0
07/03/2021 17:00	0.0	0	0	0	0	0
07/03/2021 18:00	0.0	0	0	0	0	0
07/03/2021 19:00	0.0	0	0	0	0	0
07/03/2021 20:00	0.0	0	0	0	0	0
07/03/2021 21:00	0.0	0	0	0	0	0
07/03/2021 22:00	0.0	0	0	0	0	0
07/03/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/04/2021 00:00	0.0	0	0	0	0	0
07/04/2021 01:00	0.0	0	0	0	0	0
07/04/2021 02:00	0.0	0	0	0	0	0
07/04/2021 03:00	0.0	0	0	0	0	0
07/04/2021 04:00	0.0	0	0	0	0	0
07/04/2021 05:00	0.0	0	0	0	0	0
07/04/2021 06:00	0.0	0	0	0	0	0
07/04/2021 07:00	0.0	0	0	0	0	0
07/04/2021 08:00	0.0	0	0	0	0	0
07/04/2021 09:00	0.0	0	0	0	0	0
07/04/2021 10:00	0.0	0	0	0	0	0
07/04/2021 11:00	0.0	0	0	0	0	0
07/04/2021 12:00	0.0	0	0	0	0	0
07/04/2021 13:00	0.0	0	0	0	0	0
07/04/2021 14:00	0.0	0	0	0	0	0
07/04/2021 15:00	0.0	0	0	0	0	0
07/04/2021 16:00	0.0	0	0	0	0	0
07/04/2021 17:00	0.0	0	0	0	0	0
07/04/2021 18:00	0.0	0	0	0	0	0
07/04/2021 19:00	0.0	0	0	0	0	0
07/04/2021 20:00	0.0	0	0	0	0	0
07/04/2021 21:00	0.0	0	0	0	0	0
07/04/2021 22:00	0.0	0	0	0	0	0
07/04/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/05/2021 00:00	0.0	0	0	0	0	0
07/05/2021 01:00	0.0	0	0	0	0	0
07/05/2021 02:00	0.0	0	0	0	0	0
07/05/2021 03:00	0.0	0	0	0	0	0
07/05/2021 04:00	0.0	0	0	0	0	0
07/05/2021 05:00	0.0	0	0	0	0	0
07/05/2021 06:00	0.0	0	0	0	0	0
07/05/2021 07:00	0.0	0	0	0	0	0
07/05/2021 08:00	0.0	0	0	0	0	0
07/05/2021 09:00	0.0	0	0	0	0	0
07/05/2021 10:00	0.0	0	0	0	0	0
07/05/2021 11:00	0.0	0	0	0	0	0
07/05/2021 12:00	0.0	0	0	0	0	0
07/05/2021 13:00	0.0	0	0	0	0	0
07/05/2021 14:00	0.0	0	0	0	0	0
07/05/2021 15:00	0.0	0	0	0	0	0
07/05/2021 16:00	0.0	0	0	0	0	0
07/05/2021 17:00	0.0	0	0	0	0	0
07/05/2021 18:00	0.0	0	0	0	0	0
07/05/2021 19:00	0.0	0	0	0	0	0
07/05/2021 20:00	0.0	0	0	0	0	0
07/05/2021 21:00	0.0	0	0	0	0	0
07/05/2021 22:00	0.0	0	0	0	0	0
07/05/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/06/2021 00:00	0.0	0	0	0	0	0
07/06/2021 01:00	0.0	0	0	0	0	0
07/06/2021 02:00	0.0	0	0	0	0	0
07/06/2021 03:00	0.0	0	0	0	0	0
07/06/2021 04:00	0.0	0	0	0	0	0
07/06/2021 05:00	0.0	0	0	0	0	0
07/06/2021 06:00	0.0	0	0	0	0	0
07/06/2021 07:00	0.0	0	0	0	0	0
07/06/2021 08:00	0.0	0	0	0	0	0
07/06/2021 09:00	0.0	0	0	0	0	0
07/06/2021 10:00	0.0	0	0	0	0	0
07/06/2021 11:00	0.0	0	0	0	0	0
07/06/2021 12:00	0.0	0	0	0	0	0
07/06/2021 13:00	0.0	0	0	0	0	0
07/06/2021 14:00	0.0	0	0	0	0	0
07/06/2021 15:00	0.0	0	0	0	0	0
07/06/2021 16:00	0.0	0	0	0	0	0
07/06/2021 17:00	0.0	0	0	0	0	0
07/06/2021 18:00	0.0	0	0	0	0	0
07/06/2021 19:00	0.0	0	0	0	0	0
07/06/2021 20:00	0.0	0	0	0	0	0
07/06/2021 21:00	0.0	0	0	0	0	0
07/06/2021 22:00	0.0	0	0	0	0	0
07/06/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/07/2021 00:00	0.0	0	0	0	0	0
07/07/2021 01:00	0.0	0	0	0	0	0
07/07/2021 02:00	0.0	0	0	0	0	0
07/07/2021 03:00	0.0	0	0	0	0	0
07/07/2021 04:00	0.0	0	0	0	0	0
07/07/2021 05:00	0.0	0	0	0	0	0
07/07/2021 06:00	0.0	0	0	0	0	0
07/07/2021 07:00	0.0	0	0	0	0	0
07/07/2021 08:00	0.0	0	0	0	0	0
07/07/2021 09:00	0.0	0	0	0	0	0
07/07/2021 10:00	0.0	0	0	0	0	0
07/07/2021 11:00	0.0	0	0	0	0	0
07/07/2021 12:00	0.0	0	0	0	0	0
07/07/2021 13:00	0.0	0	0	0	0	0
07/07/2021 14:00	0.0	0	0	0	0	0
07/07/2021 15:00	0.0	0	0	0	0	0
07/07/2021 16:00	0.0	0	0	0	0	0
07/07/2021 17:00	0.0	0	0	0	0	0
07/07/2021 18:00	0.0	0	0	0	0	0
07/07/2021 19:00	0.0	0	0	0	0	0
07/07/2021 20:00	0.0	0	0	0	0	0
07/07/2021 21:00	0.0	0	0	0	0	0
07/07/2021 22:00	0.0	0	0	0	0	0
07/07/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/08/2021 00:00	0.0	0	0	0	0	0
07/08/2021 01:00	0.0	0	0	0	0	0
07/08/2021 02:00	0.0	0	0	0	0	0
07/08/2021 03:00	0.0	0	0	0	0	0
07/08/2021 04:00	0.0	0	0	0	0	0
07/08/2021 05:00	0.0	0	0	0	0	0
07/08/2021 06:00	0.0	0	0	0	0	0
07/08/2021 07:00	0.0	0	0	0	0	0
07/08/2021 08:00	0.0	0	0	0	0	0
07/08/2021 09:00	0.0	0	0	0	0	0
07/08/2021 10:00	0.0	0	0	0	0	0
07/08/2021 11:00	0.0	0	0	0	0	0
07/08/2021 12:00	0.0	0	0	0	0	0
07/08/2021 13:00	0.0	0	0	0	0	0
07/08/2021 14:00	0.0	0	0	0	0	0
07/08/2021 15:00	0.0	0	0	0	0	0
07/08/2021 16:00	0.0	0	0	0	0	0
07/08/2021 17:00	0.0	0	0	0	0	0
07/08/2021 18:00	0.0	0	0	0	0	0
07/08/2021 19:00	0.0	0	0	0	0	0
07/08/2021 20:00	0.0	0	0	0	0	0
07/08/2021 21:00	0.0	0	0	0	0	0
07/08/2021 22:00	0.0	0	0	0	0	0
07/08/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/09/2021 00:00	0.0	0	0	0	0	0
07/09/2021 01:00	0.0	0	0	0	0	0
07/09/2021 02:00	0.0	0	0	0	0	0
07/09/2021 03:00	0.0	0	0	0	0	0
07/09/2021 04:00	0.0	0	0	0	0	0
07/09/2021 05:00	0.0	0	0	0	0	0
07/09/2021 06:00	0.0	0	0	0	0	0
07/09/2021 07:00	0.0	0	0	0	0	0
07/09/2021 08:00	0.0	0	0	0	0	0
07/09/2021 09:00	0.0	0	0	0	0	0
07/09/2021 10:00	0.0	0	0	0	0	0
07/09/2021 11:00	0.0	0	0	0	0	0
07/09/2021 12:00	0.0	0	0	0	0	0
07/09/2021 13:00	0.0	0	0	0	0	0
07/09/2021 14:00	0.0	0	0	0	0	0
07/09/2021 15:00	0.0	0	0	0	0	0
07/09/2021 16:00	0.0	0	0	0	0	0
07/09/2021 17:00	0.0	0	0	0	0	0
07/09/2021 18:00	0.0	0	0	0	0	0
07/09/2021 19:00	0.0	0	0	0	0	0
07/09/2021 20:00	0.0	0	0	0	0	0
07/09/2021 21:00	0.0	0	0	0	0	0
07/09/2021 22:00	0.0	0	0	0	0	0
07/09/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/10/2021 00:00	0.0	0	0	0	0	0
07/10/2021 01:00	0.0	0	0	0	0	0
07/10/2021 02:00	0.0	0	0	0	0	0
07/10/2021 03:00	0.0	0	0	0	0	0
07/10/2021 04:00	0.0	0	0	0	0	0
07/10/2021 05:00	0.0	0	0	0	0	0
07/10/2021 06:00	0.0	0	0	0	0	0
07/10/2021 07:00	0.0	0	0	0	0	0
07/10/2021 08:00	0.0	0	0	0	0	0
07/10/2021 09:00	0.0	0	0	0	0	0
07/10/2021 10:00	0.0	0	0	0	0	0
07/10/2021 11:00	0.0	0	0	0	0	0
07/10/2021 12:00	0.0	0	0	0	0	0
07/10/2021 13:00	0.0	0	0	0	0	0
07/10/2021 14:00	0.0	0	0	0	0	0
07/10/2021 15:00	0.0	0	0	0	0	0
07/10/2021 16:00	27.8	1	0	0	0	0
07/10/2021 17:00	3.3	1	0	0	1	0
07/10/2021 18:00	0.0	0	0	0	0	0
07/10/2021 19:00	0.0	0	0	0	0	0
07/10/2021 20:00	0.0	0	0	0	0	0
07/10/2021 21:00	0.0	0	0	0	0	0
07/10/2021 22:00	0.0	0	0	0	0	0
07/10/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	31.1 #	2 #	0 #	0 #	1 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	27.8	1	0	0	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/11/2021 00:00	0.0	0	0	0	0	0
07/11/2021 01:00	0.0	0	0	0	0	0
07/11/2021 02:00	0.0	0	0	0	0	0
07/11/2021 03:00	0.0	0	0	0	0	0
07/11/2021 04:00	0.0	0	0	0	0	0
07/11/2021 05:00	0.0	0	0	0	0	0
07/11/2021 06:00	0.0	0	0	0	0	0
07/11/2021 07:00	0.0	0	0	0	0	0
07/11/2021 08:00	0.0	0	0	0	0	0
07/11/2021 09:00	0.0	0	0	0	0	0
07/11/2021 10:00	0.0	0	0	0	0	0
07/11/2021 11:00	0.0	0	0	0	0	0
07/11/2021 12:00	0.0	0	0	0	0	0
07/11/2021 13:00	0.0	0	0	0	0	0
07/11/2021 14:00	0.0	0	0	0	0	0
07/11/2021 15:00	0.0	0	0	0	0	0
07/11/2021 16:00	0.0	0	0	0	0	0
07/11/2021 17:00	0.0	0	0	0	0	0
07/11/2021 18:00	0.0	0	0	0	0	0
07/11/2021 19:00	0.0	0	0	0	0	0
07/11/2021 20:00	0.0	0	0	0	0	0
07/11/2021 21:00	0.0	0	0	0	0	0
07/11/2021 22:00	0.0	0	0	0	0	0
07/11/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/12/2021 00:00	0.0	0	0	0	0	0
07/12/2021 01:00	0.0	0	0	0	0	0
07/12/2021 02:00	0.0	0	0	0	0	0
07/12/2021 03:00	0.0	0	0	0	0	0
07/12/2021 04:00	0.0	0	0	0	0	0
07/12/2021 05:00	0.0	0	0	0	0	0
07/12/2021 06:00	0.0	0	0	0	0	0
07/12/2021 07:00	9.0	0	1	0	0	0
07/12/2021 08:00	5.7	0	1	0	0	0
07/12/2021 09:00	11.8	0	1	0	0	0
07/12/2021 10:00	0.0	0	0	0	0	1
07/12/2021 11:00	0.0	0	0	0	0	1
07/12/2021 12:00	0.0	0	0	0	0	1
07/12/2021 13:00	0.0	0	0	0	0	1
07/12/2021 14:00	0.0	0	0	0	0	1
07/12/2021 15:00	0.0	0	0	0	0	1
07/12/2021 16:00	0.0	0	0	0	0	1
07/12/2021 17:00	0.0	0	0	0	0	1
07/12/2021 18:00	0.0	0	0	0	0	1
07/12/2021 19:00	0.0	0	0	0	0	1
07/12/2021 20:00	0.0	0	0	0	0	1
07/12/2021 21:00	0.0	0	0	0	0	1
07/12/2021 22:00	0.0	0	0	0	0	1
07/12/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	26.5 #	0 #	3 #	0 #	0 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	11.8	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/13/2021 00:00	0.0	0	0	0	0	1
07/13/2021 01:00	0.0	0	0	0	0	1
07/13/2021 02:00	3.2	0	0	0	1	0
07/13/2021 03:00	0.0	0	0	0	0	0
07/13/2021 04:00	0.0	0	0	0	0	0
07/13/2021 05:00	0.0	0	0	0	0	0
07/13/2021 06:00	0.0	0	0	0	0	0
07/13/2021 07:00	0.0	0	0	0	0	0
07/13/2021 08:00	0.0	0	0	0	0	0
07/13/2021 09:00	0.0	0	0	0	0	0
07/13/2021 10:00	0.0	0	0	0	0	0
07/13/2021 11:00	0.0	0	0	0	0	0
07/13/2021 12:00	0.0	0	0	0	0	0
07/13/2021 13:00	0.0	0	0	0	0	0
07/13/2021 14:00	0.0	0	0	0	0	0
07/13/2021 15:00	0.0	0	0	0	0	0
07/13/2021 16:00	0.0	0	0	0	0	0
07/13/2021 17:00	53.7	0	1	0	0	0
07/13/2021 18:00	69.7	0	1	0	0	0
07/13/2021 19:00	0.0	0	0	0	0	1
07/13/2021 20:00	0.0	0	0	0	0	1
07/13/2021 21:00	0.0	0	0	0	0	1
07/13/2021 22:00	0.0	0	0	0	0	1
07/13/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	126.6 #	0 #	2 #	0 #	1 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	69.7	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/14/2021 00:00	0.0	0	0	0	0	1
07/14/2021 01:00	0.0	0	0	0	0	1
07/14/2021 02:00	0.0	0	0	0	0	1
07/14/2021 03:00	0.0	0	0	0	0	1
07/14/2021 04:00	0.0	0	0	0	0	1
07/14/2021 05:00	0.0	0	0	0	0	1
07/14/2021 06:00	0.0	0	0	0	0	1
07/14/2021 07:00	0.0	0	0	0	0	1
07/14/2021 08:00	0.0	0	0	0	0	1
07/14/2021 09:00	0.0	0	0	0	0	1
07/14/2021 10:00	0.0	0	0	0	0	1
07/14/2021 11:00	0.0	0	0	0	0	1
07/14/2021 12:00	0.0	0	0	0	0	1
07/14/2021 13:00	0.0	0	0	0	0	1
07/14/2021 14:00	0.0	0	0	0	0	1
07/14/2021 15:00	0.0	0	0	0	0	1
07/14/2021 16:00	0.0	0	0	0	0	1
07/14/2021 17:00	0.0	0	0	0	0	1
07/14/2021 18:00	0.0	0	0	0	0	1
07/14/2021 19:00	0.0	0	0	0	0	1
07/14/2021 20:00	0.0	0	0	0	0	1
07/14/2021 21:00	0.0	0	0	0	0	1
07/14/2021 22:00	0.0	0	0	0	0	1
07/14/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/15/2021 00:00	0.0	0	0	0	0	1
07/15/2021 01:00	0.0	0	0	0	0	1
07/15/2021 02:00	0.0	0	0	0	0	1
07/15/2021 03:00	0.0	0	0	0	0	1
07/15/2021 04:00	0.0	0	0	0	0	1
07/15/2021 05:00	0.0	0	0	0	0	1
07/15/2021 06:00	0.0	0	0	0	0	1
07/15/2021 07:00	0.0	0	0	0	0	1
07/15/2021 08:00	0.0	0	0	0	0	1
07/15/2021 09:00	0.0	0	0	0	0	1
07/15/2021 10:00	0.0	0	0	0	0	1
07/15/2021 11:00	0.0	0	0	0	0	1
07/15/2021 12:00	0.0	0	0	0	0	1
07/15/2021 13:00	0.0	0	0	0	0	1
07/15/2021 14:00	0.0	0	0	0	0	1
07/15/2021 15:00	0.0	0	0	0	0	1
07/15/2021 16:00	0.0	0	0	0	0	1
07/15/2021 17:00	0.0	0	0	0	0	1
07/15/2021 18:00	0.0	0	0	0	0	1
07/15/2021 19:00	0.0	0	0	0	0	1
07/15/2021 20:00	0.0	0	0	0	0	1
07/15/2021 21:00	0.0	0	0	0	0	1
07/15/2021 22:00	0.0	0	0	0	0	1
07/15/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/16/2021 00:00	0.0	0	0	0	0	1
07/16/2021 01:00	0.0	0	0	0	0	1
07/16/2021 02:00	0.0	0	0	0	0	1
07/16/2021 03:00	0.0	0	0	0	0	1
07/16/2021 04:00	0.0	0	0	0	0	1
07/16/2021 05:00	0.0	0	0	0	0	1
07/16/2021 06:00	0.0	0	0	0	0	1
07/16/2021 07:00	0.0	0	0	0	0	1
07/16/2021 08:00	0.0	0	0	0	0	1
07/16/2021 09:00	0.0	0	0	0	0	1
07/16/2021 10:00	0.0	0	0	0	0	1
07/16/2021 11:00	0.0	0	0	0	0	1
07/16/2021 12:00	0.0	0	0	0	0	1
07/16/2021 13:00	0.0	0	0	0	0	1
07/16/2021 14:00	0.0	0	0	0	0	1
07/16/2021 15:00	0.0	0	0	0	0	1
07/16/2021 16:00	0.0	0	0	0	0	1
07/16/2021 17:00	0.0	0	0	0	0	1
07/16/2021 18:00	0.0	0	0	0	0	1
07/16/2021 19:00	0.0	0	0	0	0	1
07/16/2021 20:00	0.0	0	0	0	0	1
07/16/2021 21:00	0.0	0	0	0	0	1
07/16/2021 22:00	0.0	0	0	0	0	1
07/16/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/17/2021 00:00	0.0	0	0	0	0	1
07/17/2021 01:00	0.0	0	0	0	0	1
07/17/2021 02:00	0.0	0	0	0	0	1
07/17/2021 03:00	0.0	0	0	0	0	1
07/17/2021 04:00	0.0	0	0	0	0	1
07/17/2021 05:00	0.0	0	0	0	0	1
07/17/2021 06:00	0.0	0	0	0	0	1
07/17/2021 07:00	0.0	0	0	0	0	1
07/17/2021 08:00	0.0	0	0	0	0	1
07/17/2021 09:00	0.0	0	0	0	0	1
07/17/2021 10:00	0.0	0	0	0	0	1
07/17/2021 11:00	0.0	0	0	0	0	1
07/17/2021 12:00	0.0	0	0	0	0	1
07/17/2021 13:00	0.0	0	0	0	0	1
07/17/2021 14:00	0.0	0	0	0	0	1
07/17/2021 15:00	0.0	0	0	0	0	1
07/17/2021 16:00	0.0	0	0	0	0	1
07/17/2021 17:00	0.0	0	0	0	0	1
07/17/2021 18:00	0.0	0	0	0	0	1
07/17/2021 19:00	0.0	0	0	0	0	1
07/17/2021 20:00	0.0	0	0	0	0	1
07/17/2021 21:00	0.0	0	0	0	0	1
07/17/2021 22:00	0.0	0	0	0	0	1
07/17/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/18/2021 00:00	0.0	0	0	0	0	1
07/18/2021 01:00	0.0	0	0	0	0	1
07/18/2021 02:00	0.0	0	0	0	0	1
07/18/2021 03:00	0.0	0	0	0	0	1
07/18/2021 04:00	0.0	0	0	0	0	1
07/18/2021 05:00	0.0	0	0	0	0	1
07/18/2021 06:00	0.0	0	0	0	0	1
07/18/2021 07:00	0.0	0	0	0	0	1
07/18/2021 08:00	0.0	0	0	0	0	1
07/18/2021 09:00	0.0	0	0	0	0	1
07/18/2021 10:00	0.0	0	0	0	0	1
07/18/2021 11:00	0.0	0	0	0	0	1
07/18/2021 12:00	0.0	0	0	0	0	1
07/18/2021 13:00	0.0	0	0	0	0	1
07/18/2021 14:00	0.0	0	0	0	0	1
07/18/2021 15:00	0.0	0	0	0	0	1
07/18/2021 16:00	0.0	0	0	0	0	1
07/18/2021 17:00	0.0	0	0	0	0	1
07/18/2021 18:00	0.0	0	0	0	0	1
07/18/2021 19:00	0.0	0	0	0	0	1
07/18/2021 20:00	0.0	0	0	0	0	1
07/18/2021 21:00	0.0	0	0	0	0	1
07/18/2021 22:00	0.0	0	0	0	0	1
07/18/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/19/2021 00:00	0.0	0	0	0	0	1
07/19/2021 01:00	0.0	0	0	0	0	1
07/19/2021 02:00	0.0	0	0	0	0	1
07/19/2021 03:00	0.0	0	0	0	0	1
07/19/2021 04:00	0.0	0	0	0	0	1
07/19/2021 05:00	0.0	0	0	0	0	1
07/19/2021 06:00	0.0	0	0	0	0	1
07/19/2021 07:00	0.0	0	0	0	0	1
07/19/2021 08:00	0.0	0	0	0	0	1
07/19/2021 09:00	0.0	0	0	0	0	1
07/19/2021 10:00	0.0	0	0	0	0	1
07/19/2021 11:00	0.0	0	0	0	0	1
07/19/2021 12:00	0.0	0	0	0	0	1
07/19/2021 13:00	0.0	0	0	0	0	1
07/19/2021 14:00	0.0	0	0	0	0	1
07/19/2021 15:00	0.0	0	0	0	0	1
07/19/2021 16:00	0.0	0	0	0	0	1
07/19/2021 17:00	0.0	0	0	0	0	1
07/19/2021 18:00	0.0	0	0	0	0	1
07/19/2021 19:00	0.0	0	0	0	0	1
07/19/2021 20:00	0.0	0	0	0	0	1
07/19/2021 21:00	0.0	0	0	0	0	1
07/19/2021 22:00	0.0	0	0	0	0	1
07/19/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/20/2021 00:00	0.0	0	0	0	0	1
07/20/2021 01:00	0.0	0	0	0	0	1
07/20/2021 02:00	0.0	0	0	0	0	1
07/20/2021 03:00	0.0	0	0	0	0	1
07/20/2021 04:00	0.0	0	0	0	0	1
07/20/2021 05:00	0.0	0	0	0	0	1
07/20/2021 06:00	0.0	0	0	0	0	1
07/20/2021 07:00	0.0	0	0	0	0	1
07/20/2021 08:00	0.0	0	0	0	0	1
07/20/2021 09:00	0.0	0	0	0	0	1
07/20/2021 10:00	0.0	0	0	0	0	1
07/20/2021 11:00	0.0	0	0	0	0	1
07/20/2021 12:00	0.0	0	0	0	0	1
07/20/2021 13:00	0.0	0	0	0	0	1
07/20/2021 14:00	0.0	0	0	0	0	1
07/20/2021 15:00	0.0	0	0	0	0	1
07/20/2021 16:00	0.0	0	0	0	0	1
07/20/2021 17:00	0.0	0	0	0	0	1
07/20/2021 18:00	0.0	0	0	0	0	1
07/20/2021 19:00	0.0	0	0	0	0	1
07/20/2021 20:00	0.0	0	0	0	0	1
07/20/2021 21:00	0.0	0	0	0	0	1
07/20/2021 22:00	0.0	0	0	0	0	1
07/20/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/21/2021 00:00	0.0	0	0	0	0	1
07/21/2021 01:00	0.0	0	0	0	0	1
07/21/2021 02:00	0.0	0	0	0	0	1
07/21/2021 03:00	0.0	0	0	0	0	1
07/21/2021 04:00	0.0	0	0	0	0	1
07/21/2021 05:00	0.0	0	0	0	0	1
07/21/2021 06:00	0.0	0	0	0	0	1
07/21/2021 07:00	0.0	0	0	0	0	1
07/21/2021 08:00	0.0	0	0	0	0	1
07/21/2021 09:00	0.0	0	0	0	0	1
07/21/2021 10:00	0.0	0	0	0	0	1
07/21/2021 11:00	0.0	0	0	0	0	1
07/21/2021 12:00	0.0	0	0	0	0	1
07/21/2021 13:00	0.0	0	0	0	0	1
07/21/2021 14:00	0.0	0	0	0	0	1
07/21/2021 15:00	0.0	0	0	0	0	1
07/21/2021 16:00	0.0	0	0	0	0	1
07/21/2021 17:00	0.0	0	0	0	0	1
07/21/2021 18:00	0.0	0	0	0	0	1
07/21/2021 19:00	0.0	0	0	0	0	1
07/21/2021 20:00	0.0	0	0	0	0	1
07/21/2021 21:00	0.0	0	0	0	0	1
07/21/2021 22:00	0.0	0	0	0	0	1
07/21/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/22/2021 00:00	0.0	0	0	0	0	1
07/22/2021 01:00	0.0	0	0	0	0	1
07/22/2021 02:00	0.0	0	0	0	0	1
07/22/2021 03:00	0.0	0	0	0	0	1
07/22/2021 04:00	0.0	0	0	0	0	1
07/22/2021 05:00	0.0	0	0	0	0	1
07/22/2021 06:00	0.0	0	0	0	0	1
07/22/2021 07:00	0.0	0	0	0	0	1
07/22/2021 08:00	0.0	0	0	0	0	1
07/22/2021 09:00	0.0	0	0	0	0	1
07/22/2021 10:00	0.0	0	0	0	0	1
07/22/2021 11:00	0.0	0	0	0	0	1
07/22/2021 12:00	0.0	0	0	0	0	1
07/22/2021 13:00	0.0	0	0	0	0	1
07/22/2021 14:00	0.0	0	0	0	0	1
07/22/2021 15:00	0.0	0	0	0	0	1
07/22/2021 16:00	0.0	0	0	0	0	1
07/22/2021 17:00	0.0	0	0	0	0	1
07/22/2021 18:00	0.0	0	0	0	0	1
07/22/2021 19:00	0.0	0	0	0	0	1
07/22/2021 20:00	0.0	0	0	0	0	1
07/22/2021 21:00	0.0	0	0	0	0	1
07/22/2021 22:00	0.0	0	0	0	0	1
07/22/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/23/2021 00:00	0.0	0	0	0	0	1
07/23/2021 01:00	0.0	0	0	0	0	1
07/23/2021 02:00	0.0	0	0	0	0	1
07/23/2021 03:00	0.0	0	0	0	0	1
07/23/2021 04:00	0.0	0	0	0	0	1
07/23/2021 05:00	0.0	0	0	0	0	1
07/23/2021 06:00	0.0	0	0	0	0	1
07/23/2021 07:00	0.0	0	0	0	0	1
07/23/2021 08:00	0.0	0	0	0	0	1
07/23/2021 09:00	0.0	0	0	0	0	1
07/23/2021 10:00	0.0	0	0	0	0	1
07/23/2021 11:00	0.0	0	0	0	0	1
07/23/2021 12:00	0.0	0	0	0	0	1
07/23/2021 13:00	0.0	0	0	0	0	1
07/23/2021 14:00	0.0	0	0	0	0	1
07/23/2021 15:00	0.0	0	0	0	0	1
07/23/2021 16:00	0.0	0	0	0	0	1
07/23/2021 17:00	0.0	0	0	0	0	1
07/23/2021 18:00	0.0	0	0	0	0	1
07/23/2021 19:00	0.0	0	0	0	0	1
07/23/2021 20:00	0.0	0	0	0	0	1
07/23/2021 21:00	0.0	0	0	0	0	1
07/23/2021 22:00	0.0	0	0	0	0	1
07/23/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/24/2021 00:00	0.0	0	0	0	0	1
07/24/2021 01:00	0.0	0	0	0	0	1
07/24/2021 02:00	0.0	0	0	0	0	1
07/24/2021 03:00	0.0	0	0	0	0	1
07/24/2021 04:00	0.0	0	0	0	0	1
07/24/2021 05:00	0.0	0	0	0	0	1
07/24/2021 06:00	0.0	0	0	0	0	1
07/24/2021 07:00	0.0	0	0	0	0	1
07/24/2021 08:00	0.0	0	0	0	0	1
07/24/2021 09:00	0.0	0	0	0	0	1
07/24/2021 10:00	0.0	0	0	0	0	1
07/24/2021 11:00	0.0	0	0	0	0	1
07/24/2021 12:00	0.0	0	0	0	0	1
07/24/2021 13:00	0.0	0	0	0	0	1
07/24/2021 14:00	0.0	0	0	0	0	1
07/24/2021 15:00	0.0	0	0	0	0	1
07/24/2021 16:00	0.0	0	0	0	0	1
07/24/2021 17:00	0.0	0	0	0	0	1
07/24/2021 18:00	0.0	0	0	0	0	1
07/24/2021 19:00	0.0	0	0	0	0	1
07/24/2021 20:00	0.0	0	0	0	0	1
07/24/2021 21:00	0.0	0	0	0	0	1
07/24/2021 22:00	0.0	0	0	0	0	1
07/24/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/25/2021 00:00	0.0	0	0	0	0	1
07/25/2021 01:00	0.0	0	0	0	0	1
07/25/2021 02:00	0.0	0	0	0	0	1
07/25/2021 03:00	0.0	0	0	0	0	1
07/25/2021 04:00	0.0	0	0	0	0	1
07/25/2021 05:00	0.0	0	0	0	0	1
07/25/2021 06:00	0.0	0	0	0	0	1
07/25/2021 07:00	0.0	0	0	0	0	1
07/25/2021 08:00	0.0	0	0	0	0	1
07/25/2021 09:00	0.0	0	0	0	0	1
07/25/2021 10:00	0.0	0	0	0	0	1
07/25/2021 11:00	0.0	0	0	0	0	1
07/25/2021 12:00	0.0	0	0	0	0	1
07/25/2021 13:00	0.0	0	0	0	0	1
07/25/2021 14:00	0.0	0	0	0	0	1
07/25/2021 15:00	0.0	0	0	0	0	1
07/25/2021 16:00	0.0	0	0	0	0	1
07/25/2021 17:00	0.0	0	0	0	0	1
07/25/2021 18:00	0.0	0	0	0	0	1
07/25/2021 19:00	0.0	0	0	0	0	1
07/25/2021 20:00	0.0	0	0	0	0	1
07/25/2021 21:00	0.0	0	0	0	0	1
07/25/2021 22:00	0.0	0	0	0	0	1
07/25/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/26/2021 00:00	0.0	0	0	0	0	1
07/26/2021 01:00	0.0	0	0	0	0	1
07/26/2021 02:00	0.0	0	0	0	0	1
07/26/2021 03:00	0.0	0	0	0	0	1
07/26/2021 04:00	0.0	0	0	0	0	1
07/26/2021 05:00	0.0	0	0	0	0	1
07/26/2021 06:00	0.0	0	0	0	0	1
07/26/2021 07:00	0.0	0	0	0	0	1
07/26/2021 08:00	0.0	0	0	0	0	1
07/26/2021 09:00	0.0	0	0	0	0	1
07/26/2021 10:00	0.0	0	0	0	0	1
07/26/2021 11:00	0.0	0	0	0	0	1
07/26/2021 12:00	0.0	0	0	0	0	1
07/26/2021 13:00	0.0	0	0	0	0	1
07/26/2021 14:00	0.0	0	0	0	0	1
07/26/2021 15:00	0.0	0	0	0	0	1
07/26/2021 16:00	0.0	0	0	0	0	1
07/26/2021 17:00	0.0	0	0	0	0	1
07/26/2021 18:00	0.0	0	0	0	0	1
07/26/2021 19:00	0.0	0	0	0	0	1
07/26/2021 20:00	0.0	0	0	0	0	1
07/26/2021 21:00	0.0	0	0	0	0	1
07/26/2021 22:00	0.0	0	0	0	0	1
07/26/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/27/2021 00:00	0.0	0	0	0	0	1
07/27/2021 01:00	0.0	0	0	0	0	1
07/27/2021 02:00	0.0	0	0	0	0	1
07/27/2021 03:00	0.0	0	0	0	0	1
07/27/2021 04:00	0.0	0	0	0	0	1
07/27/2021 05:00	0.0	0	0	0	0	1
07/27/2021 06:00	0.0	0	0	0	0	1
07/27/2021 07:00	0.0	0	0	0	0	1
07/27/2021 08:00	0.0	0	0	0	0	1
07/27/2021 09:00	0.0	0	0	0	0	1
07/27/2021 10:00	0.0	0	0	0	0	1
07/27/2021 11:00	0.0	0	0	0	0	1
07/27/2021 12:00	0.0	0	0	0	0	1
07/27/2021 13:00	0.0	0	0	0	0	1
07/27/2021 14:00	0.0	0	0	0	0	1
07/27/2021 15:00	0.0	0	0	0	0	1
07/27/2021 16:00	0.0	0	0	0	0	1
07/27/2021 17:00	0.0	0	0	0	0	1
07/27/2021 18:00	0.0	0	0	0	0	1
07/27/2021 19:00	0.0	0	0	0	0	1
07/27/2021 20:00	0.0	0	0	0	0	1
07/27/2021 21:00	0.0	0	0	0	0	1
07/27/2021 22:00	0.0	0	0	0	0	1
07/27/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/28/2021 00:00	0.0	0	0	0	0	1
07/28/2021 01:00	0.0	0	0	0	0	1
07/28/2021 02:00	0.0	0	0	0	0	1
07/28/2021 03:00	0.0	0	0	0	0	1
07/28/2021 04:00	0.0	0	0	0	0	1
07/28/2021 05:00	0.0	0	0	0	0	1
07/28/2021 06:00	0.0	0	0	0	0	1
07/28/2021 07:00	0.0	0	0	0	0	1
07/28/2021 08:00	0.0	0	0	0	0	1
07/28/2021 09:00	0.0	0	0	0	0	1
07/28/2021 10:00	0.0	0	0	0	0	1
07/28/2021 11:00	0.0	0	0	0	0	1
07/28/2021 12:00	0.0	0	0	0	0	1
07/28/2021 13:00	0.0	0	0	0	0	1
07/28/2021 14:00	0.0	0	0	0	0	1
07/28/2021 15:00	0.0	0	0	0	0	1
07/28/2021 16:00	0.0	0	0	0	0	1
07/28/2021 17:00	0.0	0	0	0	0	1
07/28/2021 18:00	0.0	0	0	0	0	1
07/28/2021 19:00	0.0	0	0	0	0	1
07/28/2021 20:00	0.0	0	0	0	0	1
07/28/2021 21:00	0.0	0	0	0	0	1
07/28/2021 22:00	0.0	0	0	0	0	1
07/28/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/29/2021 00:00	0.0	0	0	0	0	1
07/29/2021 01:00	0.0	0	0	0	0	1
07/29/2021 02:00	0.0	0	0	0	0	1
07/29/2021 03:00	0.0	0	0	0	0	1
07/29/2021 04:00	0.0	0	0	0	0	1
07/29/2021 05:00	0.0	0	0	0	0	1
07/29/2021 06:00	0.0	0	0	0	0	1
07/29/2021 07:00	0.0	0	0	0	0	1
07/29/2021 08:00	0.0	0	0	0	0	1
07/29/2021 09:00	0.0	0	0	0	0	1
07/29/2021 10:00	0.0	0	0	0	0	1
07/29/2021 11:00	0.0	0	0	0	0	1
07/29/2021 12:00	0.0	0	0	0	0	1
07/29/2021 13:00	0.0	0	0	0	0	1
07/29/2021 14:00	0.0	0	0	0	0	1
07/29/2021 15:00	0.0	0	0	0	0	1
07/29/2021 16:00	0.0	0	0	0	0	1
07/29/2021 17:00	0.0	0	0	0	0	1
07/29/2021 18:00	0.0	0	0	0	0	1
07/29/2021 19:00	0.0	0	0	0	0	1
07/29/2021 20:00	0.0	0	0	0	0	1
07/29/2021 21:00	0.0	0	0	0	0	1
07/29/2021 22:00	0.0	0	0	0	0	1
07/29/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/30/2021 00:00	0.0	0	0	0	0	1
07/30/2021 01:00	0.0	0	0	0	0	1
07/30/2021 02:00	0.0	0	0	0	0	1
07/30/2021 03:00	0.0	0	0	0	0	1
07/30/2021 04:00	0.0	0	0	0	0	1
07/30/2021 05:00	0.0	0	0	0	0	1
07/30/2021 06:00	0.0	0	0	0	0	1
07/30/2021 07:00	0.0	0	0	0	0	1
07/30/2021 08:00	0.0	0	0	0	0	1
07/30/2021 09:00	0.0	0	0	0	0	1
07/30/2021 10:00	0.0	0	0	0	0	1
07/30/2021 11:00	0.0	0	0	0	0	1
07/30/2021 12:00	0.0	0	0	0	0	1
07/30/2021 13:00	0.0	0	0	0	0	1
07/30/2021 14:00	0.0	0	0	0	0	1
07/30/2021 15:00	0.0	0	0	0	0	1
07/30/2021 16:00	0.0	0	0	0	0	1
07/30/2021 17:00	0.0	0	0	0	0	1
07/30/2021 18:00	0.0	0	0	0	0	1
07/30/2021 19:00	0.0	0	0	0	0	1
07/30/2021 20:00	0.0	0	0	0	0	1
07/30/2021 21:00	0.0	0	0	0	0	1
07/30/2021 22:00	0.0	0	0	0	0	1
07/30/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/31/2021 00:00	0.0	0	0	0	0	1
07/31/2021 01:00	0.0	0	0	0	0	1
07/31/2021 02:00	0.0	0	0	0	0	1
07/31/2021 03:00	0.0	0	0	0	0	1
07/31/2021 04:00	0.0	0	0	0	0	1
07/31/2021 05:00	0.0	0	0	0	0	1
07/31/2021 06:00	0.0	0	0	0	0	1
07/31/2021 07:00	0.0	0	0	0	0	1
07/31/2021 08:00	0.0	0	0	0	0	1
07/31/2021 09:00	0.0	0	0	0	0	1
07/31/2021 10:00	0.0	0	0	0	0	1
07/31/2021 11:00	0.0	0	0	0	0	1
07/31/2021 12:00	0.0	0	0	0	0	1
07/31/2021 13:00	0.0	0	0	0	0	1
07/31/2021 14:00	0.0	0	0	0	0	1
07/31/2021 15:00	0.0	0	0	0	0	1
07/31/2021 16:00	0.0	0	0	0	0	1
07/31/2021 17:00	0.0	0	0	0	0	1
07/31/2021 18:00	0.0	0	0	0	0	1
07/31/2021 19:00	0.0	0	0	0	0	1
07/31/2021 20:00	0.0	0	0	0	0	1
07/31/2021 21:00	0.0	0	0	0	0	1
07/31/2021 22:00	0.0	0	0	0	0	1
07/31/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/01/2021 00:00	0.0	0	0	0	0	1
08/01/2021 01:00	0.0	0	0	0	0	1
08/01/2021 02:00	0.0	0	0	0	0	1
08/01/2021 03:00	0.0	0	0	0	0	1
08/01/2021 04:00	0.0	0	0	0	0	1
08/01/2021 05:00	0.0	0	0	0	0	1
08/01/2021 06:00	0.0	0	0	0	0	1
08/01/2021 07:00	0.0	0	0	0	0	1
08/01/2021 08:00	0.0	0	0	0	0	1
08/01/2021 09:00	0.0	0	0	0	0	1
08/01/2021 10:00	0.0	0	0	0	0	1
08/01/2021 11:00	0.0	0	0	0	0	1
08/01/2021 12:00	0.0	0	0	0	0	1
08/01/2021 13:00	0.0	0	0	0	0	1
08/01/2021 14:00	0.0	0	0	0	0	1
08/01/2021 15:00	0.0	0	0	0	0	1
08/01/2021 16:00	0.0	0	0	0	0	1
08/01/2021 17:00	0.0	0	0	0	0	1
08/01/2021 18:00	0.0	0	0	0	0	1
08/01/2021 19:00	0.0	0	0	0	0	1
08/01/2021 20:00	0.0	0	0	0	0	1
08/01/2021 21:00	0.0	0	0	0	0	1
08/01/2021 22:00	0.0	0	0	0	0	1
08/01/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/02/2021 00:00	0.0	0	0	0	0	1
08/02/2021 01:00	0.0	0	0	0	0	1
08/02/2021 02:00	0.0	0	0	0	0	1
08/02/2021 03:00	0.0	0	0	0	0	1
08/02/2021 04:00	0.0	0	0	0	0	1
08/02/2021 05:00	0.0	0	0	0	0	1
08/02/2021 06:00	0.0	0	0	0	0	1
08/02/2021 07:00	0.0	0	0	0	0	1
08/02/2021 08:00	0.0	0	0	0	0	1
08/02/2021 09:00	0.0	0	0	0	0	1
08/02/2021 10:00	0.0	0	0	0	0	1
08/02/2021 11:00	0.0	0	0	0	0	1
08/02/2021 12:00	0.0	0	0	0	0	1
08/02/2021 13:00	0.0	0	0	0	0	1
08/02/2021 14:00	0.0	0	0	0	0	1
08/02/2021 15:00	0.0	0	0	0	0	1
08/02/2021 16:00	0.0	0	0	0	0	1
08/02/2021 17:00	0.0	0	0	0	0	1
08/02/2021 18:00	0.0	0	0	0	0	1
08/02/2021 19:00	0.0	0	0	0	0	1
08/02/2021 20:00	0.0	0	0	0	0	1
08/02/2021 21:00	0.0	0	0	0	0	1
08/02/2021 22:00	0.0	0	0	0	0	1
08/02/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/03/2021 00:00	0.0	0	0	0	0	1
08/03/2021 01:00	0.0	0	0	0	0	1
08/03/2021 02:00	0.0	0	0	0	0	1
08/03/2021 03:00	0.0	0	0	0	0	1
08/03/2021 04:00	0.2	0	0	0	1	0
08/03/2021 05:00	0.0	0	0	0	0	0
08/03/2021 06:00	0.0	0	0	0	0	0
08/03/2021 07:00	0.0	0	0	0	0	0
08/03/2021 08:00	0.0	0	0	0	0	0
08/03/2021 09:00	0.0	0	0	0	0	0
08/03/2021 10:00	0.0	0	0	0	0	0
08/03/2021 11:00	76.9	0	0	1	0	0
08/03/2021 12:00	0.0	0	0	1	0	0
08/03/2021 13:00	0.0	0	0	0	0	1
08/03/2021 14:00	0.0	0	0	0	0	1
08/03/2021 15:00	0.0	0	0	0	0	1
08/03/2021 16:00	0.0	0	0	0	0	1
08/03/2021 17:00	0.0	0	0	0	0	1
08/03/2021 18:00	0.0	0	0	0	0	1
08/03/2021 19:00	0.0	0	0	0	0	1
08/03/2021 20:00	0.0	0	0	0	0	1
08/03/2021 21:00	0.0	0	0	0	0	1
08/03/2021 22:00	0.0	0	0	0	0	1
08/03/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	77.1 #	0 #	0 #	2 #	1 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	76.9	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/04/2021 00:00	0.0	0	0	0	0	1
08/04/2021 01:00	0.0	0	0	0	0	1
08/04/2021 02:00	0.0	0	0	0	0	1
08/04/2021 03:00	0.0	0	0	0	0	1
08/04/2021 04:00	0.0	0	0	0	0	1
08/04/2021 05:00	0.0	0	0	0	0	1
08/04/2021 06:00	0.0	0	0	0	0	1
08/04/2021 07:00	0.0	0	0	0	0	1
08/04/2021 08:00	0.0	0	0	0	0	1
08/04/2021 09:00	0.0	0	0	0	0	1
08/04/2021 10:00	0.0	0	0	0	0	1
08/04/2021 11:00	0.0	0	0	0	0	1
08/04/2021 12:00	0.0	0	0	0	0	1
08/04/2021 13:00	0.0	0	0	0	0	1
08/04/2021 14:00	0.0	0	0	0	0	1
08/04/2021 15:00	0.0	0	0	0	0	1
08/04/2021 16:00	0.0	0	0	0	0	1
08/04/2021 17:00	0.0	0	0	0	0	1
08/04/2021 18:00	0.0	0	0	0	0	1
08/04/2021 19:00	0.0	0	0	0	0	1
08/04/2021 20:00	0.0	0	0	0	0	1
08/04/2021 21:00	0.0	0	0	0	0	1
08/04/2021 22:00	0.0	0	0	0	0	1
08/04/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/05/2021 00:00	0.0	0	0	0	0	1
08/05/2021 01:00	0.0	0	0	0	0	1
08/05/2021 02:00	0.0	0	0	0	0	1
08/05/2021 03:00	0.0	0	0	0	0	1
08/05/2021 04:00	0.0	0	0	0	0	1
08/05/2021 05:00	0.0	0	0	0	0	1
08/05/2021 06:00	0.0	0	0	0	0	1
08/05/2021 07:00	0.0	0	0	0	0	1
08/05/2021 08:00	0.0	0	0	0	0	1
08/05/2021 09:00	0.0	0	0	0	0	1
08/05/2021 10:00	0.0	0	0	0	0	1
08/05/2021 11:00	0.0	0	0	0	0	1
08/05/2021 12:00	0.0	0	0	0	0	1
08/05/2021 13:00	0.0	0	0	0	0	1
08/05/2021 14:00	0.0	0	0	0	0	1
08/05/2021 15:00	0.0	0	0	0	0	1
08/05/2021 16:00	0.0	0	0	0	0	1
08/05/2021 17:00	0.0	0	0	0	0	1
08/05/2021 18:00	0.0	0	0	0	0	1
08/05/2021 19:00	0.0	0	0	0	0	1
08/05/2021 20:00	0.0	0	0	0	0	1
08/05/2021 21:00	0.0	0	0	0	0	1
08/05/2021 22:00	0.0	0	0	0	0	1
08/05/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/06/2021 00:00	0.0	0	0	0	0	1
08/06/2021 01:00	0.0	0	0	0	0	1
08/06/2021 02:00	0.0	0	0	0	0	1
08/06/2021 03:00	0.0	0	0	0	0	1
08/06/2021 04:00	0.0	0	0	0	0	1
08/06/2021 05:00	0.0	0	0	0	0	1
08/06/2021 06:00	0.0	0	0	0	0	1
08/06/2021 07:00	0.0	0	0	0	0	1
08/06/2021 08:00	0.0	0	0	0	0	1
08/06/2021 09:00	0.0	0	0	0	0	1
08/06/2021 10:00	0.0	0	0	0	0	1
08/06/2021 11:00	0.0	0	0	0	0	1
08/06/2021 12:00	0.0	0	0	0	0	1
08/06/2021 13:00	0.0	0	0	0	0	1
08/06/2021 14:00	0.0	0	0	0	0	1
08/06/2021 15:00	0.0	0	0	0	0	1
08/06/2021 16:00	0.0	0	0	0	0	1
08/06/2021 17:00	0.0	0	0	0	0	1
08/06/2021 18:00	0.0	0	0	0	0	1
08/06/2021 19:00	0.0	0	0	0	0	1
08/06/2021 20:00	0.0	0	0	0	0	1
08/06/2021 21:00	0.0	0	0	0	0	1
08/06/2021 22:00	0.0	0	0	0	0	1
08/06/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/07/2021 00:00	0.0	0	0	0	0	1
08/07/2021 01:00	0.0	0	0	0	0	1
08/07/2021 02:00	0.0	0	0	0	0	1
08/07/2021 03:00	2.2	0	0	0	1	0
08/07/2021 04:00	0.0	0	0	0	0	0
08/07/2021 05:00	0.0	0	0	0	0	0
08/07/2021 06:00	0.0	0	0	0	0	0
08/07/2021 07:00	0.0	0	0	0	0	0
08/07/2021 08:00	0.0	0	0	0	0	0
08/07/2021 09:00	2.4	0	0	1	0	0
08/07/2021 10:00	75.2	0	0	1	0	0
08/07/2021 11:00	9.9	0	0	1	1	0
08/07/2021 12:00	65.7	0	0	1	0	0
08/07/2021 13:00	0.0	0	0	0	0	1
08/07/2021 14:00	0.0	0	0	0	0	1
08/07/2021 15:00	0.0	0	0	0	0	1
08/07/2021 16:00	0.0	0	0	0	0	1
08/07/2021 17:00	0.0	0	0	0	0	1
08/07/2021 18:00	0.0	0	0	0	0	1
08/07/2021 19:00	0.0	0	0	0	0	1
08/07/2021 20:00	0.0	0	0	0	0	1
08/07/2021 21:00	0.0	0	0	0	0	1
08/07/2021 22:00	0.0	0	0	0	0	1
08/07/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	155.4 #	0 #	0 #	4 #	2 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	75.2	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/08/2021 00:00	0.0	0	0	0	0	1
08/08/2021 01:00	0.0	0	0	0	0	1
08/08/2021 02:00	0.0	0	0	0	0	1
08/08/2021 03:00	0.0	0	0	0	0	1
08/08/2021 04:00	0.0	0	0	0	0	1
08/08/2021 05:00	0.0	0	0	0	0	1
08/08/2021 06:00	0.0	0	0	0	0	1
08/08/2021 07:00	0.0	0	0	0	0	1
08/08/2021 08:00	0.0	0	0	0	0	1
08/08/2021 09:00	0.0	0	0	0	0	1
08/08/2021 10:00	0.0	0	0	0	0	1
08/08/2021 11:00	0.0	0	0	0	0	1
08/08/2021 12:00	0.0	0	0	0	0	1
08/08/2021 13:00	0.0	0	0	0	0	1
08/08/2021 14:00	0.0	0	0	0	0	1
08/08/2021 15:00	0.0	0	0	0	0	1
08/08/2021 16:00	0.0	0	0	0	0	1
08/08/2021 17:00	0.0	0	0	0	0	1
08/08/2021 18:00	0.0	0	0	0	0	1
08/08/2021 19:00	0.0	0	0	0	0	1
08/08/2021 20:00	0.0	0	0	0	0	1
08/08/2021 21:00	0.0	0	0	0	0	1
08/08/2021 22:00	0.0	0	0	0	0	1
08/08/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/09/2021 00:00	0.0	0	0	0	0	1
08/09/2021 01:00	0.0	0	0	0	0	1
08/09/2021 02:00	0.0	0	0	0	0	1
08/09/2021 03:00	0.0	0	0	0	0	1
08/09/2021 04:00	0.0	0	0	0	0	1
08/09/2021 05:00	0.0	0	0	0	0	1
08/09/2021 06:00	0.0	0	0	0	0	1
08/09/2021 07:00	0.0	0	0	0	0	1
08/09/2021 08:00	0.0	0	0	0	0	1
08/09/2021 09:00	0.0	0	0	0	0	1
08/09/2021 10:00	0.0	0	0	0	0	1
08/09/2021 11:00	0.0	0	0	0	0	1
08/09/2021 12:00	0.0	0	0	0	0	1
08/09/2021 13:00	0.0	0	0	0	0	1
08/09/2021 14:00	0.0	0	0	0	0	1
08/09/2021 15:00	0.0	0	0	0	0	1
08/09/2021 16:00	0.0	0	0	0	0	1
08/09/2021 17:00	0.0	0	0	0	0	1
08/09/2021 18:00	0.0	0	0	0	0	1
08/09/2021 19:00	0.0	0	0	0	0	1
08/09/2021 20:00	0.0	0	0	0	0	1
08/09/2021 21:00	0.0	0	0	0	0	1
08/09/2021 22:00	0.0	0	0	0	0	1
08/09/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/10/2021 00:00	0.0	0	0	0	0	1
08/10/2021 01:00	0.0	0	0	0	0	1
08/10/2021 02:00	0.0	0	0	0	0	1
08/10/2021 03:00	0.0	0	0	0	0	1
08/10/2021 04:00	0.0	0	0	0	0	1
08/10/2021 05:00	0.0	0	0	0	0	1
08/10/2021 06:00	0.0	0	0	0	0	1
08/10/2021 07:00	0.0	0	0	0	0	1
08/10/2021 08:00	0.0	0	0	0	0	1
08/10/2021 09:00	0.0	0	0	0	0	1
08/10/2021 10:00	0.0	0	0	0	0	1
08/10/2021 11:00	0.0	0	0	0	0	1
08/10/2021 12:00	0.0	0	0	0	0	1
08/10/2021 13:00	0.0	0	0	0	0	1
08/10/2021 14:00	0.0	0	0	0	0	1
08/10/2021 15:00	0.0	0	0	0	0	1
08/10/2021 16:00	0.0	0	0	0	0	1
08/10/2021 17:00	0.0	0	0	0	0	1
08/10/2021 18:00	0.0	0	0	0	0	1
08/10/2021 19:00	0.0	0	0	0	0	1
08/10/2021 20:00	0.0	0	0	0	0	1
08/10/2021 21:00	0.0	0	0	0	0	1
08/10/2021 22:00	0.0	0	0	0	0	1
08/10/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/11/2021 00:00	0.0	0	0	0	0	1
08/11/2021 01:00	0.0	0	0	0	0	1
08/11/2021 02:00	0.0	0	0	0	0	1
08/11/2021 03:00	0.0	0	0	0	0	1
08/11/2021 04:00	0.0	0	0	0	0	1
08/11/2021 05:00	0.0	0	0	0	0	1
08/11/2021 06:00	0.0	0	0	0	0	1
08/11/2021 07:00	0.0	0	0	0	0	1
08/11/2021 08:00	0.0	0	0	0	0	1
08/11/2021 09:00	0.0	0	0	0	0	1
08/11/2021 10:00	0.0	0	0	0	0	1
08/11/2021 11:00	0.0	0	0	0	0	1
08/11/2021 12:00	0.0	0	0	0	0	1
08/11/2021 13:00	0.0	0	0	0	0	1
08/11/2021 14:00	0.0	0	0	0	0	1
08/11/2021 15:00	0.0	0	0	0	0	1
08/11/2021 16:00	0.0	0	0	0	0	1
08/11/2021 17:00	0.0	0	0	0	0	1
08/11/2021 18:00	0.0	0	0	0	0	1
08/11/2021 19:00	0.0	0	0	0	0	1
08/11/2021 20:00	0.0	0	0	0	0	1
08/11/2021 21:00	0.0	0	0	0	0	1
08/11/2021 22:00	0.0	0	0	0	0	1
08/11/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/12/2021 00:00	0.0	0	0	0	0	1
08/12/2021 01:00	0.0	0	0	0	0	1
08/12/2021 02:00	0.0	0	0	0	0	1
08/12/2021 03:00	0.0	0	0	0	0	1
08/12/2021 04:00	0.0	0	0	0	0	1
08/12/2021 05:00	0.0	0	0	0	0	1
08/12/2021 06:00	0.0	0	0	0	0	1
08/12/2021 07:00	0.0	0	0	0	0	1
08/12/2021 08:00	0.0	0	0	0	0	1
08/12/2021 09:00	0.0	0	0	0	0	1
08/12/2021 10:00	0.0	0	0	0	0	1
08/12/2021 11:00	0.0	0	0	0	0	1
08/12/2021 12:00	0.0	0	0	0	0	1
08/12/2021 13:00	0.0	0	0	0	0	1
08/12/2021 14:00	0.0	0	0	0	0	1
08/12/2021 15:00	0.0	0	0	0	0	1
08/12/2021 16:00	0.0	0	0	0	0	1
08/12/2021 17:00	0.0	0	0	0	0	1
08/12/2021 18:00	0.0	0	0	0	0	1
08/12/2021 19:00	0.0	0	0	0	0	1
08/12/2021 20:00	0.0	0	0	0	0	1
08/12/2021 21:00	0.0	0	0	0	0	1
08/12/2021 22:00	0.0	0	0	0	0	1
08/12/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/13/2021 00:00	0.0	0	0	0	0	1
08/13/2021 01:00	0.0	0	0	0	0	1
08/13/2021 02:00	0.0	0	0	0	0	1
08/13/2021 03:00	0.0	0	0	0	0	1
08/13/2021 04:00	0.0	0	0	0	0	1
08/13/2021 05:00	0.0	0	0	0	0	1
08/13/2021 06:00	0.0	0	0	0	0	1
08/13/2021 07:00	0.0	0	0	0	0	1
08/13/2021 08:00	0.0	0	0	0	0	1
08/13/2021 09:00	0.0	0	0	0	0	1
08/13/2021 10:00	0.0	0	0	0	0	1
08/13/2021 11:00	0.0	0	0	0	0	1
08/13/2021 12:00	0.0	0	0	0	0	1
08/13/2021 13:00	0.0	0	0	0	0	1
08/13/2021 14:00	0.0	0	0	0	0	1
08/13/2021 15:00	0.0	0	0	0	0	1
08/13/2021 16:00	0.0	0	0	0	0	1
08/13/2021 17:00	0.0	0	0	0	0	1
08/13/2021 18:00	0.0	0	0	0	0	1
08/13/2021 19:00	0.0	0	0	0	0	1
08/13/2021 20:00	0.0	0	0	0	0	1
08/13/2021 21:00	0.0	0	0	0	0	1
08/13/2021 22:00	0.0	0	0	0	0	1
08/13/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/14/2021 00:00	0.0	0	0	0	0	1
08/14/2021 01:00	0.0	0	0	0	0	1
08/14/2021 02:00	0.0	0	0	0	0	1
08/14/2021 03:00	0.0	0	0	0	0	1
08/14/2021 04:00	0.0	0	0	0	0	1
08/14/2021 05:00	0.0	0	0	0	0	1
08/14/2021 06:00	0.0	0	0	0	0	1
08/14/2021 07:00	0.0	0	0	0	0	1
08/14/2021 08:00	0.0	0	0	0	0	1
08/14/2021 09:00	0.0	0	0	0	0	1
08/14/2021 10:00	0.0	0	0	0	0	1
08/14/2021 11:00	0.0	0	0	0	0	1
08/14/2021 12:00	0.0	0	0	0	0	1
08/14/2021 13:00	0.0	0	0	0	0	1
08/14/2021 14:00	0.0	0	0	0	0	1
08/14/2021 15:00	0.0	0	0	0	0	1
08/14/2021 16:00	0.0	0	0	0	0	1
08/14/2021 17:00	0.0	0	0	0	0	1
08/14/2021 18:00	0.0	0	0	0	0	1
08/14/2021 19:00	0.0	0	0	0	0	1
08/14/2021 20:00	0.0	0	0	0	0	1
08/14/2021 21:00	0.0	0	0	0	0	1
08/14/2021 22:00	0.0	0	0	0	0	1
08/14/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/15/2021 00:00	0.0	0	0	0	0	1
08/15/2021 01:00	0.0	0	0	0	0	1
08/15/2021 02:00	0.0	0	0	0	0	1
08/15/2021 03:00	0.0	0	0	0	0	1
08/15/2021 04:00	0.0	0	0	0	0	1
08/15/2021 05:00	0.0	0	0	0	0	1
08/15/2021 06:00	0.0	0	0	0	0	1
08/15/2021 07:00	0.0	0	0	0	0	1
08/15/2021 08:00	0.0	0	0	0	0	1
08/15/2021 09:00	0.0	0	0	0	0	1
08/15/2021 10:00	0.0	0	0	0	0	1
08/15/2021 11:00	0.0	0	0	0	0	1
08/15/2021 12:00	0.0	0	0	0	0	1
08/15/2021 13:00	0.0	0	0	0	0	1
08/15/2021 14:00	0.0	0	0	0	0	1
08/15/2021 15:00	0.0	0	0	0	0	1
08/15/2021 16:00	0.0	0	0	0	0	1
08/15/2021 17:00	0.0	0	0	0	0	1
08/15/2021 18:00	0.0	0	0	0	0	1
08/15/2021 19:00	0.0	0	0	0	0	1
08/15/2021 20:00	0.0	0	0	0	0	1
08/15/2021 21:00	0.0	0	0	0	0	1
08/15/2021 22:00	0.0	0	0	0	0	1
08/15/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/16/2021 00:00	0.0	0	0	0	0	1
08/16/2021 01:00	0.0	0	0	0	0	1
08/16/2021 02:00	0.0	0	0	0	0	1
08/16/2021 03:00	0.0	0	0	0	0	1
08/16/2021 04:00	0.0	0	0	0	0	1
08/16/2021 05:00	0.0	0	0	0	0	1
08/16/2021 06:00	0.0	0	0	0	0	1
08/16/2021 07:00	0.0	0	0	0	0	1
08/16/2021 08:00	0.0	0	0	0	0	1
08/16/2021 09:00	0.0	0	0	0	0	1
08/16/2021 10:00	0.0	0	0	0	0	1
08/16/2021 11:00	0.0	0	0	0	0	1
08/16/2021 12:00	0.0	0	0	0	0	1
08/16/2021 13:00	0.0	0	0	0	0	1
08/16/2021 14:00	0.0	0	0	0	0	1
08/16/2021 15:00	0.0	0	0	0	0	1
08/16/2021 16:00	0.0	0	0	0	0	1
08/16/2021 17:00	0.0	0	0	0	0	1
08/16/2021 18:00	0.0	0	0	0	0	1
08/16/2021 19:00	0.0	0	0	0	0	1
08/16/2021 20:00	0.0	0	0	0	0	1
08/16/2021 21:00	0.0	0	0	0	0	1
08/16/2021 22:00	0.0	0	0	0	0	1
08/16/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/17/2021 00:00	0.0	0	0	0	0	1
08/17/2021 01:00	0.0	0	0	0	0	1
08/17/2021 02:00	0.0	0	0	0	0	1
08/17/2021 03:00	0.0	0	0	0	0	1
08/17/2021 04:00	0.0	0	0	0	0	1
08/17/2021 05:00	0.0	0	0	0	0	1
08/17/2021 06:00	0.0	0	0	0	0	1
08/17/2021 07:00	0.0	0	0	0	0	1
08/17/2021 08:00	0.0	0	0	0	0	1
08/17/2021 09:00	0.0	0	0	0	0	1
08/17/2021 10:00	0.0	0	0	0	0	1
08/17/2021 11:00	0.0	0	0	0	0	1
08/17/2021 12:00	0.0	0	0	0	0	1
08/17/2021 13:00	0.0	0	0	0	0	1
08/17/2021 14:00	0.0	0	0	0	0	1
08/17/2021 15:00	0.0	0	0	0	0	1
08/17/2021 16:00	0.0	0	0	0	0	1
08/17/2021 17:00	0.0	0	0	0	0	1
08/17/2021 18:00	0.0	0	0	0	0	1
08/17/2021 19:00	0.0	0	0	0	0	1
08/17/2021 20:00	0.0	0	0	0	0	1
08/17/2021 21:00	0.0	0	0	0	0	1
08/17/2021 22:00	0.0	0	0	0	0	1
08/17/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/18/2021 00:00	0.0	0	0	0	0	1
08/18/2021 01:00	0.0	0	0	0	0	1
08/18/2021 02:00	0.0	0	0	0	0	1
08/18/2021 03:00	0.0	0	0	0	0	1
08/18/2021 04:00	0.0	0	0	0	0	1
08/18/2021 05:00	0.0	0	0	0	0	1
08/18/2021 06:00	0.0	0	0	0	0	1
08/18/2021 07:00	0.0	0	0	0	0	1
08/18/2021 08:00	0.0	0	0	0	0	1
08/18/2021 09:00	0.0	0	0	0	0	1
08/18/2021 10:00	0.0	0	0	0	0	1
08/18/2021 11:00	0.0	0	0	0	0	1
08/18/2021 12:00	0.0	0	0	0	0	1
08/18/2021 13:00	0.0	0	0	0	0	1
08/18/2021 14:00	0.0	0	0	0	0	1
08/18/2021 15:00	0.0	0	0	0	0	1
08/18/2021 16:00	0.0	0	0	0	0	1
08/18/2021 17:00	0.0	0	0	0	0	1
08/18/2021 18:00	0.0	0	0	0	0	1
08/18/2021 19:00	0.0	0	0	0	0	1
08/18/2021 20:00	0.0	0	0	0	0	1
08/18/2021 21:00	0.0	0	0	0	0	1
08/18/2021 22:00	0.0	0	0	0	0	1
08/18/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/19/2021 00:00	0.0	0	0	0	0	1
08/19/2021 01:00	0.0	0	0	0	0	1
08/19/2021 02:00	0.0	0	0	0	0	1
08/19/2021 03:00	0.0	0	0	0	0	1
08/19/2021 04:00	0.0	0	0	0	0	1
08/19/2021 05:00	0.0	0	0	0	0	1
08/19/2021 06:00	0.0	0	0	0	0	1
08/19/2021 07:00	0.0	0	0	0	0	1
08/19/2021 08:00	0.0	0	0	0	0	1
08/19/2021 09:00	0.0	0	0	0	0	1
08/19/2021 10:00	0.0	0	0	0	0	1
08/19/2021 11:00	0.0	0	0	0	0	1
08/19/2021 12:00	0.0	0	0	0	0	1
08/19/2021 13:00	0.0	0	0	0	0	1
08/19/2021 14:00	0.0	0	0	0	0	1
08/19/2021 15:00	0.0	0	0	0	0	1
08/19/2021 16:00	0.0	0	0	0	0	1
08/19/2021 17:00	0.0	0	0	0	0	1
08/19/2021 18:00	0.0	0	0	0	0	1
08/19/2021 19:00	0.0	0	0	0	0	1
08/19/2021 20:00	0.0	0	0	0	0	1
08/19/2021 21:00	0.0	0	0	0	0	1
08/19/2021 22:00	0.0	0	0	0	0	1
08/19/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/20/2021 00:00	0.0	0	0	0	0	1
08/20/2021 01:00	0.0	0	0	0	0	1
08/20/2021 02:00	0.0	0	0	0	0	1
08/20/2021 03:00	0.0	0	0	0	0	1
08/20/2021 04:00	0.0	0	0	0	0	1
08/20/2021 05:00	0.0	0	0	0	0	1
08/20/2021 06:00	0.0	0	0	0	0	1
08/20/2021 07:00	0.0	0	0	0	0	1
08/20/2021 08:00	0.0	0	0	0	0	1
08/20/2021 09:00	0.0	0	0	0	0	1
08/20/2021 10:00	0.0	0	0	0	0	1
08/20/2021 11:00	0.0	0	0	0	0	1
08/20/2021 12:00	0.0	0	0	0	0	1
08/20/2021 13:00	0.0	0	0	0	0	1
08/20/2021 14:00	0.0	0	0	0	0	1
08/20/2021 15:00	0.0	0	0	0	0	1
08/20/2021 16:00	0.0	0	0	0	0	1
08/20/2021 17:00	0.0	0	0	0	0	1
08/20/2021 18:00	0.0	0	0	0	0	1
08/20/2021 19:00	0.0	0	0	0	0	1
08/20/2021 20:00	0.0	0	0	0	0	1
08/20/2021 21:00	0.0	0	0	0	0	1
08/20/2021 22:00	0.0	0	0	0	0	1
08/20/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/21/2021 00:00	2.9	0	0	0	1	0
08/21/2021 01:00	15.5	0	0	1	0	0
08/21/2021 02:00	11.7	0	0	1	0	0
08/21/2021 03:00	0.0	0	0	0	0	1
08/21/2021 04:00	0.0	0	0	0	0	1
08/21/2021 05:00	0.0	0	0	0	0	1
08/21/2021 06:00	0.0	0	0	0	0	1
08/21/2021 07:00	0.0	0	0	0	0	1
08/21/2021 08:00	0.0	0	0	0	0	1
08/21/2021 09:00	0.0	0	0	0	0	1
08/21/2021 10:00	0.0	0	0	0	0	1
08/21/2021 11:00	0.0	0	0	0	0	1
08/21/2021 12:00	0.0	0	0	0	0	1
08/21/2021 13:00	0.0	0	0	0	0	1
08/21/2021 14:00	0.0	0	0	0	0	1
08/21/2021 15:00	1.3	0	0	0	1	0
08/21/2021 16:00	0.0	0	0	0	0	0
08/21/2021 17:00	0.0	0	0	0	0	0
08/21/2021 18:00	0.0	0	0	0	0	0
08/21/2021 19:00	0.0	0	0	0	0	0
08/21/2021 20:00	0.0	0	0	0	0	0
08/21/2021 21:00	0.0	0	0	0	0	0
08/21/2021 22:00	0.0	0	0	0	0	0
08/21/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	31.4 #	0 #	0 #	2 #	2 #	12 #
Minimum:	0.0	0	0	0	0	0
Maximum:	15.5	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/22/2021 00:00	0.0	0	0	0	0	0
08/22/2021 01:00	0.0	0	0	0	0	0
08/22/2021 02:00	0.0	0	0	0	0	0
08/22/2021 03:00	0.0	0	0	0	0	0
08/22/2021 04:00	0.0	0	0	0	0	0
08/22/2021 05:00	0.0	0	0	0	0	0
08/22/2021 06:00	0.0	0	0	0	0	0
08/22/2021 07:00	0.0	0	0	0	0	0
08/22/2021 08:00	0.0	0	0	0	0	0
08/22/2021 09:00	0.0	0	0	0	0	0
08/22/2021 10:00	0.0	0	0	0	0	0
08/22/2021 11:00	0.0	0	0	0	0	0
08/22/2021 12:00	0.0	0	0	0	0	0
08/22/2021 13:00	0.0	0	0	0	0	0
08/22/2021 14:00	0.0	0	0	0	0	0
08/22/2021 15:00	0.0	0	0	0	0	0
08/22/2021 16:00	0.0	0	0	0	0	0
08/22/2021 17:00	0.0	0	0	0	0	0
08/22/2021 18:00	0.0	0	0	0	0	0
08/22/2021 19:00	0.0	0	0	0	0	0
08/22/2021 20:00	0.0	0	0	0	0	0
08/22/2021 21:00	0.0	0	0	0	0	0
08/22/2021 22:00	0.0	0	0	0	0	0
08/22/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/23/2021 00:00	0.0	0	0	0	0	0
08/23/2021 01:00	0.0	0	0	0	0	0
08/23/2021 02:00	0.0	0	0	0	0	0
08/23/2021 03:00	0.0	0	0	0	0	0
08/23/2021 04:00	0.0	0	0	0	0	0
08/23/2021 05:00	0.0	0	0	0	0	0
08/23/2021 06:00	0.0	0	0	0	0	0
08/23/2021 07:00	0.0	0	0	0	0	0
08/23/2021 08:00	0.0	0	0	0	0	0
08/23/2021 09:00	75.2	0	1	0	0	0
08/23/2021 10:00	33.1	0	1	0	0	0
08/23/2021 11:00	90.6	0	1	0	0	0
08/23/2021 12:00	1.8	0	0	0	1	0
08/23/2021 13:00	41.3	0	0	1	0	0
08/23/2021 14:00	21.2	0	0	1	0	0
08/23/2021 15:00	0.0	0	0	0	0	1
08/23/2021 16:00	0.0	0	0	0	0	1
08/23/2021 17:00	0.0	0	0	0	0	1
08/23/2021 18:00	0.0	0	0	0	0	1
08/23/2021 19:00	0.0	0	0	0	0	1
08/23/2021 20:00	0.0	0	0	0	0	1
08/23/2021 21:00	0.0	0	0	0	0	1
08/23/2021 22:00	0.0	0	0	0	0	1
08/23/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	263.2 #	0 #	3 #	2 #	1 #	9 #
Minimum:	0.0	0	0	0	0	0
Maximum:	90.6	0	1	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/24/2021 00:00	0.0	0	0	0	0	1
08/24/2021 01:00	0.0	0	0	0	0	1
08/24/2021 02:00	0.0	0	0	0	0	1
08/24/2021 03:00	0.0	0	0	0	0	1
08/24/2021 04:00	0.0	0	0	0	0	1
08/24/2021 05:00	0.0	0	0	0	0	1
08/24/2021 06:00	0.0	0	0	0	0	1
08/24/2021 07:00	0.0	0	0	0	0	1
08/24/2021 08:00	0.0	0	0	0	0	1
08/24/2021 09:00	0.0	0	0	0	0	1
08/24/2021 10:00	0.0	0	0	0	0	1
08/24/2021 11:00	0.0	0	0	0	0	1
08/24/2021 12:00	0.0	0	0	0	0	1
08/24/2021 13:00	0.0	0	0	0	0	1
08/24/2021 14:00	0.0	0	0	0	0	1
08/24/2021 15:00	0.0	0	0	0	0	1
08/24/2021 16:00	0.0	0	0	0	0	1
08/24/2021 17:00	0.0	0	0	0	0	1
08/24/2021 18:00	0.0	0	0	0	0	1
08/24/2021 19:00	0.0	0	0	0	0	1
08/24/2021 20:00	0.0	0	0	0	0	1
08/24/2021 21:00	0.0	0	0	0	0	1
08/24/2021 22:00	0.0	0	0	0	0	1
08/24/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/25/2021 00:00	0.0	0	0	0	0	1
08/25/2021 01:00	0.0	0	0	0	0	1
08/25/2021 02:00	0.0	0	0	0	0	1
08/25/2021 03:00	0.0	0	0	0	0	1
08/25/2021 04:00	0.0	0	0	0	0	1
08/25/2021 05:00	0.0	0	0	0	0	1
08/25/2021 06:00	0.0	0	0	0	0	1
08/25/2021 07:00	0.0	0	0	0	0	1
08/25/2021 08:00	0.0	0	0	0	0	1
08/25/2021 09:00	0.0	0	0	0	0	1
08/25/2021 10:00	0.0	0	0	0	0	1
08/25/2021 11:00	0.0	0	0	0	0	1
08/25/2021 12:00	0.0	0	0	0	0	1
08/25/2021 13:00	0.0	0	0	0	0	1
08/25/2021 14:00	0.0	0	0	0	0	1
08/25/2021 15:00	0.0	0	0	0	0	1
08/25/2021 16:00	0.0	0	0	0	0	1
08/25/2021 17:00	0.0	0	0	0	0	1
08/25/2021 18:00	0.0	0	0	0	0	1
08/25/2021 19:00	0.0	0	0	0	0	1
08/25/2021 20:00	0.0	0	0	0	0	1
08/25/2021 21:00	0.0	0	0	0	0	1
08/25/2021 22:00	0.0	0	0	0	0	1
08/25/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/26/2021 00:00	0.0	0	0	0	0	1
08/26/2021 01:00	0.0	0	0	0	0	1
08/26/2021 02:00	0.0	0	0	0	0	1
08/26/2021 03:00	0.0	0	0	0	0	1
08/26/2021 04:00	0.0	0	0	0	0	1
08/26/2021 05:00	0.0	0	0	0	0	1
08/26/2021 06:00	0.0	0	0	0	0	1
08/26/2021 07:00	0.0	0	0	0	0	1
08/26/2021 08:00	0.0	0	0	0	0	1
08/26/2021 09:00	0.0	0	0	0	0	1
08/26/2021 10:00	0.0	0	0	0	0	1
08/26/2021 11:00	0.0	0	0	0	0	1
08/26/2021 12:00	0.0	0	0	0	0	1
08/26/2021 13:00	0.0	0	0	0	0	1
08/26/2021 14:00	0.0	0	0	0	0	1
08/26/2021 15:00	0.0	0	0	0	0	1
08/26/2021 16:00	0.0	0	0	0	0	1
08/26/2021 17:00	0.0	0	0	0	0	1
08/26/2021 18:00	0.0	0	0	0	0	1
08/26/2021 19:00	0.0	0	0	0	0	1
08/26/2021 20:00	0.0	0	0	0	0	1
08/26/2021 21:00	0.0	0	0	0	0	1
08/26/2021 22:00	0.0	0	0	0	0	1
08/26/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/27/2021 00:00	0.0	0	0	0	0	1
08/27/2021 01:00	0.0	0	0	0	0	1
08/27/2021 02:00	0.0	0	0	0	0	1
08/27/2021 03:00	0.0	0	0	0	0	1
08/27/2021 04:00	0.0	0	0	0	0	1
08/27/2021 05:00	0.0	0	0	0	0	1
08/27/2021 06:00	0.0	0	0	0	0	1
08/27/2021 07:00	0.0	0	0	0	0	1
08/27/2021 08:00	0.0	0	0	0	0	1
08/27/2021 09:00	0.0	0	0	0	0	1
08/27/2021 10:00	0.0	0	0	0	0	1
08/27/2021 11:00	0.0	0	0	0	0	1
08/27/2021 12:00	0.0	0	0	0	0	1
08/27/2021 13:00	0.0	0	0	0	0	1
08/27/2021 14:00	0.0	0	0	0	0	1
08/27/2021 15:00	0.0	0	0	0	0	1
08/27/2021 16:00	0.0	0	0	0	0	1
08/27/2021 17:00	0.0	0	0	0	0	1
08/27/2021 18:00	0.0	0	0	0	0	1
08/27/2021 19:00	0.0	0	0	0	0	1
08/27/2021 20:00	0.0	0	0	0	0	1
08/27/2021 21:00	0.0	0	0	0	0	1
08/27/2021 22:00	0.0	0	0	0	0	1
08/27/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/28/2021 00:00	0.0	0	0	0	0	1
08/28/2021 01:00	0.0	0	0	0	0	1
08/28/2021 02:00	0.0	0	0	0	0	1
08/28/2021 03:00	0.0	0	0	0	0	1
08/28/2021 04:00	0.0	0	0	0	0	1
08/28/2021 05:00	0.0	0	0	0	0	1
08/28/2021 06:00	0.0	0	0	0	0	1
08/28/2021 07:00	0.0	0	0	0	0	1
08/28/2021 08:00	0.0	0	0	0	0	1
08/28/2021 09:00	0.0	0	0	0	0	1
08/28/2021 10:00	0.0	0	0	0	0	1
08/28/2021 11:00	0.0	0	0	0	0	1
08/28/2021 12:00	0.0	0	0	0	0	1
08/28/2021 13:00	0.0	0	0	0	0	1
08/28/2021 14:00	0.0	0	0	0	0	1
08/28/2021 15:00	0.0	0	0	0	0	1
08/28/2021 16:00	0.0	0	0	0	0	1
08/28/2021 17:00	0.0	0	0	0	0	1
08/28/2021 18:00	0.0	0	0	0	0	1
08/28/2021 19:00	0.0	0	0	0	0	1
08/28/2021 20:00	0.0	0	0	0	0	1
08/28/2021 21:00	0.0	0	0	0	0	1
08/28/2021 22:00	0.0	0	0	0	0	1
08/28/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/29/2021 00:00	0.0	0	0	0	0	1
08/29/2021 01:00	0.0	0	0	0	0	1
08/29/2021 02:00	0.0	0	0	0	0	1
08/29/2021 03:00	0.0	0	0	0	0	1
08/29/2021 04:00	0.0	0	0	0	0	1
08/29/2021 05:00	0.0	0	0	0	0	1
08/29/2021 06:00	0.0	0	0	0	0	1
08/29/2021 07:00	0.0	0	0	0	0	1
08/29/2021 08:00	0.0	0	0	0	0	1
08/29/2021 09:00	0.0	0	0	0	0	1
08/29/2021 10:00	0.0	0	0	0	0	1
08/29/2021 11:00	0.0	0	0	0	0	1
08/29/2021 12:00	0.0	0	0	0	0	1
08/29/2021 13:00	0.0	0	0	0	0	1
08/29/2021 14:00	0.0	0	0	0	0	1
08/29/2021 15:00	0.0	0	0	0	0	1
08/29/2021 16:00	0.0	0	0	0	0	1
08/29/2021 17:00	0.0	0	0	0	0	1
08/29/2021 18:00	0.0	0	0	0	0	1
08/29/2021 19:00	0.0	0	0	0	0	1
08/29/2021 20:00	0.0	0	0	0	0	1
08/29/2021 21:00	0.0	0	0	0	0	1
08/29/2021 22:00	0.0	0	0	0	0	1
08/29/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/30/2021 00:00	0.0	0	0	0	0	1
08/30/2021 01:00	0.0	0	0	0	0	1
08/30/2021 02:00	0.0	0	0	0	0	1
08/30/2021 03:00	0.0	0	0	0	0	1
08/30/2021 04:00	0.0	0	0	0	0	1
08/30/2021 05:00	0.0	0	0	0	0	1
08/30/2021 06:00	0.0	0	0	0	0	1
08/30/2021 07:00	0.0	0	0	0	0	1
08/30/2021 08:00	0.0	0	0	0	0	1
08/30/2021 09:00	0.0	0	0	0	0	1
08/30/2021 10:00	0.0	0	0	0	0	1
08/30/2021 11:00	0.0	0	0	0	0	1
08/30/2021 12:00	0.0	0	0	0	0	1
08/30/2021 13:00	0.0	0	0	0	0	1
08/30/2021 14:00	0.0	0	0	0	0	1
08/30/2021 15:00	0.0	0	0	0	0	1
08/30/2021 16:00	0.0	0	0	0	0	1
08/30/2021 17:00	0.0	0	0	0	0	1
08/30/2021 18:00	0.0	0	0	0	0	1
08/30/2021 19:00	0.0	0	0	0	0	1
08/30/2021 20:00	0.0	0	0	0	0	1
08/30/2021 21:00	0.0	0	0	0	0	1
08/30/2021 22:00	0.0	0	0	0	0	1
08/30/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/31/2021 00:00	0.0	0	0	0	0	1
08/31/2021 01:00	0.0	0	0	0	0	1
08/31/2021 02:00	0.0	0	0	0	0	1
08/31/2021 03:00	0.0	0	0	0	0	1
08/31/2021 04:00	0.0	0	0	0	0	1
08/31/2021 05:00	0.0	0	0	0	0	1
08/31/2021 06:00	0.0	0	0	0	0	1
08/31/2021 07:00	0.0	0	0	0	0	1
08/31/2021 08:00	0.0	0	0	0	0	1
08/31/2021 09:00	0.0	0	0	0	0	1
08/31/2021 10:00	0.0	0	0	0	0	1
08/31/2021 11:00	0.0	0	0	0	0	1
08/31/2021 12:00	0.0	0	0	0	0	1
08/31/2021 13:00	0.0	0	0	0	0	1
08/31/2021 14:00	0.0	0	0	0	0	1
08/31/2021 15:00	0.0	0	0	0	0	1
08/31/2021 16:00	0.0	0	0	0	0	1
08/31/2021 17:00	0.0	0	0	0	0	1
08/31/2021 18:00	0.0	0	0	0	0	1
08/31/2021 19:00	0.0	0	0	0	0	1
08/31/2021 20:00	0.0	0	0	0	0	1
08/31/2021 21:00	0.0	0	0	0	0	1
08/31/2021 22:00	0.0	0	0	0	0	1
08/31/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/01/2021 00:00	0.0	0	0	0	0	1
09/01/2021 01:00	0.0	0	0	0	0	1
09/01/2021 02:00	0.0	0	0	0	0	1
09/01/2021 03:00	0.0	0	0	0	0	1
09/01/2021 04:00	0.0	0	0	0	0	1
09/01/2021 05:00	0.0	0	0	0	0	1
09/01/2021 06:00	0.0	0	0	0	0	1
09/01/2021 07:00	0.0	0	0	0	0	1
09/01/2021 08:00	0.0	0	0	0	0	1
09/01/2021 09:00	0.0	0	0	0	0	1
09/01/2021 10:00	0.0	0	0	0	0	1
09/01/2021 11:00	0.0	0	0	0	0	1
09/01/2021 12:00	0.0	0	0	0	0	1
09/01/2021 13:00	0.0	0	0	0	0	1
09/01/2021 14:00	0.0	0	0	0	0	1
09/01/2021 15:00	0.0	0	0	0	0	1
09/01/2021 16:00	0.0	0	0	0	0	1
09/01/2021 17:00	0.0	0	0	0	0	1
09/01/2021 18:00	0.0	0	0	0	0	1
09/01/2021 19:00	0.0	0	0	0	0	1
09/01/2021 20:00	0.0	0	0	0	0	1
09/01/2021 21:00	0.0	0	0	0	0	1
09/01/2021 22:00	0.0	0	0	0	0	1
09/01/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/02/2021 00:00	0.0	0	0	0	0	1
09/02/2021 01:00	0.0	0	0	0	0	1
09/02/2021 02:00	0.0	0	0	0	0	1
09/02/2021 03:00	0.0	0	0	0	0	1
09/02/2021 04:00	0.0	0	0	0	0	1
09/02/2021 05:00	0.0	0	0	0	0	1
09/02/2021 06:00	0.0	0	0	0	0	1
09/02/2021 07:00	0.0	0	0	0	0	1
09/02/2021 08:00	0.0	0	0	0	0	1
09/02/2021 09:00	0.0	0	0	0	0	1
09/02/2021 10:00	0.0	0	0	0	0	1
09/02/2021 11:00	0.0	0	0	0	0	1
09/02/2021 12:00	0.0	0	0	0	0	1
09/02/2021 13:00	0.0	0	0	0	0	1
09/02/2021 14:00	0.0	0	0	0	0	1
09/02/2021 15:00	0.0	0	0	0	0	1
09/02/2021 16:00	0.0	0	0	0	0	1
09/02/2021 17:00	0.0	0	0	0	0	1
09/02/2021 18:00	0.0	0	0	0	0	1
09/02/2021 19:00	0.0	0	0	0	0	1
09/02/2021 20:00	0.0	0	0	0	0	1
09/02/2021 21:00	0.0	0	0	0	0	1
09/02/2021 22:00	0.0	0	0	0	0	1
09/02/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/03/2021 00:00	0.0	0	0	0	0	1
09/03/2021 01:00	0.0	0	0	0	0	1
09/03/2021 02:00	0.0	0	0	0	0	1
09/03/2021 03:00	0.0	0	0	0	0	1
09/03/2021 04:00	0.0	0	0	0	0	1
09/03/2021 05:00	0.0	0	0	0	0	1
09/03/2021 06:00	0.0	0	0	0	0	1
09/03/2021 07:00	0.0	0	0	0	0	1
09/03/2021 08:00	0.0	0	0	0	0	1
09/03/2021 09:00	0.0	0	0	0	0	1
09/03/2021 10:00	0.0	0	0	0	0	1
09/03/2021 11:00	0.0	0	0	0	0	1
09/03/2021 12:00	0.0	0	0	0	0	1
09/03/2021 13:00	0.0	0	0	0	0	1
09/03/2021 14:00	0.0	0	0	0	0	1
09/03/2021 15:00	0.0	0	0	0	0	1
09/03/2021 16:00	0.0	0	0	0	0	1
09/03/2021 17:00	0.0	0	0	0	0	1
09/03/2021 18:00	0.0	0	0	0	0	1
09/03/2021 19:00	0.0	0	0	0	0	1
09/03/2021 20:00	0.0	0	0	0	0	1
09/03/2021 21:00	0.0	0	0	0	0	1
09/03/2021 22:00	0.0	0	0	0	0	1
09/03/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/04/2021 00:00	0.0	0	0	0	0	1
09/04/2021 01:00	0.0	0	0	0	0	1
09/04/2021 02:00	0.0	0	0	0	0	1
09/04/2021 03:00	1.6	0	0	0	1	0
09/04/2021 04:00	0.0	0	0	0	0	0
09/04/2021 05:00	0.0	0	0	0	0	0
09/04/2021 06:00	0.0	0	0	0	0	0
09/04/2021 07:00	0.0	0	0	0	0	0
09/04/2021 08:00	0.0	0	0	0	0	0
09/04/2021 09:00	0.0	0	0	0	0	0
09/04/2021 10:00	0.0	0	0	0	0	0
09/04/2021 11:00	0.0	0	0	0	0	0
09/04/2021 12:00	0.0	0	0	0	0	0
09/04/2021 13:00	17.2	0	1	0	0	0
09/04/2021 14:00	18.5	0	1	0	0	0
09/04/2021 15:00	0.0	0	0	0	0	1
09/04/2021 16:00	0.0	0	0	0	0	1
09/04/2021 17:00	0.0	0	0	0	0	1
09/04/2021 18:00	0.0	0	0	0	0	1
09/04/2021 19:00	0.0	0	0	0	0	1
09/04/2021 20:00	0.0	0	0	0	0	1
09/04/2021 21:00	0.0	0	0	0	0	1
09/04/2021 22:00	0.0	0	0	0	0	1
09/04/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	37.3 #	0 #	2 #	0 #	1 #	12 #
Minimum:	0.0	0	0	0	0	0
Maximum:	18.5	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/05/2021 00:00	0.0	0	0	0	0	1
09/05/2021 01:00	0.0	0	0	0	0	1
09/05/2021 02:00	0.0	0	0	0	0	1
09/05/2021 03:00	0.0	0	0	0	0	1
09/05/2021 04:00	0.0	0	0	0	0	1
09/05/2021 05:00	0.0	0	0	0	0	1
09/05/2021 06:00	0.0	0	0	0	0	1
09/05/2021 07:00	0.0	0	0	0	0	1
09/05/2021 08:00	0.0	0	0	0	0	1
09/05/2021 09:00	0.0	0	0	0	0	1
09/05/2021 10:00	0.0	0	0	0	0	1
09/05/2021 11:00	0.0	0	0	0	0	1
09/05/2021 12:00	0.0	0	0	0	0	1
09/05/2021 13:00	0.0	0	0	0	0	1
09/05/2021 14:00	0.0	0	0	0	0	1
09/05/2021 15:00	0.0	0	0	0	0	1
09/05/2021 16:00	0.0	0	0	0	0	1
09/05/2021 17:00	0.0	0	0	0	0	1
09/05/2021 18:00	0.0	0	0	0	0	1
09/05/2021 19:00	0.0	0	0	0	0	1
09/05/2021 20:00	0.0	0	0	0	0	1
09/05/2021 21:00	0.0	0	0	0	0	1
09/05/2021 22:00	0.0	0	0	0	0	1
09/05/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/06/2021 00:00	0.0	0	0	0	0	1
09/06/2021 01:00	0.0	0	0	0	0	1
09/06/2021 02:00	0.0	0	0	0	0	1
09/06/2021 03:00	0.0	0	0	0	0	1
09/06/2021 04:00	0.0	0	0	0	0	1
09/06/2021 05:00	0.0	0	0	0	0	1
09/06/2021 06:00	0.0	0	0	0	0	1
09/06/2021 07:00	0.0	0	0	0	0	1
09/06/2021 08:00	0.0	0	0	0	0	1
09/06/2021 09:00	0.0	0	0	0	0	1
09/06/2021 10:00	0.0	0	0	0	0	1
09/06/2021 11:00	0.0	0	0	0	0	1
09/06/2021 12:00	0.0	0	0	0	0	1
09/06/2021 13:00	0.0	0	0	0	0	1
09/06/2021 14:00	0.0	0	0	0	0	1
09/06/2021 15:00	0.0	0	0	0	0	1
09/06/2021 16:00	0.0	0	0	0	0	1
09/06/2021 17:00	0.0	0	0	0	0	1
09/06/2021 18:00	0.0	0	0	0	0	1
09/06/2021 19:00	0.0	0	0	0	0	1
09/06/2021 20:00	0.0	0	0	0	0	1
09/06/2021 21:00	0.0	0	0	0	0	1
09/06/2021 22:00	0.0	0	0	0	0	1
09/06/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/07/2021 00:00	0.0	0	0	0	0	1
09/07/2021 01:00	0.0	0	0	0	0	1
09/07/2021 02:00	0.0	0	0	0	0	1
09/07/2021 03:00	0.0	0	0	0	0	1
09/07/2021 04:00	0.0	0	0	0	0	1
09/07/2021 05:00	0.0	0	0	0	0	1
09/07/2021 06:00	0.0	0	0	0	0	1
09/07/2021 07:00	0.0	0	0	0	0	1
09/07/2021 08:00	0.0	0	0	0	0	1
09/07/2021 09:00	0.0	0	0	0	0	1
09/07/2021 10:00	0.0	0	0	0	0	1
09/07/2021 11:00	0.0	0	0	0	0	1
09/07/2021 12:00	0.0	0	0	0	0	1
09/07/2021 13:00	0.0	0	0	0	0	1
09/07/2021 14:00	0.0	0	0	0	0	1
09/07/2021 15:00	0.0	0	0	0	0	1
09/07/2021 16:00	0.0	0	0	0	0	1
09/07/2021 17:00	0.0	0	0	0	0	1
09/07/2021 18:00	0.0	0	0	0	0	1
09/07/2021 19:00	0.0	0	0	0	0	1
09/07/2021 20:00	0.0	0	0	0	0	1
09/07/2021 21:00	0.0	0	0	0	0	1
09/07/2021 22:00	0.0	0	0	0	0	1
09/07/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/08/2021 00:00	0.0	0	0	0	0	1
09/08/2021 01:00	0.0	0	0	0	0	1
09/08/2021 02:00	0.0	0	0	0	0	1
09/08/2021 03:00	0.0	0	0	0	0	1
09/08/2021 04:00	0.0	0	0	0	0	1
09/08/2021 05:00	0.0	0	0	0	0	1
09/08/2021 06:00	0.0	0	0	0	0	1
09/08/2021 07:00	0.0	0	0	0	0	1
09/08/2021 08:00	0.0	0	0	0	0	1
09/08/2021 09:00	0.0	0	0	0	0	1
09/08/2021 10:00	0.0	0	0	0	0	1
09/08/2021 11:00	0.0	0	0	0	0	1
09/08/2021 12:00	0.0	0	0	0	0	1
09/08/2021 13:00	0.0	0	0	0	0	1
09/08/2021 14:00	0.0	0	0	0	0	1
09/08/2021 15:00	0.0	0	0	0	0	1
09/08/2021 16:00	0.0	0	0	0	0	1
09/08/2021 17:00	0.0	0	0	0	0	1
09/08/2021 18:00	0.0	0	0	0	0	1
09/08/2021 19:00	0.0	0	0	0	0	1
09/08/2021 20:00	0.0	0	0	0	0	1
09/08/2021 21:00	0.0	0	0	0	0	1
09/08/2021 22:00	0.0	0	0	0	0	1
09/08/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/09/2021 00:00	0.0	0	0	0	0	1
09/09/2021 01:00	0.0	0	0	0	0	1
09/09/2021 02:00	0.0	0	0	0	0	1
09/09/2021 03:00	0.0	0	0	0	0	1
09/09/2021 04:00	0.0	0	0	0	0	1
09/09/2021 05:00	0.0	0	0	0	0	1
09/09/2021 06:00	0.0	0	0	0	0	1
09/09/2021 07:00	0.0	0	0	0	0	1
09/09/2021 08:00	0.0	0	0	0	0	1
09/09/2021 09:00	0.0	0	0	0	0	1
09/09/2021 10:00	0.0	0	0	0	0	1
09/09/2021 11:00	0.0	0	0	0	0	1
09/09/2021 12:00	0.0	0	0	0	0	1
09/09/2021 13:00	0.0	0	0	0	0	1
09/09/2021 14:00	0.0	0	0	0	0	1
09/09/2021 15:00	0.0	0	0	0	0	1
09/09/2021 16:00	0.0	0	0	0	0	1
09/09/2021 17:00	0.0	0	0	0	0	1
09/09/2021 18:00	0.0	0	0	0	0	1
09/09/2021 19:00	0.0	0	0	0	0	1
09/09/2021 20:00	0.0	0	0	0	0	1
09/09/2021 21:00	0.0	0	0	0	0	1
09/09/2021 22:00	0.0	0	0	0	0	1
09/09/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/10/2021 00:00	0.0	0	0	0	0	1
09/10/2021 01:00	0.0	0	0	0	0	1
09/10/2021 02:00	0.0	0	0	0	0	1
09/10/2021 03:00	0.0	0	0	0	0	1
09/10/2021 04:00	0.0	0	0	0	0	1
09/10/2021 05:00	0.0	0	0	0	0	1
09/10/2021 06:00	0.0	0	0	0	0	1
09/10/2021 07:00	0.0	0	0	0	0	1
09/10/2021 08:00	0.0	0	0	0	0	1
09/10/2021 09:00	0.0	0	0	0	0	1
09/10/2021 10:00	0.0	0	0	0	0	1
09/10/2021 11:00	0.0	0	0	0	0	1
09/10/2021 12:00	0.0	0	0	0	0	1
09/10/2021 13:00	0.0	0	0	0	0	1
09/10/2021 14:00	0.0	0	0	0	0	1
09/10/2021 15:00	0.0	0	0	0	0	1
09/10/2021 16:00	0.0	0	0	0	0	1
09/10/2021 17:00	0.0	0	0	0	0	1
09/10/2021 18:00	0.0	0	0	0	0	1
09/10/2021 19:00	0.0	0	0	0	0	1
09/10/2021 20:00	0.0	0	0	0	0	1
09/10/2021 21:00	0.0	0	0	0	0	1
09/10/2021 22:00	0.0	0	0	0	0	1
09/10/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/11/2021 00:00	0.0	0	0	0	0	1
09/11/2021 01:00	0.0	0	0	0	0	1
09/11/2021 02:00	0.0	0	0	0	0	1
09/11/2021 03:00	0.0	0	0	0	0	1
09/11/2021 04:00	0.0	0	0	0	0	1
09/11/2021 05:00	0.0	0	0	0	0	1
09/11/2021 06:00	0.0	0	0	0	0	1
09/11/2021 07:00	0.0	0	0	0	0	1
09/11/2021 08:00	0.0	0	0	0	0	1
09/11/2021 09:00	0.0	0	0	0	0	1
09/11/2021 10:00	0.0	0	0	0	0	1
09/11/2021 11:00	0.0	0	0	0	0	1
09/11/2021 12:00	0.0	0	0	0	0	1
09/11/2021 13:00	0.0	0	0	0	0	1
09/11/2021 14:00	0.0	0	0	0	0	1
09/11/2021 15:00	0.0	0	0	0	0	1
09/11/2021 16:00	0.0	0	0	0	0	1
09/11/2021 17:00	0.0	0	0	0	0	1
09/11/2021 18:00	0.0	0	0	0	0	1
09/11/2021 19:00	0.0	0	0	0	0	1
09/11/2021 20:00	0.0	0	0	0	0	1
09/11/2021 21:00	0.0	0	0	0	0	1
09/11/2021 22:00	0.0	0	0	0	0	1
09/11/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/12/2021 00:00	0.0	0	0	0	0	1
09/12/2021 01:00	0.0	0	0	0	0	1
09/12/2021 02:00	0.0	0	0	0	0	1
09/12/2021 03:00	0.0	0	0	0	0	1
09/12/2021 04:00	0.0	0	0	0	0	1
09/12/2021 05:00	0.0	0	0	0	0	1
09/12/2021 06:00	0.0	0	0	0	0	1
09/12/2021 07:00	0.0	0	0	0	0	1
09/12/2021 08:00	0.0	0	0	0	0	1
09/12/2021 09:00	0.0	0	0	0	0	1
09/12/2021 10:00	0.0	0	0	0	0	1
09/12/2021 11:00	0.0	0	0	0	0	1
09/12/2021 12:00	0.0	0	0	0	0	1
09/12/2021 13:00	0.0	0	0	0	0	1
09/12/2021 14:00	0.0	0	0	0	0	1
09/12/2021 15:00	0.0	0	0	0	0	1
09/12/2021 16:00	0.0	0	0	0	0	1
09/12/2021 17:00	0.0	0	0	0	0	1
09/12/2021 18:00	0.0	0	0	0	0	1
09/12/2021 19:00	0.0	0	0	0	0	1
09/12/2021 20:00	0.0	0	0	0	0	1
09/12/2021 21:00	0.0	0	0	0	0	1
09/12/2021 22:00	0.0	0	0	0	0	1
09/12/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/13/2021 00:00	0.0	0	0	0	0	1
09/13/2021 01:00	0.0	0	0	0	0	1
09/13/2021 02:00	0.0	0	0	0	0	1
09/13/2021 03:00	0.0	0	0	0	0	1
09/13/2021 04:00	0.0	0	0	0	0	1
09/13/2021 05:00	0.0	0	0	0	0	1
09/13/2021 06:00	0.0	0	0	0	0	1
09/13/2021 07:00	0.0	0	0	0	0	1
09/13/2021 08:00	0.0	0	0	0	0	1
09/13/2021 09:00	0.0	0	0	0	0	1
09/13/2021 10:00	0.0	0	0	0	0	1
09/13/2021 11:00	0.0	0	0	0	0	1
09/13/2021 12:00	0.0	0	0	0	0	1
09/13/2021 13:00	0.0	0	0	0	0	1
09/13/2021 14:00	0.0	0	0	0	0	1
09/13/2021 15:00	0.0	0	0	0	0	1
09/13/2021 16:00	0.0	0	0	0	0	1
09/13/2021 17:00	0.0	0	0	0	0	1
09/13/2021 18:00	0.0	0	0	0	0	1
09/13/2021 19:00	0.0	0	0	0	0	1
09/13/2021 20:00	0.0	0	0	0	0	1
09/13/2021 21:00	0.0	0	0	0	0	1
09/13/2021 22:00	0.0	0	0	0	0	1
09/13/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/14/2021 00:00	0.0	0	0	0	0	1
09/14/2021 01:00	0.0	0	0	0	0	1
09/14/2021 02:00	0.0	0	0	0	0	1
09/14/2021 03:00	0.0	0	0	0	0	1
09/14/2021 04:00	0.0	0	0	0	0	1
09/14/2021 05:00	0.0	0	0	0	0	1
09/14/2021 06:00	0.0	0	0	0	0	1
09/14/2021 07:00	0.0	0	0	0	0	1
09/14/2021 08:00	0.0	0	0	0	0	1
09/14/2021 09:00	0.0	0	0	0	0	1
09/14/2021 10:00	0.0	0	0	0	0	1
09/14/2021 11:00	0.0	0	0	0	0	1
09/14/2021 12:00	0.0	0	0	0	0	1
09/14/2021 13:00	0.0	0	0	0	0	1
09/14/2021 14:00	0.0	0	0	0	0	1
09/14/2021 15:00	0.0	0	0	0	0	1
09/14/2021 16:00	0.0	0	0	0	0	1
09/14/2021 17:00	0.0	0	0	0	0	1
09/14/2021 18:00	0.0	0	0	0	0	1
09/14/2021 19:00	0.0	0	0	0	0	1
09/14/2021 20:00	0.0	0	0	0	0	1
09/14/2021 21:00	0.0	0	0	0	0	1
09/14/2021 22:00	0.0	0	0	0	0	1
09/14/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/15/2021 00:00	0.0	0	0	0	0	1
09/15/2021 01:00	0.0	0	0	0	0	1
09/15/2021 02:00	0.0	0	0	0	0	1
09/15/2021 03:00	0.0	0	0	0	0	1
09/15/2021 04:00	0.0	0	0	0	0	1
09/15/2021 05:00	0.0	0	0	0	0	1
09/15/2021 06:00	0.0	0	0	0	0	1
09/15/2021 07:00	0.0	0	0	0	0	1
09/15/2021 08:00	0.0	0	0	0	0	1
09/15/2021 09:00	0.0	0	0	0	0	1
09/15/2021 10:00	0.0	0	0	0	0	1
09/15/2021 11:00	0.0	0	0	0	0	1
09/15/2021 12:00	0.0	0	0	0	0	1
09/15/2021 13:00	0.0	0	0	0	0	1
09/15/2021 14:00	0.0	0	0	0	0	1
09/15/2021 15:00	0.0	0	0	0	0	1
09/15/2021 16:00	0.0	0	0	0	0	1
09/15/2021 17:00	0.0	0	0	0	0	1
09/15/2021 18:00	0.0	0	0	0	0	1
09/15/2021 19:00	0.0	0	0	0	0	1
09/15/2021 20:00	0.0	0	0	0	0	1
09/15/2021 21:00	0.0	0	0	0	0	1
09/15/2021 22:00	0.0	0	0	0	0	1
09/15/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/16/2021 00:00	0.0	0	0	0	0	1
09/16/2021 01:00	1.9	0	0	0	1	0
09/16/2021 02:00	0.0	0	0	0	0	0
09/16/2021 03:00	0.0	0	0	0	0	0
09/16/2021 04:00	0.0	0	0	0	0	0
09/16/2021 05:00	0.0	0	0	0	0	0
09/16/2021 06:00	0.0	0	0	0	0	0
09/16/2021 07:00	0.0	0	0	0	0	0
09/16/2021 08:00	0.0	0	0	0	0	0
09/16/2021 09:00	0.0	0	0	0	0	0
09/16/2021 10:00	0.0	0	0	0	0	0
09/16/2021 11:00	0.0	0	0	0	0	0
09/16/2021 12:00	3.5	0	1	0	0	0
09/16/2021 13:00	46.5	0	1	0	0	0
09/16/2021 14:00	0.0	0	0	0	0	1
09/16/2021 15:00	0.0	0	0	0	0	1
09/16/2021 16:00	0.0	0	0	0	0	1
09/16/2021 17:00	0.0	0	0	0	0	1
09/16/2021 18:00	0.0	0	0	0	0	1
09/16/2021 19:00	0.0	0	0	0	0	1
09/16/2021 20:00	0.0	0	0	0	0	1
09/16/2021 21:00	0.0	0	0	0	0	1
09/16/2021 22:00	0.0	0	0	0	0	1
09/16/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	51.9 #	0 #	2 #	0 #	1 #	11 #
Minimum:	0.0	0	0	0	0	0
Maximum:	46.5	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/17/2021 00:00	0.0	0	0	0	0	1
09/17/2021 01:00	0.0	0	0	0	0	1
09/17/2021 02:00	2.7	0	0	0	1	0
09/17/2021 03:00	0.0	0	0	0	0	0
09/17/2021 04:00	0.0	0	0	0	0	0
09/17/2021 05:00	0.0	0	0	0	0	0
09/17/2021 06:00	0.0	0	0	0	0	0
09/17/2021 07:00	0.0	0	0	0	0	0
09/17/2021 08:00	0.0	0	0	0	0	0
09/17/2021 09:00	0.0	0	0	0	0	0
09/17/2021 10:00	0.0	0	0	0	0	0
09/17/2021 11:00	0.0	0	0	0	0	0
09/17/2021 12:00	0.0	0	0	0	0	0
09/17/2021 13:00	14.2	0	1	0	0	0
09/17/2021 14:00	37.4	0	1	0	0	0
09/17/2021 15:00	0.0	0	0	0	0	1
09/17/2021 16:00	0.0	0	0	0	0	1
09/17/2021 17:00	0.0	0	0	0	0	1
09/17/2021 18:00	0.0	0	0	0	0	1
09/17/2021 19:00	0.0	0	0	0	0	1
09/17/2021 20:00	0.0	0	0	0	0	1
09/17/2021 21:00	0.0	0	0	0	0	1
09/17/2021 22:00	0.0	0	0	0	0	1
09/17/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	54.3 #	0 #	2 #	0 #	1 #	11 #
Minimum:	0.0	0	0	0	0	0
Maximum:	37.4	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/18/2021 00:00	2.3	0	0	0	1	0
09/18/2021 01:00	0.0	0	0	0	0	0
09/18/2021 02:00	0.0	0	0	0	0	0
09/18/2021 03:00	0.0	0	0	0	0	0
09/18/2021 04:00	0.0	0	0	0	0	0
09/18/2021 05:00	0.0	0	0	0	0	0
09/18/2021 06:00	0.0	0	0	0	0	0
09/18/2021 07:00	0.0	0	0	0	0	0
09/18/2021 08:00	0.0	0	0	0	0	0
09/18/2021 09:00	0.0	0	0	0	0	0
09/18/2021 10:00	0.0	0	0	0	0	0
09/18/2021 11:00	0.0	0	0	0	0	0
09/18/2021 12:00	0.0	0	0	0	0	0
09/18/2021 13:00	0.0	0	0	0	0	0
09/18/2021 14:00	0.0	0	0	0	0	0
09/18/2021 15:00	0.0	0	0	0	0	0
09/18/2021 16:00	0.0	0	0	0	0	0
09/18/2021 17:00	0.0	0	0	0	0	0
09/18/2021 18:00	0.0	0	0	0	0	0
09/18/2021 19:00	0.0	0	0	0	0	0
09/18/2021 20:00	0.0	0	0	0	0	0
09/18/2021 21:00	0.0	0	0	0	0	0
09/18/2021 22:00	0.0	0	0	0	0	0
09/18/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	2.3 #	0 #	0 #	0 #	1 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	2.3	0	0	0	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/19/2021 00:00	0.0	0	0	0	0	0
09/19/2021 01:00	0.0	0	0	0	0	0
09/19/2021 02:00	0.0	0	0	0	0	0
09/19/2021 03:00	0.0	0	0	0	0	0
09/19/2021 04:00	0.0	0	0	0	0	0
09/19/2021 05:00	0.0	0	0	0	0	0
09/19/2021 06:00	0.0	0	0	0	0	0
09/19/2021 07:00	0.0	0	0	0	0	0
09/19/2021 08:00	0.0	0	0	0	0	0
09/19/2021 09:00	0.0	0	0	0	0	0
09/19/2021 10:00	0.0	0	0	0	0	0
09/19/2021 11:00	0.0	0	0	0	0	0
09/19/2021 12:00	0.0	0	0	0	0	0
09/19/2021 13:00	0.0	0	0	0	0	0
09/19/2021 14:00	0.0	0	0	0	0	0
09/19/2021 15:00	0.0	0	0	0	0	0
09/19/2021 16:00	0.0	0	0	0	0	0
09/19/2021 17:00	0.0	0	0	0	0	0
09/19/2021 18:00	0.0	0	0	0	0	0
09/19/2021 19:00	0.0	0	0	0	0	0
09/19/2021 20:00	0.0	0	0	0	0	0
09/19/2021 21:00	0.0	0	0	0	0	0
09/19/2021 22:00	0.0	0	0	0	0	0
09/19/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/20/2021 00:00	0.0	0	0	0	0	0
09/20/2021 01:00	41.4	0	1	0	0	0
09/20/2021 02:00	45.3	0	1	0	0	0
09/20/2021 03:00	0.1	0	1	0	0	0
09/20/2021 04:00	0.0	0	0	0	0	1
09/20/2021 05:00	0.0	0	0	0	0	1
09/20/2021 06:00	0.0	0	0	0	0	1
09/20/2021 07:00	0.0	0	0	0	0	1
09/20/2021 08:00	0.0	0	0	0	0	1
09/20/2021 09:00	0.0	0	0	0	0	1
09/20/2021 10:00	0.0	0	0	0	0	1
09/20/2021 11:00	0.0	0	0	0	0	1
09/20/2021 12:00	0.0	0	0	0	0	1
09/20/2021 13:00	0.0	0	0	0	0	1
09/20/2021 14:00	0.0	0	0	0	0	1
09/20/2021 15:00	0.0	0	0	0	0	1
09/20/2021 16:00	0.0	0	0	0	0	1
09/20/2021 17:00	0.0	0	0	0	0	1
09/20/2021 18:00	0.0	0	0	0	0	1
09/20/2021 19:00	0.0	0	0	0	0	1
09/20/2021 20:00	0.0	0	0	0	0	1
09/20/2021 21:00	0.0	0	0	0	0	1
09/20/2021 22:00	0.0	0	0	0	0	1
09/20/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	86.8 #	0 #	3 #	0 #	0 #	20 #
Minimum:	0.0	0	0	0	0	0
Maximum:	45.3	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/21/2021 00:00	0.0	0	0	0	0	1
09/21/2021 01:00	0.0	0	0	0	0	1
09/21/2021 02:00	0.0	0	0	0	0	1
09/21/2021 03:00	0.0	0	0	0	0	1
09/21/2021 04:00	0.0	0	0	0	0	1
09/21/2021 05:00	0.0	0	0	0	0	1
09/21/2021 06:00	0.0	0	0	0	0	1
09/21/2021 07:00	0.0	0	0	0	0	1
09/21/2021 08:00	0.0	0	0	0	0	1
09/21/2021 09:00	0.0	0	0	0	0	1
09/21/2021 10:00	0.0	0	0	0	0	1
09/21/2021 11:00	0.0	0	0	0	0	1
09/21/2021 12:00	0.0	0	0	0	0	1
09/21/2021 13:00	0.0	0	0	0	0	1
09/21/2021 14:00	0.0	0	0	0	0	1
09/21/2021 15:00	0.0	0	0	0	0	1
09/21/2021 16:00	0.0	0	0	0	0	1
09/21/2021 17:00	0.0	0	0	0	0	1
09/21/2021 18:00	0.0	0	0	0	0	1
09/21/2021 19:00	0.0	0	0	0	0	1
09/21/2021 20:00	0.0	0	0	0	0	1
09/21/2021 21:00	0.0	0	0	0	0	1
09/21/2021 22:00	0.0	0	0	0	0	1
09/21/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/22/2021 00:00	0.0	0	0	0	0	1
09/22/2021 01:00	0.0	0	0	0	0	1
09/22/2021 02:00	0.0	0	0	0	0	1
09/22/2021 03:00	0.0	0	0	0	0	1
09/22/2021 04:00	0.0	0	0	0	0	1
09/22/2021 05:00	0.0	0	0	0	0	1
09/22/2021 06:00	0.0	0	0	0	0	1
09/22/2021 07:00	0.0	0	0	0	0	1
09/22/2021 08:00	0.0	0	0	0	0	1
09/22/2021 09:00	0.0	0	0	0	0	1
09/22/2021 10:00	0.0	0	0	0	0	1
09/22/2021 11:00	0.0	0	0	0	0	1
09/22/2021 12:00	0.0	0	0	0	0	1
09/22/2021 13:00	0.0	0	0	0	0	1
09/22/2021 14:00	0.0	0	0	0	0	1
09/22/2021 15:00	0.0	0	0	0	0	1
09/22/2021 16:00	0.0	0	0	0	0	1
09/22/2021 17:00	0.0	0	0	0	0	1
09/22/2021 18:00	0.0	0	0	0	0	1
09/22/2021 19:00	0.0	0	0	0	0	1
09/22/2021 20:00	0.0	0	0	0	0	1
09/22/2021 21:00	0.0	0	0	0	0	1
09/22/2021 22:00	0.0	0	0	0	0	1
09/22/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/23/2021 00:00	0.0	0	0	0	0	1
09/23/2021 01:00	0.0	0	0	0	0	1
09/23/2021 02:00	0.0	0	0	0	0	1
09/23/2021 03:00	0.0	0	0	0	0	1
09/23/2021 04:00	0.0	0	0	0	0	1
09/23/2021 05:00	0.0	0	0	0	0	1
09/23/2021 06:00	0.0	0	0	0	0	1
09/23/2021 07:00	0.0	0	0	0	0	1
09/23/2021 08:00	0.0	0	0	0	0	1
09/23/2021 09:00	0.0	0	0	0	0	1
09/23/2021 10:00	0.0	0	0	0	0	1
09/23/2021 11:00	0.0	0	0	0	0	1
09/23/2021 12:00	0.0	0	0	0	0	1
09/23/2021 13:00	0.0	0	0	0	0	1
09/23/2021 14:00	0.0	0	0	0	0	1
09/23/2021 15:00	0.0	0	0	0	0	1
09/23/2021 16:00	0.0	0	0	0	0	1
09/23/2021 17:00	0.0	0	0	0	0	1
09/23/2021 18:00	0.0	0	0	0	0	1
09/23/2021 19:00	0.0	0	0	0	0	1
09/23/2021 20:00	0.0	0	0	0	0	1
09/23/2021 21:00	0.0	0	0	0	0	1
09/23/2021 22:00	0.0	0	0	0	0	1
09/23/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/24/2021 00:00	0.0	0	0	0	0	1
09/24/2021 01:00	0.0	0	0	0	0	1
09/24/2021 02:00	0.0	0	0	0	0	1
09/24/2021 03:00	0.0	0	0	0	0	1
09/24/2021 04:00	0.0	0	0	0	0	1
09/24/2021 05:00	0.0	0	0	0	0	1
09/24/2021 06:00	0.0	0	0	0	0	1
09/24/2021 07:00	0.0	0	0	0	0	1
09/24/2021 08:00	0.0	0	0	0	0	1
09/24/2021 09:00	0.0	0	0	0	0	1
09/24/2021 10:00	0.0	0	0	0	0	1
09/24/2021 11:00	0.0	0	0	0	0	1
09/24/2021 12:00	0.0	0	0	0	0	1
09/24/2021 13:00	0.0	0	0	0	0	1
09/24/2021 14:00	0.0	0	0	0	0	1
09/24/2021 15:00	0.0	0	0	0	0	1
09/24/2021 16:00	0.0	0	0	0	0	1
09/24/2021 17:00	0.0	0	0	0	0	1
09/24/2021 18:00	0.0	0	0	0	0	1
09/24/2021 19:00	0.0	0	0	0	0	1
09/24/2021 20:00	0.0	0	0	0	0	1
09/24/2021 21:00	0.0	0	0	0	0	1
09/24/2021 22:00	0.0	0	0	0	0	1
09/24/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/25/2021 00:00	0.0	0	0	0	0	1
09/25/2021 01:00	0.0	0	0	0	0	1
09/25/2021 02:00	0.0	0	0	0	0	1
09/25/2021 03:00	0.0	0	0	0	0	1
09/25/2021 04:00	0.0	0	0	0	0	1
09/25/2021 05:00	0.0	0	0	0	0	1
09/25/2021 06:00	0.0	0	0	0	0	1
09/25/2021 07:00	0.0	0	0	0	0	1
09/25/2021 08:00	0.0	0	0	0	0	1
09/25/2021 09:00	0.0	0	0	0	0	1
09/25/2021 10:00	0.0	0	0	0	0	1
09/25/2021 11:00	0.0	0	0	0	0	1
09/25/2021 12:00	0.0	0	0	0	0	1
09/25/2021 13:00	0.0	0	0	0	0	1
09/25/2021 14:00	0.0	0	0	0	0	1
09/25/2021 15:00	0.0	0	0	0	0	1
09/25/2021 16:00	0.0	0	0	0	0	1
09/25/2021 17:00	0.0	0	0	0	0	1
09/25/2021 18:00	0.0	0	0	0	0	1
09/25/2021 19:00	0.0	0	0	0	0	1
09/25/2021 20:00	0.0	0	0	0	0	1
09/25/2021 21:00	0.0	0	0	0	0	1
09/25/2021 22:00	0.0	0	0	0	0	1
09/25/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/26/2021 00:00	0.0	0	0	0	0	1
09/26/2021 01:00	0.0	0	0	0	0	1
09/26/2021 02:00	0.0	0	0	0	0	1
09/26/2021 03:00	0.0	0	0	0	0	1
09/26/2021 04:00	0.0	0	0	0	0	1
09/26/2021 05:00	0.0	0	0	0	0	1
09/26/2021 06:00	0.0	0	0	0	0	1
09/26/2021 07:00	0.0	0	0	0	0	1
09/26/2021 08:00	0.0	0	0	0	0	1
09/26/2021 09:00	0.0	0	0	0	0	1
09/26/2021 10:00	0.0	0	0	0	0	1
09/26/2021 11:00	0.0	0	0	0	0	1
09/26/2021 12:00	0.0	0	0	0	0	1
09/26/2021 13:00	0.0	0	0	0	0	1
09/26/2021 14:00	0.0	0	0	0	0	1
09/26/2021 15:00	0.0	0	0	0	0	1
09/26/2021 16:00	0.0	0	0	0	0	1
09/26/2021 17:00	0.0	0	0	0	0	1
09/26/2021 18:00	0.0	0	0	0	0	1
09/26/2021 19:00	0.0	0	0	0	0	1
09/26/2021 20:00	0.0	0	0	0	0	1
09/26/2021 21:00	0.0	0	0	0	0	1
09/26/2021 22:00	0.0	0	0	0	0	1
09/26/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/27/2021 00:00	0.0	0	0	0	0	1
09/27/2021 01:00	0.0	0	0	0	0	1
09/27/2021 02:00	0.0	0	0	0	0	1
09/27/2021 03:00	0.0	0	0	0	0	1
09/27/2021 04:00	0.0	0	0	0	0	1
09/27/2021 05:00	0.0	0	0	0	0	1
09/27/2021 06:00	0.0	0	0	0	0	1
09/27/2021 07:00	0.0	0	0	0	0	1
09/27/2021 08:00	0.0	0	0	0	0	1
09/27/2021 09:00	0.0	0	0	0	0	1
09/27/2021 10:00	0.0	0	0	0	0	1
09/27/2021 11:00	0.0	0	0	0	0	1
09/27/2021 12:00	0.0	0	0	0	0	1
09/27/2021 13:00	0.0	0	0	0	0	1
09/27/2021 14:00	0.0	0	0	0	0	1
09/27/2021 15:00	0.0	0	0	0	0	1
09/27/2021 16:00	0.0	0	0	0	0	1
09/27/2021 17:00	0.0	0	0	0	0	1
09/27/2021 18:00	0.0	0	0	0	0	1
09/27/2021 19:00	0.0	0	0	0	0	1
09/27/2021 20:00	0.0	0	0	0	0	1
09/27/2021 21:00	0.0	0	0	0	0	1
09/27/2021 22:00	0.0	0	0	0	0	1
09/27/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/28/2021 00:00	0.0	0	0	0	0	1
09/28/2021 01:00	0.0	0	0	0	0	1
09/28/2021 02:00	0.0	0	0	0	0	1
09/28/2021 03:00	0.0	0	0	0	0	1
09/28/2021 04:00	0.0	0	0	0	0	1
09/28/2021 05:00	0.0	0	0	0	0	1
09/28/2021 06:00	0.0	0	0	0	0	1
09/28/2021 07:00	0.0	0	0	0	0	1
09/28/2021 08:00	0.0	0	0	0	0	1
09/28/2021 09:00	0.0	0	0	0	0	1
09/28/2021 10:00	0.0	0	0	0	0	1
09/28/2021 11:00	0.0	0	0	0	0	1
09/28/2021 12:00	0.0	0	0	0	0	1
09/28/2021 13:00	0.0	0	0	0	0	1
09/28/2021 14:00	0.0	0	0	0	0	1
09/28/2021 15:00	0.0	0	0	0	0	1
09/28/2021 16:00	0.0	0	0	0	0	1
09/28/2021 17:00	0.0	0	0	0	0	1
09/28/2021 18:00	0.0	0	0	0	0	1
09/28/2021 19:00	0.0	0	0	0	0	1
09/28/2021 20:00	0.0	0	0	0	0	1
09/28/2021 21:00	0.0	0	0	0	0	1
09/28/2021 22:00	0.0	0	0	0	0	1
09/28/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/29/2021 00:00	0.0	0	0	0	0	1
09/29/2021 01:00	0.0	0	0	0	0	1
09/29/2021 02:00	0.0	0	0	0	0	1
09/29/2021 03:00	0.0	0	0	0	0	1
09/29/2021 04:00	0.0	0	0	0	0	1
09/29/2021 05:00	0.0	0	0	0	0	1
09/29/2021 06:00	0.0	0	0	0	0	1
09/29/2021 07:00	0.0	0	0	0	0	1
09/29/2021 08:00	0.0	0	0	0	0	1
09/29/2021 09:00	0.0	0	0	0	0	1
09/29/2021 10:00	0.0	0	0	0	0	1
09/29/2021 11:00	0.0	0	0	0	0	1
09/29/2021 12:00	0.0	0	0	0	0	1
09/29/2021 13:00	0.0	0	0	0	0	1
09/29/2021 14:00	0.0	0	0	0	0	1
09/29/2021 15:00	0.0	0	0	0	0	1
09/29/2021 16:00	0.0	0	0	0	0	1
09/29/2021 17:00	0.0	0	0	0	0	1
09/29/2021 18:00	0.0	0	0	0	0	1
09/29/2021 19:00	0.0	0	0	0	0	1
09/29/2021 20:00	0.0	0	0	0	0	1
09/29/2021 21:00	0.0	0	0	0	0	1
09/29/2021 22:00	0.0	0	0	0	0	1
09/29/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/30/2021 00:00	0.0	0	0	0	0	1
09/30/2021 01:00	0.0	0	0	0	0	1
09/30/2021 02:00	0.0	0	0	0	0	1
09/30/2021 03:00	0.0	0	0	0	0	1
09/30/2021 04:00	0.0	0	0	0	0	1
09/30/2021 05:00	0.0	0	0	0	0	1
09/30/2021 06:00	1.9	0	0	0	1	0
09/30/2021 07:00	0.0	0	0	0	0	0
09/30/2021 08:00	0.0	0	0	0	0	0
09/30/2021 09:00	0.0	0	0	0	0	0
09/30/2021 10:00	0.0	0	0	0	0	0
09/30/2021 11:00	0.0	0	0	0	0	0
09/30/2021 12:00	0.0	0	0	0	0	0
09/30/2021 13:00	0.0	0	0	0	0	0
09/30/2021 14:00	0.0	0	0	0	0	0
09/30/2021 15:00	0.0	0	0	0	0	0
09/30/2021 16:00	0.0	0	0	0	0	0
09/30/2021 17:00	0.0	0	0	0	0	0
09/30/2021 18:00	0.0	0	0	0	0	0
09/30/2021 19:00	0.0	0	0	0	0	0
09/30/2021 20:00	0.0	0	0	0	0	0
09/30/2021 21:00	0.0	0	0	0	0	0
09/30/2021 22:00	0.0	0	0	0	0	0
09/30/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	1.9 #	0 #	0 #	0 #	1 #	6 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.9	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/01/2021 00:00	0.0	0	0	0	0	0
07/01/2021 01:00	0.0	0	0	0	0	0
07/01/2021 02:00	0.0	0	0	0	0	0
07/01/2021 03:00	0.0	0	0	0	0	0
07/01/2021 04:00	0.0	0	0	0	0	0
07/01/2021 05:00	0.0	0	0	0	0	0
07/01/2021 06:00	0.0	0	0	0	0	0
07/01/2021 07:00	0.0	0	0	0	0	0
07/01/2021 08:00	0.0	0	0	0	0	0
07/01/2021 09:00	0.0	0	0	0	0	0
07/01/2021 10:00	0.0	0	0	0	0	0
07/01/2021 11:00	0.0	0	0	0	0	0
07/01/2021 12:00	0.0	0	0	0	0	0
07/01/2021 13:00	0.0	0	0	0	0	0
07/01/2021 14:00	0.0	0	0	0	0	0
07/01/2021 15:00	0.0	0	0	0	0	0
07/01/2021 16:00	0.0	0	0	0	0	0
07/01/2021 17:00	0.0	0	0	0	0	0
07/01/2021 18:00	0.0	0	0	0	0	0
07/01/2021 19:00	0.0	0	0	0	0	0
07/01/2021 20:00	0.0	0	0	0	0	0
07/01/2021 21:00	0.0	0	0	0	0	0
07/01/2021 22:00	0.0	0	0	0	0	0
07/01/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/02/2021 00:00	0.0	0	0	0	0	0
07/02/2021 01:00	0.0	0	0	0	0	0
07/02/2021 02:00	0.0	0	0	0	0	0
07/02/2021 03:00	0.0	0	0	0	0	0
07/02/2021 04:00	0.0	0	0	0	0	0
07/02/2021 05:00	0.0	0	0	0	0	0
07/02/2021 06:00	0.0	0	0	0	0	0
07/02/2021 07:00	0.0	0	0	0	0	0
07/02/2021 08:00	0.0	0	0	0	0	0
07/02/2021 09:00	0.0	0	0	0	0	0
07/02/2021 10:00	0.0	0	0	0	0	0
07/02/2021 11:00	0.0	0	0	0	0	0
07/02/2021 12:00	0.0	0	0	0	0	0
07/02/2021 13:00	0.0	0	0	0	0	0
07/02/2021 14:00	0.0	0	0	0	0	0
07/02/2021 15:00	0.0	0	0	0	0	0
07/02/2021 16:00	0.0	0	0	0	0	0
07/02/2021 17:00	0.0	0	0	0	0	0
07/02/2021 18:00	0.0	0	0	0	0	0
07/02/2021 19:00	0.0	0	0	0	0	0
07/02/2021 20:00	0.0	0	0	0	0	0
07/02/2021 21:00	0.0	0	0	0	0	0
07/02/2021 22:00	0.0	0	0	0	0	0
07/02/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/03/2021 00:00	0.0	0	0	0	0	0
07/03/2021 01:00	0.0	0	0	0	0	0
07/03/2021 02:00	0.0	0	0	0	0	0
07/03/2021 03:00	0.0	0	0	0	0	0
07/03/2021 04:00	0.0	0	0	0	0	0
07/03/2021 05:00	0.0	0	0	0	0	0
07/03/2021 06:00	0.0	0	0	0	0	0
07/03/2021 07:00	0.0	0	0	0	0	0
07/03/2021 08:00	0.0	0	0	0	0	0
07/03/2021 09:00	0.0	0	0	0	0	0
07/03/2021 10:00	0.0	0	0	0	0	0
07/03/2021 11:00	0.0	0	0	0	0	0
07/03/2021 12:00	0.0	0	0	0	0	0
07/03/2021 13:00	0.0	0	0	0	0	0
07/03/2021 14:00	0.0	0	0	0	0	0
07/03/2021 15:00	0.0	0	0	0	0	0
07/03/2021 16:00	0.0	0	0	0	0	0
07/03/2021 17:00	0.0	0	0	0	0	0
07/03/2021 18:00	0.0	0	0	0	0	0
07/03/2021 19:00	0.0	0	0	0	0	0
07/03/2021 20:00	0.0	0	0	0	0	0
07/03/2021 21:00	0.0	0	0	0	0	0
07/03/2021 22:00	0.0	0	0	0	0	0
07/03/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/04/2021 00:00	0.0	0	0	0	0	0
07/04/2021 01:00	0.0	0	0	0	0	0
07/04/2021 02:00	0.0	0	0	0	0	0
07/04/2021 03:00	0.0	0	0	0	0	0
07/04/2021 04:00	0.0	0	0	0	0	0
07/04/2021 05:00	0.0	0	0	0	0	0
07/04/2021 06:00	0.0	0	0	0	0	0
07/04/2021 07:00	0.0	0	0	0	0	0
07/04/2021 08:00	0.0	0	0	0	0	0
07/04/2021 09:00	0.0	0	0	0	0	0
07/04/2021 10:00	0.0	0	0	0	0	0
07/04/2021 11:00	0.0	0	0	0	0	0
07/04/2021 12:00	0.0	0	0	0	0	0
07/04/2021 13:00	0.0	0	0	0	0	0
07/04/2021 14:00	0.0	0	0	0	0	0
07/04/2021 15:00	0.0	0	0	0	0	0
07/04/2021 16:00	0.0	0	0	0	0	0
07/04/2021 17:00	0.0	0	0	0	0	0
07/04/2021 18:00	0.0	0	0	0	0	0
07/04/2021 19:00	0.0	0	0	0	0	0
07/04/2021 20:00	0.0	0	0	0	0	0
07/04/2021 21:00	0.0	0	0	0	0	0
07/04/2021 22:00	0.0	0	0	0	0	0
07/04/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/05/2021 00:00	0.0	0	0	0	0	0
07/05/2021 01:00	0.0	0	0	0	0	0
07/05/2021 02:00	0.0	0	0	0	0	0
07/05/2021 03:00	0.0	0	0	0	0	0
07/05/2021 04:00	0.0	0	0	0	0	0
07/05/2021 05:00	0.0	0	0	0	0	0
07/05/2021 06:00	0.0	0	0	0	0	0
07/05/2021 07:00	0.0	0	0	0	0	0
07/05/2021 08:00	0.0	0	0	0	0	0
07/05/2021 09:00	0.0	0	0	0	0	0
07/05/2021 10:00	0.0	0	0	0	0	0
07/05/2021 11:00	0.0	0	0	0	0	0
07/05/2021 12:00	0.0	0	0	0	0	0
07/05/2021 13:00	0.0	0	0	0	0	0
07/05/2021 14:00	0.0	0	0	0	0	0
07/05/2021 15:00	0.0	0	0	0	0	0
07/05/2021 16:00	0.0	0	0	0	0	0
07/05/2021 17:00	0.0	0	0	0	0	0
07/05/2021 18:00	0.0	0	0	0	0	0
07/05/2021 19:00	0.0	0	0	0	0	0
07/05/2021 20:00	0.0	0	0	0	0	0
07/05/2021 21:00	0.0	0	0	0	0	0
07/05/2021 22:00	0.0	0	0	0	0	0
07/05/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/06/2021 00:00	0.0	0	0	0	0	0
07/06/2021 01:00	0.0	0	0	0	0	0
07/06/2021 02:00	0.0	0	0	0	0	0
07/06/2021 03:00	0.0	0	0	0	0	0
07/06/2021 04:00	0.0	0	0	0	0	0
07/06/2021 05:00	0.0	0	0	0	0	0
07/06/2021 06:00	0.0	0	0	0	0	0
07/06/2021 07:00	0.0	0	0	0	0	0
07/06/2021 08:00	0.0	0	0	0	0	0
07/06/2021 09:00	0.0	0	0	0	0	0
07/06/2021 10:00	0.0	0	0	0	0	0
07/06/2021 11:00	0.0	0	0	0	0	0
07/06/2021 12:00	0.0	0	0	0	0	0
07/06/2021 13:00	0.0	0	0	0	0	0
07/06/2021 14:00	0.0	0	0	0	0	0
07/06/2021 15:00	0.0	0	0	0	0	0
07/06/2021 16:00	0.0	0	0	0	0	0
07/06/2021 17:00	0.0	0	0	0	0	0
07/06/2021 18:00	0.0	0	0	0	0	0
07/06/2021 19:00	0.0	0	0	0	0	0
07/06/2021 20:00	0.0	0	0	0	0	0
07/06/2021 21:00	0.0	0	0	0	0	0
07/06/2021 22:00	0.0	0	0	0	0	0
07/06/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/07/2021 00:00	0.0	0	0	0	0	0
07/07/2021 01:00	0.0	0	0	0	0	0
07/07/2021 02:00	0.0	0	0	0	0	0
07/07/2021 03:00	0.0	0	0	0	0	0
07/07/2021 04:00	0.0	0	0	0	0	0
07/07/2021 05:00	0.0	0	0	0	0	0
07/07/2021 06:00	0.0	0	0	0	0	0
07/07/2021 07:00	0.0	0	0	0	0	0
07/07/2021 08:00	0.0	0	0	0	0	0
07/07/2021 09:00	0.0	0	0	0	0	0
07/07/2021 10:00	0.0	0	0	0	0	0
07/07/2021 11:00	0.0	0	0	0	0	0
07/07/2021 12:00	0.0	0	0	0	0	0
07/07/2021 13:00	0.0	0	0	0	0	0
07/07/2021 14:00	0.0	0	0	0	0	0
07/07/2021 15:00	0.0	0	0	0	0	0
07/07/2021 16:00	0.0	0	0	0	0	0
07/07/2021 17:00	0.0	0	0	0	0	0
07/07/2021 18:00	0.0	0	0	0	0	0
07/07/2021 19:00	0.0	0	0	0	0	0
07/07/2021 20:00	0.0	0	0	0	0	0
07/07/2021 21:00	0.0	0	0	0	0	0
07/07/2021 22:00	0.0	0	0	0	0	0
07/07/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/08/2021 00:00	0.0	0	0	0	0	0
07/08/2021 01:00	0.0	0	0	0	0	0
07/08/2021 02:00	0.0	0	0	0	0	0
07/08/2021 03:00	0.0	0	0	0	0	0
07/08/2021 04:00	0.0	0	0	0	0	0
07/08/2021 05:00	0.0	0	0	0	0	0
07/08/2021 06:00	0.0	0	0	0	0	0
07/08/2021 07:00	0.0	0	0	0	0	0
07/08/2021 08:00	0.0	0	0	0	0	0
07/08/2021 09:00	0.0	0	0	0	0	0
07/08/2021 10:00	0.0	0	0	0	0	0
07/08/2021 11:00	0.0	0	0	0	0	0
07/08/2021 12:00	0.0	0	0	0	0	0
07/08/2021 13:00	0.0	0	0	0	0	0
07/08/2021 14:00	0.0	0	0	0	0	0
07/08/2021 15:00	0.0	0	0	0	0	0
07/08/2021 16:00	0.0	0	0	0	0	0
07/08/2021 17:00	0.0	0	0	0	0	0
07/08/2021 18:00	0.0	0	0	0	0	0
07/08/2021 19:00	0.0	0	0	0	0	0
07/08/2021 20:00	0.0	0	0	0	0	0
07/08/2021 21:00	0.0	0	0	0	0	0
07/08/2021 22:00	0.0	0	0	0	0	0
07/08/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/09/2021 00:00	0.0	0	0	0	0	0
07/09/2021 01:00	0.0	0	0	0	0	0
07/09/2021 02:00	0.0	0	0	0	0	0
07/09/2021 03:00	0.0	0	0	0	0	0
07/09/2021 04:00	0.0	0	0	0	0	0
07/09/2021 05:00	0.0	0	0	0	0	0
07/09/2021 06:00	0.0	0	0	0	0	0
07/09/2021 07:00	0.0	0	0	0	0	0
07/09/2021 08:00	0.0	0	0	0	0	0
07/09/2021 09:00	0.0	0	0	0	0	0
07/09/2021 10:00	0.0	0	0	0	0	0
07/09/2021 11:00	0.0	0	0	0	0	0
07/09/2021 12:00	0.0	0	0	0	0	0
07/09/2021 13:00	0.0	0	0	0	0	0
07/09/2021 14:00	0.0	0	0	0	0	0
07/09/2021 15:00	0.0	0	0	0	0	0
07/09/2021 16:00	0.0	0	0	0	0	0
07/09/2021 17:00	0.0	0	0	0	0	0
07/09/2021 18:00	0.0	0	0	0	0	0
07/09/2021 19:00	0.0	0	0	0	0	0
07/09/2021 20:00	0.0	0	0	0	0	0
07/09/2021 21:00	0.0	0	0	0	0	0
07/09/2021 22:00	0.0	0	0	0	0	0
07/09/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/10/2021 00:00	0.0	0	0	0	0	0
07/10/2021 01:00	0.0	0	0	0	0	0
07/10/2021 02:00	0.0	0	0	0	0	0
07/10/2021 03:00	0.0	0	0	0	0	0
07/10/2021 04:00	0.0	0	0	0	0	0
07/10/2021 05:00	0.0	0	0	0	0	0
07/10/2021 06:00	0.0	0	0	0	0	0
07/10/2021 07:00	0.0	0	0	0	0	0
07/10/2021 08:00	0.0	0	0	0	0	0
07/10/2021 09:00	0.0	0	0	0	0	0
07/10/2021 10:00	0.0	0	0	0	0	0
07/10/2021 11:00	0.0	0	0	0	0	0
07/10/2021 12:00	0.0	0	0	0	0	0
07/10/2021 13:00	0.0	0	0	0	0	0
07/10/2021 14:00	0.0	0	0	0	0	0
07/10/2021 15:00	0.0	0	0	0	0	0
07/10/2021 16:00	596.8	1	0	0	0	0
07/10/2021 17:00	936.2	1	0	0	1	0
07/10/2021 18:00	0.0	0	0	0	0	0
07/10/2021 19:00	0.0	0	0	0	0	0
07/10/2021 20:00	0.0	0	0	0	0	0
07/10/2021 21:00	0.0	0	0	0	0	0
07/10/2021 22:00	0.0	0	0	0	0	0
07/10/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	1,533.0 #	2 #	0 #	0 #	1 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	936.2	1	0	0	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/11/2021 00:00	0.0	0	0	0	0	0
07/11/2021 01:00	0.0	0	0	0	0	0
07/11/2021 02:00	0.0	0	0	0	0	0
07/11/2021 03:00	0.0	0	0	0	0	0
07/11/2021 04:00	0.0	0	0	0	0	0
07/11/2021 05:00	0.0	0	0	0	0	0
07/11/2021 06:00	0.0	0	0	0	0	0
07/11/2021 07:00	0.0	0	0	0	0	0
07/11/2021 08:00	0.0	0	0	0	0	0
07/11/2021 09:00	0.0	0	0	0	0	0
07/11/2021 10:00	0.0	0	0	0	0	0
07/11/2021 11:00	0.0	0	0	0	0	0
07/11/2021 12:00	0.0	0	0	0	0	0
07/11/2021 13:00	0.0	0	0	0	0	0
07/11/2021 14:00	0.0	0	0	0	0	0
07/11/2021 15:00	0.0	0	0	0	0	0
07/11/2021 16:00	0.0	0	0	0	0	0
07/11/2021 17:00	0.0	0	0	0	0	0
07/11/2021 18:00	0.0	0	0	0	0	0
07/11/2021 19:00	0.0	0	0	0	0	0
07/11/2021 20:00	0.0	0	0	0	0	0
07/11/2021 21:00	0.0	0	0	0	0	0
07/11/2021 22:00	0.0	0	0	0	0	0
07/11/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/12/2021 00:00	0.0	0	0	0	0	0
07/12/2021 01:00	0.0	0	0	0	0	0
07/12/2021 02:00	0.0	0	0	0	0	0
07/12/2021 03:00	0.0	0	0	0	0	0
07/12/2021 04:00	0.0	0	0	0	0	0
07/12/2021 05:00	0.0	0	0	0	0	0
07/12/2021 06:00	0.0	0	0	0	0	0
07/12/2021 07:00	2,101.6	0	1	0	0	0
07/12/2021 08:00	3,652.2	0	1	0	0	0
07/12/2021 09:00	5,686.5	0	1	0	0	0
07/12/2021 10:00	0.0	0	0	0	0	1
07/12/2021 11:00	0.0	0	0	0	0	1
07/12/2021 12:00	0.0	0	0	0	0	1
07/12/2021 13:00	0.0	0	0	0	0	1
07/12/2021 14:00	0.0	0	0	0	0	1
07/12/2021 15:00	0.0	0	0	0	0	1
07/12/2021 16:00	0.0	0	0	0	0	1
07/12/2021 17:00	0.0	0	0	0	0	1
07/12/2021 18:00	0.0	0	0	0	0	1
07/12/2021 19:00	0.0	0	0	0	0	1
07/12/2021 20:00	0.0	0	0	0	0	1
07/12/2021 21:00	0.0	0	0	0	0	1
07/12/2021 22:00	0.0	0	0	0	0	1
07/12/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	11,440.3 #	0 #	3 #	0 #	0 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,686.5	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/13/2021 00:00	0.0	0	0	0	0	1
07/13/2021 01:00	0.0	0	0	0	0	1
07/13/2021 02:00	27.6	0	0	0	1	0
07/13/2021 03:00	0.0	0	0	0	0	0
07/13/2021 04:00	0.0	0	0	0	0	0
07/13/2021 05:00	0.0	0	0	0	0	0
07/13/2021 06:00	0.0	0	0	0	0	0
07/13/2021 07:00	0.0	0	0	0	0	0
07/13/2021 08:00	0.0	0	0	0	0	0
07/13/2021 09:00	0.0	0	0	0	0	0
07/13/2021 10:00	0.0	0	0	0	0	0
07/13/2021 11:00	0.0	0	0	0	0	0
07/13/2021 12:00	0.0	0	0	0	0	0
07/13/2021 13:00	0.0	0	0	0	0	0
07/13/2021 14:00	0.0	0	0	0	0	0
07/13/2021 15:00	0.0	0	0	0	0	0
07/13/2021 16:00	0.0	0	0	0	0	0
07/13/2021 17:00	2,021.8	0	1	0	0	0
07/13/2021 18:00	5,312.9	0	1	0	0	0
07/13/2021 19:00	0.0	0	0	0	0	1
07/13/2021 20:00	0.0	0	0	0	0	1
07/13/2021 21:00	0.0	0	0	0	0	1
07/13/2021 22:00	0.0	0	0	0	0	1
07/13/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	7,362.3 #	0 #	2 #	0 #	1 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,312.9	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/14/2021 00:00	0.0	0	0	0	0	1
07/14/2021 01:00	0.0	0	0	0	0	1
07/14/2021 02:00	0.0	0	0	0	0	1
07/14/2021 03:00	0.0	0	0	0	0	1
07/14/2021 04:00	0.0	0	0	0	0	1
07/14/2021 05:00	0.0	0	0	0	0	1
07/14/2021 06:00	0.0	0	0	0	0	1
07/14/2021 07:00	0.0	0	0	0	0	1
07/14/2021 08:00	0.0	0	0	0	0	1
07/14/2021 09:00	0.0	0	0	0	0	1
07/14/2021 10:00	0.0	0	0	0	0	1
07/14/2021 11:00	0.0	0	0	0	0	1
07/14/2021 12:00	0.0	0	0	0	0	1
07/14/2021 13:00	0.0	0	0	0	0	1
07/14/2021 14:00	0.0	0	0	0	0	1
07/14/2021 15:00	0.0	0	0	0	0	1
07/14/2021 16:00	0.0	0	0	0	0	1
07/14/2021 17:00	0.0	0	0	0	0	1
07/14/2021 18:00	0.0	0	0	0	0	1
07/14/2021 19:00	0.0	0	0	0	0	1
07/14/2021 20:00	0.0	0	0	0	0	1
07/14/2021 21:00	0.0	0	0	0	0	1
07/14/2021 22:00	0.0	0	0	0	0	1
07/14/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/15/2021 00:00	0.0	0	0	0	0	1
07/15/2021 01:00	0.0	0	0	0	0	1
07/15/2021 02:00	0.0	0	0	0	0	1
07/15/2021 03:00	0.0	0	0	0	0	1
07/15/2021 04:00	0.0	0	0	0	0	1
07/15/2021 05:00	0.0	0	0	0	0	1
07/15/2021 06:00	0.0	0	0	0	0	1
07/15/2021 07:00	0.0	0	0	0	0	1
07/15/2021 08:00	0.0	0	0	0	0	1
07/15/2021 09:00	0.0	0	0	0	0	1
07/15/2021 10:00	0.0	0	0	0	0	1
07/15/2021 11:00	0.0	0	0	0	0	1
07/15/2021 12:00	0.0	0	0	0	0	1
07/15/2021 13:00	0.0	0	0	0	0	1
07/15/2021 14:00	0.0	0	0	0	0	1
07/15/2021 15:00	0.0	0	0	0	0	1
07/15/2021 16:00	0.0	0	0	0	0	1
07/15/2021 17:00	0.0	0	0	0	0	1
07/15/2021 18:00	0.0	0	0	0	0	1
07/15/2021 19:00	0.0	0	0	0	0	1
07/15/2021 20:00	0.0	0	0	0	0	1
07/15/2021 21:00	0.0	0	0	0	0	1
07/15/2021 22:00	0.0	0	0	0	0	1
07/15/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/16/2021 00:00	0.0	0	0	0	0	1
07/16/2021 01:00	0.0	0	0	0	0	1
07/16/2021 02:00	0.0	0	0	0	0	1
07/16/2021 03:00	0.0	0	0	0	0	1
07/16/2021 04:00	0.0	0	0	0	0	1
07/16/2021 05:00	0.0	0	0	0	0	1
07/16/2021 06:00	0.0	0	0	0	0	1
07/16/2021 07:00	0.0	0	0	0	0	1
07/16/2021 08:00	0.0	0	0	0	0	1
07/16/2021 09:00	0.0	0	0	0	0	1
07/16/2021 10:00	0.0	0	0	0	0	1
07/16/2021 11:00	0.0	0	0	0	0	1
07/16/2021 12:00	0.0	0	0	0	0	1
07/16/2021 13:00	0.0	0	0	0	0	1
07/16/2021 14:00	0.0	0	0	0	0	1
07/16/2021 15:00	0.0	0	0	0	0	1
07/16/2021 16:00	0.0	0	0	0	0	1
07/16/2021 17:00	0.0	0	0	0	0	1
07/16/2021 18:00	0.0	0	0	0	0	1
07/16/2021 19:00	0.0	0	0	0	0	1
07/16/2021 20:00	0.0	0	0	0	0	1
07/16/2021 21:00	0.0	0	0	0	0	1
07/16/2021 22:00	0.0	0	0	0	0	1
07/16/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/17/2021 00:00	0.0	0	0	0	0	1
07/17/2021 01:00	0.0	0	0	0	0	1
07/17/2021 02:00	0.0	0	0	0	0	1
07/17/2021 03:00	0.0	0	0	0	0	1
07/17/2021 04:00	0.0	0	0	0	0	1
07/17/2021 05:00	0.0	0	0	0	0	1
07/17/2021 06:00	0.0	0	0	0	0	1
07/17/2021 07:00	0.0	0	0	0	0	1
07/17/2021 08:00	0.0	0	0	0	0	1
07/17/2021 09:00	0.0	0	0	0	0	1
07/17/2021 10:00	0.0	0	0	0	0	1
07/17/2021 11:00	0.0	0	0	0	0	1
07/17/2021 12:00	0.0	0	0	0	0	1
07/17/2021 13:00	0.0	0	0	0	0	1
07/17/2021 14:00	0.0	0	0	0	0	1
07/17/2021 15:00	0.0	0	0	0	0	1
07/17/2021 16:00	0.0	0	0	0	0	1
07/17/2021 17:00	0.0	0	0	0	0	1
07/17/2021 18:00	0.0	0	0	0	0	1
07/17/2021 19:00	0.0	0	0	0	0	1
07/17/2021 20:00	0.0	0	0	0	0	1
07/17/2021 21:00	0.0	0	0	0	0	1
07/17/2021 22:00	0.0	0	0	0	0	1
07/17/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/18/2021 00:00	0.0	0	0	0	0	1
07/18/2021 01:00	0.0	0	0	0	0	1
07/18/2021 02:00	0.0	0	0	0	0	1
07/18/2021 03:00	0.0	0	0	0	0	1
07/18/2021 04:00	0.0	0	0	0	0	1
07/18/2021 05:00	0.0	0	0	0	0	1
07/18/2021 06:00	0.0	0	0	0	0	1
07/18/2021 07:00	0.0	0	0	0	0	1
07/18/2021 08:00	0.0	0	0	0	0	1
07/18/2021 09:00	0.0	0	0	0	0	1
07/18/2021 10:00	0.0	0	0	0	0	1
07/18/2021 11:00	0.0	0	0	0	0	1
07/18/2021 12:00	0.0	0	0	0	0	1
07/18/2021 13:00	0.0	0	0	0	0	1
07/18/2021 14:00	0.0	0	0	0	0	1
07/18/2021 15:00	0.0	0	0	0	0	1
07/18/2021 16:00	0.0	0	0	0	0	1
07/18/2021 17:00	0.0	0	0	0	0	1
07/18/2021 18:00	0.0	0	0	0	0	1
07/18/2021 19:00	0.0	0	0	0	0	1
07/18/2021 20:00	0.0	0	0	0	0	1
07/18/2021 21:00	0.0	0	0	0	0	1
07/18/2021 22:00	0.0	0	0	0	0	1
07/18/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/19/2021 00:00	0.0	0	0	0	0	1
07/19/2021 01:00	0.0	0	0	0	0	1
07/19/2021 02:00	0.0	0	0	0	0	1
07/19/2021 03:00	0.0	0	0	0	0	1
07/19/2021 04:00	0.0	0	0	0	0	1
07/19/2021 05:00	0.0	0	0	0	0	1
07/19/2021 06:00	0.0	0	0	0	0	1
07/19/2021 07:00	0.0	0	0	0	0	1
07/19/2021 08:00	0.0	0	0	0	0	1
07/19/2021 09:00	0.0	0	0	0	0	1
07/19/2021 10:00	0.0	0	0	0	0	1
07/19/2021 11:00	0.0	0	0	0	0	1
07/19/2021 12:00	0.0	0	0	0	0	1
07/19/2021 13:00	0.0	0	0	0	0	1
07/19/2021 14:00	0.0	0	0	0	0	1
07/19/2021 15:00	0.0	0	0	0	0	1
07/19/2021 16:00	0.0	0	0	0	0	1
07/19/2021 17:00	0.0	0	0	0	0	1
07/19/2021 18:00	0.0	0	0	0	0	1
07/19/2021 19:00	0.0	0	0	0	0	1
07/19/2021 20:00	0.0	0	0	0	0	1
07/19/2021 21:00	0.0	0	0	0	0	1
07/19/2021 22:00	0.0	0	0	0	0	1
07/19/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/20/2021 00:00	0.0	0	0	0	0	1
07/20/2021 01:00	0.0	0	0	0	0	1
07/20/2021 02:00	0.0	0	0	0	0	1
07/20/2021 03:00	0.0	0	0	0	0	1
07/20/2021 04:00	0.0	0	0	0	0	1
07/20/2021 05:00	0.0	0	0	0	0	1
07/20/2021 06:00	0.0	0	0	0	0	1
07/20/2021 07:00	0.0	0	0	0	0	1
07/20/2021 08:00	0.0	0	0	0	0	1
07/20/2021 09:00	0.0	0	0	0	0	1
07/20/2021 10:00	0.0	0	0	0	0	1
07/20/2021 11:00	0.0	0	0	0	0	1
07/20/2021 12:00	0.0	0	0	0	0	1
07/20/2021 13:00	0.0	0	0	0	0	1
07/20/2021 14:00	0.0	0	0	0	0	1
07/20/2021 15:00	0.0	0	0	0	0	1
07/20/2021 16:00	0.0	0	0	0	0	1
07/20/2021 17:00	0.0	0	0	0	0	1
07/20/2021 18:00	0.0	0	0	0	0	1
07/20/2021 19:00	0.0	0	0	0	0	1
07/20/2021 20:00	0.0	0	0	0	0	1
07/20/2021 21:00	0.0	0	0	0	0	1
07/20/2021 22:00	0.0	0	0	0	0	1
07/20/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/21/2021 00:00	0.0	0	0	0	0	1
07/21/2021 01:00	0.0	0	0	0	0	1
07/21/2021 02:00	0.0	0	0	0	0	1
07/21/2021 03:00	0.0	0	0	0	0	1
07/21/2021 04:00	0.0	0	0	0	0	1
07/21/2021 05:00	0.0	0	0	0	0	1
07/21/2021 06:00	0.0	0	0	0	0	1
07/21/2021 07:00	0.0	0	0	0	0	1
07/21/2021 08:00	0.0	0	0	0	0	1
07/21/2021 09:00	0.0	0	0	0	0	1
07/21/2021 10:00	0.0	0	0	0	0	1
07/21/2021 11:00	0.0	0	0	0	0	1
07/21/2021 12:00	0.0	0	0	0	0	1
07/21/2021 13:00	0.0	0	0	0	0	1
07/21/2021 14:00	0.0	0	0	0	0	1
07/21/2021 15:00	0.0	0	0	0	0	1
07/21/2021 16:00	0.0	0	0	0	0	1
07/21/2021 17:00	0.0	0	0	0	0	1
07/21/2021 18:00	0.0	0	0	0	0	1
07/21/2021 19:00	0.0	0	0	0	0	1
07/21/2021 20:00	0.0	0	0	0	0	1
07/21/2021 21:00	0.0	0	0	0	0	1
07/21/2021 22:00	0.0	0	0	0	0	1
07/21/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/22/2021 00:00	0.0	0	0	0	0	1
07/22/2021 01:00	0.0	0	0	0	0	1
07/22/2021 02:00	0.0	0	0	0	0	1
07/22/2021 03:00	0.0	0	0	0	0	1
07/22/2021 04:00	0.0	0	0	0	0	1
07/22/2021 05:00	0.0	0	0	0	0	1
07/22/2021 06:00	0.0	0	0	0	0	1
07/22/2021 07:00	0.0	0	0	0	0	1
07/22/2021 08:00	0.0	0	0	0	0	1
07/22/2021 09:00	0.0	0	0	0	0	1
07/22/2021 10:00	0.0	0	0	0	0	1
07/22/2021 11:00	0.0	0	0	0	0	1
07/22/2021 12:00	0.0	0	0	0	0	1
07/22/2021 13:00	0.0	0	0	0	0	1
07/22/2021 14:00	0.0	0	0	0	0	1
07/22/2021 15:00	0.0	0	0	0	0	1
07/22/2021 16:00	0.0	0	0	0	0	1
07/22/2021 17:00	0.0	0	0	0	0	1
07/22/2021 18:00	0.0	0	0	0	0	1
07/22/2021 19:00	0.0	0	0	0	0	1
07/22/2021 20:00	0.0	0	0	0	0	1
07/22/2021 21:00	0.0	0	0	0	0	1
07/22/2021 22:00	0.0	0	0	0	0	1
07/22/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/23/2021 00:00	0.0	0	0	0	0	1
07/23/2021 01:00	0.0	0	0	0	0	1
07/23/2021 02:00	0.0	0	0	0	0	1
07/23/2021 03:00	0.0	0	0	0	0	1
07/23/2021 04:00	0.0	0	0	0	0	1
07/23/2021 05:00	0.0	0	0	0	0	1
07/23/2021 06:00	0.0	0	0	0	0	1
07/23/2021 07:00	0.0	0	0	0	0	1
07/23/2021 08:00	0.0	0	0	0	0	1
07/23/2021 09:00	0.0	0	0	0	0	1
07/23/2021 10:00	0.0	0	0	0	0	1
07/23/2021 11:00	0.0	0	0	0	0	1
07/23/2021 12:00	0.0	0	0	0	0	1
07/23/2021 13:00	0.0	0	0	0	0	1
07/23/2021 14:00	0.0	0	0	0	0	1
07/23/2021 15:00	0.0	0	0	0	0	1
07/23/2021 16:00	0.0	0	0	0	0	1
07/23/2021 17:00	0.0	0	0	0	0	1
07/23/2021 18:00	0.0	0	0	0	0	1
07/23/2021 19:00	0.0	0	0	0	0	1
07/23/2021 20:00	0.0	0	0	0	0	1
07/23/2021 21:00	0.0	0	0	0	0	1
07/23/2021 22:00	0.0	0	0	0	0	1
07/23/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/24/2021 00:00	0.0	0	0	0	0	1
07/24/2021 01:00	0.0	0	0	0	0	1
07/24/2021 02:00	0.0	0	0	0	0	1
07/24/2021 03:00	0.0	0	0	0	0	1
07/24/2021 04:00	0.0	0	0	0	0	1
07/24/2021 05:00	0.0	0	0	0	0	1
07/24/2021 06:00	0.0	0	0	0	0	1
07/24/2021 07:00	0.0	0	0	0	0	1
07/24/2021 08:00	0.0	0	0	0	0	1
07/24/2021 09:00	0.0	0	0	0	0	1
07/24/2021 10:00	0.0	0	0	0	0	1
07/24/2021 11:00	0.0	0	0	0	0	1
07/24/2021 12:00	0.0	0	0	0	0	1
07/24/2021 13:00	0.0	0	0	0	0	1
07/24/2021 14:00	0.0	0	0	0	0	1
07/24/2021 15:00	0.0	0	0	0	0	1
07/24/2021 16:00	0.0	0	0	0	0	1
07/24/2021 17:00	0.0	0	0	0	0	1
07/24/2021 18:00	0.0	0	0	0	0	1
07/24/2021 19:00	0.0	0	0	0	0	1
07/24/2021 20:00	0.0	0	0	0	0	1
07/24/2021 21:00	0.0	0	0	0	0	1
07/24/2021 22:00	0.0	0	0	0	0	1
07/24/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/25/2021 00:00	0.0	0	0	0	0	1
07/25/2021 01:00	0.0	0	0	0	0	1
07/25/2021 02:00	0.0	0	0	0	0	1
07/25/2021 03:00	0.0	0	0	0	0	1
07/25/2021 04:00	0.0	0	0	0	0	1
07/25/2021 05:00	0.0	0	0	0	0	1
07/25/2021 06:00	0.0	0	0	0	0	1
07/25/2021 07:00	0.0	0	0	0	0	1
07/25/2021 08:00	0.0	0	0	0	0	1
07/25/2021 09:00	0.0	0	0	0	0	1
07/25/2021 10:00	0.0	0	0	0	0	1
07/25/2021 11:00	0.0	0	0	0	0	1
07/25/2021 12:00	0.0	0	0	0	0	1
07/25/2021 13:00	0.0	0	0	0	0	1
07/25/2021 14:00	0.0	0	0	0	0	1
07/25/2021 15:00	0.0	0	0	0	0	1
07/25/2021 16:00	0.0	0	0	0	0	1
07/25/2021 17:00	0.0	0	0	0	0	1
07/25/2021 18:00	0.0	0	0	0	0	1
07/25/2021 19:00	0.0	0	0	0	0	1
07/25/2021 20:00	0.0	0	0	0	0	1
07/25/2021 21:00	0.0	0	0	0	0	1
07/25/2021 22:00	0.0	0	0	0	0	1
07/25/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/26/2021 00:00	0.0	0	0	0	0	1
07/26/2021 01:00	0.0	0	0	0	0	1
07/26/2021 02:00	0.0	0	0	0	0	1
07/26/2021 03:00	0.0	0	0	0	0	1
07/26/2021 04:00	0.0	0	0	0	0	1
07/26/2021 05:00	0.0	0	0	0	0	1
07/26/2021 06:00	0.0	0	0	0	0	1
07/26/2021 07:00	0.0	0	0	0	0	1
07/26/2021 08:00	0.0	0	0	0	0	1
07/26/2021 09:00	0.0	0	0	0	0	1
07/26/2021 10:00	0.0	0	0	0	0	1
07/26/2021 11:00	0.0	0	0	0	0	1
07/26/2021 12:00	0.0	0	0	0	0	1
07/26/2021 13:00	0.0	0	0	0	0	1
07/26/2021 14:00	0.0	0	0	0	0	1
07/26/2021 15:00	0.0	0	0	0	0	1
07/26/2021 16:00	0.0	0	0	0	0	1
07/26/2021 17:00	0.0	0	0	0	0	1
07/26/2021 18:00	0.0	0	0	0	0	1
07/26/2021 19:00	0.0	0	0	0	0	1
07/26/2021 20:00	0.0	0	0	0	0	1
07/26/2021 21:00	0.0	0	0	0	0	1
07/26/2021 22:00	0.0	0	0	0	0	1
07/26/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/27/2021 00:00	0.0	0	0	0	0	1
07/27/2021 01:00	0.0	0	0	0	0	1
07/27/2021 02:00	0.0	0	0	0	0	1
07/27/2021 03:00	0.0	0	0	0	0	1
07/27/2021 04:00	0.0	0	0	0	0	1
07/27/2021 05:00	0.0	0	0	0	0	1
07/27/2021 06:00	0.0	0	0	0	0	1
07/27/2021 07:00	0.0	0	0	0	0	1
07/27/2021 08:00	0.0	0	0	0	0	1
07/27/2021 09:00	0.0	0	0	0	0	1
07/27/2021 10:00	0.0	0	0	0	0	1
07/27/2021 11:00	0.0	0	0	0	0	1
07/27/2021 12:00	0.0	0	0	0	0	1
07/27/2021 13:00	0.0	0	0	0	0	1
07/27/2021 14:00	0.0	0	0	0	0	1
07/27/2021 15:00	0.0	0	0	0	0	1
07/27/2021 16:00	0.0	0	0	0	0	1
07/27/2021 17:00	0.0	0	0	0	0	1
07/27/2021 18:00	0.0	0	0	0	0	1
07/27/2021 19:00	0.0	0	0	0	0	1
07/27/2021 20:00	0.0	0	0	0	0	1
07/27/2021 21:00	0.0	0	0	0	0	1
07/27/2021 22:00	0.0	0	0	0	0	1
07/27/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/28/2021 00:00	0.0	0	0	0	0	1
07/28/2021 01:00	0.0	0	0	0	0	1
07/28/2021 02:00	0.0	0	0	0	0	1
07/28/2021 03:00	0.0	0	0	0	0	1
07/28/2021 04:00	0.0	0	0	0	0	1
07/28/2021 05:00	0.0	0	0	0	0	1
07/28/2021 06:00	0.0	0	0	0	0	1
07/28/2021 07:00	0.0	0	0	0	0	1
07/28/2021 08:00	0.0	0	0	0	0	1
07/28/2021 09:00	0.0	0	0	0	0	1
07/28/2021 10:00	0.0	0	0	0	0	1
07/28/2021 11:00	0.0	0	0	0	0	1
07/28/2021 12:00	0.0	0	0	0	0	1
07/28/2021 13:00	0.0	0	0	0	0	1
07/28/2021 14:00	0.0	0	0	0	0	1
07/28/2021 15:00	0.0	0	0	0	0	1
07/28/2021 16:00	0.0	0	0	0	0	1
07/28/2021 17:00	0.0	0	0	0	0	1
07/28/2021 18:00	0.0	0	0	0	0	1
07/28/2021 19:00	0.0	0	0	0	0	1
07/28/2021 20:00	0.0	0	0	0	0	1
07/28/2021 21:00	0.0	0	0	0	0	1
07/28/2021 22:00	0.0	0	0	0	0	1
07/28/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/29/2021 00:00	0.0	0	0	0	0	1
07/29/2021 01:00	0.0	0	0	0	0	1
07/29/2021 02:00	0.0	0	0	0	0	1
07/29/2021 03:00	0.0	0	0	0	0	1
07/29/2021 04:00	0.0	0	0	0	0	1
07/29/2021 05:00	0.0	0	0	0	0	1
07/29/2021 06:00	0.0	0	0	0	0	1
07/29/2021 07:00	0.0	0	0	0	0	1
07/29/2021 08:00	0.0	0	0	0	0	1
07/29/2021 09:00	0.0	0	0	0	0	1
07/29/2021 10:00	0.0	0	0	0	0	1
07/29/2021 11:00	0.0	0	0	0	0	1
07/29/2021 12:00	0.0	0	0	0	0	1
07/29/2021 13:00	0.0	0	0	0	0	1
07/29/2021 14:00	0.0	0	0	0	0	1
07/29/2021 15:00	0.0	0	0	0	0	1
07/29/2021 16:00	0.0	0	0	0	0	1
07/29/2021 17:00	0.0	0	0	0	0	1
07/29/2021 18:00	0.0	0	0	0	0	1
07/29/2021 19:00	0.0	0	0	0	0	1
07/29/2021 20:00	0.0	0	0	0	0	1
07/29/2021 21:00	0.0	0	0	0	0	1
07/29/2021 22:00	0.0	0	0	0	0	1
07/29/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/30/2021 00:00	0.0	0	0	0	0	1
07/30/2021 01:00	0.0	0	0	0	0	1
07/30/2021 02:00	0.0	0	0	0	0	1
07/30/2021 03:00	0.0	0	0	0	0	1
07/30/2021 04:00	0.0	0	0	0	0	1
07/30/2021 05:00	0.0	0	0	0	0	1
07/30/2021 06:00	0.0	0	0	0	0	1
07/30/2021 07:00	0.0	0	0	0	0	1
07/30/2021 08:00	0.0	0	0	0	0	1
07/30/2021 09:00	0.0	0	0	0	0	1
07/30/2021 10:00	0.0	0	0	0	0	1
07/30/2021 11:00	0.0	0	0	0	0	1
07/30/2021 12:00	0.0	0	0	0	0	1
07/30/2021 13:00	0.0	0	0	0	0	1
07/30/2021 14:00	0.0	0	0	0	0	1
07/30/2021 15:00	0.0	0	0	0	0	1
07/30/2021 16:00	0.0	0	0	0	0	1
07/30/2021 17:00	0.0	0	0	0	0	1
07/30/2021 18:00	0.0	0	0	0	0	1
07/30/2021 19:00	0.0	0	0	0	0	1
07/30/2021 20:00	0.0	0	0	0	0	1
07/30/2021 21:00	0.0	0	0	0	0	1
07/30/2021 22:00	0.0	0	0	0	0	1
07/30/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/31/2021 00:00	0.0	0	0	0	0	1
07/31/2021 01:00	0.0	0	0	0	0	1
07/31/2021 02:00	0.0	0	0	0	0	1
07/31/2021 03:00	0.0	0	0	0	0	1
07/31/2021 04:00	0.0	0	0	0	0	1
07/31/2021 05:00	0.0	0	0	0	0	1
07/31/2021 06:00	0.0	0	0	0	0	1
07/31/2021 07:00	0.0	0	0	0	0	1
07/31/2021 08:00	0.0	0	0	0	0	1
07/31/2021 09:00	0.0	0	0	0	0	1
07/31/2021 10:00	0.0	0	0	0	0	1
07/31/2021 11:00	0.0	0	0	0	0	1
07/31/2021 12:00	0.0	0	0	0	0	1
07/31/2021 13:00	0.0	0	0	0	0	1
07/31/2021 14:00	0.0	0	0	0	0	1
07/31/2021 15:00	0.0	0	0	0	0	1
07/31/2021 16:00	0.0	0	0	0	0	1
07/31/2021 17:00	0.0	0	0	0	0	1
07/31/2021 18:00	0.0	0	0	0	0	1
07/31/2021 19:00	0.0	0	0	0	0	1
07/31/2021 20:00	0.0	0	0	0	0	1
07/31/2021 21:00	0.0	0	0	0	0	1
07/31/2021 22:00	0.0	0	0	0	0	1
07/31/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/01/2021 00:00	0.0	0	0	0	0	1
08/01/2021 01:00	0.0	0	0	0	0	1
08/01/2021 02:00	0.0	0	0	0	0	1
08/01/2021 03:00	0.0	0	0	0	0	1
08/01/2021 04:00	0.0	0	0	0	0	1
08/01/2021 05:00	0.0	0	0	0	0	1
08/01/2021 06:00	0.0	0	0	0	0	1
08/01/2021 07:00	0.0	0	0	0	0	1
08/01/2021 08:00	0.0	0	0	0	0	1
08/01/2021 09:00	0.0	0	0	0	0	1
08/01/2021 10:00	0.0	0	0	0	0	1
08/01/2021 11:00	0.0	0	0	0	0	1
08/01/2021 12:00	0.0	0	0	0	0	1
08/01/2021 13:00	0.0	0	0	0	0	1
08/01/2021 14:00	0.0	0	0	0	0	1
08/01/2021 15:00	0.0	0	0	0	0	1
08/01/2021 16:00	0.0	0	0	0	0	1
08/01/2021 17:00	0.0	0	0	0	0	1
08/01/2021 18:00	0.0	0	0	0	0	1
08/01/2021 19:00	0.0	0	0	0	0	1
08/01/2021 20:00	0.0	0	0	0	0	1
08/01/2021 21:00	0.0	0	0	0	0	1
08/01/2021 22:00	0.0	0	0	0	0	1
08/01/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/02/2021 00:00	0.0	0	0	0	0	1
08/02/2021 01:00	0.0	0	0	0	0	1
08/02/2021 02:00	0.0	0	0	0	0	1
08/02/2021 03:00	0.0	0	0	0	0	1
08/02/2021 04:00	0.0	0	0	0	0	1
08/02/2021 05:00	0.0	0	0	0	0	1
08/02/2021 06:00	0.0	0	0	0	0	1
08/02/2021 07:00	0.0	0	0	0	0	1
08/02/2021 08:00	0.0	0	0	0	0	1
08/02/2021 09:00	0.0	0	0	0	0	1
08/02/2021 10:00	0.0	0	0	0	0	1
08/02/2021 11:00	0.0	0	0	0	0	1
08/02/2021 12:00	0.0	0	0	0	0	1
08/02/2021 13:00	0.0	0	0	0	0	1
08/02/2021 14:00	0.0	0	0	0	0	1
08/02/2021 15:00	0.0	0	0	0	0	1
08/02/2021 16:00	0.0	0	0	0	0	1
08/02/2021 17:00	0.0	0	0	0	0	1
08/02/2021 18:00	0.0	0	0	0	0	1
08/02/2021 19:00	0.0	0	0	0	0	1
08/02/2021 20:00	0.0	0	0	0	0	1
08/02/2021 21:00	0.0	0	0	0	0	1
08/02/2021 22:00	0.0	0	0	0	0	1
08/02/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/03/2021 00:00	0.0	0	0	0	0	1
08/03/2021 01:00	0.0	0	0	0	0	1
08/03/2021 02:00	0.0	0	0	0	0	1
08/03/2021 03:00	0.0	0	0	0	0	1
08/03/2021 04:00	170.8	0	0	0	1	0
08/03/2021 05:00	0.0	0	0	0	0	0
08/03/2021 06:00	0.0	0	0	0	0	0
08/03/2021 07:00	0.0	0	0	0	0	0
08/03/2021 08:00	0.0	0	0	0	0	0
08/03/2021 09:00	0.0	0	0	0	0	0
08/03/2021 10:00	0.0	0	0	0	0	0
08/03/2021 11:00	4,712.7	0	0	1	0	0
08/03/2021 12:00	1,319.4	0	0	1	0	0
08/03/2021 13:00	0.0	0	0	0	0	1
08/03/2021 14:00	0.0	0	0	0	0	1
08/03/2021 15:00	0.0	0	0	0	0	1
08/03/2021 16:00	0.0	0	0	0	0	1
08/03/2021 17:00	0.0	0	0	0	0	1
08/03/2021 18:00	0.0	0	0	0	0	1
08/03/2021 19:00	0.0	0	0	0	0	1
08/03/2021 20:00	0.0	0	0	0	0	1
08/03/2021 21:00	0.0	0	0	0	0	1
08/03/2021 22:00	0.0	0	0	0	0	1
08/03/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	6,202.9 #	0 #	0 #	2 #	1 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	4,712.7	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/04/2021 00:00	0.0	0	0	0	0	1
08/04/2021 01:00	0.0	0	0	0	0	1
08/04/2021 02:00	0.0	0	0	0	0	1
08/04/2021 03:00	0.0	0	0	0	0	1
08/04/2021 04:00	0.0	0	0	0	0	1
08/04/2021 05:00	0.0	0	0	0	0	1
08/04/2021 06:00	0.0	0	0	0	0	1
08/04/2021 07:00	0.0	0	0	0	0	1
08/04/2021 08:00	0.0	0	0	0	0	1
08/04/2021 09:00	0.0	0	0	0	0	1
08/04/2021 10:00	0.0	0	0	0	0	1
08/04/2021 11:00	0.0	0	0	0	0	1
08/04/2021 12:00	0.0	0	0	0	0	1
08/04/2021 13:00	0.0	0	0	0	0	1
08/04/2021 14:00	0.0	0	0	0	0	1
08/04/2021 15:00	0.0	0	0	0	0	1
08/04/2021 16:00	0.0	0	0	0	0	1
08/04/2021 17:00	0.0	0	0	0	0	1
08/04/2021 18:00	0.0	0	0	0	0	1
08/04/2021 19:00	0.0	0	0	0	0	1
08/04/2021 20:00	0.0	0	0	0	0	1
08/04/2021 21:00	0.0	0	0	0	0	1
08/04/2021 22:00	0.0	0	0	0	0	1
08/04/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/05/2021 00:00	0.0	0	0	0	0	1
08/05/2021 01:00	0.0	0	0	0	0	1
08/05/2021 02:00	0.0	0	0	0	0	1
08/05/2021 03:00	0.0	0	0	0	0	1
08/05/2021 04:00	0.0	0	0	0	0	1
08/05/2021 05:00	0.0	0	0	0	0	1
08/05/2021 06:00	0.0	0	0	0	0	1
08/05/2021 07:00	0.0	0	0	0	0	1
08/05/2021 08:00	0.0	0	0	0	0	1
08/05/2021 09:00	0.0	0	0	0	0	1
08/05/2021 10:00	0.0	0	0	0	0	1
08/05/2021 11:00	0.0	0	0	0	0	1
08/05/2021 12:00	0.0	0	0	0	0	1
08/05/2021 13:00	0.0	0	0	0	0	1
08/05/2021 14:00	0.0	0	0	0	0	1
08/05/2021 15:00	0.0	0	0	0	0	1
08/05/2021 16:00	0.0	0	0	0	0	1
08/05/2021 17:00	0.0	0	0	0	0	1
08/05/2021 18:00	0.0	0	0	0	0	1
08/05/2021 19:00	0.0	0	0	0	0	1
08/05/2021 20:00	0.0	0	0	0	0	1
08/05/2021 21:00	0.0	0	0	0	0	1
08/05/2021 22:00	0.0	0	0	0	0	1
08/05/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/06/2021 00:00	0.0	0	0	0	0	1
08/06/2021 01:00	0.0	0	0	0	0	1
08/06/2021 02:00	0.0	0	0	0	0	1
08/06/2021 03:00	0.0	0	0	0	0	1
08/06/2021 04:00	0.0	0	0	0	0	1
08/06/2021 05:00	0.0	0	0	0	0	1
08/06/2021 06:00	0.0	0	0	0	0	1
08/06/2021 07:00	0.0	0	0	0	0	1
08/06/2021 08:00	0.0	0	0	0	0	1
08/06/2021 09:00	0.0	0	0	0	0	1
08/06/2021 10:00	0.0	0	0	0	0	1
08/06/2021 11:00	0.0	0	0	0	0	1
08/06/2021 12:00	0.0	0	0	0	0	1
08/06/2021 13:00	0.0	0	0	0	0	1
08/06/2021 14:00	0.0	0	0	0	0	1
08/06/2021 15:00	0.0	0	0	0	0	1
08/06/2021 16:00	0.0	0	0	0	0	1
08/06/2021 17:00	0.0	0	0	0	0	1
08/06/2021 18:00	0.0	0	0	0	0	1
08/06/2021 19:00	0.0	0	0	0	0	1
08/06/2021 20:00	0.0	0	0	0	0	1
08/06/2021 21:00	0.0	0	0	0	0	1
08/06/2021 22:00	0.0	0	0	0	0	1
08/06/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/07/2021 00:00	0.0	0	0	0	0	1
08/07/2021 01:00	0.0	0	0	0	0	1
08/07/2021 02:00	0.0	0	0	0	0	1
08/07/2021 03:00	48.9	0	0	0	1	0
08/07/2021 04:00	0.0	0	0	0	0	0
08/07/2021 05:00	0.0	0	0	0	0	0
08/07/2021 06:00	0.0	0	0	0	0	0
08/07/2021 07:00	0.0	0	0	0	0	0
08/07/2021 08:00	0.0	0	0	0	0	0
08/07/2021 09:00	384.4	0	0	1	0	0
08/07/2021 10:00	5,398.1	0	0	1	0	0
08/07/2021 11:00	1,983.7	0	0	1	1	0
08/07/2021 12:00	5,567.5	0	0	1	0	0
08/07/2021 13:00	0.0	0	0	0	0	1
08/07/2021 14:00	0.0	0	0	0	0	1
08/07/2021 15:00	0.0	0	0	0	0	1
08/07/2021 16:00	0.0	0	0	0	0	1
08/07/2021 17:00	0.0	0	0	0	0	1
08/07/2021 18:00	0.0	0	0	0	0	1
08/07/2021 19:00	0.0	0	0	0	0	1
08/07/2021 20:00	0.0	0	0	0	0	1
08/07/2021 21:00	0.0	0	0	0	0	1
08/07/2021 22:00	0.0	0	0	0	0	1
08/07/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	13,382.6 #	0 #	0 #	4 #	2 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,567.5	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/08/2021 00:00	0.0	0	0	0	0	1
08/08/2021 01:00	0.0	0	0	0	0	1
08/08/2021 02:00	0.0	0	0	0	0	1
08/08/2021 03:00	0.0	0	0	0	0	1
08/08/2021 04:00	0.0	0	0	0	0	1
08/08/2021 05:00	0.0	0	0	0	0	1
08/08/2021 06:00	0.0	0	0	0	0	1
08/08/2021 07:00	0.0	0	0	0	0	1
08/08/2021 08:00	0.0	0	0	0	0	1
08/08/2021 09:00	0.0	0	0	0	0	1
08/08/2021 10:00	0.0	0	0	0	0	1
08/08/2021 11:00	0.0	0	0	0	0	1
08/08/2021 12:00	0.0	0	0	0	0	1
08/08/2021 13:00	0.0	0	0	0	0	1
08/08/2021 14:00	0.0	0	0	0	0	1
08/08/2021 15:00	0.0	0	0	0	0	1
08/08/2021 16:00	0.0	0	0	0	0	1
08/08/2021 17:00	0.0	0	0	0	0	1
08/08/2021 18:00	0.0	0	0	0	0	1
08/08/2021 19:00	0.0	0	0	0	0	1
08/08/2021 20:00	0.0	0	0	0	0	1
08/08/2021 21:00	0.0	0	0	0	0	1
08/08/2021 22:00	0.0	0	0	0	0	1
08/08/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/09/2021 00:00	0.0	0	0	0	0	1
08/09/2021 01:00	0.0	0	0	0	0	1
08/09/2021 02:00	0.0	0	0	0	0	1
08/09/2021 03:00	0.0	0	0	0	0	1
08/09/2021 04:00	0.0	0	0	0	0	1
08/09/2021 05:00	0.0	0	0	0	0	1
08/09/2021 06:00	0.0	0	0	0	0	1
08/09/2021 07:00	0.0	0	0	0	0	1
08/09/2021 08:00	0.0	0	0	0	0	1
08/09/2021 09:00	0.0	0	0	0	0	1
08/09/2021 10:00	0.0	0	0	0	0	1
08/09/2021 11:00	0.0	0	0	0	0	1
08/09/2021 12:00	0.0	0	0	0	0	1
08/09/2021 13:00	0.0	0	0	0	0	1
08/09/2021 14:00	0.0	0	0	0	0	1
08/09/2021 15:00	0.0	0	0	0	0	1
08/09/2021 16:00	0.0	0	0	0	0	1
08/09/2021 17:00	0.0	0	0	0	0	1
08/09/2021 18:00	0.0	0	0	0	0	1
08/09/2021 19:00	0.0	0	0	0	0	1
08/09/2021 20:00	0.0	0	0	0	0	1
08/09/2021 21:00	0.0	0	0	0	0	1
08/09/2021 22:00	0.0	0	0	0	0	1
08/09/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/10/2021 00:00	0.0	0	0	0	0	1
08/10/2021 01:00	0.0	0	0	0	0	1
08/10/2021 02:00	0.0	0	0	0	0	1
08/10/2021 03:00	0.0	0	0	0	0	1
08/10/2021 04:00	0.0	0	0	0	0	1
08/10/2021 05:00	0.0	0	0	0	0	1
08/10/2021 06:00	0.0	0	0	0	0	1
08/10/2021 07:00	0.0	0	0	0	0	1
08/10/2021 08:00	0.0	0	0	0	0	1
08/10/2021 09:00	0.0	0	0	0	0	1
08/10/2021 10:00	0.0	0	0	0	0	1
08/10/2021 11:00	0.0	0	0	0	0	1
08/10/2021 12:00	0.0	0	0	0	0	1
08/10/2021 13:00	0.0	0	0	0	0	1
08/10/2021 14:00	0.0	0	0	0	0	1
08/10/2021 15:00	0.0	0	0	0	0	1
08/10/2021 16:00	0.0	0	0	0	0	1
08/10/2021 17:00	0.0	0	0	0	0	1
08/10/2021 18:00	0.0	0	0	0	0	1
08/10/2021 19:00	0.0	0	0	0	0	1
08/10/2021 20:00	0.0	0	0	0	0	1
08/10/2021 21:00	0.0	0	0	0	0	1
08/10/2021 22:00	0.0	0	0	0	0	1
08/10/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/11/2021 00:00	0.0	0	0	0	0	1
08/11/2021 01:00	0.0	0	0	0	0	1
08/11/2021 02:00	0.0	0	0	0	0	1
08/11/2021 03:00	0.0	0	0	0	0	1
08/11/2021 04:00	0.0	0	0	0	0	1
08/11/2021 05:00	0.0	0	0	0	0	1
08/11/2021 06:00	0.0	0	0	0	0	1
08/11/2021 07:00	0.0	0	0	0	0	1
08/11/2021 08:00	0.0	0	0	0	0	1
08/11/2021 09:00	0.0	0	0	0	0	1
08/11/2021 10:00	0.0	0	0	0	0	1
08/11/2021 11:00	0.0	0	0	0	0	1
08/11/2021 12:00	0.0	0	0	0	0	1
08/11/2021 13:00	0.0	0	0	0	0	1
08/11/2021 14:00	0.0	0	0	0	0	1
08/11/2021 15:00	0.0	0	0	0	0	1
08/11/2021 16:00	0.0	0	0	0	0	1
08/11/2021 17:00	0.0	0	0	0	0	1
08/11/2021 18:00	0.0	0	0	0	0	1
08/11/2021 19:00	0.0	0	0	0	0	1
08/11/2021 20:00	0.0	0	0	0	0	1
08/11/2021 21:00	0.0	0	0	0	0	1
08/11/2021 22:00	0.0	0	0	0	0	1
08/11/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/12/2021 00:00	0.0	0	0	0	0	1
08/12/2021 01:00	0.0	0	0	0	0	1
08/12/2021 02:00	0.0	0	0	0	0	1
08/12/2021 03:00	0.0	0	0	0	0	1
08/12/2021 04:00	0.0	0	0	0	0	1
08/12/2021 05:00	0.0	0	0	0	0	1
08/12/2021 06:00	0.0	0	0	0	0	1
08/12/2021 07:00	0.0	0	0	0	0	1
08/12/2021 08:00	0.0	0	0	0	0	1
08/12/2021 09:00	0.0	0	0	0	0	1
08/12/2021 10:00	0.0	0	0	0	0	1
08/12/2021 11:00	0.0	0	0	0	0	1
08/12/2021 12:00	0.0	0	0	0	0	1
08/12/2021 13:00	0.0	0	0	0	0	1
08/12/2021 14:00	0.0	0	0	0	0	1
08/12/2021 15:00	0.0	0	0	0	0	1
08/12/2021 16:00	0.0	0	0	0	0	1
08/12/2021 17:00	0.0	0	0	0	0	1
08/12/2021 18:00	0.0	0	0	0	0	1
08/12/2021 19:00	0.0	0	0	0	0	1
08/12/2021 20:00	0.0	0	0	0	0	1
08/12/2021 21:00	0.0	0	0	0	0	1
08/12/2021 22:00	0.0	0	0	0	0	1
08/12/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/13/2021 00:00	0.0	0	0	0	0	1
08/13/2021 01:00	0.0	0	0	0	0	1
08/13/2021 02:00	0.0	0	0	0	0	1
08/13/2021 03:00	0.0	0	0	0	0	1
08/13/2021 04:00	0.0	0	0	0	0	1
08/13/2021 05:00	0.0	0	0	0	0	1
08/13/2021 06:00	0.0	0	0	0	0	1
08/13/2021 07:00	0.0	0	0	0	0	1
08/13/2021 08:00	0.0	0	0	0	0	1
08/13/2021 09:00	0.0	0	0	0	0	1
08/13/2021 10:00	0.0	0	0	0	0	1
08/13/2021 11:00	0.0	0	0	0	0	1
08/13/2021 12:00	0.0	0	0	0	0	1
08/13/2021 13:00	0.0	0	0	0	0	1
08/13/2021 14:00	0.0	0	0	0	0	1
08/13/2021 15:00	0.0	0	0	0	0	1
08/13/2021 16:00	0.0	0	0	0	0	1
08/13/2021 17:00	0.0	0	0	0	0	1
08/13/2021 18:00	0.0	0	0	0	0	1
08/13/2021 19:00	0.0	0	0	0	0	1
08/13/2021 20:00	0.0	0	0	0	0	1
08/13/2021 21:00	0.0	0	0	0	0	1
08/13/2021 22:00	0.0	0	0	0	0	1
08/13/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/14/2021 00:00	0.0	0	0	0	0	1
08/14/2021 01:00	0.0	0	0	0	0	1
08/14/2021 02:00	0.0	0	0	0	0	1
08/14/2021 03:00	0.0	0	0	0	0	1
08/14/2021 04:00	0.0	0	0	0	0	1
08/14/2021 05:00	0.0	0	0	0	0	1
08/14/2021 06:00	0.0	0	0	0	0	1
08/14/2021 07:00	0.0	0	0	0	0	1
08/14/2021 08:00	0.0	0	0	0	0	1
08/14/2021 09:00	0.0	0	0	0	0	1
08/14/2021 10:00	0.0	0	0	0	0	1
08/14/2021 11:00	0.0	0	0	0	0	1
08/14/2021 12:00	0.0	0	0	0	0	1
08/14/2021 13:00	0.0	0	0	0	0	1
08/14/2021 14:00	0.0	0	0	0	0	1
08/14/2021 15:00	0.0	0	0	0	0	1
08/14/2021 16:00	0.0	0	0	0	0	1
08/14/2021 17:00	0.0	0	0	0	0	1
08/14/2021 18:00	0.0	0	0	0	0	1
08/14/2021 19:00	0.0	0	0	0	0	1
08/14/2021 20:00	0.0	0	0	0	0	1
08/14/2021 21:00	0.0	0	0	0	0	1
08/14/2021 22:00	0.0	0	0	0	0	1
08/14/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/15/2021 00:00	0.0	0	0	0	0	1
08/15/2021 01:00	0.0	0	0	0	0	1
08/15/2021 02:00	0.0	0	0	0	0	1
08/15/2021 03:00	0.0	0	0	0	0	1
08/15/2021 04:00	0.0	0	0	0	0	1
08/15/2021 05:00	0.0	0	0	0	0	1
08/15/2021 06:00	0.0	0	0	0	0	1
08/15/2021 07:00	0.0	0	0	0	0	1
08/15/2021 08:00	0.0	0	0	0	0	1
08/15/2021 09:00	0.0	0	0	0	0	1
08/15/2021 10:00	0.0	0	0	0	0	1
08/15/2021 11:00	0.0	0	0	0	0	1
08/15/2021 12:00	0.0	0	0	0	0	1
08/15/2021 13:00	0.0	0	0	0	0	1
08/15/2021 14:00	0.0	0	0	0	0	1
08/15/2021 15:00	0.0	0	0	0	0	1
08/15/2021 16:00	0.0	0	0	0	0	1
08/15/2021 17:00	0.0	0	0	0	0	1
08/15/2021 18:00	0.0	0	0	0	0	1
08/15/2021 19:00	0.0	0	0	0	0	1
08/15/2021 20:00	0.0	0	0	0	0	1
08/15/2021 21:00	0.0	0	0	0	0	1
08/15/2021 22:00	0.0	0	0	0	0	1
08/15/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/16/2021 00:00	0.0	0	0	0	0	1
08/16/2021 01:00	0.0	0	0	0	0	1
08/16/2021 02:00	0.0	0	0	0	0	1
08/16/2021 03:00	0.0	0	0	0	0	1
08/16/2021 04:00	0.0	0	0	0	0	1
08/16/2021 05:00	0.0	0	0	0	0	1
08/16/2021 06:00	0.0	0	0	0	0	1
08/16/2021 07:00	0.0	0	0	0	0	1
08/16/2021 08:00	0.0	0	0	0	0	1
08/16/2021 09:00	0.0	0	0	0	0	1
08/16/2021 10:00	0.0	0	0	0	0	1
08/16/2021 11:00	0.0	0	0	0	0	1
08/16/2021 12:00	0.0	0	0	0	0	1
08/16/2021 13:00	0.0	0	0	0	0	1
08/16/2021 14:00	0.0	0	0	0	0	1
08/16/2021 15:00	0.0	0	0	0	0	1
08/16/2021 16:00	0.0	0	0	0	0	1
08/16/2021 17:00	0.0	0	0	0	0	1
08/16/2021 18:00	0.0	0	0	0	0	1
08/16/2021 19:00	0.0	0	0	0	0	1
08/16/2021 20:00	0.0	0	0	0	0	1
08/16/2021 21:00	0.0	0	0	0	0	1
08/16/2021 22:00	0.0	0	0	0	0	1
08/16/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/17/2021 00:00	0.0	0	0	0	0	1
08/17/2021 01:00	0.0	0	0	0	0	1
08/17/2021 02:00	0.0	0	0	0	0	1
08/17/2021 03:00	0.0	0	0	0	0	1
08/17/2021 04:00	0.0	0	0	0	0	1
08/17/2021 05:00	0.0	0	0	0	0	1
08/17/2021 06:00	0.0	0	0	0	0	1
08/17/2021 07:00	0.0	0	0	0	0	1
08/17/2021 08:00	0.0	0	0	0	0	1
08/17/2021 09:00	0.0	0	0	0	0	1
08/17/2021 10:00	0.0	0	0	0	0	1
08/17/2021 11:00	0.0	0	0	0	0	1
08/17/2021 12:00	0.0	0	0	0	0	1
08/17/2021 13:00	0.0	0	0	0	0	1
08/17/2021 14:00	0.0	0	0	0	0	1
08/17/2021 15:00	0.0	0	0	0	0	1
08/17/2021 16:00	0.0	0	0	0	0	1
08/17/2021 17:00	0.0	0	0	0	0	1
08/17/2021 18:00	0.0	0	0	0	0	1
08/17/2021 19:00	0.0	0	0	0	0	1
08/17/2021 20:00	0.0	0	0	0	0	1
08/17/2021 21:00	0.0	0	0	0	0	1
08/17/2021 22:00	0.0	0	0	0	0	1
08/17/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/18/2021 00:00	0.0	0	0	0	0	1
08/18/2021 01:00	0.0	0	0	0	0	1
08/18/2021 02:00	0.0	0	0	0	0	1
08/18/2021 03:00	0.0	0	0	0	0	1
08/18/2021 04:00	0.0	0	0	0	0	1
08/18/2021 05:00	0.0	0	0	0	0	1
08/18/2021 06:00	0.0	0	0	0	0	1
08/18/2021 07:00	0.0	0	0	0	0	1
08/18/2021 08:00	0.0	0	0	0	0	1
08/18/2021 09:00	0.0	0	0	0	0	1
08/18/2021 10:00	0.0	0	0	0	0	1
08/18/2021 11:00	0.0	0	0	0	0	1
08/18/2021 12:00	0.0	0	0	0	0	1
08/18/2021 13:00	0.0	0	0	0	0	1
08/18/2021 14:00	0.0	0	0	0	0	1
08/18/2021 15:00	0.0	0	0	0	0	1
08/18/2021 16:00	0.0	0	0	0	0	1
08/18/2021 17:00	0.0	0	0	0	0	1
08/18/2021 18:00	0.0	0	0	0	0	1
08/18/2021 19:00	0.0	0	0	0	0	1
08/18/2021 20:00	0.0	0	0	0	0	1
08/18/2021 21:00	0.0	0	0	0	0	1
08/18/2021 22:00	0.0	0	0	0	0	1
08/18/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/19/2021 00:00	0.0	0	0	0	0	1
08/19/2021 01:00	0.0	0	0	0	0	1
08/19/2021 02:00	0.0	0	0	0	0	1
08/19/2021 03:00	0.0	0	0	0	0	1
08/19/2021 04:00	0.0	0	0	0	0	1
08/19/2021 05:00	0.0	0	0	0	0	1
08/19/2021 06:00	0.0	0	0	0	0	1
08/19/2021 07:00	0.0	0	0	0	0	1
08/19/2021 08:00	0.0	0	0	0	0	1
08/19/2021 09:00	0.0	0	0	0	0	1
08/19/2021 10:00	0.0	0	0	0	0	1
08/19/2021 11:00	0.0	0	0	0	0	1
08/19/2021 12:00	0.0	0	0	0	0	1
08/19/2021 13:00	0.0	0	0	0	0	1
08/19/2021 14:00	0.0	0	0	0	0	1
08/19/2021 15:00	0.0	0	0	0	0	1
08/19/2021 16:00	0.0	0	0	0	0	1
08/19/2021 17:00	0.0	0	0	0	0	1
08/19/2021 18:00	0.0	0	0	0	0	1
08/19/2021 19:00	0.0	0	0	0	0	1
08/19/2021 20:00	0.0	0	0	0	0	1
08/19/2021 21:00	0.0	0	0	0	0	1
08/19/2021 22:00	0.0	0	0	0	0	1
08/19/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/20/2021 00:00	0.0	0	0	0	0	1
08/20/2021 01:00	0.0	0	0	0	0	1
08/20/2021 02:00	0.0	0	0	0	0	1
08/20/2021 03:00	0.0	0	0	0	0	1
08/20/2021 04:00	0.0	0	0	0	0	1
08/20/2021 05:00	0.0	0	0	0	0	1
08/20/2021 06:00	0.0	0	0	0	0	1
08/20/2021 07:00	0.0	0	0	0	0	1
08/20/2021 08:00	0.0	0	0	0	0	1
08/20/2021 09:00	0.0	0	0	0	0	1
08/20/2021 10:00	0.0	0	0	0	0	1
08/20/2021 11:00	0.0	0	0	0	0	1
08/20/2021 12:00	0.0	0	0	0	0	1
08/20/2021 13:00	0.0	0	0	0	0	1
08/20/2021 14:00	0.0	0	0	0	0	1
08/20/2021 15:00	0.0	0	0	0	0	1
08/20/2021 16:00	0.0	0	0	0	0	1
08/20/2021 17:00	0.0	0	0	0	0	1
08/20/2021 18:00	0.0	0	0	0	0	1
08/20/2021 19:00	0.0	0	0	0	0	1
08/20/2021 20:00	0.0	0	0	0	0	1
08/20/2021 21:00	0.0	0	0	0	0	1
08/20/2021 22:00	0.0	0	0	0	0	1
08/20/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/21/2021 00:00	58.5	0	0	0	1	0
08/21/2021 01:00	1,497.7	0	0	1	0	0
08/21/2021 02:00	3,324.7	0	0	1	0	0
08/21/2021 03:00	0.0	0	0	0	0	1
08/21/2021 04:00	0.0	0	0	0	0	1
08/21/2021 05:00	0.0	0	0	0	0	1
08/21/2021 06:00	0.0	0	0	0	0	1
08/21/2021 07:00	0.0	0	0	0	0	1
08/21/2021 08:00	0.0	0	0	0	0	1
08/21/2021 09:00	0.0	0	0	0	0	1
08/21/2021 10:00	0.0	0	0	0	0	1
08/21/2021 11:00	0.0	0	0	0	0	1
08/21/2021 12:00	0.0	0	0	0	0	1
08/21/2021 13:00	0.0	0	0	0	0	1
08/21/2021 14:00	0.0	0	0	0	0	1
08/21/2021 15:00	18.1	0	0	0	1	0
08/21/2021 16:00	0.0	0	0	0	0	0
08/21/2021 17:00	0.0	0	0	0	0	0
08/21/2021 18:00	0.0	0	0	0	0	0
08/21/2021 19:00	0.0	0	0	0	0	0
08/21/2021 20:00	0.0	0	0	0	0	0
08/21/2021 21:00	0.0	0	0	0	0	0
08/21/2021 22:00	0.0	0	0	0	0	0
08/21/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	4,899.0 #	0 #	0 #	2 #	2 #	12 #
Minimum:	0.0	0	0	0	0	0
Maximum:	3,324.7	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/22/2021 00:00	0.0	0	0	0	0	0
08/22/2021 01:00	0.0	0	0	0	0	0
08/22/2021 02:00	0.0	0	0	0	0	0
08/22/2021 03:00	0.0	0	0	0	0	0
08/22/2021 04:00	0.0	0	0	0	0	0
08/22/2021 05:00	0.0	0	0	0	0	0
08/22/2021 06:00	0.0	0	0	0	0	0
08/22/2021 07:00	0.0	0	0	0	0	0
08/22/2021 08:00	0.0	0	0	0	0	0
08/22/2021 09:00	0.0	0	0	0	0	0
08/22/2021 10:00	0.0	0	0	0	0	0
08/22/2021 11:00	0.0	0	0	0	0	0
08/22/2021 12:00	0.0	0	0	0	0	0
08/22/2021 13:00	0.0	0	0	0	0	0
08/22/2021 14:00	0.0	0	0	0	0	0
08/22/2021 15:00	0.0	0	0	0	0	0
08/22/2021 16:00	0.0	0	0	0	0	0
08/22/2021 17:00	0.0	0	0	0	0	0
08/22/2021 18:00	0.0	0	0	0	0	0
08/22/2021 19:00	0.0	0	0	0	0	0
08/22/2021 20:00	0.0	0	0	0	0	0
08/22/2021 21:00	0.0	0	0	0	0	0
08/22/2021 22:00	0.0	0	0	0	0	0
08/22/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/23/2021 00:00	0.0	0	0	0	0	0
08/23/2021 01:00	0.0	0	0	0	0	0
08/23/2021 02:00	0.0	0	0	0	0	0
08/23/2021 03:00	0.0	0	0	0	0	0
08/23/2021 04:00	0.0	0	0	0	0	0
08/23/2021 05:00	0.0	0	0	0	0	0
08/23/2021 06:00	0.0	0	0	0	0	0
08/23/2021 07:00	0.0	0	0	0	0	0
08/23/2021 08:00	0.0	0	0	0	0	0
08/23/2021 09:00	2,231.1	0	1	0	0	0
08/23/2021 10:00	3,810.9	0	1	0	0	0
08/23/2021 11:00	7,248.1	0	1	0	0	0
08/23/2021 12:00	14.8	0	0	0	1	0
08/23/2021 13:00	2,936.0	0	0	1	0	0
08/23/2021 14:00	3,825.8	0	0	1	0	0
08/23/2021 15:00	0.0	0	0	0	0	1
08/23/2021 16:00	0.0	0	0	0	0	1
08/23/2021 17:00	0.0	0	0	0	0	1
08/23/2021 18:00	0.0	0	0	0	0	1
08/23/2021 19:00	0.0	0	0	0	0	1
08/23/2021 20:00	0.0	0	0	0	0	1
08/23/2021 21:00	0.0	0	0	0	0	1
08/23/2021 22:00	0.0	0	0	0	0	1
08/23/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	20,066.7 #	0 #	3 #	2 #	1 #	9 #
Minimum:	0.0	0	0	0	0	0
Maximum:	7,248.1	0	1	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/24/2021 00:00	0.0	0	0	0	0	1
08/24/2021 01:00	0.0	0	0	0	0	1
08/24/2021 02:00	0.0	0	0	0	0	1
08/24/2021 03:00	0.0	0	0	0	0	1
08/24/2021 04:00	0.0	0	0	0	0	1
08/24/2021 05:00	0.0	0	0	0	0	1
08/24/2021 06:00	0.0	0	0	0	0	1
08/24/2021 07:00	0.0	0	0	0	0	1
08/24/2021 08:00	0.0	0	0	0	0	1
08/24/2021 09:00	0.0	0	0	0	0	1
08/24/2021 10:00	0.0	0	0	0	0	1
08/24/2021 11:00	0.0	0	0	0	0	1
08/24/2021 12:00	0.0	0	0	0	0	1
08/24/2021 13:00	0.0	0	0	0	0	1
08/24/2021 14:00	0.0	0	0	0	0	1
08/24/2021 15:00	0.0	0	0	0	0	1
08/24/2021 16:00	0.0	0	0	0	0	1
08/24/2021 17:00	0.0	0	0	0	0	1
08/24/2021 18:00	0.0	0	0	0	0	1
08/24/2021 19:00	0.0	0	0	0	0	1
08/24/2021 20:00	0.0	0	0	0	0	1
08/24/2021 21:00	0.0	0	0	0	0	1
08/24/2021 22:00	0.0	0	0	0	0	1
08/24/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/25/2021 00:00	0.0	0	0	0	0	1
08/25/2021 01:00	0.0	0	0	0	0	1
08/25/2021 02:00	0.0	0	0	0	0	1
08/25/2021 03:00	0.0	0	0	0	0	1
08/25/2021 04:00	0.0	0	0	0	0	1
08/25/2021 05:00	0.0	0	0	0	0	1
08/25/2021 06:00	0.0	0	0	0	0	1
08/25/2021 07:00	0.0	0	0	0	0	1
08/25/2021 08:00	0.0	0	0	0	0	1
08/25/2021 09:00	0.0	0	0	0	0	1
08/25/2021 10:00	0.0	0	0	0	0	1
08/25/2021 11:00	0.0	0	0	0	0	1
08/25/2021 12:00	0.0	0	0	0	0	1
08/25/2021 13:00	0.0	0	0	0	0	1
08/25/2021 14:00	0.0	0	0	0	0	1
08/25/2021 15:00	0.0	0	0	0	0	1
08/25/2021 16:00	0.0	0	0	0	0	1
08/25/2021 17:00	0.0	0	0	0	0	1
08/25/2021 18:00	0.0	0	0	0	0	1
08/25/2021 19:00	0.0	0	0	0	0	1
08/25/2021 20:00	0.0	0	0	0	0	1
08/25/2021 21:00	0.0	0	0	0	0	1
08/25/2021 22:00	0.0	0	0	0	0	1
08/25/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/26/2021 00:00	0.0	0	0	0	0	1
08/26/2021 01:00	0.0	0	0	0	0	1
08/26/2021 02:00	0.0	0	0	0	0	1
08/26/2021 03:00	0.0	0	0	0	0	1
08/26/2021 04:00	0.0	0	0	0	0	1
08/26/2021 05:00	0.0	0	0	0	0	1
08/26/2021 06:00	0.0	0	0	0	0	1
08/26/2021 07:00	0.0	0	0	0	0	1
08/26/2021 08:00	0.0	0	0	0	0	1
08/26/2021 09:00	0.0	0	0	0	0	1
08/26/2021 10:00	0.0	0	0	0	0	1
08/26/2021 11:00	0.0	0	0	0	0	1
08/26/2021 12:00	0.0	0	0	0	0	1
08/26/2021 13:00	0.0	0	0	0	0	1
08/26/2021 14:00	0.0	0	0	0	0	1
08/26/2021 15:00	0.0	0	0	0	0	1
08/26/2021 16:00	0.0	0	0	0	0	1
08/26/2021 17:00	0.0	0	0	0	0	1
08/26/2021 18:00	0.0	0	0	0	0	1
08/26/2021 19:00	0.0	0	0	0	0	1
08/26/2021 20:00	0.0	0	0	0	0	1
08/26/2021 21:00	0.0	0	0	0	0	1
08/26/2021 22:00	0.0	0	0	0	0	1
08/26/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/27/2021 00:00	0.0	0	0	0	0	1
08/27/2021 01:00	0.0	0	0	0	0	1
08/27/2021 02:00	0.0	0	0	0	0	1
08/27/2021 03:00	0.0	0	0	0	0	1
08/27/2021 04:00	0.0	0	0	0	0	1
08/27/2021 05:00	0.0	0	0	0	0	1
08/27/2021 06:00	0.0	0	0	0	0	1
08/27/2021 07:00	0.0	0	0	0	0	1
08/27/2021 08:00	0.0	0	0	0	0	1
08/27/2021 09:00	0.0	0	0	0	0	1
08/27/2021 10:00	0.0	0	0	0	0	1
08/27/2021 11:00	0.0	0	0	0	0	1
08/27/2021 12:00	0.0	0	0	0	0	1
08/27/2021 13:00	0.0	0	0	0	0	1
08/27/2021 14:00	0.0	0	0	0	0	1
08/27/2021 15:00	0.0	0	0	0	0	1
08/27/2021 16:00	0.0	0	0	0	0	1
08/27/2021 17:00	0.0	0	0	0	0	1
08/27/2021 18:00	0.0	0	0	0	0	1
08/27/2021 19:00	0.0	0	0	0	0	1
08/27/2021 20:00	0.0	0	0	0	0	1
08/27/2021 21:00	0.0	0	0	0	0	1
08/27/2021 22:00	0.0	0	0	0	0	1
08/27/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/28/2021 00:00	0.0	0	0	0	0	1
08/28/2021 01:00	0.0	0	0	0	0	1
08/28/2021 02:00	0.0	0	0	0	0	1
08/28/2021 03:00	0.0	0	0	0	0	1
08/28/2021 04:00	0.0	0	0	0	0	1
08/28/2021 05:00	0.0	0	0	0	0	1
08/28/2021 06:00	0.0	0	0	0	0	1
08/28/2021 07:00	0.0	0	0	0	0	1
08/28/2021 08:00	0.0	0	0	0	0	1
08/28/2021 09:00	0.0	0	0	0	0	1
08/28/2021 10:00	0.0	0	0	0	0	1
08/28/2021 11:00	0.0	0	0	0	0	1
08/28/2021 12:00	0.0	0	0	0	0	1
08/28/2021 13:00	0.0	0	0	0	0	1
08/28/2021 14:00	0.0	0	0	0	0	1
08/28/2021 15:00	0.0	0	0	0	0	1
08/28/2021 16:00	0.0	0	0	0	0	1
08/28/2021 17:00	0.0	0	0	0	0	1
08/28/2021 18:00	0.0	0	0	0	0	1
08/28/2021 19:00	0.0	0	0	0	0	1
08/28/2021 20:00	0.0	0	0	0	0	1
08/28/2021 21:00	0.0	0	0	0	0	1
08/28/2021 22:00	0.0	0	0	0	0	1
08/28/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/29/2021 00:00	0.0	0	0	0	0	1
08/29/2021 01:00	0.0	0	0	0	0	1
08/29/2021 02:00	0.0	0	0	0	0	1
08/29/2021 03:00	0.0	0	0	0	0	1
08/29/2021 04:00	0.0	0	0	0	0	1
08/29/2021 05:00	0.0	0	0	0	0	1
08/29/2021 06:00	0.0	0	0	0	0	1
08/29/2021 07:00	0.0	0	0	0	0	1
08/29/2021 08:00	0.0	0	0	0	0	1
08/29/2021 09:00	0.0	0	0	0	0	1
08/29/2021 10:00	0.0	0	0	0	0	1
08/29/2021 11:00	0.0	0	0	0	0	1
08/29/2021 12:00	0.0	0	0	0	0	1
08/29/2021 13:00	0.0	0	0	0	0	1
08/29/2021 14:00	0.0	0	0	0	0	1
08/29/2021 15:00	0.0	0	0	0	0	1
08/29/2021 16:00	0.0	0	0	0	0	1
08/29/2021 17:00	0.0	0	0	0	0	1
08/29/2021 18:00	0.0	0	0	0	0	1
08/29/2021 19:00	0.0	0	0	0	0	1
08/29/2021 20:00	0.0	0	0	0	0	1
08/29/2021 21:00	0.0	0	0	0	0	1
08/29/2021 22:00	0.0	0	0	0	0	1
08/29/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/30/2021 00:00	0.0	0	0	0	0	1
08/30/2021 01:00	0.0	0	0	0	0	1
08/30/2021 02:00	0.0	0	0	0	0	1
08/30/2021 03:00	0.0	0	0	0	0	1
08/30/2021 04:00	0.0	0	0	0	0	1
08/30/2021 05:00	0.0	0	0	0	0	1
08/30/2021 06:00	0.0	0	0	0	0	1
08/30/2021 07:00	0.0	0	0	0	0	1
08/30/2021 08:00	0.0	0	0	0	0	1
08/30/2021 09:00	0.0	0	0	0	0	1
08/30/2021 10:00	0.0	0	0	0	0	1
08/30/2021 11:00	0.0	0	0	0	0	1
08/30/2021 12:00	0.0	0	0	0	0	1
08/30/2021 13:00	0.0	0	0	0	0	1
08/30/2021 14:00	0.0	0	0	0	0	1
08/30/2021 15:00	0.0	0	0	0	0	1
08/30/2021 16:00	0.0	0	0	0	0	1
08/30/2021 17:00	0.0	0	0	0	0	1
08/30/2021 18:00	0.0	0	0	0	0	1
08/30/2021 19:00	0.0	0	0	0	0	1
08/30/2021 20:00	0.0	0	0	0	0	1
08/30/2021 21:00	0.0	0	0	0	0	1
08/30/2021 22:00	0.0	0	0	0	0	1
08/30/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/31/2021 00:00	0.0	0	0	0	0	1
08/31/2021 01:00	0.0	0	0	0	0	1
08/31/2021 02:00	0.0	0	0	0	0	1
08/31/2021 03:00	0.0	0	0	0	0	1
08/31/2021 04:00	0.0	0	0	0	0	1
08/31/2021 05:00	0.0	0	0	0	0	1
08/31/2021 06:00	0.0	0	0	0	0	1
08/31/2021 07:00	0.0	0	0	0	0	1
08/31/2021 08:00	0.0	0	0	0	0	1
08/31/2021 09:00	0.0	0	0	0	0	1
08/31/2021 10:00	0.0	0	0	0	0	1
08/31/2021 11:00	0.0	0	0	0	0	1
08/31/2021 12:00	0.0	0	0	0	0	1
08/31/2021 13:00	0.0	0	0	0	0	1
08/31/2021 14:00	0.0	0	0	0	0	1
08/31/2021 15:00	0.0	0	0	0	0	1
08/31/2021 16:00	0.0	0	0	0	0	1
08/31/2021 17:00	0.0	0	0	0	0	1
08/31/2021 18:00	0.0	0	0	0	0	1
08/31/2021 19:00	0.0	0	0	0	0	1
08/31/2021 20:00	0.0	0	0	0	0	1
08/31/2021 21:00	0.0	0	0	0	0	1
08/31/2021 22:00	0.0	0	0	0	0	1
08/31/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/01/2021 00:00	0.0	0	0	0	0	1
09/01/2021 01:00	0.0	0	0	0	0	1
09/01/2021 02:00	0.0	0	0	0	0	1
09/01/2021 03:00	0.0	0	0	0	0	1
09/01/2021 04:00	0.0	0	0	0	0	1
09/01/2021 05:00	0.0	0	0	0	0	1
09/01/2021 06:00	0.0	0	0	0	0	1
09/01/2021 07:00	0.0	0	0	0	0	1
09/01/2021 08:00	0.0	0	0	0	0	1
09/01/2021 09:00	0.0	0	0	0	0	1
09/01/2021 10:00	0.0	0	0	0	0	1
09/01/2021 11:00	0.0	0	0	0	0	1
09/01/2021 12:00	0.0	0	0	0	0	1
09/01/2021 13:00	0.0	0	0	0	0	1
09/01/2021 14:00	0.0	0	0	0	0	1
09/01/2021 15:00	0.0	0	0	0	0	1
09/01/2021 16:00	0.0	0	0	0	0	1
09/01/2021 17:00	0.0	0	0	0	0	1
09/01/2021 18:00	0.0	0	0	0	0	1
09/01/2021 19:00	0.0	0	0	0	0	1
09/01/2021 20:00	0.0	0	0	0	0	1
09/01/2021 21:00	0.0	0	0	0	0	1
09/01/2021 22:00	0.0	0	0	0	0	1
09/01/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/02/2021 00:00	0.0	0	0	0	0	1
09/02/2021 01:00	0.0	0	0	0	0	1
09/02/2021 02:00	0.0	0	0	0	0	1
09/02/2021 03:00	0.0	0	0	0	0	1
09/02/2021 04:00	0.0	0	0	0	0	1
09/02/2021 05:00	0.0	0	0	0	0	1
09/02/2021 06:00	0.0	0	0	0	0	1
09/02/2021 07:00	0.0	0	0	0	0	1
09/02/2021 08:00	0.0	0	0	0	0	1
09/02/2021 09:00	0.0	0	0	0	0	1
09/02/2021 10:00	0.0	0	0	0	0	1
09/02/2021 11:00	0.0	0	0	0	0	1
09/02/2021 12:00	0.0	0	0	0	0	1
09/02/2021 13:00	0.0	0	0	0	0	1
09/02/2021 14:00	0.0	0	0	0	0	1
09/02/2021 15:00	0.0	0	0	0	0	1
09/02/2021 16:00	0.0	0	0	0	0	1
09/02/2021 17:00	0.0	0	0	0	0	1
09/02/2021 18:00	0.0	0	0	0	0	1
09/02/2021 19:00	0.0	0	0	0	0	1
09/02/2021 20:00	0.0	0	0	0	0	1
09/02/2021 21:00	0.0	0	0	0	0	1
09/02/2021 22:00	0.0	0	0	0	0	1
09/02/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/03/2021 00:00	0.0	0	0	0	0	1
09/03/2021 01:00	0.0	0	0	0	0	1
09/03/2021 02:00	0.0	0	0	0	0	1
09/03/2021 03:00	0.0	0	0	0	0	1
09/03/2021 04:00	0.0	0	0	0	0	1
09/03/2021 05:00	0.0	0	0	0	0	1
09/03/2021 06:00	0.0	0	0	0	0	1
09/03/2021 07:00	0.0	0	0	0	0	1
09/03/2021 08:00	0.0	0	0	0	0	1
09/03/2021 09:00	0.0	0	0	0	0	1
09/03/2021 10:00	0.0	0	0	0	0	1
09/03/2021 11:00	0.0	0	0	0	0	1
09/03/2021 12:00	0.0	0	0	0	0	1
09/03/2021 13:00	0.0	0	0	0	0	1
09/03/2021 14:00	0.0	0	0	0	0	1
09/03/2021 15:00	0.0	0	0	0	0	1
09/03/2021 16:00	0.0	0	0	0	0	1
09/03/2021 17:00	0.0	0	0	0	0	1
09/03/2021 18:00	0.0	0	0	0	0	1
09/03/2021 19:00	0.0	0	0	0	0	1
09/03/2021 20:00	0.0	0	0	0	0	1
09/03/2021 21:00	0.0	0	0	0	0	1
09/03/2021 22:00	0.0	0	0	0	0	1
09/03/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/04/2021 00:00	0.0	0	0	0	0	1
09/04/2021 01:00	0.0	0	0	0	0	1
09/04/2021 02:00	0.0	0	0	0	0	1
09/04/2021 03:00	12.2	0	0	0	1	0
09/04/2021 04:00	0.0	0	0	0	0	0
09/04/2021 05:00	0.0	0	0	0	0	0
09/04/2021 06:00	0.0	0	0	0	0	0
09/04/2021 07:00	0.0	0	0	0	0	0
09/04/2021 08:00	0.0	0	0	0	0	0
09/04/2021 09:00	0.0	0	0	0	0	0
09/04/2021 10:00	0.0	0	0	0	0	0
09/04/2021 11:00	0.0	0	0	0	0	0
09/04/2021 12:00	0.0	0	0	0	0	0
09/04/2021 13:00	1,507.6	0	1	0	0	0
09/04/2021 14:00	4,320.7	0	1	0	0	0
09/04/2021 15:00	0.0	0	0	0	0	1
09/04/2021 16:00	0.0	0	0	0	0	1
09/04/2021 17:00	0.0	0	0	0	0	1
09/04/2021 18:00	0.0	0	0	0	0	1
09/04/2021 19:00	0.0	0	0	0	0	1
09/04/2021 20:00	0.0	0	0	0	0	1
09/04/2021 21:00	0.0	0	0	0	0	1
09/04/2021 22:00	0.0	0	0	0	0	1
09/04/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	5,840.5 #	0 #	2 #	0 #	1 #	12 #
Minimum:	0.0	0	0	0	0	0
Maximum:	4,320.7	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/05/2021 00:00	0.0	0	0	0	0	1
09/05/2021 01:00	0.0	0	0	0	0	1
09/05/2021 02:00	0.0	0	0	0	0	1
09/05/2021 03:00	0.0	0	0	0	0	1
09/05/2021 04:00	0.0	0	0	0	0	1
09/05/2021 05:00	0.0	0	0	0	0	1
09/05/2021 06:00	0.0	0	0	0	0	1
09/05/2021 07:00	0.0	0	0	0	0	1
09/05/2021 08:00	0.0	0	0	0	0	1
09/05/2021 09:00	0.0	0	0	0	0	1
09/05/2021 10:00	0.0	0	0	0	0	1
09/05/2021 11:00	0.0	0	0	0	0	1
09/05/2021 12:00	0.0	0	0	0	0	1
09/05/2021 13:00	0.0	0	0	0	0	1
09/05/2021 14:00	0.0	0	0	0	0	1
09/05/2021 15:00	0.0	0	0	0	0	1
09/05/2021 16:00	0.0	0	0	0	0	1
09/05/2021 17:00	0.0	0	0	0	0	1
09/05/2021 18:00	0.0	0	0	0	0	1
09/05/2021 19:00	0.0	0	0	0	0	1
09/05/2021 20:00	0.0	0	0	0	0	1
09/05/2021 21:00	0.0	0	0	0	0	1
09/05/2021 22:00	0.0	0	0	0	0	1
09/05/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/06/2021 00:00	0.0	0	0	0	0	1
09/06/2021 01:00	0.0	0	0	0	0	1
09/06/2021 02:00	0.0	0	0	0	0	1
09/06/2021 03:00	0.0	0	0	0	0	1
09/06/2021 04:00	0.0	0	0	0	0	1
09/06/2021 05:00	0.0	0	0	0	0	1
09/06/2021 06:00	0.0	0	0	0	0	1
09/06/2021 07:00	0.0	0	0	0	0	1
09/06/2021 08:00	0.0	0	0	0	0	1
09/06/2021 09:00	0.0	0	0	0	0	1
09/06/2021 10:00	0.0	0	0	0	0	1
09/06/2021 11:00	0.0	0	0	0	0	1
09/06/2021 12:00	0.0	0	0	0	0	1
09/06/2021 13:00	0.0	0	0	0	0	1
09/06/2021 14:00	0.0	0	0	0	0	1
09/06/2021 15:00	0.0	0	0	0	0	1
09/06/2021 16:00	0.0	0	0	0	0	1
09/06/2021 17:00	0.0	0	0	0	0	1
09/06/2021 18:00	0.0	0	0	0	0	1
09/06/2021 19:00	0.0	0	0	0	0	1
09/06/2021 20:00	0.0	0	0	0	0	1
09/06/2021 21:00	0.0	0	0	0	0	1
09/06/2021 22:00	0.0	0	0	0	0	1
09/06/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/07/2021 00:00	0.0	0	0	0	0	1
09/07/2021 01:00	0.0	0	0	0	0	1
09/07/2021 02:00	0.0	0	0	0	0	1
09/07/2021 03:00	0.0	0	0	0	0	1
09/07/2021 04:00	0.0	0	0	0	0	1
09/07/2021 05:00	0.0	0	0	0	0	1
09/07/2021 06:00	0.0	0	0	0	0	1
09/07/2021 07:00	0.0	0	0	0	0	1
09/07/2021 08:00	0.0	0	0	0	0	1
09/07/2021 09:00	0.0	0	0	0	0	1
09/07/2021 10:00	0.0	0	0	0	0	1
09/07/2021 11:00	0.0	0	0	0	0	1
09/07/2021 12:00	0.0	0	0	0	0	1
09/07/2021 13:00	0.0	0	0	0	0	1
09/07/2021 14:00	0.0	0	0	0	0	1
09/07/2021 15:00	0.0	0	0	0	0	1
09/07/2021 16:00	0.0	0	0	0	0	1
09/07/2021 17:00	0.0	0	0	0	0	1
09/07/2021 18:00	0.0	0	0	0	0	1
09/07/2021 19:00	0.0	0	0	0	0	1
09/07/2021 20:00	0.0	0	0	0	0	1
09/07/2021 21:00	0.0	0	0	0	0	1
09/07/2021 22:00	0.0	0	0	0	0	1
09/07/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/08/2021 00:00	0.0	0	0	0	0	1
09/08/2021 01:00	0.0	0	0	0	0	1
09/08/2021 02:00	0.0	0	0	0	0	1
09/08/2021 03:00	0.0	0	0	0	0	1
09/08/2021 04:00	0.0	0	0	0	0	1
09/08/2021 05:00	0.0	0	0	0	0	1
09/08/2021 06:00	0.0	0	0	0	0	1
09/08/2021 07:00	0.0	0	0	0	0	1
09/08/2021 08:00	0.0	0	0	0	0	1
09/08/2021 09:00	0.0	0	0	0	0	1
09/08/2021 10:00	0.0	0	0	0	0	1
09/08/2021 11:00	0.0	0	0	0	0	1
09/08/2021 12:00	0.0	0	0	0	0	1
09/08/2021 13:00	0.0	0	0	0	0	1
09/08/2021 14:00	0.0	0	0	0	0	1
09/08/2021 15:00	0.0	0	0	0	0	1
09/08/2021 16:00	0.0	0	0	0	0	1
09/08/2021 17:00	0.0	0	0	0	0	1
09/08/2021 18:00	0.0	0	0	0	0	1
09/08/2021 19:00	0.0	0	0	0	0	1
09/08/2021 20:00	0.0	0	0	0	0	1
09/08/2021 21:00	0.0	0	0	0	0	1
09/08/2021 22:00	0.0	0	0	0	0	1
09/08/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/09/2021 00:00	0.0	0	0	0	0	1
09/09/2021 01:00	0.0	0	0	0	0	1
09/09/2021 02:00	0.0	0	0	0	0	1
09/09/2021 03:00	0.0	0	0	0	0	1
09/09/2021 04:00	0.0	0	0	0	0	1
09/09/2021 05:00	0.0	0	0	0	0	1
09/09/2021 06:00	0.0	0	0	0	0	1
09/09/2021 07:00	0.0	0	0	0	0	1
09/09/2021 08:00	0.0	0	0	0	0	1
09/09/2021 09:00	0.0	0	0	0	0	1
09/09/2021 10:00	0.0	0	0	0	0	1
09/09/2021 11:00	0.0	0	0	0	0	1
09/09/2021 12:00	0.0	0	0	0	0	1
09/09/2021 13:00	0.0	0	0	0	0	1
09/09/2021 14:00	0.0	0	0	0	0	1
09/09/2021 15:00	0.0	0	0	0	0	1
09/09/2021 16:00	0.0	0	0	0	0	1
09/09/2021 17:00	0.0	0	0	0	0	1
09/09/2021 18:00	0.0	0	0	0	0	1
09/09/2021 19:00	0.0	0	0	0	0	1
09/09/2021 20:00	0.0	0	0	0	0	1
09/09/2021 21:00	0.0	0	0	0	0	1
09/09/2021 22:00	0.0	0	0	0	0	1
09/09/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/10/2021 00:00	0.0	0	0	0	0	1
09/10/2021 01:00	0.0	0	0	0	0	1
09/10/2021 02:00	0.0	0	0	0	0	1
09/10/2021 03:00	0.0	0	0	0	0	1
09/10/2021 04:00	0.0	0	0	0	0	1
09/10/2021 05:00	0.0	0	0	0	0	1
09/10/2021 06:00	0.0	0	0	0	0	1
09/10/2021 07:00	0.0	0	0	0	0	1
09/10/2021 08:00	0.0	0	0	0	0	1
09/10/2021 09:00	0.0	0	0	0	0	1
09/10/2021 10:00	0.0	0	0	0	0	1
09/10/2021 11:00	0.0	0	0	0	0	1
09/10/2021 12:00	0.0	0	0	0	0	1
09/10/2021 13:00	0.0	0	0	0	0	1
09/10/2021 14:00	0.0	0	0	0	0	1
09/10/2021 15:00	0.0	0	0	0	0	1
09/10/2021 16:00	0.0	0	0	0	0	1
09/10/2021 17:00	0.0	0	0	0	0	1
09/10/2021 18:00	0.0	0	0	0	0	1
09/10/2021 19:00	0.0	0	0	0	0	1
09/10/2021 20:00	0.0	0	0	0	0	1
09/10/2021 21:00	0.0	0	0	0	0	1
09/10/2021 22:00	0.0	0	0	0	0	1
09/10/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/11/2021 00:00	0.0	0	0	0	0	1
09/11/2021 01:00	0.0	0	0	0	0	1
09/11/2021 02:00	0.0	0	0	0	0	1
09/11/2021 03:00	0.0	0	0	0	0	1
09/11/2021 04:00	0.0	0	0	0	0	1
09/11/2021 05:00	0.0	0	0	0	0	1
09/11/2021 06:00	0.0	0	0	0	0	1
09/11/2021 07:00	0.0	0	0	0	0	1
09/11/2021 08:00	0.0	0	0	0	0	1
09/11/2021 09:00	0.0	0	0	0	0	1
09/11/2021 10:00	0.0	0	0	0	0	1
09/11/2021 11:00	0.0	0	0	0	0	1
09/11/2021 12:00	0.0	0	0	0	0	1
09/11/2021 13:00	0.0	0	0	0	0	1
09/11/2021 14:00	0.0	0	0	0	0	1
09/11/2021 15:00	0.0	0	0	0	0	1
09/11/2021 16:00	0.0	0	0	0	0	1
09/11/2021 17:00	0.0	0	0	0	0	1
09/11/2021 18:00	0.0	0	0	0	0	1
09/11/2021 19:00	0.0	0	0	0	0	1
09/11/2021 20:00	0.0	0	0	0	0	1
09/11/2021 21:00	0.0	0	0	0	0	1
09/11/2021 22:00	0.0	0	0	0	0	1
09/11/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/12/2021 00:00	0.0	0	0	0	0	1
09/12/2021 01:00	0.0	0	0	0	0	1
09/12/2021 02:00	0.0	0	0	0	0	1
09/12/2021 03:00	0.0	0	0	0	0	1
09/12/2021 04:00	0.0	0	0	0	0	1
09/12/2021 05:00	0.0	0	0	0	0	1
09/12/2021 06:00	0.0	0	0	0	0	1
09/12/2021 07:00	0.0	0	0	0	0	1
09/12/2021 08:00	0.0	0	0	0	0	1
09/12/2021 09:00	0.0	0	0	0	0	1
09/12/2021 10:00	0.0	0	0	0	0	1
09/12/2021 11:00	0.0	0	0	0	0	1
09/12/2021 12:00	0.0	0	0	0	0	1
09/12/2021 13:00	0.0	0	0	0	0	1
09/12/2021 14:00	0.0	0	0	0	0	1
09/12/2021 15:00	0.0	0	0	0	0	1
09/12/2021 16:00	0.0	0	0	0	0	1
09/12/2021 17:00	0.0	0	0	0	0	1
09/12/2021 18:00	0.0	0	0	0	0	1
09/12/2021 19:00	0.0	0	0	0	0	1
09/12/2021 20:00	0.0	0	0	0	0	1
09/12/2021 21:00	0.0	0	0	0	0	1
09/12/2021 22:00	0.0	0	0	0	0	1
09/12/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/13/2021 00:00	0.0	0	0	0	0	1
09/13/2021 01:00	0.0	0	0	0	0	1
09/13/2021 02:00	0.0	0	0	0	0	1
09/13/2021 03:00	0.0	0	0	0	0	1
09/13/2021 04:00	0.0	0	0	0	0	1
09/13/2021 05:00	0.0	0	0	0	0	1
09/13/2021 06:00	0.0	0	0	0	0	1
09/13/2021 07:00	0.0	0	0	0	0	1
09/13/2021 08:00	0.0	0	0	0	0	1
09/13/2021 09:00	0.0	0	0	0	0	1
09/13/2021 10:00	0.0	0	0	0	0	1
09/13/2021 11:00	0.0	0	0	0	0	1
09/13/2021 12:00	0.0	0	0	0	0	1
09/13/2021 13:00	0.0	0	0	0	0	1
09/13/2021 14:00	0.0	0	0	0	0	1
09/13/2021 15:00	0.0	0	0	0	0	1
09/13/2021 16:00	0.0	0	0	0	0	1
09/13/2021 17:00	0.0	0	0	0	0	1
09/13/2021 18:00	0.0	0	0	0	0	1
09/13/2021 19:00	0.0	0	0	0	0	1
09/13/2021 20:00	0.0	0	0	0	0	1
09/13/2021 21:00	0.0	0	0	0	0	1
09/13/2021 22:00	0.0	0	0	0	0	1
09/13/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/14/2021 00:00	0.0	0	0	0	0	1
09/14/2021 01:00	0.0	0	0	0	0	1
09/14/2021 02:00	0.0	0	0	0	0	1
09/14/2021 03:00	0.0	0	0	0	0	1
09/14/2021 04:00	0.0	0	0	0	0	1
09/14/2021 05:00	0.0	0	0	0	0	1
09/14/2021 06:00	0.0	0	0	0	0	1
09/14/2021 07:00	0.0	0	0	0	0	1
09/14/2021 08:00	0.0	0	0	0	0	1
09/14/2021 09:00	0.0	0	0	0	0	1
09/14/2021 10:00	0.0	0	0	0	0	1
09/14/2021 11:00	0.0	0	0	0	0	1
09/14/2021 12:00	0.0	0	0	0	0	1
09/14/2021 13:00	0.0	0	0	0	0	1
09/14/2021 14:00	0.0	0	0	0	0	1
09/14/2021 15:00	0.0	0	0	0	0	1
09/14/2021 16:00	0.0	0	0	0	0	1
09/14/2021 17:00	0.0	0	0	0	0	1
09/14/2021 18:00	0.0	0	0	0	0	1
09/14/2021 19:00	0.0	0	0	0	0	1
09/14/2021 20:00	0.0	0	0	0	0	1
09/14/2021 21:00	0.0	0	0	0	0	1
09/14/2021 22:00	0.0	0	0	0	0	1
09/14/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/15/2021 00:00	0.0	0	0	0	0	1
09/15/2021 01:00	0.0	0	0	0	0	1
09/15/2021 02:00	0.0	0	0	0	0	1
09/15/2021 03:00	0.0	0	0	0	0	1
09/15/2021 04:00	0.0	0	0	0	0	1
09/15/2021 05:00	0.0	0	0	0	0	1
09/15/2021 06:00	0.0	0	0	0	0	1
09/15/2021 07:00	0.0	0	0	0	0	1
09/15/2021 08:00	0.0	0	0	0	0	1
09/15/2021 09:00	0.0	0	0	0	0	1
09/15/2021 10:00	0.0	0	0	0	0	1
09/15/2021 11:00	0.0	0	0	0	0	1
09/15/2021 12:00	0.0	0	0	0	0	1
09/15/2021 13:00	0.0	0	0	0	0	1
09/15/2021 14:00	0.0	0	0	0	0	1
09/15/2021 15:00	0.0	0	0	0	0	1
09/15/2021 16:00	0.0	0	0	0	0	1
09/15/2021 17:00	0.0	0	0	0	0	1
09/15/2021 18:00	0.0	0	0	0	0	1
09/15/2021 19:00	0.0	0	0	0	0	1
09/15/2021 20:00	0.0	0	0	0	0	1
09/15/2021 21:00	0.0	0	0	0	0	1
09/15/2021 22:00	0.0	0	0	0	0	1
09/15/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/16/2021 00:00	0.0	0	0	0	0	1
09/16/2021 01:00	62.4	0	0	0	1	0
09/16/2021 02:00	0.0	0	0	0	0	0
09/16/2021 03:00	0.0	0	0	0	0	0
09/16/2021 04:00	0.0	0	0	0	0	0
09/16/2021 05:00	0.0	0	0	0	0	0
09/16/2021 06:00	0.0	0	0	0	0	0
09/16/2021 07:00	0.0	0	0	0	0	0
09/16/2021 08:00	0.0	0	0	0	0	0
09/16/2021 09:00	0.0	0	0	0	0	0
09/16/2021 10:00	0.0	0	0	0	0	0
09/16/2021 11:00	0.0	0	0	0	0	0
09/16/2021 12:00	317.0	0	1	0	0	0
09/16/2021 13:00	5,972.1	0	1	0	0	0
09/16/2021 14:00	0.0	0	0	0	0	1
09/16/2021 15:00	0.0	0	0	0	0	1
09/16/2021 16:00	0.0	0	0	0	0	1
09/16/2021 17:00	0.0	0	0	0	0	1
09/16/2021 18:00	0.0	0	0	0	0	1
09/16/2021 19:00	0.0	0	0	0	0	1
09/16/2021 20:00	0.0	0	0	0	0	1
09/16/2021 21:00	0.0	0	0	0	0	1
09/16/2021 22:00	0.0	0	0	0	0	1
09/16/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	6,351.5 #	0 #	2 #	0 #	1 #	11 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,972.1	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/17/2021 00:00	0.0	0	0	0	0	1
09/17/2021 01:00	0.0	0	0	0	0	1
09/17/2021 02:00	35.1	0	0	0	1	0
09/17/2021 03:00	0.0	0	0	0	0	0
09/17/2021 04:00	0.0	0	0	0	0	0
09/17/2021 05:00	0.0	0	0	0	0	0
09/17/2021 06:00	0.0	0	0	0	0	0
09/17/2021 07:00	0.0	0	0	0	0	0
09/17/2021 08:00	0.0	0	0	0	0	0
09/17/2021 09:00	0.0	0	0	0	0	0
09/17/2021 10:00	0.0	0	0	0	0	0
09/17/2021 11:00	0.0	0	0	0	0	0
09/17/2021 12:00	0.0	0	0	0	0	0
09/17/2021 13:00	1,143.0	0	1	0	0	0
09/17/2021 14:00	5,647.3	0	1	0	0	0
09/17/2021 15:00	0.0	0	0	0	0	1
09/17/2021 16:00	0.0	0	0	0	0	1
09/17/2021 17:00	0.0	0	0	0	0	1
09/17/2021 18:00	0.0	0	0	0	0	1
09/17/2021 19:00	0.0	0	0	0	0	1
09/17/2021 20:00	0.0	0	0	0	0	1
09/17/2021 21:00	0.0	0	0	0	0	1
09/17/2021 22:00	0.0	0	0	0	0	1
09/17/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	6,825.4 #	0 #	2 #	0 #	1 #	11 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,647.3	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/18/2021 00:00	23.0	0	0	0	1	0
09/18/2021 01:00	0.0	0	0	0	0	0
09/18/2021 02:00	0.0	0	0	0	0	0
09/18/2021 03:00	0.0	0	0	0	0	0
09/18/2021 04:00	0.0	0	0	0	0	0
09/18/2021 05:00	0.0	0	0	0	0	0
09/18/2021 06:00	0.0	0	0	0	0	0
09/18/2021 07:00	0.0	0	0	0	0	0
09/18/2021 08:00	0.0	0	0	0	0	0
09/18/2021 09:00	0.0	0	0	0	0	0
09/18/2021 10:00	0.0	0	0	0	0	0
09/18/2021 11:00	0.0	0	0	0	0	0
09/18/2021 12:00	0.0	0	0	0	0	0
09/18/2021 13:00	0.0	0	0	0	0	0
09/18/2021 14:00	0.0	0	0	0	0	0
09/18/2021 15:00	0.0	0	0	0	0	0
09/18/2021 16:00	0.0	0	0	0	0	0
09/18/2021 17:00	0.0	0	0	0	0	0
09/18/2021 18:00	0.0	0	0	0	0	0
09/18/2021 19:00	0.0	0	0	0	0	0
09/18/2021 20:00	0.0	0	0	0	0	0
09/18/2021 21:00	0.0	0	0	0	0	0
09/18/2021 22:00	0.0	0	0	0	0	0
09/18/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	23.0 #	0 #	0 #	0 #	1 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	23.0	0	0	0	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/19/2021 00:00	0.0	0	0	0	0	0
09/19/2021 01:00	0.0	0	0	0	0	0
09/19/2021 02:00	0.0	0	0	0	0	0
09/19/2021 03:00	0.0	0	0	0	0	0
09/19/2021 04:00	0.0	0	0	0	0	0
09/19/2021 05:00	0.0	0	0	0	0	0
09/19/2021 06:00	0.0	0	0	0	0	0
09/19/2021 07:00	0.0	0	0	0	0	0
09/19/2021 08:00	0.0	0	0	0	0	0
09/19/2021 09:00	0.0	0	0	0	0	0
09/19/2021 10:00	0.0	0	0	0	0	0
09/19/2021 11:00	0.0	0	0	0	0	0
09/19/2021 12:00	0.0	0	0	0	0	0
09/19/2021 13:00	0.0	0	0	0	0	0
09/19/2021 14:00	0.0	0	0	0	0	0
09/19/2021 15:00	0.0	0	0	0	0	0
09/19/2021 16:00	0.0	0	0	0	0	0
09/19/2021 17:00	0.0	0	0	0	0	0
09/19/2021 18:00	0.0	0	0	0	0	0
09/19/2021 19:00	0.0	0	0	0	0	0
09/19/2021 20:00	0.0	0	0	0	0	0
09/19/2021 21:00	0.0	0	0	0	0	0
09/19/2021 22:00	0.0	0	0	0	0	0
09/19/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/20/2021 00:00	0.0	0	0	0	0	0
09/20/2021 01:00	718.7	0	1	0	0	0
09/20/2021 02:00	4,684.2	0	1	0	0	0
09/20/2021 03:00	1,827.8	0	1	0	0	0
09/20/2021 04:00	0.0	0	0	0	0	1
09/20/2021 05:00	0.0	0	0	0	0	1
09/20/2021 06:00	0.0	0	0	0	0	1
09/20/2021 07:00	0.0	0	0	0	0	1
09/20/2021 08:00	0.0	0	0	0	0	1
09/20/2021 09:00	0.0	0	0	0	0	1
09/20/2021 10:00	0.0	0	0	0	0	1
09/20/2021 11:00	0.0	0	0	0	0	1
09/20/2021 12:00	0.0	0	0	0	0	1
09/20/2021 13:00	0.0	0	0	0	0	1
09/20/2021 14:00	0.0	0	0	0	0	1
09/20/2021 15:00	0.0	0	0	0	0	1
09/20/2021 16:00	0.0	0	0	0	0	1
09/20/2021 17:00	0.0	0	0	0	0	1
09/20/2021 18:00	0.0	0	0	0	0	1
09/20/2021 19:00	0.0	0	0	0	0	1
09/20/2021 20:00	0.0	0	0	0	0	1
09/20/2021 21:00	0.0	0	0	0	0	1
09/20/2021 22:00	0.0	0	0	0	0	1
09/20/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	7,230.7 #	0 #	3 #	0 #	0 #	20 #
Minimum:	0.0	0	0	0	0	0
Maximum:	4,684.2	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/21/2021 00:00	0.0	0	0	0	0	1
09/21/2021 01:00	0.0	0	0	0	0	1
09/21/2021 02:00	0.0	0	0	0	0	1
09/21/2021 03:00	0.0	0	0	0	0	1
09/21/2021 04:00	0.0	0	0	0	0	1
09/21/2021 05:00	0.0	0	0	0	0	1
09/21/2021 06:00	0.0	0	0	0	0	1
09/21/2021 07:00	0.0	0	0	0	0	1
09/21/2021 08:00	0.0	0	0	0	0	1
09/21/2021 09:00	0.0	0	0	0	0	1
09/21/2021 10:00	0.0	0	0	0	0	1
09/21/2021 11:00	0.0	0	0	0	0	1
09/21/2021 12:00	0.0	0	0	0	0	1
09/21/2021 13:00	0.0	0	0	0	0	1
09/21/2021 14:00	0.0	0	0	0	0	1
09/21/2021 15:00	0.0	0	0	0	0	1
09/21/2021 16:00	0.0	0	0	0	0	1
09/21/2021 17:00	0.0	0	0	0	0	1
09/21/2021 18:00	0.0	0	0	0	0	1
09/21/2021 19:00	0.0	0	0	0	0	1
09/21/2021 20:00	0.0	0	0	0	0	1
09/21/2021 21:00	0.0	0	0	0	0	1
09/21/2021 22:00	0.0	0	0	0	0	1
09/21/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/22/2021 00:00	0.0	0	0	0	0	1
09/22/2021 01:00	0.0	0	0	0	0	1
09/22/2021 02:00	0.0	0	0	0	0	1
09/22/2021 03:00	0.0	0	0	0	0	1
09/22/2021 04:00	0.0	0	0	0	0	1
09/22/2021 05:00	0.0	0	0	0	0	1
09/22/2021 06:00	0.0	0	0	0	0	1
09/22/2021 07:00	0.0	0	0	0	0	1
09/22/2021 08:00	0.0	0	0	0	0	1
09/22/2021 09:00	0.0	0	0	0	0	1
09/22/2021 10:00	0.0	0	0	0	0	1
09/22/2021 11:00	0.0	0	0	0	0	1
09/22/2021 12:00	0.0	0	0	0	0	1
09/22/2021 13:00	0.0	0	0	0	0	1
09/22/2021 14:00	0.0	0	0	0	0	1
09/22/2021 15:00	0.0	0	0	0	0	1
09/22/2021 16:00	0.0	0	0	0	0	1
09/22/2021 17:00	0.0	0	0	0	0	1
09/22/2021 18:00	0.0	0	0	0	0	1
09/22/2021 19:00	0.0	0	0	0	0	1
09/22/2021 20:00	0.0	0	0	0	0	1
09/22/2021 21:00	0.0	0	0	0	0	1
09/22/2021 22:00	0.0	0	0	0	0	1
09/22/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/23/2021 00:00	0.0	0	0	0	0	1
09/23/2021 01:00	0.0	0	0	0	0	1
09/23/2021 02:00	0.0	0	0	0	0	1
09/23/2021 03:00	0.0	0	0	0	0	1
09/23/2021 04:00	0.0	0	0	0	0	1
09/23/2021 05:00	0.0	0	0	0	0	1
09/23/2021 06:00	0.0	0	0	0	0	1
09/23/2021 07:00	0.0	0	0	0	0	1
09/23/2021 08:00	0.0	0	0	0	0	1
09/23/2021 09:00	0.0	0	0	0	0	1
09/23/2021 10:00	0.0	0	0	0	0	1
09/23/2021 11:00	0.0	0	0	0	0	1
09/23/2021 12:00	0.0	0	0	0	0	1
09/23/2021 13:00	0.0	0	0	0	0	1
09/23/2021 14:00	0.0	0	0	0	0	1
09/23/2021 15:00	0.0	0	0	0	0	1
09/23/2021 16:00	0.0	0	0	0	0	1
09/23/2021 17:00	0.0	0	0	0	0	1
09/23/2021 18:00	0.0	0	0	0	0	1
09/23/2021 19:00	0.0	0	0	0	0	1
09/23/2021 20:00	0.0	0	0	0	0	1
09/23/2021 21:00	0.0	0	0	0	0	1
09/23/2021 22:00	0.0	0	0	0	0	1
09/23/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/24/2021 00:00	0.0	0	0	0	0	1
09/24/2021 01:00	0.0	0	0	0	0	1
09/24/2021 02:00	0.0	0	0	0	0	1
09/24/2021 03:00	0.0	0	0	0	0	1
09/24/2021 04:00	0.0	0	0	0	0	1
09/24/2021 05:00	0.0	0	0	0	0	1
09/24/2021 06:00	0.0	0	0	0	0	1
09/24/2021 07:00	0.0	0	0	0	0	1
09/24/2021 08:00	0.0	0	0	0	0	1
09/24/2021 09:00	0.0	0	0	0	0	1
09/24/2021 10:00	0.0	0	0	0	0	1
09/24/2021 11:00	0.0	0	0	0	0	1
09/24/2021 12:00	0.0	0	0	0	0	1
09/24/2021 13:00	0.0	0	0	0	0	1
09/24/2021 14:00	0.0	0	0	0	0	1
09/24/2021 15:00	0.0	0	0	0	0	1
09/24/2021 16:00	0.0	0	0	0	0	1
09/24/2021 17:00	0.0	0	0	0	0	1
09/24/2021 18:00	0.0	0	0	0	0	1
09/24/2021 19:00	0.0	0	0	0	0	1
09/24/2021 20:00	0.0	0	0	0	0	1
09/24/2021 21:00	0.0	0	0	0	0	1
09/24/2021 22:00	0.0	0	0	0	0	1
09/24/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/25/2021 00:00	0.0	0	0	0	0	1
09/25/2021 01:00	0.0	0	0	0	0	1
09/25/2021 02:00	0.0	0	0	0	0	1
09/25/2021 03:00	0.0	0	0	0	0	1
09/25/2021 04:00	0.0	0	0	0	0	1
09/25/2021 05:00	0.0	0	0	0	0	1
09/25/2021 06:00	0.0	0	0	0	0	1
09/25/2021 07:00	0.0	0	0	0	0	1
09/25/2021 08:00	0.0	0	0	0	0	1
09/25/2021 09:00	0.0	0	0	0	0	1
09/25/2021 10:00	0.0	0	0	0	0	1
09/25/2021 11:00	0.0	0	0	0	0	1
09/25/2021 12:00	0.0	0	0	0	0	1
09/25/2021 13:00	0.0	0	0	0	0	1
09/25/2021 14:00	0.0	0	0	0	0	1
09/25/2021 15:00	0.0	0	0	0	0	1
09/25/2021 16:00	0.0	0	0	0	0	1
09/25/2021 17:00	0.0	0	0	0	0	1
09/25/2021 18:00	0.0	0	0	0	0	1
09/25/2021 19:00	0.0	0	0	0	0	1
09/25/2021 20:00	0.0	0	0	0	0	1
09/25/2021 21:00	0.0	0	0	0	0	1
09/25/2021 22:00	0.0	0	0	0	0	1
09/25/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/26/2021 00:00	0.0	0	0	0	0	1
09/26/2021 01:00	0.0	0	0	0	0	1
09/26/2021 02:00	0.0	0	0	0	0	1
09/26/2021 03:00	0.0	0	0	0	0	1
09/26/2021 04:00	0.0	0	0	0	0	1
09/26/2021 05:00	0.0	0	0	0	0	1
09/26/2021 06:00	0.0	0	0	0	0	1
09/26/2021 07:00	0.0	0	0	0	0	1
09/26/2021 08:00	0.0	0	0	0	0	1
09/26/2021 09:00	0.0	0	0	0	0	1
09/26/2021 10:00	0.0	0	0	0	0	1
09/26/2021 11:00	0.0	0	0	0	0	1
09/26/2021 12:00	0.0	0	0	0	0	1
09/26/2021 13:00	0.0	0	0	0	0	1
09/26/2021 14:00	0.0	0	0	0	0	1
09/26/2021 15:00	0.0	0	0	0	0	1
09/26/2021 16:00	0.0	0	0	0	0	1
09/26/2021 17:00	0.0	0	0	0	0	1
09/26/2021 18:00	0.0	0	0	0	0	1
09/26/2021 19:00	0.0	0	0	0	0	1
09/26/2021 20:00	0.0	0	0	0	0	1
09/26/2021 21:00	0.0	0	0	0	0	1
09/26/2021 22:00	0.0	0	0	0	0	1
09/26/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/27/2021 00:00	0.0	0	0	0	0	1
09/27/2021 01:00	0.0	0	0	0	0	1
09/27/2021 02:00	0.0	0	0	0	0	1
09/27/2021 03:00	0.0	0	0	0	0	1
09/27/2021 04:00	0.0	0	0	0	0	1
09/27/2021 05:00	0.0	0	0	0	0	1
09/27/2021 06:00	0.0	0	0	0	0	1
09/27/2021 07:00	0.0	0	0	0	0	1
09/27/2021 08:00	0.0	0	0	0	0	1
09/27/2021 09:00	0.0	0	0	0	0	1
09/27/2021 10:00	0.0	0	0	0	0	1
09/27/2021 11:00	0.0	0	0	0	0	1
09/27/2021 12:00	0.0	0	0	0	0	1
09/27/2021 13:00	0.0	0	0	0	0	1
09/27/2021 14:00	0.0	0	0	0	0	1
09/27/2021 15:00	0.0	0	0	0	0	1
09/27/2021 16:00	0.0	0	0	0	0	1
09/27/2021 17:00	0.0	0	0	0	0	1
09/27/2021 18:00	0.0	0	0	0	0	1
09/27/2021 19:00	0.0	0	0	0	0	1
09/27/2021 20:00	0.0	0	0	0	0	1
09/27/2021 21:00	0.0	0	0	0	0	1
09/27/2021 22:00	0.0	0	0	0	0	1
09/27/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/28/2021 00:00	0.0	0	0	0	0	1
09/28/2021 01:00	0.0	0	0	0	0	1
09/28/2021 02:00	0.0	0	0	0	0	1
09/28/2021 03:00	0.0	0	0	0	0	1
09/28/2021 04:00	0.0	0	0	0	0	1
09/28/2021 05:00	0.0	0	0	0	0	1
09/28/2021 06:00	0.0	0	0	0	0	1
09/28/2021 07:00	0.0	0	0	0	0	1
09/28/2021 08:00	0.0	0	0	0	0	1
09/28/2021 09:00	0.0	0	0	0	0	1
09/28/2021 10:00	0.0	0	0	0	0	1
09/28/2021 11:00	0.0	0	0	0	0	1
09/28/2021 12:00	0.0	0	0	0	0	1
09/28/2021 13:00	0.0	0	0	0	0	1
09/28/2021 14:00	0.0	0	0	0	0	1
09/28/2021 15:00	0.0	0	0	0	0	1
09/28/2021 16:00	0.0	0	0	0	0	1
09/28/2021 17:00	0.0	0	0	0	0	1
09/28/2021 18:00	0.0	0	0	0	0	1
09/28/2021 19:00	0.0	0	0	0	0	1
09/28/2021 20:00	0.0	0	0	0	0	1
09/28/2021 21:00	0.0	0	0	0	0	1
09/28/2021 22:00	0.0	0	0	0	0	1
09/28/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/29/2021 00:00	0.0	0	0	0	0	1
09/29/2021 01:00	0.0	0	0	0	0	1
09/29/2021 02:00	0.0	0	0	0	0	1
09/29/2021 03:00	0.0	0	0	0	0	1
09/29/2021 04:00	0.0	0	0	0	0	1
09/29/2021 05:00	0.0	0	0	0	0	1
09/29/2021 06:00	0.0	0	0	0	0	1
09/29/2021 07:00	0.0	0	0	0	0	1
09/29/2021 08:00	0.0	0	0	0	0	1
09/29/2021 09:00	0.0	0	0	0	0	1
09/29/2021 10:00	0.0	0	0	0	0	1
09/29/2021 11:00	0.0	0	0	0	0	1
09/29/2021 12:00	0.0	0	0	0	0	1
09/29/2021 13:00	0.0	0	0	0	0	1
09/29/2021 14:00	0.0	0	0	0	0	1
09/29/2021 15:00	0.0	0	0	0	0	1
09/29/2021 16:00	0.0	0	0	0	0	1
09/29/2021 17:00	0.0	0	0	0	0	1
09/29/2021 18:00	0.0	0	0	0	0	1
09/29/2021 19:00	0.0	0	0	0	0	1
09/29/2021 20:00	0.0	0	0	0	0	1
09/29/2021 21:00	0.0	0	0	0	0	1
09/29/2021 22:00	0.0	0	0	0	0	1
09/29/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:10 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/30/2021 00:00	0.0	0	0	0	0	1
09/30/2021 01:00	0.0	0	0	0	0	1
09/30/2021 02:00	0.0	0	0	0	0	1
09/30/2021 03:00	0.0	0	0	0	0	1
09/30/2021 04:00	0.0	0	0	0	0	1
09/30/2021 05:00	0.0	0	0	0	0	1
09/30/2021 06:00	23.3	0	0	0	1	0
09/30/2021 07:00	0.0	0	0	0	0	0
09/30/2021 08:00	0.0	0	0	0	0	0
09/30/2021 09:00	0.0	0	0	0	0	0
09/30/2021 10:00	0.0	0	0	0	0	0
09/30/2021 11:00	0.0	0	0	0	0	0
09/30/2021 12:00	0.0	0	0	0	0	0
09/30/2021 13:00	0.0	0	0	0	0	0
09/30/2021 14:00	0.0	0	0	0	0	0
09/30/2021 15:00	0.0	0	0	0	0	0
09/30/2021 16:00	0.0	0	0	0	0	0
09/30/2021 17:00	0.0	0	0	0	0	0
09/30/2021 18:00	0.0	0	0	0	0	0
09/30/2021 19:00	0.0	0	0	0	0	0
09/30/2021 20:00	0.0	0	0	0	0	0
09/30/2021 21:00	0.0	0	0	0	0	0
09/30/2021 22:00	0.0	0	0	0	0	0
09/30/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	23.3 #	0 #	0 #	0 #	1 #	6 #
Minimum:	0.0	0	0	0	0	0
Maximum:	23.3	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/01/2021 00:00	0.0	0	0	0	0	0
07/01/2021 01:00	0.0	0	0	0	0	0
07/01/2021 02:00	0.0	0	0	0	0	0
07/01/2021 03:00	0.0	0	0	0	0	0
07/01/2021 04:00	0.0	0	0	0	0	0
07/01/2021 05:00	0.0	0	0	0	0	0
07/01/2021 06:00	0.0	0	0	0	0	0
07/01/2021 07:00	0.0	0	0	0	0	0
07/01/2021 08:00	0.0	0	0	0	0	0
07/01/2021 09:00	0.0	0	0	0	0	0
07/01/2021 10:00	0.0	0	0	0	0	0
07/01/2021 11:00	0.0	0	0	0	0	0
07/01/2021 12:00	0.0	0	0	0	0	0
07/01/2021 13:00	0.0	0	0	0	0	0
07/01/2021 14:00	0.0	0	0	0	0	0
07/01/2021 15:00	0.0	0	0	0	0	0
07/01/2021 16:00	0.0	0	0	0	0	0
07/01/2021 17:00	0.0	0	0	0	0	0
07/01/2021 18:00	0.0	0	0	0	0	0
07/01/2021 19:00	0.0	0	0	0	0	0
07/01/2021 20:00	0.0	0	0	0	0	0
07/01/2021 21:00	0.0	0	0	0	0	0
07/01/2021 22:00	0.0	0	0	0	0	0
07/01/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/02/2021 00:00	0.0	0	0	0	0	0
07/02/2021 01:00	0.0	0	0	0	0	0
07/02/2021 02:00	0.0	0	0	0	0	0
07/02/2021 03:00	0.0	0	0	0	0	0
07/02/2021 04:00	0.0	0	0	0	0	0
07/02/2021 05:00	0.0	0	0	0	0	0
07/02/2021 06:00	0.0	0	0	0	0	0
07/02/2021 07:00	0.0	0	0	0	0	0
07/02/2021 08:00	0.0	0	0	0	0	0
07/02/2021 09:00	0.0	0	0	0	0	0
07/02/2021 10:00	0.0	0	0	0	0	0
07/02/2021 11:00	0.0	0	0	0	0	0
07/02/2021 12:00	0.0	0	0	0	0	0
07/02/2021 13:00	0.0	0	0	0	0	0
07/02/2021 14:00	0.0	0	0	0	0	0
07/02/2021 15:00	0.0	0	0	0	0	0
07/02/2021 16:00	0.0	0	0	0	0	0
07/02/2021 17:00	0.0	0	0	0	0	0
07/02/2021 18:00	0.0	0	0	0	0	0
07/02/2021 19:00	0.0	0	0	0	0	0
07/02/2021 20:00	0.0	0	0	0	0	0
07/02/2021 21:00	0.0	0	0	0	0	0
07/02/2021 22:00	0.0	0	0	0	0	0
07/02/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/03/2021 00:00	0.0	0	0	0	0	0
07/03/2021 01:00	0.0	0	0	0	0	0
07/03/2021 02:00	0.0	0	0	0	0	0
07/03/2021 03:00	0.0	0	0	0	0	0
07/03/2021 04:00	0.0	0	0	0	0	0
07/03/2021 05:00	0.0	0	0	0	0	0
07/03/2021 06:00	0.0	0	0	0	0	0
07/03/2021 07:00	0.0	0	0	0	0	0
07/03/2021 08:00	0.0	0	0	0	0	0
07/03/2021 09:00	0.0	0	0	0	0	0
07/03/2021 10:00	0.0	0	0	0	0	0
07/03/2021 11:00	0.0	0	0	0	0	0
07/03/2021 12:00	0.0	0	0	0	0	0
07/03/2021 13:00	0.0	0	0	0	0	0
07/03/2021 14:00	0.0	0	0	0	0	0
07/03/2021 15:00	0.0	0	0	0	0	0
07/03/2021 16:00	0.0	0	0	0	0	0
07/03/2021 17:00	0.0	0	0	0	0	0
07/03/2021 18:00	0.0	0	0	0	0	0
07/03/2021 19:00	0.0	0	0	0	0	0
07/03/2021 20:00	0.0	0	0	0	0	0
07/03/2021 21:00	0.0	0	0	0	0	0
07/03/2021 22:00	0.0	0	0	0	0	0
07/03/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/04/2021 00:00	0.0	0	0	0	0	0
07/04/2021 01:00	0.0	0	0	0	0	0
07/04/2021 02:00	0.0	0	0	0	0	0
07/04/2021 03:00	0.0	0	0	0	0	0
07/04/2021 04:00	0.0	0	0	0	0	0
07/04/2021 05:00	0.0	0	0	0	0	0
07/04/2021 06:00	0.0	0	0	0	0	0
07/04/2021 07:00	0.0	0	0	0	0	0
07/04/2021 08:00	0.0	0	0	0	0	0
07/04/2021 09:00	0.0	0	0	0	0	0
07/04/2021 10:00	0.0	0	0	0	0	0
07/04/2021 11:00	0.0	0	0	0	0	0
07/04/2021 12:00	0.0	0	0	0	0	0
07/04/2021 13:00	0.0	0	0	0	0	0
07/04/2021 14:00	0.0	0	0	0	0	0
07/04/2021 15:00	0.0	0	0	0	0	0
07/04/2021 16:00	0.0	0	0	0	0	0
07/04/2021 17:00	0.0	0	0	0	0	0
07/04/2021 18:00	0.0	0	0	0	0	0
07/04/2021 19:00	0.0	0	0	0	0	0
07/04/2021 20:00	0.0	0	0	0	0	0
07/04/2021 21:00	0.0	0	0	0	0	0
07/04/2021 22:00	0.0	0	0	0	0	0
07/04/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/05/2021 00:00	0.0	0	0	0	0	0
07/05/2021 01:00	0.0	0	0	0	0	0
07/05/2021 02:00	0.0	0	0	0	0	0
07/05/2021 03:00	0.0	0	0	0	0	0
07/05/2021 04:00	0.0	0	0	0	0	0
07/05/2021 05:00	0.0	0	0	0	0	0
07/05/2021 06:00	0.0	0	0	0	0	0
07/05/2021 07:00	0.0	0	0	0	0	0
07/05/2021 08:00	0.0	0	0	0	0	0
07/05/2021 09:00	0.0	0	0	0	0	0
07/05/2021 10:00	0.0	0	0	0	0	0
07/05/2021 11:00	0.0	0	0	0	0	0
07/05/2021 12:00	0.0	0	0	0	0	0
07/05/2021 13:00	0.0	0	0	0	0	0
07/05/2021 14:00	0.0	0	0	0	0	0
07/05/2021 15:00	0.0	0	0	0	0	0
07/05/2021 16:00	0.0	0	0	0	0	0
07/05/2021 17:00	0.0	0	0	0	0	0
07/05/2021 18:00	0.0	0	0	0	0	0
07/05/2021 19:00	0.0	0	0	0	0	0
07/05/2021 20:00	0.0	0	0	0	0	0
07/05/2021 21:00	0.0	0	0	0	0	0
07/05/2021 22:00	0.0	0	0	0	0	0
07/05/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/06/2021 00:00	0.0	0	0	0	0	0
07/06/2021 01:00	0.0	0	0	0	0	0
07/06/2021 02:00	0.0	0	0	0	0	0
07/06/2021 03:00	0.0	0	0	0	0	0
07/06/2021 04:00	0.0	0	0	0	0	0
07/06/2021 05:00	0.0	0	0	0	0	0
07/06/2021 06:00	0.0	0	0	0	0	0
07/06/2021 07:00	0.0	0	0	0	0	0
07/06/2021 08:00	0.0	0	0	0	0	0
07/06/2021 09:00	0.0	0	0	0	0	0
07/06/2021 10:00	0.0	0	0	0	0	0
07/06/2021 11:00	0.0	0	0	0	0	0
07/06/2021 12:00	0.0	0	0	0	0	0
07/06/2021 13:00	0.0	0	0	0	0	0
07/06/2021 14:00	0.0	0	0	0	0	0
07/06/2021 15:00	0.0	0	0	0	0	0
07/06/2021 16:00	0.0	0	0	0	0	0
07/06/2021 17:00	0.0	0	0	0	0	0
07/06/2021 18:00	0.0	0	0	0	0	0
07/06/2021 19:00	0.0	0	0	0	0	0
07/06/2021 20:00	0.0	0	0	0	0	0
07/06/2021 21:00	0.0	0	0	0	0	0
07/06/2021 22:00	0.0	0	0	0	0	0
07/06/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/07/2021 00:00	0.0	0	0	0	0	0
07/07/2021 01:00	0.0	0	0	0	0	0
07/07/2021 02:00	0.0	0	0	0	0	0
07/07/2021 03:00	0.0	0	0	0	0	0
07/07/2021 04:00	0.0	0	0	0	0	0
07/07/2021 05:00	0.0	0	0	0	0	0
07/07/2021 06:00	0.0	0	0	0	0	0
07/07/2021 07:00	0.0	0	0	0	0	0
07/07/2021 08:00	0.0	0	0	0	0	0
07/07/2021 09:00	0.0	0	0	0	0	0
07/07/2021 10:00	0.0	0	0	0	0	0
07/07/2021 11:00	0.0	0	0	0	0	0
07/07/2021 12:00	0.0	0	0	0	0	0
07/07/2021 13:00	0.0	0	0	0	0	0
07/07/2021 14:00	0.0	0	0	0	0	0
07/07/2021 15:00	0.0	0	0	0	0	0
07/07/2021 16:00	0.0	0	0	0	0	0
07/07/2021 17:00	0.0	0	0	0	0	0
07/07/2021 18:00	0.0	0	0	0	0	0
07/07/2021 19:00	0.0	0	0	0	0	0
07/07/2021 20:00	0.0	0	0	0	0	0
07/07/2021 21:00	0.0	0	0	0	0	0
07/07/2021 22:00	0.0	0	0	0	0	0
07/07/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/08/2021 00:00	0.0	0	0	0	0	0
07/08/2021 01:00	0.0	0	0	0	0	0
07/08/2021 02:00	0.0	0	0	0	0	0
07/08/2021 03:00	0.0	0	0	0	0	0
07/08/2021 04:00	0.0	0	0	0	0	0
07/08/2021 05:00	0.0	0	0	0	0	0
07/08/2021 06:00	0.0	0	0	0	0	0
07/08/2021 07:00	0.0	0	0	0	0	0
07/08/2021 08:00	0.0	0	0	0	0	0
07/08/2021 09:00	0.0	0	0	0	0	0
07/08/2021 10:00	0.0	0	0	0	0	0
07/08/2021 11:00	0.0	0	0	0	0	0
07/08/2021 12:00	0.0	0	0	0	0	0
07/08/2021 13:00	0.0	0	0	0	0	0
07/08/2021 14:00	0.0	0	0	0	0	0
07/08/2021 15:00	0.0	0	0	0	0	0
07/08/2021 16:00	0.0	0	0	0	0	0
07/08/2021 17:00	0.0	0	0	0	0	0
07/08/2021 18:00	0.0	0	0	0	0	0
07/08/2021 19:00	0.0	0	0	0	0	0
07/08/2021 20:00	0.0	0	0	0	0	0
07/08/2021 21:00	0.0	0	0	0	0	0
07/08/2021 22:00	0.0	0	0	0	0	0
07/08/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/09/2021 00:00	0.0	0	0	0	0	0
07/09/2021 01:00	0.0	0	0	0	0	0
07/09/2021 02:00	0.0	0	0	0	0	0
07/09/2021 03:00	0.0	0	0	0	0	0
07/09/2021 04:00	0.0	0	0	0	0	0
07/09/2021 05:00	0.0	0	0	0	0	0
07/09/2021 06:00	0.0	0	0	0	0	0
07/09/2021 07:00	0.0	0	0	0	0	0
07/09/2021 08:00	0.0	0	0	0	0	0
07/09/2021 09:00	0.0	0	0	0	0	0
07/09/2021 10:00	0.0	0	0	0	0	0
07/09/2021 11:00	0.0	0	0	0	0	0
07/09/2021 12:00	0.0	0	0	0	0	0
07/09/2021 13:00	0.0	0	0	0	0	0
07/09/2021 14:00	0.0	0	0	0	0	0
07/09/2021 15:00	0.0	0	0	0	0	0
07/09/2021 16:00	0.0	0	0	0	0	0
07/09/2021 17:00	0.0	0	0	0	0	0
07/09/2021 18:00	0.0	0	0	0	0	0
07/09/2021 19:00	0.0	0	0	0	0	0
07/09/2021 20:00	0.0	0	0	0	0	0
07/09/2021 21:00	0.0	0	0	0	0	0
07/09/2021 22:00	0.0	0	0	0	0	0
07/09/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/10/2021 00:00	0.0	0	0	0	0	0
07/10/2021 01:00	0.0	0	0	0	0	0
07/10/2021 02:00	0.0	0	0	0	0	0
07/10/2021 03:00	0.0	0	0	0	0	0
07/10/2021 04:00	0.0	0	0	0	0	0
07/10/2021 05:00	0.0	0	0	0	0	0
07/10/2021 06:00	0.0	0	0	0	0	0
07/10/2021 07:00	0.0	0	0	0	0	0
07/10/2021 08:00	0.0	0	0	0	0	0
07/10/2021 09:00	0.0	0	0	0	0	0
07/10/2021 10:00	0.0	0	0	0	0	0
07/10/2021 11:00	0.0	0	0	0	0	0
07/10/2021 12:00	0.0	0	0	0	0	0
07/10/2021 13:00	0.0	0	0	0	0	0
07/10/2021 14:00	0.0	0	0	0	0	0
07/10/2021 15:00	0.0	0	0	0	0	0
07/10/2021 16:00	7.5	1	0	0	0	0
07/10/2021 17:00	3.7	1	0	0	1	0
07/10/2021 18:00	0.0	0	0	0	0	0
07/10/2021 19:00	0.0	0	0	0	0	0
07/10/2021 20:00	0.0	0	0	0	0	0
07/10/2021 21:00	0.0	0	0	0	0	0
07/10/2021 22:00	0.0	0	0	0	0	0
07/10/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	11.2 #	2 #	0 #	0 #	1 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	7.5	1	0	0	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/11/2021 00:00	0.0	0	0	0	0	0
07/11/2021 01:00	0.0	0	0	0	0	0
07/11/2021 02:00	0.0	0	0	0	0	0
07/11/2021 03:00	0.0	0	0	0	0	0
07/11/2021 04:00	0.0	0	0	0	0	0
07/11/2021 05:00	0.0	0	0	0	0	0
07/11/2021 06:00	0.0	0	0	0	0	0
07/11/2021 07:00	0.0	0	0	0	0	0
07/11/2021 08:00	0.0	0	0	0	0	0
07/11/2021 09:00	0.0	0	0	0	0	0
07/11/2021 10:00	0.0	0	0	0	0	0
07/11/2021 11:00	0.0	0	0	0	0	0
07/11/2021 12:00	0.0	0	0	0	0	0
07/11/2021 13:00	0.0	0	0	0	0	0
07/11/2021 14:00	0.0	0	0	0	0	0
07/11/2021 15:00	0.0	0	0	0	0	0
07/11/2021 16:00	0.0	0	0	0	0	0
07/11/2021 17:00	0.0	0	0	0	0	0
07/11/2021 18:00	0.0	0	0	0	0	0
07/11/2021 19:00	0.0	0	0	0	0	0
07/11/2021 20:00	0.0	0	0	0	0	0
07/11/2021 21:00	0.0	0	0	0	0	0
07/11/2021 22:00	0.0	0	0	0	0	0
07/11/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/12/2021 00:00	0.0	0	0	0	0	0
07/12/2021 01:00	0.0	0	0	0	0	0
07/12/2021 02:00	0.0	0	0	0	0	0
07/12/2021 03:00	0.0	0	0	0	0	0
07/12/2021 04:00	0.0	0	0	0	0	0
07/12/2021 05:00	0.0	0	0	0	0	0
07/12/2021 06:00	0.0	0	0	0	0	0
07/12/2021 07:00	0.0	0	1	0	0	0
07/12/2021 08:00	0.0	0	1	0	0	0
07/12/2021 09:00	0.0	0	1	0	0	0
07/12/2021 10:00	0.0	0	0	0	0	1
07/12/2021 11:00	0.0	0	0	0	0	1
07/12/2021 12:00	0.0	0	0	0	0	1
07/12/2021 13:00	0.0	0	0	0	0	1
07/12/2021 14:00	0.0	0	0	0	0	1
07/12/2021 15:00	0.0	0	0	0	0	1
07/12/2021 16:00	0.0	0	0	0	0	1
07/12/2021 17:00	0.0	0	0	0	0	1
07/12/2021 18:00	0.0	0	0	0	0	1
07/12/2021 19:00	0.0	0	0	0	0	1
07/12/2021 20:00	0.0	0	0	0	0	1
07/12/2021 21:00	0.0	0	0	0	0	1
07/12/2021 22:00	0.0	0	0	0	0	1
07/12/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	3 #	0 #	0 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/13/2021 00:00	0.0	0	0	0	0	1
07/13/2021 01:00	0.0	0	0	0	0	1
07/13/2021 02:00	0.7	0	0	0	1	0
07/13/2021 03:00	0.0	0	0	0	0	0
07/13/2021 04:00	0.0	0	0	0	0	0
07/13/2021 05:00	0.0	0	0	0	0	0
07/13/2021 06:00	0.0	0	0	0	0	0
07/13/2021 07:00	0.0	0	0	0	0	0
07/13/2021 08:00	0.0	0	0	0	0	0
07/13/2021 09:00	0.0	0	0	0	0	0
07/13/2021 10:00	0.0	0	0	0	0	0
07/13/2021 11:00	0.0	0	0	0	0	0
07/13/2021 12:00	0.0	0	0	0	0	0
07/13/2021 13:00	0.0	0	0	0	0	0
07/13/2021 14:00	0.0	0	0	0	0	0
07/13/2021 15:00	0.0	0	0	0	0	0
07/13/2021 16:00	0.0	0	0	0	0	0
07/13/2021 17:00	30.1	0	1	0	0	0
07/13/2021 18:00	25.1	0	1	0	0	0
07/13/2021 19:00	0.0	0	0	0	0	1
07/13/2021 20:00	0.0	0	0	0	0	1
07/13/2021 21:00	0.0	0	0	0	0	1
07/13/2021 22:00	0.0	0	0	0	0	1
07/13/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	55.9 #	0 #	2 #	0 #	1 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	30.1	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/14/2021 00:00	0.0	0	0	0	0	1
07/14/2021 01:00	0.0	0	0	0	0	1
07/14/2021 02:00	0.0	0	0	0	0	1
07/14/2021 03:00	0.0	0	0	0	0	1
07/14/2021 04:00	0.0	0	0	0	0	1
07/14/2021 05:00	0.0	0	0	0	0	1
07/14/2021 06:00	0.0	0	0	0	0	1
07/14/2021 07:00	0.0	0	0	0	0	1
07/14/2021 08:00	0.0	0	0	0	0	1
07/14/2021 09:00	0.0	0	0	0	0	1
07/14/2021 10:00	0.0	0	0	0	0	1
07/14/2021 11:00	0.0	0	0	0	0	1
07/14/2021 12:00	0.0	0	0	0	0	1
07/14/2021 13:00	0.0	0	0	0	0	1
07/14/2021 14:00	0.0	0	0	0	0	1
07/14/2021 15:00	0.0	0	0	0	0	1
07/14/2021 16:00	0.0	0	0	0	0	1
07/14/2021 17:00	0.0	0	0	0	0	1
07/14/2021 18:00	0.0	0	0	0	0	1
07/14/2021 19:00	0.0	0	0	0	0	1
07/14/2021 20:00	0.0	0	0	0	0	1
07/14/2021 21:00	0.0	0	0	0	0	1
07/14/2021 22:00	0.0	0	0	0	0	1
07/14/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/15/2021 00:00	0.0	0	0	0	0	1
07/15/2021 01:00	0.0	0	0	0	0	1
07/15/2021 02:00	0.0	0	0	0	0	1
07/15/2021 03:00	0.0	0	0	0	0	1
07/15/2021 04:00	0.0	0	0	0	0	1
07/15/2021 05:00	0.0	0	0	0	0	1
07/15/2021 06:00	0.0	0	0	0	0	1
07/15/2021 07:00	0.0	0	0	0	0	1
07/15/2021 08:00	0.0	0	0	0	0	1
07/15/2021 09:00	0.0	0	0	0	0	1
07/15/2021 10:00	0.0	0	0	0	0	1
07/15/2021 11:00	0.0	0	0	0	0	1
07/15/2021 12:00	0.0	0	0	0	0	1
07/15/2021 13:00	0.0	0	0	0	0	1
07/15/2021 14:00	0.0	0	0	0	0	1
07/15/2021 15:00	0.0	0	0	0	0	1
07/15/2021 16:00	0.0	0	0	0	0	1
07/15/2021 17:00	0.0	0	0	0	0	1
07/15/2021 18:00	0.0	0	0	0	0	1
07/15/2021 19:00	0.0	0	0	0	0	1
07/15/2021 20:00	0.0	0	0	0	0	1
07/15/2021 21:00	0.0	0	0	0	0	1
07/15/2021 22:00	0.0	0	0	0	0	1
07/15/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/16/2021 00:00	0.0	0	0	0	0	1
07/16/2021 01:00	0.0	0	0	0	0	1
07/16/2021 02:00	0.0	0	0	0	0	1
07/16/2021 03:00	0.0	0	0	0	0	1
07/16/2021 04:00	0.0	0	0	0	0	1
07/16/2021 05:00	0.0	0	0	0	0	1
07/16/2021 06:00	0.0	0	0	0	0	1
07/16/2021 07:00	0.0	0	0	0	0	1
07/16/2021 08:00	0.0	0	0	0	0	1
07/16/2021 09:00	0.0	0	0	0	0	1
07/16/2021 10:00	0.0	0	0	0	0	1
07/16/2021 11:00	0.0	0	0	0	0	1
07/16/2021 12:00	0.0	0	0	0	0	1
07/16/2021 13:00	0.0	0	0	0	0	1
07/16/2021 14:00	0.0	0	0	0	0	1
07/16/2021 15:00	0.0	0	0	0	0	1
07/16/2021 16:00	0.0	0	0	0	0	1
07/16/2021 17:00	0.0	0	0	0	0	1
07/16/2021 18:00	0.0	0	0	0	0	1
07/16/2021 19:00	0.0	0	0	0	0	1
07/16/2021 20:00	0.0	0	0	0	0	1
07/16/2021 21:00	0.0	0	0	0	0	1
07/16/2021 22:00	0.0	0	0	0	0	1
07/16/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/17/2021 00:00	0.0	0	0	0	0	1
07/17/2021 01:00	0.0	0	0	0	0	1
07/17/2021 02:00	0.0	0	0	0	0	1
07/17/2021 03:00	0.0	0	0	0	0	1
07/17/2021 04:00	0.0	0	0	0	0	1
07/17/2021 05:00	0.0	0	0	0	0	1
07/17/2021 06:00	0.0	0	0	0	0	1
07/17/2021 07:00	0.0	0	0	0	0	1
07/17/2021 08:00	0.0	0	0	0	0	1
07/17/2021 09:00	0.0	0	0	0	0	1
07/17/2021 10:00	0.0	0	0	0	0	1
07/17/2021 11:00	0.0	0	0	0	0	1
07/17/2021 12:00	0.0	0	0	0	0	1
07/17/2021 13:00	0.0	0	0	0	0	1
07/17/2021 14:00	0.0	0	0	0	0	1
07/17/2021 15:00	0.0	0	0	0	0	1
07/17/2021 16:00	0.0	0	0	0	0	1
07/17/2021 17:00	0.0	0	0	0	0	1
07/17/2021 18:00	0.0	0	0	0	0	1
07/17/2021 19:00	0.0	0	0	0	0	1
07/17/2021 20:00	0.0	0	0	0	0	1
07/17/2021 21:00	0.0	0	0	0	0	1
07/17/2021 22:00	0.0	0	0	0	0	1
07/17/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/18/2021 00:00	0.0	0	0	0	0	1
07/18/2021 01:00	0.0	0	0	0	0	1
07/18/2021 02:00	0.0	0	0	0	0	1
07/18/2021 03:00	0.0	0	0	0	0	1
07/18/2021 04:00	0.0	0	0	0	0	1
07/18/2021 05:00	0.0	0	0	0	0	1
07/18/2021 06:00	0.0	0	0	0	0	1
07/18/2021 07:00	0.0	0	0	0	0	1
07/18/2021 08:00	0.0	0	0	0	0	1
07/18/2021 09:00	0.0	0	0	0	0	1
07/18/2021 10:00	0.0	0	0	0	0	1
07/18/2021 11:00	0.0	0	0	0	0	1
07/18/2021 12:00	0.0	0	0	0	0	1
07/18/2021 13:00	0.0	0	0	0	0	1
07/18/2021 14:00	0.0	0	0	0	0	1
07/18/2021 15:00	0.0	0	0	0	0	1
07/18/2021 16:00	0.0	0	0	0	0	1
07/18/2021 17:00	0.0	0	0	0	0	1
07/18/2021 18:00	0.0	0	0	0	0	1
07/18/2021 19:00	0.0	0	0	0	0	1
07/18/2021 20:00	0.0	0	0	0	0	1
07/18/2021 21:00	0.0	0	0	0	0	1
07/18/2021 22:00	0.0	0	0	0	0	1
07/18/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/19/2021 00:00	0.0	0	0	0	0	1
07/19/2021 01:00	0.0	0	0	0	0	1
07/19/2021 02:00	0.0	0	0	0	0	1
07/19/2021 03:00	0.0	0	0	0	0	1
07/19/2021 04:00	0.0	0	0	0	0	1
07/19/2021 05:00	0.0	0	0	0	0	1
07/19/2021 06:00	0.0	0	0	0	0	1
07/19/2021 07:00	0.0	0	0	0	0	1
07/19/2021 08:00	0.0	0	0	0	0	1
07/19/2021 09:00	0.0	0	0	0	0	1
07/19/2021 10:00	0.0	0	0	0	0	1
07/19/2021 11:00	0.0	0	0	0	0	1
07/19/2021 12:00	0.0	0	0	0	0	1
07/19/2021 13:00	0.0	0	0	0	0	1
07/19/2021 14:00	0.0	0	0	0	0	1
07/19/2021 15:00	0.0	0	0	0	0	1
07/19/2021 16:00	0.0	0	0	0	0	1
07/19/2021 17:00	0.0	0	0	0	0	1
07/19/2021 18:00	0.0	0	0	0	0	1
07/19/2021 19:00	0.0	0	0	0	0	1
07/19/2021 20:00	0.0	0	0	0	0	1
07/19/2021 21:00	0.0	0	0	0	0	1
07/19/2021 22:00	0.0	0	0	0	0	1
07/19/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/20/2021 00:00	0.0	0	0	0	0	1
07/20/2021 01:00	0.0	0	0	0	0	1
07/20/2021 02:00	0.0	0	0	0	0	1
07/20/2021 03:00	0.0	0	0	0	0	1
07/20/2021 04:00	0.0	0	0	0	0	1
07/20/2021 05:00	0.0	0	0	0	0	1
07/20/2021 06:00	0.0	0	0	0	0	1
07/20/2021 07:00	0.0	0	0	0	0	1
07/20/2021 08:00	0.0	0	0	0	0	1
07/20/2021 09:00	0.0	0	0	0	0	1
07/20/2021 10:00	0.0	0	0	0	0	1
07/20/2021 11:00	0.0	0	0	0	0	1
07/20/2021 12:00	0.0	0	0	0	0	1
07/20/2021 13:00	0.0	0	0	0	0	1
07/20/2021 14:00	0.0	0	0	0	0	1
07/20/2021 15:00	0.0	0	0	0	0	1
07/20/2021 16:00	0.0	0	0	0	0	1
07/20/2021 17:00	0.0	0	0	0	0	1
07/20/2021 18:00	0.0	0	0	0	0	1
07/20/2021 19:00	0.0	0	0	0	0	1
07/20/2021 20:00	0.0	0	0	0	0	1
07/20/2021 21:00	0.0	0	0	0	0	1
07/20/2021 22:00	0.0	0	0	0	0	1
07/20/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/21/2021 00:00	0.0	0	0	0	0	1
07/21/2021 01:00	0.0	0	0	0	0	1
07/21/2021 02:00	0.0	0	0	0	0	1
07/21/2021 03:00	0.0	0	0	0	0	1
07/21/2021 04:00	0.0	0	0	0	0	1
07/21/2021 05:00	0.0	0	0	0	0	1
07/21/2021 06:00	0.0	0	0	0	0	1
07/21/2021 07:00	0.0	0	0	0	0	1
07/21/2021 08:00	0.0	0	0	0	0	1
07/21/2021 09:00	0.0	0	0	0	0	1
07/21/2021 10:00	0.0	0	0	0	0	1
07/21/2021 11:00	0.0	0	0	0	0	1
07/21/2021 12:00	0.0	0	0	0	0	1
07/21/2021 13:00	0.0	0	0	0	0	1
07/21/2021 14:00	0.0	0	0	0	0	1
07/21/2021 15:00	0.0	0	0	0	0	1
07/21/2021 16:00	0.0	0	0	0	0	1
07/21/2021 17:00	0.0	0	0	0	0	1
07/21/2021 18:00	0.0	0	0	0	0	1
07/21/2021 19:00	0.0	0	0	0	0	1
07/21/2021 20:00	0.0	0	0	0	0	1
07/21/2021 21:00	0.0	0	0	0	0	1
07/21/2021 22:00	0.0	0	0	0	0	1
07/21/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/22/2021 00:00	0.0	0	0	0	0	1
07/22/2021 01:00	0.0	0	0	0	0	1
07/22/2021 02:00	0.0	0	0	0	0	1
07/22/2021 03:00	0.0	0	0	0	0	1
07/22/2021 04:00	0.0	0	0	0	0	1
07/22/2021 05:00	0.0	0	0	0	0	1
07/22/2021 06:00	0.0	0	0	0	0	1
07/22/2021 07:00	0.0	0	0	0	0	1
07/22/2021 08:00	0.0	0	0	0	0	1
07/22/2021 09:00	0.0	0	0	0	0	1
07/22/2021 10:00	0.0	0	0	0	0	1
07/22/2021 11:00	0.0	0	0	0	0	1
07/22/2021 12:00	0.0	0	0	0	0	1
07/22/2021 13:00	0.0	0	0	0	0	1
07/22/2021 14:00	0.0	0	0	0	0	1
07/22/2021 15:00	0.0	0	0	0	0	1
07/22/2021 16:00	0.0	0	0	0	0	1
07/22/2021 17:00	0.0	0	0	0	0	1
07/22/2021 18:00	0.0	0	0	0	0	1
07/22/2021 19:00	0.0	0	0	0	0	1
07/22/2021 20:00	0.0	0	0	0	0	1
07/22/2021 21:00	0.0	0	0	0	0	1
07/22/2021 22:00	0.0	0	0	0	0	1
07/22/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/23/2021 00:00	0.0	0	0	0	0	1
07/23/2021 01:00	0.0	0	0	0	0	1
07/23/2021 02:00	0.0	0	0	0	0	1
07/23/2021 03:00	0.0	0	0	0	0	1
07/23/2021 04:00	0.0	0	0	0	0	1
07/23/2021 05:00	0.0	0	0	0	0	1
07/23/2021 06:00	0.0	0	0	0	0	1
07/23/2021 07:00	0.0	0	0	0	0	1
07/23/2021 08:00	0.0	0	0	0	0	1
07/23/2021 09:00	0.0	0	0	0	0	1
07/23/2021 10:00	0.0	0	0	0	0	1
07/23/2021 11:00	0.0	0	0	0	0	1
07/23/2021 12:00	0.0	0	0	0	0	1
07/23/2021 13:00	0.0	0	0	0	0	1
07/23/2021 14:00	0.0	0	0	0	0	1
07/23/2021 15:00	0.0	0	0	0	0	1
07/23/2021 16:00	0.0	0	0	0	0	1
07/23/2021 17:00	0.0	0	0	0	0	1
07/23/2021 18:00	0.0	0	0	0	0	1
07/23/2021 19:00	0.0	0	0	0	0	1
07/23/2021 20:00	0.0	0	0	0	0	1
07/23/2021 21:00	0.0	0	0	0	0	1
07/23/2021 22:00	0.0	0	0	0	0	1
07/23/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/24/2021 00:00	0.0	0	0	0	0	1
07/24/2021 01:00	0.0	0	0	0	0	1
07/24/2021 02:00	0.0	0	0	0	0	1
07/24/2021 03:00	0.0	0	0	0	0	1
07/24/2021 04:00	0.0	0	0	0	0	1
07/24/2021 05:00	0.0	0	0	0	0	1
07/24/2021 06:00	0.0	0	0	0	0	1
07/24/2021 07:00	0.0	0	0	0	0	1
07/24/2021 08:00	0.0	0	0	0	0	1
07/24/2021 09:00	0.0	0	0	0	0	1
07/24/2021 10:00	0.0	0	0	0	0	1
07/24/2021 11:00	0.0	0	0	0	0	1
07/24/2021 12:00	0.0	0	0	0	0	1
07/24/2021 13:00	0.0	0	0	0	0	1
07/24/2021 14:00	0.0	0	0	0	0	1
07/24/2021 15:00	0.0	0	0	0	0	1
07/24/2021 16:00	0.0	0	0	0	0	1
07/24/2021 17:00	0.0	0	0	0	0	1
07/24/2021 18:00	0.0	0	0	0	0	1
07/24/2021 19:00	0.0	0	0	0	0	1
07/24/2021 20:00	0.0	0	0	0	0	1
07/24/2021 21:00	0.0	0	0	0	0	1
07/24/2021 22:00	0.0	0	0	0	0	1
07/24/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/25/2021 00:00	0.0	0	0	0	0	1
07/25/2021 01:00	0.0	0	0	0	0	1
07/25/2021 02:00	0.0	0	0	0	0	1
07/25/2021 03:00	0.0	0	0	0	0	1
07/25/2021 04:00	0.0	0	0	0	0	1
07/25/2021 05:00	0.0	0	0	0	0	1
07/25/2021 06:00	0.0	0	0	0	0	1
07/25/2021 07:00	0.0	0	0	0	0	1
07/25/2021 08:00	0.0	0	0	0	0	1
07/25/2021 09:00	0.0	0	0	0	0	1
07/25/2021 10:00	0.0	0	0	0	0	1
07/25/2021 11:00	0.0	0	0	0	0	1
07/25/2021 12:00	0.0	0	0	0	0	1
07/25/2021 13:00	0.0	0	0	0	0	1
07/25/2021 14:00	0.0	0	0	0	0	1
07/25/2021 15:00	0.0	0	0	0	0	1
07/25/2021 16:00	0.0	0	0	0	0	1
07/25/2021 17:00	0.0	0	0	0	0	1
07/25/2021 18:00	0.0	0	0	0	0	1
07/25/2021 19:00	0.0	0	0	0	0	1
07/25/2021 20:00	0.0	0	0	0	0	1
07/25/2021 21:00	0.0	0	0	0	0	1
07/25/2021 22:00	0.0	0	0	0	0	1
07/25/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/26/2021 00:00	0.0	0	0	0	0	1
07/26/2021 01:00	0.0	0	0	0	0	1
07/26/2021 02:00	0.0	0	0	0	0	1
07/26/2021 03:00	0.0	0	0	0	0	1
07/26/2021 04:00	0.0	0	0	0	0	1
07/26/2021 05:00	0.0	0	0	0	0	1
07/26/2021 06:00	0.0	0	0	0	0	1
07/26/2021 07:00	0.0	0	0	0	0	1
07/26/2021 08:00	0.0	0	0	0	0	1
07/26/2021 09:00	0.0	0	0	0	0	1
07/26/2021 10:00	0.0	0	0	0	0	1
07/26/2021 11:00	0.0	0	0	0	0	1
07/26/2021 12:00	0.0	0	0	0	0	1
07/26/2021 13:00	0.0	0	0	0	0	1
07/26/2021 14:00	0.0	0	0	0	0	1
07/26/2021 15:00	0.0	0	0	0	0	1
07/26/2021 16:00	0.0	0	0	0	0	1
07/26/2021 17:00	0.0	0	0	0	0	1
07/26/2021 18:00	0.0	0	0	0	0	1
07/26/2021 19:00	0.0	0	0	0	0	1
07/26/2021 20:00	0.0	0	0	0	0	1
07/26/2021 21:00	0.0	0	0	0	0	1
07/26/2021 22:00	0.0	0	0	0	0	1
07/26/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/27/2021 00:00	0.0	0	0	0	0	1
07/27/2021 01:00	0.0	0	0	0	0	1
07/27/2021 02:00	0.0	0	0	0	0	1
07/27/2021 03:00	0.0	0	0	0	0	1
07/27/2021 04:00	0.0	0	0	0	0	1
07/27/2021 05:00	0.0	0	0	0	0	1
07/27/2021 06:00	0.0	0	0	0	0	1
07/27/2021 07:00	0.0	0	0	0	0	1
07/27/2021 08:00	0.0	0	0	0	0	1
07/27/2021 09:00	0.0	0	0	0	0	1
07/27/2021 10:00	0.0	0	0	0	0	1
07/27/2021 11:00	0.0	0	0	0	0	1
07/27/2021 12:00	0.0	0	0	0	0	1
07/27/2021 13:00	0.0	0	0	0	0	1
07/27/2021 14:00	0.0	0	0	0	0	1
07/27/2021 15:00	0.0	0	0	0	0	1
07/27/2021 16:00	0.0	0	0	0	0	1
07/27/2021 17:00	0.0	0	0	0	0	1
07/27/2021 18:00	0.0	0	0	0	0	1
07/27/2021 19:00	0.0	0	0	0	0	1
07/27/2021 20:00	0.0	0	0	0	0	1
07/27/2021 21:00	0.0	0	0	0	0	1
07/27/2021 22:00	0.0	0	0	0	0	1
07/27/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/28/2021 00:00	0.0	0	0	0	0	1
07/28/2021 01:00	0.0	0	0	0	0	1
07/28/2021 02:00	0.0	0	0	0	0	1
07/28/2021 03:00	0.0	0	0	0	0	1
07/28/2021 04:00	0.0	0	0	0	0	1
07/28/2021 05:00	0.0	0	0	0	0	1
07/28/2021 06:00	0.0	0	0	0	0	1
07/28/2021 07:00	0.0	0	0	0	0	1
07/28/2021 08:00	0.0	0	0	0	0	1
07/28/2021 09:00	0.0	0	0	0	0	1
07/28/2021 10:00	0.0	0	0	0	0	1
07/28/2021 11:00	0.0	0	0	0	0	1
07/28/2021 12:00	0.0	0	0	0	0	1
07/28/2021 13:00	0.0	0	0	0	0	1
07/28/2021 14:00	0.0	0	0	0	0	1
07/28/2021 15:00	0.0	0	0	0	0	1
07/28/2021 16:00	0.0	0	0	0	0	1
07/28/2021 17:00	0.0	0	0	0	0	1
07/28/2021 18:00	0.0	0	0	0	0	1
07/28/2021 19:00	0.0	0	0	0	0	1
07/28/2021 20:00	0.0	0	0	0	0	1
07/28/2021 21:00	0.0	0	0	0	0	1
07/28/2021 22:00	0.0	0	0	0	0	1
07/28/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/29/2021 00:00	0.0	0	0	0	0	1
07/29/2021 01:00	0.0	0	0	0	0	1
07/29/2021 02:00	0.0	0	0	0	0	1
07/29/2021 03:00	0.0	0	0	0	0	1
07/29/2021 04:00	0.0	0	0	0	0	1
07/29/2021 05:00	0.0	0	0	0	0	1
07/29/2021 06:00	0.0	0	0	0	0	1
07/29/2021 07:00	0.0	0	0	0	0	1
07/29/2021 08:00	0.0	0	0	0	0	1
07/29/2021 09:00	0.0	0	0	0	0	1
07/29/2021 10:00	0.0	0	0	0	0	1
07/29/2021 11:00	0.0	0	0	0	0	1
07/29/2021 12:00	0.0	0	0	0	0	1
07/29/2021 13:00	0.0	0	0	0	0	1
07/29/2021 14:00	0.0	0	0	0	0	1
07/29/2021 15:00	0.0	0	0	0	0	1
07/29/2021 16:00	0.0	0	0	0	0	1
07/29/2021 17:00	0.0	0	0	0	0	1
07/29/2021 18:00	0.0	0	0	0	0	1
07/29/2021 19:00	0.0	0	0	0	0	1
07/29/2021 20:00	0.0	0	0	0	0	1
07/29/2021 21:00	0.0	0	0	0	0	1
07/29/2021 22:00	0.0	0	0	0	0	1
07/29/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/30/2021 00:00	0.0	0	0	0	0	1
07/30/2021 01:00	0.0	0	0	0	0	1
07/30/2021 02:00	0.0	0	0	0	0	1
07/30/2021 03:00	0.0	0	0	0	0	1
07/30/2021 04:00	0.0	0	0	0	0	1
07/30/2021 05:00	0.0	0	0	0	0	1
07/30/2021 06:00	0.0	0	0	0	0	1
07/30/2021 07:00	0.0	0	0	0	0	1
07/30/2021 08:00	0.0	0	0	0	0	1
07/30/2021 09:00	0.0	0	0	0	0	1
07/30/2021 10:00	0.0	0	0	0	0	1
07/30/2021 11:00	0.0	0	0	0	0	1
07/30/2021 12:00	0.0	0	0	0	0	1
07/30/2021 13:00	0.0	0	0	0	0	1
07/30/2021 14:00	0.0	0	0	0	0	1
07/30/2021 15:00	0.0	0	0	0	0	1
07/30/2021 16:00	0.0	0	0	0	0	1
07/30/2021 17:00	0.0	0	0	0	0	1
07/30/2021 18:00	0.0	0	0	0	0	1
07/30/2021 19:00	0.0	0	0	0	0	1
07/30/2021 20:00	0.0	0	0	0	0	1
07/30/2021 21:00	0.0	0	0	0	0	1
07/30/2021 22:00	0.0	0	0	0	0	1
07/30/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/31/2021 00:00	0.0	0	0	0	0	1
07/31/2021 01:00	0.0	0	0	0	0	1
07/31/2021 02:00	0.0	0	0	0	0	1
07/31/2021 03:00	0.0	0	0	0	0	1
07/31/2021 04:00	0.0	0	0	0	0	1
07/31/2021 05:00	0.0	0	0	0	0	1
07/31/2021 06:00	0.0	0	0	0	0	1
07/31/2021 07:00	0.0	0	0	0	0	1
07/31/2021 08:00	0.0	0	0	0	0	1
07/31/2021 09:00	0.0	0	0	0	0	1
07/31/2021 10:00	0.0	0	0	0	0	1
07/31/2021 11:00	0.0	0	0	0	0	1
07/31/2021 12:00	0.0	0	0	0	0	1
07/31/2021 13:00	0.0	0	0	0	0	1
07/31/2021 14:00	0.0	0	0	0	0	1
07/31/2021 15:00	0.0	0	0	0	0	1
07/31/2021 16:00	0.0	0	0	0	0	1
07/31/2021 17:00	0.0	0	0	0	0	1
07/31/2021 18:00	0.0	0	0	0	0	1
07/31/2021 19:00	0.0	0	0	0	0	1
07/31/2021 20:00	0.0	0	0	0	0	1
07/31/2021 21:00	0.0	0	0	0	0	1
07/31/2021 22:00	0.0	0	0	0	0	1
07/31/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/01/2021 00:00	0.0	0	0	0	0	1
08/01/2021 01:00	0.0	0	0	0	0	1
08/01/2021 02:00	0.0	0	0	0	0	1
08/01/2021 03:00	0.0	0	0	0	0	1
08/01/2021 04:00	0.0	0	0	0	0	1
08/01/2021 05:00	0.0	0	0	0	0	1
08/01/2021 06:00	0.0	0	0	0	0	1
08/01/2021 07:00	0.0	0	0	0	0	1
08/01/2021 08:00	0.0	0	0	0	0	1
08/01/2021 09:00	0.0	0	0	0	0	1
08/01/2021 10:00	0.0	0	0	0	0	1
08/01/2021 11:00	0.0	0	0	0	0	1
08/01/2021 12:00	0.0	0	0	0	0	1
08/01/2021 13:00	0.0	0	0	0	0	1
08/01/2021 14:00	0.0	0	0	0	0	1
08/01/2021 15:00	0.0	0	0	0	0	1
08/01/2021 16:00	0.0	0	0	0	0	1
08/01/2021 17:00	0.0	0	0	0	0	1
08/01/2021 18:00	0.0	0	0	0	0	1
08/01/2021 19:00	0.0	0	0	0	0	1
08/01/2021 20:00	0.0	0	0	0	0	1
08/01/2021 21:00	0.0	0	0	0	0	1
08/01/2021 22:00	0.0	0	0	0	0	1
08/01/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/02/2021 00:00	0.0	0	0	0	0	1
08/02/2021 01:00	0.0	0	0	0	0	1
08/02/2021 02:00	0.0	0	0	0	0	1
08/02/2021 03:00	0.0	0	0	0	0	1
08/02/2021 04:00	0.0	0	0	0	0	1
08/02/2021 05:00	0.0	0	0	0	0	1
08/02/2021 06:00	0.0	0	0	0	0	1
08/02/2021 07:00	0.0	0	0	0	0	1
08/02/2021 08:00	0.0	0	0	0	0	1
08/02/2021 09:00	0.0	0	0	0	0	1
08/02/2021 10:00	0.0	0	0	0	0	1
08/02/2021 11:00	0.0	0	0	0	0	1
08/02/2021 12:00	0.0	0	0	0	0	1
08/02/2021 13:00	0.0	0	0	0	0	1
08/02/2021 14:00	0.0	0	0	0	0	1
08/02/2021 15:00	0.0	0	0	0	0	1
08/02/2021 16:00	0.0	0	0	0	0	1
08/02/2021 17:00	0.0	0	0	0	0	1
08/02/2021 18:00	0.0	0	0	0	0	1
08/02/2021 19:00	0.0	0	0	0	0	1
08/02/2021 20:00	0.0	0	0	0	0	1
08/02/2021 21:00	0.0	0	0	0	0	1
08/02/2021 22:00	0.0	0	0	0	0	1
08/02/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/03/2021 00:00	0.0	0	0	0	0	1
08/03/2021 01:00	0.0	0	0	0	0	1
08/03/2021 02:00	0.0	0	0	0	0	1
08/03/2021 03:00	0.0	0	0	0	0	1
08/03/2021 04:00	0.2	0	0	0	1	0
08/03/2021 05:00	0.0	0	0	0	0	0
08/03/2021 06:00	0.0	0	0	0	0	0
08/03/2021 07:00	0.0	0	0	0	0	0
08/03/2021 08:00	0.0	0	0	0	0	0
08/03/2021 09:00	0.0	0	0	0	0	0
08/03/2021 10:00	0.0	0	0	0	0	0
08/03/2021 11:00	44.2	0	0	1	0	0
08/03/2021 12:00	0.3	0	0	1	0	0
08/03/2021 13:00	0.0	0	0	0	0	1
08/03/2021 14:00	0.0	0	0	0	0	1
08/03/2021 15:00	0.0	0	0	0	0	1
08/03/2021 16:00	0.0	0	0	0	0	1
08/03/2021 17:00	0.0	0	0	0	0	1
08/03/2021 18:00	0.0	0	0	0	0	1
08/03/2021 19:00	0.0	0	0	0	0	1
08/03/2021 20:00	0.0	0	0	0	0	1
08/03/2021 21:00	0.0	0	0	0	0	1
08/03/2021 22:00	0.0	0	0	0	0	1
08/03/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	44.7 #	0 #	0 #	2 #	1 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	44.2	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/04/2021 00:00	0.0	0	0	0	0	1
08/04/2021 01:00	0.0	0	0	0	0	1
08/04/2021 02:00	0.0	0	0	0	0	1
08/04/2021 03:00	0.0	0	0	0	0	1
08/04/2021 04:00	0.0	0	0	0	0	1
08/04/2021 05:00	0.0	0	0	0	0	1
08/04/2021 06:00	0.0	0	0	0	0	1
08/04/2021 07:00	0.0	0	0	0	0	1
08/04/2021 08:00	0.0	0	0	0	0	1
08/04/2021 09:00	0.0	0	0	0	0	1
08/04/2021 10:00	0.0	0	0	0	0	1
08/04/2021 11:00	0.0	0	0	0	0	1
08/04/2021 12:00	0.0	0	0	0	0	1
08/04/2021 13:00	0.0	0	0	0	0	1
08/04/2021 14:00	0.0	0	0	0	0	1
08/04/2021 15:00	0.0	0	0	0	0	1
08/04/2021 16:00	0.0	0	0	0	0	1
08/04/2021 17:00	0.0	0	0	0	0	1
08/04/2021 18:00	0.0	0	0	0	0	1
08/04/2021 19:00	0.0	0	0	0	0	1
08/04/2021 20:00	0.0	0	0	0	0	1
08/04/2021 21:00	0.0	0	0	0	0	1
08/04/2021 22:00	0.0	0	0	0	0	1
08/04/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/05/2021 00:00	0.0	0	0	0	0	1
08/05/2021 01:00	0.0	0	0	0	0	1
08/05/2021 02:00	0.0	0	0	0	0	1
08/05/2021 03:00	0.0	0	0	0	0	1
08/05/2021 04:00	0.0	0	0	0	0	1
08/05/2021 05:00	0.0	0	0	0	0	1
08/05/2021 06:00	0.0	0	0	0	0	1
08/05/2021 07:00	0.0	0	0	0	0	1
08/05/2021 08:00	0.0	0	0	0	0	1
08/05/2021 09:00	0.0	0	0	0	0	1
08/05/2021 10:00	0.0	0	0	0	0	1
08/05/2021 11:00	0.0	0	0	0	0	1
08/05/2021 12:00	0.0	0	0	0	0	1
08/05/2021 13:00	0.0	0	0	0	0	1
08/05/2021 14:00	0.0	0	0	0	0	1
08/05/2021 15:00	0.0	0	0	0	0	1
08/05/2021 16:00	0.0	0	0	0	0	1
08/05/2021 17:00	0.0	0	0	0	0	1
08/05/2021 18:00	0.0	0	0	0	0	1
08/05/2021 19:00	0.0	0	0	0	0	1
08/05/2021 20:00	0.0	0	0	0	0	1
08/05/2021 21:00	0.0	0	0	0	0	1
08/05/2021 22:00	0.0	0	0	0	0	1
08/05/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/06/2021 00:00	0.0	0	0	0	0	1
08/06/2021 01:00	0.0	0	0	0	0	1
08/06/2021 02:00	0.0	0	0	0	0	1
08/06/2021 03:00	0.0	0	0	0	0	1
08/06/2021 04:00	0.0	0	0	0	0	1
08/06/2021 05:00	0.0	0	0	0	0	1
08/06/2021 06:00	0.0	0	0	0	0	1
08/06/2021 07:00	0.0	0	0	0	0	1
08/06/2021 08:00	0.0	0	0	0	0	1
08/06/2021 09:00	0.0	0	0	0	0	1
08/06/2021 10:00	0.0	0	0	0	0	1
08/06/2021 11:00	0.0	0	0	0	0	1
08/06/2021 12:00	0.0	0	0	0	0	1
08/06/2021 13:00	0.0	0	0	0	0	1
08/06/2021 14:00	0.0	0	0	0	0	1
08/06/2021 15:00	0.0	0	0	0	0	1
08/06/2021 16:00	0.0	0	0	0	0	1
08/06/2021 17:00	0.0	0	0	0	0	1
08/06/2021 18:00	0.0	0	0	0	0	1
08/06/2021 19:00	0.0	0	0	0	0	1
08/06/2021 20:00	0.0	0	0	0	0	1
08/06/2021 21:00	0.0	0	0	0	0	1
08/06/2021 22:00	0.0	0	0	0	0	1
08/06/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/07/2021 00:00	0.0	0	0	0	0	1
08/07/2021 01:00	0.0	0	0	0	0	1
08/07/2021 02:00	0.0	0	0	0	0	1
08/07/2021 03:00	1.2	0	0	0	1	0
08/07/2021 04:00	0.0	0	0	0	0	0
08/07/2021 05:00	0.0	0	0	0	0	0
08/07/2021 06:00	0.0	0	0	0	0	0
08/07/2021 07:00	0.0	0	0	0	0	0
08/07/2021 08:00	0.0	0	0	0	0	0
08/07/2021 09:00	0.3	0	0	1	0	0
08/07/2021 10:00	24.8	0	0	1	0	0
08/07/2021 11:00	3.4	0	0	1	1	0
08/07/2021 12:00	17.5	0	0	1	0	0
08/07/2021 13:00	0.0	0	0	0	0	1
08/07/2021 14:00	0.0	0	0	0	0	1
08/07/2021 15:00	0.0	0	0	0	0	1
08/07/2021 16:00	0.0	0	0	0	0	1
08/07/2021 17:00	0.0	0	0	0	0	1
08/07/2021 18:00	0.0	0	0	0	0	1
08/07/2021 19:00	0.0	0	0	0	0	1
08/07/2021 20:00	0.0	0	0	0	0	1
08/07/2021 21:00	0.0	0	0	0	0	1
08/07/2021 22:00	0.0	0	0	0	0	1
08/07/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	47.2 #	0 #	0 #	4 #	2 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	24.8	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/08/2021 00:00	0.0	0	0	0	0	1
08/08/2021 01:00	0.0	0	0	0	0	1
08/08/2021 02:00	0.0	0	0	0	0	1
08/08/2021 03:00	0.0	0	0	0	0	1
08/08/2021 04:00	0.0	0	0	0	0	1
08/08/2021 05:00	0.0	0	0	0	0	1
08/08/2021 06:00	0.0	0	0	0	0	1
08/08/2021 07:00	0.0	0	0	0	0	1
08/08/2021 08:00	0.0	0	0	0	0	1
08/08/2021 09:00	0.0	0	0	0	0	1
08/08/2021 10:00	0.0	0	0	0	0	1
08/08/2021 11:00	0.0	0	0	0	0	1
08/08/2021 12:00	0.0	0	0	0	0	1
08/08/2021 13:00	0.0	0	0	0	0	1
08/08/2021 14:00	0.0	0	0	0	0	1
08/08/2021 15:00	0.0	0	0	0	0	1
08/08/2021 16:00	0.0	0	0	0	0	1
08/08/2021 17:00	0.0	0	0	0	0	1
08/08/2021 18:00	0.0	0	0	0	0	1
08/08/2021 19:00	0.0	0	0	0	0	1
08/08/2021 20:00	0.0	0	0	0	0	1
08/08/2021 21:00	0.0	0	0	0	0	1
08/08/2021 22:00	0.0	0	0	0	0	1
08/08/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/09/2021 00:00	0.0	0	0	0	0	1
08/09/2021 01:00	0.0	0	0	0	0	1
08/09/2021 02:00	0.0	0	0	0	0	1
08/09/2021 03:00	0.0	0	0	0	0	1
08/09/2021 04:00	0.0	0	0	0	0	1
08/09/2021 05:00	0.0	0	0	0	0	1
08/09/2021 06:00	0.0	0	0	0	0	1
08/09/2021 07:00	0.0	0	0	0	0	1
08/09/2021 08:00	0.0	0	0	0	0	1
08/09/2021 09:00	0.0	0	0	0	0	1
08/09/2021 10:00	0.0	0	0	0	0	1
08/09/2021 11:00	0.0	0	0	0	0	1
08/09/2021 12:00	0.0	0	0	0	0	1
08/09/2021 13:00	0.0	0	0	0	0	1
08/09/2021 14:00	0.0	0	0	0	0	1
08/09/2021 15:00	0.0	0	0	0	0	1
08/09/2021 16:00	0.0	0	0	0	0	1
08/09/2021 17:00	0.0	0	0	0	0	1
08/09/2021 18:00	0.0	0	0	0	0	1
08/09/2021 19:00	0.0	0	0	0	0	1
08/09/2021 20:00	0.0	0	0	0	0	1
08/09/2021 21:00	0.0	0	0	0	0	1
08/09/2021 22:00	0.0	0	0	0	0	1
08/09/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/10/2021 00:00	0.0	0	0	0	0	1
08/10/2021 01:00	0.0	0	0	0	0	1
08/10/2021 02:00	0.0	0	0	0	0	1
08/10/2021 03:00	0.0	0	0	0	0	1
08/10/2021 04:00	0.0	0	0	0	0	1
08/10/2021 05:00	0.0	0	0	0	0	1
08/10/2021 06:00	0.0	0	0	0	0	1
08/10/2021 07:00	0.0	0	0	0	0	1
08/10/2021 08:00	0.0	0	0	0	0	1
08/10/2021 09:00	0.0	0	0	0	0	1
08/10/2021 10:00	0.0	0	0	0	0	1
08/10/2021 11:00	0.0	0	0	0	0	1
08/10/2021 12:00	0.0	0	0	0	0	1
08/10/2021 13:00	0.0	0	0	0	0	1
08/10/2021 14:00	0.0	0	0	0	0	1
08/10/2021 15:00	0.0	0	0	0	0	1
08/10/2021 16:00	0.0	0	0	0	0	1
08/10/2021 17:00	0.0	0	0	0	0	1
08/10/2021 18:00	0.0	0	0	0	0	1
08/10/2021 19:00	0.0	0	0	0	0	1
08/10/2021 20:00	0.0	0	0	0	0	1
08/10/2021 21:00	0.0	0	0	0	0	1
08/10/2021 22:00	0.0	0	0	0	0	1
08/10/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/11/2021 00:00	0.0	0	0	0	0	1
08/11/2021 01:00	0.0	0	0	0	0	1
08/11/2021 02:00	0.0	0	0	0	0	1
08/11/2021 03:00	0.0	0	0	0	0	1
08/11/2021 04:00	0.0	0	0	0	0	1
08/11/2021 05:00	0.0	0	0	0	0	1
08/11/2021 06:00	0.0	0	0	0	0	1
08/11/2021 07:00	0.0	0	0	0	0	1
08/11/2021 08:00	0.0	0	0	0	0	1
08/11/2021 09:00	0.0	0	0	0	0	1
08/11/2021 10:00	0.0	0	0	0	0	1
08/11/2021 11:00	0.0	0	0	0	0	1
08/11/2021 12:00	0.0	0	0	0	0	1
08/11/2021 13:00	0.0	0	0	0	0	1
08/11/2021 14:00	0.0	0	0	0	0	1
08/11/2021 15:00	0.0	0	0	0	0	1
08/11/2021 16:00	0.0	0	0	0	0	1
08/11/2021 17:00	0.0	0	0	0	0	1
08/11/2021 18:00	0.0	0	0	0	0	1
08/11/2021 19:00	0.0	0	0	0	0	1
08/11/2021 20:00	0.0	0	0	0	0	1
08/11/2021 21:00	0.0	0	0	0	0	1
08/11/2021 22:00	0.0	0	0	0	0	1
08/11/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/12/2021 00:00	0.0	0	0	0	0	1
08/12/2021 01:00	0.0	0	0	0	0	1
08/12/2021 02:00	0.0	0	0	0	0	1
08/12/2021 03:00	0.0	0	0	0	0	1
08/12/2021 04:00	0.0	0	0	0	0	1
08/12/2021 05:00	0.0	0	0	0	0	1
08/12/2021 06:00	0.0	0	0	0	0	1
08/12/2021 07:00	0.0	0	0	0	0	1
08/12/2021 08:00	0.0	0	0	0	0	1
08/12/2021 09:00	0.0	0	0	0	0	1
08/12/2021 10:00	0.0	0	0	0	0	1
08/12/2021 11:00	0.0	0	0	0	0	1
08/12/2021 12:00	0.0	0	0	0	0	1
08/12/2021 13:00	0.0	0	0	0	0	1
08/12/2021 14:00	0.0	0	0	0	0	1
08/12/2021 15:00	0.0	0	0	0	0	1
08/12/2021 16:00	0.0	0	0	0	0	1
08/12/2021 17:00	0.0	0	0	0	0	1
08/12/2021 18:00	0.0	0	0	0	0	1
08/12/2021 19:00	0.0	0	0	0	0	1
08/12/2021 20:00	0.0	0	0	0	0	1
08/12/2021 21:00	0.0	0	0	0	0	1
08/12/2021 22:00	0.0	0	0	0	0	1
08/12/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/13/2021 00:00	0.0	0	0	0	0	1
08/13/2021 01:00	0.0	0	0	0	0	1
08/13/2021 02:00	0.0	0	0	0	0	1
08/13/2021 03:00	0.0	0	0	0	0	1
08/13/2021 04:00	0.0	0	0	0	0	1
08/13/2021 05:00	0.0	0	0	0	0	1
08/13/2021 06:00	0.0	0	0	0	0	1
08/13/2021 07:00	0.0	0	0	0	0	1
08/13/2021 08:00	0.0	0	0	0	0	1
08/13/2021 09:00	0.0	0	0	0	0	1
08/13/2021 10:00	0.0	0	0	0	0	1
08/13/2021 11:00	0.0	0	0	0	0	1
08/13/2021 12:00	0.0	0	0	0	0	1
08/13/2021 13:00	0.0	0	0	0	0	1
08/13/2021 14:00	0.0	0	0	0	0	1
08/13/2021 15:00	0.0	0	0	0	0	1
08/13/2021 16:00	0.0	0	0	0	0	1
08/13/2021 17:00	0.0	0	0	0	0	1
08/13/2021 18:00	0.0	0	0	0	0	1
08/13/2021 19:00	0.0	0	0	0	0	1
08/13/2021 20:00	0.0	0	0	0	0	1
08/13/2021 21:00	0.0	0	0	0	0	1
08/13/2021 22:00	0.0	0	0	0	0	1
08/13/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/14/2021 00:00	0.0	0	0	0	0	1
08/14/2021 01:00	0.0	0	0	0	0	1
08/14/2021 02:00	0.0	0	0	0	0	1
08/14/2021 03:00	0.0	0	0	0	0	1
08/14/2021 04:00	0.0	0	0	0	0	1
08/14/2021 05:00	0.0	0	0	0	0	1
08/14/2021 06:00	0.0	0	0	0	0	1
08/14/2021 07:00	0.0	0	0	0	0	1
08/14/2021 08:00	0.0	0	0	0	0	1
08/14/2021 09:00	0.0	0	0	0	0	1
08/14/2021 10:00	0.0	0	0	0	0	1
08/14/2021 11:00	0.0	0	0	0	0	1
08/14/2021 12:00	0.0	0	0	0	0	1
08/14/2021 13:00	0.0	0	0	0	0	1
08/14/2021 14:00	0.0	0	0	0	0	1
08/14/2021 15:00	0.0	0	0	0	0	1
08/14/2021 16:00	0.0	0	0	0	0	1
08/14/2021 17:00	0.0	0	0	0	0	1
08/14/2021 18:00	0.0	0	0	0	0	1
08/14/2021 19:00	0.0	0	0	0	0	1
08/14/2021 20:00	0.0	0	0	0	0	1
08/14/2021 21:00	0.0	0	0	0	0	1
08/14/2021 22:00	0.0	0	0	0	0	1
08/14/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/15/2021 00:00	0.0	0	0	0	0	1
08/15/2021 01:00	0.0	0	0	0	0	1
08/15/2021 02:00	0.0	0	0	0	0	1
08/15/2021 03:00	0.0	0	0	0	0	1
08/15/2021 04:00	0.0	0	0	0	0	1
08/15/2021 05:00	0.0	0	0	0	0	1
08/15/2021 06:00	0.0	0	0	0	0	1
08/15/2021 07:00	0.0	0	0	0	0	1
08/15/2021 08:00	0.0	0	0	0	0	1
08/15/2021 09:00	0.0	0	0	0	0	1
08/15/2021 10:00	0.0	0	0	0	0	1
08/15/2021 11:00	0.0	0	0	0	0	1
08/15/2021 12:00	0.0	0	0	0	0	1
08/15/2021 13:00	0.0	0	0	0	0	1
08/15/2021 14:00	0.0	0	0	0	0	1
08/15/2021 15:00	0.0	0	0	0	0	1
08/15/2021 16:00	0.0	0	0	0	0	1
08/15/2021 17:00	0.0	0	0	0	0	1
08/15/2021 18:00	0.0	0	0	0	0	1
08/15/2021 19:00	0.0	0	0	0	0	1
08/15/2021 20:00	0.0	0	0	0	0	1
08/15/2021 21:00	0.0	0	0	0	0	1
08/15/2021 22:00	0.0	0	0	0	0	1
08/15/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/16/2021 00:00	0.0	0	0	0	0	1
08/16/2021 01:00	0.0	0	0	0	0	1
08/16/2021 02:00	0.0	0	0	0	0	1
08/16/2021 03:00	0.0	0	0	0	0	1
08/16/2021 04:00	0.0	0	0	0	0	1
08/16/2021 05:00	0.0	0	0	0	0	1
08/16/2021 06:00	0.0	0	0	0	0	1
08/16/2021 07:00	0.0	0	0	0	0	1
08/16/2021 08:00	0.0	0	0	0	0	1
08/16/2021 09:00	0.0	0	0	0	0	1
08/16/2021 10:00	0.0	0	0	0	0	1
08/16/2021 11:00	0.0	0	0	0	0	1
08/16/2021 12:00	0.0	0	0	0	0	1
08/16/2021 13:00	0.0	0	0	0	0	1
08/16/2021 14:00	0.0	0	0	0	0	1
08/16/2021 15:00	0.0	0	0	0	0	1
08/16/2021 16:00	0.0	0	0	0	0	1
08/16/2021 17:00	0.0	0	0	0	0	1
08/16/2021 18:00	0.0	0	0	0	0	1
08/16/2021 19:00	0.0	0	0	0	0	1
08/16/2021 20:00	0.0	0	0	0	0	1
08/16/2021 21:00	0.0	0	0	0	0	1
08/16/2021 22:00	0.0	0	0	0	0	1
08/16/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/17/2021 00:00	0.0	0	0	0	0	1
08/17/2021 01:00	0.0	0	0	0	0	1
08/17/2021 02:00	0.0	0	0	0	0	1
08/17/2021 03:00	0.0	0	0	0	0	1
08/17/2021 04:00	0.0	0	0	0	0	1
08/17/2021 05:00	0.0	0	0	0	0	1
08/17/2021 06:00	0.0	0	0	0	0	1
08/17/2021 07:00	0.0	0	0	0	0	1
08/17/2021 08:00	0.0	0	0	0	0	1
08/17/2021 09:00	0.0	0	0	0	0	1
08/17/2021 10:00	0.0	0	0	0	0	1
08/17/2021 11:00	0.0	0	0	0	0	1
08/17/2021 12:00	0.0	0	0	0	0	1
08/17/2021 13:00	0.0	0	0	0	0	1
08/17/2021 14:00	0.0	0	0	0	0	1
08/17/2021 15:00	0.0	0	0	0	0	1
08/17/2021 16:00	0.0	0	0	0	0	1
08/17/2021 17:00	0.0	0	0	0	0	1
08/17/2021 18:00	0.0	0	0	0	0	1
08/17/2021 19:00	0.0	0	0	0	0	1
08/17/2021 20:00	0.0	0	0	0	0	1
08/17/2021 21:00	0.0	0	0	0	0	1
08/17/2021 22:00	0.0	0	0	0	0	1
08/17/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/18/2021 00:00	0.0	0	0	0	0	1
08/18/2021 01:00	0.0	0	0	0	0	1
08/18/2021 02:00	0.0	0	0	0	0	1
08/18/2021 03:00	0.0	0	0	0	0	1
08/18/2021 04:00	0.0	0	0	0	0	1
08/18/2021 05:00	0.0	0	0	0	0	1
08/18/2021 06:00	0.0	0	0	0	0	1
08/18/2021 07:00	0.0	0	0	0	0	1
08/18/2021 08:00	0.0	0	0	0	0	1
08/18/2021 09:00	0.0	0	0	0	0	1
08/18/2021 10:00	0.0	0	0	0	0	1
08/18/2021 11:00	0.0	0	0	0	0	1
08/18/2021 12:00	0.0	0	0	0	0	1
08/18/2021 13:00	0.0	0	0	0	0	1
08/18/2021 14:00	0.0	0	0	0	0	1
08/18/2021 15:00	0.0	0	0	0	0	1
08/18/2021 16:00	0.0	0	0	0	0	1
08/18/2021 17:00	0.0	0	0	0	0	1
08/18/2021 18:00	0.0	0	0	0	0	1
08/18/2021 19:00	0.0	0	0	0	0	1
08/18/2021 20:00	0.0	0	0	0	0	1
08/18/2021 21:00	0.0	0	0	0	0	1
08/18/2021 22:00	0.0	0	0	0	0	1
08/18/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/19/2021 00:00	0.0	0	0	0	0	1
08/19/2021 01:00	0.0	0	0	0	0	1
08/19/2021 02:00	0.0	0	0	0	0	1
08/19/2021 03:00	0.0	0	0	0	0	1
08/19/2021 04:00	0.0	0	0	0	0	1
08/19/2021 05:00	0.0	0	0	0	0	1
08/19/2021 06:00	0.0	0	0	0	0	1
08/19/2021 07:00	0.0	0	0	0	0	1
08/19/2021 08:00	0.0	0	0	0	0	1
08/19/2021 09:00	0.0	0	0	0	0	1
08/19/2021 10:00	0.0	0	0	0	0	1
08/19/2021 11:00	0.0	0	0	0	0	1
08/19/2021 12:00	0.0	0	0	0	0	1
08/19/2021 13:00	0.0	0	0	0	0	1
08/19/2021 14:00	0.0	0	0	0	0	1
08/19/2021 15:00	0.0	0	0	0	0	1
08/19/2021 16:00	0.0	0	0	0	0	1
08/19/2021 17:00	0.0	0	0	0	0	1
08/19/2021 18:00	0.0	0	0	0	0	1
08/19/2021 19:00	0.0	0	0	0	0	1
08/19/2021 20:00	0.0	0	0	0	0	1
08/19/2021 21:00	0.0	0	0	0	0	1
08/19/2021 22:00	0.0	0	0	0	0	1
08/19/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/20/2021 00:00	0.0	0	0	0	0	1
08/20/2021 01:00	0.0	0	0	0	0	1
08/20/2021 02:00	0.0	0	0	0	0	1
08/20/2021 03:00	0.0	0	0	0	0	1
08/20/2021 04:00	0.0	0	0	0	0	1
08/20/2021 05:00	0.0	0	0	0	0	1
08/20/2021 06:00	0.0	0	0	0	0	1
08/20/2021 07:00	0.0	0	0	0	0	1
08/20/2021 08:00	0.0	0	0	0	0	1
08/20/2021 09:00	0.0	0	0	0	0	1
08/20/2021 10:00	0.0	0	0	0	0	1
08/20/2021 11:00	0.0	0	0	0	0	1
08/20/2021 12:00	0.0	0	0	0	0	1
08/20/2021 13:00	0.0	0	0	0	0	1
08/20/2021 14:00	0.0	0	0	0	0	1
08/20/2021 15:00	0.0	0	0	0	0	1
08/20/2021 16:00	0.0	0	0	0	0	1
08/20/2021 17:00	0.0	0	0	0	0	1
08/20/2021 18:00	0.0	0	0	0	0	1
08/20/2021 19:00	0.0	0	0	0	0	1
08/20/2021 20:00	0.0	0	0	0	0	1
08/20/2021 21:00	0.0	0	0	0	0	1
08/20/2021 22:00	0.0	0	0	0	0	1
08/20/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/21/2021 00:00	0.8	0	0	0	1	0
08/21/2021 01:00	0.8	0	0	1	0	0
08/21/2021 02:00	2.9	0	0	1	0	0
08/21/2021 03:00	0.0	0	0	0	0	1
08/21/2021 04:00	0.0	0	0	0	0	1
08/21/2021 05:00	0.0	0	0	0	0	1
08/21/2021 06:00	0.0	0	0	0	0	1
08/21/2021 07:00	0.0	0	0	0	0	1
08/21/2021 08:00	0.0	0	0	0	0	1
08/21/2021 09:00	0.0	0	0	0	0	1
08/21/2021 10:00	0.0	0	0	0	0	1
08/21/2021 11:00	0.0	0	0	0	0	1
08/21/2021 12:00	0.0	0	0	0	0	1
08/21/2021 13:00	0.0	0	0	0	0	1
08/21/2021 14:00	0.0	0	0	0	0	1
08/21/2021 15:00	0.7	0	0	0	1	0
08/21/2021 16:00	0.0	0	0	0	0	0
08/21/2021 17:00	0.0	0	0	0	0	0
08/21/2021 18:00	0.0	0	0	0	0	0
08/21/2021 19:00	0.0	0	0	0	0	0
08/21/2021 20:00	0.0	0	0	0	0	0
08/21/2021 21:00	0.0	0	0	0	0	0
08/21/2021 22:00	0.0	0	0	0	0	0
08/21/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	5.2 #	0 #	0 #	2 #	2 #	12 #
Minimum:	0.0	0	0	0	0	0
Maximum:	2.9	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/22/2021 00:00	0.0	0	0	0	0	0
08/22/2021 01:00	0.0	0	0	0	0	0
08/22/2021 02:00	0.0	0	0	0	0	0
08/22/2021 03:00	0.0	0	0	0	0	0
08/22/2021 04:00	0.0	0	0	0	0	0
08/22/2021 05:00	0.0	0	0	0	0	0
08/22/2021 06:00	0.0	0	0	0	0	0
08/22/2021 07:00	0.0	0	0	0	0	0
08/22/2021 08:00	0.0	0	0	0	0	0
08/22/2021 09:00	0.0	0	0	0	0	0
08/22/2021 10:00	0.0	0	0	0	0	0
08/22/2021 11:00	0.0	0	0	0	0	0
08/22/2021 12:00	0.0	0	0	0	0	0
08/22/2021 13:00	0.0	0	0	0	0	0
08/22/2021 14:00	0.0	0	0	0	0	0
08/22/2021 15:00	0.0	0	0	0	0	0
08/22/2021 16:00	0.0	0	0	0	0	0
08/22/2021 17:00	0.0	0	0	0	0	0
08/22/2021 18:00	0.0	0	0	0	0	0
08/22/2021 19:00	0.0	0	0	0	0	0
08/22/2021 20:00	0.0	0	0	0	0	0
08/22/2021 21:00	0.0	0	0	0	0	0
08/22/2021 22:00	0.0	0	0	0	0	0
08/22/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/23/2021 00:00	0.0	0	0	0	0	0
08/23/2021 01:00	0.0	0	0	0	0	0
08/23/2021 02:00	0.0	0	0	0	0	0
08/23/2021 03:00	0.0	0	0	0	0	0
08/23/2021 04:00	0.0	0	0	0	0	0
08/23/2021 05:00	0.0	0	0	0	0	0
08/23/2021 06:00	0.0	0	0	0	0	0
08/23/2021 07:00	0.0	0	0	0	0	0
08/23/2021 08:00	0.0	0	0	0	0	0
08/23/2021 09:00	39.0	0	1	0	0	0
08/23/2021 10:00	25.3	0	1	0	0	0
08/23/2021 11:00	32.9	0	1	0	0	0
08/23/2021 12:00	0.4	0	0	0	1	0
08/23/2021 13:00	8.4	0	0	1	0	0
08/23/2021 14:00	10.9	0	0	1	0	0
08/23/2021 15:00	0.0	0	0	0	0	1
08/23/2021 16:00	0.0	0	0	0	0	1
08/23/2021 17:00	0.0	0	0	0	0	1
08/23/2021 18:00	0.0	0	0	0	0	1
08/23/2021 19:00	0.0	0	0	0	0	1
08/23/2021 20:00	0.0	0	0	0	0	1
08/23/2021 21:00	0.0	0	0	0	0	1
08/23/2021 22:00	0.0	0	0	0	0	1
08/23/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	116.9 #	0 #	3 #	2 #	1 #	9 #
Minimum:	0.0	0	0	0	0	0
Maximum:	39.0	0	1	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/24/2021 00:00	0.0	0	0	0	0	1
08/24/2021 01:00	0.0	0	0	0	0	1
08/24/2021 02:00	0.0	0	0	0	0	1
08/24/2021 03:00	0.0	0	0	0	0	1
08/24/2021 04:00	0.0	0	0	0	0	1
08/24/2021 05:00	0.0	0	0	0	0	1
08/24/2021 06:00	0.0	0	0	0	0	1
08/24/2021 07:00	0.0	0	0	0	0	1
08/24/2021 08:00	0.0	0	0	0	0	1
08/24/2021 09:00	0.0	0	0	0	0	1
08/24/2021 10:00	0.0	0	0	0	0	1
08/24/2021 11:00	0.0	0	0	0	0	1
08/24/2021 12:00	0.0	0	0	0	0	1
08/24/2021 13:00	0.0	0	0	0	0	1
08/24/2021 14:00	0.0	0	0	0	0	1
08/24/2021 15:00	0.0	0	0	0	0	1
08/24/2021 16:00	0.0	0	0	0	0	1
08/24/2021 17:00	0.0	0	0	0	0	1
08/24/2021 18:00	0.0	0	0	0	0	1
08/24/2021 19:00	0.0	0	0	0	0	1
08/24/2021 20:00	0.0	0	0	0	0	1
08/24/2021 21:00	0.0	0	0	0	0	1
08/24/2021 22:00	0.0	0	0	0	0	1
08/24/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/25/2021 00:00	0.0	0	0	0	0	1
08/25/2021 01:00	0.0	0	0	0	0	1
08/25/2021 02:00	0.0	0	0	0	0	1
08/25/2021 03:00	0.0	0	0	0	0	1
08/25/2021 04:00	0.0	0	0	0	0	1
08/25/2021 05:00	0.0	0	0	0	0	1
08/25/2021 06:00	0.0	0	0	0	0	1
08/25/2021 07:00	0.0	0	0	0	0	1
08/25/2021 08:00	0.0	0	0	0	0	1
08/25/2021 09:00	0.0	0	0	0	0	1
08/25/2021 10:00	0.0	0	0	0	0	1
08/25/2021 11:00	0.0	0	0	0	0	1
08/25/2021 12:00	0.0	0	0	0	0	1
08/25/2021 13:00	0.0	0	0	0	0	1
08/25/2021 14:00	0.0	0	0	0	0	1
08/25/2021 15:00	0.0	0	0	0	0	1
08/25/2021 16:00	0.0	0	0	0	0	1
08/25/2021 17:00	0.0	0	0	0	0	1
08/25/2021 18:00	0.0	0	0	0	0	1
08/25/2021 19:00	0.0	0	0	0	0	1
08/25/2021 20:00	0.0	0	0	0	0	1
08/25/2021 21:00	0.0	0	0	0	0	1
08/25/2021 22:00	0.0	0	0	0	0	1
08/25/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/26/2021 00:00	0.0	0	0	0	0	1
08/26/2021 01:00	0.0	0	0	0	0	1
08/26/2021 02:00	0.0	0	0	0	0	1
08/26/2021 03:00	0.0	0	0	0	0	1
08/26/2021 04:00	0.0	0	0	0	0	1
08/26/2021 05:00	0.0	0	0	0	0	1
08/26/2021 06:00	0.0	0	0	0	0	1
08/26/2021 07:00	0.0	0	0	0	0	1
08/26/2021 08:00	0.0	0	0	0	0	1
08/26/2021 09:00	0.0	0	0	0	0	1
08/26/2021 10:00	0.0	0	0	0	0	1
08/26/2021 11:00	0.0	0	0	0	0	1
08/26/2021 12:00	0.0	0	0	0	0	1
08/26/2021 13:00	0.0	0	0	0	0	1
08/26/2021 14:00	0.0	0	0	0	0	1
08/26/2021 15:00	0.0	0	0	0	0	1
08/26/2021 16:00	0.0	0	0	0	0	1
08/26/2021 17:00	0.0	0	0	0	0	1
08/26/2021 18:00	0.0	0	0	0	0	1
08/26/2021 19:00	0.0	0	0	0	0	1
08/26/2021 20:00	0.0	0	0	0	0	1
08/26/2021 21:00	0.0	0	0	0	0	1
08/26/2021 22:00	0.0	0	0	0	0	1
08/26/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/27/2021 00:00	0.0	0	0	0	0	1
08/27/2021 01:00	0.0	0	0	0	0	1
08/27/2021 02:00	0.0	0	0	0	0	1
08/27/2021 03:00	0.0	0	0	0	0	1
08/27/2021 04:00	0.0	0	0	0	0	1
08/27/2021 05:00	0.0	0	0	0	0	1
08/27/2021 06:00	0.0	0	0	0	0	1
08/27/2021 07:00	0.0	0	0	0	0	1
08/27/2021 08:00	0.0	0	0	0	0	1
08/27/2021 09:00	0.0	0	0	0	0	1
08/27/2021 10:00	0.0	0	0	0	0	1
08/27/2021 11:00	0.0	0	0	0	0	1
08/27/2021 12:00	0.0	0	0	0	0	1
08/27/2021 13:00	0.0	0	0	0	0	1
08/27/2021 14:00	0.0	0	0	0	0	1
08/27/2021 15:00	0.0	0	0	0	0	1
08/27/2021 16:00	0.0	0	0	0	0	1
08/27/2021 17:00	0.0	0	0	0	0	1
08/27/2021 18:00	0.0	0	0	0	0	1
08/27/2021 19:00	0.0	0	0	0	0	1
08/27/2021 20:00	0.0	0	0	0	0	1
08/27/2021 21:00	0.0	0	0	0	0	1
08/27/2021 22:00	0.0	0	0	0	0	1
08/27/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/28/2021 00:00	0.0	0	0	0	0	1
08/28/2021 01:00	0.0	0	0	0	0	1
08/28/2021 02:00	0.0	0	0	0	0	1
08/28/2021 03:00	0.0	0	0	0	0	1
08/28/2021 04:00	0.0	0	0	0	0	1
08/28/2021 05:00	0.0	0	0	0	0	1
08/28/2021 06:00	0.0	0	0	0	0	1
08/28/2021 07:00	0.0	0	0	0	0	1
08/28/2021 08:00	0.0	0	0	0	0	1
08/28/2021 09:00	0.0	0	0	0	0	1
08/28/2021 10:00	0.0	0	0	0	0	1
08/28/2021 11:00	0.0	0	0	0	0	1
08/28/2021 12:00	0.0	0	0	0	0	1
08/28/2021 13:00	0.0	0	0	0	0	1
08/28/2021 14:00	0.0	0	0	0	0	1
08/28/2021 15:00	0.0	0	0	0	0	1
08/28/2021 16:00	0.0	0	0	0	0	1
08/28/2021 17:00	0.0	0	0	0	0	1
08/28/2021 18:00	0.0	0	0	0	0	1
08/28/2021 19:00	0.0	0	0	0	0	1
08/28/2021 20:00	0.0	0	0	0	0	1
08/28/2021 21:00	0.0	0	0	0	0	1
08/28/2021 22:00	0.0	0	0	0	0	1
08/28/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/29/2021 00:00	0.0	0	0	0	0	1
08/29/2021 01:00	0.0	0	0	0	0	1
08/29/2021 02:00	0.0	0	0	0	0	1
08/29/2021 03:00	0.0	0	0	0	0	1
08/29/2021 04:00	0.0	0	0	0	0	1
08/29/2021 05:00	0.0	0	0	0	0	1
08/29/2021 06:00	0.0	0	0	0	0	1
08/29/2021 07:00	0.0	0	0	0	0	1
08/29/2021 08:00	0.0	0	0	0	0	1
08/29/2021 09:00	0.0	0	0	0	0	1
08/29/2021 10:00	0.0	0	0	0	0	1
08/29/2021 11:00	0.0	0	0	0	0	1
08/29/2021 12:00	0.0	0	0	0	0	1
08/29/2021 13:00	0.0	0	0	0	0	1
08/29/2021 14:00	0.0	0	0	0	0	1
08/29/2021 15:00	0.0	0	0	0	0	1
08/29/2021 16:00	0.0	0	0	0	0	1
08/29/2021 17:00	0.0	0	0	0	0	1
08/29/2021 18:00	0.0	0	0	0	0	1
08/29/2021 19:00	0.0	0	0	0	0	1
08/29/2021 20:00	0.0	0	0	0	0	1
08/29/2021 21:00	0.0	0	0	0	0	1
08/29/2021 22:00	0.0	0	0	0	0	1
08/29/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/30/2021 00:00	0.0	0	0	0	0	1
08/30/2021 01:00	0.0	0	0	0	0	1
08/30/2021 02:00	0.0	0	0	0	0	1
08/30/2021 03:00	0.0	0	0	0	0	1
08/30/2021 04:00	0.0	0	0	0	0	1
08/30/2021 05:00	0.0	0	0	0	0	1
08/30/2021 06:00	0.0	0	0	0	0	1
08/30/2021 07:00	0.0	0	0	0	0	1
08/30/2021 08:00	0.0	0	0	0	0	1
08/30/2021 09:00	0.0	0	0	0	0	1
08/30/2021 10:00	0.0	0	0	0	0	1
08/30/2021 11:00	0.0	0	0	0	0	1
08/30/2021 12:00	0.0	0	0	0	0	1
08/30/2021 13:00	0.0	0	0	0	0	1
08/30/2021 14:00	0.0	0	0	0	0	1
08/30/2021 15:00	0.0	0	0	0	0	1
08/30/2021 16:00	0.0	0	0	0	0	1
08/30/2021 17:00	0.0	0	0	0	0	1
08/30/2021 18:00	0.0	0	0	0	0	1
08/30/2021 19:00	0.0	0	0	0	0	1
08/30/2021 20:00	0.0	0	0	0	0	1
08/30/2021 21:00	0.0	0	0	0	0	1
08/30/2021 22:00	0.0	0	0	0	0	1
08/30/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/31/2021 00:00	0.0	0	0	0	0	1
08/31/2021 01:00	0.0	0	0	0	0	1
08/31/2021 02:00	0.0	0	0	0	0	1
08/31/2021 03:00	0.0	0	0	0	0	1
08/31/2021 04:00	0.0	0	0	0	0	1
08/31/2021 05:00	0.0	0	0	0	0	1
08/31/2021 06:00	0.0	0	0	0	0	1
08/31/2021 07:00	0.0	0	0	0	0	1
08/31/2021 08:00	0.0	0	0	0	0	1
08/31/2021 09:00	0.0	0	0	0	0	1
08/31/2021 10:00	0.0	0	0	0	0	1
08/31/2021 11:00	0.0	0	0	0	0	1
08/31/2021 12:00	0.0	0	0	0	0	1
08/31/2021 13:00	0.0	0	0	0	0	1
08/31/2021 14:00	0.0	0	0	0	0	1
08/31/2021 15:00	0.0	0	0	0	0	1
08/31/2021 16:00	0.0	0	0	0	0	1
08/31/2021 17:00	0.0	0	0	0	0	1
08/31/2021 18:00	0.0	0	0	0	0	1
08/31/2021 19:00	0.0	0	0	0	0	1
08/31/2021 20:00	0.0	0	0	0	0	1
08/31/2021 21:00	0.0	0	0	0	0	1
08/31/2021 22:00	0.0	0	0	0	0	1
08/31/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/01/2021 00:00	0.0	0	0	0	0	1
09/01/2021 01:00	0.0	0	0	0	0	1
09/01/2021 02:00	0.0	0	0	0	0	1
09/01/2021 03:00	0.0	0	0	0	0	1
09/01/2021 04:00	0.0	0	0	0	0	1
09/01/2021 05:00	0.0	0	0	0	0	1
09/01/2021 06:00	0.0	0	0	0	0	1
09/01/2021 07:00	0.0	0	0	0	0	1
09/01/2021 08:00	0.0	0	0	0	0	1
09/01/2021 09:00	0.0	0	0	0	0	1
09/01/2021 10:00	0.0	0	0	0	0	1
09/01/2021 11:00	0.0	0	0	0	0	1
09/01/2021 12:00	0.0	0	0	0	0	1
09/01/2021 13:00	0.0	0	0	0	0	1
09/01/2021 14:00	0.0	0	0	0	0	1
09/01/2021 15:00	0.0	0	0	0	0	1
09/01/2021 16:00	0.0	0	0	0	0	1
09/01/2021 17:00	0.0	0	0	0	0	1
09/01/2021 18:00	0.0	0	0	0	0	1
09/01/2021 19:00	0.0	0	0	0	0	1
09/01/2021 20:00	0.0	0	0	0	0	1
09/01/2021 21:00	0.0	0	0	0	0	1
09/01/2021 22:00	0.0	0	0	0	0	1
09/01/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/02/2021 00:00	0.0	0	0	0	0	1
09/02/2021 01:00	0.0	0	0	0	0	1
09/02/2021 02:00	0.0	0	0	0	0	1
09/02/2021 03:00	0.0	0	0	0	0	1
09/02/2021 04:00	0.0	0	0	0	0	1
09/02/2021 05:00	0.0	0	0	0	0	1
09/02/2021 06:00	0.0	0	0	0	0	1
09/02/2021 07:00	0.0	0	0	0	0	1
09/02/2021 08:00	0.0	0	0	0	0	1
09/02/2021 09:00	0.0	0	0	0	0	1
09/02/2021 10:00	0.0	0	0	0	0	1
09/02/2021 11:00	0.0	0	0	0	0	1
09/02/2021 12:00	0.0	0	0	0	0	1
09/02/2021 13:00	0.0	0	0	0	0	1
09/02/2021 14:00	0.0	0	0	0	0	1
09/02/2021 15:00	0.0	0	0	0	0	1
09/02/2021 16:00	0.0	0	0	0	0	1
09/02/2021 17:00	0.0	0	0	0	0	1
09/02/2021 18:00	0.0	0	0	0	0	1
09/02/2021 19:00	0.0	0	0	0	0	1
09/02/2021 20:00	0.0	0	0	0	0	1
09/02/2021 21:00	0.0	0	0	0	0	1
09/02/2021 22:00	0.0	0	0	0	0	1
09/02/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/03/2021 00:00	0.0	0	0	0	0	1
09/03/2021 01:00	0.0	0	0	0	0	1
09/03/2021 02:00	0.0	0	0	0	0	1
09/03/2021 03:00	0.0	0	0	0	0	1
09/03/2021 04:00	0.0	0	0	0	0	1
09/03/2021 05:00	0.0	0	0	0	0	1
09/03/2021 06:00	0.0	0	0	0	0	1
09/03/2021 07:00	0.0	0	0	0	0	1
09/03/2021 08:00	0.0	0	0	0	0	1
09/03/2021 09:00	0.0	0	0	0	0	1
09/03/2021 10:00	0.0	0	0	0	0	1
09/03/2021 11:00	0.0	0	0	0	0	1
09/03/2021 12:00	0.0	0	0	0	0	1
09/03/2021 13:00	0.0	0	0	0	0	1
09/03/2021 14:00	0.0	0	0	0	0	1
09/03/2021 15:00	0.0	0	0	0	0	1
09/03/2021 16:00	0.0	0	0	0	0	1
09/03/2021 17:00	0.0	0	0	0	0	1
09/03/2021 18:00	0.0	0	0	0	0	1
09/03/2021 19:00	0.0	0	0	0	0	1
09/03/2021 20:00	0.0	0	0	0	0	1
09/03/2021 21:00	0.0	0	0	0	0	1
09/03/2021 22:00	0.0	0	0	0	0	1
09/03/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/04/2021 00:00	0.0	0	0	0	0	1
09/04/2021 01:00	0.0	0	0	0	0	1
09/04/2021 02:00	0.0	0	0	0	0	1
09/04/2021 03:00	0.7	0	0	0	1	0
09/04/2021 04:00	0.0	0	0	0	0	0
09/04/2021 05:00	0.0	0	0	0	0	0
09/04/2021 06:00	0.0	0	0	0	0	0
09/04/2021 07:00	0.0	0	0	0	0	0
09/04/2021 08:00	0.0	0	0	0	0	0
09/04/2021 09:00	0.0	0	0	0	0	0
09/04/2021 10:00	0.0	0	0	0	0	0
09/04/2021 11:00	0.0	0	0	0	0	0
09/04/2021 12:00	0.0	0	0	0	0	0
09/04/2021 13:00	20.3	0	1	0	0	0
09/04/2021 14:00	20.0	0	1	0	0	0
09/04/2021 15:00	0.0	0	0	0	0	1
09/04/2021 16:00	0.0	0	0	0	0	1
09/04/2021 17:00	0.0	0	0	0	0	1
09/04/2021 18:00	0.0	0	0	0	0	1
09/04/2021 19:00	0.0	0	0	0	0	1
09/04/2021 20:00	0.0	0	0	0	0	1
09/04/2021 21:00	0.0	0	0	0	0	1
09/04/2021 22:00	0.0	0	0	0	0	1
09/04/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	41.0 #	0 #	2 #	0 #	1 #	12 #
Minimum:	0.0	0	0	0	0	0
Maximum:	20.3	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/05/2021 00:00	0.0	0	0	0	0	1
09/05/2021 01:00	0.0	0	0	0	0	1
09/05/2021 02:00	0.0	0	0	0	0	1
09/05/2021 03:00	0.0	0	0	0	0	1
09/05/2021 04:00	0.0	0	0	0	0	1
09/05/2021 05:00	0.0	0	0	0	0	1
09/05/2021 06:00	0.0	0	0	0	0	1
09/05/2021 07:00	0.0	0	0	0	0	1
09/05/2021 08:00	0.0	0	0	0	0	1
09/05/2021 09:00	0.0	0	0	0	0	1
09/05/2021 10:00	0.0	0	0	0	0	1
09/05/2021 11:00	0.0	0	0	0	0	1
09/05/2021 12:00	0.0	0	0	0	0	1
09/05/2021 13:00	0.0	0	0	0	0	1
09/05/2021 14:00	0.0	0	0	0	0	1
09/05/2021 15:00	0.0	0	0	0	0	1
09/05/2021 16:00	0.0	0	0	0	0	1
09/05/2021 17:00	0.0	0	0	0	0	1
09/05/2021 18:00	0.0	0	0	0	0	1
09/05/2021 19:00	0.0	0	0	0	0	1
09/05/2021 20:00	0.0	0	0	0	0	1
09/05/2021 21:00	0.0	0	0	0	0	1
09/05/2021 22:00	0.0	0	0	0	0	1
09/05/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/06/2021 00:00	0.0	0	0	0	0	1
09/06/2021 01:00	0.0	0	0	0	0	1
09/06/2021 02:00	0.0	0	0	0	0	1
09/06/2021 03:00	0.0	0	0	0	0	1
09/06/2021 04:00	0.0	0	0	0	0	1
09/06/2021 05:00	0.0	0	0	0	0	1
09/06/2021 06:00	0.0	0	0	0	0	1
09/06/2021 07:00	0.0	0	0	0	0	1
09/06/2021 08:00	0.0	0	0	0	0	1
09/06/2021 09:00	0.0	0	0	0	0	1
09/06/2021 10:00	0.0	0	0	0	0	1
09/06/2021 11:00	0.0	0	0	0	0	1
09/06/2021 12:00	0.0	0	0	0	0	1
09/06/2021 13:00	0.0	0	0	0	0	1
09/06/2021 14:00	0.0	0	0	0	0	1
09/06/2021 15:00	0.0	0	0	0	0	1
09/06/2021 16:00	0.0	0	0	0	0	1
09/06/2021 17:00	0.0	0	0	0	0	1
09/06/2021 18:00	0.0	0	0	0	0	1
09/06/2021 19:00	0.0	0	0	0	0	1
09/06/2021 20:00	0.0	0	0	0	0	1
09/06/2021 21:00	0.0	0	0	0	0	1
09/06/2021 22:00	0.0	0	0	0	0	1
09/06/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/07/2021 00:00	0.0	0	0	0	0	1
09/07/2021 01:00	0.0	0	0	0	0	1
09/07/2021 02:00	0.0	0	0	0	0	1
09/07/2021 03:00	0.0	0	0	0	0	1
09/07/2021 04:00	0.0	0	0	0	0	1
09/07/2021 05:00	0.0	0	0	0	0	1
09/07/2021 06:00	0.0	0	0	0	0	1
09/07/2021 07:00	0.0	0	0	0	0	1
09/07/2021 08:00	0.0	0	0	0	0	1
09/07/2021 09:00	0.0	0	0	0	0	1
09/07/2021 10:00	0.0	0	0	0	0	1
09/07/2021 11:00	0.0	0	0	0	0	1
09/07/2021 12:00	0.0	0	0	0	0	1
09/07/2021 13:00	0.0	0	0	0	0	1
09/07/2021 14:00	0.0	0	0	0	0	1
09/07/2021 15:00	0.0	0	0	0	0	1
09/07/2021 16:00	0.0	0	0	0	0	1
09/07/2021 17:00	0.0	0	0	0	0	1
09/07/2021 18:00	0.0	0	0	0	0	1
09/07/2021 19:00	0.0	0	0	0	0	1
09/07/2021 20:00	0.0	0	0	0	0	1
09/07/2021 21:00	0.0	0	0	0	0	1
09/07/2021 22:00	0.0	0	0	0	0	1
09/07/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/08/2021 00:00	0.0	0	0	0	0	1
09/08/2021 01:00	0.0	0	0	0	0	1
09/08/2021 02:00	0.0	0	0	0	0	1
09/08/2021 03:00	0.0	0	0	0	0	1
09/08/2021 04:00	0.0	0	0	0	0	1
09/08/2021 05:00	0.0	0	0	0	0	1
09/08/2021 06:00	0.0	0	0	0	0	1
09/08/2021 07:00	0.0	0	0	0	0	1
09/08/2021 08:00	0.0	0	0	0	0	1
09/08/2021 09:00	0.0	0	0	0	0	1
09/08/2021 10:00	0.0	0	0	0	0	1
09/08/2021 11:00	0.0	0	0	0	0	1
09/08/2021 12:00	0.0	0	0	0	0	1
09/08/2021 13:00	0.0	0	0	0	0	1
09/08/2021 14:00	0.0	0	0	0	0	1
09/08/2021 15:00	0.0	0	0	0	0	1
09/08/2021 16:00	0.0	0	0	0	0	1
09/08/2021 17:00	0.0	0	0	0	0	1
09/08/2021 18:00	0.0	0	0	0	0	1
09/08/2021 19:00	0.0	0	0	0	0	1
09/08/2021 20:00	0.0	0	0	0	0	1
09/08/2021 21:00	0.0	0	0	0	0	1
09/08/2021 22:00	0.0	0	0	0	0	1
09/08/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/09/2021 00:00	0.0	0	0	0	0	1
09/09/2021 01:00	0.0	0	0	0	0	1
09/09/2021 02:00	0.0	0	0	0	0	1
09/09/2021 03:00	0.0	0	0	0	0	1
09/09/2021 04:00	0.0	0	0	0	0	1
09/09/2021 05:00	0.0	0	0	0	0	1
09/09/2021 06:00	0.0	0	0	0	0	1
09/09/2021 07:00	0.0	0	0	0	0	1
09/09/2021 08:00	0.0	0	0	0	0	1
09/09/2021 09:00	0.0	0	0	0	0	1
09/09/2021 10:00	0.0	0	0	0	0	1
09/09/2021 11:00	0.0	0	0	0	0	1
09/09/2021 12:00	0.0	0	0	0	0	1
09/09/2021 13:00	0.0	0	0	0	0	1
09/09/2021 14:00	0.0	0	0	0	0	1
09/09/2021 15:00	0.0	0	0	0	0	1
09/09/2021 16:00	0.0	0	0	0	0	1
09/09/2021 17:00	0.0	0	0	0	0	1
09/09/2021 18:00	0.0	0	0	0	0	1
09/09/2021 19:00	0.0	0	0	0	0	1
09/09/2021 20:00	0.0	0	0	0	0	1
09/09/2021 21:00	0.0	0	0	0	0	1
09/09/2021 22:00	0.0	0	0	0	0	1
09/09/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/10/2021 00:00	0.0	0	0	0	0	1
09/10/2021 01:00	0.0	0	0	0	0	1
09/10/2021 02:00	0.0	0	0	0	0	1
09/10/2021 03:00	0.0	0	0	0	0	1
09/10/2021 04:00	0.0	0	0	0	0	1
09/10/2021 05:00	0.0	0	0	0	0	1
09/10/2021 06:00	0.0	0	0	0	0	1
09/10/2021 07:00	0.0	0	0	0	0	1
09/10/2021 08:00	0.0	0	0	0	0	1
09/10/2021 09:00	0.0	0	0	0	0	1
09/10/2021 10:00	0.0	0	0	0	0	1
09/10/2021 11:00	0.0	0	0	0	0	1
09/10/2021 12:00	0.0	0	0	0	0	1
09/10/2021 13:00	0.0	0	0	0	0	1
09/10/2021 14:00	0.0	0	0	0	0	1
09/10/2021 15:00	0.0	0	0	0	0	1
09/10/2021 16:00	0.0	0	0	0	0	1
09/10/2021 17:00	0.0	0	0	0	0	1
09/10/2021 18:00	0.0	0	0	0	0	1
09/10/2021 19:00	0.0	0	0	0	0	1
09/10/2021 20:00	0.0	0	0	0	0	1
09/10/2021 21:00	0.0	0	0	0	0	1
09/10/2021 22:00	0.0	0	0	0	0	1
09/10/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/11/2021 00:00	0.0	0	0	0	0	1
09/11/2021 01:00	0.0	0	0	0	0	1
09/11/2021 02:00	0.0	0	0	0	0	1
09/11/2021 03:00	0.0	0	0	0	0	1
09/11/2021 04:00	0.0	0	0	0	0	1
09/11/2021 05:00	0.0	0	0	0	0	1
09/11/2021 06:00	0.0	0	0	0	0	1
09/11/2021 07:00	0.0	0	0	0	0	1
09/11/2021 08:00	0.0	0	0	0	0	1
09/11/2021 09:00	0.0	0	0	0	0	1
09/11/2021 10:00	0.0	0	0	0	0	1
09/11/2021 11:00	0.0	0	0	0	0	1
09/11/2021 12:00	0.0	0	0	0	0	1
09/11/2021 13:00	0.0	0	0	0	0	1
09/11/2021 14:00	0.0	0	0	0	0	1
09/11/2021 15:00	0.0	0	0	0	0	1
09/11/2021 16:00	0.0	0	0	0	0	1
09/11/2021 17:00	0.0	0	0	0	0	1
09/11/2021 18:00	0.0	0	0	0	0	1
09/11/2021 19:00	0.0	0	0	0	0	1
09/11/2021 20:00	0.0	0	0	0	0	1
09/11/2021 21:00	0.0	0	0	0	0	1
09/11/2021 22:00	0.0	0	0	0	0	1
09/11/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/12/2021 00:00	0.0	0	0	0	0	1
09/12/2021 01:00	0.0	0	0	0	0	1
09/12/2021 02:00	0.0	0	0	0	0	1
09/12/2021 03:00	0.0	0	0	0	0	1
09/12/2021 04:00	0.0	0	0	0	0	1
09/12/2021 05:00	0.0	0	0	0	0	1
09/12/2021 06:00	0.0	0	0	0	0	1
09/12/2021 07:00	0.0	0	0	0	0	1
09/12/2021 08:00	0.0	0	0	0	0	1
09/12/2021 09:00	0.0	0	0	0	0	1
09/12/2021 10:00	0.0	0	0	0	0	1
09/12/2021 11:00	0.0	0	0	0	0	1
09/12/2021 12:00	0.0	0	0	0	0	1
09/12/2021 13:00	0.0	0	0	0	0	1
09/12/2021 14:00	0.0	0	0	0	0	1
09/12/2021 15:00	0.0	0	0	0	0	1
09/12/2021 16:00	0.0	0	0	0	0	1
09/12/2021 17:00	0.0	0	0	0	0	1
09/12/2021 18:00	0.0	0	0	0	0	1
09/12/2021 19:00	0.0	0	0	0	0	1
09/12/2021 20:00	0.0	0	0	0	0	1
09/12/2021 21:00	0.0	0	0	0	0	1
09/12/2021 22:00	0.0	0	0	0	0	1
09/12/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/13/2021 00:00	0.0	0	0	0	0	1
09/13/2021 01:00	0.0	0	0	0	0	1
09/13/2021 02:00	0.0	0	0	0	0	1
09/13/2021 03:00	0.0	0	0	0	0	1
09/13/2021 04:00	0.0	0	0	0	0	1
09/13/2021 05:00	0.0	0	0	0	0	1
09/13/2021 06:00	0.0	0	0	0	0	1
09/13/2021 07:00	0.0	0	0	0	0	1
09/13/2021 08:00	0.0	0	0	0	0	1
09/13/2021 09:00	0.0	0	0	0	0	1
09/13/2021 10:00	0.0	0	0	0	0	1
09/13/2021 11:00	0.0	0	0	0	0	1
09/13/2021 12:00	0.0	0	0	0	0	1
09/13/2021 13:00	0.0	0	0	0	0	1
09/13/2021 14:00	0.0	0	0	0	0	1
09/13/2021 15:00	0.0	0	0	0	0	1
09/13/2021 16:00	0.0	0	0	0	0	1
09/13/2021 17:00	0.0	0	0	0	0	1
09/13/2021 18:00	0.0	0	0	0	0	1
09/13/2021 19:00	0.0	0	0	0	0	1
09/13/2021 20:00	0.0	0	0	0	0	1
09/13/2021 21:00	0.0	0	0	0	0	1
09/13/2021 22:00	0.0	0	0	0	0	1
09/13/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/14/2021 00:00	0.0	0	0	0	0	1
09/14/2021 01:00	0.0	0	0	0	0	1
09/14/2021 02:00	0.0	0	0	0	0	1
09/14/2021 03:00	0.0	0	0	0	0	1
09/14/2021 04:00	0.0	0	0	0	0	1
09/14/2021 05:00	0.0	0	0	0	0	1
09/14/2021 06:00	0.0	0	0	0	0	1
09/14/2021 07:00	0.0	0	0	0	0	1
09/14/2021 08:00	0.0	0	0	0	0	1
09/14/2021 09:00	0.0	0	0	0	0	1
09/14/2021 10:00	0.0	0	0	0	0	1
09/14/2021 11:00	0.0	0	0	0	0	1
09/14/2021 12:00	0.0	0	0	0	0	1
09/14/2021 13:00	0.0	0	0	0	0	1
09/14/2021 14:00	0.0	0	0	0	0	1
09/14/2021 15:00	0.0	0	0	0	0	1
09/14/2021 16:00	0.0	0	0	0	0	1
09/14/2021 17:00	0.0	0	0	0	0	1
09/14/2021 18:00	0.0	0	0	0	0	1
09/14/2021 19:00	0.0	0	0	0	0	1
09/14/2021 20:00	0.0	0	0	0	0	1
09/14/2021 21:00	0.0	0	0	0	0	1
09/14/2021 22:00	0.0	0	0	0	0	1
09/14/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/15/2021 00:00	0.0	0	0	0	0	1
09/15/2021 01:00	0.0	0	0	0	0	1
09/15/2021 02:00	0.0	0	0	0	0	1
09/15/2021 03:00	0.0	0	0	0	0	1
09/15/2021 04:00	0.0	0	0	0	0	1
09/15/2021 05:00	0.0	0	0	0	0	1
09/15/2021 06:00	0.0	0	0	0	0	1
09/15/2021 07:00	0.0	0	0	0	0	1
09/15/2021 08:00	0.0	0	0	0	0	1
09/15/2021 09:00	0.0	0	0	0	0	1
09/15/2021 10:00	0.0	0	0	0	0	1
09/15/2021 11:00	0.0	0	0	0	0	1
09/15/2021 12:00	0.0	0	0	0	0	1
09/15/2021 13:00	0.0	0	0	0	0	1
09/15/2021 14:00	0.0	0	0	0	0	1
09/15/2021 15:00	0.0	0	0	0	0	1
09/15/2021 16:00	0.0	0	0	0	0	1
09/15/2021 17:00	0.0	0	0	0	0	1
09/15/2021 18:00	0.0	0	0	0	0	1
09/15/2021 19:00	0.0	0	0	0	0	1
09/15/2021 20:00	0.0	0	0	0	0	1
09/15/2021 21:00	0.0	0	0	0	0	1
09/15/2021 22:00	0.0	0	0	0	0	1
09/15/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/04/2021 11:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/16/2021 00:00	0.0	0	0	0	0	1
09/16/2021 01:00	0.7	0	0	0	1	0
09/16/2021 02:00	0.0	0	0	0	0	0
09/16/2021 03:00	0.0	0	0	0	0	0
09/16/2021 04:00	0.0	0	0	0	0	0
09/16/2021 05:00	0.0	0	0	0	0	0
09/16/2021 06:00	0.0	0	0	0	0	0
09/16/2021 07:00	0.0	0	0	0	0	0
09/16/2021 08:00	0.0	0	0	0	0	0
09/16/2021 09:00	0.0	0	0	0	0	0
09/16/2021 10:00	0.0	0	0	0	0	0
09/16/2021 11:00	0.0	0	0	0	0	0
09/16/2021 12:00	1.9	0	1	0	0	0
09/16/2021 13:00	55.2	0	1	0	0	0
09/16/2021 14:00	0.0	0	0	0	0	1
09/16/2021 15:00	0.0	0	0	0	0	1
09/16/2021 16:00	0.0	0	0	0	0	1
09/16/2021 17:00	0.0	0	0	0	0	1
09/16/2021 18:00	0.0	0	0	0	0	1
09/16/2021 19:00	0.0	0	0	0	0	1
09/16/2021 20:00	0.0	0	0	0	0	1
09/16/2021 21:00	0.0	0	0	0	0	1
09/16/2021 22:00	0.0	0	0	0	0	1
09/16/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	57.8 #	0 #	2 #	0 #	1 #	11 #
Minimum:	0.0	0	0	0	0	0
Maximum:	55.2	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/17/2021 00:00	0.0	0	0	0	0	1
09/17/2021 01:00	0.0	0	0	0	0	1
09/17/2021 02:00	0.6	0	0	0	1	0
09/17/2021 03:00	0.0	0	0	0	0	0
09/17/2021 04:00	0.0	0	0	0	0	0
09/17/2021 05:00	0.0	0	0	0	0	0
09/17/2021 06:00	0.0	0	0	0	0	0
09/17/2021 07:00	0.0	0	0	0	0	0
09/17/2021 08:00	0.0	0	0	0	0	0
09/17/2021 09:00	0.0	0	0	0	0	0
09/17/2021 10:00	0.0	0	0	0	0	0
09/17/2021 11:00	0.0	0	0	0	0	0
09/17/2021 12:00	0.0	0	0	0	0	0
09/17/2021 13:00	17.3	0	1	0	0	0
09/17/2021 14:00	34.0	0	1	0	0	0
09/17/2021 15:00	0.0	0	0	0	0	1
09/17/2021 16:00	0.0	0	0	0	0	1
09/17/2021 17:00	0.0	0	0	0	0	1
09/17/2021 18:00	0.0	0	0	0	0	1
09/17/2021 19:00	0.0	0	0	0	0	1
09/17/2021 20:00	0.0	0	0	0	0	1
09/17/2021 21:00	0.0	0	0	0	0	1
09/17/2021 22:00	0.0	0	0	0	0	1
09/17/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	51.9 #	0 #	2 #	0 #	1 #	11 #
Minimum:	0.0	0	0	0	0	0
Maximum:	34.0	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/18/2021 00:00	0.4	0	0	0	1	0
09/18/2021 01:00	0.0	0	0	0	0	0
09/18/2021 02:00	0.0	0	0	0	0	0
09/18/2021 03:00	0.0	0	0	0	0	0
09/18/2021 04:00	0.0	0	0	0	0	0
09/18/2021 05:00	0.0	0	0	0	0	0
09/18/2021 06:00	0.0	0	0	0	0	0
09/18/2021 07:00	0.0	0	0	0	0	0
09/18/2021 08:00	0.0	0	0	0	0	0
09/18/2021 09:00	0.0	0	0	0	0	0
09/18/2021 10:00	0.0	0	0	0	0	0
09/18/2021 11:00	0.0	0	0	0	0	0
09/18/2021 12:00	0.0	0	0	0	0	0
09/18/2021 13:00	0.0	0	0	0	0	0
09/18/2021 14:00	0.0	0	0	0	0	0
09/18/2021 15:00	0.0	0	0	0	0	0
09/18/2021 16:00	0.0	0	0	0	0	0
09/18/2021 17:00	0.0	0	0	0	0	0
09/18/2021 18:00	0.0	0	0	0	0	0
09/18/2021 19:00	0.0	0	0	0	0	0
09/18/2021 20:00	0.0	0	0	0	0	0
09/18/2021 21:00	0.0	0	0	0	0	0
09/18/2021 22:00	0.0	0	0	0	0	0
09/18/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.4 #	0 #	0 #	0 #	1 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.4	0	0	0	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/19/2021 00:00	0.0	0	0	0	0	0
09/19/2021 01:00	0.0	0	0	0	0	0
09/19/2021 02:00	0.0	0	0	0	0	0
09/19/2021 03:00	0.0	0	0	0	0	0
09/19/2021 04:00	0.0	0	0	0	0	0
09/19/2021 05:00	0.0	0	0	0	0	0
09/19/2021 06:00	0.0	0	0	0	0	0
09/19/2021 07:00	0.0	0	0	0	0	0
09/19/2021 08:00	0.0	0	0	0	0	0
09/19/2021 09:00	0.0	0	0	0	0	0
09/19/2021 10:00	0.0	0	0	0	0	0
09/19/2021 11:00	0.0	0	0	0	0	0
09/19/2021 12:00	0.0	0	0	0	0	0
09/19/2021 13:00	0.0	0	0	0	0	0
09/19/2021 14:00	0.0	0	0	0	0	0
09/19/2021 15:00	0.0	0	0	0	0	0
09/19/2021 16:00	0.0	0	0	0	0	0
09/19/2021 17:00	0.0	0	0	0	0	0
09/19/2021 18:00	0.0	0	0	0	0	0
09/19/2021 19:00	0.0	0	0	0	0	0
09/19/2021 20:00	0.0	0	0	0	0	0
09/19/2021 21:00	0.0	0	0	0	0	0
09/19/2021 22:00	0.0	0	0	0	0	0
09/19/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/20/2021 00:00	0.0	0	0	0	0	0
09/20/2021 01:00	10.8	0	1	0	0	0
09/20/2021 02:00	63.7	0	1	0	0	0
09/20/2021 03:00	1.5	0	1	0	0	0
09/20/2021 04:00	0.0	0	0	0	0	1
09/20/2021 05:00	0.0	0	0	0	0	1
09/20/2021 06:00	0.0	0	0	0	0	1
09/20/2021 07:00	0.0	0	0	0	0	1
09/20/2021 08:00	0.0	0	0	0	0	1
09/20/2021 09:00	0.0	0	0	0	0	1
09/20/2021 10:00	0.0	0	0	0	0	1
09/20/2021 11:00	0.0	0	0	0	0	1
09/20/2021 12:00	0.0	0	0	0	0	1
09/20/2021 13:00	0.0	0	0	0	0	1
09/20/2021 14:00	0.0	0	0	0	0	1
09/20/2021 15:00	0.0	0	0	0	0	1
09/20/2021 16:00	0.0	0	0	0	0	1
09/20/2021 17:00	0.0	0	0	0	0	1
09/20/2021 18:00	0.0	0	0	0	0	1
09/20/2021 19:00	0.0	0	0	0	0	1
09/20/2021 20:00	0.0	0	0	0	0	1
09/20/2021 21:00	0.0	0	0	0	0	1
09/20/2021 22:00	0.0	0	0	0	0	1
09/20/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	76.0 #	0 #	3 #	0 #	0 #	20 #
Minimum:	0.0	0	0	0	0	0
Maximum:	63.7	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/21/2021 00:00	0.0	0	0	0	0	1
09/21/2021 01:00	0.0	0	0	0	0	1
09/21/2021 02:00	0.0	0	0	0	0	1
09/21/2021 03:00	0.0	0	0	0	0	1
09/21/2021 04:00	0.0	0	0	0	0	1
09/21/2021 05:00	0.0	0	0	0	0	1
09/21/2021 06:00	0.0	0	0	0	0	1
09/21/2021 07:00	0.0	0	0	0	0	1
09/21/2021 08:00	0.0	0	0	0	0	1
09/21/2021 09:00	0.0	0	0	0	0	1
09/21/2021 10:00	0.0	0	0	0	0	1
09/21/2021 11:00	0.0	0	0	0	0	1
09/21/2021 12:00	0.0	0	0	0	0	1
09/21/2021 13:00	0.0	0	0	0	0	1
09/21/2021 14:00	0.0	0	0	0	0	1
09/21/2021 15:00	0.0	0	0	0	0	1
09/21/2021 16:00	0.0	0	0	0	0	1
09/21/2021 17:00	0.0	0	0	0	0	1
09/21/2021 18:00	0.0	0	0	0	0	1
09/21/2021 19:00	0.0	0	0	0	0	1
09/21/2021 20:00	0.0	0	0	0	0	1
09/21/2021 21:00	0.0	0	0	0	0	1
09/21/2021 22:00	0.0	0	0	0	0	1
09/21/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/22/2021 00:00	0.0	0	0	0	0	1
09/22/2021 01:00	0.0	0	0	0	0	1
09/22/2021 02:00	0.0	0	0	0	0	1
09/22/2021 03:00	0.0	0	0	0	0	1
09/22/2021 04:00	0.0	0	0	0	0	1
09/22/2021 05:00	0.0	0	0	0	0	1
09/22/2021 06:00	0.0	0	0	0	0	1
09/22/2021 07:00	0.0	0	0	0	0	1
09/22/2021 08:00	0.0	0	0	0	0	1
09/22/2021 09:00	0.0	0	0	0	0	1
09/22/2021 10:00	0.0	0	0	0	0	1
09/22/2021 11:00	0.0	0	0	0	0	1
09/22/2021 12:00	0.0	0	0	0	0	1
09/22/2021 13:00	0.0	0	0	0	0	1
09/22/2021 14:00	0.0	0	0	0	0	1
09/22/2021 15:00	0.0	0	0	0	0	1
09/22/2021 16:00	0.0	0	0	0	0	1
09/22/2021 17:00	0.0	0	0	0	0	1
09/22/2021 18:00	0.0	0	0	0	0	1
09/22/2021 19:00	0.0	0	0	0	0	1
09/22/2021 20:00	0.0	0	0	0	0	1
09/22/2021 21:00	0.0	0	0	0	0	1
09/22/2021 22:00	0.0	0	0	0	0	1
09/22/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/23/2021 00:00	0.0	0	0	0	0	1
09/23/2021 01:00	0.0	0	0	0	0	1
09/23/2021 02:00	0.0	0	0	0	0	1
09/23/2021 03:00	0.0	0	0	0	0	1
09/23/2021 04:00	0.0	0	0	0	0	1
09/23/2021 05:00	0.0	0	0	0	0	1
09/23/2021 06:00	0.0	0	0	0	0	1
09/23/2021 07:00	0.0	0	0	0	0	1
09/23/2021 08:00	0.0	0	0	0	0	1
09/23/2021 09:00	0.0	0	0	0	0	1
09/23/2021 10:00	0.0	0	0	0	0	1
09/23/2021 11:00	0.0	0	0	0	0	1
09/23/2021 12:00	0.0	0	0	0	0	1
09/23/2021 13:00	0.0	0	0	0	0	1
09/23/2021 14:00	0.0	0	0	0	0	1
09/23/2021 15:00	0.0	0	0	0	0	1
09/23/2021 16:00	0.0	0	0	0	0	1
09/23/2021 17:00	0.0	0	0	0	0	1
09/23/2021 18:00	0.0	0	0	0	0	1
09/23/2021 19:00	0.0	0	0	0	0	1
09/23/2021 20:00	0.0	0	0	0	0	1
09/23/2021 21:00	0.0	0	0	0	0	1
09/23/2021 22:00	0.0	0	0	0	0	1
09/23/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/24/2021 00:00	0.0	0	0	0	0	1
09/24/2021 01:00	0.0	0	0	0	0	1
09/24/2021 02:00	0.0	0	0	0	0	1
09/24/2021 03:00	0.0	0	0	0	0	1
09/24/2021 04:00	0.0	0	0	0	0	1
09/24/2021 05:00	0.0	0	0	0	0	1
09/24/2021 06:00	0.0	0	0	0	0	1
09/24/2021 07:00	0.0	0	0	0	0	1
09/24/2021 08:00	0.0	0	0	0	0	1
09/24/2021 09:00	0.0	0	0	0	0	1
09/24/2021 10:00	0.0	0	0	0	0	1
09/24/2021 11:00	0.0	0	0	0	0	1
09/24/2021 12:00	0.0	0	0	0	0	1
09/24/2021 13:00	0.0	0	0	0	0	1
09/24/2021 14:00	0.0	0	0	0	0	1
09/24/2021 15:00	0.0	0	0	0	0	1
09/24/2021 16:00	0.0	0	0	0	0	1
09/24/2021 17:00	0.0	0	0	0	0	1
09/24/2021 18:00	0.0	0	0	0	0	1
09/24/2021 19:00	0.0	0	0	0	0	1
09/24/2021 20:00	0.0	0	0	0	0	1
09/24/2021 21:00	0.0	0	0	0	0	1
09/24/2021 22:00	0.0	0	0	0	0	1
09/24/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/25/2021 00:00	0.0	0	0	0	0	1
09/25/2021 01:00	0.0	0	0	0	0	1
09/25/2021 02:00	0.0	0	0	0	0	1
09/25/2021 03:00	0.0	0	0	0	0	1
09/25/2021 04:00	0.0	0	0	0	0	1
09/25/2021 05:00	0.0	0	0	0	0	1
09/25/2021 06:00	0.0	0	0	0	0	1
09/25/2021 07:00	0.0	0	0	0	0	1
09/25/2021 08:00	0.0	0	0	0	0	1
09/25/2021 09:00	0.0	0	0	0	0	1
09/25/2021 10:00	0.0	0	0	0	0	1
09/25/2021 11:00	0.0	0	0	0	0	1
09/25/2021 12:00	0.0	0	0	0	0	1
09/25/2021 13:00	0.0	0	0	0	0	1
09/25/2021 14:00	0.0	0	0	0	0	1
09/25/2021 15:00	0.0	0	0	0	0	1
09/25/2021 16:00	0.0	0	0	0	0	1
09/25/2021 17:00	0.0	0	0	0	0	1
09/25/2021 18:00	0.0	0	0	0	0	1
09/25/2021 19:00	0.0	0	0	0	0	1
09/25/2021 20:00	0.0	0	0	0	0	1
09/25/2021 21:00	0.0	0	0	0	0	1
09/25/2021 22:00	0.0	0	0	0	0	1
09/25/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/26/2021 00:00	0.0	0	0	0	0	1
09/26/2021 01:00	0.0	0	0	0	0	1
09/26/2021 02:00	0.0	0	0	0	0	1
09/26/2021 03:00	0.0	0	0	0	0	1
09/26/2021 04:00	0.0	0	0	0	0	1
09/26/2021 05:00	0.0	0	0	0	0	1
09/26/2021 06:00	0.0	0	0	0	0	1
09/26/2021 07:00	0.0	0	0	0	0	1
09/26/2021 08:00	0.0	0	0	0	0	1
09/26/2021 09:00	0.0	0	0	0	0	1
09/26/2021 10:00	0.0	0	0	0	0	1
09/26/2021 11:00	0.0	0	0	0	0	1
09/26/2021 12:00	0.0	0	0	0	0	1
09/26/2021 13:00	0.0	0	0	0	0	1
09/26/2021 14:00	0.0	0	0	0	0	1
09/26/2021 15:00	0.0	0	0	0	0	1
09/26/2021 16:00	0.0	0	0	0	0	1
09/26/2021 17:00	0.0	0	0	0	0	1
09/26/2021 18:00	0.0	0	0	0	0	1
09/26/2021 19:00	0.0	0	0	0	0	1
09/26/2021 20:00	0.0	0	0	0	0	1
09/26/2021 21:00	0.0	0	0	0	0	1
09/26/2021 22:00	0.0	0	0	0	0	1
09/26/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/27/2021 00:00	0.0	0	0	0	0	1
09/27/2021 01:00	0.0	0	0	0	0	1
09/27/2021 02:00	0.0	0	0	0	0	1
09/27/2021 03:00	0.0	0	0	0	0	1
09/27/2021 04:00	0.0	0	0	0	0	1
09/27/2021 05:00	0.0	0	0	0	0	1
09/27/2021 06:00	0.0	0	0	0	0	1
09/27/2021 07:00	0.0	0	0	0	0	1
09/27/2021 08:00	0.0	0	0	0	0	1
09/27/2021 09:00	0.0	0	0	0	0	1
09/27/2021 10:00	0.0	0	0	0	0	1
09/27/2021 11:00	0.0	0	0	0	0	1
09/27/2021 12:00	0.0	0	0	0	0	1
09/27/2021 13:00	0.0	0	0	0	0	1
09/27/2021 14:00	0.0	0	0	0	0	1
09/27/2021 15:00	0.0	0	0	0	0	1
09/27/2021 16:00	0.0	0	0	0	0	1
09/27/2021 17:00	0.0	0	0	0	0	1
09/27/2021 18:00	0.0	0	0	0	0	1
09/27/2021 19:00	0.0	0	0	0	0	1
09/27/2021 20:00	0.0	0	0	0	0	1
09/27/2021 21:00	0.0	0	0	0	0	1
09/27/2021 22:00	0.0	0	0	0	0	1
09/27/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/28/2021 00:00	0.0	0	0	0	0	1
09/28/2021 01:00	0.0	0	0	0	0	1
09/28/2021 02:00	0.0	0	0	0	0	1
09/28/2021 03:00	0.0	0	0	0	0	1
09/28/2021 04:00	0.0	0	0	0	0	1
09/28/2021 05:00	0.0	0	0	0	0	1
09/28/2021 06:00	0.0	0	0	0	0	1
09/28/2021 07:00	0.0	0	0	0	0	1
09/28/2021 08:00	0.0	0	0	0	0	1
09/28/2021 09:00	0.0	0	0	0	0	1
09/28/2021 10:00	0.0	0	0	0	0	1
09/28/2021 11:00	0.0	0	0	0	0	1
09/28/2021 12:00	0.0	0	0	0	0	1
09/28/2021 13:00	0.0	0	0	0	0	1
09/28/2021 14:00	0.0	0	0	0	0	1
09/28/2021 15:00	0.0	0	0	0	0	1
09/28/2021 16:00	0.0	0	0	0	0	1
09/28/2021 17:00	0.0	0	0	0	0	1
09/28/2021 18:00	0.0	0	0	0	0	1
09/28/2021 19:00	0.0	0	0	0	0	1
09/28/2021 20:00	0.0	0	0	0	0	1
09/28/2021 21:00	0.0	0	0	0	0	1
09/28/2021 22:00	0.0	0	0	0	0	1
09/28/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/29/2021 00:00	0.0	0	0	0	0	1
09/29/2021 01:00	0.0	0	0	0	0	1
09/29/2021 02:00	0.0	0	0	0	0	1
09/29/2021 03:00	0.0	0	0	0	0	1
09/29/2021 04:00	0.0	0	0	0	0	1
09/29/2021 05:00	0.0	0	0	0	0	1
09/29/2021 06:00	0.0	0	0	0	0	1
09/29/2021 07:00	0.0	0	0	0	0	1
09/29/2021 08:00	0.0	0	0	0	0	1
09/29/2021 09:00	0.0	0	0	0	0	1
09/29/2021 10:00	0.0	0	0	0	0	1
09/29/2021 11:00	0.0	0	0	0	0	1
09/29/2021 12:00	0.0	0	0	0	0	1
09/29/2021 13:00	0.0	0	0	0	0	1
09/29/2021 14:00	0.0	0	0	0	0	1
09/29/2021 15:00	0.0	0	0	0	0	1
09/29/2021 16:00	0.0	0	0	0	0	1
09/29/2021 17:00	0.0	0	0	0	0	1
09/29/2021 18:00	0.0	0	0	0	0	1
09/29/2021 19:00	0.0	0	0	0	0	1
09/29/2021 20:00	0.0	0	0	0	0	1
09/29/2021 21:00	0.0	0	0	0	0	1
09/29/2021 22:00	0.0	0	0	0	0	1
09/29/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/30/2021 00:00	0.0	0	0	0	0	1
09/30/2021 01:00	0.0	0	0	0	0	1
09/30/2021 02:00	0.0	0	0	0	0	1
09/30/2021 03:00	0.0	0	0	0	0	1
09/30/2021 04:00	0.0	0	0	0	0	1
09/30/2021 05:00	0.0	0	0	0	0	1
09/30/2021 06:00	1.2	0	0	0	1	0
09/30/2021 07:00	0.0	0	0	0	0	0
09/30/2021 08:00	0.0	0	0	0	0	0
09/30/2021 09:00	0.0	0	0	0	0	0
09/30/2021 10:00	0.0	0	0	0	0	0
09/30/2021 11:00	0.0	0	0	0	0	0
09/30/2021 12:00	0.0	0	0	0	0	0
09/30/2021 13:00	0.0	0	0	0	0	0
09/30/2021 14:00	0.0	0	0	0	0	0
09/30/2021 15:00	0.0	0	0	0	0	0
09/30/2021 16:00	0.0	0	0	0	0	0
09/30/2021 17:00	0.0	0	0	0	0	0
09/30/2021 18:00	0.0	0	0	0	0	0
09/30/2021 19:00	0.0	0	0	0	0	0
09/30/2021 20:00	0.0	0	0	0	0	0
09/30/2021 21:00	0.0	0	0	0	0	0
09/30/2021 22:00	0.0	0	0	0	0	0
09/30/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	1.2 #	0 #	0 #	0 #	1 #	6 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.2	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Pound Per Event Report

CT2 - CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:12 **Location:** Maxwell, CA

Tag Name: CT2_CO_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,765.08 Hours

Non-Operating Time: 442.92 Hours Report Time: 2,208.00 Hours

Unit Operation and Excess Events

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
07/10/2021 16:39 07/10/2021 17:21 Cold Start - Gas	43	38.0	1,355.6		
07/10/2021 17:22 07/10/2021 17:27 Shut Down - Gas	6	0.2	483.5		
07/12/2021 07:18 07/12/2021 09:56 Warm Start - Gas	159	0.0 SI	790.5		
07/13/2021 02:20 07/13/2021 02:25 Shut Down - Gas	6	0.7	483.5		
07/13/2021 17:22 07/13/2021 18:38 Warm Start - Gas	77	132.1	790.5		
08/03/2021 04:40 08/03/2021 04:40 Shut Down - Gas	1	0.0	483.5		
08/03/2021 11:10 08/03/2021 12:05 Hot Start - Gas	56	78.3	679.6		
08/07/2021 03:23 08/07/2021 03:28 Shut Down - Gas	6	1.0	483.5		
08/07/2021 09:47 08/07/2021 11:15 Hot Start - Gas	89	118.1	679.6		
08/07/2021 11:21 08/07/2021 11:26 Shut Down - Gas	6	1.6	483.5		
08/07/2021 12:04 08/07/2021 12:54 Hot Start - Gas	51	65.4	679.6		
08/21/2021 00:08 08/21/2021 00:13 Shut Down - Gas	6	1.2	483.5		
08/21/2021 01:37 08/21/2021 02:21 Hot Start - Gas	45	43.7	679.6		

Pound Per Event Report

CT2 - CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:12 **Location:** Maxwell, CA

Tag Name: CT2_CO_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,765.08 Hours

Non-Operating Time: 442.92 Hours Report Time: 2,208.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
08/21/2021 15:41 08/21/2021 15:46 Shut Down - Gas	6	0.3	483.5		
08/23/2021 09:18 08/23/2021 11:56 Warm Start - Gas	159	182.5	790.5		
08/23/2021 12:30 08/23/2021 12:35 Shut Down - Gas	6	0.3	483.5		
08/23/2021 13:25 08/23/2021 14:25 Hot Start - Gas	61	84.3	679.6		
09/04/2021 03:25 09/04/2021 03:29 Shut Down - Gas	5	0.2	483.5		
09/04/2021 13:33 09/04/2021 14:28 Warm Start - Gas	56	47.6	790.5		
09/16/2021 01:21 09/16/2021 01:26 Shut Down - Gas	6	1.1	483.5		
09/16/2021 12:48 09/16/2021 13:51 Warm Start - Gas	64	48.7	790.5		
09/17/2021 02:04 09/17/2021 02:09 Shut Down - Gas	6	0.8	483.5		
09/17/2021 13:36 09/17/2021 14:50 Warm Start - Gas	75	49.4	790.5		
09/18/2021 00:04 09/18/2021 00:08 Shut Down - Gas	5	0.5	483.5		
09/20/2021 01:42 09/20/2021 03:08 Warm Start - Gas	87	76.7	790.5		
09/30/2021 06:05 09/30/2021 06:10 Shut Down - Gas	6	0.4	483.5		

No excess emissions were found in the reporting period.

Pound Per Event Report

CT2 - CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:12 **Location:** Maxwell, CA

Tag Name: CT2_CO_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,765.08 Hours

Non-Operating Time: 442.92 Hours Report Time: 2,208.00 Hours

Event Invalid Information

Invalid Event Period		Reason	Action
Begin/End	Duration in Minute(s)	Code - Description	Code - Description
07/12/2021 07:18 07/12/2021 09:56	159		

Total CMS Downtime	**159**	**Minute(s)**
Total Downtime as a percentage of operating time	**0.15**	**%**
Total Availability as a percentage of operating time	**99.85**	**%**

Pound Per Event Report

CT2 - CO Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:12 **Location:** Maxwell, CA

Tag Name: CT2_CO_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,765.08 Hours

Non-Operating Time: 442.92 Hours Report Time: 2,208.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary	
1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	159
2. Total CMS Downtime in Minute(s)	159
3. Total Downtime as a percentage of operating time	0.15
4. Total Availability as a percentage of operating time	99.85

Pound Per Event Report

CT2 - NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/04/2021 11:13 **Location:** Maxwell, CA
Tag Name: CT2_NOx_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission
Total Operating Time: 1,765.25 Hours
Non-Operating Time: 442.75 Hours Report Time: 2,208.00 Hours

Unit Operation and Excess Events

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
07/10/2021 16:39 07/10/2021 17:21 Cold Start - Gas	43	25.52	779.10		
07/10/2021 17:22 07/10/2021 17:27 Shut Down - Gas	6	0.52	115.00		
07/12/2021 07:18 07/12/2021 09:56 Warm Start - Gas	159	0.00 SI	456.20		
07/13/2021 02:20 07/13/2021 02:25 Shut Down - Gas	6	0.08	115.00		
07/13/2021 17:22 07/13/2021 18:38 Warm Start - Gas	77	64.79	456.20		
08/03/2021 04:40 08/03/2021 04:40 Shut Down - Gas	1	0.07	115.00		
08/03/2021 11:10 08/03/2021 12:05 Hot Start - Gas	56	46.34	259.90		
08/07/2021 03:23 08/07/2021 03:28 Shut Down - Gas	6	0.25	115.00		
08/07/2021 09:47 08/07/2021 11:15 Hot Start - Gas	89	38.18	259.90		
08/07/2021 11:21 08/07/2021 11:26 Shut Down - Gas	6	0.12	115.00		
08/07/2021 12:04 08/07/2021 12:54 Hot Start - Gas	51	19.63	259.90		
08/21/2021 00:08 08/21/2021 00:13 Shut Down - Gas	6	0.24	115.00		
08/21/2021 01:37 08/21/2021 02:21 Hot Start - Gas	45	7.52	259.90		

Pound Per Event Report

CT2 - NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/04/2021 11:13 **Location:** Maxwell, CA
Tag Name: CT2_NOx_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission
Total Operating Time: 1,765.25 Hours
Non-Operating Time: 442.75 Hours Report Time: 2,208.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
08/21/2021 15:41 08/21/2021 15:46 Shut Down - Gas	6	0.05	115.00		
08/23/2021 09:18 08/23/2021 11:56 Warm Start - Gas	159	98.98	456.20		
08/23/2021 12:30 08/23/2021 12:35 Shut Down - Gas	6	0.03	115.00		
08/23/2021 13:25 08/23/2021 14:25 Hot Start - Gas	61	30.61	259.90		
09/04/2021 03:25 09/04/2021 03:29 Shut Down - Gas	5	0.03	115.00		
09/04/2021 13:33 09/04/2021 14:28 Warm Start - Gas	56	54.10	456.20		
09/16/2021 01:21 09/16/2021 01:26 Shut Down - Gas	6	0.24	115.00		
09/16/2021 12:48 09/16/2021 13:51 Warm Start - Gas	64	54.91	456.20		
09/17/2021 02:04 09/17/2021 02:09 Shut Down - Gas	6	0.11	115.00		
09/17/2021 13:36 09/17/2021 14:50 Warm Start - Gas	75	53.55	456.20		
09/18/2021 00:04 09/18/2021 00:08 Shut Down - Gas	5	0.07	115.00		
09/20/2021 01:42 09/20/2021 03:08 Warm Start - Gas	87	79.49	456.20		
09/30/2021 06:05 09/30/2021 06:10 Shut Down - Gas	6	0.13	115.00		

No excess emissions were found in the reporting period.

Pound Per Event Report

CT2 - NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:13 **Location:** Maxwell, CA

Tag Name: CT2_NOx_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,765.25 Hours

Non-Operating Time: 442.75 Hours Report Time: 2,208.00 Hours

Event Invalid Information

Invalid Event Period		Reason	Action
Begin/End	Duration in Minute(s)	Code - Description	Code - Description
07/12/2021 07:18 07/12/2021 09:56	159		

Total CMS Downtime	**159**	**Minute(s)**
Total Downtime as a percentage of operating time	**0.15**	**%**
Total Availability as a percentage of operating time	**99.85**	**%**

Pound Per Event Report

CT2 - NOx Lbs

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/04/2021 11:13 **Location:** Maxwell, CA

Tag Name: CT2_NOx_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,765.25 Hours

Non-Operating Time: 442.75 Hours Report Time: 2,208.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary	
1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	159
2. Total CMS Downtime in Minute(s)	159
3. Total Downtime as a percentage of operating time	0.15
4. Total Availability as a percentage of operating time	99.85

CT1 Process Event Report

CT1 Cold and Hot Startup Events

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/04/2021 11:13 **Location:** Maxwell, CA

Unit Offline

Tag Name: CT1_UnitOn_TF_1H

Offline Periods		
Start Time	**End Time**	**Duration in Hour(s)**
07/01/2021 00:00	07/10/2021 12:00	229
07/11/2021 00:00	07/11/2021 08:00	9
07/12/2021 02:00	07/12/2021 14:00	13
07/12/2021 23:00	07/13/2021 06:00	8
07/13/2021 10:00	07/13/2021 11:00	2
07/13/2021 22:00	07/14/2021 02:00	5
08/07/2021 04:00	08/07/2021 12:00	9
08/08/2021 05:00	08/08/2021 13:00	9
08/21/2021 01:00	08/23/2021 15:00	63
09/04/2021 04:00	09/04/2021 08:00	5
09/25/2021 23:00	09/29/2021 02:00	76
09/29/2021 04:00	09/29/2021 07:00	4

CT1 Process Event Report

CT1 Cold and Hot Startup Events

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/04/2021 11:13 **Location:** Maxwell, CA

Operating Time Summary	
Available Data for Report (excludes missing data):	2,208.00 Hour(s)
Total Offline:	432.00 Hour(s)
Offline Percentage:	19.57 %
Total Online:	1,776.00 Hour(s)
Online Percentage:	80.43 %

CT1 Process Event Report

CT1 Cold and Hot Startup Events

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/04/2021 11:13 **Location:** Maxwell, CA

Startup/Shutdown

Number	Start Time	End Time	Event Type	Duration
1	07/10/2021 13:00	07/10/2021 16:00	Cold Startup	4
2	07/11/2021 09:00	07/11/2021 11:00	Warm Startup	3
3	07/12/2021 15:00	07/12/2021 16:00	Warm Startup	2
4	07/13/2021 07:00	07/13/2021 09:00	Warm Startup	3
5	07/13/2021 12:00	07/13/2021 16:00	Warm Startup	5
6	07/14/2021 03:00	07/14/2021 04:00	Hot Startup	2
7	08/07/2021 13:00	08/07/2021 14:00	Warm Startup	2
8	08/08/2021 14:00	08/08/2021 15:00	Warm Startup	2
9	08/23/2021 16:00	08/23/2021 17:00	Warm Startup	2
10	09/04/2021 09:00	09/04/2021 10:00	Hot Startup	2
11	09/29/2021 03:00	09/29/2021 03:00	Cold Startup	1
12	09/29/2021 08:00	09/29/2021 09:00	Cold Startup	2

CT1 Process Event Report

CT1 Cold and Hot Startup Events

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/04/2021 11:13 **Location:** Maxwell, CA

Startup/Shutdown Event Summary

	# Events	Duration	Duration %
Cold Startup	3	7	0.39
Hot Startup/Startup Shutdown Event Text 02 Add	2	4	0.23
Warm Startup	7	19	1.07
Total Process Events:	12	30	1.69

Total Report Time:	2,208 Hour(s)
Total Operating Time:	1,776 Hour(s)
Total Startup Time:	30 Hour(s)
Total Shutdown Time:	0 Hour(s)
Total Startup/Shutdown Time:	30 Hour(s)
Total Startup/Shutdown Time as a Percentage of Total Operating Time:	1.69 %

CT2 Process Event Report

CT2 Cold and Hot Startup Events

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/04/2021 11:14 **Location:** Maxwell, CA

Unit Offline

Tag Name: CT2_UnitOn_TF_1H

Offline Periods		
Start Time	**End Time**	**Duration in Hour(s)**
07/01/2021 00:00	07/10/2021 15:00	232
07/10/2021 18:00	07/12/2021 06:00	37
07/13/2021 03:00	07/13/2021 16:00	14
08/03/2021 05:00	08/03/2021 10:00	6
08/07/2021 04:00	08/07/2021 08:00	5
08/21/2021 16:00	08/23/2021 08:00	41
09/04/2021 04:00	09/04/2021 12:00	9
09/16/2021 02:00	09/16/2021 11:00	10
09/17/2021 03:00	09/17/2021 12:00	10
09/18/2021 01:00	09/20/2021 00:00	48
09/30/2021 07:00	09/30/2021 23:00	17

CT2 Process Event Report

CT2 Cold and Hot Startup Events

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/04/2021 11:14 **Location:** Maxwell, CA

Operating Time Summary	
Available Data for Report (excludes missing data):	2,208.00 Hour(s)
Total Offline:	429.00 Hour(s)
Offline Percentage:	19.43 %
Total Online:	1,779.00 Hour(s)
Online Percentage:	80.57 %

CT2 Process Event Report

CT2 Cold and Hot Startup Events

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/04/2021 11:14 **Location:** Maxwell, CA

Startup/Shutdown

Number	Start Time	End Time	Event Type	Duration
1	07/10/2021 16:00	07/10/2021 17:00	Cold Startup	2
2	07/12/2021 07:00	07/12/2021 09:00	Warm startup	3
3	07/13/2021 17:00	07/13/2021 18:00	Warm startup	2
4	08/03/2021 11:00	08/03/2021 12:00	Hot Startup	2
5	08/07/2021 09:00	08/07/2021 12:00	Hot Startup	4
6	08/21/2021 01:00	08/21/2021 02:00	Hot Startup	2
7	08/23/2021 09:00	08/23/2021 11:00	Warm startup	3
8	08/23/2021 13:00	08/23/2021 14:00	Hot Startup	2
9	09/04/2021 13:00	09/04/2021 14:00	Warm startup	2
10	09/16/2021 12:00	09/16/2021 13:00	Warm startup	2
11	09/17/2021 13:00	09/17/2021 14:00	Warm startup	2
12	09/20/2021 01:00	09/20/2021 03:00	Warm startup	3

CT2 Process Event Report

CT2 Cold and Hot Startup Events

From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/04/2021 11:14 **Location:** Maxwell, CA

Startup/Shutdown Event Summary

	# Events	Duration	Duration %
Cold Startup	1	2	0.11
Hot Startup	4	10	0.56
Warm startup	7	17	0.96
Total Process Events:	12	29	1.63

Total Report Time:	2,208 Hour(s)
Total Operating Time:	1,779 Hour(s)
Total Startup Time:	29 Hour(s)
Total Shutdown Time:	0 Hour(s)
Total Startup/Shutdown Time:	29 Hour(s)
Total Startup/Shutdown Time as a Percentage of Total Operating Time:	1.63 %

ATTACHMENT 13
Water Bath Heater Operations
FCD: AQ-17
Title V: #6

The Natural Gas Fired Water Bath Heater
did not operate in the 3rd Quarter of 2021.

ATTACHMENT 14
Certification Report

FCD: AQ-22
Title V: #13

CERTIFICATION REPORT
(FORM 3.17-K1)

DISTRICT:	▸ DISTRICT USE ONLY ◂
Colusa County Air Pollution Control District	DISTRICT ID:
COMPANY NAME: Pacific Gas and Electric	FACILITY NAME: Colusa Generating Station

I. FACILITY INFORMATION

1. Company Name: Pacif ic Gas and Electric
2. Facility Name (if different than Company Name): Colusa Generating Station
3. Mailing Address: 4780 Dirks Rd , Maxwell CA 95955
4. Street Address or Source Location: Same
5. Facility Permit Number: 21006-0259

II. GENERAL INFORMATION

I. Reporting period (specify dates): July 1 - Sept 30, 2021

2. Due date for submittal of report: October 30, 2021

3. Type of submittal: [X] Monitoring Report (complete Section III below)
   [ ] Compliance Schedule Progress Report (complete Section IV of Form 3.17-K2)
   [ ] Compliance Certification (complete Section V of Form 3.17-K2)

III. MONITORING REPORT INFORMATION

1. Were deviations from monitoring requirements encountered during the reporting period?[X] No [ ] Yes (If Yes, complete Form 3.17-L)