

DOCKETED	
Docket Number:	06-AFC-09C
Project Title:	Colusa Generating Station - Compliance
TN #:	242938
Document Title:	QUARTERLY OPERATING REPORT- Q1 2022
Description:	N/A
Filer:	Anwar Ali
Organization:	PG&E
Submitter Role:	Public
Submission Date:	5/5/2022 5:25:05 PM
Docketed Date:	5/6/2022



Mailing Address
Pacific Gas and Electric Company
Colusa Generating Station
P.O. Box 398
Maxwell, CA 95955

530.934.9061
Fax: 530.934.9024

CGS22-L-06

April 26, 2022

Anwar Ali
Compliance Project Manager
California Energy Commission
1516 Ninth Street, MS-2000
Sacramento, CA 95814

Reference: Colusa Generating Station (06-AFC-9)

Subject: Condition of Certification AQSC-9 – Quarterly Operating Reports

Electronically submitted to anwar.ali@energy.ca.gov

Dear Mr. Ali:

Attached is the First Quarter 2022 Operating Report for the Colusa Generating Station.

The QOR includes the following attachments:

Attachment 1: Complaints

Attachment 2: Fuel Quality Data

Attachment 3: 40 CFR 60 Section KKKK Information

Attachment 4: Excess Emissions / Downtime Report / EDS / CMS Reports

Attachment 5: Hourly Emissions – VOC

Attachment 6: Hourly Emissions – NOx

Attachment 7: Hourly Emissions – CO

Attachment 8: Hourly Emissions – NH3

Attachment 9: Quarterly / Annual Emissions (Fuel Use, Hours of Operation, and NH3 Injection)

Attachment 10: Maximum Emissions

Attachment 11: Linearity

Attachment 12: Startup / Shutdown Emissions

Attachment 13: Water Bath Heater Operations

Attachment 14: Certification Report

If you have any questions regarding this submittal, please contact me at (530) 393-2926.

Sincerely,



TJ Gomez
Senior Environmental Field Specialist

cc: Josh Harris, PG&E
Sam Garcia, PG&E
Steve Royall, PG&E
Betsy Brunswick, PG&E

ATTACHMENT 1

Complaints (AQ-5)

During the 1st quarter of 2022, there were no complaints issued from the public for the Colusa Generating Station. The site continues to be available for inspection by representatives of the CCAPCD.

ATTACHMENT 2

Fuel Quality Data

FCD: AQ-10 & 11
Title V: #3


2022 Monthly Sulfur Content - Colusa Generating Station

All Units in Grains of Sulfur per Standard Cubic Foot

Month	Jan-15	Feb-15	Mar-15	Apr-15	May-15	Jun-15	Jul-15	Aug-15	Sep-15	Oct-15	Nov-15	Dec-15	Avg
Gr/100SCF	0.201	0.149	OUTAGE										0.155

Permit Limits:

.75 Grains/100SCF per Month (PSD Condition X.I.4); .3 Grains/100SCF Annual Average (Title V # 16)



Atmospheric Analysis & Consulting, Inc.

CLIENT : PG&E
PROJECT NAME : Natural Gas Sampling
AAC PROJECT NO. : 220093
REPORT DATE : 01/21/2022

On January 14, 2022, Atmospheric Analysis & Consulting, Inc. received one (1) 1.0-Liter Silonite Canister for Total Reduced Sulfur analysis by ASTM D-5504. Upon receipt, the sample was assigned a unique Laboratory ID number as follows:


Client ID	Lab No.	Return Pressure (mmHg)
CPP-GS-JAN-A	220093-27114	655.0

This analysis is performed in accordance with AAC's Quality Manual. Test results apply to the sample as received. For detailed information pertaining to specific EPA, NCASI, ASTM and SCAQMD accreditations (Methods & Analytes), please visit our website at www.aacclab.com.

I certify that this data is technically accurate, complete, and in compliance with the terms and conditions of the contract. No problems were encountered during receiving, preparation, and/or analysis of this sample.


The Technical Director or his/her designee, as verified by the following signature, has authorized release of the data.

If you have any questions or require further explanation of data results, please contact the undersigned.


Sucha Parmar, Ph.D.
Technical Director

This report consists of 5 pages.





Atmospheric Analysis & Consulting, Inc.

LABORATORY ANALYSIS REPORT


CLIENT : PG&E Environmental Services
PROJECT NO. : 220093
MATRIX : AIR
UNITS : ppmV

SAMPLING DATE : 01/12/2022
RECEIVING DATE : 01/14/2022
ANALYSIS DATE : 01/18/2022
REPORT DATE : 01/21/2022

Total Reduced Sulfur Compounds Analysis by ASTM D-5504

Client ID	CPP-GS-JAN-A
AAC ID	220093-27114
Canister Dil. Fac.	2.35
Analyte	Result
Hydrogen Sulfide	0.679
COS / SO ₂	0.517
Methyl Mercaptan	0.252
Ethyl Mercaptan	0.155
Dimethyl Sulfide	< 0.117
Carbon Disulfide	< 0.117
Isopropyl Mercaptan	< 0.117
tert-Butyl Mercaptan	0.835
n-Propyl Mercaptan	< 0.117
Methylethylsulfide	< 0.117
sec-Butyl Mercaptan / Thiophene	< 0.117
iso-Butyl Mercaptan	< 0.117
Diethyl Sulfide	< 0.117
n-Butyl Mercaptan	< 0.117
Dimethyl Disulfide	< 0.117
2-Methylthiophene	< 0.117
3-Methylthiophene	< 0.117
Tetrahydrothiophene	0.865
Bromothiophene	< 0.117
Thiophenol	< 0.117
Diethyl Disulfide	< 0.117
Total Unidentified Sulfur	< 0.117
Total Reduced Sulfurs	2.79
Total Sulfurs	3.30

All unidentified compound's concentrations expressed in terms of H₂S (TRS does not include COS and SO₂)
Sample Reporting Limit (SRL) is equal to Reporting Limit x Canister Dil. Fac. x Analysis Dil. Fac.



Atmospheric Analysis & Consulting, Inc.

LABORATORY ANALYSIS REPORT


CLIENT : PG&E Environmental Services
PROJECT NO. : 220088
MATRIX : AIR
UNITS : grains/100 dscf

SAMPLING DATE : 01/11/2022
RECEIVING DATE : 01/13/2022
ANALYSIS DATE : 01/17/2022
REPORT DATE : 01/20/2022

Total Reduced Sulfur Compounds Analysis by ASTM D-5504

Client ID	CPP-GS-JAN-A
AAC ID	220093-27114
Canister Dil. Fac.	2.35
Analyte	Result
Hydrogen Sulfide	0.04133
COS / SO ₂	0.03149
Methyl Mercaptan	0.00947
Ethyl Mercaptan	0.00844
Dimethyl Sulfide	< 0.00715
Carbon Disulfide	< 0.00715
Isopropyl Mercaptan	< 0.00715
tert-Butyl Mercaptan	0.05087
n-Propyl Mercaptan	< 0.00715
Methylethylsulfide	< 0.00715
sec-Butyl Mercaptan / Thiophene	< 0.00715
iso-Butyl Mercaptan	< 0.00715
Diethyl Sulfide	< 0.00715
n-Butyl Mercaptan	< 0.00715
Dimethyl Disulfide	< 0.00715
2-Methylthiophene	< 0.00715
3-Methylthiophene	< 0.00715
Tetrahydrothiophene	0.05266
Bromothiophene	< 0.00715
Thiophenol	< 0.00715
Diethyl Disulfide	< 0.00715
Total Unidentified Sulfur	< 0.00715
Total Reduced Sulfurs	0.16969
Total Sulfurs	0.20117

All unidentified compound's concentrations expressed in terms of H₂S (TRS does not include COS and SO₂)
Sample Reporting Limit (SRL) is equal to Reporting Limit x Canister Dil. Fac. x Analysis Dil. Fac.



Atmospheric Analysis & Consulting, Inc.

Quality Control/Quality Assurance Report ASTM D-5504

Date Analyzed: 1/18/2022
Analyst: DL
Units: ppbV

Instrument ID: SCD#10
Calb. Date: 12/8/2021

Opening Calibration Verification Standard

519.8 ppbV H₂S (SSI289)

H ₂ S	Resp. (area)	Result	% Rec *	% RPD ****
Initial	3004	527	101.3	1.1
Duplicate	2924	513	98.6	1.6
Triplicate	2988	524	100.8	0.5

527.0 ppbV H₂S (SSI289)

MeSH	Resp. (area)	Result	% Rec *	% RPD ****
Initial	3347	506	96.1	0.7
Duplicate	3412	516	97.9	1.2
Triplicate	3354	507	96.3	0.5

522.0 ppbV H₂S (SSI289)

DMS	Resp. (area)	Result	% Rec *	% RPD ****
Initial	3796	504	96.5	0.3
Duplicate	3787	502	96.2	0.0
Triplicate	3776	501	96.0	0.3

Method Blank

Analyte	Result
H ₂ S	<PQL
MeSH	<PQL
DMS	<PQL

Duplicate Analysis

Sample ID 220109-27155

Analyte	Sample Result	Duplicate Result	Mean	% RPD ***
H ₂ S	<PQL	<PQL	0.0	0.0
MeSH	<PQL	<PQL	0.0	0.0
DMS	<PQL	<PQL	0.0	0.0

Matrix Spike & Duplicate

Sample ID 220109-27155 x10

Analyte	Sample Conc.	Spike Added	MS Result	MSD Result	MS % Rec **	MSD % Rec **	% RPD ***
H ₂ S	<PQL	259.9	257.9	261.9	99.3	100.8	1.5
MeSH	<PQL	263.5	262.9	264.3	99.8	100.3	0.5
DMS	<PQL	261.0	269.8	276.3	103.4	105.9	2.4

Closing Calibration Verification Standard

Analyte	Std. Conc.	Result	% Rec **
H ₂ S	519.8	563.4	108.4
MeSH	527.0	563.7	107.0
DMS	522.0	563.5	108.0

* Must be 95-105%, ** Must be 90-110%, *** Must be < 10%, **** Must be < 5% RPD from Mean result.

H₂S: PQL = 10.5 ppbV, MDL = 1.12 ppbV


MeSH: PQL = 10.5 ppbV, MDL = 1.12 ppbV

DMS: PQL = 11.0 ppbV, MDL = 1.12 ppbV

220093

Colusa Fuel Gas Sampling										Preparation and Analysis																			
Client PG&E Environmental Services					Project Manager Surinder Sidhu			Date 1/12/22		Sulfur ASTM D-5504																			
Address 3400 Crow Canyon Road					Telephone Number 925-866-5245		Email: SKSG@pge.com		Laboratory AAC Labs																				
City San Ramon		State CA		Zip 94583		Site Contact Steve North 925-785-3039		Laboratory Phone 805-650-1642																					
Project Number/Name Natural Gas Sampling					Sampler Steve North 925-785-3039			Laboratory Fax																					
Contract Number, PO Number					Laboratory Contact JOHN YOKOYAMA 2225 JERRY AVE Eric Grosjean 1534 Eastman Ave. Suite A Ventura CA 93003																								
PG&E Sample ID CPP-GS- JAN -A		SAM#-ID# 27114		Date 1/12/22		Time 1615		Sample Type Gas		Containers Volume 1 liter		Type cyl		No. 1		Preservative None		Condition on Receipt/Comments		X									
Special Instruction:																													
Email results to Surinder Sidhu (SKSG@PGE.COM) , Evan Cavalli (EMCM@PGE.COM), A.J. Gomez (AJGU@PGE.COM)																													
Turn Around Time Required ☒ Normal ☐ Rush ☐ Other								QC Level ☒ I. ☐ II. ☐ III.				Project Specific Requirements (Specify)																	
1. Relinquished By Steve North								Date 1/13/22				Time 1100				1. Received By								Date		Time			
2. Relinquished By								Date				Time				2. Received By								Date		Time			
3. Relinquished By								Date				Time				3. Received By								Date 1/14/22		Time 1106			
Comments																													
Sample collected in 3L Tedlar bag and immediately field transferred to evacuated 1L mini-can onsite.																													

GLS is 1.0 L can



Atmospheric Analysis & Consulting, Inc.

CLIENT : PG&E Environmental Services
PROJECT NAME : Natural Gas Sampling
AAC PROJECT NO. : 220308
REPORT DATE : 02/21/2022


On February 11, 2022, Atmospheric Analysis & Consulting, Inc. received one (1) 1.0-Liter Silonite Canister for Total Reduced Sulfur analysis by ASTM D-5504. Upon receipt, the sample was assigned a unique Laboratory ID number as follows:

Client ID	Lab No.	Return Pressure (mmHg)
CPP-GS-FEB-A	220308-27904	667.0


This analysis is performed in accordance with AAC's Quality Manual. Test results apply to the sample(s) as received. For detailed information pertaining to specific EPA, NCASI, ASTM and SCAQMD accreditations (Methods & Analytes), please visit our website at www.aacalab.com.

I certify that this data is technically accurate, complete, and in compliance with the terms and conditions of the contract. No problems were encountered during receiving, preparation, and/or analysis of this sample. The Technical Director or his/her designee, as verified by the following signature, has authorized release of the data.

If you have any questions or require further explanation of data results, please contact the undersigned.


Sucha Parmar, Ph.D.
Technical Director

This report consists of 5 pages.



Atmospheric Analysis & Consulting, Inc.

LABORATORY ANALYSIS REPORT


CLIENT : PG&E Environmental Services
PROJECT NO. : 220308
MATRIX : AIR
UNITS : ppmV

SAMPLING DATE : 02/09/2022
RECEIVING DATE : 02/11/2022
ANALYSIS DATE : 02/15/2022
REPORT DATE : 02/21/2022

Total Reduced Sulfur Compounds Analysis by ASTM D-5504

Client ID	CPP-GS-FEB-A
AAC ID	220308-27904
Canister Dil. Fac.	2.4
Analyte	Result
Hydrogen Sulfide	0.799
COS / SO ₂	0.578
Methyl Mercaptan	0.133
Ethyl Mercaptan	< 0.119
Dimethyl Sulfide	< 0.119
Carbon Disulfide	< 0.119
Isopropyl Mercaptan	< 0.119
tert-Butyl Mercaptan	0.583
n-Propyl Mercaptan	< 0.119
Methylethylsulfide	< 0.119
sec-Butyl Mercaptan / Thiophene	< 0.119
iso-Butyl Mercaptan	< 0.119
Diethyl Sulfide	< 0.119
n-Butyl Mercaptan	< 0.119
Dimethyl Disulfide	< 0.119
2-Methylthiophene	< 0.119
3-Methylthiophene	< 0.119
Tetrahydrothiophene	0.932
Bromothiophene	< 0.119
Thiophenol	< 0.119
Diethyl Disulfide	< 0.119
Total Unidentified Sulfur	< 0.119
Total Reduced Sulfurs	2.45

All unidentified compound's concentrations expressed in terms of H₂S (TRS does not include COS and SO₂)
Sample Reporting Limit (SRL) is equal to Reporting Limit x Canister Dil. Fac. x Analysis Dil. Fac.



Atmospheric Analysis & Consulting, Inc.

LABORATORY ANALYSIS REPORT


CLIENT : PG&E Environmental Services
PROJECT NO. : 220308
MATRIX : AIR
UNITS : grains/100 dscf

SAMPLING DATE : 02/09/2022
RECEIVING DATE : 02/11/2022
ANALYSIS DATE : 02/15/2022
REPORT DATE : 02/21/2022

Total Reduced Sulfur Compounds Analysis by ASTM D-5504

Client ID	CPP-GS-FEB-A
AAC ID	220308-27904
Canister Dil. Fac.	2.4
Analyte	Result
Hydrogen Sulfide	0.0487
COS / SO ₂	0.0352
Methyl Mercaptan	0.00807
Ethyl Mercaptan	< 0.00726
Dimethyl Sulfide	< 0.00726
Carbon Disulfide	< 0.00726
Isopropyl Mercaptan	< 0.00726
tert-Butyl Mercaptan	0.0355
n-Propyl Mercaptan	< 0.00726
Methylethylsulfide	< 0.00726
sec-Butyl Mercaptan / Thiophene	< 0.00726
iso-Butyl Mercaptan	< 0.00726
Diethyl Sulfide	< 0.00726
n-Butyl Mercaptan	< 0.00726
Dimethyl Disulfide	< 0.00726
2-Methylthiophene	< 0.00726
3-Methylthiophene	< 0.00726
Tetrahydrothiophene	0.0568
Bromothiophene	< 0.00726
Thiophenol	< 0.00726
Diethyl Disulfide	< 0.00726
Total Unidentified Sulfur	< 0.00726
Total Reduced Sulfurs	0.149

All unidentified compound's concentrations expressed in terms of H₂S (TRS does not include COS and SO₂)
Sample Reporting Limit (SRL) is equal to Reporting Limit x Canister Dil. Fac. x Analysis Dil. Fac.



Atmospheric Analysis & Consulting, Inc.

Quality Control/Quality Assurance Report ASTM D-5504

Date Analyzed: 2/15/2022
Analyst: DL
Units: ppbV

Instrument ID: SCD#10
Calb. Date: 12/8/2021

Opening Calibration Verification Standard

519.8 ppbV H₂S (SS1289)

H ₂ S	Resp. (area)	Result	% Rec *	% RPD ****
Initial	2984	523	100.7	0.1
Duplicate	2963	520	100.0	0.8
Triplicate	3014	529	101.7	0.9

527.0 ppbV H₂S (SS1289)

MeSH	Resp. (area)	Result	% Rec *	% RPD ****
Initial	3446	521	98.9	1.1
Duplicate	3408	515	97.8	0.1
Triplicate	3376	511	96.9	1.0

522.0 ppbV H₂S (SS1289)

DMS	Resp. (area)	Result	% Rec *	% RPD ****
Initial	3843	510	97.7	1.8
Duplicate	3937	522	100.0	0.6
Triplicate	3960	525	100.6	1.2

Method Blank

Analyte	Result
H ₂ S	<PQL
MeSH	<PQL
DMS	<PQL

Duplicate Analysis

Sample ID 220173-27362

Analyte	Sample Result	Duplicate Result	Mean	% RPD ***
H ₂ S	<PQL	<PQL	0.0	0.0
MeSH	<PQL	<PQL	0.0	0.0
DMS	<PQL	<PQL	0.0	0.0

Matrix Spike & Duplicate

Sample ID 220173-27362

Analyte	Sample Conc.	Spike Added	MS Result	MSD Result	MS % Rec **	MSD % Rec **	% RPD ***
H ₂ S	<PQL	259.9	265.2	258.7	102.1	99.5	2.5
MeSH	<PQL	263.5	260.1	269.0	98.7	102.1	3.4
DMS	<PQL	261.0	274.1	272.4	105.0	104.4	0.6

Closing Calibration Verification Standard

Analyte	Std. Conc.	Result	% Rec **
H ₂ S	519.8	552.0	106.2
MeSH	527.0	548.7	104.1
DMS	522.0	556.9	106.7

* Must be 95-105%, ** Must be 90-110%, *** Must be < 10%, **** Must be < 5% RPD from Mean result.

H₂S: PQL = 10.5 ppbV, MDL = 1.12 ppbV

MeSH: PQL = 10.5 ppbV, MDL = 1.12 ppbV

DMS: PQL = 11.0 ppbV, MDL = 1.12 ppbV

220308

Colusa Fuel Gas Sampling								Preparation and Analysis							
Client PG&E Environmental Services				Project Manager Surinder Sidhu				Date 2/10/22							
Address 3400 Crow Canyon Road				Telephone Number 925-866-5245		Email: SKSG@pge.com		Laboratory AAC Labs							
City San Ramon		State CA		Zip 94583		Site Contact Steve North 925-785-3039		Laboratory Phone 805-650-1642							
Project Number/Name Natural Gas Sampling								Laboratory Fax							
Contract Number, PO Number				Laboratory Contact Eric Grosjean - 1534 Eastman Ave. Suite A Ventura CA 93003											
PG&E Sample ID		SAM#-ID#		Date	Time	Sample Type	Containers		Preservative	Condition on Receipt/Comments					
							Volume Type No.								
CPP-GS-FEB - A		27904		2/9/22	1618	Gas	1 liter cyl 1		None						
Special Instruction: Email results to Surinder Sidhu (SKSG@PGE.COM) , Evan Cavalli (EMCM@PGE.COM), A.J. Gomez (AJGU@PGE.COM)															
Turn Around Time Required ☒ Normal ☐ Rush ☐ Other				QC Level ☒ I. ☐ II. ☐ III.				Project Specific Requirements (Specify)							
1. Relinquished By Steve North				Date 2/10/22		Time 1115		1. Received By				Date		Time	
2. Relinquished By				Date		Time		2. Received By				Date		Time	
3. Relinquished By				Date		Time		3. Received By				Date 2/11/22		Time 0957	
Comments Sample collected in 3L Tedlar bag and immediately field transferred to evacuated 1L mini-can onsite.															

12 1.0L

ATTACHMENT 3
40 CFR 60 Section KKKK

FCD: AQ-13
Title V: #8,9, 23, 25, 28

40 CFR 60 KKKK Emission Limits:

Natural Gas Fired Combustion Turbine > 850 MMBtu

15 PPMVDC @ 15% O₂; 4 Hour Rolling Average

During Normal Operations

96 PPMVDC @ 15% O₂; 4 Hour Rolling Average

Turbines operating at less than 75% of Peak Load
(Startup/Shutdown)

KKKK Compliance (Colusa Generating Station)

40 CFR Part 60 Subpart KKKK applies to all stationary gas turbines rated at greater than or equal to 10 MMBtu/hr that commence construction, modification, or reconstruction after February 18, 2005. The gas turbines involved in this project have a rating of 1612 MMBtu/hr and were installed after February 18, 2005. Therefore, this subpart applies to these gas turbines. The KKKK compliance summaries for the stationary natural gas turbines is summarized below and are based on the following applicable sections of the KKKK performance standards. The non-applicable portions of KKKK are not listed in the compliance summary:

Section	Requirement
60.4305	CGS Turbines/HRSGs are rated at larger than 10 mmbtu/hr and construction commenced after February 18, 2005. Subpart KKKK applies.
60.4310	No exemptions apply.
60.4315	Pollutants regulated under Subpart KKKK: NO _x and SO ₂ .
60.4320	NO _x emissions limit: 15 ppmv @15%O ₂
60.4330	SO ₂ emissions limit: 0.90 lbs SO ₂ /MWh (gross output), or cannot burn any fuel which contains total potential sulfur emissions in excess of 0.060 lbs SO ₂ /MMBtu (heat input).
60.4333	Operate turbine/HRSG, APC systems, and monitoring equipment to minimize emissions at all times including during startup, shutdown, and malfunction.
60.4340(b)(1)	For units with SCR, install a NO _x CEMS per 60.4335(b) or 60.4345. If Part 75 applies, NO _x can be monitored per Appendix E of Part 75. (CGS QAP applies here)
60.4345	Meet all CEMS Performance Specs and develop a QA Plan for the CEMS. . (CGS QAP applies here)
60.4350	All CEMS data must be reduced to hourly averages per 60.13(h). . (CGS QAP applies here)
60.4355	If applicable, develop and insure all parametric monitoring and monitoring plans comply with this section. . (CGS QAP applies here)
60.4360	Monitor fuel sulfur content, or invoke exemption per 60.4365.
60.4365	Exemption for fuel sulfur monitoring, if fuel is demonstrated not to exceed potential sulfur emissions of 0.060 lbs SO ₂ /MMBtu, Use PG&E gas quality data to show that exemption applies per 60.4365 (a) or (b).
60.4375	Submit excess emissions reports per 60.7(c). Within 30 days following the end of each 6 month period (see 60.4395). In compliance.
60.4380(b)	Determine excess emissions and monitor downtime per (b) (1-3)
60.4400	Initial and annual NO _x performance tests not required if CEMS used

	per 60.4340(b)(1)
60.4405	If NO _x CEMS used, use 60.4405 (a-d) procedures in lieu of performance test.
60.4415	Perform initial SO ₂ performance test per 60.4415 (2) or (3). This test must be conducted even if the 60.4365 exemption is invoked.

Compliance with the applicable provisions of NSPS KKKK are summarized below. Specific data to support the compliance determinations listed below are included as attachments.

Section	Compliance
60.4305	KKKK is applicable to the facility. In compliance
60.4310	No exemptions apply.
60.4315	NO _x and SO ₂ are in compliance with the KKKK emission standards and monitoring requirements.
60.4320	NO _x emissions limit: 9 ppmv @15%O ₂ (See attached GE data sheet). In compliance.
60.4330	SO ₂ emissions limit: CT1 172 MW 1.283 lb/hr (SO ₂ source test date: 2010) CT2 172 MW 1.649 lb/hr (SO ₂ source test date: 2010) CT1 - $1.283/172 = 0.0075$ lb/MWh CT2 - $1.649/172 = 0.0096$ lb/MWh In compliance with SO ₂ emission limits. The project will only use pipe quality natural gas with sulfur limits less than 0.06 lbs/MMBtu. See attached natural gas fuel analysis. In compliance with limits based on monthly fuel sampling.
60.4333	The facility will operate turbine/HRSG, APC systems, and monitoring equipment to minimize emissions at all times including during startup, shutdown, and malfunction. In compliance.
60.4340(b)(1)	CT1 and CT2 utilize SCR and NO _x CEMS per 60.4335(b) or 60.4345. In addition, Part 75 applies and NO _x is monitored per Appendix E of Part 75. See attached Quality Assurance Plan (attached). In compliance.
60.4345	In compliance. .
60.4350	In compliance
60.4355	In compliance
60.4360	In compliance through exemption per 60.4365.
60.4365	Requesting exemption (a) and (b) for sulfur monitoring. The fuel used is pipeline quality natural gas with an average grain loading less than 0.30 gr/100 SCF which converts to 0.0008 lb/MMBtu of SO ₂ . See fuel

	analysis Attachment 2. Annual compliance based on PG&E supplied fuel analysis data.
60.4375	No excess emissions during this reporting period. In compliance.
60.4380(b)	No excess emissions or monitor downtime, per (b) (1-3). In compliance.
60.4400	In compliance. NO _x CEMs used per 60.4340(b)(1). NO _x , CO, and VOC will be tested annually.
60.4405	In compliance. See QAP for CEMs certification.
60.4415	In compliance. Initial SO ₂ source test results and QAP are available upon request. Future compliance under this requirement may be determined using one of three methods summarized in 60.4415.

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/06/2022 11:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
01/01/2022 00:00	1	1
01/01/2022 01:00	1	1
01/01/2022 02:00	1	1
01/01/2022 03:00	1	1
01/01/2022 04:00	1	1
01/01/2022 05:00	1	1
01/01/2022 06:00	1	1
01/01/2022 07:00	1	1
01/01/2022 08:00	1	1
01/01/2022 09:00	1	1
01/01/2022 10:00	1	1
01/01/2022 11:00	1	1
01/01/2022 12:00	1	1
01/01/2022 13:00	1	1
01/01/2022 14:00	1	1
01/01/2022 15:00	1	1
01/01/2022 16:00	1	10
01/01/2022 17:00	1	15
01/01/2022 18:00	1	15
01/01/2022 19:00	1	15
01/01/2022 20:00	1	5
01/01/2022 21:00	1	1
01/01/2022 22:00	1	1
01/01/2022 23:00	1	1
Average/Sum#:	1	3
Minimum:	1	1
Maximum:	1	15
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/06/2022 11:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
01/02/2022 00:00	1	1
01/02/2022 01:00	1	1
01/02/2022 02:00	1	1
01/02/2022 03:00	1	1
01/02/2022 04:00	1	1
01/02/2022 05:00	1	1
01/02/2022 06:00	1	1
01/02/2022 07:00	1	1
01/02/2022 08:00	1	1
01/02/2022 09:00	1	1
01/02/2022 10:00	1	1
01/02/2022 11:00	1	1
01/02/2022 12:00	1	1
01/02/2022 13:00	1	1
01/02/2022 14:00	1	1
01/02/2022 15:00	1	1
01/02/2022 16:00	1	9
01/02/2022 17:00	1	13
01/02/2022 18:00	1	13
01/02/2022 19:00	1	12
01/02/2022 20:00	1	5
01/02/2022 21:00	1	1
01/02/2022 22:00	1	1
01/02/2022 23:00	1	1
Average/Sum#:	1	3
Minimum:	1	1
Maximum:	1	13
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/06/2022 11:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
01/03/2022 00:00	1	1
01/03/2022 01:00	1	1
01/03/2022 02:00	1	1
01/03/2022 03:00	1	1
01/03/2022 04:00	1	1
01/03/2022 05:00	1	1
01/03/2022 06:00	1	1
01/03/2022 07:00	1	1
01/03/2022 08:00	1	1
01/03/2022 09:00	1	1
01/03/2022 10:00	1	1
01/03/2022 11:00	1	1
01/03/2022 12:00	1	1
01/03/2022 13:00	1	1
01/03/2022 14:00	1	1
01/03/2022 15:00	1	1
01/03/2022 16:00	1	1
01/03/2022 17:00	1	1
01/03/2022 18:00	1	1
01/03/2022 19:00	1	1
01/03/2022 20:00	1	1
01/03/2022 21:00	1	1
01/03/2022 22:00	1	1
01/03/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/06/2022 11:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
01/04/2022 00:00	1	1
01/04/2022 01:00	1	1
01/04/2022 02:00	1	1
01/04/2022 03:00	1	1
01/04/2022 04:00	1	1
01/04/2022 05:00	1	1
01/04/2022 06:00	1	1
01/04/2022 07:00	1	1
01/04/2022 08:00	1	1
01/04/2022 09:00	1	1
01/04/2022 10:00	1	1
01/04/2022 11:00	1	1
01/04/2022 12:00	1	1
01/04/2022 13:00	1	1
01/04/2022 14:00	1	1
01/04/2022 15:00	1	1
01/04/2022 16:00	1	1
01/04/2022 17:00	1	1
01/04/2022 18:00	1	1
01/04/2022 19:00	1	1
01/04/2022 20:00	1	1
01/04/2022 21:00	1	1
01/04/2022 22:00	1	1
01/04/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/06/2022 11:39 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
01/05/2022 00:00	1	1
01/05/2022 01:00	1	1
01/05/2022 02:00	1	1
01/05/2022 03:00	1	1
01/05/2022 04:00	1	1
01/05/2022 05:00	1	1
01/05/2022 06:00	1	1
01/05/2022 07:00	1	1
01/05/2022 08:00	1	1
01/05/2022 09:00	1	1
01/05/2022 10:00	1	1
01/05/2022 11:00	1	1
01/05/2022 12:00	1	1
01/05/2022 13:00	1	1
01/05/2022 14:00	1	1
01/05/2022 15:00	1	1
01/05/2022 16:00	1	1
01/05/2022 17:00	1	1
01/05/2022 18:00	1	1
01/05/2022 19:00	1	1
01/05/2022 20:00	1	1
01/05/2022 21:00	1	1
01/05/2022 22:00	1	1
01/05/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/06/2022 11:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
01/06/2022 00:00	1	1
01/06/2022 01:00	1	1
01/06/2022 02:00	1	1
01/06/2022 03:00	1	1
01/06/2022 04:00	1	1
01/06/2022 05:00	1	1
01/06/2022 06:00	1	1
01/06/2022 07:00	1	1
01/06/2022 08:00	1	1
01/06/2022 09:00	1	1
01/06/2022 10:00	1	1
01/06/2022 11:00	1	1
01/06/2022 12:00	1	1
01/06/2022 13:00	1	1
01/06/2022 14:00	1	1
01/06/2022 15:00	1	1
01/06/2022 16:00	1	1
01/06/2022 17:00	1	1
01/06/2022 18:00	1	1
01/06/2022 19:00	1	1
01/06/2022 20:00	1	1
01/06/2022 21:00	1	1
01/06/2022 22:00	1	1
01/06/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/06/2022 11:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
01/07/2022 00:00	1	1
01/07/2022 01:00	1	1
01/07/2022 02:00	1	1
01/07/2022 03:00	1	1
01/07/2022 04:00	1	1
01/07/2022 05:00	1	1
01/07/2022 06:00	1	1
01/07/2022 07:00	1	1
01/07/2022 08:00	1	1
01/07/2022 09:00	1	1
01/07/2022 10:00	1	1
01/07/2022 11:00	1	1
01/07/2022 12:00	1	1
01/07/2022 13:00	1	1
01/07/2022 14:00	1	1
01/07/2022 15:00	1	1
01/07/2022 16:00	1	1
01/07/2022 17:00	1	1
01/07/2022 18:00	1	1
01/07/2022 19:00	1	1
01/07/2022 20:00	1	1
01/07/2022 21:00	1	1
01/07/2022 22:00	1	1
01/07/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/06/2022 11:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
01/08/2022 00:00	1	1
01/08/2022 01:00	1	1
01/08/2022 02:00	1	1
01/08/2022 03:00	1	1
01/08/2022 04:00	1	1
01/08/2022 05:00	1	1
01/08/2022 06:00	1	1
01/08/2022 07:00	1	1
01/08/2022 08:00	1	1
01/08/2022 09:00	1	1
01/08/2022 10:00	14	1
01/08/2022 11:00	18	1
01/08/2022 12:00	20	1
01/08/2022 13:00	19	1
01/08/2022 14:00	7	1
01/08/2022 15:00	3	13
01/08/2022 16:00	1	15
01/08/2022 17:00	1	15
01/08/2022 18:00	1	14
01/08/2022 19:00	1	3
01/08/2022 20:00	1	1
01/08/2022 21:00	1	1
01/08/2022 22:00	1	1
01/08/2022 23:00	1	1
Average/Sum#:	4	3
Minimum:	1	1
Maximum:	20	15
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/06/2022 11:39 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
01/09/2022 00:00	1	1
01/09/2022 01:00	1	1
01/09/2022 02:00	1	1
01/09/2022 03:00	1	1
01/09/2022 04:00	1	1
01/09/2022 05:00	1	1
01/09/2022 06:00	1	1
01/09/2022 07:00	1	1
01/09/2022 08:00	1	1
01/09/2022 09:00	1	1
01/09/2022 10:00	1	1
01/09/2022 11:00	1	1
01/09/2022 12:00	1	1
01/09/2022 13:00	1	1
01/09/2022 14:00	1	1
01/09/2022 15:00	1	1
01/09/2022 16:00	1	1
01/09/2022 17:00	1	1
01/09/2022 18:00	1	1
01/09/2022 19:00	1	1
01/09/2022 20:00	1	1
01/09/2022 21:00	1	1
01/09/2022 22:00	1	1
01/09/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/06/2022 11:39 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
01/10/2022 00:00	1	1
01/10/2022 01:00	1	1
01/10/2022 02:00	1	1
01/10/2022 03:00	1	1
01/10/2022 04:00	1	1
01/10/2022 05:00	1	1
01/10/2022 06:00	1	7
01/10/2022 07:00	1	8
01/10/2022 08:00	1	8
01/10/2022 09:00	1	8
01/10/2022 10:00	1	2
01/10/2022 11:00	1	1
01/10/2022 12:00	1	1
01/10/2022 13:00	1	1
01/10/2022 14:00	1	1
01/10/2022 15:00	1	1
01/10/2022 16:00	1	1
01/10/2022 17:00	1	1
01/10/2022 18:00	1	1
01/10/2022 19:00	1	1
01/10/2022 20:00	1	1
01/10/2022 21:00	1	1
01/10/2022 22:00	1	1
01/10/2022 23:00	1	1
Average/Sum#:	1	2
Minimum:	1	1
Maximum:	1	8
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/06/2022 11:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
01/11/2022 00:00	1	1
01/11/2022 01:00	1	1
01/11/2022 02:00	1	1
01/11/2022 03:00	1	1
01/11/2022 04:00	1	1
01/11/2022 05:00	1	1
01/11/2022 06:00	1	1
01/11/2022 07:00	1	1
01/11/2022 08:00	1	1
01/11/2022 09:00	1	1
01/11/2022 10:00	1	1
01/11/2022 11:00	1	1
01/11/2022 12:00	1	1
01/11/2022 13:00	1	1
01/11/2022 14:00	1	1
01/11/2022 15:00	1	1
01/11/2022 16:00	1	1
01/11/2022 17:00	1	1
01/11/2022 18:00	1	1
01/11/2022 19:00	1	1
01/11/2022 20:00	1	1
01/11/2022 21:00	1	1
01/11/2022 22:00	1	1
01/11/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/06/2022 11:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
01/12/2022 00:00	1	1
01/12/2022 01:00	1	1
01/12/2022 02:00	1	1
01/12/2022 03:00	1	1
01/12/2022 04:00	1	1
01/12/2022 05:00	1	1
01/12/2022 06:00	1	1
01/12/2022 07:00	1	1
01/12/2022 08:00	1	1
01/12/2022 09:00	1	12
01/12/2022 10:00	1	17
01/12/2022 11:00	1	16
01/12/2022 12:00	1	16
01/12/2022 13:00	1	6
01/12/2022 14:00	1	1
01/12/2022 15:00	1	1
01/12/2022 16:00	1	1
01/12/2022 17:00	1	1
01/12/2022 18:00	1	1
01/12/2022 19:00	1	1
01/12/2022 20:00	1	1
01/12/2022 21:00	1	1
01/12/2022 22:00	1	1
01/12/2022 23:00	1	1
Average/Sum#:	1	4
Minimum:	1	1
Maximum:	1	17
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/06/2022 11:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
01/13/2022 00:00	1	1
01/13/2022 01:00	1	1
01/13/2022 02:00	1	1
01/13/2022 03:00	1	1
01/13/2022 04:00	1	1
01/13/2022 05:00	1	1
01/13/2022 06:00	1	1
01/13/2022 07:00	1	1
01/13/2022 08:00	1	1
01/13/2022 09:00	1	1
01/13/2022 10:00	1	1
01/13/2022 11:00	1	1
01/13/2022 12:00	1	1
01/13/2022 13:00	1	1
01/13/2022 14:00	1	1
01/13/2022 15:00	1	1
01/13/2022 16:00	1	1
01/13/2022 17:00	1	1
01/13/2022 18:00	1	1
01/13/2022 19:00	1	1
01/13/2022 20:00	1	1
01/13/2022 21:00	1	1
01/13/2022 22:00	1	1
01/13/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/06/2022 11:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
01/14/2022 00:00	1	1
01/14/2022 01:00	1	1
01/14/2022 02:00	1	1
01/14/2022 03:00	1	1
01/14/2022 04:00	2	1
01/14/2022 05:00	5	1
01/14/2022 06:00	4	1
01/14/2022 07:00	4	1
01/14/2022 08:00	3	1
01/14/2022 09:00	1	1
01/14/2022 10:00	1	1
01/14/2022 11:00	1	1
01/14/2022 12:00	1	1
01/14/2022 13:00	1	14
01/14/2022 14:00	1	16
01/14/2022 15:00	1	16
01/14/2022 16:00	1	16
01/14/2022 17:00	1	3
01/14/2022 18:00	1	1
01/14/2022 19:00	1	1
01/14/2022 20:00	1	1
01/14/2022 21:00	1	1
01/14/2022 22:00	1	1
01/14/2022 23:00	1	1
Average/Sum#:	2	4
Minimum:	1	1
Maximum:	5	16
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/06/2022 11:39 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
01/15/2022 00:00	1	1
01/15/2022 01:00	1	1
01/15/2022 02:00	1	1
01/15/2022 03:00	1	1
01/15/2022 04:00	2	1
01/15/2022 05:00	4	1
01/15/2022 06:00	4	1
01/15/2022 07:00	4	1
01/15/2022 08:00	3	1
01/15/2022 09:00	1	1
01/15/2022 10:00	1	1
01/15/2022 11:00	1	1
01/15/2022 12:00	1	1
01/15/2022 13:00	1	1
01/15/2022 14:00	1	11
01/15/2022 15:00	1	14
01/15/2022 16:00	1	14
01/15/2022 17:00	1	13
01/15/2022 18:00	1	3
01/15/2022 19:00	1	1
01/15/2022 20:00	1	1
01/15/2022 21:00	1	1
01/15/2022 22:00	1	1
01/15/2022 23:00	1	1
Average/Sum#:	2	3
Minimum:	1	1
Maximum:	4	14
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/06/2022 11:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
01/16/2022 00:00	1	1
01/16/2022 01:00	1	1
01/16/2022 02:00	1	1
01/16/2022 03:00	1	1
01/16/2022 04:00	1	1
01/16/2022 05:00	1	1
01/16/2022 06:00	1	1
01/16/2022 07:00	1	1
01/16/2022 08:00	1	1
01/16/2022 09:00	1	1
01/16/2022 10:00	1	1
01/16/2022 11:00	10	1
01/16/2022 12:00	13	1
01/16/2022 13:00	13	1
01/16/2022 14:00	13	1
01/16/2022 15:00	3	14
01/16/2022 16:00	1	20
01/16/2022 17:00	1	19
01/16/2022 18:00	1	19
01/16/2022 19:00	1	7
01/16/2022 20:00	1	1
01/16/2022 21:00	1	1
01/16/2022 22:00	1	1
01/16/2022 23:00	1	1
Average/Sum#:	3	4
Minimum:	1	1
Maximum:	13	20
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/06/2022 11:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
01/17/2022 00:00	1	1
01/17/2022 01:00	1	1
01/17/2022 02:00	1	1
01/17/2022 03:00	1	1
01/17/2022 04:00	1	1
01/17/2022 05:00	1	1
01/17/2022 06:00	1	1
01/17/2022 07:00	1	1
01/17/2022 08:00	1	1
01/17/2022 09:00	1	1
01/17/2022 10:00	1	1
01/17/2022 11:00	1	1
01/17/2022 12:00	1	1
01/17/2022 13:00	1	1
01/17/2022 14:00	1	1
01/17/2022 15:00	1	1
01/17/2022 16:00	1	1
01/17/2022 17:00	1	1
01/17/2022 18:00	1	1
01/17/2022 19:00	1	1
01/17/2022 20:00	1	1
01/17/2022 21:00	1	1
01/17/2022 22:00	1	1
01/17/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/06/2022 11:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
01/18/2022 00:00	1	1
01/18/2022 01:00	1	1
01/18/2022 02:00	1	1
01/18/2022 03:00	1	1
01/18/2022 04:00	1	1
01/18/2022 05:00	1	1
01/18/2022 06:00	1	1
01/18/2022 07:00	1	1
01/18/2022 08:00	1	1
01/18/2022 09:00	1	1
01/18/2022 10:00	1	1
01/18/2022 11:00	1	1
01/18/2022 12:00	1	0
01/18/2022 13:00	0	0
01/18/2022 14:00	1	0
01/18/2022 15:00	1	0
01/18/2022 16:00	1	1
01/18/2022 17:00	1	1
01/18/2022 18:00	1	1
01/18/2022 19:00	1	1
01/18/2022 20:00	1	1
01/18/2022 21:00	1	1
01/18/2022 22:00	1	1
01/18/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	4.17	16.67

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/06/2022 11:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
01/19/2022 00:00	1	1
01/19/2022 01:00	1	1
01/19/2022 02:00	1	1
01/19/2022 03:00	1	1
01/19/2022 04:00	1	1
01/19/2022 05:00	1	1
01/19/2022 06:00	1	1
01/19/2022 07:00	1	1
01/19/2022 08:00	1	1
01/19/2022 09:00	1	1
01/19/2022 10:00	1	0
01/19/2022 11:00	1	0
01/19/2022 12:00	1	1
01/19/2022 13:00	1	1
01/19/2022 14:00	1	1
01/19/2022 15:00	1	1
01/19/2022 16:00	1	1
01/19/2022 17:00	1	1
01/19/2022 18:00	1	1
01/19/2022 19:00	1	1
01/19/2022 20:00	1	1
01/19/2022 21:00	1	1
01/19/2022 22:00	1	1
01/19/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	8.33

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/06/2022 11:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
01/20/2022 00:00	1	1
01/20/2022 01:00	1	1
01/20/2022 02:00	1	1
01/20/2022 03:00	1	1
01/20/2022 04:00	1	1
01/20/2022 05:00	1	1
01/20/2022 06:00	1	1
01/20/2022 07:00	1	1
01/20/2022 08:00	1	1
01/20/2022 09:00	1	1
01/20/2022 10:00	1	1
01/20/2022 11:00	1	1
01/20/2022 12:00	1	1
01/20/2022 13:00	1	1
01/20/2022 14:00	1	1
01/20/2022 15:00	1	1
01/20/2022 16:00	1	10
01/20/2022 17:00	1	12
01/20/2022 18:00	1	12
01/20/2022 19:00	1	11
01/20/2022 20:00	1	3
01/20/2022 21:00	1	1
01/20/2022 22:00	1	1
01/20/2022 23:00	1	2
Average/Sum#:	1	3
Minimum:	1	1
Maximum:	1	12
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/06/2022 11:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
01/21/2022 00:00	1	2
01/21/2022 01:00	1	2
01/21/2022 02:00	1	2
01/21/2022 03:00	1	2
01/21/2022 04:00	1	2
01/21/2022 05:00	1	2
01/21/2022 06:00	1	2
01/21/2022 07:00	1	2
01/21/2022 08:00	1	2
01/21/2022 09:00	1	2
01/21/2022 10:00	1	2
01/21/2022 11:00	1	2
01/21/2022 12:00	1	2
01/21/2022 13:00	1	2
01/21/2022 14:00	1	2
01/21/2022 15:00	1	2
01/21/2022 16:00	1	2
01/21/2022 17:00	1	2
01/21/2022 18:00	1	2
01/21/2022 19:00	1	2
01/21/2022 20:00	1	2
01/21/2022 21:00	1	2
01/21/2022 22:00	1	2
01/21/2022 23:00	1	2
Average/Sum#:	1	2
Minimum:	1	2
Maximum:	1	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/06/2022 11:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
01/22/2022 00:00	1	2
01/22/2022 01:00	1	2
01/22/2022 02:00	1	2
01/22/2022 03:00	1	2
01/22/2022 04:00	1	2
01/22/2022 05:00	1	2
01/22/2022 06:00	1	2
01/22/2022 07:00	1	2
01/22/2022 08:00	1	2
01/22/2022 09:00	1	2
01/22/2022 10:00	1	2
01/22/2022 11:00	1	2
01/22/2022 12:00	1	2
01/22/2022 13:00	1	2
01/22/2022 14:00	1	2
01/22/2022 15:00	1	2
01/22/2022 16:00	1	2
01/22/2022 17:00	1	2
01/22/2022 18:00	1	2
01/22/2022 19:00	1	2
01/22/2022 20:00	1	2
01/22/2022 21:00	1	2
01/22/2022 22:00	1	2
01/22/2022 23:00	1	2
Average/Sum#:	1	2
Minimum:	1	2
Maximum:	1	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/06/2022 11:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
01/23/2022 00:00	1	2
01/23/2022 01:00	1	2
01/23/2022 02:00	1	2
01/23/2022 03:00	1	2
01/23/2022 04:00	1	2
01/23/2022 05:00	1	2
01/23/2022 06:00	1	2
01/23/2022 07:00	1	2
01/23/2022 08:00	1	2
01/23/2022 09:00	1	2
01/23/2022 10:00	1	2
01/23/2022 11:00	16	2
01/23/2022 12:00	22	2
01/23/2022 13:00	26	2
01/23/2022 14:00	26	2
01/23/2022 15:00	11	2
01/23/2022 16:00	5	14
01/23/2022 17:00	1	22
01/23/2022 18:00	1	22
01/23/2022 19:00	1	22
01/23/2022 20:00	1	9
01/23/2022 21:00	1	1
01/23/2022 22:00	1	1
01/23/2022 23:00	1	2
Average/Sum#:	5	5
Minimum:	1	1
Maximum:	26	22
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/06/2022 11:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
01/24/2022 00:00	1	2
01/24/2022 01:00	1	2
01/24/2022 02:00	1	2
01/24/2022 03:00	1	2
01/24/2022 04:00	3	2
01/24/2022 05:00	3	2
01/24/2022 06:00	3	2
01/24/2022 07:00	3	2
01/24/2022 08:00	1	2
01/24/2022 09:00	1	2
01/24/2022 10:00	1	2
01/24/2022 11:00	1	2
01/24/2022 12:00	1	2
01/24/2022 13:00	1	2
01/24/2022 14:00	1	11
01/24/2022 15:00	1	13
01/24/2022 16:00	1	13
01/24/2022 17:00	1	12
01/24/2022 18:00	1	3
01/24/2022 19:00	1	1
01/24/2022 20:00	1	1
01/24/2022 21:00	1	1
01/24/2022 22:00	1	1
01/24/2022 23:00	1	1
Average/Sum#:	1	4
Minimum:	1	1
Maximum:	3	13
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/06/2022 11:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
01/25/2022 00:00	1	1
01/25/2022 01:00	1	1
01/25/2022 02:00	1	1
01/25/2022 03:00	1	1
01/25/2022 04:00	1	1
01/25/2022 05:00	1	1
01/25/2022 06:00	1	1
01/25/2022 07:00	1	1
01/25/2022 08:00	1	1
01/25/2022 09:00	1	1
01/25/2022 10:00	1	1
01/25/2022 11:00	1	2
01/25/2022 12:00	1	4
01/25/2022 13:00	1	4
01/25/2022 14:00	1	4
01/25/2022 15:00	7	3
01/25/2022 16:00	10	1
01/25/2022 17:00	10	1
01/25/2022 18:00	10	1
01/25/2022 19:00	3	1
01/25/2022 20:00	1	1
01/25/2022 21:00	1	1
01/25/2022 22:00	1	1
01/25/2022 23:00	1	1
Average/Sum#:	2	2
Minimum:	1	1
Maximum:	10	4
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/06/2022 11:39 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
01/26/2022 00:00	1	1
01/26/2022 01:00	1	1
01/26/2022 02:00	1	1
01/26/2022 03:00	1	1
01/26/2022 04:00	1	1
01/26/2022 05:00	1	1
01/26/2022 06:00	1	1
01/26/2022 07:00	1	1
01/26/2022 08:00	1	1
01/26/2022 09:00	1	1
01/26/2022 10:00	1	1
01/26/2022 11:00	1	1
01/26/2022 12:00	1	4
01/26/2022 13:00	1	4
01/26/2022 14:00	1	4
01/26/2022 15:00	5	3
01/26/2022 16:00	7	1
01/26/2022 17:00	7	1
01/26/2022 18:00	7	1
01/26/2022 19:00	3	1
01/26/2022 20:00	1	1
01/26/2022 21:00	1	1
01/26/2022 22:00	1	1
01/26/2022 23:00	1	1
Average/Sum#:	2	1
Minimum:	1	1
Maximum:	7	4
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/06/2022 11:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
01/27/2022 00:00	1	1
01/27/2022 01:00	1	1
01/27/2022 02:00	1	1
01/27/2022 03:00	1	1
01/27/2022 04:00	1	1
01/27/2022 05:00	1	1
01/27/2022 06:00	1	1
01/27/2022 07:00	1	1
01/27/2022 08:00	1	1
01/27/2022 09:00	1	1
01/27/2022 10:00	1	1
01/27/2022 11:00	1	1
01/27/2022 12:00	1	1
01/27/2022 13:00	1	1
01/27/2022 14:00	1	1
01/27/2022 15:00	4	1
01/27/2022 16:00	6	1
01/27/2022 17:00	6	1
01/27/2022 18:00	6	1
01/27/2022 19:00	3	1
01/27/2022 20:00	1	1
01/27/2022 21:00	1	1
01/27/2022 22:00	1	1
01/27/2022 23:00	1	1
Average/Sum#:	2	1
Minimum:	1	1
Maximum:	6	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/06/2022 11:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
01/28/2022 00:00	1	1
01/28/2022 01:00	1	1
01/28/2022 02:00	1	1
01/28/2022 03:00	1	1
01/28/2022 04:00	1	1
01/28/2022 05:00	1	1
01/28/2022 06:00	1	1
01/28/2022 07:00	1	1
01/28/2022 08:00	1	1
01/28/2022 09:00	1	1
01/28/2022 10:00	1	1
01/28/2022 11:00	1	1
01/28/2022 12:00	1	1
01/28/2022 13:00	1	1
01/28/2022 14:00	1	1
01/28/2022 15:00	1	1
01/28/2022 16:00	1	1
01/28/2022 17:00	1	1
01/28/2022 18:00	1	1
01/28/2022 19:00	1	1
01/28/2022 20:00	1	1
01/28/2022 21:00	1	1
01/28/2022 22:00	1	1
01/28/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/06/2022 11:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
01/29/2022 00:00	1	1
01/29/2022 01:00	1	1
01/29/2022 02:00	1	1
01/29/2022 03:00	1	1
01/29/2022 04:00	1	1
01/29/2022 05:00	1	1
01/29/2022 06:00	1	1
01/29/2022 07:00	1	1
01/29/2022 08:00	1	1
01/29/2022 09:00	1	1
01/29/2022 10:00	1	1
01/29/2022 11:00	1	1
01/29/2022 12:00	1	1
01/29/2022 13:00	1	1
01/29/2022 14:00	1	1
01/29/2022 15:00	1	1
01/29/2022 16:00	1	1
01/29/2022 17:00	1	1
01/29/2022 18:00	1	1
01/29/2022 19:00	1	1
01/29/2022 20:00	1	1
01/29/2022 21:00	1	1
01/29/2022 22:00	1	1
01/29/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/06/2022 11:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
01/30/2022 00:00	1	1
01/30/2022 01:00	1	1
01/30/2022 02:00	1	1
01/30/2022 03:00	1	1
01/30/2022 04:00	1	1
01/30/2022 05:00	1	1
01/30/2022 06:00	1	1
01/30/2022 07:00	1	1
01/30/2022 08:00	1	1
01/30/2022 09:00	1	1
01/30/2022 10:00	1	1
01/30/2022 11:00	1	1
01/30/2022 12:00	1	1
01/30/2022 13:00	1	1
01/30/2022 14:00	1	9
01/30/2022 15:00	1	16
01/30/2022 16:00	1	16
01/30/2022 17:00	1	16
01/30/2022 18:00	1	8
01/30/2022 19:00	1	1
01/30/2022 20:00	1	1
01/30/2022 21:00	1	1
01/30/2022 22:00	1	1
01/30/2022 23:00	1	1
Average/Sum#:	1	4
Minimum:	1	1
Maximum:	1	16
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/06/2022 11:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
01/31/2022 00:00	1	1
01/31/2022 01:00	1	1
01/31/2022 02:00	15	1
01/31/2022 03:00	18	1
01/31/2022 04:00	18	1
01/31/2022 05:00	18	1
01/31/2022 06:00	4	1
01/31/2022 07:00	1	1
01/31/2022 08:00	1	1
01/31/2022 09:00	1	1
01/31/2022 10:00	1	1
01/31/2022 11:00	1	1
01/31/2022 12:00	1	1
01/31/2022 13:00	1	1
01/31/2022 14:00	1	1
01/31/2022 15:00	1	1
01/31/2022 16:00	1	1
01/31/2022 17:00	1	1
01/31/2022 18:00	1	1
01/31/2022 19:00	1	1
01/31/2022 20:00	1	1
01/31/2022 21:00	1	1
01/31/2022 22:00	1	1
01/31/2022 23:00	1	1
Average/Sum#:	4	1
Minimum:	1	1
Maximum:	18	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/06/2022 11:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
02/01/2022 00:00	1	1
02/01/2022 01:00	1	1
02/01/2022 02:00	1	1
02/01/2022 03:00	1	4
02/01/2022 04:00	1	5
02/01/2022 05:00	6	5
02/01/2022 06:00	8	5
02/01/2022 07:00	8	2
02/01/2022 08:00	7	1
02/01/2022 09:00	3	1
02/01/2022 10:00	1	1
02/01/2022 11:00	1	1
02/01/2022 12:00	1	1
02/01/2022 13:00	1	1
02/01/2022 14:00	1	1
02/01/2022 15:00	1	1
02/01/2022 16:00	1	1
02/01/2022 17:00	1	1
02/01/2022 18:00	1	1
02/01/2022 19:00	1	1
02/01/2022 20:00	1	1
02/01/2022 21:00	1	1
02/01/2022 22:00	1	1
02/01/2022 23:00	1	1
Average/Sum#:	2	2
Minimum:	1	1
Maximum:	8	5
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/06/2022 11:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
02/02/2022 00:00	1	1
02/02/2022 01:00	1	1
02/02/2022 02:00	1	1
02/02/2022 03:00	1	1
02/02/2022 04:00	1	1
02/02/2022 05:00	1	1
02/02/2022 06:00	1	1
02/02/2022 07:00	1	1
02/02/2022 08:00	1	1
02/02/2022 09:00	1	1
02/02/2022 10:00	1	1
02/02/2022 11:00	1	1
02/02/2022 12:00	1	1
02/02/2022 13:00	1	1
02/02/2022 14:00	1	1
02/02/2022 15:00	2	1
02/02/2022 16:00	7	1
02/02/2022 17:00	7	1
02/02/2022 18:00	6	1
02/02/2022 19:00	5	1
02/02/2022 20:00	1	1
02/02/2022 21:00	1	1
02/02/2022 22:00	1	1
02/02/2022 23:00	1	1
Average/Sum#:	2	1
Minimum:	1	1
Maximum:	7	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/06/2022 11:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
02/03/2022 00:00	1	1
02/03/2022 01:00	1	1
02/03/2022 02:00	1	1
02/03/2022 03:00	1	1
02/03/2022 04:00	1	1
02/03/2022 05:00	1	1
02/03/2022 06:00	1	1
02/03/2022 07:00	1	1
02/03/2022 08:00	1	1
02/03/2022 09:00	1	1
02/03/2022 10:00	1	1
02/03/2022 11:00	1	1
02/03/2022 12:00	1	1
02/03/2022 13:00	1	1
02/03/2022 14:00	1	1
02/03/2022 15:00	1	1
02/03/2022 16:00	1	1
02/03/2022 17:00	1	1
02/03/2022 18:00	1	1
02/03/2022 19:00	1	1
02/03/2022 20:00	1	1
02/03/2022 21:00	1	1
02/03/2022 22:00	1	1
02/03/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/06/2022 11:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
02/04/2022 00:00	1	1
02/04/2022 01:00	1	1
02/04/2022 02:00	1	1
02/04/2022 03:00	1	1
02/04/2022 04:00	1	1
02/04/2022 05:00	1	1
02/04/2022 06:00	1	1
02/04/2022 07:00	1	1
02/04/2022 08:00	1	2
02/04/2022 09:00	1	2
02/04/2022 10:00	1	2
02/04/2022 11:00	1	3
02/04/2022 12:00	1	5
02/04/2022 13:00	1	5
02/04/2022 14:00	1	5
02/04/2022 15:00	1	4
02/04/2022 16:00	7	1
02/04/2022 17:00	8	1
02/04/2022 18:00	8	1
02/04/2022 19:00	8	1
02/04/2022 20:00	2	1
02/04/2022 21:00	1	1
02/04/2022 22:00	1	1
02/04/2022 23:00	1	1
Average/Sum#:	2	2
Minimum:	1	1
Maximum:	8	5
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/06/2022 11:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
02/05/2022 00:00	1	1
02/05/2022 01:00	1	1
02/05/2022 02:00	1	1
02/05/2022 03:00	1	1
02/05/2022 04:00	1	1
02/05/2022 05:00	1	1
02/05/2022 06:00	1	1
02/05/2022 07:00	1	1
02/05/2022 08:00	1	1
02/05/2022 09:00	1	1
02/05/2022 10:00	1	1
02/05/2022 11:00	1	1
02/05/2022 12:00	1	1
02/05/2022 13:00	4	1
02/05/2022 14:00	7	1
02/05/2022 15:00	7	1
02/05/2022 16:00	7	1
02/05/2022 17:00	4	14
02/05/2022 18:00	1	18
02/05/2022 19:00	1	18
02/05/2022 20:00	1	17
02/05/2022 21:00	1	5
02/05/2022 22:00	1	1
02/05/2022 23:00	1	1
Average/Sum#:	2	4
Minimum:	1	1
Maximum:	7	18
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/06/2022 11:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
02/06/2022 00:00	1	1
02/06/2022 01:00	1	1
02/06/2022 02:00	1	1
02/06/2022 03:00	1	1
02/06/2022 04:00	1	1
02/06/2022 05:00	1	1
02/06/2022 06:00	1	1
02/06/2022 07:00	1	1
02/06/2022 08:00	2	2
02/06/2022 09:00	2	2
02/06/2022 10:00	2	2
02/06/2022 11:00	2	2
02/06/2022 12:00	2	2
02/06/2022 13:00	2	2
02/06/2022 14:00	5	2
02/06/2022 15:00	8	2
02/06/2022 16:00	8	2
02/06/2022 17:00	7	2
02/06/2022 18:00	4	2
02/06/2022 19:00	1	2
02/06/2022 20:00	1	2
02/06/2022 21:00	1	2
02/06/2022 22:00	1	2
02/06/2022 23:00	2	2
Average/Sum#:	2	2
Minimum:	1	1
Maximum:	8	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/06/2022 11:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
02/07/2022 00:00	2	2
02/07/2022 01:00	2	2
02/07/2022 02:00	2	2
02/07/2022 03:00	2	2
02/07/2022 04:00	2	2
02/07/2022 05:00	2	2
02/07/2022 06:00	2	2
02/07/2022 07:00	2	2
02/07/2022 08:00	2	2
02/07/2022 09:00	2	2
02/07/2022 10:00	2	2
02/07/2022 11:00	14	2
02/07/2022 12:00	16	2
02/07/2022 13:00	19	2
02/07/2022 14:00	18	2
02/07/2022 15:00	6	2
02/07/2022 16:00	4	16
02/07/2022 17:00	1	20
02/07/2022 18:00	1	20
02/07/2022 19:00	1	18
02/07/2022 20:00	1	5
02/07/2022 21:00	1	1
02/07/2022 22:00	1	1
02/07/2022 23:00	1	2
Average/Sum#:	4	5
Minimum:	1	1
Maximum:	19	20
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/06/2022 11:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
02/08/2022 00:00	1	2
02/08/2022 01:00	1	2
02/08/2022 02:00	1	2
02/08/2022 03:00	2	2
02/08/2022 04:00	4	2
02/08/2022 05:00	4	6
02/08/2022 06:00	3	8
02/08/2022 07:00	2	8
02/08/2022 08:00	1	7
02/08/2022 09:00	1	3
02/08/2022 10:00	1	1
02/08/2022 11:00	1	1
02/08/2022 12:00	1	1
02/08/2022 13:00	1	1
02/08/2022 14:00	1	1
02/08/2022 15:00	1	1
02/08/2022 16:00	1	1
02/08/2022 17:00	1	1
02/08/2022 18:00	1	1
02/08/2022 19:00	1	1
02/08/2022 20:00	1	1
02/08/2022 21:00	1	1
02/08/2022 22:00	1	1
02/08/2022 23:00	1	1
Average/Sum#:	1	2
Minimum:	1	1
Maximum:	4	8
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/06/2022 11:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
02/09/2022 00:00	1	1
02/09/2022 01:00	1	1
02/09/2022 02:00	1	1
02/09/2022 03:00	1	1
02/09/2022 04:00	1	1
02/09/2022 05:00	1	1
02/09/2022 06:00	1	1
02/09/2022 07:00	1	1
02/09/2022 08:00	1	1
02/09/2022 09:00	1	1
02/09/2022 10:00	1	1
02/09/2022 11:00	1	1
02/09/2022 12:00	1	1
02/09/2022 13:00	1	1
02/09/2022 14:00	1	1
02/09/2022 15:00	1	1
02/09/2022 16:00	1	13
02/09/2022 17:00	1	13
02/09/2022 18:00	1	13
02/09/2022 19:00	1	13
02/09/2022 20:00	1	1
02/09/2022 21:00	1	1
02/09/2022 22:00	1	1
02/09/2022 23:00	1	1
Average/Sum#:	1	3
Minimum:	1	1
Maximum:	1	13
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/06/2022 11:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
02/10/2022 00:00	1	1
02/10/2022 01:00	1	1
02/10/2022 02:00	1	1
02/10/2022 03:00	1	1
02/10/2022 04:00	1	1
02/10/2022 05:00	1	1
02/10/2022 06:00	1	1
02/10/2022 07:00	1	1
02/10/2022 08:00	2	2
02/10/2022 09:00	2	2
02/10/2022 10:00	2	2
02/10/2022 11:00	2	2
02/10/2022 12:00	4	2
02/10/2022 13:00	4	2
02/10/2022 14:00	3	2
02/10/2022 15:00	3	4
02/10/2022 16:00	1	10
02/10/2022 17:00	1	10
02/10/2022 18:00	1	8
02/10/2022 19:00	1	7
02/10/2022 20:00	1	1
02/10/2022 21:00	1	1
02/10/2022 22:00	1	1
02/10/2022 23:00	1	1
Average/Sum#:	2	3
Minimum:	1	1
Maximum:	4	10
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/06/2022 11:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
02/11/2022 00:00	1	1
02/11/2022 01:00	2	4
02/11/2022 02:00	2	4
02/11/2022 03:00	2	4
02/11/2022 04:00	2	4
02/11/2022 05:00	2	4
02/11/2022 06:00	2	4
02/11/2022 07:00	2	4
02/11/2022 08:00	2	4
02/11/2022 09:00	2	4
02/11/2022 10:00	2	4
02/11/2022 11:00	2	4
02/11/2022 12:00	2	4
02/11/2022 13:00	2	4
02/11/2022 14:00	2	4
02/11/2022 15:00	2	4
02/11/2022 16:00	2	4
02/11/2022 17:00	2	4
02/11/2022 18:00	2	4
02/11/2022 19:00	2	4
02/11/2022 20:00	2	4
02/11/2022 21:00	2	4
02/11/2022 22:00	2	4
02/11/2022 23:00	2	4
Average/Sum#:	2	4
Minimum:	1	1
Maximum:	2	4
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/06/2022 11:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
02/12/2022 00:00	2	4
02/12/2022 01:00	2	4
02/12/2022 02:00	2	4
02/12/2022 03:00	2	4
02/12/2022 04:00	2	4
02/12/2022 05:00	2	4
02/12/2022 06:00	2	4
02/12/2022 07:00	2	4
02/12/2022 08:00	2	4
02/12/2022 09:00	2	4
02/12/2022 10:00	2	4
02/12/2022 11:00	2	4
02/12/2022 12:00	2	4
02/12/2022 13:00	2	4
02/12/2022 14:00	2	4
02/12/2022 15:00	2	4
02/12/2022 16:00	2	4
02/12/2022 17:00	2	4
02/12/2022 18:00	2	4
02/12/2022 19:00	2	4
02/12/2022 20:00	2	4
02/12/2022 21:00	2	4
02/12/2022 22:00	2	4
02/12/2022 23:00	2	4
Average/Sum#:	2	4
Minimum:	2	4
Maximum:	2	4
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/06/2022 11:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
02/13/2022 00:00	2	4
02/13/2022 01:00	2	4
02/13/2022 02:00	2	4
02/13/2022 03:00	2	4
02/13/2022 04:00	2	4
02/13/2022 05:00	2	4
02/13/2022 06:00	2	4
02/13/2022 07:00	2	4
02/13/2022 08:00	2	4
02/13/2022 09:00	2	4
02/13/2022 10:00	2	4
02/13/2022 11:00	2	4
02/13/2022 12:00	2	4
02/13/2022 13:00	2	4
02/13/2022 14:00	2	4
02/13/2022 15:00	2	4
02/13/2022 16:00	2	4
02/13/2022 17:00	2	4
02/13/2022 18:00	2	4
02/13/2022 19:00	2	4
02/13/2022 20:00	2	4
02/13/2022 21:00	2	4
02/13/2022 22:00	2	4
02/13/2022 23:00	2	4
Average/Sum#:	2	4
Minimum:	2	4
Maximum:	2	4
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/06/2022 11:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
02/14/2022 00:00	2	4
02/14/2022 01:00	2	4
02/14/2022 02:00	2	4
02/14/2022 03:00	2	4
02/14/2022 04:00	2	4
02/14/2022 05:00	2	4
02/14/2022 06:00	2	4
02/14/2022 07:00	2	4
02/14/2022 08:00	2	4
02/14/2022 09:00	2	4
02/14/2022 10:00	2	4
02/14/2022 11:00	2	4
02/14/2022 12:00	2	4
02/14/2022 13:00	2	4
02/14/2022 14:00	2	4
02/14/2022 15:00	2	4
02/14/2022 16:00	2	4
02/14/2022 17:00	2	4
02/14/2022 18:00	2	4
02/14/2022 19:00	2	4
02/14/2022 20:00	2	4
02/14/2022 21:00	2	4
02/14/2022 22:00	2	4
02/14/2022 23:00	2	4
Average/Sum#:	2	4
Minimum:	2	4
Maximum:	2	4
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/06/2022 11:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
02/15/2022 00:00	2	4
02/15/2022 01:00	2	4
02/15/2022 02:00	2	4
02/15/2022 03:00	2	4
02/15/2022 04:00	2	4
02/15/2022 05:00	2	4
02/15/2022 06:00	2	4
02/15/2022 07:00	2	4
02/15/2022 08:00	2	4
02/15/2022 09:00	2	4
02/15/2022 10:00	2	4
02/15/2022 11:00	2	4
02/15/2022 12:00	2	4
02/15/2022 13:00	2	4
02/15/2022 14:00	2	4
02/15/2022 15:00	2	4
02/15/2022 16:00	2	4
02/15/2022 17:00	2	4
02/15/2022 18:00	2	4
02/15/2022 19:00	2	4
02/15/2022 20:00	2	4
02/15/2022 21:00	2	4
02/15/2022 22:00	2	4
02/15/2022 23:00	2	4
Average/Sum#:	2	4
Minimum:	2	4
Maximum:	2	4
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/06/2022 11:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
02/16/2022 00:00	2	4
02/16/2022 01:00	2	4
02/16/2022 02:00	2	4
02/16/2022 03:00	2	4
02/16/2022 04:00	2	4
02/16/2022 05:00	2	4
02/16/2022 06:00	2	4
02/16/2022 07:00	2	4
02/16/2022 08:00	2	4
02/16/2022 09:00	2	4
02/16/2022 10:00	2	4
02/16/2022 11:00	2	4
02/16/2022 12:00	2	4
02/16/2022 13:00	2	4
02/16/2022 14:00	2	4
02/16/2022 15:00	2	4
02/16/2022 16:00	2	4
02/16/2022 17:00	2	4
02/16/2022 18:00	2	4
02/16/2022 19:00	2	4
02/16/2022 20:00	2	4
02/16/2022 21:00	2	4
02/16/2022 22:00	2	4
02/16/2022 23:00	2	4
Average/Sum#:	2	4
Minimum:	2	4
Maximum:	2	4
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/06/2022 11:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
02/17/2022 00:00	2	4
02/17/2022 01:00	2	4
02/17/2022 02:00	2	4
02/17/2022 03:00	2	4
02/17/2022 04:00	2	4
02/17/2022 05:00	2	4
02/17/2022 06:00	2	4
02/17/2022 07:00	2	4
02/17/2022 08:00	2	4
02/17/2022 09:00	2	4
02/17/2022 10:00	2	4
02/17/2022 11:00	2	4
02/17/2022 12:00	2	4
02/17/2022 13:00	2	4
02/17/2022 14:00	2	4
02/17/2022 15:00	2	4
02/17/2022 16:00	2	4
02/17/2022 17:00	2	4
02/17/2022 18:00	2	4
02/17/2022 19:00	2	4
02/17/2022 20:00	2	4
02/17/2022 21:00	2	4
02/17/2022 22:00	2	4
02/17/2022 23:00	2	4
Average/Sum#:	2	4
Minimum:	2	4
Maximum:	2	4
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/06/2022 11:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
02/18/2022 00:00	2	4
02/18/2022 01:00	2	4
02/18/2022 02:00	2	4
02/18/2022 03:00	2	4
02/18/2022 04:00	2	4
02/18/2022 05:00	2	4
02/18/2022 06:00	2	4
02/18/2022 07:00	2	4
02/18/2022 08:00	8	4
02/18/2022 09:00	23	4
02/18/2022 10:00	26	4
02/18/2022 11:00	30	4
02/18/2022 12:00	27	4
02/18/2022 13:00	12	4
02/18/2022 14:00	9	4
02/18/2022 15:00	4	21
02/18/2022 16:00	1	26
02/18/2022 17:00	1	26
02/18/2022 18:00	1	23
02/18/2022 19:00	1	6
02/18/2022 20:00	1	1
02/18/2022 21:00	1	1
02/18/2022 22:00	1	1
02/18/2022 23:00	1	1
Average/Sum#:	7	7
Minimum:	1	1
Maximum:	30	26
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/06/2022 11:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
02/19/2022 00:00	1	1
02/19/2022 01:00	1	1
02/19/2022 02:00	1	1
02/19/2022 03:00	1	1
02/19/2022 04:00	1	1
02/19/2022 05:00	1	1
02/19/2022 06:00	1	1
02/19/2022 07:00	1	1
02/19/2022 08:00	1	1
02/19/2022 09:00	1	1
02/19/2022 10:00	1	1
02/19/2022 11:00	1	1
02/19/2022 12:00	1	1
02/19/2022 13:00	1	1
02/19/2022 14:00	1	1
02/19/2022 15:00	1	1
02/19/2022 16:00	1	1
02/19/2022 17:00	1	1
02/19/2022 18:00	1	1
02/19/2022 19:00	1	1
02/19/2022 20:00	1	1
02/19/2022 21:00	1	1
02/19/2022 22:00	1	1
02/19/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/06/2022 11:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
02/20/2022 00:00	1	1
02/20/2022 01:00	1	1
02/20/2022 02:00	1	1
02/20/2022 03:00	1	1
02/20/2022 04:00	1	1
02/20/2022 05:00	1	1
02/20/2022 06:00	1	1
02/20/2022 07:00	1	1
02/20/2022 08:00	1	1
02/20/2022 09:00	1	1
02/20/2022 10:00	1	1
02/20/2022 11:00	1	1
02/20/2022 12:00	1	1
02/20/2022 13:00	1	1
02/20/2022 14:00	1	1
02/20/2022 15:00	1	1
02/20/2022 16:00	1	1
02/20/2022 17:00	1	1
02/20/2022 18:00	1	1
02/20/2022 19:00	1	1
02/20/2022 20:00	1	1
02/20/2022 21:00	1	1
02/20/2022 22:00	1	1
02/20/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/06/2022 11:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
02/21/2022 00:00	1	1
02/21/2022 01:00	1	1
02/21/2022 02:00	1	1
02/21/2022 03:00	1	1
02/21/2022 04:00	1	1
02/21/2022 05:00	1	1
02/21/2022 06:00	1	1
02/21/2022 07:00	1	1
02/21/2022 08:00	1	1
02/21/2022 09:00	1	1
02/21/2022 10:00	1	1
02/21/2022 11:00	1	1
02/21/2022 12:00	1	1
02/21/2022 13:00	1	1
02/21/2022 14:00	1	1
02/21/2022 15:00	1	1
02/21/2022 16:00	1	1
02/21/2022 17:00	1	1
02/21/2022 18:00	1	1
02/21/2022 19:00	1	1
02/21/2022 20:00	1	1
02/21/2022 21:00	1	1
02/21/2022 22:00	1	1
02/21/2022 23:00	16	1
Average/Sum#:	2	1
Minimum:	1	1
Maximum:	16	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/06/2022 11:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
02/22/2022 00:00	23	1
02/22/2022 01:00	26	1
02/22/2022 02:00	26	1
02/22/2022 03:00	11	1
02/22/2022 04:00	4	15
02/22/2022 05:00	1	21
02/22/2022 06:00	1	21
02/22/2022 07:00	1	20
02/22/2022 08:00	1	7
02/22/2022 09:00	1	1
02/22/2022 10:00	1	1
02/22/2022 11:00	1	1
02/22/2022 12:00	1	1
02/22/2022 13:00	1	1
02/22/2022 14:00	1	1
02/22/2022 15:00	1	1
02/22/2022 16:00	1	1
02/22/2022 17:00	1	1
02/22/2022 18:00	1	1
02/22/2022 19:00	1	1
02/22/2022 20:00	1	1
02/22/2022 21:00	1	1
02/22/2022 22:00	1	1
02/22/2022 23:00	1	1
Average/Sum#:	5	4
Minimum:	1	1
Maximum:	26	21
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/06/2022 11:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
02/23/2022 00:00	1	1
02/23/2022 01:00	1	1
02/23/2022 02:00	1	1
02/23/2022 03:00	1	1
02/23/2022 04:00	1	1
02/23/2022 05:00	1	1
02/23/2022 06:00	1	1
02/23/2022 07:00	1	1
02/23/2022 08:00	1	1
02/23/2022 09:00	1	1
02/23/2022 10:00	1	1
02/23/2022 11:00	1	1
02/23/2022 12:00	1	1
02/23/2022 13:00	1	1
02/23/2022 14:00	1	1
02/23/2022 15:00	1	1
02/23/2022 16:00	1	1
02/23/2022 17:00	1	1
02/23/2022 18:00	1	1
02/23/2022 19:00	1	1
02/23/2022 20:00	1	1
02/23/2022 21:00	1	1
02/23/2022 22:00	1	1
02/23/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/06/2022 11:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
02/24/2022 00:00	1	1
02/24/2022 01:00	1	1
02/24/2022 02:00	1	1
02/24/2022 03:00	1	1
02/24/2022 04:00	1	1
02/24/2022 05:00	1	1
02/24/2022 06:00	1	1
02/24/2022 07:00	1	1
02/24/2022 08:00	1	1
02/24/2022 09:00	1	1
02/24/2022 10:00	1	1
02/24/2022 11:00	1	1
02/24/2022 12:00	1	1
02/24/2022 13:00	1	1
02/24/2022 14:00	1	1
02/24/2022 15:00	1	1
02/24/2022 16:00	1	1
02/24/2022 17:00	1	1
02/24/2022 18:00	1	1
02/24/2022 19:00	1	1
02/24/2022 20:00	1	1
02/24/2022 21:00	1	1
02/24/2022 22:00	1	1
02/24/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/06/2022 11:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
02/25/2022 00:00	1	1
02/25/2022 01:00	1	1
02/25/2022 02:00	1	1
02/25/2022 03:00	1	1
02/25/2022 04:00	1	1
02/25/2022 05:00	1	1
02/25/2022 06:00	1	1
02/25/2022 07:00	1	1
02/25/2022 08:00	1	1
02/25/2022 09:00	1	1
02/25/2022 10:00	1	1
02/25/2022 11:00	1	1
02/25/2022 12:00	1	1
02/25/2022 13:00	1	1
02/25/2022 14:00	1	1
02/25/2022 15:00	1	1
02/25/2022 16:00	1	1
02/25/2022 17:00	1	1
02/25/2022 18:00	1	1
02/25/2022 19:00	1	1
02/25/2022 20:00	1	1
02/25/2022 21:00	1	1
02/25/2022 22:00	1	1
02/25/2022 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/06/2022 11:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
02/26/2022 00:00	1	1
02/26/2022 01:00	1	1
02/26/2022 02:00	1	1
02/26/2022 03:00	1	1
02/26/2022 04:00	1	1
02/26/2022 05:00	1	1
02/26/2022 06:00	1	1
02/26/2022 07:00	1	2
02/26/2022 08:00	1	2
02/26/2022 09:00	1	2
02/26/2022 10:00	1	2
02/26/2022 11:00	1	2
02/26/2022 12:00	1	2
02/26/2022 13:00	1	2
02/26/2022 14:00	1	2
02/26/2022 15:00	12	2
02/26/2022 16:00	17	2
02/26/2022 17:00	17	2
02/26/2022 18:00	16	2
02/26/2022 19:00	5	2
02/26/2022 20:00	1	2
02/26/2022 21:00	1	2
02/26/2022 22:00	1	2
02/26/2022 23:00	2	2
Average/Sum#:	4	2
Minimum:	1	1
Maximum:	17	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/06/2022 11:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
02/27/2022 00:00	2	2
02/27/2022 01:00	2	2
02/27/2022 02:00	2	2
02/27/2022 03:00	2	2
02/27/2022 04:00	2	2
02/27/2022 05:00	2	2
02/27/2022 06:00	2	2
02/27/2022 07:00	2	2
02/27/2022 08:00	2	2
02/27/2022 09:00	2	2
02/27/2022 10:00	2	2
02/27/2022 11:00	2	2
02/27/2022 12:00	2	2
02/27/2022 13:00	2	2
02/27/2022 14:00	2	2
02/27/2022 15:00	2	2
02/27/2022 16:00	2	2
02/27/2022 17:00	2	2
02/27/2022 18:00	2	2
02/27/2022 19:00	2	2
02/27/2022 20:00	2	2
02/27/2022 21:00	2	2
02/27/2022 22:00	2	2
02/27/2022 23:00	2	2
Average/Sum#:	2	2
Minimum:	2	2
Maximum:	2	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/06/2022 11:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
02/28/2022 00:00	2	2
02/28/2022 01:00	2	2
02/28/2022 02:00	2	2
02/28/2022 03:00	2	2
02/28/2022 04:00	2	2
02/28/2022 05:00	2	2
02/28/2022 06:00	2	2
02/28/2022 07:00	2	2
02/28/2022 08:00	2	2
02/28/2022 09:00	2	2
02/28/2022 10:00	2	2
02/28/2022 11:00	2	2
02/28/2022 12:00	2	2
02/28/2022 13:00	17	2
02/28/2022 14:00	22	2
02/28/2022 15:00	25	2
02/28/2022 16:00	24	2
02/28/2022 17:00	8	2
02/28/2022 18:00	4	2
02/28/2022 19:00	1	2
02/28/2022 20:00	1	2
02/28/2022 21:00	1	2
02/28/2022 22:00	1	2
02/28/2022 23:00	1	2
Average/Sum#:	5	2
Minimum:	1	2
Maximum:	25	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/06/2022 11:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
03/01/2022 00:00	1	2
03/01/2022 01:00	1	2
03/01/2022 02:00	1	2
03/01/2022 03:00	1	2
03/01/2022 04:00	1	2
03/01/2022 05:00	1	2
03/01/2022 06:00	1	2
03/01/2022 07:00	1	2
03/01/2022 08:00	1	2
03/01/2022 09:00	1	2
03/01/2022 10:00	1	2
03/01/2022 11:00	1	2
03/01/2022 12:00	1	2
03/01/2022 13:00	1	2
03/01/2022 14:00	1	2
03/01/2022 15:00	1	2
03/01/2022 16:00	1	2
03/01/2022 17:00	1	2
03/01/2022 18:00	1	2
03/01/2022 19:00	1	2
03/01/2022 20:00	1	2
03/01/2022 21:00	1	2
03/01/2022 22:00	1	2
03/01/2022 23:00	1	2
Average/Sum#:	1	2
Minimum:	1	2
Maximum:	1	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/06/2022 11:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
03/02/2022 00:00	1	2
03/02/2022 01:00	1	2
03/02/2022 02:00	1	2
03/02/2022 03:00	1	2
03/02/2022 04:00	1	2
03/02/2022 05:00	1	2
03/02/2022 06:00	1	2
03/02/2022 07:00	1	2
03/02/2022 08:00	1	2
03/02/2022 09:00	1	2
03/02/2022 10:00	1	2
03/02/2022 11:00	1	2
03/02/2022 12:00	1	2
03/02/2022 13:00	1	2
03/02/2022 14:00	1	2
03/02/2022 15:00	1	2
03/02/2022 16:00	1	2
03/02/2022 17:00	1	2
03/02/2022 18:00	1	2
03/02/2022 19:00	1	2
03/02/2022 20:00	1	2
03/02/2022 21:00	1	2
03/02/2022 22:00	1	2
03/02/2022 23:00	1	2
Average/Sum#:	1	2
Minimum:	1	2
Maximum:	1	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/06/2022 11:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
03/03/2022 00:00	1	2
03/03/2022 01:00	1	2
03/03/2022 02:00	1	2
03/03/2022 03:00	1	2
03/03/2022 04:00	1	2
03/03/2022 05:00	1	2
03/03/2022 06:00	1	2
03/03/2022 07:00	1	2
03/03/2022 08:00	1	2
03/03/2022 09:00	1	2
03/03/2022 10:00	1	2
03/03/2022 11:00	1	2
03/03/2022 12:00	1	2
03/03/2022 13:00	1	2
03/03/2022 14:00	1	2
03/03/2022 15:00	1	2
03/03/2022 16:00	1	2
03/03/2022 17:00	1	2
03/03/2022 18:00	1	2
03/03/2022 19:00	1	2
03/03/2022 20:00	1	2
03/03/2022 21:00	1	2
03/03/2022 22:00	1	2
03/03/2022 23:00	1	2
Average/Sum#:	1	2
Minimum:	1	2
Maximum:	1	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/06/2022 11:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
03/04/2022 00:00	1	2
03/04/2022 01:00	1	2
03/04/2022 02:00	1	2
03/04/2022 03:00	1	2
03/04/2022 04:00	1	2
03/04/2022 05:00	1	2
03/04/2022 06:00	1	2
03/04/2022 07:00	1	2
03/04/2022 08:00	1	2
03/04/2022 09:00	1	2
03/04/2022 10:00	1	2
03/04/2022 11:00	1	2
03/04/2022 12:00	1	2
03/04/2022 13:00	1	2
03/04/2022 14:00	1	2
03/04/2022 15:00	1	2
03/04/2022 16:00	1	2
03/04/2022 17:00	1	2
03/04/2022 18:00	1	2
03/04/2022 19:00	1	2
03/04/2022 20:00	1	2
03/04/2022 21:00	1	2
03/04/2022 22:00	1	2
03/04/2022 23:00	1	2
Average/Sum#:	1	2
Minimum:	1	2
Maximum:	1	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/06/2022 11:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
03/05/2022 00:00	1	2
03/05/2022 01:00	1	2
03/05/2022 02:00	1	2
03/05/2022 03:00	1	2
03/05/2022 04:00	1	2
03/05/2022 05:00	1	2
03/05/2022 06:00	1	2
03/05/2022 07:00	1	2
03/05/2022 08:00	1	2
03/05/2022 09:00	1	2
03/05/2022 10:00	1	2
03/05/2022 11:00	1	2
03/05/2022 12:00	1	2
03/05/2022 13:00	1	2
03/05/2022 14:00	1	2
03/05/2022 15:00	1	2
03/05/2022 16:00	1	2
03/05/2022 17:00	1	2
03/05/2022 18:00	1	2
03/05/2022 19:00	1	2
03/05/2022 20:00	1	2
03/05/2022 21:00	1	2
03/05/2022 22:00	1	2
03/05/2022 23:00	1	2
Average/Sum#:	1	2
Minimum:	1	2
Maximum:	1	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/06/2022 11:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
03/06/2022 00:00	1	2
03/06/2022 01:00	1	2
03/06/2022 02:00	1	2
03/06/2022 03:00	1	2
03/06/2022 04:00	1	2
03/06/2022 05:00	1	2
03/06/2022 06:00	1	2
03/06/2022 07:00	1	2
03/06/2022 08:00	1	2
03/06/2022 09:00	1	2
03/06/2022 10:00	1	2
03/06/2022 11:00	1	2
03/06/2022 12:00	1	2
03/06/2022 13:00	1	2
03/06/2022 14:00	1	2
03/06/2022 15:00	1	2
03/06/2022 16:00	1	2
03/06/2022 17:00	1	2
03/06/2022 18:00	1	2
03/06/2022 19:00	1	2
03/06/2022 20:00	1	2
03/06/2022 21:00	1	2
03/06/2022 22:00	1	2
03/06/2022 23:00	1	2
Average/Sum#:	1	2
Minimum:	1	2
Maximum:	1	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/06/2022 11:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
03/07/2022 00:00	1	2
03/07/2022 01:00	1	2
03/07/2022 02:00	1	2
03/07/2022 03:00	1	2
03/07/2022 04:00	1	2
03/07/2022 05:00	1	2
03/07/2022 06:00	1	2
03/07/2022 07:00	1	2
03/07/2022 08:00	1	2
03/07/2022 09:00	1	2
03/07/2022 10:00	1	2
03/07/2022 11:00	1	2
03/07/2022 12:00	1	2
03/07/2022 13:00	1	2
03/07/2022 14:00	1	2
03/07/2022 15:00	1	2
03/07/2022 16:00	1	2
03/07/2022 17:00	1	2
03/07/2022 18:00	1	2
03/07/2022 19:00	1	2
03/07/2022 20:00	1	2
03/07/2022 21:00	1	2
03/07/2022 22:00	1	2
03/07/2022 23:00	1	2
Average/Sum#:	1	2
Minimum:	1	2
Maximum:	1	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/06/2022 11:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
03/08/2022 00:00	1	2
03/08/2022 01:00	1	2
03/08/2022 02:00	1	2
03/08/2022 03:00	1	2
03/08/2022 04:00	1	2
03/08/2022 05:00	1	2
03/08/2022 06:00	1	2
03/08/2022 07:00	1	2
03/08/2022 08:00	1	2
03/08/2022 09:00	1	2
03/08/2022 10:00	1	2
03/08/2022 11:00	1	2
03/08/2022 12:00	1	2
03/08/2022 13:00	1	2
03/08/2022 14:00	1	2
03/08/2022 15:00	1	2
03/08/2022 16:00	1	2
03/08/2022 17:00	1	2
03/08/2022 18:00	1	2
03/08/2022 19:00	1	2
03/08/2022 20:00	1	2
03/08/2022 21:00	1	2
03/08/2022 22:00	1	2
03/08/2022 23:00	1	2
Average/Sum#:	1	2
Minimum:	1	2
Maximum:	1	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/06/2022 11:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
03/09/2022 00:00	1	2
03/09/2022 01:00	1	2
03/09/2022 02:00	1	2
03/09/2022 03:00	1	2
03/09/2022 04:00	1	2
03/09/2022 05:00	1	2
03/09/2022 06:00	1	2
03/09/2022 07:00	1	2
03/09/2022 08:00	1	2
03/09/2022 09:00	1	2
03/09/2022 10:00	1	2
03/09/2022 11:00	1	2
03/09/2022 12:00	1	2
03/09/2022 13:00	1	2
03/09/2022 14:00	1	2
03/09/2022 15:00	1	2
03/09/2022 16:00	1	2
03/09/2022 17:00	1	2
03/09/2022 18:00	1	2
03/09/2022 19:00	1	2
03/09/2022 20:00	1	2
03/09/2022 21:00	1	2
03/09/2022 22:00	1	2
03/09/2022 23:00	1	2
Average/Sum#:	1	2
Minimum:	1	2
Maximum:	1	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/06/2022 11:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
03/10/2022 00:00	1	2
03/10/2022 01:00	1	2
03/10/2022 02:00	1	2
03/10/2022 03:00	1	2
03/10/2022 04:00	1	2
03/10/2022 05:00	1	2
03/10/2022 06:00	1	2
03/10/2022 07:00	1	2
03/10/2022 08:00	1	2
03/10/2022 09:00	1	2
03/10/2022 10:00	1	2
03/10/2022 11:00	1	2
03/10/2022 12:00	1	2
03/10/2022 13:00	1	2
03/10/2022 14:00	1	2
03/10/2022 15:00	1	2
03/10/2022 16:00	1	2
03/10/2022 17:00	1	2
03/10/2022 18:00	1	2
03/10/2022 19:00	1	2
03/10/2022 20:00	1	2
03/10/2022 21:00	1	2
03/10/2022 22:00	1	2
03/10/2022 23:00	1	2
Average/Sum#:	1	2
Minimum:	1	2
Maximum:	1	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/06/2022 11:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
03/11/2022 00:00	1	2
03/11/2022 01:00	1	2
03/11/2022 02:00	1	2
03/11/2022 03:00	1	2
03/11/2022 04:00	1	2
03/11/2022 05:00	1	2
03/11/2022 06:00	1	2
03/11/2022 07:00	1	2
03/11/2022 08:00	1	2
03/11/2022 09:00	1	2
03/11/2022 10:00	1	2
03/11/2022 11:00	1	2
03/11/2022 12:00	1	2
03/11/2022 13:00	1	2
03/11/2022 14:00	1	2
03/11/2022 15:00	1	2
03/11/2022 16:00	1	2
03/11/2022 17:00	1	2
03/11/2022 18:00	1	2
03/11/2022 19:00	1	2
03/11/2022 20:00	1	2
03/11/2022 21:00	1	2
03/11/2022 22:00	1	2
03/11/2022 23:00	1	2
Average/Sum#:	1	2
Minimum:	1	2
Maximum:	1	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/06/2022 11:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
03/12/2022 00:00	1	2
03/12/2022 01:00	1	2
03/12/2022 02:00	1	2
03/12/2022 03:00	1	2
03/12/2022 04:00	1	2
03/12/2022 05:00	1	2
03/12/2022 06:00	1	2
03/12/2022 07:00	1	2
03/12/2022 08:00	1	2
03/12/2022 09:00	1	2
03/12/2022 10:00	1	2
03/12/2022 11:00	1	2
03/12/2022 12:00	1	2
03/12/2022 13:00	1	2
03/12/2022 14:00	1	2
03/12/2022 15:00	1	2
03/12/2022 16:00	1	2
03/12/2022 17:00	1	2
03/12/2022 18:00	1	2
03/12/2022 19:00	1	2
03/12/2022 20:00	1	2
03/12/2022 21:00	1	2
03/12/2022 22:00	1	2
03/12/2022 23:00	1	2
Average/Sum#:	1	2
Minimum:	1	2
Maximum:	1	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/06/2022 11:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
03/13/2022 00:00	1	2
03/13/2022 01:00	1	2
03/13/2022 02:00	1	2
03/13/2022 03:00	1	2
03/13/2022 04:00	1	2
03/13/2022 05:00	1	2
03/13/2022 06:00	1	2
03/13/2022 07:00	1	2
03/13/2022 08:00	1	2
03/13/2022 09:00	1	2
03/13/2022 10:00	1	2
03/13/2022 11:00	1	2
03/13/2022 12:00	1	2
03/13/2022 13:00	1	2
03/13/2022 14:00	1	2
03/13/2022 15:00	1	2
03/13/2022 16:00	1	2
03/13/2022 17:00	1	2
03/13/2022 18:00	1	2
03/13/2022 19:00	1	2
03/13/2022 20:00	1	2
03/13/2022 21:00	1	2
03/13/2022 22:00	1	2
03/13/2022 23:00	1	2
Average/Sum#:	1	2
Minimum:	1	2
Maximum:	1	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/06/2022 11:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
03/14/2022 00:00	1	2
03/14/2022 01:00	1	2
03/14/2022 02:00	1	2
03/14/2022 03:00	1	2
03/14/2022 04:00	1	2
03/14/2022 05:00	1	2
03/14/2022 06:00	1	2
03/14/2022 07:00	1	2
03/14/2022 08:00	1	2
03/14/2022 09:00	1	2
03/14/2022 10:00	1	2
03/14/2022 11:00	1	2
03/14/2022 12:00	1	2
03/14/2022 13:00	1	2
03/14/2022 14:00	1	2
03/14/2022 15:00	1	2
03/14/2022 16:00	1	2
03/14/2022 17:00	1	2
03/14/2022 18:00	1	2
03/14/2022 19:00	1	2
03/14/2022 20:00	1	2
03/14/2022 21:00	1	2
03/14/2022 22:00	1	2
03/14/2022 23:00	1	2
Average/Sum#:	1	2
Minimum:	1	2
Maximum:	1	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/06/2022 11:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
03/15/2022 00:00	1	2
03/15/2022 01:00	1	2
03/15/2022 02:00	1	2
03/15/2022 03:00	1	2
03/15/2022 04:00	1	2
03/15/2022 05:00	1	2
03/15/2022 06:00	1	2
03/15/2022 07:00	1	2
03/15/2022 08:00	1	2
03/15/2022 09:00	1	2
03/15/2022 10:00	1	2
03/15/2022 11:00	1	2
03/15/2022 12:00	1	2
03/15/2022 13:00	1	2
03/15/2022 14:00	1	2
03/15/2022 15:00	1	2
03/15/2022 16:00	1	2
03/15/2022 17:00	1	2
03/15/2022 18:00	1	2
03/15/2022 19:00	1	2
03/15/2022 20:00	1	2
03/15/2022 21:00	1	2
03/15/2022 22:00	1	2
03/15/2022 23:00	1	2
Average/Sum#:	1	2
Minimum:	1	2
Maximum:	1	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/06/2022 11:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
03/16/2022 00:00	1	2
03/16/2022 01:00	1	2
03/16/2022 02:00	1	2
03/16/2022 03:00	1	2
03/16/2022 04:00	1	2
03/16/2022 05:00	1	2
03/16/2022 06:00	1	2
03/16/2022 07:00	1	2
03/16/2022 08:00	1	2
03/16/2022 09:00	1	2
03/16/2022 10:00	1	2
03/16/2022 11:00	1	2
03/16/2022 12:00	1	2
03/16/2022 13:00	1	2
03/16/2022 14:00	1	2
03/16/2022 15:00	1	2
03/16/2022 16:00	1	2
03/16/2022 17:00	1	2
03/16/2022 18:00	1	2
03/16/2022 19:00	1	2
03/16/2022 20:00	1	2
03/16/2022 21:00	1	2
03/16/2022 22:00	1	2
03/16/2022 23:00	1	2
Average/Sum#:	1	2
Minimum:	1	2
Maximum:	1	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/06/2022 11:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
03/17/2022 00:00	1	2
03/17/2022 01:00	1	2
03/17/2022 02:00	1	2
03/17/2022 03:00	1	2
03/17/2022 04:00	1	2
03/17/2022 05:00	1	2
03/17/2022 06:00	1	2
03/17/2022 07:00	1	2
03/17/2022 08:00	1	2
03/17/2022 09:00	1	2
03/17/2022 10:00	1	2
03/17/2022 11:00	1	2
03/17/2022 12:00	1	2
03/17/2022 13:00	1	2
03/17/2022 14:00	1	2
03/17/2022 15:00	1	2
03/17/2022 16:00	1	2
03/17/2022 17:00	1	2
03/17/2022 18:00	1	2
03/17/2022 19:00	1	2
03/17/2022 20:00	1	2
03/17/2022 21:00	1	2
03/17/2022 22:00	1	2
03/17/2022 23:00	1	2
Average/Sum#:	1	2
Minimum:	1	2
Maximum:	1	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/06/2022 11:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
03/18/2022 00:00	1	2
03/18/2022 01:00	1	2
03/18/2022 02:00	1	2
03/18/2022 03:00	1	2
03/18/2022 04:00	1	2
03/18/2022 05:00	1	2
03/18/2022 06:00	1	2
03/18/2022 07:00	1	2
03/18/2022 08:00	1	2
03/18/2022 09:00	1	2
03/18/2022 10:00	1	2
03/18/2022 11:00	1	2
03/18/2022 12:00	1	2
03/18/2022 13:00	1	2
03/18/2022 14:00	1	2
03/18/2022 15:00	1	2
03/18/2022 16:00	1	2
03/18/2022 17:00	1	2
03/18/2022 18:00	1	2
03/18/2022 19:00	1	2
03/18/2022 20:00	1	2
03/18/2022 21:00	1	2
03/18/2022 22:00	1	2
03/18/2022 23:00	1	2
Average/Sum#:	1	2
Minimum:	1	2
Maximum:	1	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/06/2022 11:39 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
03/19/2022 00:00	1	2
03/19/2022 01:00	1	2
03/19/2022 02:00	1	2
03/19/2022 03:00	1	2
03/19/2022 04:00	1	2
03/19/2022 05:00	1	2
03/19/2022 06:00	1	2
03/19/2022 07:00	1	2
03/19/2022 08:00	1	2
03/19/2022 09:00	1	2
03/19/2022 10:00	1	2
03/19/2022 11:00	1	2
03/19/2022 12:00	1	2
03/19/2022 13:00	1	2
03/19/2022 14:00	1	2
03/19/2022 15:00	1	2
03/19/2022 16:00	1	2
03/19/2022 17:00	1	2
03/19/2022 18:00	1	2
03/19/2022 19:00	1	2
03/19/2022 20:00	1	2
03/19/2022 21:00	1	2
03/19/2022 22:00	1	2
03/19/2022 23:00	1	2
Average/Sum#:	1	2
Minimum:	1	2
Maximum:	1	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/06/2022 11:39 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
03/20/2022 00:00	1	2
03/20/2022 01:00	1	2
03/20/2022 02:00	1	2
03/20/2022 03:00	1	2
03/20/2022 04:00	1	2
03/20/2022 05:00	1	2
03/20/2022 06:00	1	2
03/20/2022 07:00	1	2
03/20/2022 08:00	1	2
03/20/2022 09:00	1	2
03/20/2022 10:00	1	2
03/20/2022 11:00	1	2
03/20/2022 12:00	1	2
03/20/2022 13:00	1	2
03/20/2022 14:00	1	2
03/20/2022 15:00	1	2
03/20/2022 16:00	1	2
03/20/2022 17:00	1	2
03/20/2022 18:00	1	2
03/20/2022 19:00	1	2
03/20/2022 20:00	1	2
03/20/2022 21:00	1	2
03/20/2022 22:00	1	2
03/20/2022 23:00	1	2
Average/Sum#:	1	2
Minimum:	1	2
Maximum:	1	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/06/2022 11:39 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
03/21/2022 00:00	1	2
03/21/2022 01:00	1	2
03/21/2022 02:00	1	2
03/21/2022 03:00	1	2
03/21/2022 04:00	1	2
03/21/2022 05:00	1	2
03/21/2022 06:00	1	2
03/21/2022 07:00	1	2
03/21/2022 08:00	1	2
03/21/2022 09:00	1	2
03/21/2022 10:00	1	2
03/21/2022 11:00	1	2
03/21/2022 12:00	1	2
03/21/2022 13:00	1	2
03/21/2022 14:00	1	2
03/21/2022 15:00	1	2
03/21/2022 16:00	1	2
03/21/2022 17:00	1	2
03/21/2022 18:00	1	2
03/21/2022 19:00	1	2
03/21/2022 20:00	1	2
03/21/2022 21:00	1	2
03/21/2022 22:00	1	2
03/21/2022 23:00	1	2
Average/Sum#:	1	2
Minimum:	1	2
Maximum:	1	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/06/2022 11:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
03/22/2022 00:00	1	2
03/22/2022 01:00	1	2
03/22/2022 02:00	1	2
03/22/2022 03:00	1	2
03/22/2022 04:00	1	2
03/22/2022 05:00	1	2
03/22/2022 06:00	1	2
03/22/2022 07:00	1	2
03/22/2022 08:00	1	2
03/22/2022 09:00	1	2
03/22/2022 10:00	1	2
03/22/2022 11:00	1	2
03/22/2022 12:00	1	2
03/22/2022 13:00	1	2
03/22/2022 14:00	1	2
03/22/2022 15:00	1	2
03/22/2022 16:00	1	2
03/22/2022 17:00	1	2
03/22/2022 18:00	1	2
03/22/2022 19:00	1	2
03/22/2022 20:00	1	2
03/22/2022 21:00	1	2
03/22/2022 22:00	1	2
03/22/2022 23:00	1	2
Average/Sum#:	1	2
Minimum:	1	2
Maximum:	1	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/06/2022 11:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
03/23/2022 00:00	1	2
03/23/2022 01:00	1	2
03/23/2022 02:00	1	2
03/23/2022 03:00	1	2
03/23/2022 04:00	1	2
03/23/2022 05:00	1	2
03/23/2022 06:00	1	2
03/23/2022 07:00	1	2
03/23/2022 08:00	1	2
03/23/2022 09:00	1	2
03/23/2022 10:00	1	2
03/23/2022 11:00	1	2
03/23/2022 12:00	1	2
03/23/2022 13:00	1	2
03/23/2022 14:00	1	2
03/23/2022 15:00	1	2
03/23/2022 16:00	1	2
03/23/2022 17:00	1	2
03/23/2022 18:00	1	2
03/23/2022 19:00	1	2
03/23/2022 20:00	1	2
03/23/2022 21:00	1	2
03/23/2022 22:00	1	2
03/23/2022 23:00	1	2
Average/Sum#:	1	2
Minimum:	1	2
Maximum:	1	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/06/2022 11:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
03/24/2022 00:00	1	2
03/24/2022 01:00	1	2
03/24/2022 02:00	1	2
03/24/2022 03:00	1	2
03/24/2022 04:00	1	2
03/24/2022 05:00	1	2
03/24/2022 06:00	1	2
03/24/2022 07:00	1	2
03/24/2022 08:00	1	2
03/24/2022 09:00	1	2
03/24/2022 10:00	1	2
03/24/2022 11:00	1	2
03/24/2022 12:00	1	2
03/24/2022 13:00	1	2
03/24/2022 14:00	1	2
03/24/2022 15:00	1	2
03/24/2022 16:00	1	2
03/24/2022 17:00	1	2
03/24/2022 18:00	1	2
03/24/2022 19:00	1	2
03/24/2022 20:00	1	2
03/24/2022 21:00	1	2
03/24/2022 22:00	1	2
03/24/2022 23:00	1	2
Average/Sum#:	1	2
Minimum:	1	2
Maximum:	1	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/06/2022 11:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
03/25/2022 00:00	1	2
03/25/2022 01:00	1	2
03/25/2022 02:00	1	2
03/25/2022 03:00	1	2
03/25/2022 04:00	1	2
03/25/2022 05:00	1	2
03/25/2022 06:00	1	2
03/25/2022 07:00	1	2
03/25/2022 08:00	1	2
03/25/2022 09:00	1	2
03/25/2022 10:00	1	2
03/25/2022 11:00	1	2
03/25/2022 12:00	1	2
03/25/2022 13:00	1	2
03/25/2022 14:00	1	2
03/25/2022 15:00	1	2
03/25/2022 16:00	1	2
03/25/2022 17:00	1	2
03/25/2022 18:00	1	2
03/25/2022 19:00	1	2
03/25/2022 20:00	1	2
03/25/2022 21:00	1	2
03/25/2022 22:00	1	2
03/25/2022 23:00	1	2
Average/Sum#:	1	2
Minimum:	1	2
Maximum:	1	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/06/2022 11:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
03/26/2022 00:00	1	2
03/26/2022 01:00	1	2
03/26/2022 02:00	1	2
03/26/2022 03:00	1	2
03/26/2022 04:00	1	2
03/26/2022 05:00	1	2
03/26/2022 06:00	1	2
03/26/2022 07:00	1	2
03/26/2022 08:00	1	2
03/26/2022 09:00	1	2
03/26/2022 10:00	1	2
03/26/2022 11:00	1	2
03/26/2022 12:00	1	2
03/26/2022 13:00	1	2
03/26/2022 14:00	1	2
03/26/2022 15:00	1	2
03/26/2022 16:00	1	2
03/26/2022 17:00	1	2
03/26/2022 18:00	1	2
03/26/2022 19:00	1	2
03/26/2022 20:00	1	2
03/26/2022 21:00	1	2
03/26/2022 22:00	1	2
03/26/2022 23:00	1	2
Average/Sum#:	1	2
Minimum:	1	2
Maximum:	1	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/06/2022 11:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
03/27/2022 00:00	1	2
03/27/2022 01:00	1	2
03/27/2022 02:00	1	2
03/27/2022 03:00	1	2
03/27/2022 04:00	1	2
03/27/2022 05:00	1	2
03/27/2022 06:00	1	2
03/27/2022 07:00	1	2
03/27/2022 08:00	1	2
03/27/2022 09:00	1	2
03/27/2022 10:00	1	2
03/27/2022 11:00	1	2
03/27/2022 12:00	1	2
03/27/2022 13:00	1	2
03/27/2022 14:00	1	2
03/27/2022 15:00	1	2
03/27/2022 16:00	1	2
03/27/2022 17:00	1	2
03/27/2022 18:00	1	2
03/27/2022 19:00	1	2
03/27/2022 20:00	1	2
03/27/2022 21:00	1	2
03/27/2022 22:00	1	2
03/27/2022 23:00	1	2
Average/Sum#:	1	2
Minimum:	1	2
Maximum:	1	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/06/2022 11:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
03/28/2022 00:00	1	2
03/28/2022 01:00	1	2
03/28/2022 02:00	1	2
03/28/2022 03:00	1	2
03/28/2022 04:00	1	2
03/28/2022 05:00	1	2
03/28/2022 06:00	1	3
03/28/2022 07:00	1	0
03/28/2022 08:00	1	0
03/28/2022 09:00	1	0
03/28/2022 10:00	1	0
03/28/2022 11:00	1	0
03/28/2022 12:00	1	0
03/28/2022 13:00	1	0
03/28/2022 14:00	1	0
03/28/2022 15:00	1	0
03/28/2022 16:00	1	0
03/28/2022 17:00	1	0
03/28/2022 18:00	1	0
03/28/2022 19:00	1	0
03/28/2022 20:00	1	0
03/28/2022 21:00	1	0
03/28/2022 22:00	1	0
03/28/2022 23:00	1	0
Average/Sum#:	1	1
Minimum:	1	0
Maximum:	1	3
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/06/2022 11:39 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
03/29/2022 00:00	1	0
03/29/2022 01:00	1	0
03/29/2022 02:00	1	0
03/29/2022 03:00	1	0
03/29/2022 04:00	1	0
03/29/2022 05:00	1	0
03/29/2022 06:00	1	0
03/29/2022 07:00	1	0
03/29/2022 08:00	1	0
03/29/2022 09:00	1	0
03/29/2022 10:00	1	0
03/29/2022 11:00	1	0
03/29/2022 12:00	1	0
03/29/2022 13:00	1	0
03/29/2022 14:00	1	0
03/29/2022 15:00	1	0
03/29/2022 16:00	1	0
03/29/2022 17:00	1	0
03/29/2022 18:00	1	0
03/29/2022 19:00	1	0
03/29/2022 20:00	1	0
03/29/2022 21:00	1	0
03/29/2022 22:00	1	0
03/29/2022 23:00	1	0
Average/Sum#:	1	0
Minimum:	1	0
Maximum:	1	0
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/06/2022 11:39 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
03/30/2022 00:00	1	0
03/30/2022 01:00	1	0
03/30/2022 02:00	1	0
03/30/2022 03:00	1	0
03/30/2022 04:00	1	0
03/30/2022 05:00	1	0
03/30/2022 06:00	1	0
03/30/2022 07:00	1	0
03/30/2022 08:00	1	0
03/30/2022 09:00	1	0
03/30/2022 10:00	1	0
03/30/2022 11:00	1	0
03/30/2022 12:00	1	0
03/30/2022 13:00	1	0
03/30/2022 14:00	1	0
03/30/2022 15:00	1	0
03/30/2022 16:00	1	0
03/30/2022 17:00	1	0
03/30/2022 18:00	1	0
03/30/2022 19:00	2	0
03/30/2022 20:00	2	0
03/30/2022 21:00	3	0
03/30/2022 22:00	0	0
03/30/2022 23:00	0	0
Average/Sum#:	1	0
Minimum:	0	0
Maximum:	3	0
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/06/2022 11:39 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit	> Limit
	Unit CT1	Unit CT2
	NOx_4Hr, Ppmvdc	NOx_4Hr, Ppmvdc
	1 Hour(s)	1 Hour(s)
03/31/2022 00:00	0	0
03/31/2022 01:00	0	0
03/31/2022 02:00	0	0
03/31/2022 03:00	0	0
03/31/2022 04:00	0	0
03/31/2022 05:00	0	0
03/31/2022 06:00	0	0
03/31/2022 07:00	0	0
03/31/2022 08:00	0	0
03/31/2022 09:00	0	0
03/31/2022 10:00	0	0
03/31/2022 11:00	0	0
03/31/2022 12:00	0	0
03/31/2022 13:00	0	0
03/31/2022 14:00	0	0
03/31/2022 15:00	0	0
03/31/2022 16:00	0	0
03/31/2022 17:00	0	0
03/31/2022 18:00	0	0
03/31/2022 19:00	0	0
03/31/2022 20:00	0	0
03/31/2022 21:00	0	0
03/31/2022 22:00	0	0
03/31/2022 23:00	0	0
Average/Sum#:	0	0
Minimum:	0	0
Maximum:	0	0
%SI	0.00	0.00

Excess Emission Report



CT1 NOx 30 Day Rolling Average (KKKK)

From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/06/2022 11:42 Location: Maxwell, CA

Tag Name: CT1_NOx_30D_Ppmvdc_1D

Total Operating Time: 49.00 Day(s) No Exclusions Allowed

Non-Operating Time: 41.00 Day(s) Report Time: 90.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	49.00 Day(s)
Total Duration (Online only):	0.00 Day(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report



CT2 NOx 30 Day Rolling Average (KKKK)

From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/06/2022 11:42 Location: Maxwell, CA

Tag Name: CT2_NOx_30D_Ppmvdc_1D

Total Operating Time: 47.00 Day(s) No Exclusions Allowed

Non-Operating Time: 43.00 Day(s) Report Time: 90.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	47.00 Day(s)
Total Duration (Online only):	0.00 Day(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

ATTACHMENT 4
Excess Emission/Downtime Report

FCD:	AQ-4
Title V:	#28

EDS/CMS Summary Report

CT1 - CO LbPerHr



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/06/2022 11:43 Location: Maxwell, CA
Description: Electric Utility

CMS Data from: CT1_CO_LbPerHr_1H
EDS Data from: CT1_CONormalOp_LbPerHr_1H
Emission Limitation: CT1_COLimit_LbPerHr_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML30
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Process Unit(s) Description:
Operating time for EDS: 960.00 Hour(s)
Operating time for CMS: 960.00 Hour(s)

Emission Data Summary

1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary

1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	1
d. Other known causes	1
e. Unknown causes	0
2. Total CMS Downtime	2
3. Total Downtime as a percentage of operating time	0.21
4. Total Availability as a percentage of operating time	99.79

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

EDS/CMS Summary Report

CT1 - CO Ppmvdc



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/06/2022 11:44 Location: Maxwell, CA
Description: Electric Utility

CMS Data from: CT1_CO_Ppmvdc_1H
EDS Data from: CT1_CO_3Hr_Ppmvdc_1H
Emission Limitation: CT1_COLimit_3Hr_Ppmvdc_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML30
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Process Unit(s) Description:
Operating time for EDS: 960.00 Hour(s)
Operating time for CMS: 960.00 Hour(s)

Emission Data Summary

1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary

1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	2
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime	2
3. Total Downtime as a percentage of operating time	0.21
4. Total Availability as a percentage of operating time	99.79

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

EDS/CMS Summary Report

CT1 - NOx LbPerHr



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/06/2022 11:44 Location: Maxwell, CA
Description: Electric Utility

CMS Data from: CT1_NOx_LbPerHr_1H
EDS Data from: CT1_NOxNormalOp_LbPerHr_1H
Emission Limitation: CT1_NOxLimit_LbPerHr_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML41-02
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Process Unit(s) Description:
Operating time for EDS: 960.00 Hour(s)
Operating time for CMS: 960.00 Hour(s)

Emission Data Summary

1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary

1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	2
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime	2
3. Total Downtime as a percentage of operating time	0.21
4. Total Availability as a percentage of operating time	99.79

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

EDS/CMS Summary Report

CT1 - NOx Ppmvdc



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/06/2022 11:45 **Location:** Maxwell, CA
Description: Electric Utility

CMS Data from: CT1_NOx_Ppmvdc_1H
EDS Data from: CT1_NOx_Ppmvdc_1H
Emission Limitation: CT1_NOxLimit_Ppmvdc_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML41-02
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Process Unit(s) Description:
Operating time for EDS: 960.00 Hour(s)
Operating time for CMS: 960.00 Hour(s)

Emission Data Summary

1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary

1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	2
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime	2
3. Total Downtime as a percentage of operating time	0.21
4. Total Availability as a percentage of operating time	99.79

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

EDS/CMS Summary Report

CT2 - CO LbPerHr



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/06/2022 11:45 Location: Maxwell, CA
Description: Electric Utility

CMS Data from: CT2_CO_LbPerHr_1H
EDS Data from: CT2_CONormalOp_LbPerHr_1H
Emission Limitation: CT2_COLimit_LbPerHr_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML30
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Process Unit(s) Description:
Operating time for EDS: 848.00 Hour(s)
Operating time for CMS: 848.00 Hour(s)

Emission Data Summary

1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary

1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	3
d. Other known causes	3
e. Unknown causes	0
2. Total CMS Downtime	6
3. Total Downtime as a percentage of operating time	0.71
4. Total Availability as a percentage of operating time	99.29

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

EDS/CMS Summary Report

CT2 - CO Ppmvdc



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/06/2022 11:46 Location: Maxwell, CA
Description: Electric Utility

CMS Data from: CT2_CO_Ppmvdc_1H
EDS Data from: CT2_CO_3Hr_Ppmvdc_1H
Emission Limitation: CT2_COLimit_3Hr_Ppmvdc_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML30
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Process Unit(s) Description:
Operating time for EDS: 848.00 Hour(s)
Operating time for CMS: 848.00 Hour(s)

Emission Data Summary

1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary

1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	6
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime	6
3. Total Downtime as a percentage of operating time	0.71
4. Total Availability as a percentage of operating time	99.29

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

EDS/CMS Summary Report

CT2 - NOx LbPerHr



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/06/2022 11:46 Location: Maxwell, CA
Description: Electric Utility

CMS Data from: CT2_NOx_LbPerHr_1H
EDS Data from: CT2_NOxNormalOp_LbPerHr_1H
Emission Limitation: CT2_NOxLimit_LbPerHr_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML41-02
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Process Unit(s) Description:
Operating time for EDS: 848.00 Hour(s)
Operating time for CMS: 848.00 Hour(s)

Emission Data Summary

1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary

1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	3
d. Other known causes	3
e. Unknown causes	0
2. Total CMS Downtime	6
3. Total Downtime as a percentage of operating time	0.71
4. Total Availability as a percentage of operating time	99.29

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

EDS/CMS Summary Report

CT2 - NOx Ppmvdc



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/06/2022 11:47 **Location:** Maxwell, CA
Description: Electric Utility

CMS Data from: CT2_NOx_Ppmvdc_1H
EDS Data from: CT2_NOx_Ppmvdc_1H
Emission Limitation: CT2_NOxLimit_Ppmvdc_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML41-02
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Process Unit(s) Description:
Operating time for EDS: 848.00 Hour(s)
Operating time for CMS: 848.00 Hour(s)

Emission Data Summary

1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary

1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	6
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime	6
3. Total Downtime as a percentage of operating time	0.71
4. Total Availability as a percentage of operating time	99.29

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

Excess Emission Report



CT1 - CO LbPerHr Normal Operating 1-Hour Block Average

From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/06/2022 11:49 Location: Maxwell, CA

Tag Name: CT1_CONormalOp_LbPerHr_1H
Total Operating Time: 960.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 1,200.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	960.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report



CT1 - CO LbPerHr Normal Operating 1-Hour Block Average

From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/06/2022 11:49 Location: Maxwell, CA

Tag Name: CT1_CONormalOp_LbPerHr_1H
Total Operating Time: 960.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 1,200.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	960.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report



CT1 - NOx LbPerHr Normal Operating 1-Hour Block Average

From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/06/2022 11:50 Location: Maxwell, CA

Tag Name: CT1_NOxNormalOp_LbPerHr_1H
Total Operating Time: 960.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 1,200.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total operating Time:	960.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report



CT1 - NOx Ppmvdc 1-Hour Block Average

From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/06/2022 11:50 Location: Maxwell, CA

Tag Name: CT1_NOx_Ppmvdc_1H
Total Operating Time: 960.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 1,200.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	960.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report



CT2 - CO LbPerHr Normal Operating 1-Hour Block Average

From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/06/2022 11:51 Location: Maxwell, CA

Tag Name: CT2_CONormalOp_LbPerHr_1H
Total Operating Time: 848.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 1,312.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	848.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report



CT1 - CO Ppmvdc 3-Hour Rolling Average

From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/06/2022 11:52 Location: Maxwell, CA

Tag Name: CT1_CO_3Hr_Ppmvdc_1H
Total Operating Time: 960.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 1,200.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	960.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report



CT2 - NOx LbPerHr Normal Operating 1-Hour Block Average

From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/06/2022 11:52 Location: Maxwell, CA

Tag Name: CT2_NOxNormalOp_LbPerHr_1H
Total Operating Time: 848.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 1,312.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	848.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report



CT1 - NOx Ppmvdc 1-Hour Block Average

From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/06/2022 11:53 Location: Maxwell, CA

Tag Name: CT1_NOx_Ppmvdc_1H
Total Operating Time: 960.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 1,200.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	960.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Invalid Data Report

CT1 - Stack CO



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/06/2022 11:53 **Location:** Maxwell, CA

Tag Name: CT1_CO_LbPerHr_1H

Total Operating Time: 960.00 Hour(s)

Non-Operating Time: 1,200.00 Hour(s) **Report Time:** 2,160.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	01/18/2022 10:00	01/18/2022 10:59	1	4 - Other known causes	8 - Quarterly Maintenance
2	01/18/2022 13:00	01/18/2022 13:59	1	3 - Quality assurance calibration	4 - Quarterly linearity/cga

Total Operating Time:	960.00 Hour(s)
Total Monitor Downtime (Online only):	2.00 Hour(s)
Percent Monitor Availability:	99.79 %
Percent Monitor Downtime:	0.21 %

Report Code	Type	Text	Duration	Duration Percent
4	Reason	Other known causes	1	50.00
3	Reason	Quality assurance calibration	1	50.00
4	Action	Quarterly linearity/cga	1	50.00
8	Action	Quarterly Maintenance	1	50.00

Invalid Data Report

CT1 - Stack NOx



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/06/2022 11:54 **Location:** Maxwell, CA

Tag Name: CT1_NOx_LbPerHr_1H

Total Operating Time: 960.00 Hour(s)

Non-Operating Time: 1,200.00 Hour(s) **Report Time:** 2,160.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	01/18/2022 10:00	01/18/2022 10:59	1	3 - Quality assurance calibration	4 - Quarterly linearity/cga
2	01/18/2022 13:00	01/18/2022 13:59	1	3 - Quality assurance calibration	4 - Quarterly linearity/cga

Total Operating Time:	960.00 Hour(s)
Total Monitor Downtime (Online only):	2.00 Hour(s)
Percent Monitor Availability:	99.79 %
Percent Monitor Downtime:	0.21 %

Report Code	Type	Text	Duration	Duration Percent
3	Reason	Quality assurance calibration	2	100.00
4	Action	Quarterly linearity/cga	2	100.00

Invalid Data Report

CT2 - Stack CO



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/06/2022 11:55 **Location:** Maxwell, CA

Tag Name: CT2_CO_LbPerHr_1H

Total Operating Time: 848.00 Hour(s)

Non-Operating Time: 1,312.00 Hour(s) **Report Time:** 2,160.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	01/18/2022 11:00	01/18/2022 13:59	3	4 - Quality assurance calibration	8 - Quarterly Maintenance
2	01/19/2022 08:00	01/19/2022 08:59	1	3 - Quality assurance calibration	4 - Quarterly linearity/cga
3	01/19/2022 10:00	01/19/2022 10:59	1	3 - Quality assurance calibration	4 - Quarterly linearity/cga
4	01/19/2022 15:00	01/19/2022 15:59	1	3 - Quality assurance calibration	4 - Quarterly linearity/cga

Total Operating Time:	848.00 Hour(s)
Total Monitor Downtime (Online only):	6.00 Hour(s)
Percent Monitor Availability:	99.29 %
Percent Monitor Downtime:	0.71 %

Report Code	Type	Text	Duration	Duration Percent
3	Reason	Quality assurance calibration	3	50.00
4	Reason	Quality assurance calibration	3	50.00
4	Action	Quarterly linearity/cga	3	50.00
8	Action	Quarterly Maintenance	3	50.00

Invalid Data Report

CT2 - Stack NOx



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/06/2022 11:56 **Location:** Maxwell, CA

Tag Name: CT2_NOx_LbPerHr_1H

Total Operating Time: 848.00 Hour(s)

Non-Operating Time: 1,312.00 Hour(s) **Report Time:** 2,160.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	01/18/2022 11:00	01/18/2022 13:59	3	4 - Quality assurance calibration	8 - Quarterly Maintenance
2	01/19/2022 08:00	01/19/2022 08:59	1	3 - Quality assurance calibration	4 - Quarterly linearity/cga
3	01/19/2022 10:00	01/19/2022 10:59	1	3 - Quality assurance calibration	4 - Quarterly linearity/cga
4	01/19/2022 15:00	01/19/2022 15:59	1	3 - Quality assurance calibration	4 - Quarterly linearity/cga

Total Operating Time:	848.00 Hour(s)
Total Monitor Downtime (Online only):	6.00 Hour(s)
Percent Monitor Availability:	99.29 %
Percent Monitor Downtime:	0.71 %

Report Code	Type	Text	Duration	Duration Percent
3	Reason	Quality assurance calibration	3	50.00
4	Reason	Quality assurance calibration	3	50.00
4	Action	Quarterly linearity/cga	3	50.00
8	Action	Quarterly Maintenance	3	50.00

ATTACHMENT 5
Hourly Emissions VOC

FCD:	AQ-14
Title V:	#6

Daily Summary Report

CT1 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit	> Limit	Unit CT1	Unit CT1	Unit CT1
	VOC, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT1	Unit CT1	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	VOC, Ppmvdc	VOC, LbPerHr	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/01/2022 00:00	-1.1	13.2	1,957.7	-0.7	1.4	1	1	1
01/01/2022 01:00	0.1	13.8	1,625.0	0.2	1.1	1	1	0
01/01/2022 02:00	0.1	13.8	1,573.4	0.1	1.1	1	1	0
01/01/2022 03:00	0.2	13.8	1,785.8	0.3	1.3	1	1	0
01/01/2022 04:00	-0.7	13.5	1,893.3	-0.4	1.3	1	1	1
01/01/2022 05:00	-0.8	13.4	1,886.5	-0.5	1.3	1	1	1
01/01/2022 06:00	-0.2	13.8	1,842.7	-0.1	1.3	1	1	1
01/01/2022 07:00	-1.4	13.1	2,020.3	-0.9	1.4	1	1	1
01/01/2022 08:00	-0.7	13.5	1,708.7	-0.4	1.2	1	1	1
01/01/2022 09:00	0.0	13.9	1,380.9	0.1	1.0	1	1	0
01/01/2022 10:00	0.0	13.9	1,383.4	0.1	1.0	1	1	0
01/01/2022 11:00	0.1	13.9	1,382.8	0.1	1.0	1	1	0
01/01/2022 12:00	0.1	13.9	1,383.6	0.1	1.0	1	1	0
01/01/2022 13:00	0.1	13.9	1,379.6	0.1	1.0	1	1	0
01/01/2022 14:00	0.1	13.9	1,379.9	0.1	1.0	1	1	0
01/01/2022 15:00	0.1	13.9	1,372.4	0.1	1.0	1	1	0
01/01/2022 16:00	0.1	13.8	1,611.2	0.2	1.1	1	1	0
01/01/2022 17:00	0.1	13.8	1,591.0	0.1	1.1	1	1	0
01/01/2022 18:00	0.2	13.8	1,804.9	0.3	1.3	1	1	0
01/01/2022 19:00	-0.2	13.8	1,840.4	-0.1	1.3	1	1	1
01/01/2022 20:00	-1.2	12.6	2,128.6	-0.7	1.5	1	1	1
01/01/2022 21:00	-1.2	12.4	2,173.5	-0.7	1.5	1	1	1
01/01/2022 22:00	-1.2	12.5	2,153.3	-0.7	1.5	1	1	1
01/01/2022 23:00	-1.1	12.7	2,129.5	-0.7	1.5	1	1	1
Average/Sum#:	-0.4	13.5	1,724.5	-0.2	1.2	24 #	24 #	11 #
Minimum:	-1.4	12.4	1,372.4	-0.9	1.0	1	1	0
Maximum:	0.2	13.9	2,173.5	0.3	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/02/2022 00:00	-1.1	13.1	1,982.7	-0.7	1.4	1	1	1
01/02/2022 01:00	0.1	13.8	1,551.6	0.1	1.1	1	1	0
01/02/2022 02:00	0.0	13.8	1,427.9	0.1	1.0	1	1	0
01/02/2022 03:00	0.2	13.8	1,760.9	0.3	1.2	1	1	0
01/02/2022 04:00	-1.2	13.5	1,886.7	-0.8	1.3	1	1	1
01/02/2022 05:00	-0.8	13.5	1,898.5	-0.5	1.3	1	1	1
01/02/2022 06:00	-0.1	13.8	1,823.1	0.1	1.3	1	1	1
01/02/2022 07:00	-1.1	13.1	2,021.6	-0.7	1.4	1	1	1
01/02/2022 08:00	-0.7	13.5	1,708.5	-0.4	1.2	1	1	1
01/02/2022 09:00	0.0	13.8	1,424.2	0.1	1.0	1	1	0
01/02/2022 10:00	-0.1	13.9	1,406.9	0.0	1.0	1	1	0
01/02/2022 11:00	0.0	13.9	1,368.6	0.1	1.0	1	1	0
01/02/2022 12:00	0.0	13.9	1,367.5	0.1	1.0	1	1	0
01/02/2022 13:00	0.0	13.9	1,367.2	0.1	1.0	1	1	0
01/02/2022 14:00	0.0	13.9	1,366.9	0.1	1.0	1	1	0
01/02/2022 15:00	0.0	13.9	1,379.2	0.1	1.0	1	1	0
01/02/2022 16:00	0.1	13.8	1,673.4	0.2	1.2	1	1	0
01/02/2022 17:00	0.1	13.8	1,591.9	0.1	1.1	1	1	0
01/02/2022 18:00	-0.4	13.7	1,806.6	-0.2	1.3	1	1	1
01/02/2022 19:00	-1.5	12.7	2,081.2	-0.9	1.5	1	1	1
01/02/2022 20:00	-1.2	12.1	2,217.4	-0.7	1.6	1	1	1
01/02/2022 21:00	-1.1	12.5	2,119.6	-0.5	1.5	1	1	1
01/02/2022 22:00	-1.1	12.6	2,112.3	-0.7	1.5	1	1	1
01/02/2022 23:00	-1.1	13.0	2,017.9	-0.7	1.4	1	1	1
Average/Sum#:	-0.5	13.5	1,723.4	-0.2	1.2	24 #	24 #	12 #
Minimum:	-1.5	12.1	1,366.9	-0.9	1.0	1	1	0
Maximum:	0.2	13.9	2,217.4	0.3	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/03/2022 00:00	-1.1	13.2	1,942.9	-0.7	1.4	1	1	1
01/03/2022 01:00	0.1	13.8	1,660.6	0.2	1.2	1	1	0
01/03/2022 02:00	-0.4	13.7	1,684.7	-0.2	1.2	1	1	1
01/03/2022 03:00	-0.8	13.0	2,014.4	-0.4	1.4	1	1	1
01/03/2022 04:00	-0.8	13.1	2,006.1	-0.5	1.4	1	1	1
01/03/2022 05:00	-0.9	12.7	2,083.5	-0.5	1.5	1	1	1
01/03/2022 06:00	-0.9	11.9	2,281.8	-0.4	1.6	1	1	1
01/03/2022 07:00	-1.1	12.5	2,113.7	-0.5	1.5	1	1	1
01/03/2022 08:00	-1.2	13.0	2,014.6	-0.8	1.4	1	1	1
01/03/2022 09:00	-1.4	13.2	1,959.7	-0.9	1.4	1	1	1
01/03/2022 10:00	-0.2	13.8	1,713.6	-0.1	1.2	1	1	1
01/03/2022 11:00	-0.1	13.8	1,438.6	0.1	1.0	1	1	0
01/03/2022 12:00	0.1	13.8	1,753.3	0.2	1.2	1	1	0
01/03/2022 13:00	-0.9	13.3	1,873.5	-0.7	1.3	1	1	1
01/03/2022 14:00	-1.2	13.1	1,894.6	-0.8	1.3	1	1	1
01/03/2022 15:00	0.1	13.8	1,651.7	0.2	1.2	1	1	0
01/03/2022 16:00	-1.1	13.2	1,909.8	-0.7	1.3	1	1	1
01/03/2022 17:00	-1.2	12.3	2,124.4	-0.7	1.5	1	1	1
01/03/2022 18:00	-1.2	12.1	2,160.0	-0.7	1.5	1	1	1
01/03/2022 19:00	-1.1	11.9	2,205.8	-0.5	1.5	1	1	1
01/03/2022 20:00	-1.1	12.4	2,093.2	-0.5	1.5	1	1	1
01/03/2022 21:00	-1.1	12.6	2,050.5	-0.7	1.4	1	1	1
01/03/2022 22:00	-1.1	13.0	1,965.8	-0.7	1.4	1	1	1
01/03/2022 23:00	-0.9	12.7	2,048.0	-0.5	1.4	1	1	1
Average/Sum#:	-0.8	13.0	1,943.5	-0.5	1.4	24 #	24 #	20 #
Minimum:	-1.4	11.9	1,438.6	-0.9	1.0	1	1	0
Maximum:	0.1	13.8	2,281.8	0.2	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/04/2022 00:00	-1.1	12.6	2,031.7	-0.7	1.4	1	1	1
01/04/2022 01:00	0.1	13.8	1,562.2	0.2	1.1	1	1	0
01/04/2022 02:00	-0.2	13.7	1,676.4	-0.1	1.2	1	1	1
01/04/2022 03:00	-1.2	13.1	1,938.3	-0.8	1.4	1	1	1
01/04/2022 04:00	-1.1	13.0	1,951.7	-0.7	1.4	1	1	1
01/04/2022 05:00	0.2	13.8	1,671.4	0.3	1.2	1	1	0
01/04/2022 06:00	0.2	13.7	1,788.3	0.3	1.3	1	1	0
01/04/2022 07:00	-1.1	12.9	1,995.6	-0.7	1.4	1	1	1
01/04/2022 08:00	-0.9	12.8	2,026.0	-0.5	1.4	1	1	1
01/04/2022 09:00	-1.1	13.2	1,953.1	-0.7	1.4	1	1	1
01/04/2022 10:00	-0.5	13.7	1,452.8	-0.4	1.0	1	1	1
01/04/2022 11:00	-0.1	13.8	1,347.2	0.1	0.9	1	1	0
01/04/2022 12:00	0.1	13.8	1,727.0	0.2	1.2	1	1	0
01/04/2022 13:00	-0.5	13.5	1,826.9	-0.2	1.3	1	1	1
01/04/2022 14:00	-0.9	13.3	1,822.9	-0.7	1.3	1	1	1
01/04/2022 15:00	0.1	13.8	1,587.7	0.1	1.1	1	1	0
01/04/2022 16:00	-1.2	12.8	2,011.5	-0.7	1.4	1	1	1
01/04/2022 17:00	-1.2	12.2	2,155.4	-0.7	1.5	1	1	1
01/04/2022 18:00	-1.1	12.1	2,178.4	-0.5	1.5	1	1	1
01/04/2022 19:00	-1.1	12.2	2,160.5	-0.5	1.5	1	1	1
01/04/2022 20:00	-1.1	12.4	2,097.4	-0.5	1.5	1	1	1
01/04/2022 21:00	-0.9	12.6	2,063.5	-0.5	1.4	1	1	1
01/04/2022 22:00	-1.1	12.8	2,028.6	-0.7	1.4	1	1	1
01/04/2022 23:00	-0.9	12.7	2,048.8	-0.5	1.4	1	1	1
Average/Sum#:	-0.7	13.1	1,879.3	-0.4	1.3	24 #	24 #	18 #
Minimum:	-1.2	12.1	1,347.2	-0.8	0.9	1	1	0
Maximum:	0.2	13.8	2,178.4	0.3	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/05/2022 00:00	-0.9	13.3	1,834.7	-0.7	1.3	1	1	1
01/05/2022 01:00	-0.2	13.8	1,314.9	0.0	0.9	1	1	0
01/05/2022 02:00	-0.2	13.8	1,346.0	0.0	0.9	1	1	0
01/05/2022 03:00	0.1	13.7	1,763.8	0.2	1.2	1	1	0
01/05/2022 04:00	-0.8	13.4	1,873.9	-0.5	1.3	1	1	1
01/05/2022 05:00	-1.1	13.2	1,904.3	-0.7	1.3	1	1	1
01/05/2022 06:00	-0.4	13.7	1,688.0	-0.2	1.2	1	1	1
01/05/2022 07:00	-0.9	12.8	2,031.1	-0.5	1.4	1	1	1
01/05/2022 08:00	-0.9	12.9	2,022.7	-0.5	1.4	1	1	1
01/05/2022 09:00	-0.9	12.9	2,004.9	-0.5	1.4	1	1	1
01/05/2022 10:00	0.0	13.8	1,486.1	0.1	1.0	1	1	0
01/05/2022 11:00	0.1	13.8	1,535.8	0.1	1.1	1	1	0
01/05/2022 12:00	0.1	13.7	1,740.8	0.2	1.2	1	1	0
01/05/2022 13:00	-0.4	13.4	1,857.3	-0.2	1.3	1	1	1
01/05/2022 14:00	-0.5	13.3	1,852.4	-0.2	1.3	1	1	1
01/05/2022 15:00	-0.2	13.8	1,654.3	-0.1	1.2	1	1	1
01/05/2022 16:00	-1.1	12.8	2,033.0	-0.7	1.4	1	1	1
01/05/2022 17:00	-1.2	12.5	2,098.7	-0.7	1.5	1	1	1
01/05/2022 18:00	-1.2	12.2	2,163.9	-0.7	1.5	1	1	1
01/05/2022 19:00	-1.1	12.2	2,161.8	-0.5	1.5	1	1	1
01/05/2022 20:00	-1.1	12.2	2,165.1	-0.5	1.5	1	1	1
01/05/2022 21:00	-1.1	12.2	2,153.3	-0.5	1.5	1	1	1
01/05/2022 22:00	-1.1	13.0	1,971.4	-0.7	1.4	1	1	1
01/05/2022 23:00	-1.1	12.6	2,059.8	-0.7	1.4	1	1	1
Average/Sum#:	-0.7	13.1	1,863.3	-0.4	1.3	24 #	24 #	18 #
Minimum:	-1.2	12.2	1,314.9	-0.7	0.9	1	1	0
Maximum:	0.1	13.8	2,165.1	0.2	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit	> Limit	Unit CT1	Unit CT1	Unit CT1
	VOC, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT1	Unit CT1	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	VOC, Ppmvdc	VOC, LbPerHr	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/06/2022 00:00	-0.9	13.3	1,842.5	-0.7	1.3	1	1	1
01/06/2022 01:00	0.0	13.8	1,332.2	0.1	0.9	1	1	0
01/06/2022 02:00	-0.1	13.8	1,314.2	0.1	0.9	1	1	0
01/06/2022 03:00	0.1	13.8	1,558.9	0.1	1.1	1	1	0
01/06/2022 04:00	-0.9	13.4	1,875.2	-0.7	1.3	1	1	1
01/06/2022 05:00	-0.9	13.4	1,867.9	-0.7	1.3	1	1	1
01/06/2022 06:00	-0.2	13.7	1,771.3	-0.1	1.2	1	1	1
01/06/2022 07:00	-1.2	13.0	2,016.8	-0.8	1.4	1	1	1
01/06/2022 08:00	-1.1	12.8	2,047.0	-0.7	1.4	1	1	1
01/06/2022 09:00	-1.2	13.1	1,953.8	-0.8	1.4	1	1	1
01/06/2022 10:00	0.0	13.8	1,519.0	0.1	1.1	1	1	0
01/06/2022 11:00	0.1	13.8	1,583.0	0.1	1.1	1	1	0
01/06/2022 12:00	0.0	13.8	1,446.8	0.1	1.0	1	1	0
01/06/2022 13:00	-0.2	13.8	1,338.0	0.0	0.9	1	1	0
01/06/2022 14:00	0.1	13.7	1,621.3	0.1	1.1	1	1	0
01/06/2022 15:00	0.0	13.8	1,445.0	0.1	1.0	1	1	0
01/06/2022 16:00	0.1	13.7	1,627.5	0.2	1.1	1	1	0
01/06/2022 17:00	-0.2	13.7	1,742.2	-0.1	1.2	1	1	1
01/06/2022 18:00	-1.4	12.7	2,039.7	-0.8	1.4	1	1	1
01/06/2022 19:00	-1.2	12.4	2,094.2	-0.7	1.5	1	1	1
01/06/2022 20:00	-1.1	12.9	1,961.6	-0.7	1.4	1	1	1
01/06/2022 21:00	0.1	13.7	1,673.8	0.2	1.2	1	1	0
01/06/2022 22:00	-0.2	13.7	1,770.2	-0.1	1.2	1	1	1
01/06/2022 23:00	-1.1	12.8	2,000.5	-0.7	1.4	1	1	1
Average/Sum#:	-0.5	13.4	1,726.8	-0.3	1.2	24 #	24 #	13 #
Minimum:	-1.4	12.4	1,314.2	-0.8	0.9	1	1	0
Maximum:	0.1	13.8	2,094.2	0.2	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/07/2022 00:00	-0.9	13.3	1,829.4	-0.7	1.3	1	1	1
01/07/2022 01:00	-0.1	13.8	1,304.1	0.1	0.9	1	1	0
01/07/2022 02:00	-0.4	13.7	1,629.3	-0.2	1.1	1	1	1
01/07/2022 03:00	-1.2	13.1	1,950.4	-0.8	1.4	1	1	1
01/07/2022 04:00	-1.2	13.1	1,930.2	-0.8	1.4	1	1	1
01/07/2022 05:00	0.1	13.7	1,684.2	0.2	1.2	1	1	0
01/07/2022 06:00	-0.4	13.7	1,597.1	-0.2	1.1	1	1	1
01/07/2022 07:00	-1.2	12.8	2,002.6	-0.7	1.4	1	1	1
01/07/2022 08:00	-1.2	13.0	1,942.8	-0.8	1.4	1	1	1
01/07/2022 09:00	0.1	13.8	1,582.2	0.2	1.1	1	1	0
01/07/2022 10:00	0.1	13.8	1,538.7	0.2	1.1	1	1	0
01/07/2022 11:00	0.1	13.8	1,562.3	0.2	1.1	1	1	0
01/07/2022 12:00	0.1	13.8	1,549.0	0.2	1.1	1	1	0
01/07/2022 13:00	0.1	13.8	1,515.2	0.2	1.1	1	1	0
01/07/2022 14:00	0.1	13.8	1,497.6	0.1	1.0	1	1	0
01/07/2022 15:00	0.1	13.8	1,539.7	0.2	1.1	1	1	0
01/07/2022 16:00	0.1	13.8	1,543.7	0.2	1.1	1	1	0
01/07/2022 17:00	0.1	13.8	1,642.9	0.2	1.2	1	1	0
01/07/2022 18:00	-1.1	13.3	1,866.1	-0.7	1.3	1	1	1
01/07/2022 19:00	-0.9	13.3	1,840.4	-0.7	1.3	1	1	1
01/07/2022 20:00	-0.4	13.7	1,587.7	-0.2	1.1	1	1	1
01/07/2022 21:00	-1.4	13.0	1,998.1	-0.8	1.4	1	1	1
01/07/2022 22:00	0.0	14.4	1,215.2	0.0	0.9	1	0	1
01/07/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	-0.4	13.6	1,667.3	-0.2	1.2	23 #	22 #	12 #
Minimum:	-1.4	12.8	1,215.2	-0.8	0.9	0	0	0
Maximum:	0.1	14.4	2,002.6	0.2	1.4	1	1	1
%SI	4.17	4.17	4.17	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/08/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2022 10:00	0.0	17.9	321.6	0.0	0.2	1	0	0
01/08/2022 11:00	0.0	17.2	388.4	0.0	0.3	1	0	0
01/08/2022 12:00	0.0	15.7	813.8	0.0	0.6	1	0	0
01/08/2022 13:00	0.1	13.9	1,404.2	0.1	1.0	1	1	0
01/08/2022 14:00	0.0	13.9	1,374.0	0.1	1.0	1	1	0
01/08/2022 15:00	0.2	13.8	1,729.0	0.3	1.2	1	1	0
01/08/2022 16:00	0.1	13.8	1,554.2	0.1	1.1	1	1	0
01/08/2022 17:00	0.1	13.8	1,635.3	0.2	1.1	1	1	0
01/08/2022 18:00	-0.2	13.7	1,790.5	-0.1	1.3	1	1	1
01/08/2022 19:00	-1.2	12.8	2,051.0	-0.7	1.4	1	1	1
01/08/2022 20:00	-1.1	12.6	2,054.3	-0.7	1.4	1	1	1
01/08/2022 21:00	0.2	13.8	1,720.3	0.3	1.2	1	1	0
01/08/2022 22:00	-0.2	13.8	1,799.8	-0.1	1.3	1	1	1
01/08/2022 23:00	-1.1	12.8	2,035.8	-0.7	1.4	1	1	1
Average/Sum#:	-0.2	14.3	1,476.6	-0.1	1.0	14 #	11 #	5 #
Minimum:	-1.2	12.6	321.6	-0.7	0.2	0	0	0
Maximum:	0.2	17.9	2,054.3	0.3	1.4	1	1	1
%SI	41.67	41.67	41.67	41.67	41.67	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/09/2022 00:00	-0.9	13.1	1,966.5	-0.5	1.4	1	1	1
01/09/2022 01:00	0.1	13.8	1,536.5	0.2	1.1	1	1	0
01/09/2022 02:00	-0.4	13.8	1,602.4	-0.2	1.1	1	1	1
01/09/2022 03:00	-1.1	13.2	1,969.5	-0.7	1.4	1	1	1
01/09/2022 04:00	-1.1	13.2	1,953.1	-0.7	1.4	1	1	1
01/09/2022 05:00	0.1	13.8	1,667.9	0.2	1.2	1	1	0
01/09/2022 06:00	-0.4	13.7	1,685.1	-0.2	1.2	1	1	1
01/09/2022 07:00	-1.2	13.0	2,044.7	-0.8	1.4	1	1	1
01/09/2022 08:00	-1.2	13.1	1,988.6	-0.8	1.4	1	1	1
01/09/2022 09:00	0.1	13.8	1,594.5	0.2	1.1	1	1	0
01/09/2022 10:00	0.1	13.8	1,534.8	0.1	1.1	1	1	0
01/09/2022 11:00	0.1	13.8	1,618.0	0.2	1.1	1	1	0
01/09/2022 12:00	0.1	13.8	1,468.2	0.1	1.0	1	1	0
01/09/2022 13:00	0.1	13.8	1,521.3	0.2	1.1	1	1	0
01/09/2022 14:00	0.2	13.8	1,652.7	0.3	1.2	1	1	0
01/09/2022 15:00	0.2	13.8	1,677.3	0.3	1.2	1	1	0
01/09/2022 16:00	-0.4	13.8	1,634.7	-0.2	1.1	1	1	1
01/09/2022 17:00	-1.1	13.0	1,989.6	-0.7	1.4	1	1	1
01/09/2022 18:00	-1.1	12.7	2,073.2	-0.7	1.5	1	1	1
01/09/2022 19:00	-1.1	13.1	1,966.0	-0.7	1.4	1	1	1
01/09/2022 20:00	-0.9	12.9	2,013.4	-0.5	1.4	1	1	1
01/09/2022 21:00	-0.9	13.0	2,000.2	-0.5	1.4	1	1	1
01/09/2022 22:00	-0.9	12.7	2,059.8	-0.5	1.4	1	1	1
01/09/2022 23:00	-1.2	13.2	1,965.3	-0.8	1.4	1	1	1
Average/Sum#:	-0.5	13.4	1,799.3	-0.3	1.3	24 #	24 #	15 #
Minimum:	-1.2	12.7	1,468.2	-0.8	1.0	1	1	0
Maximum:	0.2	13.8	2,073.2	0.3	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/10/2022 00:00	-0.9	13.3	1,867.1	-0.7	1.3	1	1	1
01/10/2022 01:00	0.1	13.9	1,417.2	0.1	1.0	1	1	0
01/10/2022 02:00	0.1	13.9	1,384.2	0.1	1.0	1	1	0
01/10/2022 03:00	0.0	13.8	1,425.9	0.1	1.0	1	1	0
01/10/2022 04:00	0.1	13.8	1,503.6	0.1	1.1	1	1	0
01/10/2022 05:00	0.1	13.8	1,530.3	0.2	1.1	1	1	0
01/10/2022 06:00	0.2	13.8	1,787.2	0.3	1.3	1	1	0
01/10/2022 07:00	0.1	13.8	1,604.3	0.1	1.1	1	1	0
01/10/2022 08:00	0.1	13.8	1,673.4	0.2	1.2	1	1	0
01/10/2022 09:00	0.1	13.8	1,603.2	0.2	1.1	1	1	0
01/10/2022 10:00	-0.2	13.8	1,648.2	-0.1	1.2	1	1	1
01/10/2022 11:00	-0.8	13.1	1,994.1	-0.5	1.4	1	1	1
01/10/2022 12:00	-0.7	13.2	1,934.8	-0.4	1.4	1	1	1
01/10/2022 13:00	0.1	13.9	1,551.5	0.2	1.1	1	1	0
01/10/2022 14:00	0.2	13.8	1,656.1	0.3	1.2	1	1	0
01/10/2022 15:00	-0.9	12.9	2,002.9	-0.5	1.4	1	1	1
01/10/2022 16:00	-1.1	12.6	2,082.9	-0.7	1.5	1	1	1
01/10/2022 17:00	-1.1	12.3	2,134.1	-0.5	1.5	1	1	1
01/10/2022 18:00	-1.1	12.2	2,162.3	-0.5	1.5	1	1	1
01/10/2022 19:00	-1.1	12.2	2,157.2	-0.5	1.5	1	1	1
01/10/2022 20:00	-1.1	12.2	2,163.1	-0.5	1.5	1	1	1
01/10/2022 21:00	-1.1	12.3	2,147.3	-0.5	1.5	1	1	1
01/10/2022 22:00	-0.9	12.8	2,028.4	-0.5	1.4	1	1	1
01/10/2022 23:00	-0.9	13.0	2,007.3	-0.5	1.4	1	1	1
Average/Sum#:	-0.4	13.3	1,811.1	-0.2	1.3	24 #	24 #	13 #
Minimum:	-1.1	12.2	1,384.2	-0.7	1.0	1	1	0
Maximum:	0.2	13.9	2,163.1	0.3	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/11/2022 00:00	-0.8	13.3	1,850.1	-0.5	1.3	1	1	1
01/11/2022 01:00	-0.1	13.9	1,313.8	0.0	0.9	1	1	0
01/11/2022 02:00	-0.5	13.8	1,593.7	-0.4	1.1	1	1	1
01/11/2022 03:00	-1.4	13.2	1,966.2	-0.9	1.4	1	1	1
01/11/2022 04:00	-1.1	13.2	1,949.9	-0.7	1.4	1	1	1
01/11/2022 05:00	0.1	13.8	1,629.6	0.2	1.1	1	1	0
01/11/2022 06:00	-0.4	13.8	1,608.7	-0.2	1.1	1	1	1
01/11/2022 07:00	-1.1	13.0	2,002.9	-0.7	1.4	1	1	1
01/11/2022 08:00	-0.8	13.3	1,847.1	-0.5	1.3	1	1	1
01/11/2022 09:00	0.0	13.9	1,326.2	0.1	0.9	1	1	0
01/11/2022 10:00	0.0	13.9	1,320.5	0.1	0.9	1	1	0
01/11/2022 11:00	0.1	13.9	1,382.5	0.1	1.0	1	1	0
01/11/2022 12:00	0.1	13.9	1,366.7	0.1	1.0	1	1	0
01/11/2022 13:00	0.1	13.9	1,364.1	0.1	1.0	1	1	0
01/11/2022 14:00	0.1	13.9	1,319.5	0.2	0.9	1	1	0
01/11/2022 15:00	0.1	13.9	1,388.8	0.1	1.0	1	1	0
01/11/2022 16:00	0.1	13.8	1,638.3	0.2	1.1	1	1	0
01/11/2022 17:00	-0.2	13.8	1,681.6	-0.1	1.2	1	1	1
01/11/2022 18:00	-0.8	13.0	1,991.5	-0.4	1.4	1	1	1
01/11/2022 19:00	-0.8	13.1	1,964.9	-0.5	1.4	1	1	1
01/11/2022 20:00	-0.8	13.1	1,955.5	-0.5	1.4	1	1	1
01/11/2022 21:00	-0.8	13.1	1,971.3	-0.5	1.4	1	1	1
01/11/2022 22:00	-0.8	12.9	2,023.0	-0.4	1.4	1	1	1
01/11/2022 23:00	-0.5	13.4	1,691.6	-0.2	1.2	1	1	1
Average/Sum#:	-0.4	13.5	1,672.8	-0.2	1.2	24 #	24 #	14 #
Minimum:	-1.4	12.9	1,313.8	-0.9	0.9	1	1	0
Maximum:	0.1	13.9	2,023.0	0.2	1.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/12/2022 00:00	0.0	13.8	1,378.5	0.1	1.0	1	1	0
01/12/2022 01:00	0.0	13.8	1,366.9	0.1	1.0	1	1	0
01/12/2022 02:00	0.0	13.8	1,364.0	0.1	1.0	1	1	0
01/12/2022 03:00	0.0	13.8	1,370.0	0.1	1.0	1	1	0
01/12/2022 04:00	0.0	13.8	1,370.5	0.1	1.0	1	1	0
01/12/2022 05:00	-0.4	13.8	1,437.7	-0.2	1.0	1	1	1
01/12/2022 06:00	-1.5	13.2	1,964.8	-0.9	1.4	1	1	1
01/12/2022 07:00	-1.4	13.2	1,965.4	-0.9	1.4	1	1	1
01/12/2022 08:00	-1.4	13.2	1,963.9	-0.9	1.4	1	1	1
01/12/2022 09:00	-0.5	13.7	1,747.1	-0.4	1.2	1	1	1
01/12/2022 10:00	0.1	13.8	1,599.4	0.1	1.1	1	1	0
01/12/2022 11:00	0.0	13.9	1,402.1	0.1	1.0	1	1	0
01/12/2022 12:00	0.1	13.8	1,544.7	0.2	1.1	1	1	0
01/12/2022 13:00	0.1	13.8	1,596.6	0.2	1.1	1	1	0
01/12/2022 14:00	0.1	13.8	1,581.0	0.2	1.1	1	1	0
01/12/2022 15:00	-0.2	13.8	1,647.6	-0.1	1.2	1	1	1
01/12/2022 16:00	-0.9	12.8	2,023.2	-0.5	1.4	1	1	1
01/12/2022 17:00	-0.9	12.4	2,095.2	-0.5	1.5	1	1	1
01/12/2022 18:00	-0.9	12.6	2,070.3	-0.5	1.4	1	1	1
01/12/2022 19:00	-0.9	12.6	2,059.0	-0.5	1.4	1	1	1
01/12/2022 20:00	-0.8	13.0	1,972.7	-0.4	1.4	1	1	1
01/12/2022 21:00	0.2	13.8	1,689.8	0.3	1.2	1	1	0
01/12/2022 22:00	-0.1	13.8	1,807.4	0.1	1.3	1	1	1
01/12/2022 23:00	-1.1	13.1	1,985.3	-0.7	1.4	1	1	1
Average/Sum#:	-0.4	13.5	1,708.5	-0.2	1.2	24 #	24 #	13 #
Minimum:	-1.5	12.4	1,364.0	-0.9	1.0	1	1	0
Maximum:	0.2	13.9	2,095.2	0.3	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/13/2022 00:00	-0.8	13.4	1,844.4	-0.5	1.3	1	1	1
01/13/2022 01:00	-0.2	13.9	1,315.9	0.0	0.9	1	1	0
01/13/2022 02:00	-0.5	13.8	1,600.7	-0.4	1.1	1	1	1
01/13/2022 03:00	-1.2	13.2	1,977.5	-0.8	1.4	1	1	1
01/13/2022 04:00	-1.1	13.2	1,958.0	-0.7	1.4	1	1	1
01/13/2022 05:00	0.1	13.8	1,693.9	0.2	1.2	1	1	0
01/13/2022 06:00	-0.4	13.8	1,636.6	-0.2	1.1	1	1	1
01/13/2022 07:00	-0.8	12.8	2,034.3	-0.4	1.4	1	1	1
01/13/2022 08:00	-0.5	13.1	1,949.0	-0.2	1.4	1	1	1
01/13/2022 09:00	0.1	13.8	1,670.8	0.2	1.2	1	1	0
01/13/2022 10:00	0.0	13.8	1,407.6	0.1	1.0	1	1	0
01/13/2022 11:00	0.1	13.8	1,647.5	0.2	1.2	1	1	0
01/13/2022 12:00	-0.7	13.4	1,872.7	-0.4	1.3	1	1	1
01/13/2022 13:00	-1.1	12.7	2,012.5	-0.7	1.4	1	1	1
01/13/2022 14:00	0.1	13.8	1,563.2	0.2	1.1	1	1	0
01/13/2022 15:00	-0.4	13.8	1,579.8	-0.2	1.1	1	1	1
01/13/2022 16:00	-0.9	12.8	2,013.4	-0.5	1.4	1	1	1
01/13/2022 17:00	-0.9	12.7	2,049.9	-0.5	1.4	1	1	1
01/13/2022 18:00	-0.9	12.5	2,085.7	-0.5	1.5	1	1	1
01/13/2022 19:00	-0.8	13.0	1,969.2	-0.4	1.4	1	1	1
01/13/2022 20:00	0.2	13.8	1,611.3	0.3	1.1	1	1	0
01/13/2022 21:00	-0.2	13.8	1,648.8	-0.1	1.2	1	1	1
01/13/2022 22:00	-1.1	12.9	1,997.9	-0.7	1.4	1	1	1
01/13/2022 23:00	0.0	14.4	1,214.2	0.0	0.8	1	0	1
Average/Sum#:	-0.5	13.4	1,764.8	-0.3	1.2	24 #	23 #	17 #
Minimum:	-1.2	12.5	1,214.2	-0.8	0.8	1	0	0
Maximum:	0.2	14.4	2,085.7	0.3	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/14/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/14/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/14/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/14/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/14/2022 04:00	0.0	18.2	282.7	0.0	0.2	1	0	0
01/14/2022 05:00	0.0	15.7	779.0	0.0	0.5	1	0	0
01/14/2022 06:00	0.1	13.8	1,493.2	0.1	1.0	1	1	0
01/14/2022 07:00	0.1	13.6	1,848.6	0.2	1.3	1	1	0
01/14/2022 08:00	0.0	13.9	1,385.3	0.1	1.0	1	1	0
01/14/2022 09:00	0.0	13.9	1,366.9	0.1	1.0	1	1	0
01/14/2022 10:00	0.0	13.9	1,368.3	0.1	1.0	1	1	0
01/14/2022 11:00	0.1	13.9	1,370.0	0.1	1.0	1	1	0
01/14/2022 12:00	0.1	13.9	1,380.9	0.1	1.0	1	1	0
01/14/2022 13:00	0.1	13.7	1,752.9	0.2	1.2	1	1	0
01/14/2022 14:00	0.1	13.9	1,531.2	0.2	1.1	1	1	0
01/14/2022 15:00	0.1	13.9	1,532.5	0.2	1.1	1	1	0
01/14/2022 16:00	0.1	13.9	1,433.1	0.2	1.0	1	1	0
01/14/2022 17:00	0.2	13.8	1,599.4	0.3	1.1	1	1	0
01/14/2022 18:00	0.2	13.8	1,627.6	0.3	1.1	1	1	0
01/14/2022 19:00	-0.7	13.3	1,870.8	-0.4	1.3	1	1	1
01/14/2022 20:00	-0.9	13.2	1,890.4	-0.5	1.3	1	1	1
01/14/2022 21:00	-0.2	13.8	1,730.2	-0.1	1.2	1	1	1
01/14/2022 22:00	-1.1	12.9	2,037.7	-0.7	1.4	1	1	1
01/14/2022 23:00	0.0	14.4	1,233.4	0.0	0.9	1	0	1
Average/Sum#:	-0.1	14.1	1,475.7	0.0	1.0	20 #	17 #	5 #
Minimum:	-1.1	12.9	282.7	-0.7	0.2	0	0	0
Maximum:	0.2	18.2	2,037.7	0.3	1.4	1	1	1
%SI	16.67	16.67	16.67	16.67	16.67	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/15/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/15/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/15/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/15/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/15/2022 04:00	0.0	18.4	254.0	0.0	0.2	1	0	0
01/15/2022 05:00	0.0	15.9	760.7	0.0	0.5	1	0	0
01/15/2022 06:00	0.1	13.8	1,518.2	0.2	1.1	1	1	0
01/15/2022 07:00	0.1	13.8	1,564.5	0.2	1.1	1	1	0
01/15/2022 08:00	0.1	13.9	1,417.4	0.1	1.0	1	1	0
01/15/2022 09:00	0.1	13.8	1,532.1	0.2	1.1	1	1	0
01/15/2022 10:00	0.1	13.9	1,371.3	0.1	1.0	1	1	0
01/15/2022 11:00	0.1	13.9	1,372.9	0.1	1.0	1	1	0
01/15/2022 12:00	0.1	13.9	1,369.4	0.1	1.0	1	1	0
01/15/2022 13:00	0.0	13.9	1,375.7	0.1	1.0	1	1	0
01/15/2022 14:00	0.1	13.8	1,735.1	0.2	1.2	1	1	0
01/15/2022 15:00	0.1	13.8	1,579.2	0.2	1.1	1	1	0
01/15/2022 16:00	0.1	13.8	1,599.2	0.2	1.1	1	1	0
01/15/2022 17:00	0.1	13.8	1,682.0	0.2	1.2	1	1	0
01/15/2022 18:00	-0.9	13.3	1,883.4	-0.7	1.3	1	1	1
01/15/2022 19:00	-1.2	13.0	1,975.2	-0.8	1.4	1	1	1
01/15/2022 20:00	-0.2	13.8	1,707.9	-0.1	1.2	1	1	1
01/15/2022 21:00	-0.2	13.7	1,787.6	-0.1	1.3	1	1	1
01/15/2022 22:00	-1.2	13.0	1,996.1	-0.8	1.4	1	1	1
01/15/2022 23:00	0.0	14.0	1,474.6	0.0	1.0	1	0	1
Average/Sum#:	-0.1	14.1	1,497.8	0.0	1.1	20 #	17 #	6 #
Minimum:	-1.2	13.0	254.0	-0.8	0.2	0	0	0
Maximum:	0.1	18.4	1,996.1	0.2	1.4	1	1	1
%SI	16.67	16.67	16.67	16.67	16.67	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/16/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/16/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/16/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/16/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/16/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/16/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/16/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/16/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/16/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/16/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/16/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/16/2022 11:00	0.0	17.5	355.9	0.0	0.2	1	0	0
01/16/2022 12:00	0.0	16.1	682.8	0.0	0.5	1	0	0
01/16/2022 13:00	-0.1	13.8	1,384.6	0.1	1.0	1	1	0
01/16/2022 14:00	-0.1	13.9	1,372.8	0.0	1.0	1	1	0
01/16/2022 15:00	0.1	13.8	1,672.4	0.1	1.2	1	1	0
01/16/2022 16:00	0.1	13.8	1,664.3	0.2	1.2	1	1	0
01/16/2022 17:00	0.1	13.9	1,455.8	0.1	1.0	1	1	0
01/16/2022 18:00	0.1	13.7	1,722.5	0.2	1.2	1	1	0
01/16/2022 19:00	-1.2	13.2	1,921.4	-0.8	1.3	1	1	1
01/16/2022 20:00	-1.2	12.7	2,025.6	-0.7	1.4	1	1	1
01/16/2022 21:00	0.2	13.8	1,712.4	0.3	1.2	1	1	0
01/16/2022 22:00	0.1	13.9	1,409.5	0.1	1.0	1	1	0
01/16/2022 23:00	0.1	13.8	1,634.3	0.2	1.1	1	1	0
Average/Sum#:	-0.1	14.1	1,462.6	0.0	1.0	13 #	11 #	2 #
Minimum:	-1.2	12.7	355.9	-0.8	0.2	0	0	0
Maximum:	0.2	17.5	2,025.6	0.3	1.4	1	1	1
%SI	45.83	45.83	45.83	45.83	45.83	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/17/2022 00:00	-0.8	13.4	1,840.9	-0.5	1.3	1	1	1
01/17/2022 01:00	-0.9	13.3	1,870.0	-0.7	1.3	1	1	1
01/17/2022 02:00	-0.1	13.8	1,425.5	0.1	1.0	1	1	0
01/17/2022 03:00	0.1	13.8	1,763.8	0.2	1.2	1	1	0
01/17/2022 04:00	-0.7	13.5	1,863.6	-0.4	1.3	1	1	1
01/17/2022 05:00	-0.8	13.5	1,843.7	-0.5	1.3	1	1	1
01/17/2022 06:00	-0.4	13.7	1,713.3	-0.2	1.2	1	1	1
01/17/2022 07:00	-1.2	12.8	2,038.5	-0.7	1.4	1	1	1
01/17/2022 08:00	-1.1	12.8	2,057.3	-0.7	1.4	1	1	1
01/17/2022 09:00	-1.2	13.0	1,980.1	-0.8	1.4	1	1	1
01/17/2022 10:00	0.1	13.8	1,593.8	0.1	1.1	1	1	0
01/17/2022 11:00	0.1	13.8	1,596.2	0.2	1.1	1	1	0
01/17/2022 12:00	-0.2	13.8	1,662.3	-0.1	1.2	1	1	1
01/17/2022 13:00	-0.8	13.0	1,963.0	-0.4	1.4	1	1	1
01/17/2022 14:00	-0.7	13.0	1,939.3	-0.4	1.4	1	1	1
01/17/2022 15:00	0.2	13.8	1,614.0	0.3	1.1	1	1	0
01/17/2022 16:00	-0.2	13.8	1,606.1	-0.1	1.1	1	1	1
01/17/2022 17:00	-1.1	12.9	1,985.5	-0.7	1.4	1	1	1
01/17/2022 18:00	-0.9	12.8	2,021.2	-0.5	1.4	1	1	1
01/17/2022 19:00	-1.1	12.6	2,062.2	-0.7	1.4	1	1	1
01/17/2022 20:00	-0.9	13.0	1,952.0	-0.5	1.4	1	1	1
01/17/2022 21:00	0.2	13.8	1,659.8	0.3	1.2	1	1	0
01/17/2022 22:00	0.0	13.9	1,422.2	0.1	1.0	1	1	0
01/17/2022 23:00	0.1	13.8	1,644.1	0.2	1.2	1	1	0
Average/Sum#:	-0.5	13.4	1,796.6	-0.3	1.3	24 #	24 #	16 #
Minimum:	-1.2	12.6	1,422.2	-0.8	1.0	1	1	0
Maximum:	0.2	13.9	2,062.2	0.3	1.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/18/2022 00:00	-0.2	13.7	1,795.1	-0.1	1.3	1	1	1
01/18/2022 01:00	-0.9	13.2	1,857.5	-0.5	1.3	1	1	1
01/18/2022 02:00	0.1	13.8	1,639.3	0.1	1.1	1	1	0
01/18/2022 03:00	-0.5	13.2	1,962.3	-0.2	1.4	1	1	1
01/18/2022 04:00	-0.5	13.2	1,960.2	-0.2	1.4	1	1	1
01/18/2022 05:00	-0.4	13.8	1,586.1	-0.2	1.1	1	1	1
01/18/2022 06:00	-0.5	13.8	1,610.8	-0.4	1.1	1	1	1
01/18/2022 07:00	-1.2	13.2	1,983.9	-0.8	1.4	1	1	1
01/18/2022 08:00	-1.1	12.9	2,026.9	-0.7	1.4	1	1	1
01/18/2022 09:00	-1.2	13.2	1,947.5	-0.8	1.4	1	1	1
01/18/2022 10:00	0.6	0.0	1,445.2	0.6	1.0	1	1	0
01/18/2022 11:00	-0.1	13.8	1,411.2	0.1	1.0	1	1	0
01/18/2022 12:00	-0.1	13.9	1,313.9	0.0	0.9	1	1	0
01/18/2022 13:00	0.6	0.0	1,323.2	0.6	0.9	1	1	0
01/18/2022 14:00	0.1	13.9	1,362.3	0.1	1.0	1	1	0
01/18/2022 15:00	0.1	13.8	1,542.4	0.1	1.1	1	1	0
01/18/2022 16:00	-0.2	13.7	1,637.2	-0.1	1.1	1	1	1
01/18/2022 17:00	-1.2	12.7	2,032.0	-0.7	1.4	1	1	1
01/18/2022 18:00	-1.1	12.7	2,047.9	-0.7	1.4	1	1	1
01/18/2022 19:00	-1.1	12.5	2,082.4	-0.5	1.5	1	1	1
01/18/2022 20:00	-0.9	13.1	1,952.4	-0.5	1.4	1	1	1
01/18/2022 21:00	-0.2	13.7	1,601.0	-0.1	1.1	1	1	1
01/18/2022 22:00	-0.4	13.8	1,606.3	-0.2	1.1	1	1	1
01/18/2022 23:00	-1.2	13.0	1,992.0	-0.8	1.4	1	1	1
Average/Sum#:	-0.6	13.4	1,738.3	-0.3	1.2	24 #	24 #	17 #
Minimum:	-1.2	12.5	1,313.9	-0.8	0.9	1	1	0
Maximum:	0.1	13.9	2,082.4	0.1	1.5	1	1	1
%SI	8.33	8.33	0.00	8.33	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit	> Limit	Unit CT1	Unit CT1	Unit CT1
	VOC, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT1	Unit CT1	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	VOC, Ppmvdc	VOC, LbPerHr	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/19/2022 00:00	-0.8	13.3	1,846.2	-0.5	1.3	1	1	1
01/19/2022 01:00	-0.2	13.9	1,311.8	0.0	0.9	1	1	0
01/19/2022 02:00	-0.5	13.8	1,600.1	-0.4	1.1	1	1	1
01/19/2022 03:00	-1.1	13.2	1,975.1	-0.7	1.4	1	1	1
01/19/2022 04:00	-1.1	13.2	1,944.5	-0.7	1.4	1	1	1
01/19/2022 05:00	0.0	13.8	1,593.6	0.1	1.1	1	1	0
01/19/2022 06:00	-0.7	13.8	1,610.8	-0.4	1.1	1	1	1
01/19/2022 07:00	-1.2	13.1	1,980.7	-0.8	1.4	1	1	1
01/19/2022 08:00	-1.2	13.2	1,962.0	-0.8	1.4	1	1	1
01/19/2022 09:00	0.0	13.8	1,518.3	0.1	1.1	1	1	0
01/19/2022 10:00	-0.1	13.9	1,363.9	0.0	1.0	1	1	0
01/19/2022 11:00	0.0	13.9	1,428.7	0.1	1.0	1	1	0
01/19/2022 12:00	0.0	13.9	1,332.7	0.1	0.9	1	1	0
01/19/2022 13:00	0.1	13.9	1,385.3	0.1	1.0	1	1	0
01/19/2022 14:00	0.0	13.9	1,361.1	0.1	1.0	1	1	0
01/19/2022 15:00	-0.4	13.7	1,584.8	-0.2	1.1	1	1	1
01/19/2022 16:00	-1.2	12.5	2,080.9	-0.7	1.5	1	1	1
01/19/2022 17:00	-1.1	12.3	2,106.3	-0.5	1.5	1	1	1
01/19/2022 18:00	-1.1	12.5	2,081.8	-0.5	1.5	1	1	1
01/19/2022 19:00	-1.1	12.4	2,096.4	-0.5	1.5	1	1	1
01/19/2022 20:00	-0.9	12.6	2,027.1	-0.5	1.4	1	1	1
01/19/2022 21:00	0.2	13.8	1,700.4	0.3	1.2	1	1	0
01/19/2022 22:00	-0.1	13.7	1,795.7	0.1	1.3	1	1	1
01/19/2022 23:00	-0.8	12.9	1,999.9	-0.4	1.4	1	1	1
Average/Sum#:	-0.6	13.4	1,737.0	-0.3	1.2	24 #	24 #	15 #
Minimum:	-1.2	12.3	1,311.8	-0.8	0.9	1	1	0
Maximum:	0.2	13.9	2,106.3	0.3	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/20/2022 00:00	-0.7	13.1	1,860.6	-0.4	1.3	1	1	1
01/20/2022 01:00	0.1	13.9	1,315.3	0.1	0.9	1	1	0
01/20/2022 02:00	0.0	13.9	1,325.6	0.1	0.9	1	1	0
01/20/2022 03:00	0.2	13.8	1,748.2	0.3	1.2	1	1	0
01/20/2022 04:00	-0.7	13.4	1,863.7	-0.4	1.3	1	1	1
01/20/2022 05:00	-0.7	13.4	1,871.0	-0.4	1.3	1	1	1
01/20/2022 06:00	-0.2	13.8	1,726.9	-0.1	1.2	1	1	1
01/20/2022 07:00	-1.1	13.0	1,995.8	-0.7	1.4	1	1	1
01/20/2022 08:00	-0.7	13.5	1,704.2	-0.4	1.2	1	1	1
01/20/2022 09:00	0.0	13.9	1,391.1	0.1	1.0	1	1	0
01/20/2022 10:00	0.0	13.9	1,368.4	0.1	1.0	1	1	0
01/20/2022 11:00	0.1	13.9	1,373.3	0.1	1.0	1	1	0
01/20/2022 12:00	0.1	13.9	1,375.3	0.1	1.0	1	1	0
01/20/2022 13:00	0.1	13.9	1,376.3	0.1	1.0	1	1	0
01/20/2022 14:00	0.1	13.9	1,379.9	0.1	1.0	1	1	0
01/20/2022 15:00	0.1	13.9	1,382.6	0.1	1.0	1	1	0
01/20/2022 16:00	0.1	13.7	1,712.2	0.2	1.2	1	1	0
01/20/2022 17:00	0.1	13.8	1,531.9	0.1	1.1	1	1	0
01/20/2022 18:00	0.1	13.8	1,622.8	0.2	1.1	1	1	0
01/20/2022 19:00	-0.2	13.7	1,728.0	-0.1	1.2	1	1	1
01/20/2022 20:00	-1.2	12.8	2,029.0	-0.7	1.4	1	1	1
01/20/2022 21:00	-1.1	12.8	2,031.2	-0.7	1.4	1	1	1
01/20/2022 22:00	-1.1	12.6	2,065.1	-0.7	1.4	1	1	1
01/20/2022 23:00	0.0	14.2	1,247.7	0.0	0.9	1	0	1
Average/Sum#:	-0.3	13.6	1,626.1	-0.1	1.1	24 #	23 #	11 #
Minimum:	-1.2	12.6	1,247.7	-0.7	0.9	1	0	0
Maximum:	0.2	14.2	2,065.1	0.3	1.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/21/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/21/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/21/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/21/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/21/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/21/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/21/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/21/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/21/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/21/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/21/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/21/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/21/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/21/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/21/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/21/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/21/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/21/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/21/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/21/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/21/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/21/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/21/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/21/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/22/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/22/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/22/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/22/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/22/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/22/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/22/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/22/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/22/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/22/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/22/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/22/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/22/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/22/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/22/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/22/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/22/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/22/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/22/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/22/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/22/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/22/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/22/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/22/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/23/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/23/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/23/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/23/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/23/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/23/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/23/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/23/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/23/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/23/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/23/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/23/2022 11:00	0.0	17.6	323.4	0.0	0.2	1	0	0
01/23/2022 12:00	0.0	17.2	383.6	0.0	0.3	1	0	0
01/23/2022 13:00	0.0	15.6	810.3	0.0	0.6	1	0	0
01/23/2022 14:00	0.2	13.9	1,420.3	0.3	1.0	1	1	0
01/23/2022 15:00	0.2	13.9	1,380.4	0.3	1.0	1	1	0
01/23/2022 16:00	0.2	13.8	1,630.1	0.3	1.1	1	1	0
01/23/2022 17:00	0.2	13.9	1,605.7	0.3	1.1	1	1	0
01/23/2022 18:00	-0.2	13.7	1,776.1	-0.1	1.2	1	1	1
01/23/2022 19:00	-0.9	13.0	1,986.4	-0.5	1.4	1	1	1
01/23/2022 20:00	-1.2	12.6	2,083.5	-0.7	1.5	1	1	1
01/23/2022 21:00	-0.9	12.7	2,049.0	-0.5	1.4	1	1	1
01/23/2022 22:00	-0.8	13.0	2,006.0	-0.4	1.4	1	1	1
01/23/2022 23:00	0.0	14.4	1,211.0	0.0	0.8	1	0	1
Average/Sum#:	-0.2	14.3	1,435.8	-0.1	1.0	13 #	9 #	6 #
Minimum:	-1.2	12.6	323.4	-0.7	0.2	0	0	0
Maximum:	0.2	17.6	2,083.5	0.3	1.5	1	1	1
%SI	45.83	45.83	45.83	45.83	45.83	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/24/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/24/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/24/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/24/2022 03:00	0.0	18.7	215.0	0.0	0.2	1	0	0
01/24/2022 04:00	0.0	15.6	843.4	0.0	0.6	1	0	0
01/24/2022 05:00	-0.5	13.8	1,526.6	-0.4	1.1	1	1	1
01/24/2022 06:00	-1.1	12.7	2,085.9	-0.7	1.5	1	1	1
01/24/2022 07:00	-1.1	12.3	2,171.9	-0.5	1.5	1	1	1
01/24/2022 08:00	-0.7	13.3	1,836.4	-0.4	1.3	1	1	1
01/24/2022 09:00	-0.1	13.8	1,379.1	0.1	1.0	1	1	0
01/24/2022 10:00	-0.1	13.8	1,373.4	0.1	1.0	1	1	0
01/24/2022 11:00	0.0	13.8	1,362.9	0.1	1.0	1	1	0
01/24/2022 12:00	-0.1	13.8	1,375.1	0.1	1.0	1	1	0
01/24/2022 13:00	0.0	13.8	1,379.0	0.1	1.0	1	1	0
01/24/2022 14:00	0.1	13.7	1,756.9	0.2	1.2	1	1	0
01/24/2022 15:00	0.1	13.8	1,466.0	0.1	1.0	1	1	0
01/24/2022 16:00	0.1	13.8	1,667.8	0.2	1.2	1	1	0
01/24/2022 17:00	-0.4	13.7	1,665.4	-0.2	1.2	1	1	1
01/24/2022 18:00	-1.1	12.9	1,995.1	-0.7	1.4	1	1	1
01/24/2022 19:00	-1.2	12.6	2,069.6	-0.7	1.4	1	1	1
01/24/2022 20:00	-0.9	12.9	1,971.2	-0.5	1.4	1	1	1
01/24/2022 21:00	0.1	13.8	1,631.0	0.2	1.1	1	1	0
01/24/2022 22:00	-0.2	13.7	1,753.1	-0.1	1.2	1	1	1
01/24/2022 23:00	-1.1	12.9	2,002.0	-0.7	1.4	1	1	1
Average/Sum#:	-0.4	13.8	1,596.5	-0.2	1.1	21 #	19 #	10 #
Minimum:	-1.2	12.3	215.0	-0.7	0.2	0	0	0
Maximum:	0.1	18.7	2,171.9	0.2	1.5	1	1	1
%SI	12.50	12.50	12.50	12.50	12.50	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/25/2022 00:00	-1.1	13.1	1,943.4	-0.7	1.4	1	1	1
01/25/2022 01:00	0.1	13.8	1,573.3	0.1	1.1	1	1	0
01/25/2022 02:00	-0.4	13.7	1,681.9	-0.2	1.2	1	1	1
01/25/2022 03:00	-1.1	13.1	1,975.6	-0.7	1.4	1	1	1
01/25/2022 04:00	-1.1	13.1	1,954.3	-0.7	1.4	1	1	1
01/25/2022 05:00	0.1	13.8	1,674.2	0.1	1.2	1	1	0
01/25/2022 06:00	-0.2	13.7	1,785.7	-0.1	1.2	1	1	1
01/25/2022 07:00	-1.1	12.9	2,039.5	-0.7	1.4	1	1	1
01/25/2022 08:00	0.0	13.6	1,525.7	0.0	1.1	1	0	1
01/25/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2022 15:00	0.0	17.9	311.7	0.0	0.2	1	0	0
01/25/2022 16:00	0.0	15.5	946.6	0.0	0.7	1	0	0
01/25/2022 17:00	0.2	13.8	1,672.8	0.3	1.2	1	1	0
01/25/2022 18:00	0.2	13.7	1,744.2	0.3	1.2	1	1	0
01/25/2022 19:00	-0.9	13.1	1,933.7	-0.5	1.4	1	1	1
01/25/2022 20:00	-0.9	13.1	1,942.8	-0.5	1.4	1	1	1
01/25/2022 21:00	0.1	13.9	1,546.2	0.2	1.1	1	1	0
01/25/2022 22:00	-0.2	13.7	1,719.8	-0.1	1.2	1	1	1
01/25/2022 23:00	-0.7	13.2	1,963.8	-0.4	1.4	1	1	1
Average/Sum#:	-0.4	13.8	1,663.1	-0.2	1.2	18 #	15 #	11 #
Minimum:	-1.1	12.9	311.7	-0.7	0.2	0	0	0
Maximum:	0.2	17.9	2,039.5	0.3	1.4	1	1	1
%SI	25.00	25.00	25.00	25.00	25.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/26/2022 00:00	-0.8	13.1	1,973.5	-0.5	1.4	1	1	1
01/26/2022 01:00	0.2	13.8	1,715.3	0.3	1.2	1	1	0
01/26/2022 02:00	-0.2	13.8	1,718.2	-0.1	1.2	1	1	1
01/26/2022 03:00	-0.9	13.1	2,004.0	-0.5	1.4	1	1	1
01/26/2022 04:00	-0.9	13.1	1,996.1	-0.5	1.4	1	1	1
01/26/2022 05:00	0.1	13.8	1,604.8	0.2	1.1	1	1	0
01/26/2022 06:00	-0.2	13.8	1,819.7	-0.1	1.3	1	1	1
01/26/2022 07:00	-1.2	13.0	2,013.8	-0.8	1.4	1	1	1
01/26/2022 08:00	0.0	14.0	1,471.0	0.0	1.0	1	0	1
01/26/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2022 15:00	0.0	17.9	322.6	0.0	0.2	1	0	0
01/26/2022 16:00	0.0	15.5	945.8	0.0	0.7	1	0	0
01/26/2022 17:00	0.2	13.8	1,718.2	0.3	1.2	1	1	0
01/26/2022 18:00	0.1	13.7	1,821.3	0.2	1.3	1	1	0
01/26/2022 19:00	-0.8	13.1	1,939.8	-0.5	1.4	1	1	1
01/26/2022 20:00	-1.1	12.7	2,033.8	-0.7	1.4	1	1	1
01/26/2022 21:00	0.2	13.8	1,691.2	0.3	1.2	1	1	0
01/26/2022 22:00	0.2	13.8	1,809.5	0.3	1.3	1	1	0
01/26/2022 23:00	-0.9	13.0	2,021.0	-0.5	1.4	1	1	1
Average/Sum#:	-0.3	13.8	1,701.1	-0.1	1.2	18 #	15 #	10 #
Minimum:	-1.2	12.7	322.6	-0.8	0.2	0	0	0
Maximum:	0.2	17.9	2,033.8	0.3	1.4	1	1	1
%SI	25.00	25.00	25.00	25.00	25.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/27/2022 00:00	-0.9	13.1	1,983.2	-0.5	1.4	1	1	1
01/27/2022 01:00	-0.4	13.8	1,538.6	-0.2	1.1	1	1	1
01/27/2022 02:00	0.1	13.8	1,717.6	0.2	1.2	1	1	0
01/27/2022 03:00	-0.9	13.2	1,962.9	-0.5	1.4	1	1	1
01/27/2022 04:00	-0.9	13.2	1,962.5	-0.5	1.4	1	1	1
01/27/2022 05:00	0.1	13.8	1,599.2	0.2	1.1	1	1	0
01/27/2022 06:00	-0.5	13.3	1,880.6	-0.2	1.3	1	1	1
01/27/2022 07:00	-0.9	12.9	2,035.5	-0.5	1.4	1	1	1
01/27/2022 08:00	-0.8	13.1	1,986.8	-0.5	1.4	1	1	1
01/27/2022 09:00	-0.7	13.5	1,695.4	-0.4	1.2	1	1	1
01/27/2022 10:00	0.0	14.9	905.9	0.0	0.6	1	0	0
01/27/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/27/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/27/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/27/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/27/2022 15:00	0.0	17.9	320.2	0.0	0.2	1	0	0
01/27/2022 16:00	0.0	15.5	951.2	0.0	0.7	1	0	0
01/27/2022 17:00	0.1	13.9	1,542.4	0.2	1.1	1	1	0
01/27/2022 18:00	-0.2	13.7	1,818.1	-0.1	1.3	1	1	1
01/27/2022 19:00	-0.8	12.8	2,026.7	-0.4	1.4	1	1	1
01/27/2022 20:00	-0.7	12.9	2,002.8	-0.4	1.4	1	1	1
01/27/2022 21:00	0.2	13.8	1,695.8	0.3	1.2	1	1	0
01/27/2022 22:00	0.1	13.9	1,493.0	0.2	1.0	1	1	0
01/27/2022 23:00	-0.8	13.3	1,930.5	-0.5	1.4	1	1	1
Average/Sum#:	-0.4	13.8	1,652.4	-0.2	1.2	20 #	17 #	12 #
Minimum:	-0.9	12.8	320.2	-0.5	0.2	0	0	0
Maximum:	0.2	17.9	2,035.5	0.3	1.4	1	1	1
%SI	16.67	16.67	16.67	16.67	16.67	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/28/2022 00:00	-1.1	12.8	2,069.1	-0.7	1.4	1	1	1
01/28/2022 01:00	-1.1	12.7	2,058.1	-0.7	1.4	1	1	1
01/28/2022 02:00	-0.4	13.8	1,523.3	-0.2	1.1	1	1	1
01/28/2022 03:00	0.1	13.8	1,537.5	0.2	1.1	1	1	0
01/28/2022 04:00	-0.1	13.8	1,780.1	0.1	1.2	1	1	1
01/28/2022 05:00	-0.9	13.0	2,014.7	-0.5	1.4	1	1	1
01/28/2022 06:00	-1.1	12.5	2,141.5	-0.5	1.5	1	1	1
01/28/2022 07:00	-1.1	12.5	2,126.0	-0.5	1.5	1	1	1
01/28/2022 08:00	-0.8	13.1	1,986.2	-0.5	1.4	1	1	1
01/28/2022 09:00	0.1	13.9	1,542.1	0.1	1.1	1	1	0
01/28/2022 10:00	0.1	13.9	1,435.9	0.1	1.0	1	1	0
01/28/2022 11:00	0.1	13.9	1,506.9	0.2	1.1	1	1	0
01/28/2022 12:00	0.1	13.9	1,466.5	0.2	1.0	1	1	0
01/28/2022 13:00	0.1	13.9	1,448.2	0.2	1.0	1	1	0
01/28/2022 14:00	0.2	13.9	1,649.6	0.3	1.2	1	1	0
01/28/2022 15:00	0.2	13.9	1,573.8	0.3	1.1	1	1	0
01/28/2022 16:00	-0.2	13.8	1,613.2	-0.1	1.1	1	1	1
01/28/2022 17:00	-1.1	13.2	1,937.0	-0.7	1.4	1	1	1
01/28/2022 18:00	-1.1	12.7	2,053.4	-0.7	1.4	1	1	1
01/28/2022 19:00	-1.2	12.2	2,168.5	-0.7	1.5	1	1	1
01/28/2022 20:00	-1.1	12.4	2,086.6	-0.5	1.5	1	1	1
01/28/2022 21:00	0.1	13.9	1,544.3	0.2	1.1	1	1	0
01/28/2022 22:00	-0.1	13.8	1,825.6	0.1	1.3	1	1	1
01/28/2022 23:00	-0.9	13.0	1,998.7	-0.5	1.4	1	1	1
Average/Sum#:	-0.5	13.3	1,795.3	-0.2	1.3	24 #	24 #	15 #
Minimum:	-1.2	12.2	1,435.9	-0.7	1.0	1	1	0
Maximum:	0.2	13.9	2,168.5	0.3	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit	> Limit	Unit CT1	Unit CT1	Unit CT1
	VOC, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT1	Unit CT1	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	VOC, Ppmvdc	VOC, LbPerHr	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/29/2022 00:00	-0.9	13.2	1,944.2	-0.5	1.4	1	1	1
01/29/2022 01:00	0.1	13.8	1,588.8	0.2	1.1	1	1	0
01/29/2022 02:00	-0.5	13.8	1,599.6	-0.4	1.1	1	1	1
01/29/2022 03:00	-1.1	13.2	1,965.0	-0.7	1.4	1	1	1
01/29/2022 04:00	-0.9	13.2	1,946.9	-0.5	1.4	1	1	1
01/29/2022 05:00	0.1	13.8	1,624.7	0.1	1.1	1	1	0
01/29/2022 06:00	-0.5	13.8	1,644.8	-0.4	1.2	1	1	1
01/29/2022 07:00	-1.2	13.1	2,016.6	-0.8	1.4	1	1	1
01/29/2022 08:00	-0.9	12.9	2,061.6	-0.5	1.4	1	1	1
01/29/2022 09:00	-1.1	13.2	1,950.5	-0.7	1.4	1	1	1
01/29/2022 10:00	0.1	13.9	1,422.6	0.1	1.0	1	1	0
01/29/2022 11:00	0.1	13.9	1,541.2	0.2	1.1	1	1	0
01/29/2022 12:00	0.1	13.9	1,389.9	0.2	1.0	1	1	0
01/29/2022 13:00	0.1	13.9	1,411.8	0.2	1.0	1	1	0
01/29/2022 14:00	0.2	13.9	1,626.6	0.3	1.1	1	1	0
01/29/2022 15:00	0.1	13.9	1,393.9	0.1	1.0	1	1	0
01/29/2022 16:00	0.1	13.9	1,607.4	0.2	1.1	1	1	0
01/29/2022 17:00	0.1	13.8	1,636.3	0.2	1.1	1	1	0
01/29/2022 18:00	-0.7	13.4	1,825.0	-0.4	1.3	1	1	1
01/29/2022 19:00	-0.9	13.0	1,901.9	-0.5	1.3	1	1	1
01/29/2022 20:00	-0.2	13.8	1,806.0	-0.1	1.3	1	1	1
01/29/2022 21:00	-0.9	12.8	2,037.9	-0.5	1.4	1	1	1
01/29/2022 22:00	-0.9	12.3	2,128.6	-0.5	1.5	1	1	1
01/29/2022 23:00	-0.7	13.3	1,856.3	-0.4	1.3	1	1	1
Average/Sum#:	-0.4	13.5	1,747.0	-0.2	1.2	24 #	24 #	14 #
Minimum:	-1.2	12.3	1,389.9	-0.8	1.0	1	1	0
Maximum:	0.2	13.9	2,128.6	0.3	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/30/2022 00:00	0.1	13.8	1,609.1	0.2	1.1	1	1	0
01/30/2022 01:00	-0.1	13.9	1,401.1	0.0	1.0	1	1	0
01/30/2022 02:00	0.1	13.8	1,756.1	0.2	1.2	1	1	0
01/30/2022 03:00	-0.8	13.4	1,887.8	-0.5	1.3	1	1	1
01/30/2022 04:00	-0.9	13.3	1,868.6	-0.7	1.3	1	1	1
01/30/2022 05:00	-0.4	13.8	1,626.7	-0.2	1.1	1	1	1
01/30/2022 06:00	-1.2	13.0	2,023.2	-0.8	1.4	1	1	1
01/30/2022 07:00	0.0	13.7	1,536.4	0.0	1.1	1	0	1
01/30/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/30/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/30/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/30/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/30/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/30/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/30/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/30/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/30/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/30/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/30/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/30/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/30/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/30/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/30/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/30/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	-0.4	13.6	1,713.6	-0.2	1.2	8 #	7 #	5 #
Minimum:	-1.2	13.0	1,401.1	-0.8	1.0	0	0	0
Maximum:	0.1	13.9	2,023.2	0.2	1.4	1	1	1
%SI	66.67	66.67	66.67	66.67	66.67	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/31/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/31/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/31/2022 02:00	0.0	17.6	342.8	0.0	0.2	1	0	0
01/31/2022 03:00	0.0	15.5	865.7	0.0	0.6	1	0	0
01/31/2022 04:00	0.0	13.8	1,487.4	0.1	1.0	1	1	0
01/31/2022 05:00	-0.4	13.8	1,606.4	-0.2	1.1	1	1	1
01/31/2022 06:00	-0.7	13.0	1,991.1	-0.4	1.4	1	1	1
01/31/2022 07:00	-0.8	12.9	2,064.8	-0.4	1.4	1	1	1
01/31/2022 08:00	-0.7	13.2	1,960.7	-0.4	1.4	1	1	1
01/31/2022 09:00	-0.4	13.8	1,610.1	-0.2	1.1	1	1	1
01/31/2022 10:00	0.0	13.8	1,490.7	0.1	1.0	1	1	0
01/31/2022 11:00	0.1	13.8	1,563.0	0.2	1.1	1	1	0
01/31/2022 12:00	0.1	13.8	1,600.6	0.2	1.1	1	1	0
01/31/2022 13:00	0.1	13.9	1,442.8	0.2	1.0	1	1	0
01/31/2022 14:00	0.1	13.9	1,561.2	0.2	1.1	1	1	0
01/31/2022 15:00	-0.4	13.7	1,659.5	-0.2	1.2	1	1	1
01/31/2022 16:00	-1.1	12.8	2,010.2	-0.7	1.4	1	1	1
01/31/2022 17:00	-1.2	12.4	2,118.2	-0.7	1.5	1	1	1
01/31/2022 18:00	-1.1	12.4	2,120.0	-0.5	1.5	1	1	1
01/31/2022 19:00	-0.8	13.1	1,938.8	-0.5	1.4	1	1	1
01/31/2022 20:00	0.2	13.8	1,615.9	0.3	1.1	1	1	0
01/31/2022 21:00	-0.1	13.8	1,688.6	0.1	1.2	1	1	1
01/31/2022 22:00	-1.1	12.9	2,010.8	-0.7	1.4	1	1	1
01/31/2022 23:00	0.0	14.3	1,222.7	0.0	0.9	1	0	1
Average/Sum#:	-0.4	13.7	1,635.1	-0.2	1.1	22 #	19 #	13 #
Minimum:	-1.2	12.4	342.8	-0.7	0.2	0	0	0
Maximum:	0.2	17.6	2,120.0	0.3	1.5	1	1	1
%SI	8.33	8.33	8.33	8.33	8.33	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/01/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2022 05:00	0.0	16.6	465.6	0.0	0.3	1	0	0
02/01/2022 06:00	0.0	14.5	1,134.6	0.0	0.8	1	0	0
02/01/2022 07:00	-0.8	13.1	1,674.3	-0.5	1.2	1	1	1
02/01/2022 08:00	-0.9	11.6	2,360.2	-0.4	1.7	1	1	1
02/01/2022 09:00	-0.8	11.5	2,355.4	-0.2	1.6	1	1	1
02/01/2022 10:00	-0.2	13.5	1,868.7	-0.1	1.3	1	1	1
02/01/2022 11:00	0.2	13.9	1,569.3	0.3	1.1	1	1	0
02/01/2022 12:00	0.1	13.9	1,312.6	0.1	0.9	1	1	0
02/01/2022 13:00	0.1	13.9	1,312.2	0.1	0.9	1	1	0
02/01/2022 14:00	0.1	13.9	1,313.0	0.1	0.9	1	1	0
02/01/2022 15:00	0.1	13.9	1,335.2	0.2	0.9	1	1	0
02/01/2022 16:00	0.1	13.9	1,559.0	0.2	1.1	1	1	0
02/01/2022 17:00	0.2	13.8	1,818.8	0.3	1.3	1	1	0
02/01/2022 18:00	-0.8	13.2	1,951.6	-0.5	1.4	1	1	1
02/01/2022 19:00	-0.9	12.8	2,058.6	-0.5	1.4	1	1	1
02/01/2022 20:00	-0.9	12.9	2,005.4	-0.5	1.4	1	1	1
02/01/2022 21:00	0.2	13.8	1,615.2	0.3	1.1	1	1	0
02/01/2022 22:00	-0.1	13.8	1,798.8	0.1	1.3	1	1	1
02/01/2022 23:00	-0.9	12.9	2,049.6	-0.5	1.4	1	1	1
Average/Sum#:	-0.3	13.5	1,661.0	-0.1	1.2	19 #	17 #	9 #
Minimum:	-0.9	11.5	465.6	-0.5	0.3	0	0	0
Maximum:	0.2	16.6	2,360.2	0.3	1.7	1	1	1
%SI	20.83	20.83	20.83	20.83	20.83	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/02/2022 00:00	-1.1	12.2	2,195.1	-0.5	1.5	1	1	1
02/02/2022 01:00	-0.2	13.7	1,750.9	-0.1	1.2	1	1	1
02/02/2022 02:00	-0.4	13.8	1,609.1	-0.2	1.1	1	1	1
02/02/2022 03:00	-0.9	13.0	2,029.7	-0.5	1.4	1	1	1
02/02/2022 04:00	-0.8	13.1	1,996.9	-0.5	1.4	1	1	1
02/02/2022 05:00	-1.1	12.8	2,053.5	-0.7	1.4	1	1	1
02/02/2022 06:00	-1.1	12.7	2,114.5	-0.7	1.5	1	1	1
02/02/2022 07:00	-1.1	12.8	2,069.7	-0.7	1.4	1	1	1
02/02/2022 08:00	-0.8	13.0	2,038.4	-0.4	1.4	1	1	1
02/02/2022 09:00	-0.7	13.6	1,675.6	-0.4	1.2	1	1	1
02/02/2022 10:00	0.0	14.9	907.4	0.0	0.6	1	0	0
02/02/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2022 15:00	0.0	18.7	213.6	0.0	0.1	1	0	0
02/02/2022 16:00	0.0	15.9	707.7	0.0	0.5	1	0	0
02/02/2022 17:00	0.0	13.7	1,727.8	0.0	1.2	1	0	1
02/02/2022 18:00	-1.1	12.7	2,083.0	-0.7	1.5	1	1	1
02/02/2022 19:00	-0.8	11.9	2,264.5	-0.4	1.6	1	1	1
02/02/2022 20:00	-0.7	11.8	2,275.1	-0.2	1.6	1	1	1
02/02/2022 21:00	-0.8	12.1	2,191.9	-0.4	1.5	1	1	1
02/02/2022 22:00	-0.7	12.5	2,093.8	-0.2	1.5	1	1	1
02/02/2022 23:00	-0.8	12.7	2,063.8	-0.4	1.4	1	1	1
Average/Sum#:	-0.7	13.4	1,803.1	-0.4	1.3	20 #	16 #	17 #
Minimum:	-1.1	11.8	213.6	-0.7	0.1	0	0	0
Maximum:	0.0	18.7	2,275.1	0.0	1.6	1	1	1
%SI	16.67	16.67	16.67	16.67	16.67	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/03/2022 00:00	-0.5	13.2	1,946.0	-0.2	1.4	1	1	1
02/03/2022 01:00	0.2	13.8	1,686.6	0.3	1.2	1	1	0
02/03/2022 02:00	-0.1	13.8	1,817.8	0.1	1.3	1	1	1
02/03/2022 03:00	-0.7	12.8	2,041.4	-0.4	1.4	1	1	1
02/03/2022 04:00	-0.7	12.9	2,021.0	-0.4	1.4	1	1	1
02/03/2022 05:00	-0.7	12.8	2,031.6	-0.4	1.4	1	1	1
02/03/2022 06:00	-0.8	12.3	2,185.2	-0.4	1.5	1	1	1
02/03/2022 07:00	-0.7	12.5	2,127.9	-0.2	1.5	1	1	1
02/03/2022 08:00	-0.5	13.2	1,953.7	-0.2	1.4	1	1	1
02/03/2022 09:00	-0.4	13.8	1,477.4	-0.2	1.0	1	1	1
02/03/2022 10:00	0.1	13.8	1,689.7	0.2	1.2	1	1	0
02/03/2022 11:00	0.2	13.8	1,695.7	0.3	1.2	1	1	0
02/03/2022 12:00	0.1	13.9	1,405.6	0.2	1.0	1	1	0
02/03/2022 13:00	0.1	13.9	1,574.3	0.2	1.1	1	1	0
02/03/2022 14:00	0.1	13.9	1,494.0	0.2	1.0	1	1	0
02/03/2022 15:00	-0.2	13.8	1,555.7	-0.1	1.1	1	1	1
02/03/2022 16:00	-1.1	12.8	2,008.0	-0.7	1.4	1	1	1
02/03/2022 17:00	-1.2	12.4	2,098.2	-0.7	1.5	1	1	1
02/03/2022 18:00	-1.1	12.3	2,148.2	-0.5	1.5	1	1	1
02/03/2022 19:00	-1.1	12.3	2,151.2	-0.5	1.5	1	1	1
02/03/2022 20:00	-1.1	12.3	2,153.7	-0.5	1.5	1	1	1
02/03/2022 21:00	-0.9	12.0	2,215.7	-0.4	1.6	1	1	1
02/03/2022 22:00	-1.1	12.4	2,126.4	-0.5	1.5	1	1	1
02/03/2022 23:00	-1.1	12.5	2,101.7	-0.5	1.5	1	1	1
Average/Sum#:	-0.6	13.1	1,904.4	-0.2	1.3	24 #	24 #	18 #
Minimum:	-1.2	12.0	1,405.6	-0.7	1.0	1	1	0
Maximum:	0.2	13.9	2,215.7	0.3	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/04/2022 00:00	-0.9	12.7	2,062.4	-0.5	1.4	1	1	1
02/04/2022 01:00	-0.8	13.2	1,939.9	-0.5	1.4	1	1	1
02/04/2022 02:00	0.1	13.8	1,629.5	0.2	1.1	1	1	0
02/04/2022 03:00	0.1	13.8	1,557.9	0.2	1.1	1	1	0
02/04/2022 04:00	-0.4	13.8	1,618.4	-0.2	1.1	1	1	1
02/04/2022 05:00	-1.2	12.8	2,032.7	-0.7	1.4	1	1	1
02/04/2022 06:00	-1.2	12.2	2,194.2	-0.7	1.5	1	1	1
02/04/2022 07:00	-0.9	12.6	2,098.0	-0.5	1.5	1	1	1
02/04/2022 08:00	0.0	14.6	1,200.8	0.0	0.8	1	0	1
02/04/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/04/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/04/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/04/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/04/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/04/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/04/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/04/2022 16:00	0.0	16.3	627.0	0.0	0.4	1	0	0
02/04/2022 17:00	0.0	14.0	1,550.1	0.0	1.1	1	0	0
02/04/2022 18:00	0.1	13.9	1,487.3	0.1	1.0	1	1	0
02/04/2022 19:00	-0.9	13.2	1,909.6	-0.5	1.3	1	1	1
02/04/2022 20:00	-1.1	13.1	1,952.9	-0.7	1.4	1	1	1
02/04/2022 21:00	-0.9	13.2	1,948.3	-0.5	1.4	1	1	1
02/04/2022 22:00	-0.9	13.1	1,975.5	-0.5	1.4	1	1	1
02/04/2022 23:00	-1.1	12.7	2,055.7	-0.7	1.4	1	1	1
Average/Sum#:	-0.6	13.5	1,755.3	-0.3	1.2	17 #	14 #	12 #
Minimum:	-1.2	12.2	627.0	-0.7	0.4	0	0	0
Maximum:	0.1	16.3	2,194.2	0.2	1.5	1	1	1
%SI	29.17	29.17	29.17	29.17	29.17	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/05/2022 00:00	-0.9	13.2	1,952.1	-0.5	1.4	1	1	1
02/05/2022 01:00	-0.4	13.7	1,719.6	-0.2	1.2	1	1	1
02/05/2022 02:00	0.0	13.9	1,425.1	0.1	1.0	1	1	0
02/05/2022 03:00	-0.8	13.3	1,917.8	-0.5	1.3	1	1	1
02/05/2022 04:00	-0.9	13.2	1,962.5	-0.5	1.4	1	1	1
02/05/2022 05:00	-0.2	13.8	1,738.0	-0.1	1.2	1	1	1
02/05/2022 06:00	-0.4	13.8	1,621.4	-0.2	1.1	1	1	1
02/05/2022 07:00	-1.1	12.8	2,041.6	-0.7	1.4	1	1	1
02/05/2022 08:00	0.0	14.4	1,233.2	0.0	0.9	1	0	1
02/05/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/05/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/05/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/05/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/05/2022 13:00	0.0	18.1	294.9	0.0	0.2	1	0	0
02/05/2022 14:00	0.0	15.5	856.7	0.0	0.6	1	0	0
02/05/2022 15:00	0.1	13.9	1,374.8	0.2	1.0	1	1	0
02/05/2022 16:00	0.1	13.9	1,430.8	0.2	1.0	1	1	0
02/05/2022 17:00	0.1	13.8	1,622.3	0.2	1.1	1	1	0
02/05/2022 18:00	0.1	13.8	1,609.8	0.2	1.1	1	1	0
02/05/2022 19:00	0.1	14.0	1,319.6	0.2	0.9	1	1	0
02/05/2022 20:00	-0.4	13.8	1,573.5	-0.2	1.1	1	1	1
02/05/2022 21:00	-1.2	12.7	2,038.2	-0.7	1.4	1	1	1
02/05/2022 22:00	-1.1	12.7	2,054.3	-0.7	1.4	1	1	1
02/05/2022 23:00	-1.1	12.7	2,061.0	-0.7	1.4	1	1	1
Average/Sum#:	-0.4	13.9	1,592.4	-0.2	1.1	20 #	17 #	12 #
Minimum:	-1.2	12.7	294.9	-0.7	0.2	0	0	0
Maximum:	0.1	18.1	2,061.0	0.2	1.4	1	1	1
%SI	16.67	16.67	16.67	16.67	16.67	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/06/2022 00:00	-0.9	13.2	1,947.5	-0.5	1.4	1	1	1
02/06/2022 01:00	-0.2	13.8	1,698.0	-0.1	1.2	1	1	1
02/06/2022 02:00	-0.4	13.8	1,639.8	-0.2	1.1	1	1	1
02/06/2022 03:00	-0.8	12.9	2,015.1	-0.4	1.4	1	1	1
02/06/2022 04:00	-0.7	13.2	1,943.3	-0.4	1.4	1	1	1
02/06/2022 05:00	0.1	13.8	1,585.3	0.2	1.1	1	1	0
02/06/2022 06:00	-0.1	13.9	1,333.8	0.0	0.9	1	1	0
02/06/2022 07:00	0.1	13.8	1,573.7	0.2	1.1	1	1	0
02/06/2022 08:00	0.0	15.9	468.5	0.0	0.3	1	0	0
02/06/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/06/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/06/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/06/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/06/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/06/2022 14:00	0.0	17.9	314.7	0.0	0.2	1	0	0
02/06/2022 15:00	0.0	15.5	848.0	0.0	0.6	1	0	0
02/06/2022 16:00	0.1	13.9	1,398.6	0.2	1.0	1	1	0
02/06/2022 17:00	-1.1	13.2	1,882.9	-0.7	1.3	1	1	1
02/06/2022 18:00	-1.2	13.0	1,945.2	-0.8	1.4	1	1	1
02/06/2022 19:00	-1.2	13.1	1,944.8	-0.8	1.4	1	1	1
02/06/2022 20:00	-1.2	13.1	1,943.8	-0.8	1.4	1	1	1
02/06/2022 21:00	-1.2	13.1	1,933.6	-0.8	1.4	1	1	1
02/06/2022 22:00	0.1	13.8	1,659.3	0.1	1.2	1	1	0
02/06/2022 23:00	0.0	16.1	421.3	0.0	0.3	1	0	0
Average/Sum#:	-0.5	14.1	1,499.9	-0.3	1.1	19 #	15 #	10 #
Minimum:	-1.2	12.9	314.7	-0.8	0.2	0	0	0
Maximum:	0.1	17.9	2,015.1	0.2	1.4	1	1	1
%SI	20.83	20.83	20.83	20.83	20.83	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/07/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/07/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/07/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/07/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/07/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/07/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/07/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/07/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/07/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/07/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/07/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/07/2022 11:00	0.0	17.9	291.8	0.0	0.2	1	0	0
02/07/2022 12:00	0.0	17.5	332.8	0.0	0.2	1	0	0
02/07/2022 13:00	0.0	15.7	796.3	0.0	0.6	1	0	0
02/07/2022 14:00	0.1	13.9	1,385.1	0.1	1.0	1	1	0
02/07/2022 15:00	0.1	13.9	1,384.8	0.1	1.0	1	1	0
02/07/2022 16:00	0.1	13.7	1,656.0	0.2	1.2	1	1	0
02/07/2022 17:00	0.1	13.9	1,583.3	0.1	1.1	1	1	0
02/07/2022 18:00	0.1	13.9	1,422.9	0.1	1.0	1	1	0
02/07/2022 19:00	-0.4	13.8	1,596.4	-0.2	1.1	1	1	1
02/07/2022 20:00	-1.4	12.6	2,078.8	-0.8	1.5	1	1	1
02/07/2022 21:00	-1.2	12.5	2,103.3	-0.7	1.5	1	1	1
02/07/2022 22:00	-1.1	12.6	2,089.7	-0.7	1.5	1	1	1
02/07/2022 23:00	0.0	14.3	1,231.5	0.0	0.9	1	0	1
Average/Sum#:	-0.3	14.3	1,381.0	-0.1	1.0	13 #	9 #	5 #
Minimum:	-1.4	12.5	291.8	-0.8	0.2	0	0	0
Maximum:	0.1	17.9	2,103.3	0.2	1.5	1	1	1
%SI	45.83	45.83	45.83	45.83	45.83	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/08/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2022 03:00	0.0	17.7	359.4	0.0	0.3	1	0	0
02/08/2022 04:00	0.0	14.5	1,227.9	0.0	0.9	1	0	0
02/08/2022 05:00	0.1	13.9	1,408.0	0.1	1.0	1	1	0
02/08/2022 06:00	0.1	13.9	1,399.1	0.1	1.0	1	1	0
02/08/2022 07:00	0.1	13.9	1,297.0	0.1	0.9	1	1	0
02/08/2022 08:00	0.2	13.8	1,823.6	0.3	1.3	1	1	0
02/08/2022 09:00	0.1	13.7	1,842.9	0.2	1.3	1	1	0
02/08/2022 10:00	0.1	13.7	1,843.3	0.2	1.3	1	1	0
02/08/2022 11:00	0.1	13.7	1,841.3	0.2	1.3	1	1	0
02/08/2022 12:00	0.1	13.6	1,853.5	0.2	1.3	1	1	0
02/08/2022 13:00	0.1	13.6	1,854.8	0.2	1.3	1	1	0
02/08/2022 14:00	0.1	13.6	1,856.2	0.2	1.3	1	1	0
02/08/2022 15:00	0.1	13.7	1,830.2	0.2	1.3	1	1	0
02/08/2022 16:00	0.1	13.7	1,825.9	0.2	1.3	1	1	0
02/08/2022 17:00	-1.1	13.2	1,939.9	-0.7	1.4	1	1	1
02/08/2022 18:00	-1.1	12.9	2,018.1	-0.7	1.4	1	1	1
02/08/2022 19:00	-1.1	13.1	1,983.1	-0.7	1.4	1	1	1
02/08/2022 20:00	-1.2	13.1	1,990.6	-0.8	1.4	1	1	1
02/08/2022 21:00	-0.7	13.5	1,719.2	-0.4	1.2	1	1	1
02/08/2022 22:00	0.1	13.9	1,427.9	0.2	1.0	1	1	0
02/08/2022 23:00	0.1	13.9	1,385.9	0.2	1.0	1	1	0
Average/Sum#:	-0.2	13.8	1,653.7	0.0	1.2	21 #	19 #	5 #
Minimum:	-1.2	12.9	359.4	-0.8	0.3	0	0	0
Maximum:	0.2	17.7	2,018.1	0.3	1.4	1	1	1
%SI	12.50	12.50	12.50	12.50	12.50	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/09/2022 00:00	0.1	13.9	1,390.8	0.2	1.0	1	1	0
02/09/2022 01:00	0.1	13.9	1,398.1	0.2	1.0	1	1	0
02/09/2022 02:00	0.1	13.9	1,394.6	0.2	1.0	1	1	0
02/09/2022 03:00	0.1	13.9	1,390.2	0.2	1.0	1	1	0
02/09/2022 04:00	0.1	13.9	1,389.2	0.1	1.0	1	1	0
02/09/2022 05:00	0.1	13.9	1,386.7	0.1	1.0	1	1	0
02/09/2022 06:00	0.0	13.9	1,416.6	0.1	1.0	1	1	0
02/09/2022 07:00	0.1	13.7	1,839.7	0.2	1.3	1	1	0
02/09/2022 08:00	0.1	13.7	1,853.6	0.2	1.3	1	1	0
02/09/2022 09:00	0.1	13.6	1,872.2	0.2	1.3	1	1	0
02/09/2022 10:00	-0.2	13.6	1,864.0	-0.1	1.3	1	1	1
02/09/2022 11:00	-1.1	12.1	2,199.8	-0.5	1.5	1	1	1
02/09/2022 12:00	-0.9	12.2	2,109.9	-0.4	1.5	1	1	1
02/09/2022 13:00	0.1	13.6	1,843.8	0.2	1.3	1	1	0
02/09/2022 14:00	0.1	13.6	1,844.5	0.2	1.3	1	1	0
02/09/2022 15:00	0.1	13.8	1,651.5	0.2	1.2	1	1	0
02/09/2022 16:00	0.1	13.7	1,749.8	0.2	1.2	1	1	0
02/09/2022 17:00	0.1	13.7	1,723.5	0.2	1.2	1	1	0
02/09/2022 18:00	-0.2	13.7	1,828.1	-0.1	1.3	1	1	1
02/09/2022 19:00	-0.9	12.8	2,039.5	-0.5	1.4	1	1	1
02/09/2022 20:00	-1.1	12.5	2,112.4	-0.5	1.5	1	1	1
02/09/2022 21:00	-0.9	12.4	2,117.3	-0.5	1.5	1	1	1
02/09/2022 22:00	-0.8	12.7	2,043.9	-0.4	1.4	1	1	1
02/09/2022 23:00	-0.5	13.7	1,546.5	-0.4	1.1	1	1	1
Average/Sum#:	-0.2	13.4	1,750.3	0.0	1.2	24 #	24 #	9 #
Minimum:	-1.1	12.1	1,386.7	-0.5	1.0	1	1	0
Maximum:	0.1	13.9	2,199.8	0.2	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/10/2022 00:00	0.1	13.9	1,383.3	0.1	1.0	1	1	0
02/10/2022 01:00	-0.2	13.7	1,624.4	-0.1	1.1	1	1	1
02/10/2022 02:00	-1.2	13.0	1,995.6	-0.8	1.4	1	1	1
02/10/2022 03:00	-1.1	12.9	2,005.0	-0.7	1.4	1	1	1
02/10/2022 04:00	-0.2	13.8	1,631.2	-0.1	1.1	1	1	1
02/10/2022 05:00	-0.4	13.7	1,617.8	-0.2	1.1	1	1	1
02/10/2022 06:00	-1.2	12.6	2,087.3	-0.7	1.5	1	1	1
02/10/2022 07:00	-1.1	12.6	2,054.1	-0.7	1.4	1	1	1
02/10/2022 08:00	0.0	15.6	622.6	0.0	0.4	1	0	0
02/10/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/10/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/10/2022 11:00	0.0	18.9	145.9	0.0	0.1	1	0	0
02/10/2022 12:00	0.0	15.7	810.5	0.0	0.6	1	0	0
02/10/2022 13:00	0.2	13.9	1,397.4	0.3	1.0	1	1	0
02/10/2022 14:00	0.2	13.9	1,393.4	0.3	1.0	1	1	0
02/10/2022 15:00	0.1	13.7	1,646.0	0.2	1.2	1	1	0
02/10/2022 16:00	0.1	13.8	1,607.0	0.2	1.1	1	1	0
02/10/2022 17:00	-0.7	13.2	1,587.8	-0.4	1.1	1	1	1
02/10/2022 18:00	-1.1	11.5	2,315.1	-0.5	1.6	1	1	1
02/10/2022 19:00	-0.9	11.7	2,278.8	-0.4	1.6	1	1	1
02/10/2022 20:00	-1.1	12.0	2,193.6	-0.5	1.5	1	1	1
02/10/2022 21:00	-1.1	12.6	2,074.4	-0.7	1.5	1	1	1
02/10/2022 22:00	-1.1	12.7	2,040.5	-0.7	1.4	1	1	1
02/10/2022 23:00	-0.7	13.6	1,539.0	-0.4	1.1	1	1	1
Average/Sum#:	-0.5	13.6	1,638.7	-0.3	1.1	22 #	19 #	14 #
Minimum:	-1.2	11.5	145.9	-0.8	0.1	0	0	0
Maximum:	0.2	18.9	2,315.1	0.3	1.6	1	1	1
%SI	8.33	8.33	8.33	8.33	8.33	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/11/2022 00:00	-0.1	13.9	1,324.4	0.0	0.9	1	1	0
02/11/2022 01:00	0.0	16.3	362.2	0.0	0.3	1	0	0
02/11/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/11/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/11/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/11/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/11/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/11/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/11/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/11/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/11/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/11/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/11/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/11/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/11/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/11/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/11/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/11/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/11/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/11/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/11/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/11/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/11/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/11/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	-0.1	15.1	843.3	0.0	0.6	2 #	1 #	0 #
Minimum:	-0.1	13.9	362.2	0.0	0.3	0	0	0
Maximum:	0.0	16.3	1,324.4	0.0	0.9	1	1	0
%SI	91.67	91.67	91.67	91.67	91.67	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/12/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/12/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/12/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/12/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/12/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/12/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/12/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/12/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/12/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/12/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/12/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/12/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/12/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/12/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/12/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/12/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/12/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/12/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/12/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/12/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/12/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/12/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/12/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/12/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/13/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/13/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/13/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/13/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/13/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/13/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/13/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/13/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/13/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/13/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/13/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/13/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/13/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/13/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/13/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/13/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/13/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/13/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/13/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/13/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/13/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/13/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/13/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/13/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/14/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/15/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/16/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/17/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/18/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/18/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/18/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/18/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/18/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/18/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/18/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/18/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/18/2022 08:00	0.0	19.3	116.9	0.0	0.1	1	0	0
02/18/2022 09:00	0.0	17.2	379.6	0.0	0.3	1	0	0
02/18/2022 10:00	0.0	17.2	393.2	0.0	0.3	1	0	0
02/18/2022 11:00	0.0	16.2	684.0	0.0	0.5	1	0	0
02/18/2022 12:00	0.0	15.0	1,006.2	0.0	0.7	1	0	0
02/18/2022 13:00	0.1	13.9	1,394.1	0.2	1.0	1	1	0
02/18/2022 14:00	0.1	13.9	1,395.8	0.2	1.0	1	1	0
02/18/2022 15:00	0.1	13.8	1,751.9	0.2	1.2	1	1	0
02/18/2022 16:00	0.1	13.8	1,597.5	0.1	1.1	1	1	0
02/18/2022 17:00	0.1	13.9	1,658.4	0.2	1.2	1	1	0
02/18/2022 18:00	-0.4	13.8	1,594.8	-0.2	1.1	1	1	1
02/18/2022 19:00	-1.2	12.8	2,037.3	-0.7	1.4	1	1	1
02/18/2022 20:00	-1.1	13.1	1,958.5	-0.7	1.4	1	1	1
02/18/2022 21:00	0.1	13.8	1,578.7	0.1	1.1	1	1	0
02/18/2022 22:00	-0.4	13.8	1,609.8	-0.2	1.1	1	1	1
02/18/2022 23:00	-1.1	12.9	2,034.1	-0.7	1.4	1	1	1
Average/Sum#:	-0.2	14.7	1,324.4	-0.1	0.9	16 #	11 #	5 #
Minimum:	-1.2	12.8	116.9	-0.7	0.1	0	0	0
Maximum:	0.1	19.3	2,037.3	0.2	1.4	1	1	1
%SI	33.33	33.33	33.33	33.33	33.33	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/19/2022 00:00	0.0	14.3	1,260.4	0.0	0.9	1	0	1
02/19/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/19/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/19/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/19/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/19/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/19/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/19/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/19/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/19/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/19/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/19/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/19/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/19/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/19/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/19/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/19/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/19/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/19/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/19/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/19/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/19/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/19/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/19/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	14.3	1,260.4	0.0	0.9	1 #	0 #	1 #
Minimum:	0.0	14.3	1,260.4	0.0	0.9	0	0	0
Maximum:	0.0	14.3	1,260.4	0.0	0.9	1	0	1
%SI	95.83	95.83	95.83	95.83	95.83	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/20/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/21/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2022 23:00	0.0	17.6	324.7	0.0	0.2	1	0	0
Average/Sum#:	0.0	17.6	324.7	0.0	0.2	1 #	0 #	0 #
Minimum:	0.0	17.6	324.7	0.0	0.2	0	0	0
Maximum:	0.0	17.6	324.7	0.0	0.2	1	0	0
%SI	95.83	95.83	95.83	95.83	95.83	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/22/2022 00:00	0.0	17.2	381.3	0.0	0.3	1	0	0
02/22/2022 01:00	0.0	16.1	705.1	0.0	0.5	1	0	0
02/22/2022 02:00	-0.1	13.8	1,453.2	0.1	1.0	1	1	0
02/22/2022 03:00	-0.1	13.8	1,460.4	0.1	1.0	1	1	0
02/22/2022 04:00	-0.1	13.7	1,697.2	0.1	1.2	1	1	0
02/22/2022 05:00	-0.1	13.8	1,582.8	0.1	1.1	1	1	0
02/22/2022 06:00	0.1	13.8	1,764.2	0.1	1.2	1	1	0
02/22/2022 07:00	0.0	13.8	1,602.1	0.1	1.1	1	1	0
02/22/2022 08:00	0.1	13.8	1,669.2	0.1	1.2	1	1	0
02/22/2022 09:00	0.0	13.8	1,568.6	0.1	1.1	1	1	0
02/22/2022 10:00	0.1	13.8	1,547.1	0.1	1.1	1	1	0
02/22/2022 11:00	0.1	13.8	1,547.9	0.1	1.1	1	1	0
02/22/2022 12:00	0.1	13.8	1,626.2	0.2	1.1	1	1	0
02/22/2022 13:00	0.1	13.8	1,611.1	0.1	1.1	1	1	0
02/22/2022 14:00	0.1	13.8	1,631.0	0.2	1.1	1	1	0
02/22/2022 15:00	0.1	13.8	1,645.7	0.1	1.2	1	1	0
02/22/2022 16:00	-0.4	13.8	1,652.3	-0.2	1.2	1	1	1
02/22/2022 17:00	-1.4	12.8	2,095.9	-0.8	1.5	1	1	1
02/22/2022 18:00	-1.2	12.7	2,105.6	-0.7	1.5	1	1	1
02/22/2022 19:00	-1.2	12.4	2,199.4	-0.7	1.5	1	1	1
02/22/2022 20:00	-1.1	11.8	2,337.7	-0.5	1.6	1	1	1
02/22/2022 21:00	-1.2	12.4	2,183.6	-0.7	1.5	1	1	1
02/22/2022 22:00	-1.2	12.4	2,174.0	-0.7	1.5	1	1	1
02/22/2022 23:00	-1.2	12.2	2,220.4	-0.7	1.6	1	1	1
Average/Sum#:	-0.4	13.6	1,685.9	-0.1	1.2	24 #	22 #	8 #
Minimum:	-1.4	11.8	381.3	-0.8	0.3	1	0	0
Maximum:	0.1	17.2	2,337.7	0.2	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/23/2022 00:00	-1.1	11.9	2,302.6	-0.5	1.6	1	1	1
02/23/2022 01:00	-1.2	12.1	2,240.7	-0.7	1.6	1	1	1
02/23/2022 02:00	-1.2	12.2	2,223.9	-0.7	1.6	1	1	1
02/23/2022 03:00	-1.1	12.7	2,092.5	-0.7	1.5	1	1	1
02/23/2022 04:00	0.1	13.8	1,735.7	0.2	1.2	1	1	0
02/23/2022 05:00	-0.9	13.3	1,902.1	-0.7	1.3	1	1	1
02/23/2022 06:00	-1.2	12.3	2,247.5	-0.7	1.6	1	1	1
02/23/2022 07:00	-1.2	12.2	2,247.8	-0.7	1.6	1	1	1
02/23/2022 08:00	-0.4	13.6	1,730.6	-0.2	1.2	1	1	1
02/23/2022 09:00	0.1	13.8	1,565.1	0.1	1.1	1	1	0
02/23/2022 10:00	0.1	13.8	1,627.6	0.1	1.1	1	1	0
02/23/2022 11:00	0.1	13.8	1,691.9	0.2	1.2	1	1	0
02/23/2022 12:00	0.1	13.9	1,557.1	0.1	1.1	1	1	0
02/23/2022 13:00	0.1	13.9	1,459.5	0.1	1.0	1	1	0
02/23/2022 14:00	0.1	13.8	1,670.8	0.2	1.2	1	1	0
02/23/2022 15:00	0.1	13.8	1,638.1	0.2	1.1	1	1	0
02/23/2022 16:00	-0.4	13.8	1,662.2	-0.2	1.2	1	1	1
02/23/2022 17:00	-1.1	13.0	2,048.2	-0.7	1.4	1	1	1
02/23/2022 18:00	-1.1	12.8	2,093.4	-0.7	1.5	1	1	1
02/23/2022 19:00	-0.9	12.9	2,094.3	-0.5	1.5	1	1	1
02/23/2022 20:00	-1.1	12.4	2,194.8	-0.5	1.5	1	1	1
02/23/2022 21:00	-0.9	11.7	2,355.2	-0.4	1.6	1	1	1
02/23/2022 22:00	-1.1	12.3	2,217.2	-0.5	1.6	1	1	1
02/23/2022 23:00	-1.1	12.6	2,170.8	-0.7	1.5	1	1	1
Average/Sum#:	-0.6	13.0	1,948.7	-0.3	1.4	24 #	24 #	16 #
Minimum:	-1.2	11.7	1,459.5	-0.7	1.0	1	1	0
Maximum:	0.1	13.9	2,355.2	0.2	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/24/2022 00:00	-1.1	12.0	2,310.2	-0.5	1.6	1	1	1
02/24/2022 01:00	-1.1	12.0	2,301.4	-0.5	1.6	1	1	1
02/24/2022 02:00	-1.1	11.9	2,330.9	-0.5	1.6	1	1	1
02/24/2022 03:00	-0.9	11.7	2,357.2	-0.4	1.7	1	1	1
02/24/2022 04:00	-1.1	11.9	2,354.3	-0.5	1.6	1	1	1
02/24/2022 05:00	-1.1	11.8	2,360.9	-0.5	1.7	1	1	1
02/24/2022 06:00	-1.1	11.8	2,361.4	-0.5	1.7	1	1	1
02/24/2022 07:00	-1.1	12.2	2,279.1	-0.5	1.6	1	1	1
02/24/2022 08:00	-1.1	12.8	2,116.0	-0.7	1.5	1	1	1
02/24/2022 09:00	-0.9	13.1	2,020.2	-0.5	1.4	1	1	1
02/24/2022 10:00	0.1	13.8	1,604.3	0.1	1.1	1	1	0
02/24/2022 11:00	0.0	13.9	1,464.1	0.1	1.0	1	1	0
02/24/2022 12:00	-0.1	13.9	1,369.7	0.0	1.0	1	1	0
02/24/2022 13:00	0.1	13.9	1,419.0	0.1	1.0	1	1	0
02/24/2022 14:00	0.1	13.9	1,502.8	0.1	1.1	1	1	0
02/24/2022 15:00	0.1	13.9	1,498.2	0.1	1.0	1	1	0
02/24/2022 16:00	-0.5	13.8	1,608.5	-0.4	1.1	1	1	1
02/24/2022 17:00	-1.1	12.9	2,054.7	-0.7	1.4	1	1	1
02/24/2022 18:00	-1.1	11.9	2,302.0	-0.5	1.6	1	1	1
02/24/2022 19:00	-0.9	11.6	2,358.8	-0.4	1.7	1	1	1
02/24/2022 20:00	-0.9	12.0	2,276.3	-0.4	1.6	1	1	1
02/24/2022 21:00	-0.9	11.8	2,316.4	-0.4	1.6	1	1	1
02/24/2022 22:00	-1.1	12.0	2,306.8	-0.5	1.6	1	1	1
02/24/2022 23:00	-1.2	12.2	2,245.5	-0.7	1.6	1	1	1
Average/Sum#:	-0.8	12.6	2,046.6	-0.4	1.4	24 #	24 #	18 #
Minimum:	-1.2	11.6	1,369.7	-0.7	1.0	1	1	0
Maximum:	0.1	13.9	2,361.4	0.1	1.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/25/2022 00:00	-1.1	12.6	2,144.7	-0.7	1.5	1	1	1
02/25/2022 01:00	-0.9	12.9	2,075.0	-0.5	1.5	1	1	1
02/25/2022 02:00	-0.9	12.9	2,079.4	-0.5	1.5	1	1	1
02/25/2022 03:00	-0.9	12.9	2,092.3	-0.5	1.5	1	1	1
02/25/2022 04:00	-1.1	12.7	2,140.5	-0.7	1.5	1	1	1
02/25/2022 05:00	-1.1	12.8	2,099.4	-0.7	1.5	1	1	1
02/25/2022 06:00	-1.1	12.0	2,288.7	-0.5	1.6	1	1	1
02/25/2022 07:00	-1.1	12.8	2,106.7	-0.7	1.5	1	1	1
02/25/2022 08:00	-0.9	13.1	1,995.7	-0.5	1.4	1	1	1
02/25/2022 09:00	0.1	13.8	1,555.8	0.1	1.1	1	1	0
02/25/2022 10:00	0.1	13.9	1,543.5	0.2	1.1	1	1	0
02/25/2022 11:00	0.1	13.8	1,659.5	0.2	1.2	1	1	0
02/25/2022 12:00	0.1	13.8	1,632.3	0.2	1.1	1	1	0
02/25/2022 13:00	0.1	13.9	1,642.0	0.2	1.1	1	1	0
02/25/2022 14:00	0.1	13.9	1,625.8	0.2	1.1	1	1	0
02/25/2022 15:00	0.1	13.9	1,585.3	0.2	1.1	1	1	0
02/25/2022 16:00	-0.2	13.8	1,683.4	-0.1	1.2	1	1	1
02/25/2022 17:00	-1.1	12.9	2,036.2	-0.7	1.4	1	1	1
02/25/2022 18:00	-0.8	13.0	1,991.9	-0.4	1.4	1	1	1
02/25/2022 19:00	-0.8	13.1	1,979.3	-0.5	1.4	1	1	1
02/25/2022 20:00	-0.9	13.0	2,021.8	-0.5	1.4	1	1	1
02/25/2022 21:00	-0.9	12.8	2,058.0	-0.5	1.4	1	1	1
02/25/2022 22:00	-1.1	12.7	2,102.3	-0.7	1.5	1	1	1
02/25/2022 23:00	-1.1	12.7	2,105.2	-0.7	1.5	1	1	1
Average/Sum#:	-0.6	13.2	1,926.9	-0.3	1.4	24 #	24 #	17 #
Minimum:	-1.1	12.0	1,543.5	-0.7	1.1	1	1	0
Maximum:	0.1	13.9	2,288.7	0.2	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/26/2022 00:00	-1.1	12.7	2,136.2	-0.7	1.5	1	1	1
02/26/2022 01:00	-1.1	12.6	2,147.3	-0.7	1.5	1	1	1
02/26/2022 02:00	-0.9	13.1	2,008.5	-0.5	1.4	1	1	1
02/26/2022 03:00	-1.1	13.2	2,006.3	-0.7	1.4	1	1	1
02/26/2022 04:00	-0.9	12.8	2,089.7	-0.5	1.5	1	1	1
02/26/2022 05:00	-0.9	12.9	2,085.7	-0.5	1.5	1	1	1
02/26/2022 06:00	-0.9	12.9	2,068.3	-0.5	1.4	1	1	1
02/26/2022 07:00	0.0	14.4	1,244.5	0.0	0.9	1	0	1
02/26/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/26/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/26/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/26/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/26/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/26/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/26/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/26/2022 15:00	0.0	18.0	303.4	0.0	0.2	1	0	0
02/26/2022 16:00	0.0	15.7	817.8	0.0	0.6	1	0	0
02/26/2022 17:00	-0.4	13.8	1,526.7	-0.2	1.1	1	1	1
02/26/2022 18:00	-1.2	13.1	1,990.5	-0.8	1.4	1	1	1
02/26/2022 19:00	-1.1	13.1	2,000.5	-0.7	1.4	1	1	1
02/26/2022 20:00	-1.1	13.1	1,999.3	-0.7	1.4	1	1	1
02/26/2022 21:00	-1.4	12.6	2,124.5	-0.8	1.5	1	1	1
02/26/2022 22:00	-1.2	12.8	2,072.8	-0.7	1.5	1	1	1
02/26/2022 23:00	0.0	14.1	1,314.2	0.0	0.9	1	0	1
Average/Sum#:	-0.8	13.6	1,761.0	-0.5	1.2	17 #	13 #	15 #
Minimum:	-1.4	12.6	303.4	-0.8	0.2	0	0	0
Maximum:	0.0	18.0	2,147.3	0.0	1.5	1	1	1
%SI	29.17	29.17	29.17	29.17	29.17	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/27/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/28/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2022 13:00	0.0	17.6	332.4	0.0	0.2	1	0	0
02/28/2022 14:00	0.0	17.2	392.9	0.0	0.3	1	0	0
02/28/2022 15:00	0.0	15.6	830.2	0.0	0.6	1	0	0
02/28/2022 16:00	0.1	13.9	1,499.6	0.2	1.0	1	1	0
02/28/2022 17:00	-0.9	13.1	1,979.3	-0.5	1.4	1	1	1
02/28/2022 18:00	-1.4	12.3	2,134.2	-0.8	1.5	1	1	1
02/28/2022 19:00	-1.1	12.8	2,016.0	-0.7	1.4	1	1	1
02/28/2022 20:00	-1.1	12.9	2,000.9	-0.7	1.4	1	1	1
02/28/2022 21:00	-1.1	13.0	1,966.4	-0.7	1.4	1	1	1
02/28/2022 22:00	0.0	15.6	605.1	0.0	0.4	1	0	0
02/28/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	-0.6	14.4	1,375.7	-0.3	1.0	10 #	6 #	5 #
Minimum:	-1.4	12.3	332.4	-0.8	0.2	0	0	0
Maximum:	0.1	17.6	2,134.2	0.2	1.5	1	1	1
%SI	58.33	58.33	58.33	58.33	58.33	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/01/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/02/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/03/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/04/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/04/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/04/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/04/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/04/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/04/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/04/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/04/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/04/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/04/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/04/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/04/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/04/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/04/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/04/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/04/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/04/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/04/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/04/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/04/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/04/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/04/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/04/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/04/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/05/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/05/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/05/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/05/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/05/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/05/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/05/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/05/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/05/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/05/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/05/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/05/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/05/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/05/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/05/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/05/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/05/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/05/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/05/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/05/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/05/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/05/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/05/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/05/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/06/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/06/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/06/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/06/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/06/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/06/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/06/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/06/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/06/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/06/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/06/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/06/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/06/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/06/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/06/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/06/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/06/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/06/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/06/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/06/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/06/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/06/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/06/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/06/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/07/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/08/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/09/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/09/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/09/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/09/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/09/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/09/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/09/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/09/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/09/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/09/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/09/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/09/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/09/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/09/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/09/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/09/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/09/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/09/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/09/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/09/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/09/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/09/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/09/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/09/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/10/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/10/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/10/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/10/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/10/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/10/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/10/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/10/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/10/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/10/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/10/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/10/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/10/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/10/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/10/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/10/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/10/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/10/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/10/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/10/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/10/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/10/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/10/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/10/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/11/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/11/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/11/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/11/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/11/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/11/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/11/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/11/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/11/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/11/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/11/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/11/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/11/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/11/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/11/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/11/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/11/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/11/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/11/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/11/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/11/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/11/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/11/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/11/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/12/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/12/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/12/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/12/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/12/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/12/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/12/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/12/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/12/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/12/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/12/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/12/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/12/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/12/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/12/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/12/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/12/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/12/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/12/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/12/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/12/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/12/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/12/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/12/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/13/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/13/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/13/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/13/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/13/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/13/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/13/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/13/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/13/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/13/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/13/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/13/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/13/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/13/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/13/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/13/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/13/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/13/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/13/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/13/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/13/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/13/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/13/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/13/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/14/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/14/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/14/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/14/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/14/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/14/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/14/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/14/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/14/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/14/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/14/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/14/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/14/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/14/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/14/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/14/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/14/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/14/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/14/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/14/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/14/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/14/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/14/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/14/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/15/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/15/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/15/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/15/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/15/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/15/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/15/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/15/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/15/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/15/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/15/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/15/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/15/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/15/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/15/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/15/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/15/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/15/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/15/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/15/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/15/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/15/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/15/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/15/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/16/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/16/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/16/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/16/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/16/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/16/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/16/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/16/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/16/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/16/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/16/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/16/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/16/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/16/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/16/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/16/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/16/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/16/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/16/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/16/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/16/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/16/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/16/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/16/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/17/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/17/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/17/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/17/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/17/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/17/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/17/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/17/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/17/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/17/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/17/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/17/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/17/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/17/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/17/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/17/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/17/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/17/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/17/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/17/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/17/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/17/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/17/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/17/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/18/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/18/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/18/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/18/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/18/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/18/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/18/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/18/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/18/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/18/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/18/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/18/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/18/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/18/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/18/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/18/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/18/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/18/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/18/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/18/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/18/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/18/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/18/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/18/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/19/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/19/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/19/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/19/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/19/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/19/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/19/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/19/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/19/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/19/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/19/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/19/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/19/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/19/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/19/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/19/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/19/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/19/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/19/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/19/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/19/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/19/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/19/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/19/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/20/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/20/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/20/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/20/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/20/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/20/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/20/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/20/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/20/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/20/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/20/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/20/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/20/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/20/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/20/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/20/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/20/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/20/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/20/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/20/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/20/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/20/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/20/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/20/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/21/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/22/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/23/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/24/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/25/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/26/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/27/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/28/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/29/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/30/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:11 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/31/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/01/2022 00:00	-0.2	13.3	1,909.9	-0.1	0.6	1	1	1
01/01/2022 01:00	0.4	13.9	1,589.2	0.4	0.5	1	1	0
01/01/2022 02:00	0.3	13.9	1,542.9	0.4	0.5	1	1	0
01/01/2022 03:00	0.3	13.9	1,743.3	0.4	0.5	1	1	0
01/01/2022 04:00	-0.1	13.6	1,842.3	0.1	0.6	1	1	1
01/01/2022 05:00	-0.1	13.5	1,839.7	0.1	0.6	1	1	1
01/01/2022 06:00	0.1	13.8	1,792.0	0.2	0.5	1	1	1
01/01/2022 07:00	-0.2	13.2	1,977.6	-0.1	0.6	1	1	1
01/01/2022 08:00	0.1	13.6	1,666.2	0.2	0.5	1	1	1
01/01/2022 09:00	0.0	15.0	889.4	0.0	0.3	1	0	0
01/01/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/01/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/01/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/01/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/01/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/01/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/01/2022 16:00	0.0	18.4	273.7	0.0	0.1	1	0	0
01/01/2022 17:00	0.0	15.8	812.6	0.0	0.2	1	0	0
01/01/2022 18:00	0.4	13.9	1,765.4	0.4	0.5	1	1	0
01/01/2022 19:00	0.1	13.8	1,796.6	0.2	0.5	1	1	1
01/01/2022 20:00	-0.4	12.8	2,066.2	-0.1	0.6	1	1	1
01/01/2022 21:00	-0.2	12.6	2,108.0	0.1	0.6	1	1	1
01/01/2022 22:00	-0.2	12.7	2,090.2	0.1	0.6	1	1	1
01/01/2022 23:00	-0.2	12.8	2,068.4	0.1	0.6	1	1	1
Average/Sum#:	0.0	13.9	1,654.1	0.1	0.5	18 #	15 #	11 #
Minimum:	-0.4	12.6	273.7	-0.1	0.1	0	0	0
Maximum:	0.4	18.4	2,108.0	0.4	0.6	1	1	1
%SI	25.00	25.00	25.00	25.00	25.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	VOC, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT2	Unit CT2	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	VOC, Ppmvdc	VOC, LbPerHr	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/02/2022 00:00	-0.5	13.2	1,934.3	-0.2	0.6	1	1	1
01/02/2022 01:00	0.4	13.9	1,522.0	0.4	0.5	1	1	0
01/02/2022 02:00	0.3	13.9	1,396.8	0.4	0.4	1	1	0
01/02/2022 03:00	0.3	13.8	1,714.4	0.4	0.5	1	1	0
01/02/2022 04:00	-0.4	13.5	1,832.8	-0.2	0.5	1	1	1
01/02/2022 05:00	-0.4	13.4	1,836.6	-0.2	0.6	1	1	1
01/02/2022 06:00	0.1	13.8	1,771.7	0.2	0.5	1	1	1
01/02/2022 07:00	-0.1	13.2	1,981.4	0.1	0.6	1	1	1
01/02/2022 08:00	0.1	13.6	1,668.3	0.2	0.5	1	1	1
01/02/2022 09:00	0.0	15.0	896.5	0.0	0.3	1	0	0
01/02/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/02/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/02/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/02/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/02/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/02/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/02/2022 16:00	0.0	18.4	240.6	0.0	0.1	1	0	0
01/02/2022 17:00	0.0	15.7	829.9	0.0	0.2	1	0	0
01/02/2022 18:00	0.1	13.7	1,769.2	0.2	0.5	1	1	1
01/02/2022 19:00	-0.5	12.9	2,024.3	-0.2	0.6	1	1	1
01/02/2022 20:00	-0.2	12.4	2,138.0	0.1	0.6	1	1	1
01/02/2022 21:00	-0.2	12.7	2,061.8	0.1	0.6	1	1	1
01/02/2022 22:00	-0.2	12.7	2,056.6	0.1	0.6	1	1	1
01/02/2022 23:00	-0.5	13.1	1,970.3	-0.2	0.6	1	1	1
Average/Sum#:	-0.1	13.8	1,647.0	0.1	0.5	18 #	15 #	12 #
Minimum:	-0.5	12.4	240.6	-0.2	0.1	0	0	0
Maximum:	0.4	18.4	2,138.0	0.4	0.6	1	1	1
%SI	25.00	25.00	25.00	25.00	25.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	VOC, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT2	Unit CT2	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	VOC, Ppmvdc	VOC, LbPerHr	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/03/2022 00:00	-0.7	13.3	1,908.5	-0.4	0.6	1	1	1
01/03/2022 01:00	0.3	13.9	1,628.6	0.4	0.5	1	1	0
01/03/2022 02:00	0.1	13.8	1,648.2	0.2	0.5	1	1	1
01/03/2022 03:00	-0.4	13.2	1,971.1	-0.1	0.6	1	1	1
01/03/2022 04:00	-0.4	13.2	1,965.4	-0.1	0.6	1	1	1
01/03/2022 05:00	-0.2	12.9	2,033.5	0.1	0.6	1	1	1
01/03/2022 06:00	-0.1	12.3	2,173.3	0.2	0.7	1	1	1
01/03/2022 07:00	-0.1	12.8	2,052.1	0.1	0.6	1	1	1
01/03/2022 08:00	-0.2	13.1	1,971.7	-0.1	0.6	1	1	1
01/03/2022 09:00	-0.4	13.3	1,919.9	-0.1	0.6	1	1	1
01/03/2022 10:00	0.1	13.8	1,680.4	0.2	0.5	1	1	1
01/03/2022 11:00	0.3	13.9	1,408.9	0.4	0.4	1	1	0
01/03/2022 12:00	0.3	13.8	1,723.4	0.4	0.5	1	1	0
01/03/2022 13:00	-0.2	13.4	1,842.7	-0.1	0.6	1	1	1
01/03/2022 14:00	-0.2	13.3	1,847.4	-0.1	0.6	1	1	1
01/03/2022 15:00	0.3	13.8	1,621.1	0.4	0.5	1	1	0
01/03/2022 16:00	-0.4	13.3	1,870.0	-0.1	0.6	1	1	1
01/03/2022 17:00	-0.2	12.6	2,065.2	0.1	0.6	1	1	1
01/03/2022 18:00	-0.2	12.4	2,092.8	0.1	0.6	1	1	1
01/03/2022 19:00	-0.1	12.3	2,124.9	0.2	0.6	1	1	1
01/03/2022 20:00	-0.2	12.6	2,035.6	0.1	0.6	1	1	1
01/03/2022 21:00	-0.2	12.8	2,004.7	0.1	0.6	1	1	1
01/03/2022 22:00	-0.5	13.1	1,934.6	-0.2	0.6	1	1	1
01/03/2022 23:00	-0.2	12.8	1,996.3	0.1	0.6	1	1	1
Average/Sum#:	-0.1	13.2	1,896.7	0.1	0.6	24 #	24 #	20 #
Minimum:	-0.7	12.3	1,408.9	-0.4	0.4	1	1	0
Maximum:	0.3	13.9	2,173.3	0.4	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/04/2022 00:00	-0.2	12.8	1,978.6	0.1	0.6	1	1	1
01/04/2022 01:00	0.4	13.9	1,541.5	0.4	0.5	1	1	0
01/04/2022 02:00	0.1	13.8	1,650.0	0.2	0.5	1	1	1
01/04/2022 03:00	-0.2	13.2	1,893.1	-0.1	0.6	1	1	1
01/04/2022 04:00	-0.2	13.2	1,913.3	-0.1	0.6	1	1	1
01/04/2022 05:00	0.4	13.9	1,637.6	0.4	0.5	1	1	0
01/04/2022 06:00	0.3	13.8	1,750.2	0.4	0.5	1	1	0
01/04/2022 07:00	-0.4	13.1	1,951.4	-0.1	0.6	1	1	1
01/04/2022 08:00	-0.2	12.9	1,980.4	0.1	0.6	1	1	1
01/04/2022 09:00	-0.5	13.2	1,911.3	-0.2	0.6	1	1	1
01/04/2022 10:00	0.1	13.8	1,425.8	0.2	0.4	1	1	1
01/04/2022 11:00	0.3	13.9	1,321.2	0.4	0.4	1	1	0
01/04/2022 12:00	0.3	13.8	1,693.1	0.4	0.5	1	1	0
01/04/2022 13:00	-0.2	13.6	1,796.6	-0.1	0.5	1	1	1
01/04/2022 14:00	-0.5	13.4	1,792.3	-0.2	0.5	1	1	1
01/04/2022 15:00	0.4	13.8	1,560.4	0.4	0.5	1	1	0
01/04/2022 16:00	-0.5	13.0	1,971.7	-0.2	0.6	1	1	1
01/04/2022 17:00	-0.2	12.4	2,092.2	0.1	0.6	1	1	1
01/04/2022 18:00	-0.2	12.3	2,109.5	0.1	0.6	1	1	1
01/04/2022 19:00	-0.2	12.4	2,097.2	0.1	0.6	1	1	1
01/04/2022 20:00	-0.2	12.7	2,042.7	0.1	0.6	1	1	1
01/04/2022 21:00	-0.2	12.8	2,013.5	0.1	0.6	1	1	1
01/04/2022 22:00	-0.4	12.9	1,979.5	-0.1	0.6	1	1	1
01/04/2022 23:00	-0.2	12.9	1,996.3	0.1	0.6	1	1	1
Average/Sum#:	-0.1	13.2	1,837.5	0.1	0.6	24 #	24 #	18 #
Minimum:	-0.5	12.3	1,321.2	-0.2	0.4	1	1	0
Maximum:	0.4	13.9	2,109.5	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	VOC, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT2	Unit CT2	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	VOC, Ppmvdc	VOC, LbPerHr	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/05/2022 00:00	-0.4	13.4	1,794.1	-0.2	0.5	1	1	1
01/05/2022 01:00	0.3	13.9	1,289.5	0.4	0.4	1	1	0
01/05/2022 02:00	0.3	13.9	1,319.7	0.4	0.4	1	1	0
01/05/2022 03:00	0.3	13.8	1,724.1	0.4	0.5	1	1	0
01/05/2022 04:00	-0.5	13.5	1,832.7	-0.2	0.5	1	1	1
01/05/2022 05:00	-0.7	13.2	1,864.2	-0.4	0.6	1	1	1
01/05/2022 06:00	0.1	13.8	1,651.5	0.2	0.5	1	1	1
01/05/2022 07:00	-0.5	13.0	1,984.2	-0.2	0.6	1	1	1
01/05/2022 08:00	-0.5	13.1	1,975.2	-0.2	0.6	1	1	1
01/05/2022 09:00	-0.4	13.0	1,957.0	-0.1	0.6	1	1	1
01/05/2022 10:00	0.4	13.9	1,455.8	0.4	0.4	1	1	0
01/05/2022 11:00	0.4	13.9	1,506.0	0.4	0.5	1	1	0
01/05/2022 12:00	0.4	13.8	1,702.2	0.4	0.5	1	1	0
01/05/2022 13:00	-0.1	13.5	1,819.7	0.1	0.5	1	1	1
01/05/2022 14:00	-0.1	13.4	1,822.9	0.1	0.5	1	1	1
01/05/2022 15:00	0.2	13.9	1,630.7	0.2	0.5	1	1	1
01/05/2022 16:00	-0.2	13.0	1,984.0	0.1	0.6	1	1	1
01/05/2022 17:00	-0.1	12.8	2,031.0	0.1	0.6	1	1	1
01/05/2022 18:00	-0.1	12.6	2,080.5	0.1	0.6	1	1	1
01/05/2022 19:00	-0.1	12.6	2,077.9	0.1	0.6	1	1	1
01/05/2022 20:00	0.1	12.6	2,075.8	0.2	0.6	1	1	1
01/05/2022 21:00	0.1	12.6	2,066.5	0.2	0.6	1	1	1
01/05/2022 22:00	-0.2	13.2	1,927.2	-0.1	0.6	1	1	1
01/05/2022 23:00	-0.1	12.9	1,997.6	0.1	0.6	1	1	1
Average/Sum#:	-0.1	13.3	1,815.4	0.1	0.5	24 #	24 #	18 #
Minimum:	-0.7	12.6	1,289.5	-0.4	0.4	1	1	0
Maximum:	0.4	13.9	2,080.5	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	VOC, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT2	Unit CT2	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	VOC, Ppmvdc	VOC, LbPerHr	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/06/2022 00:00	-0.1	13.4	1,802.4	0.1	0.5	1	1	1
01/06/2022 01:00	0.4	13.9	1,306.9	0.4	0.4	1	1	0
01/06/2022 02:00	0.3	13.9	1,288.7	0.4	0.4	1	1	0
01/06/2022 03:00	0.3	13.8	1,527.6	0.4	0.5	1	1	0
01/06/2022 04:00	-0.4	13.5	1,834.6	-0.2	0.6	1	1	1
01/06/2022 05:00	-0.5	13.3	1,829.1	-0.2	0.5	1	1	1
01/06/2022 06:00	0.1	13.8	1,728.3	0.2	0.5	1	1	1
01/06/2022 07:00	-0.4	13.1	1,975.1	-0.1	0.6	1	1	1
01/06/2022 08:00	-0.2	13.0	2,001.3	0.1	0.6	1	1	1
01/06/2022 09:00	-0.2	13.2	1,917.8	-0.1	0.6	1	1	1
01/06/2022 10:00	0.3	13.9	1,494.9	0.4	0.4	1	1	0
01/06/2022 11:00	0.3	13.9	1,559.2	0.4	0.5	1	1	0
01/06/2022 12:00	0.3	13.9	1,425.8	0.4	0.4	1	1	0
01/06/2022 13:00	0.3	13.9	1,312.0	0.4	0.4	1	1	0
01/06/2022 14:00	0.3	13.8	1,588.2	0.4	0.5	1	1	0
01/06/2022 15:00	0.3	13.9	1,417.2	0.4	0.4	1	1	0
01/06/2022 16:00	0.3	13.8	1,592.9	0.4	0.5	1	1	0
01/06/2022 17:00	0.1	13.8	1,708.7	0.2	0.5	1	1	1
01/06/2022 18:00	-0.5	12.8	1,990.9	-0.2	0.6	1	1	1
01/06/2022 19:00	-0.2	12.6	2,038.6	0.1	0.6	1	1	1
01/06/2022 20:00	-0.4	13.0	1,927.6	-0.1	0.6	1	1	1
01/06/2022 21:00	0.3	13.8	1,642.4	0.4	0.5	1	1	0
01/06/2022 22:00	0.1	13.8	1,740.8	0.2	0.5	1	1	1
01/06/2022 23:00	-0.4	13.0	1,959.5	-0.1	0.6	1	1	1
Average/Sum#:	0.0	13.5	1,692.1	0.2	0.5	24 #	24 #	13 #
Minimum:	-0.5	12.6	1,288.7	-0.2	0.4	1	1	0
Maximum:	0.4	13.9	2,038.6	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	VOC, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT2	Unit CT2	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	VOC, Ppmvdc	VOC, LbPerHr	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/07/2022 00:00	-0.4	13.4	1,799.2	-0.2	0.5	1	1	1
01/07/2022 01:00	0.3	13.9	1,278.9	0.4	0.4	1	1	0
01/07/2022 02:00	0.1	13.8	1,598.4	0.2	0.5	1	1	1
01/07/2022 03:00	-0.7	13.2	1,918.0	-0.4	0.6	1	1	1
01/07/2022 04:00	-0.7	13.1	1,896.8	-0.4	0.6	1	1	1
01/07/2022 05:00	0.3	13.8	1,660.6	0.4	0.5	1	1	0
01/07/2022 06:00	0.1	13.8	1,568.4	0.2	0.5	1	1	1
01/07/2022 07:00	-0.5	13.0	1,954.9	-0.2	0.6	1	1	1
01/07/2022 08:00	-0.7	13.1	1,919.2	-0.4	0.6	1	1	1
01/07/2022 09:00	0.4	13.9	1,558.9	0.4	0.5	1	1	0
01/07/2022 10:00	0.3	13.9	1,518.0	0.4	0.5	1	1	0
01/07/2022 11:00	0.4	13.9	1,535.4	0.4	0.5	1	1	0
01/07/2022 12:00	0.4	13.9	1,525.6	0.4	0.5	1	1	0
01/07/2022 13:00	0.3	13.9	1,495.3	0.4	0.4	1	1	0
01/07/2022 14:00	0.4	13.9	1,467.8	0.4	0.4	1	1	0
01/07/2022 15:00	0.3	13.9	1,512.7	0.4	0.5	1	1	0
01/07/2022 16:00	0.3	13.9	1,515.8	0.4	0.5	1	1	0
01/07/2022 17:00	0.3	13.9	1,601.0	0.4	0.5	1	1	0
01/07/2022 18:00	-0.5	13.4	1,824.9	-0.2	0.5	1	1	1
01/07/2022 19:00	-0.5	13.4	1,803.4	-0.2	0.5	1	1	1
01/07/2022 20:00	0.1	13.8	1,553.0	0.2	0.5	1	1	1
01/07/2022 21:00	-0.8	13.1	1,942.1	-0.5	0.6	1	1	1
01/07/2022 22:00	0.0	14.5	1,190.3	0.0	0.4	1	0	1
01/07/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	13.7	1,636.5	0.1	0.5	23 #	22 #	12 #
Minimum:	-0.8	13.0	1,190.3	-0.5	0.4	0	0	0
Maximum:	0.4	14.5	1,954.9	0.4	0.6	1	1	1
%SI	4.17	4.17	4.17	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/08/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2022 15:00	0.0	17.6	356.7	0.0	0.1	1	0	0
01/08/2022 16:00	0.0	14.9	1,098.8	0.0	0.3	1	0	0
01/08/2022 17:00	0.4	13.9	1,600.9	0.4	0.5	1	1	0
01/08/2022 18:00	0.1	13.8	1,760.8	0.2	0.5	1	1	1
01/08/2022 19:00	-0.5	13.0	1,995.8	-0.2	0.6	1	1	1
01/08/2022 20:00	-0.2	12.8	2,000.7	0.1	0.6	1	1	1
01/08/2022 21:00	0.4	13.9	1,689.8	0.4	0.5	1	1	0
01/08/2022 22:00	0.2	13.8	1,765.5	0.4	0.5	1	1	1
01/08/2022 23:00	-0.4	13.0	1,980.7	-0.1	0.6	1	1	1
Average/Sum#:	0.0	14.1	1,583.3	0.1	0.5	9 #	7 #	5 #
Minimum:	-0.5	12.8	356.7	-0.2	0.1	0	0	0
Maximum:	0.4	17.6	2,000.7	0.4	0.6	1	1	1
%SI	62.50	62.50	62.50	62.50	62.50	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	VOC, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT2	Unit CT2	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	VOC, Ppmvdc	VOC, LbPerHr	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/09/2022 00:00	-0.4	13.2	1,923.2	-0.1	0.6	1	1	1
01/09/2022 01:00	0.4	13.9	1,506.4	0.4	0.5	1	1	0
01/09/2022 02:00	0.1	13.8	1,565.9	0.2	0.5	1	1	1
01/09/2022 03:00	-0.7	13.3	1,921.4	-0.4	0.6	1	1	1
01/09/2022 04:00	-0.7	13.3	1,912.5	-0.4	0.6	1	1	1
01/09/2022 05:00	0.4	13.9	1,631.5	0.4	0.5	1	1	0
01/09/2022 06:00	0.1	13.8	1,645.5	0.2	0.5	1	1	1
01/09/2022 07:00	-0.7	13.1	1,998.0	-0.4	0.6	1	1	1
01/09/2022 08:00	-0.7	13.2	1,938.3	-0.4	0.6	1	1	1
01/09/2022 09:00	0.4	13.9	1,559.8	0.4	0.5	1	1	0
01/09/2022 10:00	0.4	13.9	1,502.4	0.4	0.5	1	1	0
01/09/2022 11:00	0.4	13.9	1,583.6	0.4	0.5	1	1	0
01/09/2022 12:00	0.4	13.9	1,443.6	0.4	0.4	1	1	0
01/09/2022 13:00	0.4	13.9	1,493.7	0.4	0.4	1	1	0
01/09/2022 14:00	0.4	13.9	1,621.8	0.4	0.5	1	1	0
01/09/2022 15:00	0.4	13.9	1,647.8	0.4	0.5	1	1	0
01/09/2022 16:00	0.1	13.9	1,606.7	0.2	0.5	1	1	1
01/09/2022 17:00	-0.5	13.1	1,951.9	-0.2	0.6	1	1	1
01/09/2022 18:00	-0.2	12.8	2,020.7	0.1	0.6	1	1	1
01/09/2022 19:00	-0.5	13.2	1,926.2	-0.2	0.6	1	1	1
01/09/2022 20:00	-0.4	13.0	1,974.9	-0.1	0.6	1	1	1
01/09/2022 21:00	-0.4	13.1	1,956.5	-0.1	0.6	1	1	1
01/09/2022 22:00	-0.2	12.9	2,013.0	0.1	0.6	1	1	1
01/09/2022 23:00	-0.8	13.3	1,919.6	-0.5	0.6	1	1	1
Average/Sum#:	-0.1	13.5	1,761.0	0.1	0.5	24 #	24 #	15 #
Minimum:	-0.8	12.8	1,443.6	-0.5	0.4	1	1	0
Maximum:	0.4	13.9	2,020.7	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/10/2022 00:00	-0.5	13.4	1,829.0	-0.2	0.5	1	1	1
01/10/2022 01:00	0.0	14.4	1,165.6	0.0	0.3	1	0	0
01/10/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/10/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/10/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/10/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/10/2022 06:00	0.0	17.0	441.8	0.0	0.1	1	0	0
01/10/2022 07:00	0.0	14.6	1,237.4	0.0	0.4	1	0	0
01/10/2022 08:00	0.4	13.9	1,639.2	0.4	0.5	1	1	0
01/10/2022 09:00	0.4	13.9	1,570.4	0.4	0.5	1	1	0
01/10/2022 10:00	0.2	13.9	1,618.8	0.2	0.5	1	1	1
01/10/2022 11:00	-0.7	13.1	1,949.8	-0.4	0.6	1	1	1
01/10/2022 12:00	-0.7	13.2	1,901.3	-0.4	0.6	1	1	1
01/10/2022 13:00	0.4	13.9	1,531.1	0.4	0.5	1	1	0
01/10/2022 14:00	0.4	13.9	1,632.3	0.4	0.5	1	1	0
01/10/2022 15:00	-0.4	13.0	1,956.2	-0.1	0.6	1	1	1
01/10/2022 16:00	-0.2	12.7	2,027.1	0.1	0.6	1	1	1
01/10/2022 17:00	-0.1	12.6	2,067.0	0.1	0.6	1	1	1
01/10/2022 18:00	-0.1	12.5	2,090.3	0.1	0.6	1	1	1
01/10/2022 19:00	-0.1	12.5	2,084.1	0.1	0.6	1	1	1
01/10/2022 20:00	-0.1	12.5	2,087.9	0.1	0.6	1	1	1
01/10/2022 21:00	-0.1	12.6	2,074.0	0.1	0.6	1	1	1
01/10/2022 22:00	-0.2	12.9	1,976.4	0.1	0.6	1	1	1
01/10/2022 23:00	-0.4	13.1	1,958.4	-0.1	0.6	1	1	1
Average/Sum#:	-0.1	13.5	1,741.9	0.1	0.5	20 #	17 #	13 #
Minimum:	-0.7	12.5	441.8	-0.4	0.1	0	0	0
Maximum:	0.4	17.0	2,090.3	0.4	0.6	1	1	1
%SI	16.67	16.67	16.67	16.67	16.67	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	VOC, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT2	Unit CT2	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	VOC, Ppmvdc	VOC, LbPerHr	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/11/2022 00:00	-0.5	13.4	1,810.0	-0.2	0.5	1	1	1
01/11/2022 01:00	0.4	14.0	1,288.8	0.4	0.4	1	1	0
01/11/2022 02:00	0.1	13.9	1,559.9	0.2	0.5	1	1	1
01/11/2022 03:00	-0.2	13.3	1,922.6	-0.1	0.6	1	1	1
01/11/2022 04:00	-0.2	13.3	1,910.4	-0.1	0.6	1	1	1
01/11/2022 05:00	0.4	13.9	1,594.2	0.4	0.5	1	1	0
01/11/2022 06:00	0.1	13.9	1,574.4	0.2	0.5	1	1	1
01/11/2022 07:00	-0.5	13.2	1,958.2	-0.2	0.6	1	1	1
01/11/2022 08:00	-0.4	13.4	1,807.6	-0.2	0.5	1	1	1
01/11/2022 09:00	0.4	13.9	1,300.9	0.4	0.4	1	1	0
01/11/2022 10:00	0.4	14.0	1,294.5	0.4	0.4	1	1	0
01/11/2022 11:00	0.4	14.0	1,357.4	0.4	0.4	1	1	0
01/11/2022 12:00	0.4	14.0	1,341.2	0.4	0.4	1	1	0
01/11/2022 13:00	0.4	14.0	1,337.0	0.4	0.4	1	1	0
01/11/2022 14:00	0.4	14.0	1,293.2	0.4	0.4	1	1	0
01/11/2022 15:00	0.4	14.0	1,361.7	0.4	0.4	1	1	0
01/11/2022 16:00	0.4	13.9	1,605.9	0.4	0.5	1	1	0
01/11/2022 17:00	0.1	13.8	1,648.8	0.2	0.5	1	1	1
01/11/2022 18:00	-0.8	13.1	1,947.0	-0.5	0.6	1	1	1
01/11/2022 19:00	-0.7	13.2	1,932.6	-0.4	0.6	1	1	1
01/11/2022 20:00	-0.7	13.3	1,915.0	-0.4	0.6	1	1	1
01/11/2022 21:00	-0.7	13.2	1,929.1	-0.4	0.6	1	1	1
01/11/2022 22:00	-0.5	13.0	1,977.4	-0.2	0.6	1	1	1
01/11/2022 23:00	-0.2	13.5	1,654.0	-0.1	0.5	1	1	1
Average/Sum#:	0.0	13.6	1,638.4	0.1	0.5	24 #	24 #	14 #
Minimum:	-0.8	13.0	1,288.8	-0.5	0.4	1	1	0
Maximum:	0.4	14.0	1,977.4	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/12/2022 00:00	0.0	14.9	904.8	0.0	0.3	1	0	0
01/12/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2022 09:00	0.0	18.1	310.1	0.0	0.1	1	0	0
01/12/2022 10:00	0.0	15.9	755.2	0.0	0.2	1	0	0
01/12/2022 11:00	0.4	13.9	1,378.4	0.4	0.4	1	1	0
01/12/2022 12:00	0.4	13.9	1,517.0	0.4	0.5	1	1	0
01/12/2022 13:00	0.4	13.9	1,569.1	0.4	0.5	1	1	0
01/12/2022 14:00	0.4	13.9	1,548.1	0.4	0.5	1	1	0
01/12/2022 15:00	0.1	13.9	1,616.2	0.2	0.5	1	1	1
01/12/2022 16:00	-0.4	13.0	1,976.7	-0.1	0.6	1	1	1
01/12/2022 17:00	-0.2	12.6	2,041.8	0.1	0.6	1	1	1
01/12/2022 18:00	-0.2	12.8	2,017.2	0.1	0.6	1	1	1
01/12/2022 19:00	-0.2	12.8	1,998.2	0.1	0.6	1	1	1
01/12/2022 20:00	-0.4	13.1	1,925.8	-0.1	0.6	1	1	1
01/12/2022 21:00	0.4	13.9	1,651.5	0.4	0.5	1	1	0
01/12/2022 22:00	0.1	13.8	1,767.8	0.2	0.5	1	1	1
01/12/2022 23:00	-0.7	13.2	1,942.1	-0.4	0.6	1	1	1
Average/Sum#:	0.0	14.0	1,557.5	0.1	0.5	16 #	13 #	8 #
Minimum:	-0.7	12.6	310.1	-0.4	0.1	0	0	0
Maximum:	0.4	18.1	2,041.8	0.4	0.6	1	1	1
%SI	33.33	33.33	33.33	33.33	33.33	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/13/2022 00:00	-0.4	13.4	1,804.4	-0.2	0.5	1	1	1
01/13/2022 01:00	0.3	13.9	1,289.7	0.4	0.4	1	1	0
01/13/2022 02:00	0.1	13.8	1,565.0	0.2	0.5	1	1	1
01/13/2022 03:00	-0.8	13.3	1,933.3	-0.5	0.6	1	1	1
01/13/2022 04:00	-0.8	13.3	1,916.5	-0.5	0.6	1	1	1
01/13/2022 05:00	0.3	13.9	1,664.6	0.4	0.5	1	1	0
01/13/2022 06:00	0.1	13.8	1,600.3	0.2	0.5	1	1	1
01/13/2022 07:00	-0.2	13.0	1,987.4	0.1	0.6	1	1	1
01/13/2022 08:00	-0.2	13.3	1,906.7	-0.1	0.6	1	1	1
01/13/2022 09:00	0.3	13.9	1,630.0	0.4	0.5	1	1	0
01/13/2022 10:00	0.3	13.9	1,378.8	0.4	0.4	1	1	0
01/13/2022 11:00	0.4	13.9	1,611.2	0.4	0.5	1	1	0
01/13/2022 12:00	-0.4	13.5	1,836.1	-0.2	0.6	1	1	1
01/13/2022 13:00	-0.2	12.9	1,964.6	0.1	0.6	1	1	1
01/13/2022 14:00	0.4	13.9	1,535.2	0.4	0.5	1	1	0
01/13/2022 15:00	0.2	13.9	1,549.3	0.2	0.5	1	1	1
01/13/2022 16:00	-0.4	13.0	1,968.7	-0.1	0.6	1	1	1
01/13/2022 17:00	-0.2	12.8	1,999.9	0.1	0.6	1	1	1
01/13/2022 18:00	-0.2	12.7	2,029.3	0.1	0.6	1	1	1
01/13/2022 19:00	-0.5	13.1	1,929.5	-0.2	0.6	1	1	1
01/13/2022 20:00	0.4	13.9	1,577.5	0.4	0.5	1	1	0
01/13/2022 21:00	0.1	13.9	1,617.7	0.2	0.5	1	1	1
01/13/2022 22:00	-0.5	13.0	1,950.6	-0.2	0.6	1	1	1
01/13/2022 23:00	0.0	14.5	1,185.2	0.0	0.4	1	0	1
Average/Sum#:	-0.1	13.5	1,726.3	0.1	0.5	24 #	23 #	17 #
Minimum:	-0.8	12.7	1,185.2	-0.5	0.4	1	0	0
Maximum:	0.4	14.5	2,029.3	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/14/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/14/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/14/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/14/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/14/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/14/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/14/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/14/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/14/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/14/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/14/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/14/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/14/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/14/2022 13:00	0.0	17.7	335.2	0.0	0.1	1	0	0
01/14/2022 14:00	0.0	15.3	971.1	0.0	0.3	1	0	0
01/14/2022 15:00	0.4	13.9	1,506.0	0.4	0.5	1	1	0
01/14/2022 16:00	0.4	14.0	1,407.7	0.4	0.4	1	1	0
01/14/2022 17:00	0.4	13.9	1,568.6	0.4	0.5	1	1	0
01/14/2022 18:00	0.4	13.9	1,596.1	0.4	0.5	1	1	0
01/14/2022 19:00	-0.1	13.4	1,827.7	0.1	0.5	1	1	1
01/14/2022 20:00	-0.1	13.3	1,849.1	0.1	0.6	1	1	1
01/14/2022 21:00	0.1	13.8	1,693.2	0.2	0.5	1	1	1
01/14/2022 22:00	-0.4	13.0	1,986.6	-0.1	0.6	1	1	1
01/14/2022 23:00	0.0	14.4	1,207.3	0.0	0.4	1	0	1
Average/Sum#:	0.1	14.2	1,449.9	0.2	0.4	11 #	8 #	5 #
Minimum:	-0.4	13.0	335.2	-0.1	0.1	0	0	0
Maximum:	0.4	17.7	1,986.6	0.4	0.6	1	1	1
%SI	54.17	54.17	54.17	54.17	54.17	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/15/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/15/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/15/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/15/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/15/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/15/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/15/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/15/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/15/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/15/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/15/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/15/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/15/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/15/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/15/2022 14:00	0.0	17.6	351.2	0.0	0.1	1	0	0
01/15/2022 15:00	0.0	15.1	1,058.7	0.0	0.3	1	0	0
01/15/2022 16:00	0.4	13.9	1,567.4	0.4	0.5	1	1	0
01/15/2022 17:00	0.4	13.8	1,653.4	0.4	0.5	1	1	0
01/15/2022 18:00	-0.2	13.5	1,838.8	-0.1	0.6	1	1	1
01/15/2022 19:00	-0.7	13.1	1,930.0	-0.4	0.6	1	1	1
01/15/2022 20:00	0.1	13.8	1,671.2	0.2	0.5	1	1	1
01/15/2022 21:00	0.1	13.8	1,750.1	0.2	0.5	1	1	1
01/15/2022 22:00	-0.8	13.1	1,950.9	-0.5	0.6	1	1	1
01/15/2022 23:00	0.0	14.1	1,441.0	0.0	0.4	1	0	1
Average/Sum#:	-0.1	14.2	1,521.3	0.0	0.5	10 #	7 #	6 #
Minimum:	-0.8	13.1	351.2	-0.5	0.1	0	0	0
Maximum:	0.4	17.6	1,950.9	0.4	0.6	1	1	1
%SI	58.33	58.33	58.33	58.33	58.33	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/16/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/16/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/16/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/16/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/16/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/16/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/16/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/16/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/16/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/16/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/16/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/16/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/16/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/16/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/16/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/16/2022 15:00	0.0	18.0	289.9	0.0	0.1	1	0	0
01/16/2022 16:00	0.0	16.4	611.9	0.0	0.2	1	0	0
01/16/2022 17:00	0.0	13.9	1,440.9	0.0	0.4	1	0	0
01/16/2022 18:00	0.3	13.8	1,687.8	0.4	0.5	1	1	0
01/16/2022 19:00	-0.5	13.3	1,876.4	-0.2	0.6	1	1	1
01/16/2022 20:00	-0.4	13.0	1,970.4	-0.1	0.6	1	1	1
01/16/2022 21:00	0.4	13.9	1,676.1	0.4	0.5	1	1	0
01/16/2022 22:00	0.4	14.0	1,383.3	0.4	0.4	1	1	0
01/16/2022 23:00	0.4	13.9	1,596.5	0.4	0.5	1	1	0
Average/Sum#:	0.1	14.5	1,392.6	0.1	0.4	9 #	6 #	2 #
Minimum:	-0.5	13.0	289.9	-0.2	0.1	0	0	0
Maximum:	0.4	18.0	1,970.4	0.4	0.6	1	1	1
%SI	62.50	62.50	62.50	62.50	62.50	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	VOC, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT2	Unit CT2	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	VOC, Ppmvdc	VOC, LbPerHr	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/17/2022 00:00	-0.4	13.5	1,798.6	-0.2	0.5	1	1	1
01/17/2022 01:00	-0.5	13.4	1,826.8	-0.2	0.5	1	1	1
01/17/2022 02:00	0.3	13.9	1,396.3	0.4	0.4	1	1	0
01/17/2022 03:00	0.3	13.8	1,722.3	0.4	0.5	1	1	0
01/17/2022 04:00	-0.2	13.5	1,820.8	-0.1	0.5	1	1	1
01/17/2022 05:00	-0.4	13.4	1,795.2	-0.2	0.5	1	1	1
01/17/2022 06:00	0.1	13.8	1,672.6	0.2	0.5	1	1	1
01/17/2022 07:00	-0.4	12.9	1,984.6	-0.1	0.6	1	1	1
01/17/2022 08:00	-0.2	12.9	2,003.7	0.1	0.6	1	1	1
01/17/2022 09:00	-0.5	13.1	1,935.0	-0.2	0.6	1	1	1
01/17/2022 10:00	0.4	13.9	1,561.7	0.4	0.5	1	1	0
01/17/2022 11:00	0.4	13.9	1,563.0	0.4	0.5	1	1	0
01/17/2022 12:00	0.1	13.8	1,633.9	0.2	0.5	1	1	1
01/17/2022 13:00	-0.7	13.1	1,920.4	-0.4	0.6	1	1	1
01/17/2022 14:00	-0.5	13.1	1,893.2	-0.2	0.6	1	1	1
01/17/2022 15:00	0.4	13.9	1,588.4	0.4	0.5	1	1	0
01/17/2022 16:00	0.2	13.9	1,574.5	0.2	0.5	1	1	1
01/17/2022 17:00	-0.5	13.1	1,946.0	-0.2	0.6	1	1	1
01/17/2022 18:00	-0.2	12.9	1,965.1	0.1	0.6	1	1	1
01/17/2022 19:00	-0.2	12.8	2,000.1	0.1	0.6	1	1	1
01/17/2022 20:00	-0.4	13.1	1,908.0	-0.1	0.6	1	1	1
01/17/2022 21:00	0.4	13.9	1,627.2	0.4	0.5	1	1	0
01/17/2022 22:00	0.4	14.0	1,395.3	0.4	0.4	1	1	0
01/17/2022 23:00	0.3	13.9	1,599.9	0.4	0.5	1	1	0
Average/Sum#:	-0.1	13.5	1,755.5	0.1	0.5	24 #	24 #	16 #
Minimum:	-0.7	12.8	1,395.3	-0.4	0.4	1	1	0
Maximum:	0.4	14.0	2,003.7	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/18/2022 00:00	0.1	13.8	1,751.0	0.2	0.5	1	1	1
01/18/2022 01:00	-0.5	13.3	1,820.2	-0.2	0.5	1	1	1
01/18/2022 02:00	0.3	13.9	1,602.3	0.4	0.5	1	1	0
01/18/2022 03:00	-0.2	13.3	1,913.4	-0.1	0.6	1	1	1
01/18/2022 04:00	-0.2	13.3	1,919.1	-0.1	0.6	1	1	1
01/18/2022 05:00	0.1	13.8	1,550.3	0.2	0.5	1	1	1
01/18/2022 06:00	0.1	13.8	1,574.5	0.2	0.5	1	1	1
01/18/2022 07:00	-0.2	13.3	1,937.6	-0.1	0.6	1	1	1
01/18/2022 08:00	-0.1	13.1	1,978.0	0.1	0.6	1	1	1
01/18/2022 09:00	-0.2	13.3	1,912.7	-0.1	0.6	1	1	1
01/18/2022 10:00	0.4	13.9	1,424.7	0.4	0.4	1	1	0
01/18/2022 11:00	0.6	0.0	1,388.0	0.6	0.4	1	1	0
01/18/2022 12:00	0.6	0.0	1,288.8	0.6	0.4	1	1	0
01/18/2022 13:00	0.6	0.0	1,297.7	0.6	0.4	1	1	0
01/18/2022 14:00	0.4	14.0	1,338.1	0.4	0.4	1	1	0
01/18/2022 15:00	0.4	13.9	1,510.9	0.4	0.5	1	1	0
01/18/2022 16:00	0.1	13.9	1,610.3	0.2	0.5	1	1	1
01/18/2022 17:00	-0.4	12.9	1,984.1	-0.1	0.6	1	1	1
01/18/2022 18:00	-0.2	12.8	1,990.1	0.1	0.6	1	1	1
01/18/2022 19:00	-0.2	12.7	2,017.1	0.1	0.6	1	1	1
01/18/2022 20:00	-0.4	13.2	1,913.8	-0.1	0.6	1	1	1
01/18/2022 21:00	0.2	13.8	1,571.8	0.4	0.5	1	1	1
01/18/2022 22:00	0.1	13.9	1,574.3	0.2	0.5	1	1	1
01/18/2022 23:00	-0.7	13.1	1,948.2	-0.4	0.6	1	1	1
Average/Sum#:	-0.1	13.5	1,700.7	0.1	0.5	24 #	24 #	17 #
Minimum:	-0.7	12.7	1,288.8	-0.4	0.4	1	1	0
Maximum:	0.4	14.0	2,017.1	0.4	0.6	1	1	1
%SI	12.50	12.50	0.00	12.50	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	VOC, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT2	Unit CT2	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	VOC, Ppmvdc	VOC, LbPerHr	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/19/2022 00:00	-0.4	13.4	1,808.1	-0.2	0.5	1	1	1
01/19/2022 01:00	0.4	14.0	1,286.5	0.4	0.4	1	1	0
01/19/2022 02:00	0.1	13.9	1,566.8	0.2	0.5	1	1	1
01/19/2022 03:00	-0.7	13.3	1,932.6	-0.4	0.6	1	1	1
01/19/2022 04:00	-0.5	13.3	1,905.0	-0.2	0.6	1	1	1
01/19/2022 05:00	0.3	13.9	1,556.8	0.4	0.5	1	1	0
01/19/2022 06:00	-0.1	13.8	1,576.0	0.1	0.5	1	1	1
01/19/2022 07:00	-0.7	13.2	1,940.1	-0.4	0.6	1	1	1
01/19/2022 08:00	0.7	0.0	1,918.7	0.7	0.6	1	1	1
01/19/2022 09:00	0.2	13.9	1,488.7	0.3	0.4	1	1	0
01/19/2022 10:00	0.6	0.0	1,339.8	0.6	0.4	1	1	0
01/19/2022 11:00	0.4	14.0	1,403.5	0.4	0.4	1	1	0
01/19/2022 12:00	0.2	14.0	1,307.0	0.3	0.4	1	1	0
01/19/2022 13:00	0.3	14.0	1,359.5	0.4	0.4	1	1	0
01/19/2022 14:00	0.4	14.0	1,335.7	0.4	0.4	1	1	0
01/19/2022 15:00	0.7	0.0	1,552.9	0.7	0.5	1	1	1
01/19/2022 16:00	-0.1	12.8	2,008.1	0.1	0.6	1	1	1
01/19/2022 17:00	0.1	12.7	2,030.9	0.2	0.6	1	1	1
01/19/2022 18:00	0.1	12.8	2,012.3	0.2	0.6	1	1	1
01/19/2022 19:00	-0.1	12.6	2,027.9	0.1	0.6	1	1	1
01/19/2022 20:00	-0.1	12.8	1,967.8	0.1	0.6	1	1	1
01/19/2022 21:00	0.4	13.9	1,672.9	0.4	0.5	1	1	0
01/19/2022 22:00	0.2	13.8	1,764.6	0.4	0.5	1	1	1
01/19/2022 23:00	-0.1	13.1	1,952.2	0.1	0.6	1	1	1
Average/Sum#:	0.0	13.5	1,696.4	0.2	0.5	24 #	24 #	15 #
Minimum:	-0.7	12.6	1,286.5	-0.4	0.4	1	1	0
Maximum:	0.4	14.0	2,030.9	0.4	0.6	1	1	1
%SI	12.50	12.50	0.00	12.50	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/20/2022 00:00	0.1	13.2	1,821.6	0.2	0.5	1	1	1
01/20/2022 01:00	0.4	14.0	1,290.4	0.4	0.4	1	1	0
01/20/2022 02:00	0.4	14.0	1,299.6	0.4	0.4	1	1	0
01/20/2022 03:00	0.4	13.9	1,710.7	0.4	0.5	1	1	0
01/20/2022 04:00	-0.1	13.5	1,824.8	0.1	0.5	1	1	1
01/20/2022 05:00	-0.1	13.4	1,830.3	0.1	0.5	1	1	1
01/20/2022 06:00	0.1	13.8	1,691.9	0.2	0.5	1	1	1
01/20/2022 07:00	-0.2	13.2	1,947.8	-0.1	0.6	1	1	1
01/20/2022 08:00	0.1	13.6	1,669.1	0.2	0.5	1	1	1
01/20/2022 09:00	0.0	14.8	935.8	0.0	0.3	1	0	0
01/20/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/20/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/20/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/20/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/20/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/20/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/20/2022 16:00	0.0	17.9	340.4	0.0	0.1	1	0	0
01/20/2022 17:00	0.0	14.8	1,120.8	0.0	0.3	1	0	0
01/20/2022 18:00	0.4	13.9	1,598.9	0.4	0.5	1	1	0
01/20/2022 19:00	0.1	13.8	1,696.8	0.2	0.5	1	1	1
01/20/2022 20:00	-0.4	12.9	1,975.1	-0.1	0.6	1	1	1
01/20/2022 21:00	-0.4	13.0	1,975.1	-0.1	0.6	1	1	1
01/20/2022 22:00	-0.2	12.8	2,006.6	0.1	0.6	1	1	1
01/20/2022 23:00	0.0	14.3	1,229.5	0.0	0.4	1	0	1
Average/Sum#:	0.0	13.9	1,553.6	0.1	0.5	18 #	14 #	11 #
Minimum:	-0.4	12.8	340.4	-0.1	0.1	0	0	0
Maximum:	0.4	17.9	2,006.6	0.4	0.6	1	1	1
%SI	25.00	25.00	25.00	25.00	25.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/21/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/21/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/21/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/21/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/21/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/21/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/21/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/21/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/21/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/21/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/21/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/21/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/21/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/21/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/21/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/21/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/21/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/21/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/21/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/21/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/21/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/21/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/21/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/21/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/22/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/22/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/22/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/22/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/22/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/22/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/22/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/22/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/22/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/22/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/22/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/22/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/22/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/22/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/22/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/22/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/22/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/22/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/22/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/22/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/22/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/22/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/22/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/22/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/23/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/23/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/23/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/23/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/23/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/23/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/23/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/23/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/23/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/23/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/23/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/23/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/23/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/23/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/23/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/23/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/23/2022 16:00	0.0	17.9	291.0	0.0	0.1	1	0	0
01/23/2022 17:00	0.0	15.8	749.9	0.0	0.2	1	0	0
01/23/2022 18:00	0.2	13.8	1,712.2	0.4	0.5	1	1	1
01/23/2022 19:00	-0.4	13.1	1,954.9	-0.1	0.6	1	1	1
01/23/2022 20:00	-0.2	12.7	2,019.1	0.1	0.6	1	1	1
01/23/2022 21:00	-0.2	13.0	1,992.3	0.1	0.6	1	1	1
01/23/2022 22:00	-0.5	13.1	1,958.4	-0.2	0.6	1	1	1
01/23/2022 23:00	0.0	14.5	1,191.0	0.0	0.4	1	0	1
Average/Sum#:	-0.1	14.2	1,483.6	0.0	0.5	8 #	5 #	6 #
Minimum:	-0.5	12.7	291.0	-0.2	0.1	0	0	0
Maximum:	0.2	17.9	2,019.1	0.4	0.6	1	1	1
%SI	66.67	66.67	66.67	66.67	66.67	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/24/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/24/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/24/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/24/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/24/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/24/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/24/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/24/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/24/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/24/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/24/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/24/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/24/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/24/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/24/2022 14:00	0.0	17.6	354.3	0.0	0.1	1	0	0
01/24/2022 15:00	0.0	14.8	1,083.8	0.0	0.3	1	0	0
01/24/2022 16:00	0.4	13.9	1,649.1	0.4	0.5	1	1	0
01/24/2022 17:00	0.1	13.8	1,635.3	0.2	0.5	1	1	1
01/24/2022 18:00	-0.4	13.1	1,941.1	-0.1	0.6	1	1	1
01/24/2022 19:00	-0.2	12.8	2,005.5	0.1	0.6	1	1	1
01/24/2022 20:00	-0.2	13.1	1,917.9	-0.1	0.6	1	1	1
01/24/2022 21:00	0.4	13.9	1,593.6	0.4	0.5	1	1	0
01/24/2022 22:00	0.1	13.8	1,711.8	0.2	0.5	1	1	1
01/24/2022 23:00	-0.5	13.1	1,948.0	-0.2	0.6	1	1	1
Average/Sum#:	0.0	14.0	1,584.0	0.1	0.5	10 #	8 #	6 #
Minimum:	-0.5	12.8	354.3	-0.2	0.1	0	0	0
Maximum:	0.4	17.6	2,005.5	0.4	0.6	1	1	1
%SI	58.33	58.33	58.33	58.33	58.33	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	VOC, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT2	Unit CT2	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	VOC, Ppmvdc	VOC, LbPerHr	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/25/2022 00:00	-0.5	13.3	1,896.4	-0.2	0.6	1	1	1
01/25/2022 01:00	0.3	13.9	1,535.3	0.4	0.5	1	1	0
01/25/2022 02:00	0.1	13.8	1,642.7	0.2	0.5	1	1	1
01/25/2022 03:00	-0.2	13.3	1,928.8	-0.1	0.6	1	1	1
01/25/2022 04:00	-0.2	13.3	1,910.4	-0.1	0.6	1	1	1
01/25/2022 05:00	0.3	13.9	1,644.5	0.4	0.5	1	1	0
01/25/2022 06:00	0.1	13.8	1,745.0	0.2	0.5	1	1	1
01/25/2022 07:00	-0.4	13.0	1,978.0	-0.1	0.6	1	1	1
01/25/2022 08:00	0.0	13.8	1,481.9	0.0	0.4	1	0	1
01/25/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2022 11:00	0.0	18.7	211.4	0.0	0.1	1	0	0
01/25/2022 12:00	0.0	16.0	764.8	0.0	0.2	1	0	0
01/25/2022 13:00	0.4	14.0	1,370.6	0.4	0.4	1	1	0
01/25/2022 14:00	0.4	14.0	1,355.8	0.4	0.4	1	1	0
01/25/2022 15:00	0.4	13.8	1,715.9	0.4	0.5	1	1	0
01/25/2022 16:00	0.4	14.0	1,559.4	0.4	0.5	1	1	0
01/25/2022 17:00	0.4	14.0	1,635.7	0.4	0.5	1	1	0
01/25/2022 18:00	0.4	13.9	1,706.5	0.4	0.5	1	1	0
01/25/2022 19:00	-0.4	13.3	1,884.4	-0.1	0.6	1	1	1
01/25/2022 20:00	-0.4	13.2	1,900.7	-0.1	0.6	1	1	1
01/25/2022 21:00	0.4	14.0	1,515.9	0.4	0.5	1	1	0
01/25/2022 22:00	0.1	13.8	1,688.2	0.2	0.5	1	1	1
01/25/2022 23:00	-0.1	13.3	1,919.9	0.1	0.6	1	1	1
Average/Sum#:	0.1	14.0	1,590.6	0.2	0.5	22 #	19 #	11 #
Minimum:	-0.5	13.0	211.4	-0.2	0.1	0	0	0
Maximum:	0.4	18.7	1,978.0	0.4	0.6	1	1	1
%SI	8.33	8.33	8.33	8.33	8.33	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	VOC, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT2	Unit CT2	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	VOC, Ppmvdc	VOC, LbPerHr	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/26/2022 00:00	-0.1	13.2	1,924.8	0.1	0.6	1	1	1
01/26/2022 01:00	0.4	13.9	1,679.3	0.4	0.5	1	1	0
01/26/2022 02:00	0.1	13.9	1,681.1	0.2	0.5	1	1	1
01/26/2022 03:00	-0.2	13.3	1,949.6	-0.1	0.6	1	1	1
01/26/2022 04:00	-0.1	13.3	1,938.2	0.1	0.6	1	1	1
01/26/2022 05:00	0.4	13.9	1,570.0	0.4	0.5	1	1	0
01/26/2022 06:00	0.1	13.8	1,780.7	0.2	0.5	1	1	1
01/26/2022 07:00	-0.1	13.2	1,956.3	0.1	0.6	1	1	1
01/26/2022 08:00	0.0	14.1	1,440.7	0.0	0.4	1	0	1
01/26/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2022 11:00	0.0	18.7	222.7	0.0	0.1	1	0	0
01/26/2022 12:00	0.0	15.9	790.0	0.0	0.2	1	0	0
01/26/2022 13:00	0.4	14.0	1,353.7	0.4	0.4	1	1	0
01/26/2022 14:00	0.4	14.0	1,346.1	0.4	0.4	1	1	0
01/26/2022 15:00	0.4	13.9	1,686.0	0.4	0.5	1	1	0
01/26/2022 16:00	0.4	14.0	1,556.1	0.4	0.5	1	1	0
01/26/2022 17:00	0.4	13.9	1,695.5	0.4	0.5	1	1	0
01/26/2022 18:00	0.3	13.8	1,778.2	0.4	0.5	1	1	0
01/26/2022 19:00	-0.2	13.3	1,877.1	-0.1	0.6	1	1	1
01/26/2022 20:00	-0.2	12.9	1,981.6	0.1	0.6	1	1	1
01/26/2022 21:00	0.4	13.9	1,648.9	0.4	0.5	1	1	0
01/26/2022 22:00	0.4	13.8	1,768.1	0.4	0.5	1	1	0
01/26/2022 23:00	-0.4	13.1	1,971.1	-0.1	0.6	1	1	1
Average/Sum#:	0.1	14.0	1,618.0	0.2	0.5	22 #	19 #	10 #
Minimum:	-0.4	12.9	222.7	-0.1	0.1	0	0	0
Maximum:	0.4	18.7	1,981.6	0.4	0.6	1	1	1
%SI	8.33	8.33	8.33	8.33	8.33	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	VOC, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT2	Unit CT2	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	VOC, Ppmvdc	VOC, LbPerHr	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/27/2022 00:00	-0.4	13.2	1,935.0	-0.1	0.6	1	1	1
01/27/2022 01:00	0.1	13.9	1,502.8	0.2	0.5	1	1	1
01/27/2022 02:00	0.3	13.9	1,675.8	0.4	0.5	1	1	0
01/27/2022 03:00	-0.2	13.3	1,934.7	-0.1	0.6	1	1	1
01/27/2022 04:00	-0.1	13.3	1,917.5	0.1	0.6	1	1	1
01/27/2022 05:00	0.4	13.9	1,565.4	0.4	0.5	1	1	0
01/27/2022 06:00	-0.2	13.3	1,834.3	-0.1	0.6	1	1	1
01/27/2022 07:00	-0.2	13.0	1,979.5	0.1	0.6	1	1	1
01/27/2022 08:00	-0.4	13.2	1,941.1	-0.1	0.6	1	1	1
01/27/2022 09:00	-0.1	13.6	1,658.5	0.1	0.5	1	1	1
01/27/2022 10:00	0.4	14.0	1,360.0	0.4	0.4	1	1	0
01/27/2022 11:00	0.4	14.0	1,349.3	0.4	0.4	1	1	0
01/27/2022 12:00	0.4	14.0	1,352.3	0.4	0.4	1	1	0
01/27/2022 13:00	0.4	14.0	1,353.7	0.4	0.4	1	1	0
01/27/2022 14:00	0.4	14.0	1,356.2	0.4	0.4	1	1	0
01/27/2022 15:00	0.4	13.9	1,684.2	0.4	0.5	1	1	0
01/27/2022 16:00	0.4	13.9	1,560.7	0.4	0.5	1	1	0
01/27/2022 17:00	0.4	14.0	1,514.3	0.4	0.5	1	1	0
01/27/2022 18:00	0.1	13.7	1,783.4	0.2	0.5	1	1	1
01/27/2022 19:00	-0.5	13.0	1,985.3	-0.2	0.6	1	1	1
01/27/2022 20:00	-0.4	13.0	1,964.1	-0.1	0.6	1	1	1
01/27/2022 21:00	0.4	13.9	1,672.3	0.4	0.5	1	1	0
01/27/2022 22:00	0.4	14.0	1,466.1	0.4	0.4	1	1	0
01/27/2022 23:00	-0.2	13.4	1,881.2	-0.1	0.6	1	1	1
Average/Sum#:	0.1	13.6	1,676.2	0.2	0.5	24 #	24 #	12 #
Minimum:	-0.5	13.0	1,349.3	-0.2	0.4	1	1	0
Maximum:	0.4	14.0	1,985.3	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	VOC, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT2	Unit CT2	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	VOC, Ppmvdc	VOC, LbPerHr	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/28/2022 00:00	-0.2	12.9	2,011.2	0.1	0.6	1	1	1
01/28/2022 01:00	-0.2	12.9	1,997.3	0.1	0.6	1	1	1
01/28/2022 02:00	0.2	13.9	1,487.4	0.2	0.4	1	1	1
01/28/2022 03:00	0.3	13.9	1,500.7	0.4	0.5	1	1	0
01/28/2022 04:00	0.1	13.9	1,736.7	0.2	0.5	1	1	1
01/28/2022 05:00	-0.1	13.2	1,964.9	0.1	0.6	1	1	1
01/28/2022 06:00	-0.1	12.8	2,069.9	0.1	0.6	1	1	1
01/28/2022 07:00	-0.1	12.8	2,057.3	0.1	0.6	1	1	1
01/28/2022 08:00	-0.1	13.2	1,941.8	0.1	0.6	1	1	1
01/28/2022 09:00	0.4	14.0	1,515.3	0.4	0.5	1	1	0
01/28/2022 10:00	0.4	14.0	1,408.8	0.4	0.4	1	1	0
01/28/2022 11:00	0.4	14.0	1,479.2	0.4	0.4	1	1	0
01/28/2022 12:00	0.4	14.0	1,438.2	0.4	0.4	1	1	0
01/28/2022 13:00	0.4	14.0	1,418.6	0.4	0.4	1	1	0
01/28/2022 14:00	0.4	14.0	1,613.2	0.4	0.5	1	1	0
01/28/2022 15:00	0.4	14.0	1,539.9	0.4	0.5	1	1	0
01/28/2022 16:00	0.2	13.9	1,587.8	0.2	0.5	1	1	1
01/28/2022 17:00	-0.4	13.3	1,904.9	-0.1	0.6	1	1	1
01/28/2022 18:00	-0.4	12.8	2,019.0	-0.1	0.6	1	1	1
01/28/2022 19:00	-0.2	12.5	2,087.9	0.1	0.6	1	1	1
01/28/2022 20:00	-0.1	12.7	2,017.3	0.1	0.6	1	1	1
01/28/2022 21:00	0.4	14.0	1,522.1	0.4	0.5	1	1	0
01/28/2022 22:00	0.1	13.8	1,784.8	0.2	0.5	1	1	1
01/28/2022 23:00	-0.4	13.1	1,946.1	-0.1	0.6	1	1	1
Average/Sum#:	0.1	13.5	1,752.1	0.2	0.5	24 #	24 #	15 #
Minimum:	-0.4	12.5	1,408.8	-0.1	0.4	1	1	0
Maximum:	0.4	14.0	2,087.9	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	VOC, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT2	Unit CT2	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	VOC, Ppmvdc	VOC, LbPerHr	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/29/2022 00:00	-0.5	13.3	1,897.9	-0.2	0.6	1	1	1
01/29/2022 01:00	0.4	13.9	1,551.0	0.4	0.5	1	1	0
01/29/2022 02:00	0.1	13.9	1,563.3	0.2	0.5	1	1	1
01/29/2022 03:00	-0.5	13.3	1,918.2	-0.2	0.6	1	1	1
01/29/2022 04:00	-0.5	13.3	1,895.6	-0.2	0.6	1	1	1
01/29/2022 05:00	0.4	13.9	1,586.3	0.4	0.5	1	1	0
01/29/2022 06:00	0.1	13.8	1,604.1	0.2	0.5	1	1	1
01/29/2022 07:00	-0.5	13.2	1,964.3	-0.2	0.6	1	1	1
01/29/2022 08:00	-0.4	13.0	2,008.7	-0.1	0.6	1	1	1
01/29/2022 09:00	-0.5	13.3	1,904.4	-0.2	0.6	1	1	1
01/29/2022 10:00	0.4	14.0	1,395.6	0.4	0.4	1	1	0
01/29/2022 11:00	0.4	13.9	1,514.2	0.4	0.5	1	1	0
01/29/2022 12:00	0.4	14.0	1,364.2	0.4	0.4	1	1	0
01/29/2022 13:00	0.4	14.0	1,384.3	0.4	0.4	1	1	0
01/29/2022 14:00	0.4	14.0	1,591.9	0.4	0.5	1	1	0
01/29/2022 15:00	0.4	14.0	1,367.5	0.4	0.4	1	1	0
01/29/2022 16:00	0.4	14.0	1,572.6	0.4	0.5	1	1	0
01/29/2022 17:00	0.4	13.9	1,603.5	0.4	0.5	1	1	0
01/29/2022 18:00	-0.2	13.5	1,786.3	-0.1	0.5	1	1	1
01/29/2022 19:00	-0.2	13.2	1,859.9	-0.1	0.6	1	1	1
01/29/2022 20:00	0.1	13.8	1,767.4	0.2	0.5	1	1	1
01/29/2022 21:00	-0.1	13.0	1,980.7	0.1	0.6	1	1	1
01/29/2022 22:00	-0.1	12.7	2,052.7	0.1	0.6	1	1	1
01/29/2022 23:00	-0.1	13.4	1,816.1	0.1	0.5	1	1	1
Average/Sum#:	0.0	13.6	1,706.3	0.2	0.5	24 #	24 #	14 #
Minimum:	-0.5	12.7	1,364.2	-0.2	0.4	1	1	0
Maximum:	0.4	14.0	2,052.7	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/30/2022 00:00	0.4	13.9	1,572.5	0.4	0.5	1	1	0
01/30/2022 01:00	0.3	14.0	1,373.3	0.4	0.4	1	1	0
01/30/2022 02:00	0.3	13.9	1,716.3	0.4	0.5	1	1	0
01/30/2022 03:00	-0.1	13.6	1,837.1	0.1	0.6	1	1	1
01/30/2022 04:00	-0.1	13.5	1,822.2	0.1	0.5	1	1	1
01/30/2022 05:00	0.1	13.9	1,589.8	0.2	0.5	1	1	1
01/30/2022 06:00	-0.4	13.0	1,970.9	-0.1	0.6	1	1	1
01/30/2022 07:00	0.0	13.8	1,493.2	0.0	0.4	1	0	1
01/30/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/30/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/30/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/30/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/30/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/30/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/30/2022 14:00	0.0	18.6	223.8	0.0	0.1	1	0	0
01/30/2022 15:00	0.0	15.8	790.6	0.0	0.2	1	0	0
01/30/2022 16:00	0.4	13.9	1,518.4	0.4	0.5	1	1	0
01/30/2022 17:00	-0.7	13.2	1,915.9	-0.4	0.6	1	1	1
01/30/2022 18:00	-0.5	13.2	1,908.4	-0.2	0.6	1	1	1
01/30/2022 19:00	-0.5	13.2	1,905.0	-0.2	0.6	1	1	1
01/30/2022 20:00	-0.4	12.7	2,027.8	-0.1	0.6	1	1	1
01/30/2022 21:00	-0.5	13.3	1,878.4	-0.2	0.6	1	1	1
01/30/2022 22:00	0.3	14.0	1,379.9	0.4	0.4	1	1	0
01/30/2022 23:00	0.3	14.0	1,355.9	0.4	0.4	1	1	0
Average/Sum#:	-0.1	14.0	1,571.1	0.1	0.5	18 #	15 #	10 #
Minimum:	-0.7	12.7	223.8	-0.4	0.1	0	0	0
Maximum:	0.4	18.6	2,027.8	0.4	0.6	1	1	1
%SI	25.00	25.00	25.00	25.00	25.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/31/2022 00:00	0.3	13.9	1,349.4	0.4	0.4	1	1	0
01/31/2022 01:00	0.3	13.9	1,347.3	0.4	0.4	1	1	0
01/31/2022 02:00	0.3	13.9	1,564.4	0.4	0.5	1	1	0
01/31/2022 03:00	0.3	13.9	1,535.5	0.4	0.5	1	1	0
01/31/2022 04:00	0.3	13.9	1,454.8	0.4	0.4	1	1	0
01/31/2022 05:00	0.1	13.9	1,569.4	0.2	0.5	1	1	1
01/31/2022 06:00	-0.5	13.0	1,961.3	-0.2	0.6	1	1	1
01/31/2022 07:00	-0.4	12.9	2,010.6	-0.1	0.6	1	1	1
01/31/2022 08:00	-0.5	13.3	1,924.6	-0.2	0.6	1	1	1
01/31/2022 09:00	0.1	13.9	1,575.0	0.2	0.5	1	1	1
01/31/2022 10:00	0.3	13.9	1,458.7	0.4	0.4	1	1	0
01/31/2022 11:00	0.4	13.9	1,531.3	0.4	0.5	1	1	0
01/31/2022 12:00	0.4	13.9	1,569.9	0.4	0.5	1	1	0
01/31/2022 13:00	0.4	14.0	1,417.0	0.4	0.4	1	1	0
01/31/2022 14:00	0.4	14.0	1,529.0	0.4	0.5	1	1	0
01/31/2022 15:00	0.1	13.9	1,626.5	0.2	0.5	1	1	1
01/31/2022 16:00	-0.4	13.0	1,959.3	-0.1	0.6	1	1	1
01/31/2022 17:00	-0.2	12.6	2,053.2	0.1	0.6	1	1	1
01/31/2022 18:00	-0.2	12.6	2,054.9	0.1	0.6	1	1	1
01/31/2022 19:00	-0.4	13.2	1,902.2	-0.1	0.6	1	1	1
01/31/2022 20:00	0.4	14.0	1,585.7	0.4	0.5	1	1	0
01/31/2022 21:00	0.1	13.9	1,655.2	0.2	0.5	1	1	1
01/31/2022 22:00	-0.7	13.1	1,958.9	-0.4	0.6	1	1	1
01/31/2022 23:00	0.0	14.5	1,196.9	0.0	0.4	1	0	1
Average/Sum#:	0.0	13.6	1,658.0	0.2	0.5	24 #	23 #	13 #
Minimum:	-0.7	12.6	1,196.9	-0.4	0.4	1	0	0
Maximum:	0.4	14.5	2,054.9	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/01/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2022 03:00	0.0	17.3	446.9	0.0	0.1	1	0	0
02/01/2022 04:00	0.0	14.3	1,264.2	0.0	0.4	1	0	0
02/01/2022 05:00	0.4	14.0	1,317.4	0.4	0.4	1	1	0
02/01/2022 06:00	0.4	14.0	1,286.6	0.4	0.4	1	1	0
02/01/2022 07:00	0.1	13.9	1,640.7	0.2	0.5	1	1	1
02/01/2022 08:00	-0.1	11.9	2,272.8	0.2	0.7	1	1	1
02/01/2022 09:00	0.1	11.9	2,265.9	0.2	0.7	1	1	1
02/01/2022 10:00	0.1	13.3	1,829.9	0.2	0.5	1	1	1
02/01/2022 11:00	0.4	14.0	1,540.4	0.4	0.5	1	1	0
02/01/2022 12:00	0.4	14.0	1,288.3	0.4	0.4	1	1	0
02/01/2022 13:00	0.4	14.0	1,288.9	0.4	0.4	1	1	0
02/01/2022 14:00	0.4	14.0	1,289.1	0.4	0.4	1	1	0
02/01/2022 15:00	0.4	14.0	1,311.7	0.4	0.4	1	1	0
02/01/2022 16:00	0.4	13.9	1,527.3	0.4	0.5	1	1	0
02/01/2022 17:00	0.3	13.9	1,781.3	0.4	0.5	1	1	0
02/01/2022 18:00	-0.4	13.3	1,896.4	-0.1	0.6	1	1	1
02/01/2022 19:00	-0.2	13.0	1,993.5	0.1	0.6	1	1	1
02/01/2022 20:00	-0.4	13.1	1,949.2	-0.1	0.6	1	1	1
02/01/2022 21:00	0.4	13.9	1,582.9	0.4	0.5	1	1	0
02/01/2022 22:00	0.1	13.8	1,760.5	0.2	0.5	1	1	1
02/01/2022 23:00	-0.1	13.1	1,987.0	0.1	0.6	1	1	1
Average/Sum#:	0.1	13.7	1,596.2	0.2	0.5	21 #	19 #	9 #
Minimum:	-0.4	11.9	446.9	-0.1	0.1	0	0	0
Maximum:	0.4	17.3	2,272.8	0.4	0.7	1	1	1
%SI	12.50	12.50	12.50	12.50	12.50	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/02/2022 00:00	0.1	12.6	2,111.6	0.2	0.6	1	1	1
02/02/2022 01:00	0.1	13.8	1,713.4	0.2	0.5	1	1	1
02/02/2022 02:00	0.2	13.9	1,573.4	0.2	0.5	1	1	1
02/02/2022 03:00	-0.2	13.2	1,966.6	-0.1	0.6	1	1	1
02/02/2022 04:00	-0.2	13.3	1,943.0	-0.1	0.6	1	1	1
02/02/2022 05:00	-0.2	13.1	1,992.0	-0.1	0.6	1	1	1
02/02/2022 06:00	-0.1	12.8	2,054.2	0.1	0.6	1	1	1
02/02/2022 07:00	-0.1	13.0	2,021.5	0.1	0.6	1	1	1
02/02/2022 08:00	-0.1	13.1	1,994.1	0.1	0.6	1	1	1
02/02/2022 09:00	-0.1	13.7	1,645.1	0.1	0.5	1	1	1
02/02/2022 10:00	0.4	14.0	1,336.7	0.4	0.4	1	1	0
02/02/2022 11:00	0.4	14.0	1,341.3	0.4	0.4	1	1	0
02/02/2022 12:00	0.4	14.0	1,346.6	0.4	0.4	1	1	0
02/02/2022 13:00	0.4	14.0	1,358.1	0.4	0.4	1	1	0
02/02/2022 14:00	0.4	14.0	1,360.7	0.4	0.4	1	1	0
02/02/2022 15:00	0.3	13.9	1,626.5	0.4	0.5	1	1	0
02/02/2022 16:00	0.4	13.9	1,608.5	0.4	0.5	1	1	0
02/02/2022 17:00	0.1	13.8	1,687.2	0.2	0.5	1	1	1
02/02/2022 18:00	-0.4	12.8	2,027.7	-0.1	0.6	1	1	1
02/02/2022 19:00	-0.1	12.1	2,205.2	0.2	0.7	1	1	1
02/02/2022 20:00	0.1	12.0	2,215.8	0.2	0.7	1	1	1
02/02/2022 21:00	-0.1	12.4	2,131.5	0.2	0.6	1	1	1
02/02/2022 22:00	-0.1	12.7	2,038.4	0.1	0.6	1	1	1
02/02/2022 23:00	-0.1	12.9	2,007.3	0.1	0.6	1	1	1
Average/Sum#:	0.1	13.3	1,804.4	0.2	0.5	24 #	24 #	17 #
Minimum:	-0.4	12.0	1,336.7	-0.1	0.4	1	1	0
Maximum:	0.4	14.0	2,215.8	0.4	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/03/2022 00:00	-0.5	13.3	1,905.8	-0.2	0.6	1	1	1
02/03/2022 01:00	0.4	13.9	1,647.6	0.4	0.5	1	1	0
02/03/2022 02:00	0.2	13.9	1,775.6	0.2	0.5	1	1	1
02/03/2022 03:00	-0.4	13.0	1,990.0	-0.1	0.6	1	1	1
02/03/2022 04:00	-0.4	13.1	1,971.2	-0.1	0.6	1	1	1
02/03/2022 05:00	-0.4	13.1	1,987.1	-0.1	0.6	1	1	1
02/03/2022 06:00	-0.2	12.4	2,136.7	0.1	0.6	1	1	1
02/03/2022 07:00	-0.2	12.7	2,075.7	0.1	0.6	1	1	1
02/03/2022 08:00	-0.7	13.3	1,913.9	-0.4	0.6	1	1	1
02/03/2022 09:00	0.1	13.9	1,448.4	0.2	0.4	1	1	1
02/03/2022 10:00	0.4	13.9	1,656.2	0.4	0.5	1	1	0
02/03/2022 11:00	0.4	13.9	1,665.7	0.4	0.5	1	1	0
02/03/2022 12:00	0.4	14.0	1,378.1	0.4	0.4	1	1	0
02/03/2022 13:00	0.4	14.0	1,540.7	0.4	0.5	1	1	0
02/03/2022 14:00	0.4	14.0	1,466.2	0.4	0.4	1	1	0
02/03/2022 15:00	0.1	13.9	1,524.7	0.2	0.5	1	1	1
02/03/2022 16:00	-0.5	13.0	1,956.6	-0.2	0.6	1	1	1
02/03/2022 17:00	-0.2	12.7	2,038.7	0.1	0.6	1	1	1
02/03/2022 18:00	-0.1	12.5	2,082.2	0.1	0.6	1	1	1
02/03/2022 19:00	-0.1	12.5	2,084.0	0.1	0.6	1	1	1
02/03/2022 20:00	-0.1	12.5	2,084.4	0.1	0.6	1	1	1
02/03/2022 21:00	-0.1	12.3	2,135.7	0.2	0.6	1	1	1
02/03/2022 22:00	-0.1	12.6	2,057.7	0.1	0.6	1	1	1
02/03/2022 23:00	-0.1	12.8	2,035.7	0.1	0.6	1	1	1
Average/Sum#:	-0.1	13.2	1,856.6	0.1	0.6	24 #	24 #	18 #
Minimum:	-0.7	12.3	1,378.1	-0.4	0.4	1	1	0
Maximum:	0.4	14.0	2,136.7	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/04/2022 00:00	-0.2	12.9	2,000.8	0.1	0.6	1	1	1
02/04/2022 01:00	-0.7	13.3	1,899.3	-0.4	0.6	1	1	1
02/04/2022 02:00	0.4	13.9	1,596.2	0.4	0.5	1	1	0
02/04/2022 03:00	0.4	13.9	1,527.3	0.4	0.5	1	1	0
02/04/2022 04:00	0.1	13.9	1,582.9	0.2	0.5	1	1	1
02/04/2022 05:00	-0.4	13.1	1,975.2	-0.1	0.6	1	1	1
02/04/2022 06:00	-0.2	12.5	2,117.4	0.1	0.6	1	1	1
02/04/2022 07:00	-0.2	12.8	2,032.3	0.1	0.6	1	1	1
02/04/2022 08:00	0.0	14.6	1,184.3	0.0	0.4	1	0	1
02/04/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/04/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/04/2022 11:00	0.0	17.9	332.2	0.0	0.1	1	0	0
02/04/2022 12:00	0.0	15.6	845.9	0.0	0.3	1	0	0
02/04/2022 13:00	0.4	14.0	1,355.6	0.4	0.4	1	1	0
02/04/2022 14:00	0.4	14.0	1,350.1	0.4	0.4	1	1	0
02/04/2022 15:00	0.4	13.9	1,493.6	0.4	0.4	1	1	0
02/04/2022 16:00	0.4	14.0	1,605.4	0.4	0.5	1	1	0
02/04/2022 17:00	0.4	13.9	1,567.7	0.4	0.5	1	1	0
02/04/2022 18:00	0.4	14.0	1,456.5	0.4	0.4	1	1	0
02/04/2022 19:00	-0.4	13.3	1,869.9	-0.1	0.6	1	1	1
02/04/2022 20:00	-0.4	13.2	1,913.9	-0.1	0.6	1	1	1
02/04/2022 21:00	-0.4	13.3	1,911.2	-0.1	0.6	1	1	1
02/04/2022 22:00	-0.4	13.2	1,934.0	-0.1	0.6	1	1	1
02/04/2022 23:00	-0.2	12.9	1,994.0	0.1	0.6	1	1	1
Average/Sum#:	0.0	13.8	1,615.7	0.1	0.5	22 #	19 #	12 #
Minimum:	-0.7	12.5	332.2	-0.4	0.1	0	0	0
Maximum:	0.4	17.9	2,117.4	0.4	0.6	1	1	1
%SI	8.33	8.33	8.33	8.33	8.33	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/05/2022 00:00	-0.4	13.3	1,905.9	-0.1	0.6	1	1	1
02/05/2022 01:00	0.1	13.8	1,680.5	0.2	0.5	1	1	1
02/05/2022 02:00	0.3	14.0	1,394.3	0.4	0.4	1	1	0
02/05/2022 03:00	-0.5	13.4	1,871.4	-0.2	0.6	1	1	1
02/05/2022 04:00	-0.7	13.3	1,915.1	-0.4	0.6	1	1	1
02/05/2022 05:00	0.1	13.8	1,697.4	0.2	0.5	1	1	1
02/05/2022 06:00	0.1	13.9	1,585.6	0.2	0.5	1	1	1
02/05/2022 07:00	-0.4	13.0	1,985.6	-0.1	0.6	1	1	1
02/05/2022 08:00	0.0	14.4	1,212.6	0.0	0.4	1	0	1
02/05/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/05/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/05/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/05/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/05/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/05/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/05/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/05/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/05/2022 17:00	0.0	18.0	307.4	0.0	0.1	1	0	0
02/05/2022 18:00	0.0	16.2	689.7	0.0	0.2	1	0	0
02/05/2022 19:00	0.4	14.0	1,294.5	0.4	0.4	1	1	0
02/05/2022 20:00	0.1	13.9	1,548.5	0.2	0.5	1	1	1
02/05/2022 21:00	-0.4	12.9	1,984.5	-0.1	0.6	1	1	1
02/05/2022 22:00	-0.2	12.9	1,998.6	0.1	0.6	1	1	1
02/05/2022 23:00	-0.2	12.9	2,002.2	0.1	0.6	1	1	1
Average/Sum#:	-0.1	14.0	1,567.1	0.1	0.5	16 #	13 #	12 #
Minimum:	-0.7	12.9	307.4	-0.4	0.1	0	0	0
Maximum:	0.4	18.0	2,002.2	0.4	0.6	1	1	1
%SI	33.33	33.33	33.33	33.33	33.33	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/06/2022 00:00	-0.7	13.3	1,905.9	-0.4	0.6	1	1	1
02/06/2022 01:00	0.1	13.9	1,661.5	0.2	0.5	1	1	1
02/06/2022 02:00	0.1	13.9	1,600.0	0.2	0.5	1	1	1
02/06/2022 03:00	-0.5	13.1	1,960.0	-0.2	0.6	1	1	1
02/06/2022 04:00	-0.7	13.3	1,897.3	-0.4	0.6	1	1	1
02/06/2022 05:00	0.3	13.9	1,547.6	0.4	0.5	1	1	0
02/06/2022 06:00	0.3	14.0	1,305.9	0.4	0.4	1	1	0
02/06/2022 07:00	0.3	13.9	1,537.9	0.4	0.5	1	1	0
02/06/2022 08:00	0.0	16.1	452.6	0.0	0.1	1	0	0
02/06/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/06/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/06/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/06/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/06/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/06/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/06/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/06/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/06/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/06/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/06/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/06/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/06/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/06/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/06/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	-0.1	13.9	1,541.0	0.1	0.5	9 #	8 #	5 #
Minimum:	-0.7	13.1	452.6	-0.4	0.1	0	0	0
Maximum:	0.3	16.1	1,960.0	0.4	0.6	1	1	1
%SI	62.50	62.50	62.50	62.50	62.50	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/07/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/07/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/07/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/07/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/07/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/07/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/07/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/07/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/07/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/07/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/07/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/07/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/07/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/07/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/07/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/07/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/07/2022 16:00	0.0	17.7	330.2	0.0	0.1	1	0	0
02/07/2022 17:00	0.0	15.7	821.9	0.0	0.2	1	0	0
02/07/2022 18:00	0.4	14.0	1,381.2	0.4	0.4	1	1	0
02/07/2022 19:00	0.1	13.9	1,549.4	0.2	0.5	1	1	1
02/07/2022 20:00	-0.4	12.8	2,015.9	-0.1	0.6	1	1	1
02/07/2022 21:00	-0.2	12.7	2,036.8	0.1	0.6	1	1	1
02/07/2022 22:00	-0.2	12.8	2,021.2	0.1	0.6	1	1	1
02/07/2022 23:00	0.0	14.4	1,196.7	0.0	0.4	1	0	1
Average/Sum#:	0.0	14.3	1,419.2	0.1	0.4	8 #	5 #	5 #
Minimum:	-0.4	12.7	330.2	-0.1	0.1	0	0	0
Maximum:	0.4	17.7	2,036.8	0.4	0.6	1	1	1
%SI	66.67	66.67	66.67	66.67	66.67	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/08/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2022 05:00	0.0	17.8	330.0	0.0	0.1	1	0	0
02/08/2022 06:00	0.0	15.6	869.8	0.0	0.3	1	0	0
02/08/2022 07:00	0.4	14.0	1,260.1	0.4	0.4	1	1	0
02/08/2022 08:00	0.3	13.8	1,775.9	0.4	0.5	1	1	0
02/08/2022 09:00	0.3	13.8	1,795.8	0.4	0.5	1	1	0
02/08/2022 10:00	0.3	13.7	1,797.2	0.4	0.5	1	1	0
02/08/2022 11:00	0.4	13.7	1,793.5	0.4	0.5	1	1	0
02/08/2022 12:00	0.3	13.7	1,797.8	0.4	0.5	1	1	0
02/08/2022 13:00	0.3	13.7	1,795.4	0.4	0.5	1	1	0
02/08/2022 14:00	0.3	13.7	1,789.5	0.4	0.5	1	1	0
02/08/2022 15:00	0.3	13.8	1,769.9	0.4	0.5	1	1	0
02/08/2022 16:00	0.4	13.8	1,776.5	0.4	0.5	1	1	0
02/08/2022 17:00	-0.4	13.3	1,884.8	-0.1	0.6	1	1	1
02/08/2022 18:00	-0.2	13.1	1,955.6	-0.1	0.6	1	1	1
02/08/2022 19:00	-0.4	13.2	1,929.8	-0.1	0.6	1	1	1
02/08/2022 20:00	-0.4	13.2	1,932.3	-0.1	0.6	1	1	1
02/08/2022 21:00	-0.1	13.6	1,673.9	0.1	0.5	1	1	1
02/08/2022 22:00	0.0	15.1	872.7	0.0	0.3	1	0	0
02/08/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.1	14.0	1,600.0	0.2	0.5	18 #	15 #	5 #
Minimum:	-0.4	13.1	330.0	-0.1	0.1	0	0	0
Maximum:	0.4	17.8	1,955.6	0.4	0.6	1	1	1
%SI	25.00	25.00	25.00	25.00	25.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/09/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2022 16:00	0.0	17.0	499.7	0.0	0.1	1	0	0
02/09/2022 17:00	0.0	13.9	1,657.8	0.0	0.5	1	0	0
02/09/2022 18:00	0.2	13.7	1,788.3	0.4	0.5	1	1	1
02/09/2022 19:00	-0.2	13.0	1,967.4	0.1	0.6	1	1	1
02/09/2022 20:00	-0.1	12.8	2,033.7	0.1	0.6	1	1	1
02/09/2022 21:00	0.1	12.8	2,036.9	0.2	0.6	1	1	1
02/09/2022 22:00	-0.1	13.0	1,977.7	0.1	0.6	1	1	1
02/09/2022 23:00	0.1	13.8	1,504.7	0.2	0.5	1	1	1
Average/Sum#:	0.0	13.8	1,683.3	0.1	0.5	8 #	6 #	6 #
Minimum:	-0.2	12.8	499.7	0.0	0.1	0	0	0
Maximum:	0.2	17.0	2,036.9	0.4	0.6	1	1	1
%SI	66.67	66.67	66.67	66.67	66.67	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/10/2022 00:00	0.4	14.0	1,343.6	0.4	0.4	1	1	0
02/10/2022 01:00	0.1	13.9	1,574.3	0.2	0.5	1	1	1
02/10/2022 02:00	-0.9	13.1	1,933.0	-0.5	0.6	1	1	1
02/10/2022 03:00	-0.7	13.1	1,940.8	-0.4	0.6	1	1	1
02/10/2022 04:00	0.2	13.9	1,581.8	0.2	0.5	1	1	1
02/10/2022 05:00	0.1	13.9	1,576.2	0.2	0.5	1	1	1
02/10/2022 06:00	-0.4	12.7	2,014.9	-0.1	0.6	1	1	1
02/10/2022 07:00	-0.4	12.8	1,986.6	-0.1	0.6	1	1	1
02/10/2022 08:00	0.0	15.7	599.4	0.0	0.2	1	0	0
02/10/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/10/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/10/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/10/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/10/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/10/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/10/2022 15:00	0.0	19.1	97.3	0.0	0.0	1	0	0
02/10/2022 16:00	0.0	15.8	779.3	0.0	0.2	1	0	0
02/10/2022 17:00	0.1	13.5	1,535.8	0.2	0.5	1	1	1
02/10/2022 18:00	-0.1	11.9	2,195.2	0.2	0.7	1	1	1
02/10/2022 19:00	-0.1	12.1	2,169.8	0.2	0.7	1	1	1
02/10/2022 20:00	-0.1	12.3	2,100.9	0.2	0.6	1	1	1
02/10/2022 21:00	-0.2	12.8	1,999.4	0.1	0.6	1	1	1
02/10/2022 22:00	-0.5	12.9	1,974.2	-0.2	0.6	1	1	1
02/10/2022 23:00	-0.1	13.7	1,499.0	0.1	0.4	1	1	1
Average/Sum#:	-0.1	13.7	1,605.6	0.0	0.5	18 #	15 #	14 #
Minimum:	-0.9	11.9	97.3	-0.5	0.0	0	0	0
Maximum:	0.4	19.1	2,195.2	0.4	0.7	1	1	1
%SI	25.00	25.00	25.00	25.00	25.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/11/2022 00:00	0.3	14.0	1,272.7	0.4	0.4	1	1	0
02/11/2022 01:00	0.0	16.7	264.2	0.0	0.1	1	0	0
02/11/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/11/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/11/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/11/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/11/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/11/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/11/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/11/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/11/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/11/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/11/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/11/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/11/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/11/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/11/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/11/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/11/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/11/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/11/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/11/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/11/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/11/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.2	15.4	768.5	0.2	0.3	2 #	1 #	0 #
Minimum:	0.0	14.0	264.2	0.0	0.1	0	0	0
Maximum:	0.3	16.7	1,272.7	0.4	0.4	1	1	0
%SI	91.67	91.67	91.67	91.67	91.67	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/12/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/12/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/12/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/12/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/12/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/12/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/12/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/12/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/12/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/12/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/12/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/12/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/12/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/12/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/12/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/12/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/12/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/12/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/12/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/12/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/12/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/12/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/12/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/12/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/13/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/13/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/13/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/13/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/13/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/13/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/13/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/13/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/13/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/13/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/13/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/13/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/13/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/13/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/13/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/13/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/13/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/13/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/13/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/13/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/13/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/13/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/13/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/13/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/14/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/15/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/16/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/17/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/18/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/18/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/18/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/18/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/18/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/18/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/18/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/18/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/18/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/18/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/18/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/18/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/18/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/18/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/18/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/18/2022 15:00	0.0	17.7	334.1	0.0	0.1	1	0	0
02/18/2022 16:00	0.0	15.4	875.8	0.0	0.3	1	0	0
02/18/2022 17:00	0.4	14.0	1,609.4	0.4	0.5	1	1	0
02/18/2022 18:00	0.1	13.9	1,553.7	0.2	0.5	1	1	1
02/18/2022 19:00	-0.4	13.1	1,972.3	-0.1	0.6	1	1	1
02/18/2022 20:00	-0.8	13.2	1,907.0	-0.5	0.6	1	1	1
02/18/2022 21:00	0.4	13.9	1,533.5	0.4	0.5	1	1	0
02/18/2022 22:00	0.1	13.9	1,562.7	0.2	0.5	1	1	1
02/18/2022 23:00	-0.4	13.1	1,965.8	-0.1	0.6	1	1	1
Average/Sum#:	-0.1	14.2	1,479.4	0.1	0.5	9 #	7 #	5 #
Minimum:	-0.8	13.1	334.1	-0.5	0.1	0	0	0
Maximum:	0.4	17.7	1,972.3	0.4	0.6	1	1	1
%SI	62.50	62.50	62.50	62.50	62.50	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/19/2022 00:00	0.0	14.5	1,208.5	0.0	0.4	1	0	1
02/19/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/19/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/19/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/19/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/19/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/19/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/19/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/19/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/19/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/19/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/19/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/19/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/19/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/19/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/19/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/19/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/19/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/19/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/19/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/19/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/19/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/19/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/19/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	14.5	1,208.5	0.0	0.4	1 #	0 #	1 #
Minimum:	0.0	14.5	1,208.5	0.0	0.4	0	0	0
Maximum:	0.0	14.5	1,208.5	0.0	0.4	1	0	1
%SI	95.83	95.83	95.83	95.83	95.83	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/20/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/21/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/22/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2022 04:00	0.0	17.9	299.7	0.0	0.1	1	0	0
02/22/2022 05:00	0.0	15.8	820.3	0.0	0.2	1	0	0
02/22/2022 06:00	0.3	13.9	1,706.2	0.4	0.5	1	1	0
02/22/2022 07:00	0.3	13.9	1,559.6	0.4	0.5	1	1	0
02/22/2022 08:00	0.3	13.9	1,615.1	0.4	0.5	1	1	0
02/22/2022 09:00	0.3	13.9	1,516.2	0.4	0.5	1	1	0
02/22/2022 10:00	0.3	14.0	1,499.6	0.4	0.4	1	1	0
02/22/2022 11:00	0.3	14.0	1,499.1	0.4	0.4	1	1	0
02/22/2022 12:00	0.3	14.0	1,574.7	0.4	0.5	1	1	0
02/22/2022 13:00	0.3	14.0	1,563.0	0.4	0.5	1	1	0
02/22/2022 14:00	0.3	13.9	1,577.7	0.4	0.5	1	1	0
02/22/2022 15:00	0.3	13.9	1,591.5	0.4	0.5	1	1	0
02/22/2022 16:00	0.1	13.9	1,599.1	0.2	0.5	1	1	1
02/22/2022 17:00	-0.5	13.0	2,008.1	-0.2	0.6	1	1	1
02/22/2022 18:00	-0.4	12.9	2,019.2	-0.1	0.6	1	1	1
02/22/2022 19:00	-0.2	12.7	2,097.9	0.1	0.6	1	1	1
02/22/2022 20:00	-0.1	12.1	2,214.7	0.2	0.7	1	1	1
02/22/2022 21:00	-0.2	12.7	2,085.3	0.1	0.6	1	1	1
02/22/2022 22:00	-0.2	12.7	2,079.8	0.1	0.6	1	1	1
02/22/2022 23:00	-0.2	12.5	2,128.8	0.1	0.6	1	1	1
Average/Sum#:	0.1	13.8	1,652.8	0.2	0.5	20 #	18 #	8 #
Minimum:	-0.5	12.1	299.7	-0.2	0.1	0	0	0
Maximum:	0.3	17.9	2,214.7	0.4	0.7	1	1	1
%SI	16.67	16.67	16.67	16.67	16.67	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/23/2022 00:00	-0.1	12.3	2,198.7	0.2	0.7	1	1	1
02/23/2022 01:00	-0.2	12.5	2,149.8	0.1	0.6	1	1	1
02/23/2022 02:00	-0.2	12.6	2,132.6	0.1	0.6	1	1	1
02/23/2022 03:00	-0.4	12.9	2,016.1	-0.1	0.6	1	1	1
02/23/2022 04:00	0.4	13.9	1,684.9	0.4	0.5	1	1	0
02/23/2022 05:00	-0.4	13.6	1,844.4	-0.2	0.6	1	1	1
02/23/2022 06:00	-0.4	12.5	2,156.2	-0.1	0.6	1	1	1
02/23/2022 07:00	-0.2	12.5	2,157.1	0.1	0.6	1	1	1
02/23/2022 08:00	0.1	13.8	1,676.2	0.2	0.5	1	1	1
02/23/2022 09:00	0.4	14.0	1,522.7	0.4	0.5	1	1	0
02/23/2022 10:00	0.4	14.0	1,577.8	0.4	0.5	1	1	0
02/23/2022 11:00	0.4	13.9	1,639.3	0.4	0.5	1	1	0
02/23/2022 12:00	0.4	14.0	1,511.7	0.4	0.5	1	1	0
02/23/2022 13:00	0.4	14.0	1,415.6	0.4	0.4	1	1	0
02/23/2022 14:00	0.4	14.0	1,619.6	0.4	0.5	1	1	0
02/23/2022 15:00	0.4	14.0	1,587.3	0.4	0.5	1	1	0
02/23/2022 16:00	0.1	14.0	1,611.3	0.2	0.5	1	1	1
02/23/2022 17:00	-0.5	13.1	1,977.6	-0.2	0.6	1	1	1
02/23/2022 18:00	-0.2	13.0	2,007.4	0.1	0.6	1	1	1
02/23/2022 19:00	-0.2	13.1	2,007.7	-0.1	0.6	1	1	1
02/23/2022 20:00	-0.2	12.7	2,106.4	0.1	0.6	1	1	1
02/23/2022 21:00	-0.1	12.1	2,235.4	0.2	0.7	1	1	1
02/23/2022 22:00	-0.2	12.6	2,124.7	0.1	0.6	1	1	1
02/23/2022 23:00	-0.2	12.9	2,085.2	0.1	0.6	1	1	1
Average/Sum#:	0.0	13.3	1,876.9	0.2	0.6	24 #	24 #	16 #
Minimum:	-0.5	12.1	1,415.6	-0.2	0.4	1	1	0
Maximum:	0.4	14.0	2,235.4	0.4	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	VOC, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT2	Unit CT2	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	VOC, Ppmvdc	VOC, LbPerHr	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/24/2022 00:00	-0.2	12.3	2,203.4	0.1	0.7	1	1	1
02/24/2022 01:00	-0.2	12.3	2,197.9	0.1	0.7	1	1	1
02/24/2022 02:00	-0.2	12.3	2,214.0	0.1	0.7	1	1	1
02/24/2022 03:00	-0.1	12.1	2,239.1	0.2	0.7	1	1	1
02/24/2022 04:00	-0.2	12.3	2,239.6	0.1	0.7	1	1	1
02/24/2022 05:00	-0.2	12.2	2,242.3	0.1	0.7	1	1	1
02/24/2022 06:00	-0.2	12.2	2,243.8	0.1	0.7	1	1	1
02/24/2022 07:00	-0.2	12.5	2,177.8	0.1	0.7	1	1	1
02/24/2022 08:00	-0.5	13.1	2,036.2	-0.2	0.6	1	1	1
02/24/2022 09:00	-0.5	13.3	1,952.9	-0.2	0.6	1	1	1
02/24/2022 10:00	0.4	13.9	1,561.0	0.4	0.5	1	1	0
02/24/2022 11:00	0.4	14.0	1,430.3	0.4	0.4	1	1	0
02/24/2022 12:00	0.4	14.0	1,331.4	0.4	0.4	1	1	0
02/24/2022 13:00	0.4	14.0	1,379.1	0.4	0.4	1	1	0
02/24/2022 14:00	0.4	14.0	1,460.6	0.4	0.4	1	1	0
02/24/2022 15:00	0.4	14.0	1,456.1	0.4	0.4	1	1	0
02/24/2022 16:00	0.1	13.9	1,561.9	0.2	0.5	1	1	1
02/24/2022 17:00	-0.2	13.1	1,974.4	-0.1	0.6	1	1	1
02/24/2022 18:00	-0.2	12.4	2,172.5	0.1	0.7	1	1	1
02/24/2022 19:00	-0.1	12.2	2,214.2	0.2	0.7	1	1	1
02/24/2022 20:00	-0.2	12.4	2,164.0	0.1	0.6	1	1	1
02/24/2022 21:00	-0.1	12.3	2,189.9	0.2	0.7	1	1	1
02/24/2022 22:00	-0.1	12.4	2,186.1	0.2	0.7	1	1	1
02/24/2022 23:00	-0.2	12.6	2,143.6	0.1	0.6	1	1	1
Average/Sum#:	0.0	12.9	1,957.2	0.2	0.6	24 #	24 #	18 #
Minimum:	-0.5	12.1	1,331.4	-0.2	0.4	1	1	0
Maximum:	0.4	14.0	2,243.8	0.4	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/25/2022 00:00	-0.2	12.9	2,050.8	0.1	0.6	1	1	1
02/25/2022 01:00	-0.2	13.1	2,002.0	-0.1	0.6	1	1	1
02/25/2022 02:00	-0.2	13.1	1,999.0	-0.1	0.6	1	1	1
02/25/2022 03:00	-0.2	13.1	2,000.8	-0.1	0.6	1	1	1
02/25/2022 04:00	-0.2	13.0	2,040.3	0.1	0.6	1	1	1
02/25/2022 05:00	-0.2	13.1	2,008.1	-0.1	0.6	1	1	1
02/25/2022 06:00	-0.2	12.5	2,161.3	0.1	0.6	1	1	1
02/25/2022 07:00	-0.2	13.1	2,021.7	-0.1	0.6	1	1	1
02/25/2022 08:00	-0.2	13.4	1,923.1	-0.1	0.6	1	1	1
02/25/2022 09:00	0.4	14.0	1,512.8	0.4	0.5	1	1	0
02/25/2022 10:00	0.4	14.0	1,504.3	0.4	0.5	1	1	0
02/25/2022 11:00	0.4	14.0	1,606.9	0.4	0.5	1	1	0
02/25/2022 12:00	0.4	14.0	1,587.5	0.4	0.5	1	1	0
02/25/2022 13:00	0.4	14.0	1,599.2	0.4	0.5	1	1	0
02/25/2022 14:00	0.4	14.0	1,575.8	0.4	0.5	1	1	0
02/25/2022 15:00	0.4	14.0	1,552.1	0.4	0.5	1	1	0
02/25/2022 16:00	0.2	13.9	1,641.1	0.2	0.5	1	1	1
02/25/2022 17:00	-0.5	13.1	1,994.9	-0.2	0.6	1	1	1
02/25/2022 18:00	-0.7	13.2	1,938.0	-0.4	0.6	1	1	1
02/25/2022 19:00	-0.5	13.3	1,921.8	-0.2	0.6	1	1	1
02/25/2022 20:00	-0.4	13.2	1,958.0	-0.1	0.6	1	1	1
02/25/2022 21:00	-0.4	13.0	1,986.5	-0.1	0.6	1	1	1
02/25/2022 22:00	-0.2	12.9	2,022.4	0.1	0.6	1	1	1
02/25/2022 23:00	-0.2	13.0	2,029.4	0.1	0.6	1	1	1
Average/Sum#:	-0.1	13.4	1,859.9	0.1	0.6	24 #	24 #	17 #
Minimum:	-0.7	12.5	1,504.3	-0.4	0.5	1	1	0
Maximum:	0.4	14.0	2,161.3	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/26/2022 00:00	-0.4	12.9	2,058.5	-0.1	0.6	1	1	1
02/26/2022 01:00	-0.2	12.9	2,059.7	0.1	0.6	1	1	1
02/26/2022 02:00	-0.8	13.3	1,936.3	-0.5	0.6	1	1	1
02/26/2022 03:00	-0.9	13.4	1,932.8	-0.7	0.6	1	1	1
02/26/2022 04:00	-0.2	13.1	2,008.5	-0.1	0.6	1	1	1
02/26/2022 05:00	-0.4	13.1	2,006.2	-0.1	0.6	1	1	1
02/26/2022 06:00	-0.7	13.2	1,994.2	-0.4	0.6	1	1	1
02/26/2022 07:00	0.0	14.6	1,200.5	0.0	0.4	1	0	1
02/26/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/26/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/26/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/26/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/26/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/26/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/26/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/26/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/26/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/26/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/26/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/26/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/26/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/26/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/26/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/26/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	-0.5	13.3	1,899.6	-0.2	0.6	8 #	7 #	8 #
Minimum:	-0.9	12.9	1,200.5	-0.7	0.4	0	0	0
Maximum:	0.0	14.6	2,059.7	0.1	0.6	1	1	1
%SI	66.67	66.67	66.67	66.67	66.67	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/27/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/28/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/01/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/02/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/03/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/04/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/04/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/04/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/04/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/04/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/04/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/04/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/04/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/04/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/04/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/04/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/04/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/04/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/04/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/04/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/04/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/04/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/04/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/04/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/04/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/04/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/04/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/04/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/04/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/05/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/05/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/05/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/05/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/05/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/05/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/05/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/05/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/05/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/05/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/05/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/05/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/05/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/05/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/05/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/05/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/05/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/05/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/05/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/05/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/05/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/05/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/05/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/05/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/06/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/06/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/06/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/06/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/06/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/06/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/06/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/06/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/06/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/06/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/06/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/06/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/06/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/06/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/06/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/06/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/06/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/06/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/06/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/06/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/06/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/06/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/06/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/06/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/07/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/08/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/09/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/09/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/09/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/09/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/09/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/09/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/09/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/09/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/09/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/09/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/09/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/09/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/09/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/09/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/09/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/09/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/09/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/09/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/09/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/09/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/09/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/09/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/09/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/09/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/10/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/10/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/10/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/10/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/10/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/10/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/10/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/10/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/10/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/10/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/10/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/10/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/10/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/10/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/10/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/10/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/10/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/10/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/10/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/10/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/10/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/10/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/10/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/10/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/11/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/11/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/11/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/11/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/11/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/11/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/11/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/11/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/11/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/11/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/11/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/11/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/11/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/11/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/11/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/11/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/11/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/11/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/11/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/11/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/11/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/11/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/11/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/11/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/12/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/12/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/12/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/12/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/12/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/12/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/12/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/12/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/12/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/12/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/12/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/12/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/12/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/12/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/12/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/12/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/12/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/12/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/12/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/12/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/12/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/12/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/12/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/12/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/13/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/13/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/13/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/13/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/13/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/13/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/13/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/13/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/13/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/13/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/13/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/13/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/13/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/13/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/13/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/13/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/13/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/13/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/13/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/13/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/13/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/13/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/13/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/13/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/14/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/14/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/14/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/14/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/14/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/14/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/14/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/14/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/14/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/14/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/14/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/14/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/14/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/14/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/14/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/14/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/14/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/14/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/14/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/14/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/14/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/14/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/14/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/14/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/15/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/15/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/15/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/15/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/15/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/15/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/15/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/15/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/15/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/15/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/15/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/15/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/15/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/15/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/15/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/15/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/15/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/15/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/15/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/15/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/15/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/15/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/15/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/15/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/16/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/16/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/16/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/16/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/16/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/16/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/16/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/16/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/16/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/16/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/16/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/16/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/16/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/16/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/16/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/16/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/16/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/16/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/16/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/16/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/16/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/16/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/16/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/16/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/17/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/17/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/17/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/17/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/17/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/17/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/17/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/17/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/17/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/17/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/17/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/17/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/17/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/17/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/17/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/17/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/17/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/17/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/17/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/17/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/17/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/17/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/17/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/17/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/18/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/18/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/18/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/18/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/18/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/18/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/18/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/18/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/18/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/18/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/18/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/18/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/18/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/18/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/18/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/18/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/18/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/18/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/18/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/18/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/18/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/18/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/18/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/18/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/19/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/19/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/19/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/19/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/19/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/19/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/19/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/19/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/19/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/19/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/19/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/19/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/19/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/19/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/19/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/19/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/19/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/19/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/19/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/19/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/19/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/19/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/19/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/19/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/20/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/20/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/20/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/20/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/20/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/20/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/20/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/20/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/20/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/20/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/20/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/20/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/20/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/20/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/20/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/20/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/20/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/20/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/20/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/20/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/20/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/20/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/20/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/20/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/21/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/22/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/23/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/24/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/25/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/26/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/27/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/28/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/29/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/30/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/31/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Excess Emission Report



CT1 - VOC Lb 1-Day Block Average

From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:13 Location: Maxwell, CA

Tag Name: CT1_VOC_Lb_1D
Total Operating Time: 49.00 Day(s) No Exclusions Allowed
Non-Operating Time: 41.00 Day(s) Report Time: 90.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	49.00 Day(s)
Total Duration (Online only):	0.00 Day(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report



CT1 - VOC LbPerHr 1-Hour Block Average

From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:14 Location: Maxwell, CA

Tag Name: CT1_VOC_LbPerHr_1H
Total Operating Time: 884.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 1,276.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	884.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report



CT1 - VOC Ppmvdc 1-Hour Block Average

From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:15 Location: Maxwell, CA

Tag Name: CT1_VOC_Ppmvdc_1H
Total Operating Time: 884.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 1,276.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	884.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report



CT2 -VOC Lb 1-Day Block Average

From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:15 Location: Maxwell, CA

Tag Name: CT2_VOC_Lb_1D
Total Operating Time: 47.00 Day(s) No Exclusions Allowed
Non-Operating Time: 43.00 Day(s) Report Time: 90.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	47.00 Day(s)
Total Duration (Online only):	0.00 Day(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report



CT2 - VOC LbPerHr 1-Hour Block Average

From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:16 Location: Maxwell, CA

Tag Name: CT2_VOC_LbPerHr_1H
Total Operating Time: 777.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 1,383.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	777.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report



CT2 - VOC Ppmvdc 1-Hour Block Average

From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:16 Location: Maxwell, CA

Tag Name: CT2_VOC_Ppmvdc_1H
Total Operating Time: 777.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 1,383.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	777.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

ATTACHMENT 6
Hourly Emissions NOX

FCD:	AQ-15
Title V:	#6

Excess Emission Report



CT1 - NOx Lb 1-Day Block Average

From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:18 Location: Maxwell, CA

Tag Name: CT1_NOx_Lb_1D
Total Operating Time: 960.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 1,200.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	960.00 Hour(s)
Total Duration (Online only):	0.00 Day(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report



CT2 - NOx Lb 1-Day Block Average

From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:19 Location: Maxwell, CA

Tag Name: CT2_NOx_Lb_1D
Total Operating Time: 848.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 1,312.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	848.00 Hour(s)
Total Duration (Online only):	0.00 Day(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Daily Summary Report

CT1 - NOx



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/07/2022 10:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOX, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/01/2022 00:00	1.2	13.2	1,957.7	0.9	5.90	1	1	1
01/01/2022 01:00	1.1	13.8	1,625.0	0.9	4.90	1	1	0
01/01/2022 02:00	1.1	13.8	1,573.4	0.9	4.70	1	1	0
01/01/2022 03:00	1.2	13.8	1,785.8	1.0	7.10	1	1	0
01/01/2022 04:00	1.2	13.5	1,893.3	1.0	7.60	1	1	1
01/01/2022 05:00	1.3	13.4	1,886.5	1.0	7.50	1	1	1
01/01/2022 06:00	1.1	13.8	1,842.7	0.9	5.50	1	1	1
01/01/2022 07:00	1.2	13.1	2,020.3	0.9	6.10	1	1	1
01/01/2022 08:00	1.2	13.5	1,708.7	1.0	6.80	1	1	1
01/01/2022 09:00	1.1	13.9	1,380.9	0.9	4.10	1	1	0
01/01/2022 10:00	1.1	13.9	1,383.4	0.9	4.20	1	1	0
01/01/2022 11:00	1.1	13.9	1,382.8	0.9	4.10	1	1	0
01/01/2022 12:00	1.1	13.9	1,383.6	0.9	4.20	1	1	0
01/01/2022 13:00	1.1	13.9	1,379.6	0.9	4.10	1	1	0
01/01/2022 14:00	1.1	13.9	1,379.9	0.9	4.10	1	1	0
01/01/2022 15:00	1.1	13.9	1,372.4	0.9	4.10	1	1	0
01/01/2022 16:00	1.1	13.8	1,611.2	0.9	4.80	1	1	0
01/01/2022 17:00	1.1	13.8	1,591.0	0.9	4.80	1	1	0
01/01/2022 18:00	1.1	13.8	1,804.9	0.9	5.40	1	1	0
01/01/2022 19:00	1.1	13.8	1,840.4	0.9	5.50	1	1	1
01/01/2022 20:00	1.3	12.6	2,128.6	0.9	6.40	1	1	1
01/01/2022 21:00	1.3	12.4	2,173.5	0.9	6.50	1	1	1
01/01/2022 22:00	1.3	12.5	2,153.3	0.9	6.50	1	1	1
01/01/2022 23:00	1.3	12.7	2,129.5	0.9	6.40	1	1	1
Average/Sum#:	1.2	13.5	1,724.5	0.9	131.30 #	24 #	24 #	11 #
Minimum:	1.1	12.4	1,372.4	0.9	4.10	1	1	0
Maximum:	1.3	13.9	2,173.5	1.0	7.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:22 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit	> Limit	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT1	Unit CT1	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	NOx, Ppmvdc	NOx, Lb	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/02/2022 00:00	1.2	13.1	1,982.7	0.9	5.90	1	1	1
01/02/2022 01:00	1.1	13.8	1,551.6	0.9	4.70	1	1	0
01/02/2022 02:00	1.1	13.8	1,427.9	0.9	4.30	1	1	0
01/02/2022 03:00	1.1	13.8	1,760.9	0.9	5.30	1	1	0
01/02/2022 04:00	1.2	13.5	1,886.7	1.0	7.50	1	1	1
01/02/2022 05:00	1.1	13.5	1,898.5	0.9	5.70	1	1	1
01/02/2022 06:00	1.2	13.8	1,823.1	1.0	7.30	1	1	1
01/02/2022 07:00	1.3	13.1	2,021.6	1.0	8.10	1	1	1
01/02/2022 08:00	1.1	13.5	1,708.5	0.9	5.10	1	1	1
01/02/2022 09:00	1.1	13.8	1,424.2	0.9	4.30	1	1	0
01/02/2022 10:00	1.1	13.9	1,406.9	0.9	4.20	1	1	0
01/02/2022 11:00	1.1	13.9	1,368.6	0.9	4.10	1	1	0
01/02/2022 12:00	1.1	13.9	1,367.5	0.9	4.10	1	1	0
01/02/2022 13:00	1.1	13.9	1,367.2	0.9	4.10	1	1	0
01/02/2022 14:00	1.1	13.9	1,366.9	0.9	4.10	1	1	0
01/02/2022 15:00	1.1	13.9	1,379.2	0.9	4.10	1	1	0
01/02/2022 16:00	1.2	13.8	1,673.4	1.0	6.70	1	1	0
01/02/2022 17:00	1.1	13.8	1,591.9	0.9	4.80	1	1	0
01/02/2022 18:00	1.2	13.7	1,806.6	1.0	7.20	1	1	1
01/02/2022 19:00	1.3	12.7	2,081.2	0.9	6.20	1	1	1
01/02/2022 20:00	1.4	12.1	2,217.4	0.9	6.70	1	1	1
01/02/2022 21:00	1.3	12.5	2,119.6	0.9	6.40	1	1	1
01/02/2022 22:00	1.3	12.6	2,112.3	0.9	6.30	1	1	1
01/02/2022 23:00	1.3	13.0	2,017.9	1.0	8.10	1	1	1
Average/Sum#:	1.2	13.5	1,723.4	0.9	135.30 #	24 #	24 #	12 #
Minimum:	1.1	12.1	1,366.9	0.9	4.10	1	1	0
Maximum:	1.4	13.9	2,217.4	1.0	8.10	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:22 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit	> Limit	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT1	Unit CT1	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	NOx, Ppmvdc	NOx, Lb	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/03/2022 00:00	1.2	13.2	1,942.9	0.9	5.80	1	1	1
01/03/2022 01:00	1.1	13.8	1,660.6	0.9	5.00	1	1	0
01/03/2022 02:00	1.1	13.7	1,684.7	0.9	5.10	1	1	1
01/03/2022 03:00	1.3	13.0	2,014.4	1.0	8.10	1	1	1
01/03/2022 04:00	1.2	13.1	2,006.1	0.9	6.00	1	1	1
01/03/2022 05:00	1.3	12.7	2,083.5	0.9	6.30	1	1	1
01/03/2022 06:00	1.4	11.9	2,281.8	0.9	6.80	1	1	1
01/03/2022 07:00	1.3	12.5	2,113.7	0.9	6.30	1	1	1
01/03/2022 08:00	1.3	13.0	2,014.6	1.0	8.10	1	1	1
01/03/2022 09:00	1.2	13.2	1,959.7	0.9	5.90	1	1	1
01/03/2022 10:00	1.2	13.8	1,713.6	1.0	6.90	1	1	1
01/03/2022 11:00	1.1	13.8	1,438.6	0.9	4.30	1	1	0
01/03/2022 12:00	1.1	13.8	1,753.3	0.9	5.30	1	1	0
01/03/2022 13:00	1.2	13.3	1,873.5	0.9	5.60	1	1	1
01/03/2022 14:00	1.2	13.1	1,894.6	0.9	5.70	1	1	1
01/03/2022 15:00	1.1	13.8	1,651.7	0.9	5.00	1	1	0
01/03/2022 16:00	1.2	13.2	1,909.8	0.9	5.70	1	1	1
01/03/2022 17:00	1.4	12.3	2,124.4	1.0	8.50	1	1	1
01/03/2022 18:00	1.4	12.1	2,160.0	0.9	6.50	1	1	1
01/03/2022 19:00	1.4	11.9	2,205.8	0.9	6.60	1	1	1
01/03/2022 20:00	1.3	12.4	2,093.2	0.9	6.30	1	1	1
01/03/2022 21:00	1.3	12.6	2,050.5	0.9	6.20	1	1	1
01/03/2022 22:00	1.2	13.0	1,965.8	0.9	5.90	1	1	1
01/03/2022 23:00	1.3	12.7	2,048.0	0.9	6.10	1	1	1
Average/Sum#:	1.2	13.0	1,943.5	0.9	148.00 #	24 #	24 #	20 #
Minimum:	1.1	11.9	1,438.6	0.9	4.30	1	1	0
Maximum:	1.4	13.8	2,281.8	1.0	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:22 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit	> Limit	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT1	Unit CT1	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	NOx, Ppmvdc	NOx, Lb	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/04/2022 00:00	1.3	12.6	2,031.7	0.9	6.10	1	1	1
01/04/2022 01:00	1.1	13.8	1,562.2	0.9	4.70	1	1	0
01/04/2022 02:00	1.1	13.7	1,676.4	0.9	5.00	1	1	1
01/04/2022 03:00	1.2	13.1	1,938.3	0.9	5.80	1	1	1
01/04/2022 04:00	1.2	13.0	1,951.7	0.9	5.90	1	1	1
01/04/2022 05:00	1.1	13.8	1,671.4	0.9	5.00	1	1	0
01/04/2022 06:00	1.1	13.7	1,788.3	0.9	5.40	1	1	0
01/04/2022 07:00	1.3	12.9	1,995.6	1.0	8.00	1	1	1
01/04/2022 08:00	1.3	12.8	2,026.0	0.9	6.10	1	1	1
01/04/2022 09:00	1.2	13.2	1,953.1	0.9	5.90	1	1	1
01/04/2022 10:00	1.1	13.7	1,452.8	0.9	4.40	1	1	1
01/04/2022 11:00	1.1	13.8	1,347.2	0.9	4.00	1	1	0
01/04/2022 12:00	1.2	13.8	1,727.0	1.0	6.90	1	1	0
01/04/2022 13:00	1.2	13.5	1,826.9	1.0	7.30	1	1	1
01/04/2022 14:00	1.2	13.3	1,822.9	0.9	5.50	1	1	1
01/04/2022 15:00	1.1	13.8	1,587.7	0.9	4.80	1	1	0
01/04/2022 16:00	1.3	12.8	2,011.5	0.9	6.00	1	1	1
01/04/2022 17:00	1.4	12.2	2,155.4	0.9	6.50	1	1	1
01/04/2022 18:00	1.4	12.1	2,178.4	0.9	6.50	1	1	1
01/04/2022 19:00	1.4	12.2	2,160.5	0.9	6.50	1	1	1
01/04/2022 20:00	1.3	12.4	2,097.4	0.9	6.30	1	1	1
01/04/2022 21:00	1.3	12.6	2,063.5	0.9	6.20	1	1	1
01/04/2022 22:00	1.3	12.8	2,028.6	0.9	6.10	1	1	1
01/04/2022 23:00	1.3	12.7	2,048.8	0.9	6.10	1	1	1
Average/Sum#:	1.2	13.1	1,879.3	0.9	141.00 #	24 #	24 #	18 #
Minimum:	1.1	12.1	1,347.2	0.9	4.00	1	1	0
Maximum:	1.4	13.8	2,178.4	1.0	8.00	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:22 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit	> Limit	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT1	Unit CT1	UnitOn, TF	NormalOp, TF	Unit CT1
	1 Hour(s)	1 Hour(s)	1 Hour(s)	NOx, Ppmvdc	NOx, Lb	1 Hour(s)	1 Hour(s)	DBOn, TF
				1 Hour(s)	1 Hour(s)			1 Hour(s)
01/05/2022 00:00	1.2	13.3	1,834.7	0.9	5.50	1	1	1
01/05/2022 01:00	1.1	13.8	1,314.9	0.9	3.90	1	1	0
01/05/2022 02:00	1.1	13.8	1,346.0	0.9	4.00	1	1	0
01/05/2022 03:00	1.1	13.7	1,763.8	0.9	5.30	1	1	0
01/05/2022 04:00	1.2	13.4	1,873.9	0.9	5.60	1	1	1
01/05/2022 05:00	1.2	13.2	1,904.3	0.9	5.70	1	1	1
01/05/2022 06:00	1.1	13.7	1,688.0	0.9	5.10	1	1	1
01/05/2022 07:00	1.3	12.8	2,031.1	0.9	6.10	1	1	1
01/05/2022 08:00	1.3	12.9	2,022.7	1.0	8.10	1	1	1
01/05/2022 09:00	1.3	12.9	2,004.9	1.0	8.00	1	1	1
01/05/2022 10:00	1.1	13.8	1,486.1	0.9	4.50	1	1	0
01/05/2022 11:00	1.1	13.8	1,535.8	0.9	4.60	1	1	0
01/05/2022 12:00	1.1	13.7	1,740.8	0.9	5.20	1	1	0
01/05/2022 13:00	1.2	13.4	1,857.3	0.9	5.60	1	1	1
01/05/2022 14:00	1.2	13.3	1,852.4	0.9	5.60	1	1	1
01/05/2022 15:00	1.1	13.8	1,654.3	0.9	5.00	1	1	1
01/05/2022 16:00	1.3	12.8	2,033.0	0.9	6.10	1	1	1
01/05/2022 17:00	1.3	12.5	2,098.7	0.9	6.30	1	1	1
01/05/2022 18:00	1.4	12.2	2,163.9	0.9	6.50	1	1	1
01/05/2022 19:00	1.4	12.2	2,161.8	0.9	6.50	1	1	1
01/05/2022 20:00	1.4	12.2	2,165.1	0.9	6.50	1	1	1
01/05/2022 21:00	1.4	12.2	2,153.3	0.9	6.50	1	1	1
01/05/2022 22:00	1.2	13.0	1,971.4	0.9	5.90	1	1	1
01/05/2022 23:00	1.3	12.6	2,059.8	0.9	6.20	1	1	1
Average/Sum#:	1.2	13.1	1,863.3	0.9	138.30 #	24 #	24 #	18 #
Minimum:	1.1	12.2	1,314.9	0.9	3.90	1	1	0
Maximum:	1.4	13.8	2,165.1	1.0	8.10	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:22 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/06/2022 00:00	1.2	13.3	1,842.5	0.9	5.50	1	1	1
01/06/2022 01:00	1.1	13.8	1,332.2	0.9	4.00	1	1	0
01/06/2022 02:00	1.1	13.8	1,314.2	0.9	3.90	1	1	0
01/06/2022 03:00	1.1	13.8	1,558.9	0.9	4.70	1	1	0
01/06/2022 04:00	1.2	13.4	1,875.2	0.9	5.60	1	1	1
01/06/2022 05:00	1.1	13.4	1,867.9	0.9	5.60	1	1	1
01/06/2022 06:00	1.1	13.7	1,771.3	0.9	5.30	1	1	1
01/06/2022 07:00	1.3	13.0	2,016.8	1.0	8.10	1	1	1
01/06/2022 08:00	1.3	12.8	2,047.0	0.9	6.10	1	1	1
01/06/2022 09:00	1.2	13.1	1,953.8	0.9	5.90	1	1	1
01/06/2022 10:00	1.1	13.8	1,519.0	0.9	4.60	1	1	0
01/06/2022 11:00	1.1	13.8	1,583.0	0.9	4.70	1	1	0
01/06/2022 12:00	1.1	13.8	1,446.8	0.9	4.30	1	1	0
01/06/2022 13:00	1.1	13.8	1,338.0	0.9	4.00	1	1	0
01/06/2022 14:00	1.1	13.7	1,621.3	0.9	4.90	1	1	0
01/06/2022 15:00	1.1	13.8	1,445.0	0.9	4.30	1	1	0
01/06/2022 16:00	1.1	13.7	1,627.5	0.9	4.90	1	1	0
01/06/2022 17:00	1.1	13.7	1,742.2	0.9	5.20	1	1	1
01/06/2022 18:00	1.3	12.7	2,039.7	0.9	6.10	1	1	1
01/06/2022 19:00	1.3	12.4	2,094.2	0.9	6.30	1	1	1
01/06/2022 20:00	1.3	12.9	1,961.6	1.0	7.80	1	1	1
01/06/2022 21:00	1.1	13.7	1,673.8	0.9	5.00	1	1	0
01/06/2022 22:00	1.1	13.7	1,770.2	0.9	5.30	1	1	1
01/06/2022 23:00	1.3	12.8	2,000.5	0.9	6.00	1	1	1
Average/Sum#:	1.2	13.4	1,726.8	0.9	128.10 #	24 #	24 #	13 #
Minimum:	1.1	12.4	1,314.2	0.9	3.90	1	1	0
Maximum:	1.3	13.8	2,094.2	1.0	8.10	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:22 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/07/2022 00:00	1.2	13.3	1,829.4	0.9	5.50	1	1	1
01/07/2022 01:00	1.0	13.8	1,304.1	0.8	3.90	1	1	0
01/07/2022 02:00	0.9	13.7	1,629.3	0.7	4.90	1	1	1
01/07/2022 03:00	1.0	13.1	1,950.4	0.8	5.90	1	1	1
01/07/2022 04:00	1.0	13.1	1,930.2	0.8	5.80	1	1	1
01/07/2022 05:00	1.1	13.7	1,684.2	0.9	5.10	1	1	0
01/07/2022 06:00	1.1	13.7	1,597.1	0.9	4.80	1	1	1
01/07/2022 07:00	1.3	12.8	2,002.6	0.9	6.00	1	1	1
01/07/2022 08:00	1.3	13.0	1,942.8	1.0	7.80	1	1	1
01/07/2022 09:00	1.1	13.8	1,582.2	0.9	4.70	1	1	0
01/07/2022 10:00	1.1	13.8	1,538.7	0.9	4.60	1	1	0
01/07/2022 11:00	1.1	13.8	1,562.3	0.9	4.70	1	1	0
01/07/2022 12:00	1.1	13.8	1,549.0	0.9	4.60	1	1	0
01/07/2022 13:00	1.1	13.8	1,515.2	0.9	4.50	1	1	0
01/07/2022 14:00	1.1	13.8	1,497.6	0.9	4.50	1	1	0
01/07/2022 15:00	1.1	13.8	1,539.7	0.9	4.60	1	1	0
01/07/2022 16:00	1.1	13.8	1,543.7	0.9	4.60	1	1	0
01/07/2022 17:00	1.2	13.8	1,642.9	1.0	6.60	1	1	0
01/07/2022 18:00	1.2	13.3	1,866.1	0.9	5.60	1	1	1
01/07/2022 19:00	1.2	13.3	1,840.4	0.9	5.50	1	1	1
01/07/2022 20:00	1.1	13.7	1,587.7	0.9	4.80	1	1	1
01/07/2022 21:00	1.3	13.0	1,998.1	1.0	8.00	1	1	1
01/07/2022 22:00	2.0	14.4	1,215.2	1.8	4.25	1	0	1
01/07/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	1.2	13.6	1,667.3	0.9	121.25 #	23 #	22 #	12 #
Minimum:	0.9	12.8	1,215.2	0.7	3.90	0	0	0
Maximum:	2.0	14.4	2,002.6	1.8	8.00	1	1	1
%SI	4.17	4.17	4.17	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:22 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/08/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/08/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/08/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/08/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/08/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/08/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/08/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/08/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/08/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/08/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/08/2022 10:00	25.7	17.9	321.6	50.5	29.90	1	0	0
01/08/2022 11:00	10.7	17.2	388.4	17.1	24.50	1	0	0
01/08/2022 12:00	7.7	15.7	813.8	8.7	26.00	1	0	0
01/08/2022 13:00	1.1	13.9	1,404.2	0.9	4.20	1	1	0
01/08/2022 14:00	1.1	13.9	1,374.0	0.9	4.10	1	1	0
01/08/2022 15:00	1.1	13.8	1,729.0	0.9	5.20	1	1	0
01/08/2022 16:00	1.1	13.8	1,554.2	0.9	4.70	1	1	0
01/08/2022 17:00	1.1	13.8	1,635.3	0.9	4.90	1	1	0
01/08/2022 18:00	1.2	13.7	1,790.5	1.0	7.20	1	1	1
01/08/2022 19:00	1.3	12.8	2,051.0	0.9	6.20	1	1	1
01/08/2022 20:00	1.3	12.6	2,054.3	0.9	6.20	1	1	1
01/08/2022 21:00	1.1	13.8	1,720.3	0.9	5.20	1	1	0
01/08/2022 22:00	1.1	13.8	1,799.8	0.9	5.40	1	1	1
01/08/2022 23:00	1.3	12.8	2,035.8	0.9	6.10	1	1	1
Average/Sum#:	4.1	14.3	1,476.6	6.2	139.80 #	14 #	11 #	5 #
Minimum:	1.1	12.6	321.6	0.9	4.10	0	0	0
Maximum:	25.7	17.9	2,054.3	50.5	29.90	1	1	1
%SI	41.67	41.67	41.67	41.67	41.67	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:22 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit	> Limit	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT1	Unit CT1	UnitOn, TF	NormalOp, TF	Unit CT1
	1 Hour(s)	1 Hour(s)	1 Hour(s)	NOx, Ppmvdc	NOx, Lb	1 Hour(s)	1 Hour(s)	DBOn, TF
				1 Hour(s)	1 Hour(s)			1 Hour(s)
01/09/2022 00:00	1.2	13.1	1,966.5	0.9	5.90	1	1	1
01/09/2022 01:00	1.1	13.8	1,536.5	0.9	4.60	1	1	0
01/09/2022 02:00	1.1	13.8	1,602.4	0.9	4.80	1	1	1
01/09/2022 03:00	1.2	13.2	1,969.5	0.9	5.90	1	1	1
01/09/2022 04:00	1.2	13.2	1,953.1	0.9	5.90	1	1	1
01/09/2022 05:00	1.2	13.8	1,667.9	1.0	6.70	1	1	0
01/09/2022 06:00	1.1	13.7	1,685.1	0.9	5.10	1	1	1
01/09/2022 07:00	1.3	13.0	2,044.7	1.0	8.20	1	1	1
01/09/2022 08:00	1.2	13.1	1,988.6	0.9	6.00	1	1	1
01/09/2022 09:00	1.1	13.8	1,594.5	0.9	4.80	1	1	0
01/09/2022 10:00	1.1	13.8	1,534.8	0.9	4.60	1	1	0
01/09/2022 11:00	1.1	13.8	1,618.0	0.9	4.90	1	1	0
01/09/2022 12:00	1.1	13.8	1,468.2	0.9	4.40	1	1	0
01/09/2022 13:00	1.1	13.8	1,521.3	0.9	4.60	1	1	0
01/09/2022 14:00	1.1	13.8	1,652.7	0.9	5.00	1	1	0
01/09/2022 15:00	1.1	13.8	1,677.3	0.9	5.00	1	1	0
01/09/2022 16:00	1.1	13.8	1,634.7	0.9	4.90	1	1	1
01/09/2022 17:00	1.3	13.0	1,989.6	1.0	8.00	1	1	1
01/09/2022 18:00	1.3	12.7	2,073.2	0.9	6.20	1	1	1
01/09/2022 19:00	1.2	13.1	1,966.0	0.9	5.90	1	1	1
01/09/2022 20:00	1.3	12.9	2,013.4	1.0	8.10	1	1	1
01/09/2022 21:00	1.3	13.0	2,000.2	1.0	8.00	1	1	1
01/09/2022 22:00	1.3	12.7	2,059.8	0.9	6.20	1	1	1
01/09/2022 23:00	1.2	13.2	1,965.3	0.9	5.90	1	1	1
Average/Sum#:	1.2	13.4	1,799.3	0.9	139.60 #	24 #	24 #	15 #
Minimum:	1.1	12.7	1,468.2	0.9	4.40	1	1	0
Maximum:	1.3	13.8	2,073.2	1.0	8.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:22 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit	> Limit	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT1	Unit CT1	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	NOx, Ppmvdc	NOx, Lb	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/10/2022 00:00	1.2	13.3	1,867.1	0.9	5.60	1	1	1
01/10/2022 01:00	1.1	13.9	1,417.2	0.9	4.30	1	1	0
01/10/2022 02:00	1.1	13.9	1,384.2	0.9	4.20	1	1	0
01/10/2022 03:00	1.1	13.8	1,425.9	0.9	4.30	1	1	0
01/10/2022 04:00	1.1	13.8	1,503.6	0.9	4.50	1	1	0
01/10/2022 05:00	1.1	13.8	1,530.3	0.9	4.60	1	1	0
01/10/2022 06:00	1.2	13.8	1,787.2	1.0	7.10	1	1	0
01/10/2022 07:00	1.1	13.8	1,604.3	0.9	4.80	1	1	0
01/10/2022 08:00	1.1	13.8	1,673.4	0.9	5.00	1	1	0
01/10/2022 09:00	1.1	13.8	1,603.2	0.9	4.80	1	1	0
01/10/2022 10:00	1.1	13.8	1,648.2	0.9	4.90	1	1	1
01/10/2022 11:00	1.2	13.1	1,994.1	0.9	6.00	1	1	1
01/10/2022 12:00	1.2	13.2	1,934.8	0.9	5.80	1	1	1
01/10/2022 13:00	1.1	13.9	1,551.5	0.9	4.70	1	1	0
01/10/2022 14:00	1.1	13.8	1,656.1	0.9	5.00	1	1	0
01/10/2022 15:00	1.3	12.9	2,002.9	1.0	8.00	1	1	1
01/10/2022 16:00	1.3	12.6	2,082.9	0.9	6.20	1	1	1
01/10/2022 17:00	1.4	12.3	2,134.1	1.0	8.50	1	1	1
01/10/2022 18:00	1.4	12.2	2,162.3	0.9	6.50	1	1	1
01/10/2022 19:00	1.4	12.2	2,157.2	0.9	6.50	1	1	1
01/10/2022 20:00	1.4	12.2	2,163.1	0.9	6.50	1	1	1
01/10/2022 21:00	1.4	12.3	2,147.3	1.0	8.60	1	1	1
01/10/2022 22:00	1.3	12.8	2,028.4	0.9	6.10	1	1	1
01/10/2022 23:00	1.3	13.0	2,007.3	1.0	8.00	1	1	1
Average/Sum#:	1.2	13.3	1,811.1	0.9	140.50 #	24 #	24 #	13 #
Minimum:	1.1	12.2	1,384.2	0.9	4.20	1	1	0
Maximum:	1.4	13.9	2,163.1	1.0	8.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:22 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit	> Limit	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT1	Unit CT1	UnitOn, TF	NormalOp, TF	Unit CT1
	1 Hour(s)	1 Hour(s)	1 Hour(s)	NOx, Ppmvdc	NOx, Lb	1 Hour(s)	1 Hour(s)	DBOn, TF
				1 Hour(s)	1 Hour(s)			1 Hour(s)
01/11/2022 00:00	1.2	13.3	1,850.1	0.9	5.60	1	1	1
01/11/2022 01:00	1.1	13.9	1,313.8	0.9	3.90	1	1	0
01/11/2022 02:00	1.1	13.8	1,593.7	0.9	4.80	1	1	1
01/11/2022 03:00	1.2	13.2	1,966.2	0.9	5.90	1	1	1
01/11/2022 04:00	1.2	13.2	1,949.9	0.9	5.80	1	1	1
01/11/2022 05:00	1.1	13.8	1,629.6	0.9	4.90	1	1	0
01/11/2022 06:00	1.1	13.8	1,608.7	0.9	4.80	1	1	1
01/11/2022 07:00	1.2	13.0	2,002.9	0.9	6.00	1	1	1
01/11/2022 08:00	1.2	13.3	1,847.1	0.9	5.50	1	1	1
01/11/2022 09:00	1.1	13.9	1,326.2	0.9	4.00	1	1	0
01/11/2022 10:00	1.1	13.9	1,320.5	0.9	4.00	1	1	0
01/11/2022 11:00	1.1	13.9	1,382.5	0.9	4.10	1	1	0
01/11/2022 12:00	1.1	13.9	1,366.7	0.9	4.10	1	1	0
01/11/2022 13:00	1.1	13.9	1,364.1	0.9	4.10	1	1	0
01/11/2022 14:00	1.1	13.9	1,319.5	0.9	4.00	1	1	0
01/11/2022 15:00	1.1	13.9	1,388.8	0.9	4.20	1	1	0
01/11/2022 16:00	1.1	13.8	1,638.3	0.9	4.90	1	1	0
01/11/2022 17:00	1.2	13.8	1,681.6	1.0	6.70	1	1	1
01/11/2022 18:00	1.2	13.0	1,991.5	0.9	6.00	1	1	1
01/11/2022 19:00	1.3	13.1	1,964.9	1.0	7.90	1	1	1
01/11/2022 20:00	1.2	13.1	1,955.5	0.9	5.90	1	1	1
01/11/2022 21:00	1.2	13.1	1,971.3	0.9	5.90	1	1	1
01/11/2022 22:00	1.3	12.9	2,023.0	1.0	8.10	1	1	1
01/11/2022 23:00	1.2	13.4	1,691.6	0.9	5.10	1	1	1
Average/Sum#:	1.2	13.5	1,672.8	0.9	126.20 #	24 #	24 #	14 #
Minimum:	1.1	12.9	1,313.8	0.9	3.90	1	1	0
Maximum:	1.3	13.9	2,023.0	1.0	8.10	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:22 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit	> Limit	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT1	Unit CT1	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	NOx, Ppmvdc	NOx, Lb	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/12/2022 00:00	1.1	13.8	1,378.5	0.9	4.10	1	1	0
01/12/2022 01:00	1.1	13.8	1,366.9	0.9	4.10	1	1	0
01/12/2022 02:00	1.1	13.8	1,364.0	0.9	4.10	1	1	0
01/12/2022 03:00	1.1	13.8	1,370.0	0.9	4.10	1	1	0
01/12/2022 04:00	1.1	13.8	1,370.5	0.9	4.10	1	1	0
01/12/2022 05:00	1.2	13.8	1,437.7	1.0	5.80	1	1	1
01/12/2022 06:00	1.2	13.2	1,964.8	0.9	5.90	1	1	1
01/12/2022 07:00	1.2	13.2	1,965.4	0.9	5.90	1	1	1
01/12/2022 08:00	1.2	13.2	1,963.9	0.9	5.90	1	1	1
01/12/2022 09:00	1.1	13.7	1,747.1	0.9	5.20	1	1	1
01/12/2022 10:00	1.1	13.8	1,599.4	0.9	4.80	1	1	0
01/12/2022 11:00	1.1	13.9	1,402.1	0.9	4.20	1	1	0
01/12/2022 12:00	1.1	13.8	1,544.7	0.9	4.60	1	1	0
01/12/2022 13:00	1.1	13.8	1,596.6	0.9	4.80	1	1	0
01/12/2022 14:00	1.1	13.8	1,581.0	0.9	4.70	1	1	0
01/12/2022 15:00	1.1	13.8	1,647.6	0.9	4.90	1	1	1
01/12/2022 16:00	1.3	12.8	2,023.2	0.9	6.10	1	1	1
01/12/2022 17:00	1.3	12.4	2,095.2	0.9	6.30	1	1	1
01/12/2022 18:00	1.3	12.6	2,070.3	0.9	6.20	1	1	1
01/12/2022 19:00	1.3	12.6	2,059.0	0.9	6.20	1	1	1
01/12/2022 20:00	1.3	13.0	1,972.7	1.0	7.90	1	1	1
01/12/2022 21:00	1.1	13.8	1,689.8	0.9	5.10	1	1	0
01/12/2022 22:00	1.1	13.8	1,807.4	0.9	5.40	1	1	1
01/12/2022 23:00	1.2	13.1	1,985.3	0.9	6.00	1	1	1
Average/Sum#:	1.2	13.5	1,708.5	0.9	126.40 #	24 #	24 #	13 #
Minimum:	1.1	12.4	1,364.0	0.9	4.10	1	1	0
Maximum:	1.3	13.9	2,095.2	1.0	7.90	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:22 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/13/2022 00:00	1.2	13.4	1,844.4	0.9	5.50	1	1	1
01/13/2022 01:00	1.1	13.9	1,315.9	0.9	3.90	1	1	0
01/13/2022 02:00	1.1	13.8	1,600.7	0.9	4.80	1	1	1
01/13/2022 03:00	1.2	13.2	1,977.5	0.9	5.90	1	1	1
01/13/2022 04:00	1.2	13.2	1,958.0	0.9	5.90	1	1	1
01/13/2022 05:00	1.2	13.8	1,693.9	1.0	6.80	1	1	0
01/13/2022 06:00	1.1	13.8	1,636.6	0.9	4.90	1	1	1
01/13/2022 07:00	1.3	12.8	2,034.3	0.9	6.10	1	1	1
01/13/2022 08:00	1.2	13.1	1,949.0	0.9	5.80	1	1	1
01/13/2022 09:00	1.1	13.8	1,670.8	0.9	5.00	1	1	0
01/13/2022 10:00	1.1	13.8	1,407.6	0.9	4.20	1	1	0
01/13/2022 11:00	1.1	13.8	1,647.5	0.9	4.90	1	1	0
01/13/2022 12:00	1.2	13.4	1,872.7	0.9	5.60	1	1	1
01/13/2022 13:00	1.3	12.7	2,012.5	0.9	6.00	1	1	1
01/13/2022 14:00	1.1	13.8	1,563.2	0.9	4.70	1	1	0
01/13/2022 15:00	1.1	13.8	1,579.8	0.9	4.70	1	1	1
01/13/2022 16:00	1.3	12.8	2,013.4	0.9	6.00	1	1	1
01/13/2022 17:00	1.3	12.7	2,049.9	0.9	6.10	1	1	1
01/13/2022 18:00	1.3	12.5	2,085.7	0.9	6.30	1	1	1
01/13/2022 19:00	1.3	13.0	1,969.2	1.0	7.90	1	1	1
01/13/2022 20:00	1.1	13.8	1,611.3	0.9	4.80	1	1	0
01/13/2022 21:00	1.1	13.8	1,648.8	0.9	4.90	1	1	1
01/13/2022 22:00	1.3	12.9	1,997.9	1.0	8.00	1	1	1
01/13/2022 23:00	2.7	14.4	1,214.2	2.5	5.23	1	0	1
Average/Sum#:	1.3	13.4	1,764.8	1.0	133.93 #	24 #	23 #	17 #
Minimum:	1.1	12.5	1,214.2	0.9	3.90	1	0	0
Maximum:	2.7	14.4	2,085.7	2.5	8.00	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:22 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/14/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/14/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/14/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/14/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/14/2022 04:00	1.9	18.2	282.7	4.2	1.26	1	0	0
01/14/2022 05:00	9.1	15.7	779.0	10.3	29.60	1	0	0
01/14/2022 06:00	1.1	13.8	1,493.2	0.9	4.50	1	1	0
01/14/2022 07:00	1.2	13.6	1,848.6	1.0	7.40	1	1	0
01/14/2022 08:00	1.1	13.9	1,385.3	0.9	4.20	1	1	0
01/14/2022 09:00	1.1	13.9	1,366.9	0.9	4.10	1	1	0
01/14/2022 10:00	1.1	13.9	1,368.3	0.9	4.10	1	1	0
01/14/2022 11:00	1.1	13.9	1,370.0	0.9	4.10	1	1	0
01/14/2022 12:00	1.1	13.9	1,380.9	0.9	4.10	1	1	0
01/14/2022 13:00	1.2	13.7	1,752.9	1.0	7.00	1	1	0
01/14/2022 14:00	1.1	13.9	1,531.2	0.9	4.60	1	1	0
01/14/2022 15:00	1.1	13.9	1,532.5	0.9	4.60	1	1	0
01/14/2022 16:00	1.1	13.9	1,433.1	0.9	4.30	1	1	0
01/14/2022 17:00	1.1	13.8	1,599.4	0.9	4.80	1	1	0
01/14/2022 18:00	1.1	13.8	1,627.6	0.9	4.90	1	1	0
01/14/2022 19:00	1.2	13.3	1,870.8	0.9	5.60	1	1	1
01/14/2022 20:00	1.2	13.2	1,890.4	0.9	5.70	1	1	1
01/14/2022 21:00	1.1	13.8	1,730.2	0.9	5.20	1	1	1
01/14/2022 22:00	1.3	12.9	2,037.7	1.0	8.20	1	1	1
01/14/2022 23:00	2.0	14.4	1,233.4	1.8	4.13	1	0	1
Average/Sum#:	1.6	14.1	1,475.7	1.6	122.39 #	20 #	17 #	5 #
Minimum:	1.1	12.9	282.7	0.9	1.26	0	0	0
Maximum:	9.1	18.2	2,037.7	10.3	29.60	1	1	1
%SI	16.67	16.67	16.67	16.67	16.67	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:22 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/15/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/15/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/15/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/15/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/15/2022 04:00	1.2	18.4	254.0	2.8	0.58	1	0	0
01/15/2022 05:00	9.2	15.9	760.7	10.9	30.40	1	0	0
01/15/2022 06:00	1.1	13.8	1,518.2	0.9	4.60	1	1	0
01/15/2022 07:00	1.1	13.8	1,564.5	0.9	4.70	1	1	0
01/15/2022 08:00	1.1	13.9	1,417.4	0.9	4.30	1	1	0
01/15/2022 09:00	1.1	13.8	1,532.1	0.9	4.60	1	1	0
01/15/2022 10:00	1.1	13.9	1,371.3	0.9	4.10	1	1	0
01/15/2022 11:00	1.1	13.9	1,372.9	0.9	4.10	1	1	0
01/15/2022 12:00	1.1	13.9	1,369.4	0.9	4.10	1	1	0
01/15/2022 13:00	1.1	13.9	1,375.7	0.9	4.10	1	1	0
01/15/2022 14:00	1.1	13.8	1,735.1	0.9	5.20	1	1	0
01/15/2022 15:00	1.1	13.8	1,579.2	0.9	4.70	1	1	0
01/15/2022 16:00	1.1	13.8	1,599.2	0.9	4.80	1	1	0
01/15/2022 17:00	1.2	13.8	1,682.0	1.0	6.70	1	1	0
01/15/2022 18:00	1.2	13.3	1,883.4	0.9	5.70	1	1	1
01/15/2022 19:00	1.3	13.0	1,975.2	1.0	7.90	1	1	1
01/15/2022 20:00	1.1	13.8	1,707.9	0.9	5.10	1	1	1
01/15/2022 21:00	1.1	13.7	1,787.6	0.9	5.40	1	1	1
01/15/2022 22:00	1.3	13.0	1,996.1	1.0	8.00	1	1	1
01/15/2022 23:00	1.7	14.0	1,474.6	1.5	5.40	1	0	1
Average/Sum#:	1.6	14.1	1,497.8	1.5	124.48 #	20 #	17 #	6 #
Minimum:	1.1	13.0	254.0	0.9	0.58	0	0	0
Maximum:	9.2	18.4	1,996.1	10.9	30.40	1	1	1
%SI	16.67	16.67	16.67	16.67	16.67	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:22 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/16/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/16/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/16/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/16/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/16/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/16/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/16/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/16/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/16/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/16/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/16/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/16/2022 11:00	21.4	17.5	355.9	37.1	48.80	1	0	0
01/16/2022 12:00	9.1	16.1	682.8	11.2	28.00	1	0	0
01/16/2022 13:00	1.1	13.8	1,384.6	0.9	4.20	1	1	0
01/16/2022 14:00	1.1	13.9	1,372.8	0.9	4.10	1	1	0
01/16/2022 15:00	1.1	13.8	1,672.4	0.9	5.00	1	1	0
01/16/2022 16:00	1.1	13.8	1,664.3	0.9	5.00	1	1	0
01/16/2022 17:00	1.1	13.9	1,455.8	0.9	4.40	1	1	0
01/16/2022 18:00	1.1	13.7	1,722.5	0.9	5.20	1	1	0
01/16/2022 19:00	1.2	13.2	1,921.4	0.9	5.80	1	1	1
01/16/2022 20:00	1.3	12.7	2,025.6	0.9	6.10	1	1	1
01/16/2022 21:00	1.2	13.8	1,712.4	1.0	6.80	1	1	0
01/16/2022 22:00	1.1	13.9	1,409.5	0.9	4.20	1	1	0
01/16/2022 23:00	1.1	13.8	1,634.3	0.9	4.90	1	1	0
Average/Sum#:	3.3	14.1	1,462.6	4.5	132.50 #	13 #	11 #	2 #
Minimum:	1.1	12.7	355.9	0.9	4.10	0	0	0
Maximum:	21.4	17.5	2,025.6	37.1	48.80	1	1	1
%SI	45.83	45.83	45.83	45.83	45.83	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:22 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit	> Limit	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT1	Unit CT1	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	NOx, Ppmvdc	NOx, Lb	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/17/2022 00:00	1.2	13.4	1,840.9	0.9	5.50	1	1	1
01/17/2022 01:00	1.2	13.3	1,870.0	0.9	5.60	1	1	1
01/17/2022 02:00	1.1	13.8	1,425.5	0.9	4.30	1	1	0
01/17/2022 03:00	1.1	13.8	1,763.8	0.9	5.30	1	1	0
01/17/2022 04:00	1.2	13.5	1,863.6	1.0	7.50	1	1	1
01/17/2022 05:00	1.2	13.5	1,843.7	1.0	7.40	1	1	1
01/17/2022 06:00	1.1	13.7	1,713.3	0.9	5.10	1	1	1
01/17/2022 07:00	1.3	12.8	2,038.5	0.9	6.10	1	1	1
01/17/2022 08:00	1.3	12.8	2,057.3	0.9	6.20	1	1	1
01/17/2022 09:00	1.3	13.0	1,980.1	1.0	7.90	1	1	1
01/17/2022 10:00	1.1	13.8	1,593.8	0.9	4.80	1	1	0
01/17/2022 11:00	1.1	13.8	1,596.2	0.9	4.80	1	1	0
01/17/2022 12:00	1.2	13.8	1,662.3	1.0	6.60	1	1	1
01/17/2022 13:00	1.3	13.0	1,963.0	1.0	7.90	1	1	1
01/17/2022 14:00	1.3	13.0	1,939.3	1.0	7.80	1	1	1
01/17/2022 15:00	1.1	13.8	1,614.0	0.9	4.80	1	1	0
01/17/2022 16:00	1.1	13.8	1,606.1	0.9	4.80	1	1	1
01/17/2022 17:00	1.3	12.9	1,985.5	1.0	7.90	1	1	1
01/17/2022 18:00	1.3	12.8	2,021.2	0.9	6.10	1	1	1
01/17/2022 19:00	1.3	12.6	2,062.2	0.9	6.20	1	1	1
01/17/2022 20:00	1.2	13.0	1,952.0	0.9	5.90	1	1	1
01/17/2022 21:00	1.1	13.8	1,659.8	0.9	5.00	1	1	0
01/17/2022 22:00	1.1	13.9	1,422.2	0.9	4.30	1	1	0
01/17/2022 23:00	1.1	13.8	1,644.1	0.9	4.90	1	1	0
Average/Sum#:	1.2	13.4	1,796.6	0.9	142.70 #	24 #	24 #	16 #
Minimum:	1.1	12.6	1,422.2	0.9	4.30	1	1	0
Maximum:	1.3	13.9	2,062.2	1.0	7.90	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:22 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/18/2022 00:00	1.2	13.7	1,795.1	1.0	7.20	1	1	1
01/18/2022 01:00	1.2	13.2	1,857.5	0.9	5.60	1	1	1
01/18/2022 02:00	1.1	13.8	1,639.3	0.9	4.90	1	1	0
01/18/2022 03:00	1.2	13.2	1,962.3	0.9	5.90	1	1	1
01/18/2022 04:00	1.2	13.2	1,960.2	0.9	5.90	1	1	1
01/18/2022 05:00	1.0	13.8	1,586.1	0.8	4.80	1	1	1
01/18/2022 06:00	1.1	13.8	1,610.8	0.9	4.80	1	1	1
01/18/2022 07:00	1.2	13.2	1,983.9	0.9	6.00	1	1	1
01/18/2022 08:00	1.3	12.9	2,026.9	1.0	8.10	1	1	1
01/18/2022 09:00	1.2	13.2	1,947.5	0.9	5.80	1	1	1
01/18/2022 10:00	0.0	0.0	1,445.2	0.0	0.00	1	1	0
01/18/2022 11:00	1.1	13.8	1,411.2	0.9	4.20	1	1	0
01/18/2022 12:00	1.1	13.9	1,313.9	0.9	3.90	1	1	0
01/18/2022 13:00	0.0	0.0	1,323.2	0.0	0.00	1	1	0
01/18/2022 14:00	1.1	13.9	1,362.3	0.9	4.10	1	1	0
01/18/2022 15:00	1.1	13.8	1,542.4	0.9	4.60	1	1	0
01/18/2022 16:00	1.2	13.7	1,637.2	1.0	6.50	1	1	1
01/18/2022 17:00	1.3	12.7	2,032.0	0.9	6.10	1	1	1
01/18/2022 18:00	1.3	12.7	2,047.9	0.9	6.10	1	1	1
01/18/2022 19:00	1.3	12.5	2,082.4	0.9	6.20	1	1	1
01/18/2022 20:00	1.2	13.1	1,952.4	0.9	5.90	1	1	1
01/18/2022 21:00	1.1	13.7	1,601.0	0.9	4.80	1	1	1
01/18/2022 22:00	1.1	13.8	1,606.3	0.9	4.80	1	1	1
01/18/2022 23:00	1.2	13.0	1,992.0	0.9	6.00	1	1	1
Average/Sum#:	1.2	13.4	1,738.3	0.9	122.20 #	24 #	24 #	17 #
Minimum:	1.0	12.5	1,313.9	0.8	3.90	1	1	0
Maximum:	1.3	13.9	2,082.4	1.0	8.10	1	1	1
%SI	8.33	8.33	0.00	8.33	8.33	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:22 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit	> Limit	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT1	Unit CT1	UnitOn, TF	NormalOp, TF	Unit CT1
	1 Hour(s)	1 Hour(s)	1 Hour(s)	NOx, Ppmvdc	NOx, Lb	1 Hour(s)	1 Hour(s)	DBOn, TF
				1 Hour(s)	1 Hour(s)			1 Hour(s)
01/19/2022 00:00	1.2	13.3	1,846.2	0.9	5.50	1	1	1
01/19/2022 01:00	1.1	13.9	1,311.8	0.9	3.90	1	1	0
01/19/2022 02:00	1.1	13.8	1,600.1	0.9	4.80	1	1	1
01/19/2022 03:00	1.2	13.2	1,975.1	0.9	5.90	1	1	1
01/19/2022 04:00	1.2	13.2	1,944.5	0.9	5.80	1	1	1
01/19/2022 05:00	1.0	13.8	1,593.6	0.8	4.80	1	1	0
01/19/2022 06:00	1.2	13.8	1,610.8	1.0	6.40	1	1	1
01/19/2022 07:00	1.2	13.1	1,980.7	0.9	5.90	1	1	1
01/19/2022 08:00	1.5	13.2	1,962.0	1.1	7.80	1	1	1
01/19/2022 09:00	1.3	13.8	1,518.3	1.1	6.10	1	1	0
01/19/2022 10:00	1.1	13.9	1,363.9	0.9	4.10	1	1	0
01/19/2022 11:00	1.1	13.9	1,428.7	0.9	4.30	1	1	0
01/19/2022 12:00	1.1	13.9	1,332.7	0.9	4.00	1	1	0
01/19/2022 13:00	1.1	13.9	1,385.3	0.9	4.20	1	1	0
01/19/2022 14:00	1.1	13.9	1,361.1	0.9	4.10	1	1	0
01/19/2022 15:00	1.2	13.7	1,584.8	1.0	6.30	1	1	1
01/19/2022 16:00	1.4	12.5	2,080.9	1.0	8.30	1	1	1
01/19/2022 17:00	1.3	12.3	2,106.3	0.9	6.30	1	1	1
01/19/2022 18:00	1.3	12.5	2,081.8	0.9	6.20	1	1	1
01/19/2022 19:00	1.3	12.4	2,096.4	0.9	6.30	1	1	1
01/19/2022 20:00	1.3	12.6	2,027.1	0.9	6.10	1	1	1
01/19/2022 21:00	1.1	13.8	1,700.4	0.9	5.10	1	1	0
01/19/2022 22:00	1.1	13.7	1,795.7	0.9	5.40	1	1	1
01/19/2022 23:00	1.3	12.9	1,999.9	1.0	8.00	1	1	1
Average/Sum#:	1.2	13.4	1,737.0	0.9	135.60 #	24 #	24 #	15 #
Minimum:	1.0	12.3	1,311.8	0.8	3.90	1	1	0
Maximum:	1.5	13.9	2,106.3	1.1	8.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:22 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit	> Limit	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT1	Unit CT1	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	NOx, Ppmvdc	NOx, Lb	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/20/2022 00:00	1.2	13.1	1,860.6	0.9	5.60	1	1	1
01/20/2022 01:00	1.1	13.9	1,315.3	0.9	3.90	1	1	0
01/20/2022 02:00	1.1	13.9	1,325.6	0.9	4.00	1	1	0
01/20/2022 03:00	1.1	13.8	1,748.2	0.9	5.20	1	1	0
01/20/2022 04:00	1.2	13.4	1,863.7	0.9	5.60	1	1	1
01/20/2022 05:00	1.2	13.4	1,871.0	0.9	5.60	1	1	1
01/20/2022 06:00	1.1	13.8	1,726.9	0.9	5.20	1	1	1
01/20/2022 07:00	1.3	13.0	1,995.8	1.0	8.00	1	1	1
01/20/2022 08:00	1.2	13.5	1,704.2	1.0	6.80	1	1	1
01/20/2022 09:00	1.1	13.9	1,391.1	0.9	4.20	1	1	0
01/20/2022 10:00	1.1	13.9	1,368.4	0.9	4.10	1	1	0
01/20/2022 11:00	1.1	13.9	1,373.3	0.9	4.10	1	1	0
01/20/2022 12:00	1.1	13.9	1,375.3	0.9	4.10	1	1	0
01/20/2022 13:00	1.1	13.9	1,376.3	0.9	4.10	1	1	0
01/20/2022 14:00	1.1	13.9	1,379.9	0.9	4.10	1	1	0
01/20/2022 15:00	1.1	13.9	1,382.6	0.9	4.10	1	1	0
01/20/2022 16:00	1.2	13.7	1,712.2	1.0	6.80	1	1	0
01/20/2022 17:00	1.1	13.8	1,531.9	0.9	4.60	1	1	0
01/20/2022 18:00	1.1	13.8	1,622.8	0.9	4.90	1	1	0
01/20/2022 19:00	1.2	13.7	1,728.0	1.0	6.90	1	1	1
01/20/2022 20:00	1.3	12.8	2,029.0	0.9	6.10	1	1	1
01/20/2022 21:00	1.3	12.8	2,031.2	0.9	6.10	1	1	1
01/20/2022 22:00	1.3	12.6	2,065.1	0.9	6.20	1	1	1
01/20/2022 23:00	1.7	14.2	1,247.7	1.5	6.15	1	0	1
Average/Sum#:	1.2	13.6	1,626.1	0.9	126.45 #	24 #	23 #	11 #
Minimum:	1.1	12.6	1,247.7	0.9	3.90	1	0	0
Maximum:	1.7	14.2	2,065.1	1.5	8.00	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:22 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/21/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/21/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/21/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/21/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/21/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/21/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/21/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/21/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/21/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/21/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/21/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/21/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/21/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/21/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/21/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/21/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/21/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/21/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/21/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/21/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/21/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/21/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/21/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/21/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:22 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/22/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/22/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/22/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/22/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/22/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/22/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/22/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/22/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/22/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/22/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/22/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/22/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/22/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/22/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/22/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/22/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/22/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/22/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/22/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/22/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/22/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/22/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/22/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/22/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:22 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/23/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/23/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/23/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/23/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/23/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/23/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/23/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/23/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/23/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/23/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/23/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/23/2022 11:00	34.6	17.6	323.4	61.9	55.28	1	0	0
01/23/2022 12:00	14.8	17.2	383.6	23.6	33.40	1	0	0
01/23/2022 13:00	16.4	15.6	810.3	18.3	54.30	1	0	0
01/23/2022 14:00	1.0	13.9	1,420.3	0.8	4.30	1	1	0
01/23/2022 15:00	1.1	13.9	1,380.4	0.9	4.10	1	1	0
01/23/2022 16:00	1.1	13.8	1,630.1	0.9	4.90	1	1	0
01/23/2022 17:00	1.1	13.9	1,605.7	0.9	4.80	1	1	0
01/23/2022 18:00	1.1	13.7	1,776.1	0.9	5.30	1	1	1
01/23/2022 19:00	1.3	13.0	1,986.4	1.0	7.90	1	1	1
01/23/2022 20:00	1.3	12.6	2,083.5	0.9	6.30	1	1	1
01/23/2022 21:00	1.3	12.7	2,049.0	0.9	6.10	1	1	1
01/23/2022 22:00	1.2	13.0	2,006.0	0.9	6.00	1	1	1
01/23/2022 23:00	2.1	14.4	1,211.0	1.9	4.08	1	0	1
Average/Sum#:	6.0	14.3	1,435.8	8.8	196.76 #	13 #	9 #	6 #
Minimum:	1.0	12.6	323.4	0.8	4.08	0	0	0
Maximum:	34.6	17.6	2,083.5	61.9	55.28	1	1	1
%SI	45.83	45.83	45.83	45.83	45.83	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:22 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/24/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/24/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/24/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/24/2022 03:00	0.6	18.7	215.0	1.6	0.23	1	0	0
01/24/2022 04:00	8.1	15.6	843.4	9.0	27.80	1	0	0
01/24/2022 05:00	1.1	13.8	1,526.6	0.9	4.60	1	1	1
01/24/2022 06:00	1.3	12.7	2,085.9	0.9	6.30	1	1	1
01/24/2022 07:00	1.3	12.3	2,171.9	0.9	6.50	1	1	1
01/24/2022 08:00	1.2	13.3	1,836.4	0.9	5.50	1	1	1
01/24/2022 09:00	1.1	13.8	1,379.1	0.9	4.10	1	1	0
01/24/2022 10:00	1.1	13.8	1,373.4	0.9	4.10	1	1	0
01/24/2022 11:00	1.1	13.8	1,362.9	0.9	4.10	1	1	0
01/24/2022 12:00	1.1	13.8	1,375.1	0.9	4.10	1	1	0
01/24/2022 13:00	1.1	13.8	1,379.0	0.9	4.10	1	1	0
01/24/2022 14:00	1.2	13.7	1,756.9	1.0	7.00	1	1	0
01/24/2022 15:00	1.1	13.8	1,466.0	0.9	4.40	1	1	0
01/24/2022 16:00	1.1	13.8	1,667.8	0.9	5.00	1	1	0
01/24/2022 17:00	1.1	13.7	1,665.4	0.9	5.00	1	1	1
01/24/2022 18:00	1.3	12.9	1,995.1	1.0	8.00	1	1	1
01/24/2022 19:00	1.3	12.6	2,069.6	0.9	6.20	1	1	1
01/24/2022 20:00	1.3	12.9	1,971.2	1.0	7.90	1	1	1
01/24/2022 21:00	1.1	13.8	1,631.0	0.9	4.90	1	1	0
01/24/2022 22:00	1.1	13.7	1,753.1	0.9	5.30	1	1	1
01/24/2022 23:00	1.3	12.9	2,002.0	1.0	8.00	1	1	1
Average/Sum#:	1.5	13.8	1,596.5	1.3	133.13 #	21 #	19 #	10 #
Minimum:	0.6	12.3	215.0	0.9	0.23	0	0	0
Maximum:	8.1	18.7	2,171.9	9.0	27.80	1	1	1
%SI	12.50	12.50	12.50	12.50	12.50	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:22 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/25/2022 00:00	1.2	13.1	1,943.4	0.9	5.80	1	1	1
01/25/2022 01:00	1.1	13.8	1,573.3	0.9	4.70	1	1	0
01/25/2022 02:00	1.1	13.7	1,681.9	0.9	5.00	1	1	1
01/25/2022 03:00	1.2	13.1	1,975.6	0.9	5.90	1	1	1
01/25/2022 04:00	1.2	13.1	1,954.3	0.9	5.90	1	1	1
01/25/2022 05:00	1.1	13.8	1,674.2	0.9	5.00	1	1	0
01/25/2022 06:00	1.1	13.7	1,785.7	0.9	5.40	1	1	1
01/25/2022 07:00	1.3	12.9	2,039.5	1.0	8.20	1	1	1
01/25/2022 08:00	2.2	13.6	1,525.7	1.8	8.03	1	0	1
01/25/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/25/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/25/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/25/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/25/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/25/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/25/2022 15:00	12.9	17.9	311.7	25.4	13.63	1	0	0
01/25/2022 16:00	9.9	15.5	946.6	10.8	37.90	1	0	0
01/25/2022 17:00	1.1	13.8	1,672.8	0.9	5.00	1	1	0
01/25/2022 18:00	1.1	13.7	1,744.2	0.9	5.20	1	1	0
01/25/2022 19:00	1.2	13.1	1,933.7	0.9	5.80	1	1	1
01/25/2022 20:00	1.3	13.1	1,942.8	1.0	7.80	1	1	1
01/25/2022 21:00	1.1	13.9	1,546.2	0.9	4.60	1	1	0
01/25/2022 22:00	1.1	13.7	1,719.8	0.9	5.20	1	1	1
01/25/2022 23:00	1.2	13.2	1,963.8	0.9	5.90	1	1	1
Average/Sum#:	2.4	13.8	1,663.1	2.9	144.96 #	18 #	15 #	11 #
Minimum:	1.1	12.9	311.7	0.9	4.60	0	0	0
Maximum:	12.9	17.9	2,039.5	25.4	37.90	1	1	1
%SI	25.00	25.00	25.00	25.00	25.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:22 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit	> Limit	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT1	Unit CT1	UnitOn, TF	NormalOp, TF	Unit CT1
	1 Hour(s)	1 Hour(s)	1 Hour(s)	NOx, Ppmvdc	NOx, Lb	1 Hour(s)	1 Hour(s)	DBOn, TF
				1 Hour(s)	1 Hour(s)			1 Hour(s)
01/26/2022 00:00	1.2	13.1	1,973.5	0.9	5.90	1	1	1
01/26/2022 01:00	1.1	13.8	1,715.3	0.9	5.10	1	1	0
01/26/2022 02:00	1.1	13.8	1,718.2	0.9	5.20	1	1	1
01/26/2022 03:00	1.2	13.1	2,004.0	0.9	6.00	1	1	1
01/26/2022 04:00	1.3	13.1	1,996.1	1.0	8.00	1	1	1
01/26/2022 05:00	1.1	13.8	1,604.8	0.9	4.80	1	1	0
01/26/2022 06:00	1.1	13.8	1,819.7	0.9	5.50	1	1	1
01/26/2022 07:00	1.2	13.0	2,013.8	0.9	6.00	1	1	1
01/26/2022 08:00	2.2	14.0	1,471.0	1.9	7.52	1	0	1
01/26/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/26/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/26/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/26/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/26/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/26/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/26/2022 15:00	7.6	17.9	322.6	14.9	8.32	1	0	0
01/26/2022 16:00	8.6	15.5	945.8	9.4	33.10	1	0	0
01/26/2022 17:00	1.1	13.8	1,718.2	0.9	5.20	1	1	0
01/26/2022 18:00	1.2	13.7	1,821.3	1.0	7.30	1	1	0
01/26/2022 19:00	1.2	13.1	1,939.8	0.9	5.80	1	1	1
01/26/2022 20:00	1.3	12.7	2,033.8	0.9	6.10	1	1	1
01/26/2022 21:00	1.1	13.8	1,691.2	0.9	5.10	1	1	0
01/26/2022 22:00	1.1	13.8	1,809.5	0.9	5.40	1	1	0
01/26/2022 23:00	1.3	13.0	2,021.0	1.0	8.10	1	1	1
Average/Sum#:	2.0	13.8	1,701.1	2.2	138.44 #	18 #	15 #	10 #
Minimum:	1.1	12.7	322.6	0.9	4.80	0	0	0
Maximum:	8.6	17.9	2,033.8	14.9	33.10	1	1	1
%SI	25.00	25.00	25.00	25.00	25.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:22 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/27/2022 00:00	1.2	13.1	1,983.2	0.9	5.90	1	1	1
01/27/2022 01:00	1.1	13.8	1,538.6	0.9	4.60	1	1	1
01/27/2022 02:00	1.1	13.8	1,717.6	0.9	5.20	1	1	0
01/27/2022 03:00	1.2	13.2	1,962.9	0.9	5.90	1	1	1
01/27/2022 04:00	1.2	13.2	1,962.5	0.9	5.90	1	1	1
01/27/2022 05:00	1.0	13.8	1,599.2	0.8	4.80	1	1	0
01/27/2022 06:00	1.2	13.3	1,880.6	0.9	5.60	1	1	1
01/27/2022 07:00	1.3	12.9	2,035.5	1.0	8.10	1	1	1
01/27/2022 08:00	1.2	13.1	1,986.8	0.9	6.00	1	1	1
01/27/2022 09:00	1.2	13.5	1,695.4	1.0	6.80	1	1	1
01/27/2022 10:00	2.7	14.9	905.9	2.7	3.91	1	0	0
01/27/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/27/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/27/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/27/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/27/2022 15:00	6.5	17.9	320.2	12.8	7.05	1	0	0
01/27/2022 16:00	7.9	15.5	951.2	8.6	30.40	1	0	0
01/27/2022 17:00	1.1	13.9	1,542.4	0.9	4.60	1	1	0
01/27/2022 18:00	1.2	13.7	1,818.1	1.0	7.30	1	1	1
01/27/2022 19:00	1.3	12.8	2,026.7	0.9	6.10	1	1	1
01/27/2022 20:00	1.3	12.9	2,002.8	1.0	8.00	1	1	1
01/27/2022 21:00	1.1	13.8	1,695.8	0.9	5.10	1	1	0
01/27/2022 22:00	1.1	13.9	1,493.0	0.9	4.50	1	1	0
01/27/2022 23:00	1.2	13.3	1,930.5	0.9	5.80	1	1	1
Average/Sum#:	1.9	13.8	1,652.4	2.0	141.56 #	20 #	17 #	12 #
Minimum:	1.0	12.8	320.2	0.8	3.91	0	0	0
Maximum:	7.9	17.9	2,035.5	12.8	30.40	1	1	1
%SI	16.67	16.67	16.67	16.67	16.67	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:22 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit	> Limit	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT1	Unit CT1	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	NOx, Ppmvdc	NOx, Lb	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/28/2022 00:00	1.3	12.8	2,069.1	0.9	6.20	1	1	1
01/28/2022 01:00	1.3	12.7	2,058.1	0.9	6.20	1	1	1
01/28/2022 02:00	1.1	13.8	1,523.3	0.9	4.60	1	1	1
01/28/2022 03:00	1.1	13.8	1,537.5	0.9	4.60	1	1	0
01/28/2022 04:00	1.1	13.8	1,780.1	0.9	5.30	1	1	1
01/28/2022 05:00	1.1	13.0	2,014.7	0.8	6.00	1	1	1
01/28/2022 06:00	1.3	12.5	2,141.5	0.9	6.40	1	1	1
01/28/2022 07:00	1.3	12.5	2,126.0	0.9	6.40	1	1	1
01/28/2022 08:00	1.3	13.1	1,986.2	1.0	7.90	1	1	1
01/28/2022 09:00	1.1	13.9	1,542.1	0.9	4.60	1	1	0
01/28/2022 10:00	1.1	13.9	1,435.9	0.9	4.30	1	1	0
01/28/2022 11:00	1.1	13.9	1,506.9	0.9	4.50	1	1	0
01/28/2022 12:00	1.1	13.9	1,466.5	0.9	4.40	1	1	0
01/28/2022 13:00	1.1	13.9	1,448.2	0.9	4.30	1	1	0
01/28/2022 14:00	1.1	13.9	1,649.6	0.9	4.90	1	1	0
01/28/2022 15:00	1.1	13.9	1,573.8	0.9	4.70	1	1	0
01/28/2022 16:00	1.1	13.8	1,613.2	0.9	4.80	1	1	1
01/28/2022 17:00	1.2	13.2	1,937.0	0.9	5.80	1	1	1
01/28/2022 18:00	1.3	12.7	2,053.4	0.9	6.20	1	1	1
01/28/2022 19:00	1.4	12.2	2,168.5	0.9	6.50	1	1	1
01/28/2022 20:00	1.3	12.4	2,086.6	0.9	6.30	1	1	1
01/28/2022 21:00	1.1	13.9	1,544.3	0.9	4.60	1	1	0
01/28/2022 22:00	1.1	13.8	1,825.6	0.9	5.50	1	1	1
01/28/2022 23:00	1.2	13.0	1,998.7	0.9	6.00	1	1	1
Average/Sum#:	1.2	13.3	1,795.3	0.9	131.00 #	24 #	24 #	15 #
Minimum:	1.1	12.2	1,435.9	0.8	4.30	1	1	0
Maximum:	1.4	13.9	2,168.5	1.0	7.90	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:22 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit	> Limit	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT1	Unit CT1	UnitOn, TF	NormalOp, TF	Unit CT1
	1 Hour(s)	1 Hour(s)	1 Hour(s)	NOx, Ppmvdc	NOx, Lb	1 Hour(s)	1 Hour(s)	DBOn, TF
				1 Hour(s)	1 Hour(s)			1 Hour(s)
01/29/2022 00:00	1.2	13.2	1,944.2	0.9	5.80	1	1	1
01/29/2022 01:00	1.1	13.8	1,588.8	0.9	4.80	1	1	0
01/29/2022 02:00	0.8	13.8	1,599.6	0.7	3.20	1	1	1
01/29/2022 03:00	0.9	13.2	1,965.0	0.7	5.90	1	1	1
01/29/2022 04:00	0.9	13.2	1,946.9	0.7	5.80	1	1	1
01/29/2022 05:00	1.1	13.8	1,624.7	0.9	4.90	1	1	0
01/29/2022 06:00	1.0	13.8	1,644.8	0.8	4.90	1	1	1
01/29/2022 07:00	1.3	13.1	2,016.6	1.0	8.10	1	1	1
01/29/2022 08:00	1.3	12.9	2,061.6	1.0	8.20	1	1	1
01/29/2022 09:00	1.2	13.2	1,950.5	0.9	5.90	1	1	1
01/29/2022 10:00	1.1	13.9	1,422.6	0.9	4.30	1	1	0
01/29/2022 11:00	1.1	13.9	1,541.2	0.9	4.60	1	1	0
01/29/2022 12:00	1.1	13.9	1,389.9	0.9	4.20	1	1	0
01/29/2022 13:00	1.1	13.9	1,411.8	0.9	4.20	1	1	0
01/29/2022 14:00	1.1	13.9	1,626.6	0.9	4.90	1	1	0
01/29/2022 15:00	1.1	13.9	1,393.9	0.9	4.20	1	1	0
01/29/2022 16:00	1.1	13.9	1,607.4	0.9	4.80	1	1	0
01/29/2022 17:00	1.1	13.8	1,636.3	0.9	4.90	1	1	0
01/29/2022 18:00	1.2	13.4	1,825.0	0.9	5.50	1	1	1
01/29/2022 19:00	1.2	13.0	1,901.9	0.9	5.70	1	1	1
01/29/2022 20:00	1.1	13.8	1,806.0	0.9	5.40	1	1	1
01/29/2022 21:00	1.3	12.8	2,037.9	0.9	6.10	1	1	1
01/29/2022 22:00	1.3	12.3	2,128.6	0.9	6.40	1	1	1
01/29/2022 23:00	1.2	13.3	1,856.3	0.9	5.60	1	1	1
Average/Sum#:	1.1	13.5	1,747.0	0.9	128.30 #	24 #	24 #	14 #
Minimum:	0.8	12.3	1,389.9	0.7	3.20	1	1	0
Maximum:	1.3	13.9	2,128.6	1.0	8.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:22 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/30/2022 00:00	1.1	13.8	1,609.1	0.9	4.80	1	1	0
01/30/2022 01:00	1.1	13.9	1,401.1	0.9	4.20	1	1	0
01/30/2022 02:00	1.1	13.8	1,756.1	0.9	5.30	1	1	0
01/30/2022 03:00	1.2	13.4	1,887.8	0.9	5.70	1	1	1
01/30/2022 04:00	1.2	13.3	1,868.6	0.9	5.60	1	1	1
01/30/2022 05:00	1.2	13.8	1,626.7	1.0	6.50	1	1	1
01/30/2022 06:00	1.2	13.0	2,023.2	0.9	6.10	1	1	1
01/30/2022 07:00	1.8	13.7	1,536.4	1.5	5.93	1	0	1
01/30/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/30/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/30/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/30/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/30/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/30/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/30/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/30/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/30/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/30/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/30/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/30/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/30/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/30/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/30/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/30/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	1.2	13.6	1,713.6	1.0	44.13 #	8 #	7 #	5 #
Minimum:	1.1	13.0	1,401.1	0.9	4.20	0	0	0
Maximum:	1.8	13.9	2,023.2	1.5	6.50	1	1	1
%SI	66.67	66.67	66.67	66.67	66.67	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:22 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit	> Limit	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT1	Unit CT1	UnitOn, TF	NormalOp, TF	Unit CT1
	1 Hour(s)	1 Hour(s)	1 Hour(s)	NOx, Ppmvdc	NOx, Lb	1 Hour(s)	1 Hour(s)	DBOn, TF
				1 Hour(s)	1 Hour(s)			1 Hour(s)
01/31/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/31/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/31/2022 02:00	31.7	17.6	342.8	56.7	51.55	1	0	0
01/31/2022 03:00	11.6	15.5	865.7	12.7	40.70	1	0	0
01/31/2022 04:00	1.1	13.8	1,487.4	0.9	4.50	1	1	0
01/31/2022 05:00	1.1	13.8	1,606.4	0.9	4.80	1	1	1
01/31/2022 06:00	1.3	13.0	1,991.1	1.0	8.00	1	1	1
01/31/2022 07:00	1.2	12.9	2,064.8	0.9	6.20	1	1	1
01/31/2022 08:00	1.2	13.2	1,960.7	0.9	5.90	1	1	1
01/31/2022 09:00	1.1	13.8	1,610.1	0.9	4.80	1	1	1
01/31/2022 10:00	1.1	13.8	1,490.7	0.9	4.50	1	1	0
01/31/2022 11:00	1.1	13.8	1,563.0	0.9	4.70	1	1	0
01/31/2022 12:00	1.1	13.8	1,600.6	0.9	4.80	1	1	0
01/31/2022 13:00	1.1	13.9	1,442.8	0.9	4.30	1	1	0
01/31/2022 14:00	1.1	13.9	1,561.2	0.9	4.70	1	1	0
01/31/2022 15:00	1.2	13.7	1,659.5	1.0	6.60	1	1	1
01/31/2022 16:00	1.3	12.8	2,010.2	0.9	6.00	1	1	1
01/31/2022 17:00	1.3	12.4	2,118.2	0.9	6.40	1	1	1
01/31/2022 18:00	1.3	12.4	2,120.0	0.9	6.40	1	1	1
01/31/2022 19:00	1.2	13.1	1,938.8	0.9	5.80	1	1	1
01/31/2022 20:00	1.1	13.8	1,615.9	0.9	4.80	1	1	0
01/31/2022 21:00	1.1	13.8	1,688.6	0.9	5.10	1	1	1
01/31/2022 22:00	1.3	12.9	2,010.8	1.0	8.00	1	1	1
01/31/2022 23:00	2.2	14.3	1,222.7	2.0	4.13	1	0	1
Average/Sum#:	3.1	13.7	1,635.1	4.0	202.68 #	22 #	19 #	13 #
Minimum:	1.1	12.4	342.8	0.9	4.13	0	0	0
Maximum:	31.7	17.6	2,120.0	56.7	51.55	1	1	1
%SI	8.33	8.33	8.33	8.33	8.33	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:22 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/01/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/01/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/01/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/01/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/01/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/01/2022 05:00	13.8	16.6	465.6	18.9	28.69	1	0	0
02/01/2022 06:00	9.4	14.5	1,134.6	8.7	36.30	1	0	0
02/01/2022 07:00	1.2	13.1	1,674.3	0.9	5.00	1	1	1
02/01/2022 08:00	1.4	11.6	2,360.2	0.9	7.10	1	1	1
02/01/2022 09:00	1.4	11.5	2,355.4	0.9	7.10	1	1	1
02/01/2022 10:00	1.2	13.5	1,868.7	1.0	7.50	1	1	1
02/01/2022 11:00	1.1	13.9	1,569.3	0.9	4.70	1	1	0
02/01/2022 12:00	1.1	13.9	1,312.6	0.9	3.90	1	1	0
02/01/2022 13:00	1.1	13.9	1,312.2	0.9	3.90	1	1	0
02/01/2022 14:00	1.1	13.9	1,313.0	0.9	3.90	1	1	0
02/01/2022 15:00	1.1	13.9	1,335.2	0.9	4.00	1	1	0
02/01/2022 16:00	1.1	13.9	1,559.0	0.9	4.70	1	1	0
02/01/2022 17:00	1.1	13.8	1,818.8	0.9	5.50	1	1	0
02/01/2022 18:00	1.2	13.2	1,951.6	0.9	5.90	1	1	1
02/01/2022 19:00	1.3	12.8	2,058.6	0.9	6.20	1	1	1
02/01/2022 20:00	1.3	12.9	2,005.4	1.0	8.00	1	1	1
02/01/2022 21:00	1.1	13.8	1,615.2	0.9	4.80	1	1	0
02/01/2022 22:00	1.1	13.8	1,798.8	0.9	5.40	1	1	1
02/01/2022 23:00	1.3	12.9	2,049.6	1.0	8.20	1	1	1
Average/Sum#:	2.3	13.5	1,661.0	2.3	160.79 #	19 #	17 #	9 #
Minimum:	1.1	11.5	465.6	0.9	3.90	0	0	0
Maximum:	13.8	16.6	2,360.2	18.9	36.30	1	1	1
%SI	20.83	20.83	20.83	20.83	20.83	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:22 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/02/2022 00:00	1.4	12.2	2,195.1	0.9	6.60	1	1	1
02/02/2022 01:00	1.1	13.7	1,750.9	0.9	5.30	1	1	1
02/02/2022 02:00	1.1	13.8	1,609.1	0.9	4.80	1	1	1
02/02/2022 03:00	1.3	13.0	2,029.7	1.0	8.10	1	1	1
02/02/2022 04:00	1.2	13.1	1,996.9	0.9	6.00	1	1	1
02/02/2022 05:00	1.1	12.8	2,053.5	0.8	6.20	1	1	1
02/02/2022 06:00	1.3	12.7	2,114.5	0.9	6.30	1	1	1
02/02/2022 07:00	1.3	12.8	2,069.7	0.9	6.20	1	1	1
02/02/2022 08:00	1.3	13.0	2,038.4	1.0	8.20	1	1	1
02/02/2022 09:00	1.1	13.6	1,675.6	0.9	5.00	1	1	1
02/02/2022 10:00	2.8	14.9	907.4	2.8	3.82	1	0	0
02/02/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/02/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/02/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/02/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/02/2022 15:00	1.5	18.7	213.6	4.0	0.74	1	0	0
02/02/2022 16:00	15.6	15.9	707.7	18.4	48.10	1	0	0
02/02/2022 17:00	1.0	13.7	1,727.8	0.8	5.20	1	0	1
02/02/2022 18:00	1.3	12.7	2,083.0	0.9	6.20	1	1	1
02/02/2022 19:00	1.4	11.9	2,264.5	0.9	6.80	1	1	1
02/02/2022 20:00	1.4	11.8	2,275.1	0.9	6.80	1	1	1
02/02/2022 21:00	1.4	12.1	2,191.9	0.9	6.60	1	1	1
02/02/2022 22:00	1.3	12.5	2,093.8	0.9	6.30	1	1	1
02/02/2022 23:00	1.3	12.7	2,063.8	0.9	6.20	1	1	1
Average/Sum#:	2.1	13.4	1,803.1	2.0	159.46 #	20 #	16 #	17 #
Minimum:	1.0	11.8	213.6	0.8	0.74	0	0	0
Maximum:	15.6	18.7	2,275.1	18.4	48.10	1	1	1
%SI	16.67	16.67	16.67	16.67	16.67	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:22 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit	> Limit	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT1	Unit CT1	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	NOx, Ppmvdc	NOx, Lb	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/03/2022 00:00	1.2	13.2	1,946.0	0.9	5.80	1	1	1
02/03/2022 01:00	1.1	13.8	1,686.6	0.9	5.10	1	1	0
02/03/2022 02:00	1.1	13.8	1,817.8	0.9	5.50	1	1	1
02/03/2022 03:00	1.3	12.8	2,041.4	0.9	6.10	1	1	1
02/03/2022 04:00	1.3	12.9	2,021.0	1.0	8.10	1	1	1
02/03/2022 05:00	1.4	12.8	2,031.6	1.0	8.10	1	1	1
02/03/2022 06:00	1.3	12.3	2,185.2	0.9	6.60	1	1	1
02/03/2022 07:00	1.3	12.5	2,127.9	0.9	6.40	1	1	1
02/03/2022 08:00	1.2	13.2	1,953.7	0.9	5.90	1	1	1
02/03/2022 09:00	1.1	13.8	1,477.4	0.9	4.40	1	1	1
02/03/2022 10:00	1.1	13.8	1,689.7	0.9	5.10	1	1	0
02/03/2022 11:00	1.1	13.8	1,695.7	0.9	5.10	1	1	0
02/03/2022 12:00	1.1	13.9	1,405.6	0.9	4.20	1	1	0
02/03/2022 13:00	1.1	13.9	1,574.3	0.9	4.70	1	1	0
02/03/2022 14:00	1.1	13.9	1,494.0	0.9	4.50	1	1	0
02/03/2022 15:00	1.1	13.8	1,555.7	0.9	4.70	1	1	1
02/03/2022 16:00	1.3	12.8	2,008.0	0.9	6.00	1	1	1
02/03/2022 17:00	1.3	12.4	2,098.2	0.9	6.30	1	1	1
02/03/2022 18:00	1.4	12.3	2,148.2	1.0	8.60	1	1	1
02/03/2022 19:00	1.4	12.3	2,151.2	1.0	8.60	1	1	1
02/03/2022 20:00	1.4	12.3	2,153.7	1.0	8.60	1	1	1
02/03/2022 21:00	1.4	12.0	2,215.7	0.9	6.60	1	1	1
02/03/2022 22:00	1.3	12.4	2,126.4	0.9	6.40	1	1	1
02/03/2022 23:00	1.3	12.5	2,101.7	0.9	6.30	1	1	1
Average/Sum#:	1.2	13.1	1,904.4	0.9	147.70 #	24 #	24 #	18 #
Minimum:	1.1	12.0	1,405.6	0.9	4.20	1	1	0
Maximum:	1.4	13.9	2,215.7	1.0	8.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:22 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/04/2022 00:00	1.3	12.7	2,062.4	0.9	6.20	1	1	1
02/04/2022 01:00	1.2	13.2	1,939.9	0.9	5.80	1	1	1
02/04/2022 02:00	1.1	13.8	1,629.5	0.9	4.90	1	1	0
02/04/2022 03:00	1.1	13.8	1,557.9	0.9	4.70	1	1	0
02/04/2022 04:00	1.1	13.8	1,618.4	0.9	4.90	1	1	1
02/04/2022 05:00	1.3	12.8	2,032.7	0.9	6.10	1	1	1
02/04/2022 06:00	1.4	12.2	2,194.2	0.9	6.60	1	1	1
02/04/2022 07:00	1.3	12.6	2,098.0	0.9	6.30	1	1	1
02/04/2022 08:00	2.6	14.6	1,200.8	2.4	5.18	1	0	1
02/04/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/04/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/04/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/04/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/04/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/04/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/04/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/04/2022 16:00	19.5	16.3	627.0	25.0	57.70	1	0	0
02/04/2022 17:00	4.5	14.0	1,550.1	3.8	21.70	1	0	0
02/04/2022 18:00	1.1	13.9	1,487.3	0.9	4.50	1	1	0
02/04/2022 19:00	1.2	13.2	1,909.6	0.9	5.70	1	1	1
02/04/2022 20:00	1.3	13.1	1,952.9	1.0	7.80	1	1	1
02/04/2022 21:00	1.2	13.2	1,948.3	0.9	5.80	1	1	1
02/04/2022 22:00	1.2	13.1	1,975.5	0.9	5.90	1	1	1
02/04/2022 23:00	1.3	12.7	2,055.7	0.9	6.20	1	1	1
Average/Sum#:	2.6	13.5	1,755.3	2.6	165.98 #	17 #	14 #	12 #
Minimum:	1.1	12.2	627.0	0.9	4.50	0	0	0
Maximum:	19.5	16.3	2,194.2	25.0	57.70	1	1	1
%SI	29.17	29.17	29.17	29.17	29.17	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:22 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/05/2022 00:00	1.2	13.2	1,952.1	0.9	5.90	1	1	1
02/05/2022 01:00	1.2	13.7	1,719.6	1.0	6.90	1	1	1
02/05/2022 02:00	1.1	13.9	1,425.1	0.9	4.30	1	1	0
02/05/2022 03:00	1.2	13.3	1,917.8	0.9	5.80	1	1	1
02/05/2022 04:00	1.2	13.2	1,962.5	0.9	5.90	1	1	1
02/05/2022 05:00	1.1	13.8	1,738.0	0.9	5.20	1	1	1
02/05/2022 06:00	1.1	13.8	1,621.4	0.9	4.90	1	1	1
02/05/2022 07:00	1.3	12.8	2,041.6	0.9	6.10	1	1	1
02/05/2022 08:00	2.3	14.4	1,233.2	2.1	4.95	1	0	1
02/05/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/05/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/05/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/05/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/05/2022 13:00	4.8	18.1	294.9	10.1	4.14	1	0	0
02/05/2022 14:00	13.4	15.5	856.7	14.6	46.30	1	0	0
02/05/2022 15:00	1.1	13.9	1,374.8	0.9	4.10	1	1	0
02/05/2022 16:00	1.1	13.9	1,430.8	0.9	4.30	1	1	0
02/05/2022 17:00	1.1	13.8	1,622.3	0.9	4.90	1	1	0
02/05/2022 18:00	1.1	13.8	1,609.8	0.9	4.80	1	1	0
02/05/2022 19:00	1.1	14.0	1,319.6	0.9	4.00	1	1	0
02/05/2022 20:00	1.1	13.8	1,573.5	0.9	4.70	1	1	1
02/05/2022 21:00	1.3	12.7	2,038.2	0.9	6.10	1	1	1
02/05/2022 22:00	1.3	12.7	2,054.3	0.9	6.20	1	1	1
02/05/2022 23:00	1.3	12.7	2,061.0	0.9	6.20	1	1	1
Average/Sum#:	2.0	13.9	1,592.4	2.1	145.69 #	20 #	17 #	12 #
Minimum:	1.1	12.7	294.9	0.9	4.00	0	0	0
Maximum:	13.4	18.1	2,061.0	14.6	46.30	1	1	1
%SI	16.67	16.67	16.67	16.67	16.67	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:22 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/06/2022 00:00	1.2	13.2	1,947.5	0.9	5.80	1	1	1
02/06/2022 01:00	1.1	13.8	1,698.0	0.9	5.10	1	1	1
02/06/2022 02:00	1.1	13.8	1,639.8	0.9	4.90	1	1	1
02/06/2022 03:00	1.3	12.9	2,015.1	1.0	8.10	1	1	1
02/06/2022 04:00	1.2	13.2	1,943.3	0.9	5.80	1	1	1
02/06/2022 05:00	1.1	13.8	1,585.3	0.9	4.80	1	1	0
02/06/2022 06:00	1.1	13.9	1,333.8	0.9	4.00	1	1	0
02/06/2022 07:00	1.1	13.8	1,573.7	0.9	4.70	1	1	0
02/06/2022 08:00	4.3	15.9	468.5	5.1	1.60	1	0	0
02/06/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/06/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/06/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/06/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/06/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/06/2022 14:00	6.5	17.9	314.7	12.8	6.66	1	0	0
02/06/2022 15:00	12.2	15.5	848.0	13.3	41.60	1	0	0
02/06/2022 16:00	1.1	13.9	1,398.6	0.9	4.20	1	1	0
02/06/2022 17:00	1.3	13.2	1,882.9	1.0	7.50	1	1	1
02/06/2022 18:00	1.3	13.0	1,945.2	1.0	7.80	1	1	1
02/06/2022 19:00	1.3	13.1	1,944.8	1.0	7.80	1	1	1
02/06/2022 20:00	1.2	13.1	1,943.8	0.9	5.80	1	1	1
02/06/2022 21:00	1.2	13.1	1,933.6	0.9	5.80	1	1	1
02/06/2022 22:00	1.2	13.8	1,659.3	1.0	6.60	1	1	0
02/06/2022 23:00	3.5	16.1	421.3	4.3	1.21	1	0	0
Average/Sum#:	2.3	14.1	1,499.9	2.6	139.77 #	19 #	15 #	10 #
Minimum:	1.1	12.9	314.7	0.9	1.21	0	0	0
Maximum:	12.2	17.9	2,015.1	13.3	41.60	1	1	1
%SI	20.83	20.83	20.83	20.83	20.83	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:22 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/07/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/07/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/07/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/07/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/07/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/07/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/07/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/07/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/07/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/07/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/07/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/07/2022 11:00	24.6	17.9	291.8	48.4	36.33	1	0	0
02/07/2022 12:00	6.5	17.5	332.8	11.3	14.00	1	0	0
02/07/2022 13:00	10.7	15.7	796.3	12.1	35.80	1	0	0
02/07/2022 14:00	1.1	13.9	1,385.1	0.9	4.20	1	1	0
02/07/2022 15:00	1.1	13.9	1,384.8	0.9	4.20	1	1	0
02/07/2022 16:00	1.2	13.7	1,656.0	1.0	6.60	1	1	0
02/07/2022 17:00	1.1	13.9	1,583.3	0.9	4.70	1	1	0
02/07/2022 18:00	1.1	13.9	1,422.9	0.9	4.30	1	1	0
02/07/2022 19:00	1.1	13.8	1,596.4	0.9	4.80	1	1	1
02/07/2022 20:00	1.3	12.6	2,078.8	0.9	6.20	1	1	1
02/07/2022 21:00	1.3	12.5	2,103.3	0.9	6.30	1	1	1
02/07/2022 22:00	1.3	12.6	2,089.7	0.9	6.30	1	1	1
02/07/2022 23:00	2.2	14.3	1,231.5	2.0	4.13	1	0	1
Average/Sum#:	4.2	14.3	1,381.0	6.3	137.86 #	13 #	9 #	5 #
Minimum:	1.1	12.5	291.8	0.9	4.13	0	0	0
Maximum:	24.6	17.9	2,103.3	48.4	36.33	1	1	1
%SI	45.83	45.83	45.83	45.83	45.83	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:22 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/08/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/08/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/08/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/08/2022 03:00	3.3	17.7	359.4	6.1	5.53	1	0	0
02/08/2022 04:00	5.9	14.5	1,227.9	5.4	24.60	1	0	0
02/08/2022 05:00	1.1	13.9	1,408.0	0.9	4.20	1	1	0
02/08/2022 06:00	1.0	13.9	1,399.1	0.8	4.20	1	1	0
02/08/2022 07:00	1.1	13.9	1,297.0	0.9	3.90	1	1	0
02/08/2022 08:00	1.3	13.8	1,823.6	1.1	7.30	1	1	0
02/08/2022 09:00	1.2	13.7	1,842.9	1.0	7.40	1	1	0
02/08/2022 10:00	1.2	13.7	1,843.3	1.0	7.40	1	1	0
02/08/2022 11:00	1.2	13.7	1,841.3	1.0	7.40	1	1	0
02/08/2022 12:00	1.2	13.6	1,853.5	1.0	7.40	1	1	0
02/08/2022 13:00	1.2	13.6	1,854.8	1.0	7.40	1	1	0
02/08/2022 14:00	1.2	13.6	1,856.2	1.0	7.40	1	1	0
02/08/2022 15:00	1.2	13.7	1,830.2	1.0	7.30	1	1	0
02/08/2022 16:00	1.2	13.7	1,825.9	1.0	7.30	1	1	0
02/08/2022 17:00	1.2	13.2	1,939.9	0.9	5.80	1	1	1
02/08/2022 18:00	1.3	12.9	2,018.1	1.0	8.10	1	1	1
02/08/2022 19:00	1.3	13.1	1,983.1	1.0	7.90	1	1	1
02/08/2022 20:00	1.3	13.1	1,990.6	1.0	8.00	1	1	1
02/08/2022 21:00	1.2	13.5	1,719.2	1.0	6.90	1	1	1
02/08/2022 22:00	1.1	13.9	1,427.9	0.9	4.30	1	1	0
02/08/2022 23:00	1.1	13.9	1,385.9	0.9	4.20	1	1	0
Average/Sum#:	1.5	13.8	1,653.7	1.4	153.93 #	21 #	19 #	5 #
Minimum:	1.0	12.9	359.4	0.8	3.90	0	0	0
Maximum:	5.9	17.7	2,018.1	6.1	24.60	1	1	1
%SI	12.50	12.50	12.50	12.50	12.50	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:22 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit	> Limit	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT1	Unit CT1	UnitOn, TF	NormalOp, TF	Unit CT1
	1 Hour(s)	1 Hour(s)	1 Hour(s)	NOx, Ppmvdc	NOx, Lb	1 Hour(s)	1 Hour(s)	DBOn, TF
				1 Hour(s)	1 Hour(s)			1 Hour(s)
02/09/2022 00:00	1.1	13.9	1,390.8	0.9	4.20	1	1	0
02/09/2022 01:00	1.1	13.9	1,398.1	0.9	4.20	1	1	0
02/09/2022 02:00	1.1	13.9	1,394.6	0.9	4.20	1	1	0
02/09/2022 03:00	1.1	13.9	1,390.2	0.9	4.20	1	1	0
02/09/2022 04:00	1.1	13.9	1,389.2	0.9	4.20	1	1	0
02/09/2022 05:00	1.1	13.9	1,386.7	0.9	4.20	1	1	0
02/09/2022 06:00	1.1	13.9	1,416.6	0.9	4.20	1	1	0
02/09/2022 07:00	1.2	13.7	1,839.7	1.0	7.40	1	1	0
02/09/2022 08:00	1.2	13.7	1,853.6	1.0	7.40	1	1	0
02/09/2022 09:00	1.2	13.6	1,872.2	1.0	7.50	1	1	0
02/09/2022 10:00	1.2	13.6	1,864.0	1.0	7.50	1	1	1
02/09/2022 11:00	1.4	12.1	2,199.8	0.9	6.60	1	1	1
02/09/2022 12:00	1.3	12.2	2,109.9	0.9	6.30	1	1	1
02/09/2022 13:00	1.1	13.6	1,843.8	0.9	5.50	1	1	0
02/09/2022 14:00	1.1	13.6	1,844.5	0.9	5.50	1	1	0
02/09/2022 15:00	1.1	13.8	1,651.5	0.9	5.00	1	1	0
02/09/2022 16:00	1.1	13.7	1,749.8	0.9	5.20	1	1	0
02/09/2022 17:00	1.1	13.7	1,723.5	0.9	5.20	1	1	0
02/09/2022 18:00	1.1	13.7	1,828.1	0.9	5.50	1	1	1
02/09/2022 19:00	1.2	12.8	2,039.5	0.9	6.10	1	1	1
02/09/2022 20:00	1.3	12.5	2,112.4	0.9	6.30	1	1	1
02/09/2022 21:00	1.3	12.4	2,117.3	0.9	6.40	1	1	1
02/09/2022 22:00	1.2	12.7	2,043.9	0.9	6.10	1	1	1
02/09/2022 23:00	1.1	13.7	1,546.5	0.9	4.60	1	1	1
Average/Sum#:	1.2	13.4	1,750.3	0.9	133.50 #	24 #	24 #	9 #
Minimum:	1.1	12.1	1,386.7	0.9	4.20	1	1	0
Maximum:	1.4	13.9	2,199.8	1.0	7.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:22 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit	> Limit	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT1	Unit CT1	UnitOn, TF	NormalOp, TF	Unit CT1
	1 Hour(s)	1 Hour(s)	1 Hour(s)	NOx, Ppmvdc	NOx, Lb	1 Hour(s)	1 Hour(s)	DBOn, TF
				1 Hour(s)	1 Hour(s)			1 Hour(s)
02/10/2022 00:00	1.1	13.9	1,383.3	0.9	4.10	1	1	0
02/10/2022 01:00	1.1	13.7	1,624.4	0.9	4.90	1	1	1
02/10/2022 02:00	1.2	13.0	1,995.6	0.9	6.00	1	1	1
02/10/2022 03:00	1.2	12.9	2,005.0	0.9	6.00	1	1	1
02/10/2022 04:00	1.1	13.8	1,631.2	0.9	4.90	1	1	1
02/10/2022 05:00	1.0	13.7	1,617.8	0.8	4.90	1	1	1
02/10/2022 06:00	1.3	12.6	2,087.3	0.9	6.30	1	1	1
02/10/2022 07:00	1.3	12.6	2,054.1	0.9	6.20	1	1	1
02/10/2022 08:00	3.4	15.6	622.6	3.8	2.00	1	0	0
02/10/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/10/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/10/2022 11:00	0.2	18.9	145.9	0.6	0.05	1	0	0
02/10/2022 12:00	9.3	15.7	810.5	10.6	31.60	1	0	0
02/10/2022 13:00	1.0	13.9	1,397.4	0.8	4.20	1	1	0
02/10/2022 14:00	1.1	13.9	1,393.4	0.9	4.20	1	1	0
02/10/2022 15:00	1.1	13.7	1,646.0	0.9	4.90	1	1	0
02/10/2022 16:00	1.0	13.8	1,607.0	0.8	4.80	1	1	0
02/10/2022 17:00	1.2	13.2	1,587.8	0.9	4.80	1	1	1
02/10/2022 18:00	1.4	11.5	2,315.1	0.9	6.90	1	1	1
02/10/2022 19:00	1.4	11.7	2,278.8	0.9	6.80	1	1	1
02/10/2022 20:00	1.3	12.0	2,193.6	0.9	6.60	1	1	1
02/10/2022 21:00	1.2	12.6	2,074.4	0.9	6.20	1	1	1
02/10/2022 22:00	1.2	12.7	2,040.5	0.9	6.10	1	1	1
02/10/2022 23:00	1.0	13.6	1,539.0	0.8	4.60	1	1	1
Average/Sum#:	1.6	13.6	1,638.7	1.4	137.05 #	22 #	19 #	14 #
Minimum:	0.2	11.5	145.9	0.6	0.05	0	0	0
Maximum:	9.3	18.9	2,315.1	10.6	31.60	1	1	1
%SI	8.33	8.33	8.33	8.33	8.33	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:22 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/11/2022 00:00	1.1	13.9	1,324.4	0.9	4.00	1	1	0
02/11/2022 01:00	3.4	16.3	362.2	4.4	0.99	1	0	0
02/11/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/11/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/11/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/11/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/11/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/11/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/11/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/11/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/11/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/11/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/11/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/11/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/11/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/11/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/11/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/11/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/11/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/11/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/11/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/11/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/11/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/11/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	2.3	15.1	843.3	2.7	4.99 #	2 #	1 #	0 #
Minimum:	1.1	13.9	362.2	0.9	0.99	0	0	0
Maximum:	3.4	16.3	1,324.4	4.4	4.00	1	1	0
%SI	91.67	91.67	91.67	91.67	91.67	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:22 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/12/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/12/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/12/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/12/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/12/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/12/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/12/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/12/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/12/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/12/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/12/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/12/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/12/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/12/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/12/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/12/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/12/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/12/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/12/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/12/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/12/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/12/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/12/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/12/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:22 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/13/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/13/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/13/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/13/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/13/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/13/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/13/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/13/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/13/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/13/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/13/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/13/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/13/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/13/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/13/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/13/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/13/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/13/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/13/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/13/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/13/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/13/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/13/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/13/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:22 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/14/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/14/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/14/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/14/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/14/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/14/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/14/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/14/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/14/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/14/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/14/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/14/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/14/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/14/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/14/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/14/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/14/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/14/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/14/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/14/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/14/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/14/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/14/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/14/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:22 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/15/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:22 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/16/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/16/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/16/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/16/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/16/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/16/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/16/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/16/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/16/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/16/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/16/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/16/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/16/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/16/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/16/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/16/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/16/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/16/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/16/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/16/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/16/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/16/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/16/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/16/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:22 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/17/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/17/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/17/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/17/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/17/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/17/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/17/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/17/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/17/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/17/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/17/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/17/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/17/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/17/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/17/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/17/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/17/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/17/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/17/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/17/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/17/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/17/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/17/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/17/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:22 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/18/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/18/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/18/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/18/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/18/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/18/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/18/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/18/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/18/2022 08:00	6.9	19.3	116.9	25.4	1.56	1	0	0
02/18/2022 09:00	37.6	17.2	379.6	60.0	83.90	1	0	0
02/18/2022 10:00	8.7	17.2	393.2	13.9	20.10	1	0	0
02/18/2022 11:00	15.2	16.2	684.0	19.1	47.90	1	0	0
02/18/2022 12:00	14.4	15.0	1,006.2	14.4	53.30	1	0	0
02/18/2022 13:00	1.1	13.9	1,394.1	0.9	4.20	1	1	0
02/18/2022 14:00	1.1	13.9	1,395.8	0.9	4.20	1	1	0
02/18/2022 15:00	1.1	13.8	1,751.9	0.9	5.30	1	1	0
02/18/2022 16:00	1.1	13.8	1,597.5	0.9	4.80	1	1	0
02/18/2022 17:00	1.1	13.9	1,658.4	0.9	5.00	1	1	0
02/18/2022 18:00	1.1	13.8	1,594.8	0.9	4.80	1	1	1
02/18/2022 19:00	1.2	12.8	2,037.3	0.9	6.10	1	1	1
02/18/2022 20:00	1.2	13.1	1,958.5	0.9	5.90	1	1	1
02/18/2022 21:00	1.1	13.8	1,578.7	0.9	4.70	1	1	0
02/18/2022 22:00	1.1	13.8	1,609.8	0.9	4.80	1	1	1
02/18/2022 23:00	1.2	12.9	2,034.1	0.9	6.10	1	1	1
Average/Sum#:	6.0	14.7	1,324.4	8.9	262.66 #	16 #	11 #	5 #
Minimum:	1.1	12.8	116.9	0.9	1.56	0	0	0
Maximum:	37.6	19.3	2,037.3	60.0	83.90	1	1	1
%SI	33.33	33.33	33.33	33.33	33.33	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:22 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/19/2022 00:00	2.2	14.3	1,260.4	2.0	4.22	1	0	1
02/19/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/19/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/19/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/19/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/19/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/19/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/19/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/19/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/19/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/19/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/19/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/19/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/19/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/19/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/19/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/19/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/19/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/19/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/19/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/19/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/19/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/19/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/19/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	2.2	14.3	1,260.4	2.0	4.22 #	1 #	0 #	1 #
Minimum:	2.2	14.3	1,260.4	2.0	4.22	0	0	0
Maximum:	2.2	14.3	1,260.4	2.0	4.22	1	0	1
%SI	95.83	95.83	95.83	95.83	95.83	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:22 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/20/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/20/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/20/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/20/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/20/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/20/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/20/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/20/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/20/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/20/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/20/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/20/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/20/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/20/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/20/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/20/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/20/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/20/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/20/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/20/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/20/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/20/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/20/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/20/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:22 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/21/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/21/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/21/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/21/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/21/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/21/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/21/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/21/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/21/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/21/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/21/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/21/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/21/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/21/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/21/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/21/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/21/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/21/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/21/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/21/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/21/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/21/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/21/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/21/2022 23:00	33.2	17.6	324.7	59.4	49.77	1	0	0
Average/Sum#:	33.2	17.6	324.7	59.4	49.77 #	1 #	0 #	0 #
Minimum:	33.2	17.6	324.7	59.4	49.77	0	0	0
Maximum:	33.2	17.6	324.7	59.4	49.77	1	0	0
%SI	95.83	95.83	95.83	95.83	95.83	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:22 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit	> Limit	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT1	Unit CT1	UnitOn, TF	NormalOp, TF	Unit CT1
	1 Hour(s)	1 Hour(s)	1 Hour(s)	NOx, Ppmvdc	NOx, Lb	1 Hour(s)	1 Hour(s)	DBOn, TF
				1 Hour(s)	1 Hour(s)			1 Hour(s)
02/22/2022 00:00	18.3	17.2	381.3	29.2	41.20	1	0	0
02/22/2022 01:00	11.0	16.1	705.1	13.5	35.30	1	0	0
02/22/2022 02:00	1.0	13.8	1,453.2	0.8	4.40	1	1	0
02/22/2022 03:00	1.1	13.8	1,460.4	0.9	4.40	1	1	0
02/22/2022 04:00	1.0	13.7	1,697.2	0.8	5.10	1	1	0
02/22/2022 05:00	0.9	13.8	1,582.8	0.7	4.70	1	1	0
02/22/2022 06:00	1.1	13.8	1,764.2	0.9	5.30	1	1	0
02/22/2022 07:00	1.1	13.8	1,602.1	0.9	4.80	1	1	0
02/22/2022 08:00	1.1	13.8	1,669.2	0.9	5.00	1	1	0
02/22/2022 09:00	1.1	13.8	1,568.6	0.9	4.70	1	1	0
02/22/2022 10:00	1.1	13.8	1,547.1	0.9	4.60	1	1	0
02/22/2022 11:00	1.1	13.8	1,547.9	0.9	4.60	1	1	0
02/22/2022 12:00	1.1	13.8	1,626.2	0.9	4.90	1	1	0
02/22/2022 13:00	1.1	13.8	1,611.1	0.9	4.80	1	1	0
02/22/2022 14:00	1.1	13.8	1,631.0	0.9	4.90	1	1	0
02/22/2022 15:00	1.1	13.8	1,645.7	0.9	4.90	1	1	0
02/22/2022 16:00	1.1	13.8	1,652.3	0.9	5.00	1	1	1
02/22/2022 17:00	1.2	12.8	2,095.9	0.9	6.30	1	1	1
02/22/2022 18:00	1.2	12.7	2,105.6	0.9	6.30	1	1	1
02/22/2022 19:00	1.3	12.4	2,199.4	0.9	6.60	1	1	1
02/22/2022 20:00	1.4	11.8	2,337.7	0.9	7.00	1	1	1
02/22/2022 21:00	1.3	12.4	2,183.6	0.9	6.60	1	1	1
02/22/2022 22:00	1.3	12.4	2,174.0	0.9	6.50	1	1	1
02/22/2022 23:00	1.3	12.2	2,220.4	0.9	6.70	1	1	1
Average/Sum#:	2.3	13.6	1,685.9	2.6	194.60 #	24 #	22 #	8 #
Minimum:	0.9	11.8	381.3	0.7	4.40	1	0	0
Maximum:	18.3	17.2	2,337.7	29.2	41.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:22 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/23/2022 00:00	1.4	11.9	2,302.6	0.9	6.90	1	1	1
02/23/2022 01:00	1.3	12.1	2,240.7	0.9	6.70	1	1	1
02/23/2022 02:00	1.3	12.2	2,223.9	0.9	6.70	1	1	1
02/23/2022 03:00	1.2	12.7	2,092.5	0.9	6.30	1	1	1
02/23/2022 04:00	1.1	13.8	1,735.7	0.9	5.20	1	1	0
02/23/2022 05:00	1.2	13.3	1,902.1	0.9	5.70	1	1	1
02/23/2022 06:00	1.3	12.3	2,247.5	0.9	6.70	1	1	1
02/23/2022 07:00	1.3	12.2	2,247.8	0.9	6.70	1	1	1
02/23/2022 08:00	1.1	13.6	1,730.6	0.9	5.20	1	1	1
02/23/2022 09:00	1.1	13.8	1,565.1	0.9	4.70	1	1	0
02/23/2022 10:00	1.1	13.8	1,627.6	0.9	4.90	1	1	0
02/23/2022 11:00	1.1	13.8	1,691.9	0.9	5.10	1	1	0
02/23/2022 12:00	1.0	13.9	1,557.1	0.8	4.70	1	1	0
02/23/2022 13:00	1.1	13.9	1,459.5	0.9	4.40	1	1	0
02/23/2022 14:00	1.1	13.8	1,670.8	0.9	5.00	1	1	0
02/23/2022 15:00	1.1	13.8	1,638.1	0.9	4.90	1	1	0
02/23/2022 16:00	1.1	13.8	1,662.2	0.9	5.00	1	1	1
02/23/2022 17:00	1.2	13.0	2,048.2	0.9	6.10	1	1	1
02/23/2022 18:00	1.2	12.8	2,093.4	0.9	6.30	1	1	1
02/23/2022 19:00	1.2	12.9	2,094.3	0.9	6.30	1	1	1
02/23/2022 20:00	1.3	12.4	2,194.8	0.9	6.60	1	1	1
02/23/2022 21:00	1.4	11.7	2,355.2	0.9	7.10	1	1	1
02/23/2022 22:00	1.3	12.3	2,217.2	0.9	6.70	1	1	1
02/23/2022 23:00	1.2	12.6	2,170.8	0.9	6.50	1	1	1
Average/Sum#:	1.2	13.0	1,948.7	0.9	140.40 #	24 #	24 #	16 #
Minimum:	1.0	11.7	1,459.5	0.8	4.40	1	1	0
Maximum:	1.4	13.9	2,355.2	0.9	7.10	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:22 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit	> Limit	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT1	Unit CT1	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	NOx, Ppmvdc	NOx, Lb	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/24/2022 00:00	1.4	12.0	2,310.2	0.9	6.90	1	1	1
02/24/2022 01:00	1.3	12.0	2,301.4	0.9	6.90	1	1	1
02/24/2022 02:00	1.4	11.9	2,330.9	0.9	7.00	1	1	1
02/24/2022 03:00	1.4	11.7	2,357.2	0.9	7.10	1	1	1
02/24/2022 04:00	1.3	11.9	2,354.3	0.9	7.10	1	1	1
02/24/2022 05:00	1.5	11.8	2,360.9	1.0	9.40	1	1	1
02/24/2022 06:00	1.3	11.8	2,361.4	0.8	7.10	1	1	1
02/24/2022 07:00	1.3	12.2	2,279.1	0.9	6.80	1	1	1
02/24/2022 08:00	1.2	12.8	2,116.0	0.9	6.30	1	1	1
02/24/2022 09:00	1.2	13.1	2,020.2	0.9	6.10	1	1	1
02/24/2022 10:00	1.1	13.8	1,604.3	0.9	4.80	1	1	0
02/24/2022 11:00	1.1	13.9	1,464.1	0.9	4.40	1	1	0
02/24/2022 12:00	1.1	13.9	1,369.7	0.9	4.10	1	1	0
02/24/2022 13:00	1.1	13.9	1,419.0	0.9	4.30	1	1	0
02/24/2022 14:00	1.1	13.9	1,502.8	0.9	4.50	1	1	0
02/24/2022 15:00	1.1	13.9	1,498.2	0.9	4.50	1	1	0
02/24/2022 16:00	1.1	13.8	1,608.5	0.9	4.80	1	1	1
02/24/2022 17:00	1.2	12.9	2,054.7	0.9	6.20	1	1	1
02/24/2022 18:00	1.3	11.9	2,302.0	0.9	6.90	1	1	1
02/24/2022 19:00	1.4	11.6	2,358.8	0.9	7.10	1	1	1
02/24/2022 20:00	1.3	12.0	2,276.3	0.9	6.80	1	1	1
02/24/2022 21:00	1.4	11.8	2,316.4	0.9	6.90	1	1	1
02/24/2022 22:00	1.3	12.0	2,306.8	0.9	6.90	1	1	1
02/24/2022 23:00	1.3	12.2	2,245.5	0.9	6.70	1	1	1
Average/Sum#:	1.3	12.6	2,046.6	0.9	149.60 #	24 #	24 #	18 #
Minimum:	1.1	11.6	1,369.7	0.8	4.10	1	1	0
Maximum:	1.5	13.9	2,361.4	1.0	9.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:22 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit	> Limit	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT1	Unit CT1	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	NOx, Ppmvdc	NOx, Lb	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/25/2022 00:00	1.3	12.6	2,144.7	0.9	6.40	1	1	1
02/25/2022 01:00	1.2	12.9	2,075.0	0.9	6.20	1	1	1
02/25/2022 02:00	1.2	12.9	2,079.4	0.9	6.20	1	1	1
02/25/2022 03:00	1.2	12.9	2,092.3	0.9	6.30	1	1	1
02/25/2022 04:00	1.3	12.7	2,140.5	0.9	6.40	1	1	1
02/25/2022 05:00	1.2	12.8	2,099.4	0.9	6.30	1	1	1
02/25/2022 06:00	1.3	12.0	2,288.7	0.9	6.90	1	1	1
02/25/2022 07:00	1.2	12.8	2,106.7	0.9	6.30	1	1	1
02/25/2022 08:00	1.2	13.1	1,995.7	0.9	6.00	1	1	1
02/25/2022 09:00	1.1	13.8	1,555.8	0.9	4.70	1	1	0
02/25/2022 10:00	1.1	13.9	1,543.5	0.9	4.60	1	1	0
02/25/2022 11:00	1.1	13.8	1,659.5	0.9	5.00	1	1	0
02/25/2022 12:00	1.1	13.8	1,632.3	0.9	4.90	1	1	0
02/25/2022 13:00	1.1	13.9	1,642.0	0.9	4.90	1	1	0
02/25/2022 14:00	1.1	13.9	1,625.8	0.9	4.90	1	1	0
02/25/2022 15:00	1.1	13.9	1,585.3	0.9	4.80	1	1	0
02/25/2022 16:00	1.1	13.8	1,683.4	0.9	5.10	1	1	1
02/25/2022 17:00	1.2	12.9	2,036.2	0.9	6.10	1	1	1
02/25/2022 18:00	1.2	13.0	1,991.9	0.9	6.00	1	1	1
02/25/2022 19:00	1.2	13.1	1,979.3	0.9	5.90	1	1	1
02/25/2022 20:00	1.2	13.0	2,021.8	0.9	6.10	1	1	1
02/25/2022 21:00	1.2	12.8	2,058.0	0.9	6.20	1	1	1
02/25/2022 22:00	1.2	12.7	2,102.3	0.9	6.30	1	1	1
02/25/2022 23:00	1.3	12.7	2,105.2	0.9	6.30	1	1	1
Average/Sum#:	1.2	13.2	1,926.9	0.9	138.80 #	24 #	24 #	17 #
Minimum:	1.1	12.0	1,543.5	0.9	4.60	1	1	0
Maximum:	1.3	13.9	2,288.7	0.9	6.90	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:22 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/26/2022 00:00	1.2	12.7	2,136.2	0.9	6.40	1	1	1
02/26/2022 01:00	1.3	12.6	2,147.3	0.9	6.40	1	1	1
02/26/2022 02:00	1.2	13.1	2,008.5	0.9	6.00	1	1	1
02/26/2022 03:00	1.2	13.2	2,006.3	0.9	6.00	1	1	1
02/26/2022 04:00	1.2	12.8	2,089.7	0.9	6.30	1	1	1
02/26/2022 05:00	1.1	12.9	2,085.7	0.8	6.30	1	1	1
02/26/2022 06:00	1.6	12.9	2,068.3	1.2	8.30	1	1	1
02/26/2022 07:00	3.3	14.4	1,244.5	3.0	6.58	1	0	1
02/26/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/26/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/26/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/26/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/26/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/26/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/26/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/26/2022 15:00	22.0	18.0	303.4	44.8	19.04	1	0	0
02/26/2022 16:00	15.2	15.7	817.8	17.2	52.30	1	0	0
02/26/2022 17:00	1.2	13.8	1,526.7	1.0	6.10	1	1	1
02/26/2022 18:00	1.7	13.1	1,990.5	1.3	10.00	1	1	1
02/26/2022 19:00	1.8	13.1	2,000.5	1.4	10.00	1	1	1
02/26/2022 20:00	1.8	13.1	1,999.3	1.4	10.00	1	1	1
02/26/2022 21:00	2.0	12.6	2,124.5	1.4	10.60	1	1	1
02/26/2022 22:00	1.9	12.8	2,072.8	1.4	10.40	1	1	1
02/26/2022 23:00	3.5	14.1	1,314.2	3.0	6.96	1	0	1
Average/Sum#:	3.7	13.6	1,761.0	4.8	187.68 #	17 #	13 #	15 #
Minimum:	1.1	12.6	303.4	0.8	6.00	0	0	0
Maximum:	22.0	18.0	2,147.3	44.8	52.30	1	1	1
%SI	29.17	29.17	29.17	29.17	29.17	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:22 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/27/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/27/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/27/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/27/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/27/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/27/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/27/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/27/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/27/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/27/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/27/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/27/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/27/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/27/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/27/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/27/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/27/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/27/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/27/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/27/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/27/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/27/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/27/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/27/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:22 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/28/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/28/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/28/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/28/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/28/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/28/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/28/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/28/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/28/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/28/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/28/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/28/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/28/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/28/2022 13:00	35.4	17.6	332.4	63.3	60.37	1	0	0
02/28/2022 14:00	11.6	17.2	392.9	18.5	26.70	1	0	0
02/28/2022 15:00	12.3	15.6	830.2	13.7	41.50	1	0	0
02/28/2022 16:00	1.0	13.9	1,499.6	0.8	4.50	1	1	0
02/28/2022 17:00	1.2	13.1	1,979.3	0.9	5.90	1	1	1
02/28/2022 18:00	1.3	12.3	2,134.2	0.9	6.40	1	1	1
02/28/2022 19:00	1.2	12.8	2,016.0	0.9	6.00	1	1	1
02/28/2022 20:00	1.2	12.9	2,000.9	0.9	6.00	1	1	1
02/28/2022 21:00	1.2	13.0	1,966.4	0.9	5.90	1	1	1
02/28/2022 22:00	2.5	15.6	605.1	2.8	1.40	1	0	0
02/28/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	6.9	14.4	1,375.7	10.4	164.67 #	10 #	6 #	5 #
Minimum:	1.0	12.3	332.4	0.8	1.40	0	0	0
Maximum:	35.4	17.6	2,134.2	63.3	60.37	1	1	1
%SI	58.33	58.33	58.33	58.33	58.33	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:22 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/01/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/01/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/01/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/01/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/01/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/01/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/01/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/01/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/01/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/01/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/01/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/01/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/01/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/01/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/01/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/01/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/01/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/01/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/01/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/01/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/01/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/01/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/01/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/01/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:22 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/02/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/02/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/02/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/02/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/02/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/02/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/02/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/02/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/02/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/02/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/02/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/02/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/02/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/02/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/02/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/02/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/02/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/02/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/02/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/02/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/02/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/02/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/02/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/02/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:22 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/03/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/03/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/03/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/03/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/03/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/03/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/03/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/03/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/03/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/03/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/03/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/03/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/03/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/03/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/03/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/03/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/03/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/03/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/03/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/03/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/03/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/03/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/03/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/03/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:22 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/04/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/04/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/04/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/04/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/04/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/04/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/04/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/04/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/04/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/04/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/04/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/04/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/04/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/04/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/04/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/04/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/04/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/04/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/04/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/04/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/04/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/04/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/04/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/04/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:22 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/05/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/05/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/05/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/05/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/05/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/05/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/05/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/05/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/05/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/05/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/05/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/05/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/05/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/05/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/05/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/05/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/05/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/05/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/05/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/05/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/05/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/05/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/05/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/05/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:22 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/06/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/06/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/06/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/06/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/06/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/06/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/06/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/06/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/06/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/06/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/06/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/06/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/06/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/06/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/06/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/06/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/06/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/06/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/06/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/06/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/06/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/06/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/06/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/06/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:22 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/07/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:22 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/08/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:22 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/09/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/09/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/09/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/09/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/09/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/09/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/09/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/09/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/09/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/09/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/09/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/09/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/09/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/09/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/09/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/09/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/09/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/09/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/09/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/09/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/09/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/09/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/09/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/09/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:22 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/10/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/10/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/10/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/10/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/10/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/10/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/10/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/10/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/10/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/10/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/10/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/10/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/10/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/10/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/10/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/10/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/10/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/10/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/10/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/10/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/10/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/10/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/10/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/10/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:22 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/11/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/11/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/11/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/11/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/11/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/11/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/11/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/11/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/11/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/11/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/11/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/11/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/11/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/11/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/11/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/11/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/11/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/11/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/11/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/11/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/11/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/11/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/11/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/11/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:22 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/12/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/12/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/12/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/12/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/12/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/12/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/12/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/12/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/12/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/12/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/12/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/12/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/12/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/12/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/12/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/12/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/12/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/12/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/12/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/12/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/12/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/12/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/12/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/12/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:22 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/13/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/13/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/13/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/13/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/13/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/13/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/13/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/13/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/13/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/13/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/13/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/13/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/13/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/13/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/13/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/13/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/13/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/13/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/13/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/13/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/13/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/13/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/13/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/13/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:22 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/14/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/14/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/14/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/14/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/14/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/14/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/14/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/14/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/14/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/14/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/14/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/14/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/14/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/14/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/14/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/14/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/14/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/14/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/14/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/14/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/14/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/14/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/14/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/14/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:22 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/15/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/15/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/15/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/15/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/15/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/15/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/15/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/15/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/15/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/15/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/15/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/15/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/15/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/15/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/15/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/15/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/15/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/15/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/15/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/15/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/15/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/15/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/15/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/15/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:22 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/16/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/16/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/16/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/16/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/16/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/16/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/16/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/16/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/16/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/16/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/16/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/16/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/16/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/16/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/16/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/16/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/16/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/16/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/16/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/16/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/16/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/16/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/16/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/16/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:22 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/17/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/17/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/17/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/17/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/17/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/17/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/17/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/17/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/17/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/17/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/17/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/17/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/17/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/17/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/17/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/17/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/17/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/17/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/17/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/17/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/17/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/17/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/17/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/17/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:22 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/18/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/18/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/18/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/18/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/18/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/18/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/18/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/18/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/18/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/18/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/18/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/18/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/18/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/18/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/18/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/18/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/18/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/18/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/18/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/18/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/18/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/18/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/18/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/18/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:22 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/19/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/19/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/19/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/19/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/19/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/19/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/19/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/19/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/19/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/19/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/19/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/19/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/19/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/19/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/19/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/19/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/19/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/19/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/19/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/19/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/19/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/19/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/19/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/19/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:22 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/20/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/20/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/20/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/20/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/20/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/20/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/20/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/20/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/20/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/20/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/20/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/20/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/20/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/20/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/20/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/20/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/20/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/20/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/20/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/20/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/20/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/20/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/20/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/20/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:22 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/21/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/21/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/21/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/21/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/21/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/21/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/21/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/21/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/21/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/21/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/21/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/21/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/21/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/21/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/21/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/21/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/21/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/21/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/21/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/21/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/21/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/21/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/21/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/21/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:22 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/22/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/22/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/22/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/22/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/22/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/22/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/22/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/22/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/22/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/22/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/22/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/22/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/22/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/22/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/22/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/22/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/22/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/22/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/22/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/22/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/22/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/22/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/22/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/22/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:22 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/23/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:22 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/24/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:22 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/25/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:22 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/26/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:22 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/27/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:22 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/28/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/28/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/28/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/28/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/28/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/28/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/28/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/28/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/28/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/28/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/28/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/28/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/28/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/28/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/28/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/28/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/28/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/28/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/28/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/28/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/28/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/28/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/28/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/28/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:22 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/29/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/29/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/29/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/29/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/29/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/29/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/29/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/29/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/29/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/29/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/29/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/29/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/29/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/29/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/29/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/29/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/29/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/29/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/29/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/29/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/29/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/29/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/29/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/29/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:22 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/30/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/30/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/30/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/30/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/30/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/30/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/30/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/30/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/30/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/30/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/30/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/30/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/30/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/30/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/30/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/30/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/30/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/30/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/30/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/30/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/30/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/30/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/30/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/30/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:22 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/31/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/31/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/31/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/31/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/31/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/31/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/31/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/31/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/31/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/31/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/31/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/31/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/31/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/31/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/31/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/31/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/31/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/31/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/31/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/31/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/31/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/31/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/31/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/31/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:23 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/01/2022 00:00	1.2	13.3	1,909.9	0.9	5.70	1	1	1
01/01/2022 01:00	0.9	13.9	1,589.2	0.8	4.80	1	1	0
01/01/2022 02:00	0.8	13.9	1,542.9	0.7	3.10	1	1	0
01/01/2022 03:00	0.9	13.9	1,743.3	0.8	5.20	1	1	0
01/01/2022 04:00	1.0	13.6	1,842.3	0.8	5.50	1	1	1
01/01/2022 05:00	1.1	13.5	1,839.7	0.9	5.50	1	1	1
01/01/2022 06:00	0.9	13.8	1,792.0	0.7	5.40	1	1	1
01/01/2022 07:00	1.3	13.2	1,977.6	1.0	7.90	1	1	1
01/01/2022 08:00	1.0	13.6	1,666.2	0.8	5.00	1	1	1
01/01/2022 09:00	2.4	15.0	889.4	2.4	3.36	1	0	0
01/01/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/01/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/01/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/01/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/01/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/01/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/01/2022 16:00	15.9	18.4	273.7	37.5	11.34	1	0	0
01/01/2022 17:00	16.6	15.8	812.6	19.2	57.70	1	0	0
01/01/2022 18:00	0.9	13.9	1,765.4	0.8	5.30	1	1	0
01/01/2022 19:00	0.9	13.8	1,796.6	0.7	5.40	1	1	1
01/01/2022 20:00	1.5	12.8	2,066.2	1.1	8.30	1	1	1
01/01/2022 21:00	1.6	12.6	2,108.0	1.1	8.40	1	1	1
01/01/2022 22:00	1.6	12.7	2,090.2	1.2	8.40	1	1	1
01/01/2022 23:00	1.6	12.8	2,068.4	1.2	8.30	1	1	1
Average/Sum#:	2.9	13.9	1,654.1	4.0	164.60 #	18 #	15 #	11 #
Minimum:	0.8	12.6	273.7	0.7	3.10	0	0	0
Maximum:	16.6	18.4	2,108.0	37.5	57.70	1	1	1
%SI	25.00	25.00	25.00	25.00	25.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:23 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT2	Unit CT2	UnitOn, TF	NormalOp, TF	Unit CT2
	1 Hour(s)	1 Hour(s)	1 Hour(s)	NOx, Ppmvdc	NOx, Lb	1 Hour(s)	1 Hour(s)	DBOn, TF
				1 Hour(s)	1 Hour(s)			1 Hour(s)
01/02/2022 00:00	1.3	13.2	1,934.3	1.0	7.70	1	1	1
01/02/2022 01:00	0.8	13.9	1,522.0	0.7	3.00	1	1	0
01/02/2022 02:00	0.7	13.9	1,396.8	0.6	2.80	1	1	0
01/02/2022 03:00	0.9	13.8	1,714.4	0.7	5.10	1	1	0
01/02/2022 04:00	1.0	13.5	1,832.8	0.8	5.50	1	1	1
01/02/2022 05:00	1.1	13.4	1,836.6	0.9	5.50	1	1	1
01/02/2022 06:00	0.9	13.8	1,771.7	0.7	5.30	1	1	1
01/02/2022 07:00	1.3	13.2	1,981.4	1.0	7.90	1	1	1
01/02/2022 08:00	1.0	13.6	1,668.3	0.8	5.00	1	1	1
01/02/2022 09:00	2.4	15.0	896.5	2.4	3.40	1	0	0
01/02/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/02/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/02/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/02/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/02/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/02/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/02/2022 16:00	13.3	18.4	240.6	31.4	8.37	1	0	0
01/02/2022 17:00	14.3	15.7	829.9	16.2	49.80	1	0	0
01/02/2022 18:00	0.9	13.7	1,769.2	0.7	5.30	1	1	1
01/02/2022 19:00	1.4	12.9	2,024.3	1.0	8.10	1	1	1
01/02/2022 20:00	1.6	12.4	2,138.0	1.1	8.60	1	1	1
01/02/2022 21:00	1.6	12.7	2,061.8	1.2	8.20	1	1	1
01/02/2022 22:00	1.6	12.7	2,056.6	1.2	8.20	1	1	1
01/02/2022 23:00	1.4	13.1	1,970.3	1.1	7.90	1	1	1
Average/Sum#:	2.6	13.8	1,647.0	3.5	155.67 #	18 #	15 #	12 #
Minimum:	0.7	12.4	240.6	0.6	2.80	0	0	0
Maximum:	14.3	18.4	2,138.0	31.4	49.80	1	1	1
%SI	25.00	25.00	25.00	25.00	25.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:23 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT2	Unit CT2	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	NOx, Ppmvdc	NOx, Lb	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/03/2022 00:00	1.2	13.3	1,908.5	0.9	5.70	1	1	1
01/03/2022 01:00	0.9	13.9	1,628.6	0.8	4.90	1	1	0
01/03/2022 02:00	0.9	13.8	1,648.2	0.7	4.90	1	1	1
01/03/2022 03:00	1.3	13.2	1,971.1	1.0	7.90	1	1	1
01/03/2022 04:00	1.3	13.2	1,965.4	1.0	7.90	1	1	1
01/03/2022 05:00	1.5	12.9	2,033.5	1.1	8.10	1	1	1
01/03/2022 06:00	1.5	12.3	2,173.3	1.0	8.70	1	1	1
01/03/2022 07:00	1.4	12.8	2,052.1	1.0	8.20	1	1	1
01/03/2022 08:00	1.4	13.1	1,971.7	1.1	7.90	1	1	1
01/03/2022 09:00	1.2	13.3	1,919.9	0.9	5.80	1	1	1
01/03/2022 10:00	0.9	13.8	1,680.4	0.7	5.00	1	1	1
01/03/2022 11:00	0.7	13.9	1,408.9	0.6	2.80	1	1	0
01/03/2022 12:00	0.9	13.8	1,723.4	0.7	5.20	1	1	0
01/03/2022 13:00	1.1	13.4	1,842.7	0.9	5.50	1	1	1
01/03/2022 14:00	1.2	13.3	1,847.4	0.9	5.50	1	1	1
01/03/2022 15:00	0.9	13.8	1,621.1	0.7	4.90	1	1	0
01/03/2022 16:00	1.2	13.3	1,870.0	0.9	5.60	1	1	1
01/03/2022 17:00	1.5	12.6	2,065.2	1.1	8.30	1	1	1
01/03/2022 18:00	1.6	12.4	2,092.8	1.1	8.40	1	1	1
01/03/2022 19:00	1.7	12.3	2,124.9	1.2	8.50	1	1	1
01/03/2022 20:00	1.6	12.6	2,035.6	1.1	8.10	1	1	1
01/03/2022 21:00	1.5	12.8	2,004.7	1.1	8.00	1	1	1
01/03/2022 22:00	1.4	13.1	1,934.6	1.1	7.70	1	1	1
01/03/2022 23:00	1.5	12.8	1,996.3	1.1	8.00	1	1	1
Average/Sum#:	1.3	13.2	1,896.7	0.9	161.50 #	24 #	24 #	20 #
Minimum:	0.7	12.3	1,408.9	0.6	2.80	1	1	0
Maximum:	1.7	13.9	2,173.3	1.2	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:23 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT2	Unit CT2	UnitOn, TF	NormalOp, TF	Unit CT2
	1 Hour(s)	1 Hour(s)	1 Hour(s)	NOx, Ppmvdc	NOx, Lb	1 Hour(s)	1 Hour(s)	DBOn, TF
				1 Hour(s)	1 Hour(s)			1 Hour(s)
01/04/2022 00:00	1.5	12.8	1,978.6	1.1	7.90	1	1	1
01/04/2022 01:00	0.9	13.9	1,541.5	0.8	4.60	1	1	0
01/04/2022 02:00	0.9	13.8	1,650.0	0.7	5.00	1	1	1
01/04/2022 03:00	1.2	13.2	1,893.1	0.9	5.70	1	1	1
01/04/2022 04:00	1.3	13.2	1,913.3	1.0	7.70	1	1	1
01/04/2022 05:00	0.9	13.9	1,637.6	0.8	4.90	1	1	0
01/04/2022 06:00	1.0	13.8	1,750.2	0.8	5.30	1	1	0
01/04/2022 07:00	1.3	13.1	1,951.4	1.0	7.80	1	1	1
01/04/2022 08:00	1.5	12.9	1,980.4	1.1	7.90	1	1	1
01/04/2022 09:00	1.3	13.2	1,911.3	1.0	7.60	1	1	1
01/04/2022 10:00	0.8	13.8	1,425.8	0.7	2.90	1	1	1
01/04/2022 11:00	0.7	13.9	1,321.2	0.6	2.60	1	1	0
01/04/2022 12:00	0.9	13.8	1,693.1	0.7	5.10	1	1	0
01/04/2022 13:00	1.1	13.6	1,796.6	0.9	5.40	1	1	1
01/04/2022 14:00	1.1	13.4	1,792.3	0.9	5.40	1	1	1
01/04/2022 15:00	0.9	13.8	1,560.4	0.7	4.70	1	1	0
01/04/2022 16:00	1.3	13.0	1,971.7	1.0	7.90	1	1	1
01/04/2022 17:00	1.6	12.4	2,092.2	1.1	8.40	1	1	1
01/04/2022 18:00	1.6	12.3	2,109.5	1.1	8.40	1	1	1
01/04/2022 19:00	1.6	12.4	2,097.2	1.1	8.40	1	1	1
01/04/2022 20:00	1.6	12.7	2,042.7	1.2	8.20	1	1	1
01/04/2022 21:00	1.6	12.8	2,013.5	1.2	8.10	1	1	1
01/04/2022 22:00	1.4	12.9	1,979.5	1.0	7.90	1	1	1
01/04/2022 23:00	1.5	12.9	1,996.3	1.1	8.00	1	1	1
Average/Sum#:	1.2	13.2	1,837.5	0.9	155.80 #	24 #	24 #	18 #
Minimum:	0.7	12.3	1,321.2	0.6	2.60	1	1	0
Maximum:	1.6	13.9	2,109.5	1.2	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:23 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT2	Unit CT2	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	NOx, Ppmvdc	NOx, Lb	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/05/2022 00:00	1.2	13.4	1,794.1	0.9	5.40	1	1	1
01/05/2022 01:00	0.7	13.9	1,289.5	0.6	2.60	1	1	0
01/05/2022 02:00	0.7	13.9	1,319.7	0.6	2.60	1	1	0
01/05/2022 03:00	0.9	13.8	1,724.1	0.7	5.20	1	1	0
01/05/2022 04:00	1.1	13.5	1,832.7	0.9	5.50	1	1	1
01/05/2022 05:00	1.2	13.2	1,864.2	0.9	5.60	1	1	1
01/05/2022 06:00	1.0	13.8	1,651.5	0.8	5.00	1	1	1
01/05/2022 07:00	1.3	13.0	1,984.2	1.0	7.90	1	1	1
01/05/2022 08:00	1.4	13.1	1,975.2	1.1	7.90	1	1	1
01/05/2022 09:00	1.4	13.0	1,957.0	1.0	7.80	1	1	1
01/05/2022 10:00	0.8	13.9	1,455.8	0.7	2.90	1	1	0
01/05/2022 11:00	0.8	13.9	1,506.0	0.7	3.00	1	1	0
01/05/2022 12:00	0.9	13.8	1,702.2	0.7	5.10	1	1	0
01/05/2022 13:00	1.0	13.5	1,819.7	0.8	5.50	1	1	1
01/05/2022 14:00	1.1	13.4	1,822.9	0.9	5.50	1	1	1
01/05/2022 15:00	0.9	13.9	1,630.7	0.8	4.90	1	1	1
01/05/2022 16:00	1.3	13.0	1,984.0	1.0	7.90	1	1	1
01/05/2022 17:00	1.5	12.8	2,031.0	1.1	8.10	1	1	1
01/05/2022 18:00	1.5	12.6	2,080.5	1.1	8.30	1	1	1
01/05/2022 19:00	1.5	12.6	2,077.9	1.1	8.30	1	1	1
01/05/2022 20:00	1.6	12.6	2,075.8	1.1	8.30	1	1	1
01/05/2022 21:00	1.6	12.6	2,066.5	1.1	8.30	1	1	1
01/05/2022 22:00	1.3	13.2	1,927.2	1.0	7.70	1	1	1
01/05/2022 23:00	1.5	12.9	1,997.6	1.1	8.00	1	1	1
Average/Sum#:	1.2	13.3	1,815.4	0.9	147.30 #	24 #	24 #	18 #
Minimum:	0.7	12.6	1,289.5	0.6	2.60	1	1	0
Maximum:	1.6	13.9	2,080.5	1.1	8.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:23 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT2	Unit CT2	UnitOn, TF	NormalOp, TF	Unit CT2
	1 Hour(s)	1 Hour(s)	1 Hour(s)	NOx, Ppmvdc	NOx, Lb	1 Hour(s)	1 Hour(s)	DBOn, TF
				1 Hour(s)	1 Hour(s)			1 Hour(s)
01/06/2022 00:00	1.2	13.4	1,802.4	0.9	5.40	1	1	1
01/06/2022 01:00	0.7	13.9	1,306.9	0.6	2.60	1	1	0
01/06/2022 02:00	0.7	13.9	1,288.7	0.6	2.60	1	1	0
01/06/2022 03:00	0.8	13.8	1,527.6	0.7	3.10	1	1	0
01/06/2022 04:00	1.0	13.5	1,834.6	0.8	5.50	1	1	1
01/06/2022 05:00	1.2	13.3	1,829.1	0.9	5.50	1	1	1
01/06/2022 06:00	1.0	13.8	1,728.3	0.8	5.20	1	1	1
01/06/2022 07:00	1.3	13.1	1,975.1	1.0	7.90	1	1	1
01/06/2022 08:00	1.4	13.0	2,001.3	1.0	8.00	1	1	1
01/06/2022 09:00	1.3	13.2	1,917.8	1.0	7.70	1	1	1
01/06/2022 10:00	0.8	13.9	1,494.9	0.7	3.00	1	1	0
01/06/2022 11:00	0.8	13.9	1,559.2	0.7	3.10	1	1	0
01/06/2022 12:00	0.8	13.9	1,425.8	0.7	2.90	1	1	0
01/06/2022 13:00	0.7	13.9	1,312.0	0.6	2.60	1	1	0
01/06/2022 14:00	0.9	13.8	1,588.2	0.7	4.80	1	1	0
01/06/2022 15:00	0.8	13.9	1,417.2	0.7	2.80	1	1	0
01/06/2022 16:00	0.8	13.8	1,592.9	0.7	3.20	1	1	0
01/06/2022 17:00	0.9	13.8	1,708.7	0.7	5.10	1	1	1
01/06/2022 18:00	1.4	12.8	1,990.9	1.0	8.00	1	1	1
01/06/2022 19:00	1.6	12.6	2,038.6	1.1	8.20	1	1	1
01/06/2022 20:00	1.4	13.0	1,927.6	1.0	7.70	1	1	1
01/06/2022 21:00	0.9	13.8	1,642.4	0.7	4.90	1	1	0
01/06/2022 22:00	1.0	13.8	1,740.8	0.8	5.20	1	1	1
01/06/2022 23:00	1.4	13.0	1,959.5	1.0	7.80	1	1	1
Average/Sum#:	1.0	13.5	1,692.1	0.8	122.80 #	24 #	24 #	13 #
Minimum:	0.7	12.6	1,288.7	0.6	2.60	1	1	0
Maximum:	1.6	13.9	2,038.6	1.1	8.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:23 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT2	Unit CT2	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	NOx, Ppmvdc	NOx, Lb	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/07/2022 00:00	1.2	13.4	1,799.2	0.9	5.40	1	1	1
01/07/2022 01:00	0.7	13.9	1,278.9	0.6	2.60	1	1	0
01/07/2022 02:00	0.9	13.8	1,598.4	0.7	4.80	1	1	1
01/07/2022 03:00	1.2	13.2	1,918.0	0.9	5.80	1	1	1
01/07/2022 04:00	1.3	13.1	1,896.8	1.0	7.60	1	1	1
01/07/2022 05:00	0.9	13.8	1,660.6	0.7	5.00	1	1	0
01/07/2022 06:00	1.1	13.8	1,568.4	0.9	4.70	1	1	1
01/07/2022 07:00	1.4	13.0	1,954.9	1.0	7.80	1	1	1
01/07/2022 08:00	1.5	13.1	1,919.2	1.1	7.70	1	1	1
01/07/2022 09:00	0.9	13.9	1,558.9	0.8	4.70	1	1	0
01/07/2022 10:00	0.8	13.9	1,518.0	0.7	3.00	1	1	0
01/07/2022 11:00	0.8	13.9	1,535.4	0.7	3.10	1	1	0
01/07/2022 12:00	0.8	13.9	1,525.6	0.7	3.10	1	1	0
01/07/2022 13:00	0.8	13.9	1,495.3	0.7	3.00	1	1	0
01/07/2022 14:00	0.8	13.9	1,467.8	0.7	2.90	1	1	0
01/07/2022 15:00	0.8	13.9	1,512.7	0.7	3.00	1	1	0
01/07/2022 16:00	0.8	13.9	1,515.8	0.7	3.00	1	1	0
01/07/2022 17:00	0.8	13.9	1,601.0	0.7	3.20	1	1	0
01/07/2022 18:00	1.2	13.4	1,824.9	0.9	5.50	1	1	1
01/07/2022 19:00	1.1	13.4	1,803.4	0.9	5.40	1	1	1
01/07/2022 20:00	0.9	13.8	1,553.0	0.7	4.70	1	1	1
01/07/2022 21:00	1.3	13.1	1,942.1	1.0	7.80	1	1	1
01/07/2022 22:00	3.4	14.5	1,190.3	3.1	7.15	1	0	1
01/07/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	1.1	13.7	1,636.5	0.9	110.95 #	23 #	22 #	12 #
Minimum:	0.7	13.0	1,190.3	0.6	2.60	0	0	0
Maximum:	3.4	14.5	1,954.9	3.1	7.80	1	1	1
%SI	4.17	4.17	4.17	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:23 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/08/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/08/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/08/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/08/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/08/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/08/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/08/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/08/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/08/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/08/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/08/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/08/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/08/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/08/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/08/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/08/2022 15:00	26.5	17.6	356.7	47.4	56.16	1	0	0
01/08/2022 16:00	8.7	14.9	1,098.8	8.6	35.20	1	0	0
01/08/2022 17:00	0.8	13.9	1,600.9	0.7	3.20	1	1	0
01/08/2022 18:00	1.1	13.8	1,760.8	0.9	5.30	1	1	1
01/08/2022 19:00	1.4	13.0	1,995.8	1.0	8.00	1	1	1
01/08/2022 20:00	1.5	12.8	2,000.7	1.1	8.00	1	1	1
01/08/2022 21:00	0.9	13.9	1,689.8	0.8	5.10	1	1	0
01/08/2022 22:00	1.0	13.8	1,765.5	0.8	5.30	1	1	1
01/08/2022 23:00	1.5	13.0	1,980.7	1.1	7.90	1	1	1
Average/Sum#:	4.8	14.1	1,583.3	6.9	134.16 #	9 #	7 #	5 #
Minimum:	0.8	12.8	356.7	0.7	3.20	0	0	0
Maximum:	26.5	17.6	2,000.7	47.4	56.16	1	1	1
%SI	62.50	62.50	62.50	62.50	62.50	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:23 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT2	Unit CT2	UnitOn, TF	NormalOp, TF	Unit CT2
	1 Hour(s)	1 Hour(s)	1 Hour(s)	NOx, Ppmvdc	NOx, Lb	1 Hour(s)	1 Hour(s)	DBOn, TF
				1 Hour(s)	1 Hour(s)			1 Hour(s)
01/09/2022 00:00	1.4	13.2	1,923.2	1.1	7.70	1	1	1
01/09/2022 01:00	0.8	13.9	1,506.4	0.7	3.00	1	1	0
01/09/2022 02:00	0.9	13.8	1,565.9	0.7	4.70	1	1	1
01/09/2022 03:00	1.2	13.3	1,921.4	0.9	5.80	1	1	1
01/09/2022 04:00	1.2	13.3	1,912.5	0.9	5.70	1	1	1
01/09/2022 05:00	0.8	13.9	1,631.5	0.7	3.30	1	1	0
01/09/2022 06:00	0.9	13.8	1,645.5	0.7	4.90	1	1	1
01/09/2022 07:00	1.3	13.1	1,998.0	1.0	8.00	1	1	1
01/09/2022 08:00	1.3	13.2	1,938.3	1.0	7.80	1	1	1
01/09/2022 09:00	0.8	13.9	1,559.8	0.7	3.10	1	1	0
01/09/2022 10:00	0.8	13.9	1,502.4	0.7	3.00	1	1	0
01/09/2022 11:00	0.8	13.9	1,583.6	0.7	3.20	1	1	0
01/09/2022 12:00	0.7	13.9	1,443.6	0.6	2.90	1	1	0
01/09/2022 13:00	0.8	13.9	1,493.7	0.7	3.00	1	1	0
01/09/2022 14:00	0.8	13.9	1,621.8	0.7	3.20	1	1	0
01/09/2022 15:00	0.8	13.9	1,647.8	0.7	3.30	1	1	0
01/09/2022 16:00	0.9	13.9	1,606.7	0.8	4.80	1	1	1
01/09/2022 17:00	1.4	13.1	1,951.9	1.1	7.80	1	1	1
01/09/2022 18:00	1.6	12.8	2,020.7	1.2	8.10	1	1	1
01/09/2022 19:00	1.3	13.2	1,926.2	1.0	7.70	1	1	1
01/09/2022 20:00	1.5	13.0	1,974.9	1.1	7.90	1	1	1
01/09/2022 21:00	1.4	13.1	1,956.5	1.1	7.80	1	1	1
01/09/2022 22:00	1.5	12.9	2,013.0	1.1	8.10	1	1	1
01/09/2022 23:00	1.2	13.3	1,919.6	0.9	5.80	1	1	1
Average/Sum#:	1.1	13.5	1,761.0	0.9	130.60 #	24 #	24 #	15 #
Minimum:	0.7	12.8	1,443.6	0.6	2.90	1	1	0
Maximum:	1.6	13.9	2,020.7	1.2	8.10	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:23 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/10/2022 00:00	1.1	13.4	1,829.0	0.9	5.50	1	1	1
01/10/2022 01:00	1.5	14.4	1,165.6	1.4	5.34	1	0	0
01/10/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/10/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/10/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/10/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/10/2022 06:00	15.3	17.0	441.8	23.1	27.07	1	0	0
01/10/2022 07:00	7.9	14.6	1,237.4	7.4	33.40	1	0	0
01/10/2022 08:00	0.8	13.9	1,639.2	0.7	3.30	1	1	0
01/10/2022 09:00	0.8	13.9	1,570.4	0.7	3.10	1	1	0
01/10/2022 10:00	0.9	13.9	1,618.8	0.8	4.90	1	1	1
01/10/2022 11:00	1.4	13.1	1,949.8	1.1	7.80	1	1	1
01/10/2022 12:00	1.4	13.2	1,901.3	1.1	7.60	1	1	1
01/10/2022 13:00	0.8	13.9	1,531.1	0.7	3.10	1	1	0
01/10/2022 14:00	0.9	13.9	1,632.3	0.8	4.90	1	1	0
01/10/2022 15:00	1.4	13.0	1,956.2	1.0	7.80	1	1	1
01/10/2022 16:00	1.6	12.7	2,027.1	1.2	8.10	1	1	1
01/10/2022 17:00	1.6	12.6	2,067.0	1.1	8.30	1	1	1
01/10/2022 18:00	1.6	12.5	2,090.3	1.1	8.40	1	1	1
01/10/2022 19:00	1.6	12.5	2,084.1	1.1	8.30	1	1	1
01/10/2022 20:00	1.6	12.5	2,087.9	1.1	8.40	1	1	1
01/10/2022 21:00	1.6	12.6	2,074.0	1.1	8.30	1	1	1
01/10/2022 22:00	1.5	12.9	1,976.4	1.1	7.90	1	1	1
01/10/2022 23:00	1.5	13.1	1,958.4	1.1	7.80	1	1	1
Average/Sum#:	2.3	13.5	1,741.9	2.4	179.31 #	20 #	17 #	13 #
Minimum:	0.8	12.5	441.8	0.7	3.10	0	0	0
Maximum:	15.3	17.0	2,090.3	23.1	33.40	1	1	1
%SI	16.67	16.67	16.67	16.67	16.67	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:23 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT2	Unit CT2	UnitOn, TF	NormalOp, TF	Unit CT2
	1 Hour(s)	1 Hour(s)	1 Hour(s)	NOx, Ppmvdc	NOx, Lb	1 Hour(s)	1 Hour(s)	DBOn, TF
				1 Hour(s)	1 Hour(s)			1 Hour(s)
01/11/2022 00:00	1.2	13.4	1,810.0	0.9	5.40	1	1	1
01/11/2022 01:00	0.7	14.0	1,288.8	0.6	2.60	1	1	0
01/11/2022 02:00	0.8	13.9	1,559.9	0.7	3.10	1	1	1
01/11/2022 03:00	1.1	13.3	1,922.6	0.9	5.80	1	1	1
01/11/2022 04:00	1.2	13.3	1,910.4	0.9	5.70	1	1	1
01/11/2022 05:00	0.8	13.9	1,594.2	0.7	3.20	1	1	0
01/11/2022 06:00	0.9	13.9	1,574.4	0.8	4.70	1	1	1
01/11/2022 07:00	1.3	13.2	1,958.2	1.0	7.80	1	1	1
01/11/2022 08:00	1.2	13.4	1,807.6	0.9	5.40	1	1	1
01/11/2022 09:00	0.7	13.9	1,300.9	0.6	2.60	1	1	0
01/11/2022 10:00	0.7	14.0	1,294.5	0.6	2.60	1	1	0
01/11/2022 11:00	0.7	14.0	1,357.4	0.6	2.70	1	1	0
01/11/2022 12:00	0.7	14.0	1,341.2	0.6	2.70	1	1	0
01/11/2022 13:00	0.7	14.0	1,337.0	0.6	2.70	1	1	0
01/11/2022 14:00	0.7	14.0	1,293.2	0.6	2.60	1	1	0
01/11/2022 15:00	0.7	14.0	1,361.7	0.6	2.70	1	1	0
01/11/2022 16:00	0.8	13.9	1,605.9	0.7	3.20	1	1	0
01/11/2022 17:00	0.9	13.8	1,648.8	0.7	4.90	1	1	1
01/11/2022 18:00	1.3	13.1	1,947.0	1.0	7.80	1	1	1
01/11/2022 19:00	1.3	13.2	1,932.6	1.0	7.70	1	1	1
01/11/2022 20:00	1.2	13.3	1,915.0	0.9	5.70	1	1	1
01/11/2022 21:00	1.3	13.2	1,929.1	1.0	7.70	1	1	1
01/11/2022 22:00	1.5	13.0	1,977.4	1.1	7.90	1	1	1
01/11/2022 23:00	1.1	13.5	1,654.0	0.9	5.00	1	1	1
Average/Sum#:	1.0	13.6	1,638.4	0.8	112.20 #	24 #	24 #	14 #
Minimum:	0.7	13.0	1,288.8	0.6	2.60	1	1	0
Maximum:	1.5	14.0	1,977.4	1.1	7.90	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:23 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/12/2022 00:00	2.8	14.9	904.8	2.8	3.60	1	0	0
01/12/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/12/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/12/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/12/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/12/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/12/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/12/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/12/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/12/2022 09:00	19.9	18.1	310.1	41.9	15.77	1	0	0
01/12/2022 10:00	17.5	15.9	755.2	20.7	57.40	1	0	0
01/12/2022 11:00	0.6	13.9	1,378.4	0.5	2.80	1	1	0
01/12/2022 12:00	0.8	13.9	1,517.0	0.7	3.00	1	1	0
01/12/2022 13:00	0.8	13.9	1,569.1	0.7	3.10	1	1	0
01/12/2022 14:00	0.8	13.9	1,548.1	0.7	3.10	1	1	0
01/12/2022 15:00	0.9	13.9	1,616.2	0.8	4.80	1	1	1
01/12/2022 16:00	1.4	13.0	1,976.7	1.0	7.90	1	1	1
01/12/2022 17:00	1.6	12.6	2,041.8	1.1	8.20	1	1	1
01/12/2022 18:00	1.6	12.8	2,017.2	1.2	8.10	1	1	1
01/12/2022 19:00	1.6	12.8	1,998.2	1.2	8.00	1	1	1
01/12/2022 20:00	1.3	13.1	1,925.8	1.0	7.70	1	1	1
01/12/2022 21:00	0.9	13.9	1,651.5	0.8	5.00	1	1	0
01/12/2022 22:00	0.9	13.8	1,767.8	0.7	5.30	1	1	1
01/12/2022 23:00	1.3	13.2	1,942.1	1.0	7.80	1	1	1
Average/Sum#:	3.4	14.0	1,557.5	4.8	151.57 #	16 #	13 #	8 #
Minimum:	0.6	12.6	310.1	0.5	2.80	0	0	0
Maximum:	19.9	18.1	2,041.8	41.9	57.40	1	1	1
%SI	33.33	33.33	33.33	33.33	33.33	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:23 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT2	Unit CT2	UnitOn, TF	NormalOp, TF	Unit CT2
	1 Hour(s)	1 Hour(s)	1 Hour(s)	NOx, Ppmvdc	NOx, Lb	1 Hour(s)	1 Hour(s)	DBOn, TF
				1 Hour(s)	1 Hour(s)			1 Hour(s)
01/13/2022 00:00	1.2	13.4	1,804.4	0.9	5.40	1	1	1
01/13/2022 01:00	0.7	13.9	1,289.7	0.6	2.60	1	1	0
01/13/2022 02:00	0.9	13.8	1,565.0	0.7	4.70	1	1	1
01/13/2022 03:00	1.2	13.3	1,933.3	0.9	5.80	1	1	1
01/13/2022 04:00	1.2	13.3	1,916.5	0.9	5.70	1	1	1
01/13/2022 05:00	0.9	13.9	1,664.6	0.8	5.00	1	1	0
01/13/2022 06:00	1.0	13.8	1,600.3	0.8	4.80	1	1	1
01/13/2022 07:00	1.4	13.0	1,987.4	1.0	7.90	1	1	1
01/13/2022 08:00	1.2	13.3	1,906.7	0.9	5.70	1	1	1
01/13/2022 09:00	0.9	13.9	1,630.0	0.8	4.90	1	1	0
01/13/2022 10:00	0.7	13.9	1,378.8	0.6	2.80	1	1	0
01/13/2022 11:00	0.9	13.9	1,611.2	0.8	4.80	1	1	0
01/13/2022 12:00	1.1	13.5	1,836.1	0.9	5.50	1	1	1
01/13/2022 13:00	1.5	12.9	1,964.6	1.1	7.90	1	1	1
01/13/2022 14:00	0.9	13.9	1,535.2	0.8	4.60	1	1	0
01/13/2022 15:00	0.9	13.9	1,549.3	0.8	4.60	1	1	1
01/13/2022 16:00	1.4	13.0	1,968.7	1.0	7.90	1	1	1
01/13/2022 17:00	1.6	12.8	1,999.9	1.2	8.00	1	1	1
01/13/2022 18:00	1.6	12.7	2,029.3	1.2	8.10	1	1	1
01/13/2022 19:00	1.4	13.1	1,929.5	1.1	7.70	1	1	1
01/13/2022 20:00	0.9	13.9	1,577.5	0.8	4.70	1	1	0
01/13/2022 21:00	0.9	13.9	1,617.7	0.8	4.90	1	1	1
01/13/2022 22:00	1.5	13.0	1,950.6	1.1	7.80	1	1	1
01/13/2022 23:00	3.5	14.5	1,185.2	3.2	6.82	1	0	1
Average/Sum#:	1.2	13.5	1,726.3	1.0	138.62 #	24 #	23 #	17 #
Minimum:	0.7	12.7	1,185.2	0.6	2.60	1	0	0
Maximum:	3.5	14.5	2,029.3	3.2	8.10	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:23 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT2	Unit CT2	UnitOn, TF	NormalOp, TF	Unit CT2
	1 Hour(s)	1 Hour(s)	1 Hour(s)	NOx, Ppmvdc	NOx, Lb	1 Hour(s)	1 Hour(s)	DBOn, TF
				1 Hour(s)	1 Hour(s)			1 Hour(s)
01/14/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/14/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/14/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/14/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/14/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/14/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/14/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/14/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/14/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/14/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/14/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/14/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/14/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/14/2022 13:00	27.1	17.7	335.2	50.0	43.19	1	0	0
01/14/2022 14:00	10.5	15.3	971.1	11.1	39.80	1	0	0
01/14/2022 15:00	0.8	13.9	1,506.0	0.7	3.00	1	1	0
01/14/2022 16:00	0.8	14.0	1,407.7	0.7	4.20	1	1	0
01/14/2022 17:00	0.8	13.9	1,568.6	0.7	3.10	1	1	0
01/14/2022 18:00	0.8	13.9	1,596.1	0.7	3.20	1	1	0
01/14/2022 19:00	1.3	13.4	1,827.7	1.0	7.30	1	1	1
01/14/2022 20:00	1.3	13.3	1,849.1	1.0	7.40	1	1	1
01/14/2022 21:00	0.9	13.8	1,693.2	0.7	5.10	1	1	1
01/14/2022 22:00	1.4	13.0	1,986.6	1.0	7.90	1	1	1
01/14/2022 23:00	3.1	14.4	1,207.3	2.8	5.81	1	0	1
Average/Sum#:	4.4	14.2	1,449.9	6.4	130.00 #	11 #	8 #	5 #
Minimum:	0.8	13.0	335.2	0.7	3.00	0	0	0
Maximum:	27.1	17.7	1,986.6	50.0	43.19	1	1	1
%SI	54.17	54.17	54.17	54.17	54.17	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:23 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/15/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/15/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/15/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/15/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/15/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/15/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/15/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/15/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/15/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/15/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/15/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/15/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/15/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/15/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/15/2022 14:00	22.6	17.6	351.2	40.4	47.07	1	0	0
01/15/2022 15:00	10.7	15.1	1,058.7	10.9	42.30	1	0	0
01/15/2022 16:00	0.8	13.9	1,567.4	0.7	3.10	1	1	0
01/15/2022 17:00	1.0	13.8	1,653.4	0.8	5.00	1	1	0
01/15/2022 18:00	1.2	13.5	1,838.8	1.0	7.40	1	1	1
01/15/2022 19:00	1.4	13.1	1,930.0	1.1	7.70	1	1	1
01/15/2022 20:00	1.0	13.8	1,671.2	0.8	5.00	1	1	1
01/15/2022 21:00	1.0	13.8	1,750.1	0.8	5.30	1	1	1
01/15/2022 22:00	1.3	13.1	1,950.9	1.0	7.80	1	1	1
01/15/2022 23:00	2.4	14.1	1,441.0	2.1	8.40	1	0	1
Average/Sum#:	4.3	14.2	1,521.3	6.0	139.07 #	10 #	7 #	6 #
Minimum:	0.8	13.1	351.2	0.7	3.10	0	0	0
Maximum:	22.6	17.6	1,950.9	40.4	47.07	1	1	1
%SI	58.33	58.33	58.33	58.33	58.33	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:23 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/16/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/16/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/16/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/16/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/16/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/16/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/16/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/16/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/16/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/16/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/16/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/16/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/16/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/16/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/16/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/16/2022 15:00	24.8	18.0	289.9	50.5	22.64	1	0	0
01/16/2022 16:00	18.7	16.4	611.9	24.5	55.10	1	0	0
01/16/2022 17:00	0.6	13.9	1,440.9	0.5	2.90	1	0	0
01/16/2022 18:00	1.0	13.8	1,687.8	0.8	5.10	1	1	0
01/16/2022 19:00	1.3	13.3	1,876.4	1.0	7.50	1	1	1
01/16/2022 20:00	1.4	13.0	1,970.4	1.0	7.90	1	1	1
01/16/2022 21:00	0.9	13.9	1,676.1	0.8	5.00	1	1	0
01/16/2022 22:00	0.7	14.0	1,383.3	0.6	2.80	1	1	0
01/16/2022 23:00	0.8	13.9	1,596.5	0.7	3.20	1	1	0
Average/Sum#:	5.6	14.5	1,392.6	8.9	112.14 #	9 #	6 #	2 #
Minimum:	0.6	13.0	289.9	0.5	2.80	0	0	0
Maximum:	24.8	18.0	1,970.4	50.5	55.10	1	1	1
%SI	62.50	62.50	62.50	62.50	62.50	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:23 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT2	Unit CT2	UnitOn, TF	NormalOp, TF	Unit CT2
	1 Hour(s)	1 Hour(s)	1 Hour(s)	NOx, Ppmvdc	NOx, Lb	1 Hour(s)	1 Hour(s)	DBOn, TF
				1 Hour(s)	1 Hour(s)			1 Hour(s)
01/17/2022 00:00	1.1	13.5	1,798.6	0.9	5.40	1	1	1
01/17/2022 01:00	1.2	13.4	1,826.8	0.9	5.50	1	1	1
01/17/2022 02:00	0.7	13.9	1,396.3	0.6	2.80	1	1	0
01/17/2022 03:00	0.9	13.8	1,722.3	0.7	5.20	1	1	0
01/17/2022 04:00	1.1	13.5	1,820.8	0.9	5.50	1	1	1
01/17/2022 05:00	1.1	13.4	1,795.2	0.9	5.40	1	1	1
01/17/2022 06:00	1.0	13.8	1,672.6	0.8	5.00	1	1	1
01/17/2022 07:00	1.5	12.9	1,984.6	1.1	7.90	1	1	1
01/17/2022 08:00	1.5	12.9	2,003.7	1.1	8.00	1	1	1
01/17/2022 09:00	1.3	13.1	1,935.0	1.0	7.70	1	1	1
01/17/2022 10:00	0.9	13.9	1,561.7	0.8	4.70	1	1	0
01/17/2022 11:00	0.8	13.9	1,563.0	0.7	3.10	1	1	0
01/17/2022 12:00	0.9	13.8	1,633.9	0.7	4.90	1	1	1
01/17/2022 13:00	1.4	13.1	1,920.4	1.1	7.70	1	1	1
01/17/2022 14:00	1.5	13.1	1,893.2	1.1	7.60	1	1	1
01/17/2022 15:00	0.9	13.9	1,588.4	0.8	4.80	1	1	0
01/17/2022 16:00	0.9	13.9	1,574.5	0.8	4.70	1	1	1
01/17/2022 17:00	1.4	13.1	1,946.0	1.1	7.80	1	1	1
01/17/2022 18:00	1.5	12.9	1,965.1	1.1	7.90	1	1	1
01/17/2022 19:00	1.6	12.8	2,000.1	1.2	8.00	1	1	1
01/17/2022 20:00	1.4	13.1	1,908.0	1.1	7.60	1	1	1
01/17/2022 21:00	0.9	13.9	1,627.2	0.8	4.90	1	1	0
01/17/2022 22:00	0.7	14.0	1,395.3	0.6	2.80	1	1	0
01/17/2022 23:00	0.9	13.9	1,599.9	0.8	4.80	1	1	0
Average/Sum#:	1.1	13.5	1,755.5	0.9	139.70 #	24 #	24 #	16 #
Minimum:	0.7	12.8	1,395.3	0.6	2.80	1	1	0
Maximum:	1.6	14.0	2,003.7	1.2	8.00	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:23 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT2	Unit CT2	UnitOn, TF	NormalOp, TF	Unit CT2
	1 Hour(s)	1 Hour(s)	1 Hour(s)	NOx, Ppmvdc	NOx, Lb	1 Hour(s)	1 Hour(s)	DBOn, TF
				1 Hour(s)	1 Hour(s)			1 Hour(s)
01/18/2022 00:00	1.1	13.8	1,751.0	0.9	5.30	1	1	1
01/18/2022 01:00	1.1	13.3	1,820.2	0.9	5.50	1	1	1
01/18/2022 02:00	0.9	13.9	1,602.3	0.8	4.80	1	1	0
01/18/2022 03:00	1.2	13.3	1,913.4	0.9	5.70	1	1	1
01/18/2022 04:00	1.2	13.3	1,919.1	0.9	5.80	1	1	1
01/18/2022 05:00	0.9	13.8	1,550.3	0.7	4.70	1	1	1
01/18/2022 06:00	0.9	13.8	1,574.5	0.7	4.70	1	1	1
01/18/2022 07:00	1.2	13.3	1,937.6	0.9	5.80	1	1	1
01/18/2022 08:00	1.5	13.1	1,978.0	1.1	7.90	1	1	1
01/18/2022 09:00	1.2	13.3	1,912.7	0.9	5.70	1	1	1
01/18/2022 10:00	0.8	13.9	1,424.7	0.7	2.80	1	1	0
01/18/2022 11:00	0.0	0.0	1,388.0	0.0	0.00	1	1	0
01/18/2022 12:00	0.0	0.0	1,288.8	0.0	0.00	1	1	0
01/18/2022 13:00	0.0	0.0	1,297.7	0.0	0.00	1	1	0
01/18/2022 14:00	0.7	14.0	1,338.1	0.6	2.70	1	1	0
01/18/2022 15:00	0.9	13.9	1,510.9	0.8	4.50	1	1	0
01/18/2022 16:00	0.9	13.9	1,610.3	0.8	4.80	1	1	1
01/18/2022 17:00	1.4	12.9	1,984.1	1.0	7.90	1	1	1
01/18/2022 18:00	1.6	12.8	1,990.1	1.2	8.00	1	1	1
01/18/2022 19:00	1.6	12.7	2,017.1	1.2	8.10	1	1	1
01/18/2022 20:00	1.4	13.2	1,913.8	1.1	7.70	1	1	1
01/18/2022 21:00	0.9	13.8	1,571.8	0.7	4.70	1	1	1
01/18/2022 22:00	0.9	13.9	1,574.3	0.8	4.70	1	1	1
01/18/2022 23:00	1.4	13.1	1,948.2	1.1	7.80	1	1	1
Average/Sum#:	1.1	13.5	1,700.7	0.9	119.60 #	24 #	24 #	17 #
Minimum:	0.7	12.7	1,288.8	0.6	2.70	1	1	0
Maximum:	1.6	14.0	2,017.1	1.2	8.10	1	1	1
%SI	12.50	12.50	0.00	12.50	12.50	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:23 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT2	Unit CT2	UnitOn, TF	NormalOp, TF	Unit CT2
	1 Hour(s)	1 Hour(s)	1 Hour(s)	NOx, Ppmvdc	NOx, Lb	1 Hour(s)	1 Hour(s)	DBOn, TF
				1 Hour(s)	1 Hour(s)			1 Hour(s)
01/19/2022 00:00	1.2	13.4	1,808.1	0.9	5.40	1	1	1
01/19/2022 01:00	0.7	14.0	1,286.5	0.6	2.60	1	1	0
01/19/2022 02:00	0.9	13.9	1,566.8	0.8	4.70	1	1	1
01/19/2022 03:00	1.2	13.3	1,932.6	0.9	5.80	1	1	1
01/19/2022 04:00	1.2	13.3	1,905.0	0.9	5.70	1	1	1
01/19/2022 05:00	0.9	13.9	1,556.8	0.8	4.70	1	1	0
01/19/2022 06:00	0.9	13.8	1,576.0	0.7	4.70	1	1	1
01/19/2022 07:00	1.3	13.2	1,940.1	1.0	7.80	1	1	1
01/19/2022 08:00	0.0	0.0	1,918.7	0.0	0.00	1	1	1
01/19/2022 09:00	0.6	13.9	1,488.7	0.5	3.00	1	1	0
01/19/2022 10:00	0.0	0.0	1,339.8	0.0	0.00	1	1	0
01/19/2022 11:00	0.7	14.0	1,403.5	0.6	2.80	1	1	0
01/19/2022 12:00	0.7	14.0	1,307.0	0.6	2.60	1	1	0
01/19/2022 13:00	0.7	14.0	1,359.5	0.6	2.70	1	1	0
01/19/2022 14:00	0.7	14.0	1,335.7	0.6	2.70	1	1	0
01/19/2022 15:00	0.0	0.0	1,552.9	0.0	0.00	1	1	1
01/19/2022 16:00	1.4	12.8	2,008.1	1.0	8.00	1	1	1
01/19/2022 17:00	1.6	12.7	2,030.9	1.2	8.10	1	1	1
01/19/2022 18:00	1.6	12.8	2,012.3	1.2	8.00	1	1	1
01/19/2022 19:00	1.6	12.6	2,027.9	1.1	8.10	1	1	1
01/19/2022 20:00	1.5	12.8	1,967.8	1.1	7.90	1	1	1
01/19/2022 21:00	0.9	13.9	1,672.9	0.8	5.00	1	1	0
01/19/2022 22:00	1.1	13.8	1,764.6	0.9	5.30	1	1	1
01/19/2022 23:00	1.4	13.1	1,952.2	1.1	7.80	1	1	1
Average/Sum#:	1.1	13.5	1,696.4	0.9	113.40 #	24 #	24 #	15 #
Minimum:	0.6	12.6	1,286.5	0.5	2.60	1	1	0
Maximum:	1.6	14.0	2,030.9	1.2	8.10	1	1	1
%SI	12.50	12.50	0.00	12.50	12.50	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:23 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/20/2022 00:00	1.3	13.2	1,821.6	1.0	7.30	1	1	1
01/20/2022 01:00	0.7	14.0	1,290.4	0.6	2.60	1	1	0
01/20/2022 02:00	0.7	14.0	1,299.6	0.6	2.60	1	1	0
01/20/2022 03:00	0.9	13.9	1,710.7	0.8	5.10	1	1	0
01/20/2022 04:00	1.1	13.5	1,824.8	0.9	5.50	1	1	1
01/20/2022 05:00	1.2	13.4	1,830.3	0.9	5.50	1	1	1
01/20/2022 06:00	1.0	13.8	1,691.9	0.8	5.10	1	1	1
01/20/2022 07:00	1.3	13.2	1,947.8	1.0	7.80	1	1	1
01/20/2022 08:00	1.1	13.6	1,669.1	0.9	5.00	1	1	1
01/20/2022 09:00	2.5	14.8	935.8	2.4	3.61	1	0	0
01/20/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/20/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/20/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/20/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/20/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/20/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/20/2022 16:00	17.4	17.9	340.4	34.2	22.74	1	0	0
01/20/2022 17:00	10.4	14.8	1,120.8	10.1	41.50	1	0	0
01/20/2022 18:00	0.8	13.9	1,598.9	0.7	3.20	1	1	0
01/20/2022 19:00	0.9	13.8	1,696.8	0.7	5.10	1	1	1
01/20/2022 20:00	1.4	12.9	1,975.1	1.0	7.90	1	1	1
01/20/2022 21:00	1.5	13.0	1,975.1	1.1	7.90	1	1	1
01/20/2022 22:00	1.5	12.8	2,006.6	1.1	8.00	1	1	1
01/20/2022 23:00	3.5	14.3	1,229.5	3.1	6.96	1	0	1
Average/Sum#:	2.7	13.9	1,553.6	3.4	153.41 #	18 #	14 #	11 #
Minimum:	0.7	12.8	340.4	0.6	2.60	0	0	0
Maximum:	17.4	17.9	2,006.6	34.2	41.50	1	1	1
%SI	25.00	25.00	25.00	25.00	25.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:23 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/21/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/21/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/21/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/21/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/21/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/21/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/21/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/21/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/21/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/21/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/21/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/21/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/21/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/21/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/21/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/21/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/21/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/21/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/21/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/21/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/21/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/21/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/21/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/21/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:23 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/22/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/22/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/22/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/22/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/22/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/22/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/22/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/22/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/22/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/22/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/22/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/22/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/22/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/22/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/22/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/22/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/22/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/22/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/22/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/22/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/22/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/22/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/22/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/22/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:23 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/23/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/23/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/23/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/23/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/23/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/23/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/23/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/23/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/23/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/23/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/23/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/23/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/23/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/23/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/23/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/23/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/23/2022 16:00	25.5	17.9	291.0	50.2	25.29	1	0	0
01/23/2022 17:00	29.4	15.8	749.9	34.0	93.70	1	0	0
01/23/2022 18:00	0.9	13.8	1,712.2	0.7	5.10	1	1	1
01/23/2022 19:00	1.4	13.1	1,954.9	1.1	7.80	1	1	1
01/23/2022 20:00	1.6	12.7	2,019.1	1.2	8.10	1	1	1
01/23/2022 21:00	1.5	13.0	1,992.3	1.1	8.00	1	1	1
01/23/2022 22:00	1.5	13.1	1,958.4	1.1	7.80	1	1	1
01/23/2022 23:00	4.0	14.5	1,191.0	3.7	8.02	1	0	1
Average/Sum#:	8.2	14.2	1,483.6	11.6	163.81 #	8 #	5 #	6 #
Minimum:	0.9	12.7	291.0	0.7	5.10	0	0	0
Maximum:	29.4	17.9	2,019.1	50.2	93.70	1	1	1
%SI	66.67	66.67	66.67	66.67	66.67	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:23 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/24/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/24/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/24/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/24/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/24/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/24/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/24/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/24/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/24/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/24/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/24/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/24/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/24/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/24/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/24/2022 14:00	22.0	17.6	354.3	39.3	47.29	1	0	0
01/24/2022 15:00	8.5	14.8	1,083.8	8.2	32.50	1	0	0
01/24/2022 16:00	0.9	13.9	1,649.1	0.8	4.90	1	1	0
01/24/2022 17:00	0.9	13.8	1,635.3	0.7	4.90	1	1	1
01/24/2022 18:00	1.4	13.1	1,941.1	1.1	7.80	1	1	1
01/24/2022 19:00	1.6	12.8	2,005.5	1.2	8.00	1	1	1
01/24/2022 20:00	1.5	13.1	1,917.9	1.1	7.70	1	1	1
01/24/2022 21:00	0.8	13.9	1,593.6	0.7	3.20	1	1	0
01/24/2022 22:00	0.9	13.8	1,711.8	0.7	5.10	1	1	1
01/24/2022 23:00	1.4	13.1	1,948.0	1.1	7.80	1	1	1
Average/Sum#:	4.0	14.0	1,584.0	5.5	129.19 #	10 #	8 #	6 #
Minimum:	0.8	12.8	354.3	0.7	3.20	0	0	0
Maximum:	22.0	17.6	2,005.5	39.3	47.29	1	1	1
%SI	58.33	58.33	58.33	58.33	58.33	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:23 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT2	Unit CT2	UnitOn, TF	NormalOp, TF	Unit CT2
	1 Hour(s)	1 Hour(s)	1 Hour(s)	NOx, Ppmvdc	NOx, Lb	1 Hour(s)	1 Hour(s)	DBOn, TF
				1 Hour(s)	1 Hour(s)			1 Hour(s)
01/25/2022 00:00	1.2	13.3	1,896.4	0.9	5.70	1	1	1
01/25/2022 01:00	0.8	13.9	1,535.3	0.7	3.10	1	1	0
01/25/2022 02:00	0.9	13.8	1,642.7	0.7	4.90	1	1	1
01/25/2022 03:00	1.1	13.3	1,928.8	0.9	5.80	1	1	1
01/25/2022 04:00	1.1	13.3	1,910.4	0.9	5.70	1	1	1
01/25/2022 05:00	0.8	13.9	1,644.5	0.7	3.30	1	1	0
01/25/2022 06:00	0.9	13.8	1,745.0	0.7	5.20	1	1	1
01/25/2022 07:00	1.4	13.0	1,978.0	1.0	7.90	1	1	1
01/25/2022 08:00	2.7	13.8	1,481.9	2.2	8.93	1	0	1
01/25/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/25/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/25/2022 11:00	0.9	18.7	211.4	2.4	0.42	1	0	0
01/25/2022 12:00	9.1	16.0	764.8	11.0	30.60	1	0	0
01/25/2022 13:00	0.6	14.0	1,370.6	0.5	2.70	1	1	0
01/25/2022 14:00	0.7	14.0	1,355.8	0.6	2.70	1	1	0
01/25/2022 15:00	1.2	13.8	1,715.9	1.0	6.90	1	1	0
01/25/2022 16:00	0.9	14.0	1,559.4	0.8	4.70	1	1	0
01/25/2022 17:00	0.8	14.0	1,635.7	0.7	4.90	1	1	0
01/25/2022 18:00	1.0	13.9	1,706.5	0.8	5.10	1	1	0
01/25/2022 19:00	1.4	13.3	1,884.4	1.1	7.50	1	1	1
01/25/2022 20:00	1.5	13.2	1,900.7	1.1	7.60	1	1	1
01/25/2022 21:00	0.8	14.0	1,515.9	0.7	4.50	1	1	0
01/25/2022 22:00	1.0	13.8	1,688.2	0.8	5.10	1	1	1
01/25/2022 23:00	1.3	13.3	1,919.9	1.0	7.70	1	1	1
Average/Sum#:	1.5	14.0	1,590.6	1.4	140.95 #	22 #	19 #	11 #
Minimum:	0.6	13.0	211.4	0.5	0.42	0	0	0
Maximum:	9.1	18.7	1,978.0	11.0	30.60	1	1	1
%SI	8.33	8.33	8.33	8.33	8.33	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:23 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT2	Unit CT2	UnitOn, TF	NormalOp, TF	Unit CT2
	1 Hour(s)	1 Hour(s)	1 Hour(s)	NOx, Ppmvdc	NOx, Lb	1 Hour(s)	1 Hour(s)	DBOn, TF
				1 Hour(s)	1 Hour(s)			1 Hour(s)
01/26/2022 00:00	1.4	13.2	1,924.8	1.1	7.70	1	1	1
01/26/2022 01:00	0.9	13.9	1,679.3	0.8	5.00	1	1	0
01/26/2022 02:00	0.8	13.9	1,681.1	0.7	3.40	1	1	1
01/26/2022 03:00	1.2	13.3	1,949.6	0.9	5.80	1	1	1
01/26/2022 04:00	1.4	13.3	1,938.2	1.1	7.80	1	1	1
01/26/2022 05:00	0.8	13.9	1,570.0	0.7	3.10	1	1	0
01/26/2022 06:00	0.9	13.8	1,780.7	0.7	5.30	1	1	1
01/26/2022 07:00	1.3	13.2	1,956.3	1.0	7.80	1	1	1
01/26/2022 08:00	2.8	14.1	1,440.7	2.4	9.49	1	0	1
01/26/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/26/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/26/2022 11:00	0.6	18.7	222.7	1.6	0.29	1	0	0
01/26/2022 12:00	9.9	15.9	790.0	11.7	34.00	1	0	0
01/26/2022 13:00	0.6	14.0	1,353.7	0.5	2.70	1	1	0
01/26/2022 14:00	0.7	14.0	1,346.1	0.6	2.70	1	1	0
01/26/2022 15:00	1.1	13.9	1,686.0	0.9	5.10	1	1	0
01/26/2022 16:00	0.8	14.0	1,556.1	0.7	4.70	1	1	0
01/26/2022 17:00	0.9	13.9	1,695.5	0.8	5.10	1	1	0
01/26/2022 18:00	1.1	13.8	1,778.2	0.9	5.30	1	1	0
01/26/2022 19:00	1.3	13.3	1,877.1	1.0	7.50	1	1	1
01/26/2022 20:00	1.5	12.9	1,981.6	1.1	7.90	1	1	1
01/26/2022 21:00	0.9	13.9	1,648.9	0.8	4.90	1	1	0
01/26/2022 22:00	1.0	13.8	1,768.1	0.8	5.30	1	1	0
01/26/2022 23:00	1.3	13.1	1,971.1	1.0	7.90	1	1	1
Average/Sum#:	1.5	14.0	1,618.0	1.4	148.78 #	22 #	19 #	10 #
Minimum:	0.6	12.9	222.7	0.5	0.29	0	0	0
Maximum:	9.9	18.7	1,981.6	11.7	34.00	1	1	1
%SI	8.33	8.33	8.33	8.33	8.33	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:23 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT2	Unit CT2	UnitOn, TF	NormalOp, TF	Unit CT2
	1 Hour(s)	1 Hour(s)	1 Hour(s)	NOx, Ppmvdc	NOx, Lb	1 Hour(s)	1 Hour(s)	DBOn, TF
				1 Hour(s)	1 Hour(s)			1 Hour(s)
01/27/2022 00:00	1.4	13.2	1,935.0	1.1	7.70	1	1	1
01/27/2022 01:00	0.8	13.9	1,502.8	0.7	3.00	1	1	1
01/27/2022 02:00	0.9	13.9	1,675.8	0.8	5.00	1	1	0
01/27/2022 03:00	1.2	13.3	1,934.7	0.9	5.80	1	1	1
01/27/2022 04:00	1.2	13.3	1,917.5	0.9	5.80	1	1	1
01/27/2022 05:00	0.8	13.9	1,565.4	0.7	3.10	1	1	0
01/27/2022 06:00	1.3	13.3	1,834.3	1.0	7.30	1	1	1
01/27/2022 07:00	1.5	13.0	1,979.5	1.1	7.90	1	1	1
01/27/2022 08:00	1.4	13.2	1,941.1	1.1	7.80	1	1	1
01/27/2022 09:00	1.1	13.6	1,658.5	0.9	5.00	1	1	1
01/27/2022 10:00	0.7	14.0	1,360.0	0.6	2.70	1	1	0
01/27/2022 11:00	0.7	14.0	1,349.3	0.6	2.70	1	1	0
01/27/2022 12:00	0.7	14.0	1,352.3	0.6	2.70	1	1	0
01/27/2022 13:00	0.7	14.0	1,353.7	0.6	2.70	1	1	0
01/27/2022 14:00	0.7	14.0	1,356.2	0.6	2.70	1	1	0
01/27/2022 15:00	1.2	13.9	1,684.2	1.0	6.70	1	1	0
01/27/2022 16:00	0.8	13.9	1,560.7	0.7	3.10	1	1	0
01/27/2022 17:00	0.8	14.0	1,514.3	0.7	4.50	1	1	0
01/27/2022 18:00	1.2	13.7	1,783.4	1.0	7.10	1	1	1
01/27/2022 19:00	1.4	13.0	1,985.3	1.0	7.90	1	1	1
01/27/2022 20:00	1.5	13.0	1,964.1	1.1	7.90	1	1	1
01/27/2022 21:00	0.9	13.9	1,672.3	0.8	5.00	1	1	0
01/27/2022 22:00	0.8	14.0	1,466.1	0.7	4.40	1	1	0
01/27/2022 23:00	1.2	13.4	1,881.2	0.9	5.60	1	1	1
Average/Sum#:	1.0	13.6	1,676.2	0.8	124.10 #	24 #	24 #	12 #
Minimum:	0.7	13.0	1,349.3	0.6	2.70	1	1	0
Maximum:	1.5	14.0	1,985.3	1.1	7.90	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:23 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT2	Unit CT2	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	NOx, Ppmvdc	NOx, Lb	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/28/2022 00:00	1.5	12.9	2,011.2	1.1	8.00	1	1	1
01/28/2022 01:00	1.5	12.9	1,997.3	1.1	8.00	1	1	1
01/28/2022 02:00	0.8	13.9	1,487.4	0.7	3.00	1	1	1
01/28/2022 03:00	0.8	13.9	1,500.7	0.7	3.00	1	1	0
01/28/2022 04:00	0.9	13.9	1,736.7	0.8	5.20	1	1	1
01/28/2022 05:00	1.3	13.2	1,964.9	1.0	7.90	1	1	1
01/28/2022 06:00	1.4	12.8	2,069.9	1.0	8.30	1	1	1
01/28/2022 07:00	1.5	12.8	2,057.3	1.1	8.20	1	1	1
01/28/2022 08:00	1.4	13.2	1,941.8	1.1	7.80	1	1	1
01/28/2022 09:00	0.8	14.0	1,515.3	0.7	4.50	1	1	0
01/28/2022 10:00	0.7	14.0	1,408.8	0.6	2.80	1	1	0
01/28/2022 11:00	0.8	14.0	1,479.2	0.7	4.40	1	1	0
01/28/2022 12:00	0.7	14.0	1,438.2	0.6	2.90	1	1	0
01/28/2022 13:00	0.7	14.0	1,418.6	0.6	2.80	1	1	0
01/28/2022 14:00	0.8	14.0	1,613.2	0.7	4.80	1	1	0
01/28/2022 15:00	0.8	14.0	1,539.9	0.7	4.60	1	1	0
01/28/2022 16:00	0.9	13.9	1,587.8	0.8	4.80	1	1	1
01/28/2022 17:00	1.2	13.3	1,904.9	0.9	5.70	1	1	1
01/28/2022 18:00	1.4	12.8	2,019.0	1.0	8.10	1	1	1
01/28/2022 19:00	1.6	12.5	2,087.9	1.1	8.40	1	1	1
01/28/2022 20:00	1.5	12.7	2,017.3	1.1	8.10	1	1	1
01/28/2022 21:00	0.8	14.0	1,522.1	0.7	4.60	1	1	0
01/28/2022 22:00	1.0	13.8	1,784.8	0.8	5.40	1	1	1
01/28/2022 23:00	1.4	13.1	1,946.1	1.1	7.80	1	1	1
Average/Sum#:	1.1	13.5	1,752.1	0.9	139.10 #	24 #	24 #	15 #
Minimum:	0.7	12.5	1,408.8	0.6	2.80	1	1	0
Maximum:	1.6	14.0	2,087.9	1.1	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:23 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT2	Unit CT2	UnitOn, TF	NormalOp, TF	Unit CT2
	1 Hour(s)	1 Hour(s)	1 Hour(s)	NOx, Ppmvdc	NOx, Lb	1 Hour(s)	1 Hour(s)	DBOn, TF
				1 Hour(s)	1 Hour(s)			1 Hour(s)
01/29/2022 00:00	1.3	13.3	1,897.9	1.0	7.60	1	1	1
01/29/2022 01:00	0.8	13.9	1,551.0	0.7	3.10	1	1	0
01/29/2022 02:00	0.8	13.9	1,563.3	0.7	3.10	1	1	1
01/29/2022 03:00	1.3	13.3	1,918.2	1.0	7.70	1	1	1
01/29/2022 04:00	1.4	13.3	1,895.6	1.1	7.60	1	1	1
01/29/2022 05:00	0.8	13.9	1,586.3	0.7	3.20	1	1	0
01/29/2022 06:00	0.9	13.8	1,604.1	0.7	4.80	1	1	1
01/29/2022 07:00	1.3	13.2	1,964.3	1.0	7.90	1	1	1
01/29/2022 08:00	1.5	13.0	2,008.7	1.1	8.00	1	1	1
01/29/2022 09:00	1.3	13.3	1,904.4	1.0	7.60	1	1	1
01/29/2022 10:00	0.8	14.0	1,395.6	0.7	4.20	1	1	0
01/29/2022 11:00	0.8	13.9	1,514.2	0.7	3.00	1	1	0
01/29/2022 12:00	0.7	14.0	1,364.2	0.6	2.70	1	1	0
01/29/2022 13:00	0.7	14.0	1,384.3	0.6	2.80	1	1	0
01/29/2022 14:00	0.8	14.0	1,591.9	0.7	4.80	1	1	0
01/29/2022 15:00	0.7	14.0	1,367.5	0.6	2.70	1	1	0
01/29/2022 16:00	0.8	14.0	1,572.6	0.7	4.70	1	1	0
01/29/2022 17:00	0.8	13.9	1,603.5	0.7	3.20	1	1	0
01/29/2022 18:00	1.1	13.5	1,786.3	0.9	5.40	1	1	1
01/29/2022 19:00	1.4	13.2	1,859.9	1.1	7.40	1	1	1
01/29/2022 20:00	0.9	13.8	1,767.4	0.7	5.30	1	1	1
01/29/2022 21:00	1.4	13.0	1,980.7	1.0	7.90	1	1	1
01/29/2022 22:00	1.6	12.7	2,052.7	1.2	8.20	1	1	1
01/29/2022 23:00	1.2	13.4	1,816.1	0.9	5.40	1	1	1
Average/Sum#:	1.0	13.6	1,706.3	0.8	128.30 #	24 #	24 #	14 #
Minimum:	0.7	12.7	1,364.2	0.6	2.70	1	1	0
Maximum:	1.6	14.0	2,052.7	1.2	8.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:23 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT2	Unit CT2	UnitOn, TF	NormalOp, TF	Unit CT2
	1 Hour(s)	1 Hour(s)	1 Hour(s)	NOx, Ppmvdc	NOx, Lb	1 Hour(s)	1 Hour(s)	DBOn, TF
				1 Hour(s)	1 Hour(s)			1 Hour(s)
01/30/2022 00:00	0.8	13.9	1,572.5	0.7	3.10	1	1	0
01/30/2022 01:00	0.7	14.0	1,373.3	0.6	2.70	1	1	0
01/30/2022 02:00	0.9	13.9	1,716.3	0.8	5.10	1	1	0
01/30/2022 03:00	1.0	13.6	1,837.1	0.8	5.50	1	1	1
01/30/2022 04:00	1.1	13.5	1,822.2	0.9	5.50	1	1	1
01/30/2022 05:00	0.8	13.9	1,589.8	0.7	3.20	1	1	1
01/30/2022 06:00	1.4	13.0	1,970.9	1.0	7.90	1	1	1
01/30/2022 07:00	2.8	13.8	1,493.2	2.3	10.32	1	0	1
01/30/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/30/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/30/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/30/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/30/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/30/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/30/2022 14:00	13.1	18.6	223.8	33.6	6.39	1	0	0
01/30/2022 15:00	24.6	15.8	790.6	28.5	83.00	1	0	0
01/30/2022 16:00	0.8	13.9	1,518.4	0.7	3.00	1	1	0
01/30/2022 17:00	1.3	13.2	1,915.9	1.0	7.70	1	1	1
01/30/2022 18:00	1.4	13.2	1,908.4	1.1	7.60	1	1	1
01/30/2022 19:00	1.3	13.2	1,905.0	1.0	7.60	1	1	1
01/30/2022 20:00	1.6	12.7	2,027.8	1.2	8.10	1	1	1
01/30/2022 21:00	1.3	13.3	1,878.4	1.0	7.50	1	1	1
01/30/2022 22:00	0.7	14.0	1,379.9	0.6	2.80	1	1	0
01/30/2022 23:00	0.7	14.0	1,355.9	0.6	2.70	1	1	0
Average/Sum#:	3.1	14.0	1,571.1	4.3	179.71 #	18 #	15 #	10 #
Minimum:	0.7	12.7	223.8	0.6	2.70	0	0	0
Maximum:	24.6	18.6	2,027.8	33.6	83.00	1	1	1
%SI	25.00	25.00	25.00	25.00	25.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:23 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT2	Unit CT2	UnitOn, TF	NormalOp, TF	Unit CT2
	1 Hour(s)	1 Hour(s)	1 Hour(s)	NOx, Ppmvdc	NOx, Lb	1 Hour(s)	1 Hour(s)	DBOn, TF
				1 Hour(s)	1 Hour(s)			1 Hour(s)
01/31/2022 00:00	0.7	13.9	1,349.4	0.6	2.70	1	1	0
01/31/2022 01:00	0.7	13.9	1,347.3	0.6	2.70	1	1	0
01/31/2022 02:00	0.9	13.9	1,564.4	0.8	4.70	1	1	0
01/31/2022 03:00	0.8	13.9	1,535.5	0.7	3.10	1	1	0
01/31/2022 04:00	0.8	13.9	1,454.8	0.7	2.90	1	1	0
01/31/2022 05:00	0.8	13.9	1,569.4	0.7	3.10	1	1	1
01/31/2022 06:00	1.3	13.0	1,961.3	1.0	7.80	1	1	1
01/31/2022 07:00	1.5	12.9	2,010.6	1.1	8.00	1	1	1
01/31/2022 08:00	1.2	13.3	1,924.6	0.9	5.80	1	1	1
01/31/2022 09:00	0.9	13.9	1,575.0	0.8	4.70	1	1	1
01/31/2022 10:00	0.8	13.9	1,458.7	0.7	2.90	1	1	0
01/31/2022 11:00	0.8	13.9	1,531.3	0.7	3.10	1	1	0
01/31/2022 12:00	0.8	13.9	1,569.9	0.7	3.10	1	1	0
01/31/2022 13:00	0.7	14.0	1,417.0	0.6	2.80	1	1	0
01/31/2022 14:00	0.8	14.0	1,529.0	0.7	4.60	1	1	0
01/31/2022 15:00	1.0	13.9	1,626.5	0.8	4.90	1	1	1
01/31/2022 16:00	1.5	13.0	1,959.3	1.1	7.80	1	1	1
01/31/2022 17:00	1.6	12.6	2,053.2	1.1	8.20	1	1	1
01/31/2022 18:00	1.6	12.6	2,054.9	1.1	8.20	1	1	1
01/31/2022 19:00	1.5	13.2	1,902.2	1.1	7.60	1	1	1
01/31/2022 20:00	0.9	14.0	1,585.7	0.8	4.80	1	1	0
01/31/2022 21:00	1.0	13.9	1,655.2	0.8	5.00	1	1	1
01/31/2022 22:00	1.4	13.1	1,958.9	1.1	7.80	1	1	1
01/31/2022 23:00	3.1	14.5	1,196.9	2.9	6.34	1	0	1
Average/Sum#:	1.1	13.6	1,658.0	0.9	122.64 #	24 #	23 #	13 #
Minimum:	0.7	12.6	1,196.9	0.6	2.70	1	0	0
Maximum:	3.1	14.5	2,054.9	2.9	8.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:23 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT2	Unit CT2	UnitOn, TF	NormalOp, TF	Unit CT2
	1 Hour(s)	1 Hour(s)	1 Hour(s)	NOx, Ppmvdc	NOx, Lb	1 Hour(s)	1 Hour(s)	DBOn, TF
				1 Hour(s)	1 Hour(s)			1 Hour(s)
02/01/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/01/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/01/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/01/2022 03:00	7.7	17.3	446.9	12.6	18.95	1	0	0
02/01/2022 04:00	5.2	14.3	1,264.2	4.6	21.50	1	0	0
02/01/2022 05:00	0.7	14.0	1,317.4	0.6	2.60	1	1	0
02/01/2022 06:00	0.7	14.0	1,286.6	0.6	2.60	1	1	0
02/01/2022 07:00	0.8	13.9	1,640.7	0.7	3.30	1	1	1
02/01/2022 08:00	1.5	11.9	2,272.8	1.0	9.10	1	1	1
02/01/2022 09:00	1.7	11.9	2,265.9	1.1	9.10	1	1	1
02/01/2022 10:00	1.2	13.3	1,829.9	0.9	5.50	1	1	1
02/01/2022 11:00	0.8	14.0	1,540.4	0.7	4.60	1	1	0
02/01/2022 12:00	0.7	14.0	1,288.3	0.6	2.60	1	1	0
02/01/2022 13:00	0.7	14.0	1,288.9	0.6	2.60	1	1	0
02/01/2022 14:00	0.7	14.0	1,289.1	0.6	2.60	1	1	0
02/01/2022 15:00	0.7	14.0	1,311.7	0.6	2.60	1	1	0
02/01/2022 16:00	0.9	13.9	1,527.3	0.8	4.60	1	1	0
02/01/2022 17:00	1.0	13.9	1,781.3	0.8	5.30	1	1	0
02/01/2022 18:00	1.3	13.3	1,896.4	1.0	7.60	1	1	1
02/01/2022 19:00	1.5	13.0	1,993.5	1.1	8.00	1	1	1
02/01/2022 20:00	1.5	13.1	1,949.2	1.1	7.80	1	1	1
02/01/2022 21:00	0.8	13.9	1,582.9	0.7	3.20	1	1	0
02/01/2022 22:00	1.0	13.8	1,760.5	0.8	5.30	1	1	1
02/01/2022 23:00	1.4	13.1	1,987.0	1.1	7.90	1	1	1
Average/Sum#:	1.5	13.7	1,596.2	1.6	137.35 #	21 #	19 #	9 #
Minimum:	0.7	11.9	446.9	0.6	2.60	0	0	0
Maximum:	7.7	17.3	2,272.8	12.6	21.50	1	1	1
%SI	12.50	12.50	12.50	12.50	12.50	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:23 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT2	Unit CT2	UnitOn, TF	NormalOp, TF	Unit CT2
	1 Hour(s)	1 Hour(s)	1 Hour(s)	NOx, Ppmvdc	NOx, Lb	1 Hour(s)	1 Hour(s)	DBOn, TF
				1 Hour(s)	1 Hour(s)			1 Hour(s)
02/02/2022 00:00	1.6	12.6	2,111.6	1.1	8.40	1	1	1
02/02/2022 01:00	1.0	13.8	1,713.4	0.8	5.10	1	1	1
02/02/2022 02:00	0.9	13.9	1,573.4	0.8	4.70	1	1	1
02/02/2022 03:00	1.4	13.2	1,966.6	1.1	7.90	1	1	1
02/02/2022 04:00	1.3	13.3	1,943.0	1.0	7.80	1	1	1
02/02/2022 05:00	1.5	13.1	1,992.0	1.1	8.00	1	1	1
02/02/2022 06:00	1.5	12.8	2,054.2	1.1	8.20	1	1	1
02/02/2022 07:00	1.5	13.0	2,021.5	1.1	8.10	1	1	1
02/02/2022 08:00	1.5	13.1	1,994.1	1.1	8.00	1	1	1
02/02/2022 09:00	1.0	13.7	1,645.1	0.8	4.90	1	1	1
02/02/2022 10:00	0.7	14.0	1,336.7	0.6	2.70	1	1	0
02/02/2022 11:00	0.7	14.0	1,341.3	0.6	2.70	1	1	0
02/02/2022 12:00	0.7	14.0	1,346.6	0.6	2.70	1	1	0
02/02/2022 13:00	0.7	14.0	1,358.1	0.6	2.70	1	1	0
02/02/2022 14:00	0.7	14.0	1,360.7	0.6	2.70	1	1	0
02/02/2022 15:00	1.0	13.9	1,626.5	0.8	4.90	1	1	0
02/02/2022 16:00	0.9	13.9	1,608.5	0.8	4.80	1	1	0
02/02/2022 17:00	1.0	13.8	1,687.2	0.8	5.10	1	1	1
02/02/2022 18:00	1.5	12.8	2,027.7	1.1	8.10	1	1	1
02/02/2022 19:00	1.7	12.1	2,205.2	1.1	8.80	1	1	1
02/02/2022 20:00	1.6	12.0	2,215.8	1.1	8.90	1	1	1
02/02/2022 21:00	1.6	12.4	2,131.5	1.1	8.50	1	1	1
02/02/2022 22:00	1.5	12.7	2,038.4	1.1	8.20	1	1	1
02/02/2022 23:00	1.5	12.9	2,007.3	1.1	8.00	1	1	1
Average/Sum#:	1.2	13.3	1,804.4	0.9	149.90 #	24 #	24 #	17 #
Minimum:	0.7	12.0	1,336.7	0.6	2.70	1	1	0
Maximum:	1.7	14.0	2,215.8	1.1	8.90	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:23 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT2	Unit CT2	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	NOx, Ppmvdc	NOx, Lb	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/03/2022 00:00	1.4	13.3	1,905.8	1.1	7.60	1	1	1
02/03/2022 01:00	0.9	13.9	1,647.6	0.8	4.90	1	1	0
02/03/2022 02:00	0.9	13.9	1,775.6	0.8	5.30	1	1	1
02/03/2022 03:00	1.4	13.0	1,990.0	1.0	8.00	1	1	1
02/03/2022 04:00	1.5	13.1	1,971.2	1.1	7.90	1	1	1
02/03/2022 05:00	1.4	13.1	1,987.1	1.1	7.90	1	1	1
02/03/2022 06:00	1.6	12.4	2,136.7	1.1	8.50	1	1	1
02/03/2022 07:00	1.5	12.7	2,075.7	1.1	8.30	1	1	1
02/03/2022 08:00	1.3	13.3	1,913.9	1.0	7.70	1	1	1
02/03/2022 09:00	0.8	13.9	1,448.4	0.7	2.90	1	1	1
02/03/2022 10:00	0.9	13.9	1,656.2	0.8	5.00	1	1	0
02/03/2022 11:00	0.9	13.9	1,665.7	0.8	5.00	1	1	0
02/03/2022 12:00	0.7	14.0	1,378.1	0.6	2.80	1	1	0
02/03/2022 13:00	0.8	14.0	1,540.7	0.7	4.60	1	1	0
02/03/2022 14:00	0.8	14.0	1,466.2	0.7	4.40	1	1	0
02/03/2022 15:00	1.0	13.9	1,524.7	0.8	4.60	1	1	1
02/03/2022 16:00	1.5	13.0	1,956.6	1.1	7.80	1	1	1
02/03/2022 17:00	1.6	12.7	2,038.7	1.2	8.20	1	1	1
02/03/2022 18:00	1.6	12.5	2,082.2	1.1	8.30	1	1	1
02/03/2022 19:00	1.5	12.5	2,084.0	1.1	8.30	1	1	1
02/03/2022 20:00	1.6	12.5	2,084.4	1.1	8.30	1	1	1
02/03/2022 21:00	1.6	12.3	2,135.7	1.1	8.50	1	1	1
02/03/2022 22:00	1.6	12.6	2,057.7	1.1	8.20	1	1	1
02/03/2022 23:00	1.5	12.8	2,035.7	1.1	8.10	1	1	1
Average/Sum#:	1.3	13.2	1,856.6	1.0	161.10 #	24 #	24 #	18 #
Minimum:	0.7	12.3	1,378.1	0.6	2.80	1	1	0
Maximum:	1.6	14.0	2,136.7	1.2	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:23 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT2	Unit CT2	UnitOn, TF	NormalOp, TF	Unit CT2
	1 Hour(s)	1 Hour(s)	1 Hour(s)	NOx, Ppmvdc	NOx, Lb	1 Hour(s)	1 Hour(s)	DBOn, TF
				1 Hour(s)	1 Hour(s)			1 Hour(s)
02/04/2022 00:00	1.5	12.9	2,000.8	1.1	8.00	1	1	1
02/04/2022 01:00	1.3	13.3	1,899.3	1.0	7.60	1	1	1
02/04/2022 02:00	0.8	13.9	1,596.2	0.7	3.20	1	1	0
02/04/2022 03:00	0.8	13.9	1,527.3	0.7	3.10	1	1	0
02/04/2022 04:00	0.8	13.9	1,582.9	0.7	3.20	1	1	1
02/04/2022 05:00	1.3	13.1	1,975.2	1.0	7.90	1	1	1
02/04/2022 06:00	1.5	12.5	2,117.4	1.1	8.50	1	1	1
02/04/2022 07:00	1.5	12.8	2,032.3	1.1	8.10	1	1	1
02/04/2022 08:00	3.3	14.6	1,184.3	3.1	6.24	1	0	1
02/04/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/04/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/04/2022 11:00	2.5	17.9	332.2	4.9	3.12	1	0	0
02/04/2022 12:00	11.0	15.6	845.9	12.2	38.10	1	0	0
02/04/2022 13:00	0.6	14.0	1,355.6	0.5	2.70	1	1	0
02/04/2022 14:00	0.7	14.0	1,350.1	0.6	2.70	1	1	0
02/04/2022 15:00	0.9	13.9	1,493.6	0.8	4.50	1	1	0
02/04/2022 16:00	0.9	14.0	1,605.4	0.8	4.80	1	1	0
02/04/2022 17:00	0.8	13.9	1,567.7	0.7	3.10	1	1	0
02/04/2022 18:00	0.7	14.0	1,456.5	0.6	2.90	1	1	0
02/04/2022 19:00	1.3	13.3	1,869.9	1.0	7.50	1	1	1
02/04/2022 20:00	1.4	13.2	1,913.9	1.1	7.70	1	1	1
02/04/2022 21:00	1.3	13.3	1,911.2	1.0	7.60	1	1	1
02/04/2022 22:00	1.4	13.2	1,934.0	1.1	7.70	1	1	1
02/04/2022 23:00	1.5	12.9	1,994.0	1.1	8.00	1	1	1
Average/Sum#:	1.7	13.8	1,615.7	1.7	156.26 #	22 #	19 #	12 #
Minimum:	0.6	12.5	332.2	0.5	2.70	0	0	0
Maximum:	11.0	17.9	2,117.4	12.2	38.10	1	1	1
%SI	8.33	8.33	8.33	8.33	8.33	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:23 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/05/2022 00:00	1.3	13.3	1,905.9	1.0	7.60	1	1	1
02/05/2022 01:00	1.0	13.8	1,680.5	0.8	5.00	1	1	1
02/05/2022 02:00	0.7	14.0	1,394.3	0.6	2.80	1	1	0
02/05/2022 03:00	1.2	13.4	1,871.4	0.9	5.60	1	1	1
02/05/2022 04:00	1.2	13.3	1,915.1	0.9	5.70	1	1	1
02/05/2022 05:00	1.0	13.8	1,697.4	0.8	5.10	1	1	1
02/05/2022 06:00	0.9	13.9	1,585.6	0.8	4.80	1	1	1
02/05/2022 07:00	1.5	13.0	1,985.6	1.1	7.90	1	1	1
02/05/2022 08:00	3.2	14.4	1,212.6	2.9	6.38	1	0	1
02/05/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/05/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/05/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/05/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/05/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/05/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/05/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/05/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/05/2022 17:00	24.5	18.0	307.4	49.8	25.47	1	0	0
02/05/2022 18:00	14.7	16.2	689.7	18.5	46.90	1	0	0
02/05/2022 19:00	0.5	14.0	1,294.5	0.4	2.60	1	1	0
02/05/2022 20:00	1.0	13.9	1,548.5	0.8	4.60	1	1	1
02/05/2022 21:00	1.5	12.9	1,984.5	1.1	7.90	1	1	1
02/05/2022 22:00	1.5	12.9	1,998.6	1.1	8.00	1	1	1
02/05/2022 23:00	1.6	12.9	2,002.2	1.2	8.00	1	1	1
Average/Sum#:	3.6	14.0	1,567.1	5.2	154.35 #	16 #	13 #	12 #
Minimum:	0.5	12.9	307.4	0.4	2.60	0	0	0
Maximum:	24.5	18.0	2,002.2	49.8	46.90	1	1	1
%SI	33.33	33.33	33.33	33.33	33.33	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:23 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/06/2022 00:00	1.3	13.3	1,905.9	1.0	7.60	1	1	1
02/06/2022 01:00	0.9	13.9	1,661.5	0.8	5.00	1	1	1
02/06/2022 02:00	0.9	13.9	1,600.0	0.8	4.80	1	1	1
02/06/2022 03:00	1.4	13.1	1,960.0	1.1	7.80	1	1	1
02/06/2022 04:00	1.2	13.3	1,897.3	0.9	5.70	1	1	1
02/06/2022 05:00	0.8	13.9	1,547.6	0.7	3.10	1	1	0
02/06/2022 06:00	0.7	14.0	1,305.9	0.6	2.60	1	1	0
02/06/2022 07:00	0.8	13.9	1,537.9	0.7	3.10	1	1	0
02/06/2022 08:00	4.4	16.1	452.6	5.4	1.64	1	0	0
02/06/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/06/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/06/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/06/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/06/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/06/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/06/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/06/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/06/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/06/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/06/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/06/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/06/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/06/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/06/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	1.4	13.9	1,541.0	1.3	41.34 #	9 #	8 #	5 #
Minimum:	0.7	13.1	452.6	0.6	1.64	0	0	0
Maximum:	4.4	16.1	1,960.0	5.4	7.80	1	1	1
%SI	62.50	62.50	62.50	62.50	62.50	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:23 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/07/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/07/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/07/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/07/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/07/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/07/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/07/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/07/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/07/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/07/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/07/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/07/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/07/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/07/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/07/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/07/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/07/2022 16:00	30.4	17.7	330.2	56.1	47.60	1	0	0
02/07/2022 17:00	14.2	15.7	821.9	16.1	48.50	1	0	0
02/07/2022 18:00	0.6	14.0	1,381.2	0.5	2.80	1	1	0
02/07/2022 19:00	1.0	13.9	1,549.4	0.8	4.60	1	1	1
02/07/2022 20:00	1.5	12.8	2,015.9	1.1	8.10	1	1	1
02/07/2022 21:00	1.6	12.7	2,036.8	1.2	8.10	1	1	1
02/07/2022 22:00	1.6	12.8	2,021.2	1.2	8.10	1	1	1
02/07/2022 23:00	3.4	14.4	1,196.7	3.1	6.34	1	0	1
Average/Sum#:	6.8	14.3	1,419.2	10.0	134.14 #	8 #	5 #	5 #
Minimum:	0.6	12.7	330.2	0.5	2.80	0	0	0
Maximum:	30.4	17.7	2,036.8	56.1	48.50	1	1	1
%SI	66.67	66.67	66.67	66.67	66.67	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:23 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/08/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/08/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/08/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/08/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/08/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/08/2022 05:00	8.8	17.8	330.0	16.7	11.89	1	0	0
02/08/2022 06:00	9.4	15.6	869.8	10.5	33.90	1	0	0
02/08/2022 07:00	0.5	14.0	1,260.1	0.4	2.50	1	1	0
02/08/2022 08:00	0.9	13.8	1,775.9	0.7	5.30	1	1	0
02/08/2022 09:00	1.0	13.8	1,795.8	0.8	5.40	1	1	0
02/08/2022 10:00	1.0	13.7	1,797.2	0.8	5.40	1	1	0
02/08/2022 11:00	1.0	13.7	1,793.5	0.8	5.40	1	1	0
02/08/2022 12:00	1.1	13.7	1,797.8	0.9	5.40	1	1	0
02/08/2022 13:00	1.1	13.7	1,795.4	0.9	5.40	1	1	0
02/08/2022 14:00	1.1	13.7	1,789.5	0.9	5.40	1	1	0
02/08/2022 15:00	1.0	13.8	1,769.9	0.8	5.30	1	1	0
02/08/2022 16:00	1.0	13.8	1,776.5	0.8	5.30	1	1	0
02/08/2022 17:00	1.2	13.3	1,884.8	0.9	5.70	1	1	1
02/08/2022 18:00	1.3	13.1	1,955.6	1.0	7.80	1	1	1
02/08/2022 19:00	1.2	13.2	1,929.8	0.9	5.80	1	1	1
02/08/2022 20:00	1.2	13.2	1,932.3	0.9	5.80	1	1	1
02/08/2022 21:00	1.0	13.6	1,673.9	0.8	5.00	1	1	1
02/08/2022 22:00	2.8	15.1	872.7	2.8	3.65	1	0	0
02/08/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	2.0	14.0	1,600.0	2.4	130.34 #	18 #	15 #	5 #
Minimum:	0.5	13.1	330.0	0.4	2.50	0	0	0
Maximum:	9.4	17.8	1,955.6	16.7	33.90	1	1	1
%SI	25.00	25.00	25.00	25.00	25.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:23 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/09/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/09/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/09/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/09/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/09/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/09/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/09/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/09/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/09/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/09/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/09/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/09/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/09/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/09/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/09/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/09/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/09/2022 16:00	31.3	17.0	499.7	47.4	75.60	1	0	0
02/09/2022 17:00	1.1	13.9	1,657.8	0.9	5.00	1	0	0
02/09/2022 18:00	1.1	13.7	1,788.3	0.9	5.40	1	1	1
02/09/2022 19:00	1.3	13.0	1,967.4	1.0	7.90	1	1	1
02/09/2022 20:00	1.4	12.8	2,033.7	1.0	8.10	1	1	1
02/09/2022 21:00	1.4	12.8	2,036.9	1.0	8.10	1	1	1
02/09/2022 22:00	1.3	13.0	1,977.7	1.0	7.90	1	1	1
02/09/2022 23:00	0.9	13.8	1,504.7	0.7	4.50	1	1	1
Average/Sum#:	5.0	13.8	1,683.3	6.7	122.50 #	8 #	6 #	6 #
Minimum:	0.9	12.8	499.7	0.7	4.50	0	0	0
Maximum:	31.3	17.0	2,036.9	47.4	75.60	1	1	1
%SI	66.67	66.67	66.67	66.67	66.67	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:23 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/10/2022 00:00	0.7	14.0	1,343.6	0.6	2.70	1	1	0
02/10/2022 01:00	1.0	13.9	1,574.3	0.8	4.70	1	1	1
02/10/2022 02:00	1.3	13.1	1,933.0	1.0	7.70	1	1	1
02/10/2022 03:00	1.3	13.1	1,940.8	1.0	7.80	1	1	1
02/10/2022 04:00	0.8	13.9	1,581.8	0.7	3.20	1	1	1
02/10/2022 05:00	0.9	13.9	1,576.2	0.8	4.70	1	1	1
02/10/2022 06:00	1.4	12.7	2,014.9	1.0	8.10	1	1	1
02/10/2022 07:00	1.4	12.8	1,986.6	1.0	7.90	1	1	1
02/10/2022 08:00	5.2	15.7	599.4	5.9	3.04	1	0	0
02/10/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/10/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/10/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/10/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/10/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/10/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/10/2022 15:00	2.0	19.1	97.3	6.6	0.33	1	0	0
02/10/2022 16:00	21.5	15.8	779.3	24.9	71.70	1	0	0
02/10/2022 17:00	0.8	13.5	1,535.8	0.6	3.10	1	1	1
02/10/2022 18:00	1.7	11.9	2,195.2	1.1	8.80	1	1	1
02/10/2022 19:00	1.7	12.1	2,169.8	1.1	8.70	1	1	1
02/10/2022 20:00	1.6	12.3	2,100.9	1.1	8.40	1	1	1
02/10/2022 21:00	1.5	12.8	1,999.4	1.1	8.00	1	1	1
02/10/2022 22:00	1.4	12.9	1,974.2	1.0	7.90	1	1	1
02/10/2022 23:00	0.9	13.7	1,499.0	0.7	4.50	1	1	1
Average/Sum#:	2.6	13.7	1,605.6	2.8	171.27 #	18 #	15 #	14 #
Minimum:	0.7	11.9	97.3	0.6	0.33	0	0	0
Maximum:	21.5	19.1	2,195.2	24.9	71.70	1	1	1
%SI	25.00	25.00	25.00	25.00	25.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:23 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/11/2022 00:00	0.6	14.0	1,272.7	0.5	2.50	1	1	0
02/11/2022 01:00	8.6	16.7	264.2	12.1	1.55	1	0	0
02/11/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/11/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/11/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/11/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/11/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/11/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/11/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/11/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/11/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/11/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/11/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/11/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/11/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/11/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/11/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/11/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/11/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/11/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/11/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/11/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/11/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/11/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	4.6	15.4	768.5	6.3	4.05 #	2 #	1 #	0 #
Minimum:	0.6	14.0	264.2	0.5	1.55	0	0	0
Maximum:	8.6	16.7	1,272.7	12.1	2.50	1	1	0
%SI	91.67	91.67	91.67	91.67	91.67	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:23 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/12/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/12/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/12/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/12/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/12/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/12/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/12/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/12/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/12/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/12/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/12/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/12/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/12/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/12/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/12/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/12/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/12/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/12/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/12/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/12/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/12/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/12/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/12/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/12/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:23 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/13/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/13/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/13/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/13/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/13/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/13/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/13/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/13/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/13/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/13/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/13/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/13/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/13/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/13/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/13/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/13/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/13/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/13/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/13/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/13/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/13/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/13/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/13/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/13/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:23 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/14/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/14/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/14/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/14/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/14/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/14/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/14/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/14/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/14/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/14/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/14/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/14/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/14/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/14/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/14/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/14/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/14/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/14/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/14/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/14/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/14/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/14/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/14/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/14/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:23 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/15/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:23 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/16/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/16/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/16/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/16/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/16/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/16/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/16/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/16/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/16/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/16/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/16/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/16/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/16/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/16/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/16/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/16/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/16/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/16/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/16/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/16/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/16/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/16/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/16/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/16/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:23 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/17/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/17/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/17/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/17/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/17/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/17/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/17/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/17/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/17/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/17/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/17/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/17/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/17/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/17/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/17/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/17/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/17/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/17/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/17/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/17/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/17/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/17/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/17/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/17/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:23 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/18/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/18/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/18/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/18/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/18/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/18/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/18/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/18/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/18/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/18/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/18/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/18/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/18/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/18/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/18/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/18/2022 15:00	37.7	17.7	334.1	69.5	79.52	1	0	0
02/18/2022 16:00	21.0	15.4	875.8	22.5	72.70	1	0	0
02/18/2022 17:00	0.8	14.0	1,609.4	0.7	4.80	1	1	0
02/18/2022 18:00	1.0	13.9	1,553.7	0.8	4.70	1	1	1
02/18/2022 19:00	1.5	13.1	1,972.3	1.1	7.90	1	1	1
02/18/2022 20:00	1.3	13.2	1,907.0	1.0	7.60	1	1	1
02/18/2022 21:00	0.9	13.9	1,533.5	0.8	4.60	1	1	0
02/18/2022 22:00	0.9	13.9	1,562.7	0.8	4.70	1	1	1
02/18/2022 23:00	1.5	13.1	1,965.8	1.1	7.90	1	1	1
Average/Sum#:	7.4	14.2	1,479.4	10.9	194.42 #	9 #	7 #	5 #
Minimum:	0.8	13.1	334.1	0.7	4.60	0	0	0
Maximum:	37.7	17.7	1,972.3	69.5	79.52	1	1	1
%SI	62.50	62.50	62.50	62.50	62.50	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:23 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/19/2022 00:00	3.3	14.5	1,208.5	3.0	6.38	1	0	1
02/19/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/19/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/19/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/19/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/19/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/19/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/19/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/19/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/19/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/19/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/19/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/19/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/19/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/19/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/19/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/19/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/19/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/19/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/19/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/19/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/19/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/19/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/19/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	3.3	14.5	1,208.5	3.0	6.38 #	1 #	0 #	1 #
Minimum:	3.3	14.5	1,208.5	3.0	6.38	0	0	0
Maximum:	3.3	14.5	1,208.5	3.0	6.38	1	0	1
%SI	95.83	95.83	95.83	95.83	95.83	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:23 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/20/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/20/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/20/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/20/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/20/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/20/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/20/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/20/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/20/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/20/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/20/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/20/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/20/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/20/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/20/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/20/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/20/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/20/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/20/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/20/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/20/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/20/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/20/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/20/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:23 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/21/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/21/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/21/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/21/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/21/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/21/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/21/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/21/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/21/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/21/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/21/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/21/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/21/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/21/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/21/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/21/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/21/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/21/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/21/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/21/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/21/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/21/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/21/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/21/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:23 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT2	Unit CT2	UnitOn, TF	NormalOp, TF	Unit CT2
	1 Hour(s)	1 Hour(s)	1 Hour(s)	NOx, Ppmvdc	NOx, Lb	1 Hour(s)	1 Hour(s)	DBOn, TF
				1 Hour(s)	1 Hour(s)			1 Hour(s)
02/22/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/22/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/22/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/22/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/22/2022 04:00	27.0	17.9	299.7	53.1	32.29	1	0	0
02/22/2022 05:00	22.0	15.8	820.3	25.5	77.10	1	0	0
02/22/2022 06:00	0.8	13.9	1,706.2	0.7	3.40	1	1	0
02/22/2022 07:00	0.8	13.9	1,559.6	0.7	3.10	1	1	0
02/22/2022 08:00	0.8	13.9	1,615.1	0.7	3.20	1	1	0
02/22/2022 09:00	0.8	13.9	1,516.2	0.7	3.00	1	1	0
02/22/2022 10:00	0.8	14.0	1,499.6	0.7	4.50	1	1	0
02/22/2022 11:00	0.8	14.0	1,499.1	0.7	4.50	1	1	0
02/22/2022 12:00	0.8	14.0	1,574.7	0.7	4.70	1	1	0
02/22/2022 13:00	0.8	14.0	1,563.0	0.7	4.70	1	1	0
02/22/2022 14:00	0.8	13.9	1,577.7	0.7	3.20	1	1	0
02/22/2022 15:00	0.8	13.9	1,591.5	0.7	3.20	1	1	0
02/22/2022 16:00	0.8	13.9	1,599.1	0.7	3.20	1	1	1
02/22/2022 17:00	1.4	13.0	2,008.1	1.0	8.00	1	1	1
02/22/2022 18:00	1.4	12.9	2,019.2	1.0	8.10	1	1	1
02/22/2022 19:00	1.6	12.7	2,097.9	1.2	8.40	1	1	1
02/22/2022 20:00	1.7	12.1	2,214.7	1.1	8.90	1	1	1
02/22/2022 21:00	1.6	12.7	2,085.3	1.2	8.30	1	1	1
02/22/2022 22:00	1.6	12.7	2,079.8	1.2	8.30	1	1	1
02/22/2022 23:00	1.6	12.5	2,128.8	1.1	8.50	1	1	1
Average/Sum#:	3.4	13.8	1,652.8	4.7	208.59 #	20 #	18 #	8 #
Minimum:	0.8	12.1	299.7	0.7	3.00	0	0	0
Maximum:	27.0	17.9	2,214.7	53.1	77.10	1	1	1
%SI	16.67	16.67	16.67	16.67	16.67	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:23 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT2	Unit CT2	UnitOn, TF	NormalOp, TF	Unit CT2
	1 Hour(s)	1 Hour(s)	1 Hour(s)	NOx, Ppmvdc	NOx, Lb	1 Hour(s)	1 Hour(s)	DBOn, TF
				1 Hour(s)	1 Hour(s)			1 Hour(s)
02/23/2022 00:00	1.7	12.3	2,198.7	1.2	8.80	1	1	1
02/23/2022 01:00	1.6	12.5	2,149.8	1.1	8.60	1	1	1
02/23/2022 02:00	1.6	12.6	2,132.6	1.1	8.50	1	1	1
02/23/2022 03:00	1.5	12.9	2,016.1	1.1	8.10	1	1	1
02/23/2022 04:00	0.8	13.9	1,684.9	0.7	3.40	1	1	0
02/23/2022 05:00	1.0	13.6	1,844.4	0.8	5.50	1	1	1
02/23/2022 06:00	1.5	12.5	2,156.2	1.1	8.60	1	1	1
02/23/2022 07:00	1.6	12.5	2,157.1	1.1	8.60	1	1	1
02/23/2022 08:00	0.9	13.8	1,676.2	0.7	5.00	1	1	1
02/23/2022 09:00	0.8	14.0	1,522.7	0.7	4.60	1	1	0
02/23/2022 10:00	0.8	14.0	1,577.8	0.7	4.70	1	1	0
02/23/2022 11:00	0.8	13.9	1,639.3	0.7	3.30	1	1	0
02/23/2022 12:00	0.8	14.0	1,511.7	0.7	4.50	1	1	0
02/23/2022 13:00	0.7	14.0	1,415.6	0.6	2.80	1	1	0
02/23/2022 14:00	0.8	14.0	1,619.6	0.7	4.90	1	1	0
02/23/2022 15:00	0.8	14.0	1,587.3	0.7	4.80	1	1	0
02/23/2022 16:00	0.8	14.0	1,611.3	0.7	4.80	1	1	1
02/23/2022 17:00	1.4	13.1	1,977.6	1.1	7.90	1	1	1
02/23/2022 18:00	1.5	13.0	2,007.4	1.1	8.00	1	1	1
02/23/2022 19:00	1.5	13.1	2,007.7	1.1	8.00	1	1	1
02/23/2022 20:00	1.6	12.7	2,106.4	1.2	8.40	1	1	1
02/23/2022 21:00	1.7	12.1	2,235.4	1.1	8.90	1	1	1
02/23/2022 22:00	1.6	12.6	2,124.7	1.1	8.50	1	1	1
02/23/2022 23:00	1.6	12.9	2,085.2	1.2	8.30	1	1	1
Average/Sum#:	1.2	13.3	1,876.9	0.9	157.50 #	24 #	24 #	16 #
Minimum:	0.7	12.1	1,415.6	0.6	2.80	1	1	0
Maximum:	1.7	14.0	2,235.4	1.2	8.90	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:23 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT2	Unit CT2	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	NOx, Ppmvdc	NOx, Lb	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/24/2022 00:00	1.6	12.3	2,203.4	1.1	8.80	1	1	1
02/24/2022 01:00	1.6	12.3	2,197.9	1.1	8.80	1	1	1
02/24/2022 02:00	1.6	12.3	2,214.0	1.1	8.90	1	1	1
02/24/2022 03:00	1.7	12.1	2,239.1	1.1	9.00	1	1	1
02/24/2022 04:00	1.6	12.3	2,239.6	1.1	9.00	1	1	1
02/24/2022 05:00	1.7	12.2	2,242.3	1.2	9.00	1	1	1
02/24/2022 06:00	1.6	12.2	2,243.8	1.1	9.00	1	1	1
02/24/2022 07:00	1.6	12.5	2,177.8	1.1	8.70	1	1	1
02/24/2022 08:00	1.5	13.1	2,036.2	1.1	8.10	1	1	1
02/24/2022 09:00	1.4	13.3	1,952.9	1.1	7.80	1	1	1
02/24/2022 10:00	0.8	13.9	1,561.0	0.7	3.10	1	1	0
02/24/2022 11:00	0.7	14.0	1,430.3	0.6	2.90	1	1	0
02/24/2022 12:00	0.7	14.0	1,331.4	0.6	2.70	1	1	0
02/24/2022 13:00	0.7	14.0	1,379.1	0.6	2.80	1	1	0
02/24/2022 14:00	0.8	14.0	1,460.6	0.7	4.40	1	1	0
02/24/2022 15:00	0.8	14.0	1,456.1	0.7	4.40	1	1	0
02/24/2022 16:00	0.9	13.9	1,561.9	0.8	4.70	1	1	1
02/24/2022 17:00	1.5	13.1	1,974.4	1.1	7.90	1	1	1
02/24/2022 18:00	1.6	12.4	2,172.5	1.1	8.70	1	1	1
02/24/2022 19:00	1.7	12.2	2,214.2	1.2	8.90	1	1	1
02/24/2022 20:00	1.6	12.4	2,164.0	1.1	8.70	1	1	1
02/24/2022 21:00	1.6	12.3	2,189.9	1.1	8.80	1	1	1
02/24/2022 22:00	1.6	12.4	2,186.1	1.1	8.70	1	1	1
02/24/2022 23:00	1.6	12.6	2,143.6	1.1	8.60	1	1	1
Average/Sum#:	1.4	12.9	1,957.2	1.0	172.40 #	24 #	24 #	18 #
Minimum:	0.7	12.1	1,331.4	0.6	2.70	1	1	0
Maximum:	1.7	14.0	2,243.8	1.2	9.00	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:23 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT2	Unit CT2	UnitOn, TF	NormalOp, TF	Unit CT2
	1 Hour(s)	1 Hour(s)	1 Hour(s)	NOx, Ppmvdc	NOx, Lb	1 Hour(s)	1 Hour(s)	DBOn, TF
				1 Hour(s)	1 Hour(s)			1 Hour(s)
02/25/2022 00:00	1.5	12.9	2,050.8	1.1	8.20	1	1	1
02/25/2022 01:00	1.5	13.1	2,002.0	1.1	8.00	1	1	1
02/25/2022 02:00	1.5	13.1	1,999.0	1.1	8.00	1	1	1
02/25/2022 03:00	1.5	13.1	2,000.8	1.1	8.00	1	1	1
02/25/2022 04:00	1.5	13.0	2,040.3	1.1	8.20	1	1	1
02/25/2022 05:00	1.5	13.1	2,008.1	1.1	8.00	1	1	1
02/25/2022 06:00	1.5	12.5	2,161.3	1.1	8.60	1	1	1
02/25/2022 07:00	1.4	13.1	2,021.7	1.1	8.10	1	1	1
02/25/2022 08:00	1.3	13.4	1,923.1	1.0	7.70	1	1	1
02/25/2022 09:00	0.8	14.0	1,512.8	0.7	4.50	1	1	0
02/25/2022 10:00	0.8	14.0	1,504.3	0.7	4.50	1	1	0
02/25/2022 11:00	0.8	14.0	1,606.9	0.7	4.80	1	1	0
02/25/2022 12:00	0.8	14.0	1,587.5	0.7	4.80	1	1	0
02/25/2022 13:00	0.8	14.0	1,599.2	0.7	4.80	1	1	0
02/25/2022 14:00	0.8	14.0	1,575.8	0.7	4.70	1	1	0
02/25/2022 15:00	0.8	14.0	1,552.1	0.7	4.70	1	1	0
02/25/2022 16:00	1.0	13.9	1,641.1	0.8	4.90	1	1	1
02/25/2022 17:00	1.3	13.1	1,994.9	1.0	8.00	1	1	1
02/25/2022 18:00	1.3	13.2	1,938.0	1.0	7.80	1	1	1
02/25/2022 19:00	1.4	13.3	1,921.8	1.1	7.70	1	1	1
02/25/2022 20:00	1.4	13.2	1,958.0	1.1	7.80	1	1	1
02/25/2022 21:00	1.5	13.0	1,986.5	1.1	7.90	1	1	1
02/25/2022 22:00	1.5	12.9	2,022.4	1.1	8.10	1	1	1
02/25/2022 23:00	1.5	13.0	2,029.4	1.1	8.10	1	1	1
Average/Sum#:	1.2	13.4	1,859.9	1.0	165.90 #	24 #	24 #	17 #
Minimum:	0.8	12.5	1,504.3	0.7	4.50	1	1	0
Maximum:	1.5	14.0	2,161.3	1.1	8.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:23 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/26/2022 00:00	1.5	12.9	2,058.5	1.1	8.20	1	1	1
02/26/2022 01:00	1.6	12.9	2,059.7	1.2	8.20	1	1	1
02/26/2022 02:00	1.3	13.3	1,936.3	1.0	7.70	1	1	1
02/26/2022 03:00	1.2	13.4	1,932.8	0.9	5.80	1	1	1
02/26/2022 04:00	1.5	13.1	2,008.5	1.1	8.00	1	1	1
02/26/2022 05:00	1.5	13.1	2,006.2	1.1	8.00	1	1	1
02/26/2022 06:00	1.4	13.2	1,994.2	1.1	8.00	1	1	1
02/26/2022 07:00	3.1	14.6	1,200.5	2.9	6.34	1	0	1
02/26/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/26/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/26/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/26/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/26/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/26/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/26/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/26/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/26/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/26/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/26/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/26/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/26/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/26/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/26/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/26/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	1.6	13.3	1,899.6	1.3	60.24 #	8 #	7 #	8 #
Minimum:	1.2	12.9	1,200.5	0.9	5.80	0	0	0
Maximum:	3.1	14.6	2,059.7	2.9	8.20	1	1	1
%SI	66.67	66.67	66.67	66.67	66.67	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:23 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/27/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/27/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/27/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/27/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/27/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/27/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/27/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/27/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/27/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/27/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/27/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/27/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/27/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/27/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/27/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/27/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/27/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/27/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/27/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/27/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/27/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/27/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/27/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/27/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:23 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/28/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/28/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/28/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/28/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/28/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/28/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/28/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/28/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/28/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/28/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/28/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/28/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/28/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/28/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/28/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/28/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/28/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/28/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/28/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/28/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/28/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/28/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/28/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/28/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:23 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/01/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/01/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/01/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/01/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/01/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/01/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/01/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/01/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/01/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/01/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/01/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/01/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/01/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/01/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/01/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/01/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/01/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/01/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/01/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/01/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/01/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/01/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/01/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/01/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:23 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/02/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/02/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/02/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/02/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/02/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/02/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/02/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/02/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/02/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/02/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/02/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/02/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/02/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/02/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/02/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/02/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/02/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/02/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/02/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/02/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/02/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/02/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/02/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/02/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:23 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/03/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/03/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/03/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/03/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/03/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/03/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/03/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/03/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/03/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/03/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/03/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/03/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/03/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/03/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/03/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/03/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/03/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/03/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/03/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/03/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/03/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/03/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/03/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/03/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:23 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/04/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/04/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/04/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/04/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/04/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/04/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/04/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/04/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/04/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/04/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/04/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/04/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/04/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/04/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/04/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/04/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/04/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/04/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/04/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/04/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/04/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/04/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/04/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/04/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:23 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/05/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/05/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/05/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/05/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/05/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/05/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/05/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/05/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/05/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/05/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/05/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/05/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/05/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/05/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/05/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/05/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/05/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/05/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/05/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/05/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/05/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/05/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/05/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/05/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:23 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/06/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/06/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/06/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/06/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/06/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/06/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/06/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/06/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/06/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/06/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/06/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/06/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/06/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/06/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/06/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/06/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/06/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/06/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/06/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/06/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/06/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/06/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/06/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/06/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:23 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/07/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:23 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/08/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:23 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/09/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/09/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/09/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/09/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/09/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/09/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/09/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/09/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/09/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/09/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/09/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/09/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/09/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/09/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/09/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/09/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/09/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/09/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/09/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/09/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/09/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/09/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/09/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/09/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:23 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/10/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/10/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/10/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/10/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/10/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/10/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/10/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/10/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/10/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/10/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/10/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/10/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/10/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/10/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/10/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/10/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/10/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/10/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/10/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/10/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/10/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/10/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/10/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/10/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:23 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/11/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/11/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/11/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/11/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/11/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/11/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/11/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/11/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/11/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/11/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/11/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/11/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/11/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/11/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/11/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/11/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/11/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/11/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/11/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/11/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/11/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/11/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/11/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/11/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:23 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/12/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/12/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/12/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/12/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/12/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/12/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/12/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/12/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/12/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/12/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/12/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/12/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/12/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/12/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/12/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/12/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/12/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/12/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/12/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/12/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/12/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/12/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/12/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/12/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:23 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/13/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/13/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/13/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/13/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/13/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/13/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/13/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/13/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/13/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/13/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/13/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/13/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/13/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/13/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/13/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/13/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/13/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/13/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/13/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/13/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/13/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/13/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/13/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/13/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:23 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/14/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/14/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/14/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/14/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/14/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/14/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/14/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/14/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/14/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/14/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/14/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/14/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/14/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/14/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/14/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/14/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/14/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/14/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/14/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/14/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/14/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/14/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/14/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/14/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:23 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/15/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/15/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/15/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/15/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/15/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/15/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/15/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/15/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/15/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/15/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/15/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/15/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/15/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/15/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/15/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/15/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/15/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/15/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/15/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/15/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/15/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/15/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/15/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/15/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:23 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/16/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/16/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/16/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/16/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/16/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/16/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/16/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/16/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/16/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/16/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/16/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/16/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/16/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/16/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/16/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/16/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/16/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/16/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/16/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/16/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/16/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/16/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/16/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/16/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:23 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/17/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/17/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/17/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/17/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/17/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/17/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/17/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/17/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/17/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/17/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/17/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/17/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/17/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/17/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/17/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/17/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/17/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/17/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/17/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/17/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/17/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/17/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/17/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/17/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:23 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/18/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/18/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/18/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/18/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/18/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/18/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/18/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/18/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/18/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/18/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/18/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/18/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/18/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/18/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/18/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/18/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/18/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/18/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/18/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/18/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/18/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/18/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/18/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/18/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:23 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/19/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/19/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/19/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/19/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/19/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/19/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/19/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/19/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/19/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/19/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/19/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/19/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/19/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/19/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/19/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/19/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/19/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/19/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/19/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/19/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/19/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/19/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/19/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/19/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:23 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/20/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/20/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/20/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/20/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/20/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/20/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/20/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/20/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/20/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/20/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/20/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/20/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/20/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/20/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/20/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/20/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/20/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/20/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/20/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/20/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/20/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/20/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/20/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/20/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:23 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/21/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/21/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/21/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/21/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/21/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/21/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/21/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/21/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/21/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/21/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/21/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/21/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/21/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/21/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/21/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/21/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/21/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/21/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/21/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/21/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/21/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/21/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/21/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/21/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:23 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/22/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/22/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/22/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/22/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/22/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/22/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/22/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/22/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/22/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/22/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/22/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/22/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/22/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/22/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/22/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/22/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/22/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/22/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/22/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/22/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/22/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/22/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/22/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/22/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:23 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/23/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:23 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/24/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:23 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/25/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:23 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/26/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:23 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/27/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:23 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/28/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/28/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/28/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/28/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/28/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/28/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/28/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/28/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/28/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/28/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/28/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/28/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/28/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/28/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/28/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/28/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/28/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/28/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/28/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/28/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/28/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/28/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/28/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/28/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:23 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/29/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/29/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/29/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/29/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/29/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/29/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/29/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/29/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/29/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/29/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/29/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/29/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/29/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/29/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/29/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/29/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/29/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/29/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/29/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/29/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/29/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/29/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/29/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/29/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:23 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/30/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/30/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/30/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/30/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/30/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/30/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/30/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/30/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/30/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/30/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/30/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/30/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/30/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/30/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/30/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/30/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/30/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/30/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/30/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/30/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/30/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/30/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/30/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/30/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/07/2022 10:23 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/31/2022 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/31/2022 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/31/2022 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/31/2022 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/31/2022 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/31/2022 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/31/2022 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/31/2022 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/31/2022 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/31/2022 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/31/2022 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/31/2022 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/31/2022 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/31/2022 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/31/2022 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/31/2022 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/31/2022 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/31/2022 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/31/2022 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/31/2022 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/31/2022 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/31/2022 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/31/2022 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/31/2022 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

ATTACHMENT 7
Hourly Emissions CO

FCD:	AQ-16
Title V:	#6

Daily Summary Report

CT1 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:07 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit Unit CT1	> Limit Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/01/2022 00:00	1.2	13.2	1,957.7	0.8	4.0	1	1	1
01/01/2022 01:00	0.6	13.8	1,625.0	0.8	1.8	1	1	0
01/01/2022 02:00	0.7	13.8	1,573.4	0.7	2.0	1	1	0
01/01/2022 03:00	0.5	13.8	1,785.8	0.5	1.7	1	1	0
01/01/2022 04:00	0.9	13.5	1,893.3	0.6	3.0	1	1	1
01/01/2022 05:00	1.0	13.4	1,886.5	0.6	3.3	1	1	1
01/01/2022 06:00	0.6	13.8	1,842.7	0.7	2.1	1	1	1
01/01/2022 07:00	1.4	13.1	2,020.3	0.8	4.8	1	1	1
01/01/2022 08:00	0.9	13.5	1,708.7	0.8	2.7	1	1	1
01/01/2022 09:00	0.8	13.9	1,380.9	0.8	2.1	1	0	0
01/01/2022 10:00	0.8	13.9	1,383.4	0.7	2.1	1	0	0
01/01/2022 11:00	0.7	13.9	1,382.8	0.7	1.8	1	0	0
01/01/2022 12:00	0.7	13.9	1,383.6	0.6	1.8	1	0	0
01/01/2022 13:00	0.7	13.9	1,379.6	0.6	1.8	1	0	0
01/01/2022 14:00	0.7	13.9	1,379.9	0.6	1.8	1	0	0
01/01/2022 15:00	0.7	13.9	1,372.4	0.6	1.8	1	0	0
01/01/2022 16:00	0.6	13.8	1,611.2	0.6	1.8	1	0	0
01/01/2022 17:00	0.7	13.8	1,591.0	0.6	2.1	1	0	0
01/01/2022 18:00	0.5	13.8	1,804.9	0.5	1.7	1	1	0
01/01/2022 19:00	0.6	13.8	1,840.4	0.5	2.1	1	1	1
01/01/2022 20:00	1.3	12.6	2,128.6	0.6	4.4	1	1	1
01/01/2022 21:00	1.3	12.4	2,173.5	0.8	4.4	1	1	1
01/01/2022 22:00	1.3	12.5	2,153.3	0.9	4.4	1	1	1
01/01/2022 23:00	1.2	12.7	2,129.5	0.9	4.1	1	1	1
Average/Sum#:	0.9	13.5	1,724.5	0.7	63.6 #	24 #	15 #	11 #
Minimum:	0.5	12.4	1,372.4	0.5	1.7	1	0	0
Maximum:	1.4	13.9	2,173.5	0.9	4.8	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:07 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit Unit CT1	> Limit Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/02/2022 00:00	1.2	13.1	1,982.7	0.9	4.0	1	1	1
01/02/2022 01:00	0.7	13.8	1,551.6	0.8	2.0	1	1	0
01/02/2022 02:00	0.8	13.8	1,427.9	0.7	2.1	1	1	0
01/02/2022 03:00	0.5	13.8	1,760.9	0.6	1.6	1	1	0
01/02/2022 04:00	1.3	13.5	1,886.7	0.7	4.4	1	1	1
01/02/2022 05:00	1.0	13.5	1,898.5	0.7	3.4	1	1	1
01/02/2022 06:00	0.5	13.8	1,823.1	0.7	1.7	1	1	1
01/02/2022 07:00	1.2	13.1	2,021.6	0.7	4.1	1	1	1
01/02/2022 08:00	0.9	13.5	1,708.5	0.7	2.7	1	1	1
01/02/2022 09:00	0.8	13.8	1,424.2	0.8	2.1	1	0	0
01/02/2022 10:00	0.9	13.9	1,406.9	0.7	2.4	1	0	0
01/02/2022 11:00	0.8	13.9	1,368.6	0.7	2.1	1	0	0
01/02/2022 12:00	0.8	13.9	1,367.5	0.7	2.1	1	0	0
01/02/2022 13:00	0.8	13.9	1,367.2	0.7	2.1	1	0	0
01/02/2022 14:00	0.8	13.9	1,366.9	0.7	2.1	1	0	0
01/02/2022 15:00	0.8	13.9	1,379.2	0.7	2.1	1	0	0
01/02/2022 16:00	0.6	13.8	1,673.4	0.6	1.9	1	0	0
01/02/2022 17:00	0.7	13.8	1,591.9	0.6	2.1	1	0	0
01/02/2022 18:00	0.7	13.7	1,806.6	0.6	2.3	1	1	1
01/02/2022 19:00	1.5	12.7	2,081.2	0.8	5.0	1	1	1
01/02/2022 20:00	1.3	12.1	2,217.4	0.9	4.3	1	1	1
01/02/2022 21:00	1.2	12.5	2,119.6	0.9	4.0	1	1	1
01/02/2022 22:00	1.2	12.6	2,112.3	0.9	4.0	1	1	1
01/02/2022 23:00	1.2	13.0	2,017.9	0.9	4.0	1	1	1
Average/Sum#:	0.9	13.5	1,723.4	0.7	68.6 #	24 #	15 #	12 #
Minimum:	0.5	12.1	1,366.9	0.6	1.6	1	0	0
Maximum:	1.5	13.9	2,217.4	0.9	5.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit Unit CT1	> Limit Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/03/2022 00:00	1.2	13.2	1,942.9	0.9	4.0	1	1	1
01/03/2022 01:00	0.6	13.8	1,660.6	0.8	1.9	1	1	0
01/03/2022 02:00	0.7	13.7	1,684.7	0.7	2.2	1	1	1
01/03/2022 03:00	1.0	13.0	2,014.4	0.6	3.4	1	1	1
01/03/2022 04:00	1.0	13.1	2,006.1	0.7	3.4	1	1	1
01/03/2022 05:00	1.1	12.7	2,083.5	0.8	3.7	1	1	1
01/03/2022 06:00	1.1	11.9	2,281.8	0.8	3.7	1	1	1
01/03/2022 07:00	1.2	12.5	2,113.7	0.8	4.0	1	1	1
01/03/2022 08:00	1.3	13.0	2,014.6	0.8	4.4	1	1	1
01/03/2022 09:00	1.4	13.2	1,959.7	1.0	4.7	1	1	1
01/03/2022 10:00	0.6	13.8	1,713.6	0.9	1.9	1	1	1
01/03/2022 11:00	0.9	13.8	1,438.6	0.8	2.4	1	1	0
01/03/2022 12:00	0.6	13.8	1,753.3	0.6	2.0	1	1	0
01/03/2022 13:00	1.1	13.3	1,873.5	0.7	3.6	1	1	1
01/03/2022 14:00	1.3	13.1	1,894.6	0.8	4.2	1	1	1
01/03/2022 15:00	0.6	13.8	1,651.7	0.8	1.8	1	1	0
01/03/2022 16:00	1.2	13.2	1,909.8	0.8	3.9	1	1	1
01/03/2022 17:00	1.3	12.3	2,124.4	0.8	4.2	1	1	1
01/03/2022 18:00	1.3	12.1	2,160.0	0.9	4.2	1	1	1
01/03/2022 19:00	1.2	11.9	2,205.8	0.9	3.9	1	1	1
01/03/2022 20:00	1.2	12.4	2,093.2	0.8	3.9	1	1	1
01/03/2022 21:00	1.2	12.6	2,050.5	0.8	3.9	1	1	1
01/03/2022 22:00	1.2	13.0	1,965.8	0.9	3.9	1	1	1
01/03/2022 23:00	1.1	12.7	2,048.0	0.9	3.6	1	1	1
Average/Sum#:	1.1	13.0	1,943.5	0.8	82.8 #	24 #	24 #	20 #
Minimum:	0.6	11.9	1,438.6	0.6	1.8	1	1	0
Maximum:	1.4	13.8	2,281.8	1.0	4.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:07 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit Unit CT1	> Limit Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/04/2022 00:00	1.2	12.6	2,031.7	0.9	3.9	1	1	1
01/04/2022 01:00	0.6	13.8	1,562.2	0.7	1.7	1	1	0
01/04/2022 02:00	0.6	13.7	1,676.4	0.6	1.8	1	1	1
01/04/2022 03:00	1.3	13.1	1,938.3	0.7	4.3	1	1	1
01/04/2022 04:00	1.2	13.0	1,951.7	0.8	3.9	1	1	1
01/04/2022 05:00	0.5	13.8	1,671.4	0.8	1.6	1	1	0
01/04/2022 06:00	0.5	13.7	1,788.3	0.6	1.6	1	1	0
01/04/2022 07:00	1.2	12.9	1,995.6	0.6	4.0	1	1	1
01/04/2022 08:00	1.1	12.8	2,026.0	0.7	3.6	1	1	1
01/04/2022 09:00	1.2	13.2	1,953.1	0.9	4.0	1	1	1
01/04/2022 10:00	0.8	13.7	1,452.8	0.8	2.1	1	1	1
01/04/2022 11:00	0.9	13.8	1,347.2	0.8	2.3	1	1	0
01/04/2022 12:00	0.6	13.8	1,727.0	0.6	1.9	1	1	0
01/04/2022 13:00	0.8	13.5	1,826.9	0.6	2.6	1	1	1
01/04/2022 14:00	1.1	13.3	1,822.9	0.7	3.5	1	1	1
01/04/2022 15:00	0.7	13.8	1,587.7	0.7	2.1	1	1	0
01/04/2022 16:00	1.3	12.8	2,011.5	0.8	4.3	1	1	1
01/04/2022 17:00	1.3	12.2	2,155.4	0.8	4.3	1	1	1
01/04/2022 18:00	1.2	12.1	2,178.4	0.9	3.9	1	1	1
01/04/2022 19:00	1.2	12.2	2,160.5	0.8	3.9	1	1	1
01/04/2022 20:00	1.2	12.4	2,097.4	0.8	3.9	1	1	1
01/04/2022 21:00	1.1	12.6	2,063.5	0.8	3.6	1	1	1
01/04/2022 22:00	1.2	12.8	2,028.6	0.8	4.0	1	1	1
01/04/2022 23:00	1.1	12.7	2,048.8	0.8	3.6	1	1	1
Average/Sum#:	1.0	13.1	1,879.3	0.8	76.4 #	24 #	24 #	18 #
Minimum:	0.5	12.1	1,347.2	0.6	1.6	1	1	0
Maximum:	1.3	13.8	2,178.4	0.9	4.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit	> Limit			
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/05/2022 00:00	1.1	13.3	1,834.7	0.9	3.5	1	1	1
01/05/2022 01:00	1.0	13.8	1,314.9	0.8	2.4	1	1	0
01/05/2022 02:00	1.0	13.8	1,346.0	0.8	2.5	1	1	0
01/05/2022 03:00	0.6	13.7	1,763.8	0.7	1.9	1	1	0
01/05/2022 04:00	1.0	13.4	1,873.9	0.7	3.3	1	1	1
01/05/2022 05:00	1.2	13.2	1,904.3	0.7	3.9	1	1	1
01/05/2022 06:00	0.7	13.7	1,688.0	0.8	2.2	1	1	1
01/05/2022 07:00	1.1	12.8	2,031.1	0.8	3.6	1	1	1
01/05/2022 08:00	1.1	12.9	2,022.7	0.7	3.7	1	1	1
01/05/2022 09:00	1.1	12.9	2,004.9	0.8	3.6	1	1	1
01/05/2022 10:00	0.8	13.8	1,486.1	0.8	2.2	1	1	0
01/05/2022 11:00	0.7	13.8	1,535.8	0.7	2.0	1	1	0
01/05/2022 12:00	0.6	13.7	1,740.8	0.6	1.9	1	1	0
01/05/2022 13:00	0.7	13.4	1,857.3	0.6	2.3	1	1	1
01/05/2022 14:00	0.8	13.3	1,852.4	0.6	2.6	1	1	1
01/05/2022 15:00	0.6	13.8	1,654.3	0.6	1.8	1	1	1
01/05/2022 16:00	1.2	12.8	2,033.0	0.7	4.0	1	1	1
01/05/2022 17:00	1.3	12.5	2,098.7	0.8	4.3	1	1	1
01/05/2022 18:00	1.3	12.2	2,163.9	0.9	4.3	1	1	1
01/05/2022 19:00	1.2	12.2	2,161.8	0.9	3.9	1	1	1
01/05/2022 20:00	1.2	12.2	2,165.1	0.8	3.9	1	1	1
01/05/2022 21:00	1.2	12.2	2,153.3	0.8	3.9	1	1	1
01/05/2022 22:00	1.2	13.0	1,971.4	0.8	4.0	1	1	1
01/05/2022 23:00	1.2	12.6	2,059.8	0.9	3.9	1	1	1
Average/Sum#:	1.0	13.1	1,863.3	0.8	75.6 #	24 #	24 #	18 #
Minimum:	0.6	12.2	1,314.9	0.6	1.8	1	1	0
Maximum:	1.3	13.8	2,165.1	0.9	4.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:07 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit Unit CT1	> Limit Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/06/2022 00:00	1.1	13.3	1,842.5	0.9	3.5	1	1	1
01/06/2022 01:00	0.8	13.8	1,332.2	0.8	2.0	1	1	0
01/06/2022 02:00	0.9	13.8	1,314.2	0.8	2.2	1	1	0
01/06/2022 03:00	0.7	13.8	1,558.9	0.7	2.0	1	1	0
01/06/2022 04:00	1.1	13.4	1,875.2	0.7	3.6	1	1	1
01/06/2022 05:00	1.1	13.4	1,867.9	0.8	3.6	1	1	1
01/06/2022 06:00	0.6	13.7	1,771.3	0.8	1.9	1	1	1
01/06/2022 07:00	1.3	13.0	2,016.8	0.8	4.4	1	1	1
01/06/2022 08:00	1.2	12.8	2,047.0	0.8	4.0	1	1	1
01/06/2022 09:00	1.3	13.1	1,953.8	1.0	4.3	1	1	1
01/06/2022 10:00	0.8	13.8	1,519.0	0.9	2.3	1	1	0
01/06/2022 11:00	0.7	13.8	1,583.0	0.8	2.1	1	1	0
01/06/2022 12:00	0.8	13.8	1,446.8	0.7	2.2	1	1	0
01/06/2022 13:00	1.0	13.8	1,338.0	0.7	2.5	1	1	0
01/06/2022 14:00	0.7	13.7	1,621.3	0.7	2.1	1	1	0
01/06/2022 15:00	0.8	13.8	1,445.0	0.7	2.2	1	1	0
01/06/2022 16:00	0.6	13.7	1,627.5	0.6	1.8	1	1	0
01/06/2022 17:00	0.6	13.7	1,742.2	0.6	1.9	1	1	1
01/06/2022 18:00	1.4	12.7	2,039.7	0.7	4.6	1	1	1
01/06/2022 19:00	1.3	12.4	2,094.2	0.8	4.2	1	1	1
01/06/2022 20:00	1.2	12.9	1,961.6	0.9	3.9	1	1	1
01/06/2022 21:00	0.6	13.7	1,673.8	0.8	1.8	1	1	0
01/06/2022 22:00	0.6	13.7	1,770.2	0.6	1.9	1	1	1
01/06/2022 23:00	1.2	12.8	2,000.5	0.6	3.9	1	1	1
Average/Sum#:	0.9	13.4	1,726.8	0.8	68.9 #	24 #	24 #	13 #
Minimum:	0.6	12.4	1,314.2	0.6	1.8	1	1	0
Maximum:	1.4	13.8	2,094.2	1.0	4.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:07 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit Unit CT1	> Limit Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/07/2022 00:00	1.1	13.3	1,829.4	0.8	3.5	1	1	1
01/07/2022 01:00	0.9	13.8	1,304.1	0.8	2.2	1	1	0
01/07/2022 02:00	0.7	13.7	1,629.3	0.7	2.1	1	1	1
01/07/2022 03:00	1.3	13.1	1,950.4	0.8	4.3	1	1	1
01/07/2022 04:00	1.3	13.1	1,930.2	0.9	4.2	1	1	1
01/07/2022 05:00	0.6	13.7	1,684.2	0.8	1.9	1	1	0
01/07/2022 06:00	0.7	13.7	1,597.1	0.7	2.1	1	1	1
01/07/2022 07:00	1.3	12.8	2,002.6	0.7	4.2	1	1	1
01/07/2022 08:00	1.3	13.0	1,942.8	0.8	4.2	1	1	1
01/07/2022 09:00	0.6	13.8	1,582.2	0.8	1.8	1	1	0
01/07/2022 10:00	0.6	13.8	1,538.7	0.7	1.7	1	1	0
01/07/2022 11:00	0.6	13.8	1,562.3	0.5	1.7	1	1	0
01/07/2022 12:00	0.6	13.8	1,549.0	0.5	1.7	1	1	0
01/07/2022 13:00	0.6	13.8	1,515.2	0.5	1.7	1	1	0
01/07/2022 14:00	0.7	13.8	1,497.6	0.5	2.0	1	1	0
01/07/2022 15:00	0.6	13.8	1,539.7	0.5	1.7	1	1	0
01/07/2022 16:00	0.6	13.8	1,543.7	0.5	1.7	1	1	0
01/07/2022 17:00	0.6	13.8	1,642.9	0.5	1.8	1	1	0
01/07/2022 18:00	1.2	13.3	1,866.1	0.6	3.9	1	1	1
01/07/2022 19:00	1.1	13.3	1,840.4	0.8	3.5	1	1	1
01/07/2022 20:00	0.7	13.7	1,587.7	0.8	2.0	1	1	1
01/07/2022 21:00	1.4	13.0	1,998.1	0.8	4.7	1	1	1
01/07/2022 22:00	11.0	14.4	1,215.2	0.0	13.6	1	0	1
01/07/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	1.3	13.6	1,667.3	0.7	72.2 #	23 #	22 #	12 #
Minimum:	0.6	12.8	1,215.2	0.5	1.7	0	0	0
Maximum:	11.0	14.4	2,002.6	0.9	13.6	1	1	1
%SI	4.17	4.17	4.17	8.33	4.17	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:07 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit	> Limit	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT1	Unit CT1	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	CO, _3Hr, Ppmvdc	CO, Lb	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/08/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2022 10:00	57.1	17.9	321.6	0.0	40.4	1	0	0
01/08/2022 11:00	21.6	17.2	388.4	0.0	29.9	1	0	0
01/08/2022 12:00	31.5	15.7	813.8	0.0	65.1	1	0	0
01/08/2022 13:00	0.7	13.9	1,404.2	0.0	1.9	1	0	0
01/08/2022 14:00	0.8	13.9	1,374.0	0.0	2.1	1	0	0
01/08/2022 15:00	0.5	13.8	1,729.0	0.6	1.6	1	0	0
01/08/2022 16:00	0.7	13.8	1,554.2	0.6	2.0	1	0	0
01/08/2022 17:00	0.6	13.8	1,635.3	0.5	1.8	1	1	0
01/08/2022 18:00	0.6	13.7	1,790.5	0.5	2.0	1	1	1
01/08/2022 19:00	1.3	12.8	2,051.0	0.6	4.3	1	1	1
01/08/2022 20:00	1.2	12.6	2,054.3	0.8	3.9	1	1	1
01/08/2022 21:00	0.5	13.8	1,720.3	0.7	1.6	1	1	0
01/08/2022 22:00	0.6	13.8	1,799.8	0.6	2.0	1	1	1
01/08/2022 23:00	1.2	12.8	2,035.8	0.6	4.0	1	1	1
Average/Sum#:	8.5	14.3	1,476.6	0.6	162.6 #	14 #	7 #	5 #
Minimum:	0.5	12.6	321.6	0.5	1.6	0	0	0
Maximum:	57.1	17.9	2,054.3	0.8	65.1	1	1	1
%SI	41.67	41.67	41.67	62.50	41.67	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:07 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit Unit CT1	> Limit Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/09/2022 00:00	1.1	13.1	1,966.5	0.7	3.7	1	1	1
01/09/2022 01:00	0.6	13.8	1,536.5	0.7	1.7	1	1	0
01/09/2022 02:00	0.7	13.8	1,602.4	0.6	2.1	1	1	1
01/09/2022 03:00	1.2	13.2	1,969.5	0.7	4.1	1	1	1
01/09/2022 04:00	1.2	13.2	1,953.1	0.8	4.0	1	1	1
01/09/2022 05:00	0.6	13.8	1,667.9	0.8	1.9	1	1	0
01/09/2022 06:00	0.7	13.7	1,685.1	0.7	2.2	1	1	1
01/09/2022 07:00	1.3	13.0	2,044.7	0.7	4.4	1	1	1
01/09/2022 08:00	1.3	13.1	1,988.6	0.9	4.4	1	1	1
01/09/2022 09:00	0.6	13.8	1,594.5	0.8	1.8	1	1	0
01/09/2022 10:00	0.7	13.8	1,534.8	0.7	2.0	1	1	0
01/09/2022 11:00	0.6	13.8	1,618.0	0.5	1.8	1	1	0
01/09/2022 12:00	0.7	13.8	1,468.2	0.6	1.9	1	1	0
01/09/2022 13:00	0.6	13.8	1,521.3	0.5	1.7	1	1	0
01/09/2022 14:00	0.5	13.8	1,652.7	0.5	1.5	1	1	0
01/09/2022 15:00	0.5	13.8	1,677.3	0.4	1.6	1	1	0
01/09/2022 16:00	0.7	13.8	1,634.7	0.5	2.1	1	1	1
01/09/2022 17:00	1.2	13.0	1,989.6	0.6	4.0	1	1	1
01/09/2022 18:00	1.2	12.7	2,073.2	0.8	4.0	1	1	1
01/09/2022 19:00	1.2	13.1	1,966.0	0.9	4.0	1	1	1
01/09/2022 20:00	1.1	12.9	2,013.4	0.9	3.7	1	1	1
01/09/2022 21:00	1.1	13.0	2,000.2	0.8	3.7	1	1	1
01/09/2022 22:00	1.1	12.7	2,059.8	0.8	3.6	1	1	1
01/09/2022 23:00	1.3	13.2	1,965.3	0.9	4.4	1	1	1
Average/Sum#:	0.9	13.4	1,799.3	0.7	70.3 #	24 #	24 #	15 #
Minimum:	0.5	12.7	1,468.2	0.4	1.5	1	1	0
Maximum:	1.3	13.8	2,073.2	0.9	4.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:07 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit Unit CT1	> Limit Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/10/2022 00:00	1.1	13.3	1,867.1	0.9	3.6	1	1	1
01/10/2022 01:00	0.7	13.9	1,417.2	0.8	1.9	1	0	0
01/10/2022 02:00	0.7	13.9	1,384.2	0.7	1.8	1	0	0
01/10/2022 03:00	0.8	13.8	1,425.9	0.6	2.1	1	0	0
01/10/2022 04:00	0.7	13.8	1,503.6	0.6	2.0	1	0	0
01/10/2022 05:00	0.6	13.8	1,530.3	0.6	1.7	1	0	0
01/10/2022 06:00	0.5	13.8	1,787.2	0.5	1.7	1	0	0
01/10/2022 07:00	0.7	13.8	1,604.3	0.5	2.1	1	0	0
01/10/2022 08:00	0.6	13.8	1,673.4	0.5	1.9	1	1	0
01/10/2022 09:00	0.6	13.8	1,603.2	0.5	1.8	1	1	0
01/10/2022 10:00	0.6	13.8	1,648.2	0.5	1.8	1	1	1
01/10/2022 11:00	1.0	13.1	1,994.1	0.6	3.4	1	1	1
01/10/2022 12:00	0.9	13.2	1,934.8	0.7	3.0	1	1	1
01/10/2022 13:00	0.6	13.9	1,551.5	0.7	1.8	1	1	0
01/10/2022 14:00	0.5	13.8	1,656.1	0.5	1.5	1	1	0
01/10/2022 15:00	1.1	12.9	2,002.9	0.6	3.6	1	1	1
01/10/2022 16:00	1.2	12.6	2,082.9	0.7	4.0	1	1	1
01/10/2022 17:00	1.2	12.3	2,134.1	0.8	3.9	1	1	1
01/10/2022 18:00	1.2	12.2	2,162.3	0.8	3.9	1	1	1
01/10/2022 19:00	1.2	12.2	2,157.2	0.8	3.9	1	1	1
01/10/2022 20:00	1.2	12.2	2,163.1	0.8	3.9	1	1	1
01/10/2022 21:00	1.2	12.3	2,147.3	0.8	4.0	1	1	1
01/10/2022 22:00	1.1	12.8	2,028.4	0.8	3.6	1	1	1
01/10/2022 23:00	1.1	13.0	2,007.3	0.8	3.7	1	1	1
Average/Sum#:	0.9	13.3	1,811.1	0.7	66.6 #	24 #	17 #	13 #
Minimum:	0.5	12.2	1,384.2	0.5	1.5	1	0	0
Maximum:	1.2	13.9	2,163.1	0.9	4.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:07 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit	> Limit			
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/11/2022 00:00	1.0	13.3	1,850.1	0.8	3.2	1	1	1
01/11/2022 01:00	0.9	13.9	1,313.8	0.8	2.2	1	1	0
01/11/2022 02:00	0.8	13.8	1,593.7	0.8	2.4	1	1	1
01/11/2022 03:00	1.4	13.2	1,966.2	0.9	4.7	1	1	1
01/11/2022 04:00	1.2	13.2	1,949.9	0.9	4.0	1	1	1
01/11/2022 05:00	0.6	13.8	1,629.6	0.8	1.8	1	1	0
01/11/2022 06:00	0.7	13.8	1,608.7	0.7	2.1	1	1	1
01/11/2022 07:00	1.2	13.0	2,002.9	0.7	4.0	1	1	1
01/11/2022 08:00	1.0	13.3	1,847.1	0.8	3.2	1	1	1
01/11/2022 09:00	0.8	13.9	1,326.2	0.8	2.0	1	1	0
01/11/2022 10:00	0.8	13.9	1,320.5	0.7	2.0	1	1	0
01/11/2022 11:00	0.7	13.9	1,382.5	0.7	1.8	1	1	0
01/11/2022 12:00	0.7	13.9	1,366.7	0.6	1.8	1	1	0
01/11/2022 13:00	0.7	13.9	1,364.1	0.6	1.8	1	1	0
01/11/2022 14:00	0.6	13.9	1,319.5	0.6	1.5	1	1	0
01/11/2022 15:00	0.7	13.9	1,388.8	0.6	1.8	1	1	0
01/11/2022 16:00	0.6	13.8	1,638.3	0.5	1.8	1	1	0
01/11/2022 17:00	0.6	13.8	1,681.6	0.5	1.9	1	1	1
01/11/2022 18:00	1.0	13.0	1,991.5	0.6	3.3	1	1	1
01/11/2022 19:00	1.0	13.1	1,964.9	0.7	3.3	1	1	1
01/11/2022 20:00	1.0	13.1	1,955.5	0.8	3.3	1	1	1
01/11/2022 21:00	1.0	13.1	1,971.3	0.8	3.3	1	1	1
01/11/2022 22:00	1.0	12.9	2,023.0	0.8	3.3	1	1	1
01/11/2022 23:00	0.8	13.4	1,691.6	0.7	2.4	1	1	1
Average/Sum#:	0.9	13.5	1,672.8	0.7	62.9 #	24 #	24 #	14 #
Minimum:	0.6	12.9	1,313.8	0.5	1.5	1	1	0
Maximum:	1.4	13.9	2,023.0	0.9	4.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:07 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit Unit CT1	> Limit Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/12/2022 00:00	0.8	13.8	1,378.5	0.7	2.1	1	0	0
01/12/2022 01:00	0.8	13.8	1,366.9	0.7	2.0	1	0	0
01/12/2022 02:00	0.8	13.8	1,364.0	0.7	2.0	1	0	0
01/12/2022 03:00	0.8	13.8	1,370.0	0.7	2.0	1	0	0
01/12/2022 04:00	0.8	13.8	1,370.5	0.7	2.0	1	0	0
01/12/2022 05:00	0.7	13.8	1,437.7	0.7	1.9	1	0	1
01/12/2022 06:00	1.5	13.2	1,964.8	0.8	5.1	1	0	1
01/12/2022 07:00	1.4	13.2	1,965.4	0.9	4.7	1	0	1
01/12/2022 08:00	1.4	13.2	1,963.9	1.1	4.7	1	0	1
01/12/2022 09:00	0.8	13.7	1,747.1	1.0	2.6	1	0	1
01/12/2022 10:00	0.7	13.8	1,599.4	0.8	2.1	1	0	0
01/12/2022 11:00	0.8	13.9	1,402.1	0.7	2.1	1	1	0
01/12/2022 12:00	0.6	13.8	1,544.7	0.6	1.7	1	1	0
01/12/2022 13:00	0.6	13.8	1,596.6	0.6	1.8	1	1	0
01/12/2022 14:00	0.6	13.8	1,581.0	0.5	1.8	1	1	0
01/12/2022 15:00	0.6	13.8	1,647.6	0.5	1.8	1	1	1
01/12/2022 16:00	1.1	12.8	2,023.2	0.6	3.6	1	1	1
01/12/2022 17:00	1.1	12.4	2,095.2	0.7	3.6	1	1	1
01/12/2022 18:00	1.1	12.6	2,070.3	0.8	3.6	1	1	1
01/12/2022 19:00	1.1	12.6	2,059.0	0.8	3.6	1	1	1
01/12/2022 20:00	1.0	13.0	1,972.7	0.8	3.3	1	1	1
01/12/2022 21:00	0.5	13.8	1,689.8	0.6	1.6	1	1	0
01/12/2022 22:00	0.5	13.8	1,807.4	0.5	1.7	1	1	1
01/12/2022 23:00	1.2	13.1	1,985.3	0.6	4.0	1	1	1
Average/Sum#:	0.9	13.5	1,708.5	0.7	65.4 #	24 #	13 #	13 #
Minimum:	0.5	12.4	1,364.0	0.5	1.6	1	0	0
Maximum:	1.5	13.9	2,095.2	1.1	5.1	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:07 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit	> Limit			
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/13/2022 00:00	1.0	13.4	1,844.4	0.7	3.2	1	1	1
01/13/2022 01:00	1.0	13.9	1,315.9	0.8	2.5	1	1	0
01/13/2022 02:00	0.8	13.8	1,600.7	0.8	2.4	1	1	1
01/13/2022 03:00	1.3	13.2	1,977.5	0.8	4.4	1	1	1
01/13/2022 04:00	1.2	13.2	1,958.0	0.9	4.0	1	1	1
01/13/2022 05:00	0.6	13.8	1,693.9	0.8	1.9	1	1	0
01/13/2022 06:00	0.7	13.8	1,636.6	0.7	2.1	1	1	1
01/13/2022 07:00	1.0	12.8	2,034.3	0.6	3.3	1	1	1
01/13/2022 08:00	0.8	13.1	1,949.0	0.6	2.6	1	1	1
01/13/2022 09:00	0.6	13.8	1,670.8	0.6	1.9	1	1	0
01/13/2022 10:00	0.8	13.8	1,407.6	0.6	2.1	1	1	0
01/13/2022 11:00	0.6	13.8	1,647.5	0.6	1.8	1	1	0
01/13/2022 12:00	0.9	13.4	1,872.7	0.6	3.0	1	1	1
01/13/2022 13:00	1.2	12.7	2,012.5	0.7	3.9	1	1	1
01/13/2022 14:00	0.6	13.8	1,563.2	0.7	1.7	1	1	0
01/13/2022 15:00	0.7	13.8	1,579.8	0.7	2.1	1	1	1
01/13/2022 16:00	1.1	12.8	2,013.4	0.6	3.6	1	1	1
01/13/2022 17:00	1.1	12.7	2,049.9	0.7	3.6	1	1	1
01/13/2022 18:00	1.1	12.5	2,085.7	0.8	3.6	1	1	1
01/13/2022 19:00	1.0	13.0	1,969.2	0.8	3.3	1	1	1
01/13/2022 20:00	0.5	13.8	1,611.3	0.6	1.5	1	1	0
01/13/2022 21:00	0.6	13.8	1,648.8	0.5	1.8	1	1	1
01/13/2022 22:00	1.2	12.9	1,997.9	0.6	4.0	1	1	1
01/13/2022 23:00	10.6	14.4	1,214.2	0.0	12.6	1	0	1
Average/Sum#:	1.3	13.4	1,764.8	0.7	76.9 #	24 #	23 #	17 #
Minimum:	0.5	12.5	1,214.2	0.5	1.5	1	0	0
Maximum:	10.6	14.4	2,085.7	0.9	12.6	1	1	1
%SI	0.00	0.00	0.00	4.17	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:07 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit	> Limit	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT1	Unit CT1	UnitOn, TF	NormalOp, TF	DBOn, TF
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/14/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/14/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/14/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/14/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/14/2022 04:00	16.5	18.2	282.7	0.0	6.8	1	0	0
01/14/2022 05:00	43.3	15.7	779.0	0.0	85.7	1	0	0
01/14/2022 06:00	0.7	13.8	1,493.2	0.0	1.9	1	0	0
01/14/2022 07:00	0.6	13.6	1,848.6	0.0	2.0	1	0	0
01/14/2022 08:00	0.8	13.9	1,385.3	0.6	2.1	1	0	0
01/14/2022 09:00	0.8	13.9	1,366.9	0.6	2.1	1	0	0
01/14/2022 10:00	0.8	13.9	1,368.3	0.7	2.1	1	0	0
01/14/2022 11:00	0.7	13.9	1,370.0	0.7	1.8	1	0	0
01/14/2022 12:00	0.7	13.9	1,380.9	0.6	1.8	1	0	0
01/14/2022 13:00	0.6	13.7	1,752.9	0.6	1.9	1	0	0
01/14/2022 14:00	0.6	13.9	1,531.2	0.5	1.7	1	0	0
01/14/2022 15:00	0.6	13.9	1,532.5	0.5	1.7	1	1	0
01/14/2022 16:00	0.6	13.9	1,433.1	0.5	1.6	1	1	0
01/14/2022 17:00	0.5	13.8	1,599.4	0.5	1.5	1	1	0
01/14/2022 18:00	0.5	13.8	1,627.6	0.4	1.5	1	1	0
01/14/2022 19:00	0.9	13.3	1,870.8	0.5	2.9	1	1	1
01/14/2022 20:00	1.1	13.2	1,890.4	0.6	3.6	1	1	1
01/14/2022 21:00	0.6	13.8	1,730.2	0.7	1.9	1	1	1
01/14/2022 22:00	1.2	12.9	2,037.7	0.7	4.0	1	1	1
01/14/2022 23:00	11.8	14.4	1,233.4	0.0	14.2	1	0	1
Average/Sum#:	4.2	14.1	1,475.7	0.6	142.8 #	20 #	8 #	5 #
Minimum:	0.5	12.9	282.7	0.4	1.5	0	0	0
Maximum:	43.3	18.2	2,037.7	0.7	85.7	1	1	1
%SI	16.67	16.67	16.67	37.50	16.67	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:07 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit	> Limit	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/15/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/15/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/15/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/15/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/15/2022 04:00	15.9	18.4	254.0	0.0	4.9	1	0	0
01/15/2022 05:00	46.8	15.9	760.7	0.0	94.0	1	0	0
01/15/2022 06:00	0.6	13.8	1,518.2	0.0	1.7	1	0	0
01/15/2022 07:00	0.6	13.8	1,564.5	0.0	1.7	1	0	0
01/15/2022 08:00	0.7	13.9	1,417.4	0.5	1.9	1	0	0
01/15/2022 09:00	0.6	13.8	1,532.1	0.5	1.7	1	0	0
01/15/2022 10:00	0.7	13.9	1,371.3	0.6	1.8	1	0	0
01/15/2022 11:00	0.7	13.9	1,372.9	0.6	1.8	1	0	0
01/15/2022 12:00	0.7	13.9	1,369.4	0.6	1.8	1	0	0
01/15/2022 13:00	0.8	13.9	1,375.7	0.6	2.1	1	0	0
01/15/2022 14:00	0.6	13.8	1,735.1	0.6	1.9	1	0	0
01/15/2022 15:00	0.6	13.8	1,579.2	0.6	1.8	1	0	0
01/15/2022 16:00	0.6	13.8	1,599.2	0.5	1.8	1	1	0
01/15/2022 17:00	0.6	13.8	1,682.0	0.5	1.9	1	1	0
01/15/2022 18:00	1.1	13.3	1,883.4	0.6	3.6	1	1	1
01/15/2022 19:00	1.3	13.0	1,975.2	0.8	4.3	1	1	1
01/15/2022 20:00	0.6	13.8	1,707.9	0.8	1.9	1	1	1
01/15/2022 21:00	0.6	13.7	1,787.6	0.7	2.0	1	1	1
01/15/2022 22:00	1.3	13.0	1,996.1	0.7	4.3	1	1	1
01/15/2022 23:00	8.6	14.0	1,474.6	0.0	17.7	1	0	1
Average/Sum#:	4.2	14.1	1,497.8	0.6	154.6 #	20 #	7 #	6 #
Minimum:	0.6	13.0	254.0	0.5	1.7	0	0	0
Maximum:	46.8	18.4	1,996.1	0.8	94.0	1	1	1
%SI	16.67	16.67	16.67	37.50	16.67	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:07 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit	> Limit	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT1	Unit CT1	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	CO, _3Hr, Ppmvdc	CO, Lb	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/16/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/16/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/16/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/16/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/16/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/16/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/16/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/16/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/16/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/16/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/16/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/16/2022 11:00	36.9	17.5	355.9	0.0	51.0	1	0	0
01/16/2022 12:00	44.4	16.1	682.8	0.0	83.4	1	0	0
01/16/2022 13:00	0.9	13.8	1,384.6	0.0	2.3	1	0	0
01/16/2022 14:00	0.9	13.9	1,372.8	0.0	2.3	1	0	0
01/16/2022 15:00	0.7	13.8	1,672.4	0.7	2.2	1	0	0
01/16/2022 16:00	0.6	13.8	1,664.3	0.6	1.9	1	0	0
01/16/2022 17:00	0.7	13.9	1,455.8	0.6	1.9	1	0	0
01/16/2022 18:00	0.6	13.7	1,722.5	0.5	1.9	1	1	0
01/16/2022 19:00	1.3	13.2	1,921.4	0.7	4.3	1	1	1
01/16/2022 20:00	1.3	12.7	2,025.6	0.8	4.2	1	1	1
01/16/2022 21:00	0.5	13.8	1,712.4	0.8	1.6	1	1	0
01/16/2022 22:00	0.7	13.9	1,409.5	0.6	1.9	1	1	0
01/16/2022 23:00	0.6	13.8	1,634.3	0.5	1.8	1	1	0
Average/Sum#:	6.9	14.1	1,462.6	0.6	160.7 #	13 #	6 #	2 #
Minimum:	0.5	12.7	355.9	0.5	1.6	0	0	0
Maximum:	44.4	17.5	2,025.6	0.8	83.4	1	1	1
%SI	45.83	45.83	45.83	62.50	45.83	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:07 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit Unit CT1	> Limit Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/17/2022 00:00	1.0	13.4	1,840.9	0.6	3.2	1	1	1
01/17/2022 01:00	1.1	13.3	1,870.0	0.7	3.6	1	1	1
01/17/2022 02:00	0.9	13.8	1,425.5	0.8	2.4	1	1	0
01/17/2022 03:00	0.6	13.8	1,763.8	0.7	2.0	1	1	0
01/17/2022 04:00	0.9	13.5	1,863.6	0.6	3.0	1	1	1
01/17/2022 05:00	1.0	13.5	1,843.7	0.7	3.3	1	1	1
01/17/2022 06:00	0.7	13.7	1,713.3	0.7	2.2	1	1	1
01/17/2022 07:00	1.3	12.8	2,038.5	0.8	4.3	1	1	1
01/17/2022 08:00	1.2	12.8	2,057.3	0.8	4.0	1	1	1
01/17/2022 09:00	1.3	13.0	1,980.1	0.9	4.3	1	1	1
01/17/2022 10:00	0.7	13.8	1,593.8	0.8	2.1	1	1	0
01/17/2022 11:00	0.6	13.8	1,596.2	0.7	1.8	1	1	0
01/17/2022 12:00	0.6	13.8	1,662.3	0.5	1.9	1	1	1
01/17/2022 13:00	1.0	13.0	1,963.0	0.6	3.3	1	1	1
01/17/2022 14:00	0.9	13.0	1,939.3	0.6	2.9	1	1	1
01/17/2022 15:00	0.5	13.8	1,614.0	0.6	1.5	1	1	0
01/17/2022 16:00	0.6	13.8	1,606.1	0.5	1.8	1	1	1
01/17/2022 17:00	1.2	12.9	1,985.5	0.6	3.9	1	1	1
01/17/2022 18:00	1.1	12.8	2,021.2	0.7	3.6	1	1	1
01/17/2022 19:00	1.2	12.6	2,062.2	0.9	3.9	1	1	1
01/17/2022 20:00	1.1	13.0	1,952.0	0.8	3.6	1	1	1
01/17/2022 21:00	0.5	13.8	1,659.8	0.7	1.5	1	1	0
01/17/2022 22:00	0.8	13.9	1,422.2	0.6	2.1	1	1	0
01/17/2022 23:00	0.6	13.8	1,644.1	0.5	1.8	1	1	0
Average/Sum#:	0.9	13.4	1,796.6	0.7	68.0 #	24 #	24 #	16 #
Minimum:	0.5	12.6	1,422.2	0.5	1.5	1	1	0
Maximum:	1.3	13.9	2,062.2	0.9	4.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:07 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit Unit CT1	> Limit Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/18/2022 00:00	0.6	13.7	1,795.1	0.6	2.0	1	1	1
01/18/2022 01:00	1.1	13.2	1,857.5	0.6	3.5	1	1	1
01/18/2022 02:00	0.7	13.8	1,639.3	0.6	2.1	1	1	0
01/18/2022 03:00	0.8	13.2	1,962.3	0.7	2.7	1	1	1
01/18/2022 04:00	0.8	13.2	1,960.2	0.6	2.7	1	1	1
01/18/2022 05:00	0.7	13.8	1,586.1	0.6	2.1	1	1	1
01/18/2022 06:00	0.8	13.8	1,610.8	0.6	2.4	1	1	1
01/18/2022 07:00	1.3	13.2	1,983.9	0.8	4.4	1	1	1
01/18/2022 08:00	1.2	12.9	2,026.9	0.9	4.0	1	1	1
01/18/2022 09:00	1.3	13.2	1,947.5	1.0	4.3	1	1	1
01/18/2022 10:00	0.0	0.0	1,445.2	0.0	0.0	1	1	0
01/18/2022 11:00	0.9	13.8	1,411.2	0.0	2.4	1	1	0
01/18/2022 12:00	0.9	13.9	1,313.9	0.0	2.2	1	1	0
01/18/2022 13:00	0.0	0.0	1,323.2	0.0	0.0	1	1	0
01/18/2022 14:00	0.7	13.9	1,362.3	0.0	1.8	1	1	0
01/18/2022 15:00	0.7	13.8	1,542.4	0.0	2.0	1	1	0
01/18/2022 16:00	0.6	13.7	1,637.2	0.6	1.8	1	1	1
01/18/2022 17:00	1.3	12.7	2,032.0	0.7	4.3	1	1	1
01/18/2022 18:00	1.2	12.7	2,047.9	0.8	4.0	1	1	1
01/18/2022 19:00	1.2	12.5	2,082.4	0.9	3.9	1	1	1
01/18/2022 20:00	1.1	13.1	1,952.4	0.8	3.6	1	1	1
01/18/2022 21:00	0.6	13.7	1,601.0	0.7	1.8	1	1	1
01/18/2022 22:00	0.7	13.8	1,606.3	0.6	2.1	1	1	1
01/18/2022 23:00	1.3	13.0	1,992.0	0.7	4.3	1	1	1
Average/Sum#:	0.9	13.4	1,738.3	0.7	64.4 #	24 #	24 #	17 #
Minimum:	0.6	12.5	1,313.9	0.6	1.8	1	1	0
Maximum:	1.3	13.9	2,082.4	1.0	4.4	1	1	1
%SI	8.33	8.33	0.00	25.00	8.33	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit Unit CT1	> Limit Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/19/2022 00:00	1.0	13.3	1,846.2	0.8	3.2	1	1	1
01/19/2022 01:00	1.0	13.9	1,311.8	0.9	2.5	1	1	0
01/19/2022 02:00	0.8	13.8	1,600.1	0.8	2.4	1	1	1
01/19/2022 03:00	1.2	13.2	1,975.1	0.8	4.1	1	1	1
01/19/2022 04:00	1.2	13.2	1,944.5	0.8	4.0	1	1	1
01/19/2022 05:00	0.8	13.8	1,593.6	0.8	2.4	1	1	0
01/19/2022 06:00	0.9	13.8	1,610.8	0.8	2.7	1	1	1
01/19/2022 07:00	1.3	13.1	1,980.7	0.8	4.4	1	1	1
01/19/2022 08:00	1.3	13.2	1,962.0	0.9	4.4	1	1	1
01/19/2022 09:00	0.8	13.8	1,518.3	0.9	2.3	1	1	0
01/19/2022 10:00	0.9	13.9	1,363.9	0.8	2.3	1	1	0
01/19/2022 11:00	0.8	13.9	1,428.7	0.7	2.2	1	1	0
01/19/2022 12:00	0.8	13.9	1,332.7	0.7	2.0	1	1	0
01/19/2022 13:00	0.7	13.9	1,385.3	0.7	1.8	1	1	0
01/19/2022 14:00	0.8	13.9	1,361.1	0.7	2.1	1	1	0
01/19/2022 15:00	0.7	13.7	1,584.8	0.6	2.0	1	1	1
01/19/2022 16:00	1.3	12.5	2,080.9	0.7	4.3	1	1	1
01/19/2022 17:00	1.2	12.3	2,106.3	0.8	3.9	1	1	1
01/19/2022 18:00	1.2	12.5	2,081.8	0.8	3.9	1	1	1
01/19/2022 19:00	1.2	12.4	2,096.4	0.8	3.9	1	1	1
01/19/2022 20:00	1.1	12.6	2,027.1	0.8	3.5	1	1	1
01/19/2022 21:00	0.5	13.8	1,700.4	0.7	1.6	1	1	0
01/19/2022 22:00	0.5	13.7	1,795.7	0.5	1.6	1	1	1
01/19/2022 23:00	1.0	12.9	1,999.9	0.5	3.3	1	1	1
Average/Sum#:	1.0	13.4	1,737.0	0.8	70.8 #	24 #	24 #	15 #
Minimum:	0.5	12.3	1,311.8	0.5	1.6	1	1	0
Maximum:	1.3	13.9	2,106.3	0.9	4.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:07 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit Unit CT1	> Limit Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/20/2022 00:00	0.9	13.1	1,860.6	0.6	2.8	1	1	1
01/20/2022 01:00	0.7	13.9	1,315.3	0.7	1.7	1	1	0
01/20/2022 02:00	0.8	13.9	1,325.6	0.7	2.0	1	1	0
01/20/2022 03:00	0.5	13.8	1,748.2	0.6	1.6	1	1	0
01/20/2022 04:00	0.9	13.4	1,863.7	0.6	3.0	1	1	1
01/20/2022 05:00	0.9	13.4	1,871.0	0.6	3.0	1	1	1
01/20/2022 06:00	0.6	13.8	1,726.9	0.6	1.9	1	1	1
01/20/2022 07:00	1.2	13.0	1,995.8	0.7	4.0	1	1	1
01/20/2022 08:00	0.9	13.5	1,704.2	0.7	2.7	1	1	1
01/20/2022 09:00	0.8	13.9	1,391.1	0.8	2.1	1	0	0
01/20/2022 10:00	0.8	13.9	1,368.4	0.7	2.1	1	0	0
01/20/2022 11:00	0.7	13.9	1,373.3	0.7	1.8	1	0	0
01/20/2022 12:00	0.7	13.9	1,375.3	0.6	1.8	1	0	0
01/20/2022 13:00	0.7	13.9	1,376.3	0.6	1.8	1	0	0
01/20/2022 14:00	0.7	13.9	1,379.9	0.6	1.8	1	0	0
01/20/2022 15:00	0.7	13.9	1,382.6	0.6	1.8	1	0	0
01/20/2022 16:00	0.6	13.7	1,712.2	0.6	1.9	1	0	0
01/20/2022 17:00	0.7	13.8	1,531.9	0.6	2.0	1	0	0
01/20/2022 18:00	0.6	13.8	1,622.8	0.5	1.8	1	1	0
01/20/2022 19:00	0.6	13.7	1,728.0	0.5	1.9	1	1	1
01/20/2022 20:00	1.3	12.8	2,029.0	0.6	4.3	1	1	1
01/20/2022 21:00	1.2	12.8	2,031.2	0.8	4.0	1	1	1
01/20/2022 22:00	1.2	12.6	2,065.1	0.9	3.9	1	1	1
01/20/2022 23:00	6.2	14.2	1,247.7	0.0	12.5	1	0	1
Average/Sum#:	1.0	13.6	1,626.1	0.6	68.2 #	24 #	14 #	11 #
Minimum:	0.5	12.6	1,247.7	0.5	1.6	1	0	0
Maximum:	6.2	14.2	2,065.1	0.9	12.5	1	1	1
%SI	0.00	0.00	0.00	4.17	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:07 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit Unit CT1	> Limit Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/21/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/21/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/21/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/21/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/21/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/21/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/21/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/21/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/21/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/21/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/21/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/21/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/21/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/21/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/21/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/21/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/21/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/21/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/21/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/21/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/21/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/21/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/21/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/21/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:07 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit	> Limit	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT1	Unit CT1	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	CO, _3Hr, Ppmvdc	CO, Lb	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/22/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/22/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/22/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/22/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/22/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/22/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/22/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/22/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/22/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/22/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/22/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/22/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/22/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/22/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/22/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/22/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/22/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/22/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/22/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/22/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/22/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/22/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/22/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/22/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:07 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit	> Limit	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/23/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/23/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/23/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/23/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/23/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/23/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/23/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/23/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/23/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/23/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/23/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/23/2022 11:00	63.5	17.6	323.4	0.0	61.7	1	0	0
01/23/2022 12:00	17.6	17.2	383.6	0.0	24.1	1	0	0
01/23/2022 13:00	37.8	15.6	810.3	0.0	76.3	1	0	0
01/23/2022 14:00	0.5	13.9	1,420.3	0.0	1.3	1	0	0
01/23/2022 15:00	0.5	13.9	1,380.4	0.0	1.3	1	0	0
01/23/2022 16:00	0.5	13.8	1,630.1	0.4	1.5	1	0	0
01/23/2022 17:00	0.5	13.9	1,605.7	0.4	1.5	1	0	0
01/23/2022 18:00	0.6	13.7	1,776.1	0.4	2.0	1	1	1
01/23/2022 19:00	1.1	13.0	1,986.4	0.6	3.7	1	1	1
01/23/2022 20:00	1.3	12.6	2,083.5	0.7	4.3	1	1	1
01/23/2022 21:00	1.1	12.7	2,049.0	0.8	3.6	1	1	1
01/23/2022 22:00	1.0	13.0	2,006.0	0.8	3.4	1	1	1
01/23/2022 23:00	10.8	14.4	1,211.0	0.0	12.8	1	0	1
Average/Sum#:	10.5	14.3	1,435.8	0.6	197.5 #	13 #	5 #	6 #
Minimum:	0.5	12.6	323.4	0.4	1.3	0	0	0
Maximum:	63.5	17.6	2,083.5	0.8	76.3	1	1	1
%SI	45.83	45.83	45.83	70.83	45.83	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:07 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit Unit CT1	> Limit Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/24/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/24/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/24/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/24/2022 03:00	11.2	18.7	215.0	0.0	2.6	1	0	0
01/24/2022 04:00	52.0	15.6	843.4	0.0	109.3	1	0	0
01/24/2022 05:00	0.8	13.8	1,526.6	0.0	2.3	1	0	1
01/24/2022 06:00	1.2	12.7	2,085.9	0.0	4.0	1	0	1
01/24/2022 07:00	1.2	12.3	2,171.9	0.8	4.0	1	0	1
01/24/2022 08:00	0.9	13.3	1,836.4	0.8	2.9	1	0	1
01/24/2022 09:00	0.9	13.8	1,379.1	0.7	2.3	1	0	0
01/24/2022 10:00	0.9	13.8	1,373.4	0.7	2.3	1	0	0
01/24/2022 11:00	0.8	13.8	1,362.9	0.7	2.0	1	0	0
01/24/2022 12:00	0.9	13.8	1,375.1	0.7	2.3	1	0	0
01/24/2022 13:00	0.8	13.8	1,379.0	0.7	2.1	1	0	0
01/24/2022 14:00	0.6	13.7	1,756.9	0.6	1.9	1	0	0
01/24/2022 15:00	0.7	13.8	1,466.0	0.6	1.9	1	0	0
01/24/2022 16:00	0.6	13.8	1,667.8	0.5	1.9	1	1	0
01/24/2022 17:00	0.7	13.7	1,665.4	0.6	2.1	1	1	1
01/24/2022 18:00	1.2	12.9	1,995.1	0.7	4.0	1	1	1
01/24/2022 19:00	1.3	12.6	2,069.6	0.8	4.3	1	1	1
01/24/2022 20:00	1.1	12.9	1,971.2	0.9	3.6	1	1	1
01/24/2022 21:00	0.6	13.8	1,631.0	0.7	1.8	1	1	0
01/24/2022 22:00	0.6	13.7	1,753.1	0.6	1.9	1	1	1
01/24/2022 23:00	1.2	12.9	2,002.0	0.6	4.0	1	1	1
Average/Sum#:	3.8	13.8	1,596.5	0.7	163.5 #	21 #	8 #	10 #
Minimum:	0.6	12.3	215.0	0.5	1.8	0	0	0
Maximum:	52.0	18.7	2,171.9	0.9	109.3	1	1	1
%SI	12.50	12.50	12.50	29.17	12.50	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:07 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit Unit CT1	> Limit Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/25/2022 00:00	1.2	13.1	1,943.4	0.8	3.9	1	1	1
01/25/2022 01:00	0.7	13.8	1,573.3	0.8	2.0	1	1	0
01/25/2022 02:00	0.7	13.7	1,681.9	0.7	2.2	1	1	1
01/25/2022 03:00	1.2	13.1	1,975.6	0.7	4.0	1	1	1
01/25/2022 04:00	1.2	13.1	1,954.3	0.8	4.0	1	1	1
01/25/2022 05:00	0.7	13.8	1,674.2	0.8	2.2	1	1	0
01/25/2022 06:00	0.6	13.7	1,785.7	0.7	2.0	1	1	1
01/25/2022 07:00	1.2	12.9	2,039.5	0.7	4.0	1	1	1
01/25/2022 08:00	7.0	13.6	1,525.7	0.0	14.5	1	0	1
01/25/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	1	0
01/25/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	1	0
01/25/2022 15:00	23.9	17.9	311.7	0.0	15.4	1	1	0
01/25/2022 16:00	24.9	15.5	946.6	0.0	57.6	1	1	0
01/25/2022 17:00	0.5	13.8	1,672.8	0.0	1.6	1	1	0
01/25/2022 18:00	0.5	13.7	1,744.2	0.0	1.6	1	1	0
01/25/2022 19:00	1.1	13.1	1,933.7	0.5	3.6	1	1	1
01/25/2022 20:00	1.1	13.1	1,942.8	0.7	3.6	1	1	1
01/25/2022 21:00	0.6	13.9	1,546.2	0.7	1.8	1	1	0
01/25/2022 22:00	0.6	13.7	1,719.8	0.6	1.9	1	1	1
01/25/2022 23:00	0.9	13.2	1,963.8	0.6	3.0	1	1	1
Average/Sum#:	3.8	13.8	1,663.1	0.7	128.9 #	18 #	19 #	11 #
Minimum:	0.5	12.9	311.7	0.5	1.6	0	0	0
Maximum:	24.9	17.9	2,039.5	0.8	57.6	1	1	1
%SI	25.00	25.00	25.00	45.83	25.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:07 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit Unit CT1	> Limit Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/26/2022 00:00	1.0	13.1	1,973.5	0.7	3.3	1	1	1
01/26/2022 01:00	0.5	13.8	1,715.3	0.6	1.6	1	1	0
01/26/2022 02:00	0.6	13.8	1,718.2	0.6	1.9	1	1	1
01/26/2022 03:00	1.1	13.1	2,004.0	0.6	3.7	1	1	1
01/26/2022 04:00	1.1	13.1	1,996.1	0.7	3.7	1	1	1
01/26/2022 05:00	0.6	13.8	1,604.8	0.7	1.8	1	1	0
01/26/2022 06:00	0.6	13.8	1,819.7	0.6	2.0	1	1	1
01/26/2022 07:00	1.3	13.0	2,013.8	0.7	4.4	1	1	1
01/26/2022 08:00	8.5	14.0	1,471.0	0.0	17.4	1	0	1
01/26/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	1	0
01/26/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	1	0
01/26/2022 15:00	23.3	17.9	322.6	0.0	15.6	1	1	0
01/26/2022 16:00	26.7	15.5	945.8	0.0	61.8	1	1	0
01/26/2022 17:00	0.5	13.8	1,718.2	0.0	1.6	1	1	0
01/26/2022 18:00	0.6	13.7	1,821.3	0.0	2.0	1	1	0
01/26/2022 19:00	1.0	13.1	1,939.8	0.6	3.3	1	1	1
01/26/2022 20:00	1.2	12.7	2,033.8	0.7	3.9	1	1	1
01/26/2022 21:00	0.5	13.8	1,691.2	0.7	1.6	1	1	0
01/26/2022 22:00	0.5	13.8	1,809.5	0.6	1.7	1	1	0
01/26/2022 23:00	1.1	13.0	2,021.0	0.5	3.7	1	1	1
Average/Sum#:	3.9	13.8	1,701.1	0.6	135.0 #	18 #	19 #	10 #
Minimum:	0.5	12.7	322.6	0.5	1.6	0	0	0
Maximum:	26.7	17.9	2,033.8	0.7	61.8	1	1	1
%SI	25.00	25.00	25.00	45.83	25.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:07 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit Unit CT1	> Limit Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/27/2022 00:00	1.1	13.1	1,983.2	0.7	3.7	1	1	1
01/27/2022 01:00	0.7	13.8	1,538.6	0.7	2.0	1	1	1
01/27/2022 02:00	0.6	13.8	1,717.6	0.6	1.9	1	1	0
01/27/2022 03:00	1.1	13.2	1,962.9	0.6	3.7	1	1	1
01/27/2022 04:00	1.1	13.2	1,962.5	0.7	3.7	1	1	1
01/27/2022 05:00	0.6	13.8	1,599.2	0.7	1.8	1	1	0
01/27/2022 06:00	0.8	13.3	1,880.6	0.6	2.6	1	1	1
01/27/2022 07:00	1.1	12.9	2,035.5	0.6	3.7	1	1	1
01/27/2022 08:00	1.0	13.1	1,986.8	0.7	3.4	1	1	1
01/27/2022 09:00	0.9	13.5	1,695.4	0.8	2.7	1	1	1
01/27/2022 10:00	14.3	14.9	905.9	0.0	12.3	1	1	0
01/27/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	1	0
01/27/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	1	0
01/27/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	1	0
01/27/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	1	0
01/27/2022 15:00	20.8	17.9	320.2	0.0	13.8	1	1	0
01/27/2022 16:00	25.1	15.5	951.2	0.0	58.4	1	1	0
01/27/2022 17:00	0.6	13.9	1,542.4	0.0	1.7	1	1	0
01/27/2022 18:00	0.6	13.7	1,818.1	0.0	2.0	1	1	1
01/27/2022 19:00	1.0	12.8	2,026.7	0.6	3.3	1	1	1
01/27/2022 20:00	0.9	12.9	2,002.8	0.6	3.0	1	1	1
01/27/2022 21:00	0.5	13.8	1,695.8	0.6	1.6	1	1	0
01/27/2022 22:00	0.6	13.9	1,493.0	0.5	1.7	1	1	0
01/27/2022 23:00	1.0	13.3	1,930.5	0.6	3.4	1	1	1
Average/Sum#:	3.7	13.8	1,652.4	0.6	130.4 #	20 #	24 #	12 #
Minimum:	0.5	12.8	320.2	0.5	1.6	0	1	0
Maximum:	25.1	17.9	2,035.5	0.8	58.4	1	1	1
%SI	16.67	16.67	16.67	37.50	16.67	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:07 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit	> Limit			
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/28/2022 00:00	1.2	12.8	2,069.1	0.7	4.0	1	1	1
01/28/2022 01:00	1.2	12.7	2,058.1	0.9	4.0	1	1	1
01/28/2022 02:00	0.7	13.8	1,523.3	0.8	2.0	1	1	1
01/28/2022 03:00	0.6	13.8	1,537.5	0.7	1.7	1	1	0
01/28/2022 04:00	0.5	13.8	1,780.1	0.5	1.7	1	1	1
01/28/2022 05:00	1.1	13.0	2,014.7	0.6	3.7	1	1	1
01/28/2022 06:00	1.2	12.5	2,141.5	0.7	4.0	1	1	1
01/28/2022 07:00	1.2	12.5	2,126.0	0.8	4.0	1	1	1
01/28/2022 08:00	1.0	13.1	1,986.2	0.8	3.4	1	1	1
01/28/2022 09:00	0.7	13.9	1,542.1	0.7	2.0	1	1	0
01/28/2022 10:00	0.7	13.9	1,435.9	0.7	1.9	1	1	0
01/28/2022 11:00	0.6	13.9	1,506.9	0.6	1.7	1	1	0
01/28/2022 12:00	0.6	13.9	1,466.5	0.5	1.7	1	1	0
01/28/2022 13:00	0.6	13.9	1,448.2	0.5	1.6	1	1	0
01/28/2022 14:00	0.5	13.9	1,649.6	0.5	1.6	1	1	0
01/28/2022 15:00	0.5	13.9	1,573.8	0.4	1.5	1	1	0
01/28/2022 16:00	0.6	13.8	1,613.2	0.4	1.8	1	1	1
01/28/2022 17:00	1.2	13.2	1,937.0	0.6	4.0	1	1	1
01/28/2022 18:00	1.2	12.7	2,053.4	0.8	4.0	1	1	1
01/28/2022 19:00	1.3	12.2	2,168.5	0.9	4.3	1	1	1
01/28/2022 20:00	1.2	12.4	2,086.6	0.9	3.9	1	1	1
01/28/2022 21:00	0.6	13.9	1,544.3	0.7	1.7	1	1	0
01/28/2022 22:00	0.5	13.8	1,825.6	0.6	1.7	1	1	1
01/28/2022 23:00	1.1	13.0	1,998.7	0.6	3.7	1	1	1
Average/Sum#:	0.9	13.3	1,795.3	0.7	65.6 #	24 #	24 #	15 #
Minimum:	0.5	12.2	1,435.9	0.4	1.5	1	1	0
Maximum:	1.3	13.9	2,168.5	0.9	4.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:07 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit Unit CT1	> Limit Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/29/2022 00:00	1.1	13.2	1,944.2	0.7	3.7	1	1	1
01/29/2022 01:00	0.6	13.8	1,588.8	0.7	1.8	1	1	0
01/29/2022 02:00	0.8	13.8	1,599.6	0.7	2.4	1	1	1
01/29/2022 03:00	1.2	13.2	1,965.0	0.7	4.0	1	1	1
01/29/2022 04:00	1.1	13.2	1,946.9	0.8	3.7	1	1	1
01/29/2022 05:00	0.7	13.8	1,624.7	0.8	2.1	1	1	0
01/29/2022 06:00	0.8	13.8	1,644.8	0.7	2.4	1	1	1
01/29/2022 07:00	1.3	13.1	2,016.6	0.8	4.4	1	1	1
01/29/2022 08:00	1.1	12.9	2,061.6	0.8	3.7	1	1	1
01/29/2022 09:00	1.2	13.2	1,950.5	0.9	4.0	1	1	1
01/29/2022 10:00	0.7	13.9	1,422.6	0.8	1.9	1	1	0
01/29/2022 11:00	0.6	13.9	1,541.2	0.7	1.7	1	1	0
01/29/2022 12:00	0.6	13.9	1,389.9	0.5	1.6	1	1	0
01/29/2022 13:00	0.6	13.9	1,411.8	0.5	1.6	1	1	0
01/29/2022 14:00	0.5	13.9	1,626.6	0.5	1.5	1	1	0
01/29/2022 15:00	0.7	13.9	1,393.9	0.5	1.8	1	1	0
01/29/2022 16:00	0.6	13.9	1,607.4	0.5	1.8	1	1	0
01/29/2022 17:00	0.6	13.8	1,636.3	0.5	1.8	1	1	0
01/29/2022 18:00	0.9	13.4	1,825.0	0.6	2.9	1	1	1
01/29/2022 19:00	1.1	13.0	1,901.9	0.7	3.5	1	1	1
01/29/2022 20:00	0.6	13.8	1,806.0	0.7	2.0	1	1	1
01/29/2022 21:00	1.1	12.8	2,037.9	0.7	3.7	1	1	1
01/29/2022 22:00	1.1	12.3	2,128.6	0.7	3.6	1	1	1
01/29/2022 23:00	0.9	13.3	1,856.3	0.8	2.9	1	1	1
Average/Sum#:	0.9	13.5	1,747.0	0.7	64.5 #	24 #	24 #	14 #
Minimum:	0.5	12.3	1,389.9	0.5	1.5	1	1	0
Maximum:	1.3	13.9	2,128.6	0.9	4.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:07 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit Unit CT1	> Limit Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/30/2022 00:00	0.6	13.8	1,609.1	0.7	1.8	1	1	0
01/30/2022 01:00	0.9	13.9	1,401.1	0.7	2.4	1	1	0
01/30/2022 02:00	0.6	13.8	1,756.1	0.6	2.0	1	1	0
01/30/2022 03:00	1.0	13.4	1,887.8	0.7	3.3	1	1	1
01/30/2022 04:00	1.1	13.3	1,868.6	0.7	3.6	1	1	1
01/30/2022 05:00	0.7	13.8	1,626.7	0.8	2.1	1	1	1
01/30/2022 06:00	1.3	13.0	2,023.2	0.8	4.4	1	1	1
01/30/2022 07:00	7.7	13.7	1,536.4	0.0	16.7	1	0	1
01/30/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/30/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/30/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/30/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/30/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/30/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/30/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/30/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/30/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	1	0
01/30/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	1	0
01/30/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	1	0
01/30/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	1	0
01/30/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	1	0
01/30/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	1	0
01/30/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	1	0
01/30/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	1	0
Average/Sum#:	1.7	13.6	1,713.6	0.7	36.3 #	8 #	15 #	5 #
Minimum:	0.6	13.0	1,401.1	0.6	1.8	0	0	0
Maximum:	7.7	13.9	2,023.2	0.8	16.7	1	1	1
%SI	66.67	66.67	66.67	70.83	66.67	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:07 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit	> Limit	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/31/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	1	0
01/31/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	1	0
01/31/2022 02:00	61.5	17.6	342.8	0.0	60.8	1	1	0
01/31/2022 03:00	42.7	15.5	865.7	0.0	90.4	1	1	0
01/31/2022 04:00	0.8	13.8	1,487.4	0.0	2.2	1	1	0
01/31/2022 05:00	0.7	13.8	1,606.4	0.0	2.1	1	1	1
01/31/2022 06:00	0.9	13.0	1,991.1	0.7	3.0	1	1	1
01/31/2022 07:00	1.0	12.9	2,064.8	0.7	3.4	1	1	1
01/31/2022 08:00	0.9	13.2	1,960.7	0.7	3.0	1	1	1
01/31/2022 09:00	0.7	13.8	1,610.1	0.7	2.1	1	1	1
01/31/2022 10:00	0.8	13.8	1,490.7	0.7	2.2	1	1	0
01/31/2022 11:00	0.6	13.8	1,563.0	0.6	1.7	1	1	0
01/31/2022 12:00	0.6	13.8	1,600.6	0.6	1.8	1	1	0
01/31/2022 13:00	0.6	13.9	1,442.8	0.5	1.6	1	1	0
01/31/2022 14:00	0.6	13.9	1,561.2	0.5	1.8	1	1	0
01/31/2022 15:00	0.7	13.7	1,659.5	0.5	2.1	1	1	1
01/31/2022 16:00	1.2	12.8	2,010.2	0.7	3.9	1	1	1
01/31/2022 17:00	1.3	12.4	2,118.2	0.8	4.3	1	1	1
01/31/2022 18:00	1.2	12.4	2,120.0	0.9	4.0	1	1	1
01/31/2022 19:00	1.0	13.1	1,938.8	0.8	3.3	1	1	1
01/31/2022 20:00	0.5	13.8	1,615.9	0.7	1.5	1	1	0
01/31/2022 21:00	0.5	13.8	1,688.6	0.5	1.6	1	1	1
01/31/2022 22:00	1.2	12.9	2,010.8	0.6	4.0	1	1	1
01/31/2022 23:00	10.2	14.3	1,222.7	0.0	12.0	1	0	1
Average/Sum#:	5.9	13.7	1,635.1	0.7	212.8 #	22 #	23 #	13 #
Minimum:	0.5	12.4	342.8	0.5	1.5	0	0	0
Maximum:	61.5	17.6	2,120.0	0.9	90.4	1	1	1
%SI	8.33	8.33	8.33	29.17	8.33	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:07 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit Unit CT1	> Limit Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/01/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2022 05:00	52.1	16.6	465.6	0.0	65.6	1	1	0
02/01/2022 06:00	35.7	14.5	1,134.6	0.0	83.6	1	1	0
02/01/2022 07:00	1.0	13.1	1,674.3	0.0	2.8	1	1	1
02/01/2022 08:00	1.1	11.6	2,360.2	0.0	3.7	1	1	1
02/01/2022 09:00	1.0	11.5	2,355.4	0.7	3.3	1	1	1
02/01/2022 10:00	0.6	13.5	1,868.7	0.6	2.0	1	1	1
02/01/2022 11:00	0.5	13.9	1,569.3	0.5	1.5	1	1	0
02/01/2022 12:00	0.7	13.9	1,312.6	0.5	1.7	1	1	0
02/01/2022 13:00	0.7	13.9	1,312.2	0.5	1.7	1	1	0
02/01/2022 14:00	0.7	13.9	1,313.0	0.6	1.7	1	1	0
02/01/2022 15:00	0.6	13.9	1,335.2	0.6	1.5	1	1	0
02/01/2022 16:00	0.6	13.9	1,559.0	0.5	1.8	1	1	0
02/01/2022 17:00	0.5	13.8	1,818.8	0.5	1.7	1	1	0
02/01/2022 18:00	1.0	13.2	1,951.6	0.6	3.3	1	1	1
02/01/2022 19:00	1.1	12.8	2,058.6	0.7	3.7	1	1	1
02/01/2022 20:00	1.1	12.9	2,005.4	0.8	3.6	1	1	1
02/01/2022 21:00	0.5	13.8	1,615.2	0.7	1.5	1	1	0
02/01/2022 22:00	0.5	13.8	1,798.8	0.5	1.7	1	1	1
02/01/2022 23:00	1.1	12.9	2,049.6	0.5	3.7	1	1	1
Average/Sum#:	5.3	13.5	1,661.0	0.6	190.1 #	19 #	19 #	9 #
Minimum:	0.5	11.5	465.6	0.5	1.5	0	0	0
Maximum:	52.1	16.6	2,360.2	0.8	83.6	1	1	1
%SI	20.83	20.83	20.83	37.50	20.83	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:07 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit Unit CT1	> Limit Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/02/2022 00:00	1.2	12.2	2,195.1	0.7	4.0	1	1	1
02/02/2022 01:00	0.6	13.7	1,750.9	0.7	1.9	1	1	1
02/02/2022 02:00	0.7	13.8	1,609.1	0.6	2.1	1	1	1
02/02/2022 03:00	1.1	13.0	2,029.7	0.6	3.7	1	1	1
02/02/2022 04:00	1.0	13.1	1,996.9	0.7	3.4	1	1	1
02/02/2022 05:00	1.2	12.8	2,053.5	0.8	4.0	1	1	1
02/02/2022 06:00	1.2	12.7	2,114.5	0.9	4.1	1	1	1
02/02/2022 07:00	1.2	12.8	2,069.7	0.9	4.0	1	1	1
02/02/2022 08:00	1.0	13.0	2,038.4	0.8	3.4	1	1	1
02/02/2022 09:00	0.9	13.6	1,675.6	0.8	2.7	1	1	1
02/02/2022 10:00	13.8	14.9	907.4	0.0	11.6	1	1	0
02/02/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	1	0
02/02/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	1	0
02/02/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	1	0
02/02/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	1	0
02/02/2022 15:00	14.5	18.7	213.6	0.0	4.3	1	1	0
02/02/2022 16:00	77.1	15.9	707.7	0.0	144.1	1	1	0
02/02/2022 17:00	0.7	13.7	1,727.8	0.0	2.2	1	1	1
02/02/2022 18:00	1.2	12.7	2,083.0	0.0	4.0	1	1	1
02/02/2022 19:00	1.0	11.9	2,264.5	0.0	3.3	1	1	1
02/02/2022 20:00	0.9	11.8	2,275.1	0.7	3.0	1	1	1
02/02/2022 21:00	1.0	12.1	2,191.9	0.7	3.3	1	1	1
02/02/2022 22:00	0.9	12.5	2,093.8	0.6	3.0	1	1	1
02/02/2022 23:00	1.0	12.7	2,063.8	0.7	3.3	1	1	1
Average/Sum#:	6.1	13.4	1,803.1	0.7	215.4 #	20 #	24 #	17 #
Minimum:	0.6	11.8	213.6	0.6	1.9	0	1	0
Maximum:	77.1	18.7	2,275.1	0.9	144.1	1	1	1
%SI	16.67	16.67	16.67	41.67	16.67	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:07 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit Unit CT1	> Limit Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/03/2022 00:00	0.8	13.2	1,946.0	0.6	2.7	1	1	1
02/03/2022 01:00	0.5	13.8	1,686.6	0.6	1.6	1	1	0
02/03/2022 02:00	0.5	13.8	1,817.8	0.5	1.7	1	1	1
02/03/2022 03:00	0.9	12.8	2,041.4	0.5	3.0	1	1	1
02/03/2022 04:00	0.9	12.9	2,021.0	0.6	3.0	1	1	1
02/03/2022 05:00	0.9	12.8	2,031.6	0.7	3.0	1	1	1
02/03/2022 06:00	1.0	12.3	2,185.2	0.7	3.4	1	1	1
02/03/2022 07:00	0.9	12.5	2,127.9	0.7	3.0	1	1	1
02/03/2022 08:00	0.8	13.2	1,953.7	0.6	2.7	1	1	1
02/03/2022 09:00	0.7	13.8	1,477.4	0.6	1.9	1	1	1
02/03/2022 10:00	0.6	13.8	1,689.7	0.6	1.9	1	1	0
02/03/2022 11:00	0.5	13.8	1,695.7	0.5	1.6	1	1	0
02/03/2022 12:00	0.6	13.9	1,405.6	0.5	1.6	1	1	0
02/03/2022 13:00	0.6	13.9	1,574.3	0.5	1.8	1	1	0
02/03/2022 14:00	0.6	13.9	1,494.0	0.5	1.7	1	1	0
02/03/2022 15:00	0.6	13.8	1,555.7	0.5	1.7	1	1	1
02/03/2022 16:00	1.2	12.8	2,008.0	0.6	3.9	1	1	1
02/03/2022 17:00	1.3	12.4	2,098.2	0.8	4.2	1	1	1
02/03/2022 18:00	1.2	12.3	2,148.2	0.9	4.0	1	1	1
02/03/2022 19:00	1.2	12.3	2,151.2	0.8	4.0	1	1	1
02/03/2022 20:00	1.2	12.3	2,153.7	0.8	4.0	1	1	1
02/03/2022 21:00	1.1	12.0	2,215.7	0.8	3.6	1	1	1
02/03/2022 22:00	1.2	12.4	2,126.4	0.8	4.0	1	1	1
02/03/2022 23:00	1.2	12.5	2,101.7	0.8	4.0	1	1	1
Average/Sum#:	0.9	13.1	1,904.4	0.6	68.0 #	24 #	24 #	18 #
Minimum:	0.5	12.0	1,405.6	0.5	1.6	1	1	0
Maximum:	1.3	13.9	2,215.7	0.9	4.2	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:07 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit Unit CT1	> Limit Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/04/2022 00:00	1.1	12.7	2,062.4	0.8	3.7	1	1	1
02/04/2022 01:00	1.0	13.2	1,939.9	0.8	3.3	1	1	1
02/04/2022 02:00	0.6	13.8	1,629.5	0.7	1.8	1	1	0
02/04/2022 03:00	0.6	13.8	1,557.9	0.6	1.7	1	1	0
02/04/2022 04:00	0.7	13.8	1,618.4	0.5	2.1	1	1	1
02/04/2022 05:00	1.3	12.8	2,032.7	0.7	4.3	1	1	1
02/04/2022 06:00	1.3	12.2	2,194.2	0.8	4.3	1	1	1
02/04/2022 07:00	1.1	12.6	2,098.0	0.9	3.7	1	1	1
02/04/2022 08:00	10.2	14.6	1,200.8	0.0	12.3	1	0	1
02/04/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/04/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/04/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/04/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/04/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	1	0
02/04/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	1	0
02/04/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	1	0
02/04/2022 16:00	103.8	16.3	627.0	0.0	186.9	1	1	0
02/04/2022 17:00	8.4	14.0	1,550.1	0.0	24.9	1	1	0
02/04/2022 18:00	0.7	13.9	1,487.3	0.0	2.0	1	1	0
02/04/2022 19:00	1.1	13.2	1,909.6	0.0	3.6	1	1	1
02/04/2022 20:00	1.2	13.1	1,952.9	0.8	4.0	1	1	1
02/04/2022 21:00	1.1	13.2	1,948.3	0.8	3.7	1	1	1
02/04/2022 22:00	1.1	13.1	1,975.5	0.8	3.7	1	1	1
02/04/2022 23:00	1.2	12.7	2,055.7	0.8	4.0	1	1	1
Average/Sum#:	8.0	13.5	1,755.3	0.8	270.0 #	17 #	19 #	12 #
Minimum:	0.6	12.2	627.0	0.5	1.7	0	0	0
Maximum:	103.8	16.3	2,194.2	0.9	186.9	1	1	1
%SI	29.17	29.17	29.17	50.00	29.17	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:07 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit Unit CT1	> Limit Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/05/2022 00:00	1.1	13.2	1,952.1	0.8	3.7	1	1	1
02/05/2022 01:00	0.7	13.7	1,719.6	0.8	2.2	1	1	1
02/05/2022 02:00	0.8	13.9	1,425.1	0.7	2.2	1	1	0
02/05/2022 03:00	1.0	13.3	1,917.8	0.7	3.3	1	1	1
02/05/2022 04:00	1.1	13.2	1,962.5	0.8	3.7	1	1	1
02/05/2022 05:00	0.6	13.8	1,738.0	0.7	1.9	1	1	1
02/05/2022 06:00	0.7	13.8	1,621.4	0.6	2.1	1	1	1
02/05/2022 07:00	1.2	12.8	2,041.6	0.7	4.0	1	1	1
02/05/2022 08:00	10.9	14.4	1,233.2	0.0	13.7	1	0	1
02/05/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/05/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/05/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/05/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/05/2022 13:00	16.5	18.1	294.9	0.0	8.7	1	0	0
02/05/2022 14:00	37.1	15.5	856.7	0.0	77.7	1	0	0
02/05/2022 15:00	0.6	13.9	1,374.8	0.0	1.6	1	0	0
02/05/2022 16:00	0.6	13.9	1,430.8	0.0	1.6	1	0	0
02/05/2022 17:00	0.6	13.8	1,622.3	0.5	1.8	1	0	0
02/05/2022 18:00	0.6	13.8	1,609.8	0.5	1.8	1	0	0
02/05/2022 19:00	0.6	14.0	1,319.6	0.5	1.5	1	1	0
02/05/2022 20:00	0.7	13.8	1,573.5	0.5	2.0	1	1	1
02/05/2022 21:00	1.3	12.7	2,038.2	0.7	4.3	1	1	1
02/05/2022 22:00	1.2	12.7	2,054.3	0.8	4.0	1	1	1
02/05/2022 23:00	1.2	12.7	2,061.0	0.9	4.0	1	1	1
Average/Sum#:	4.0	13.9	1,592.4	0.7	145.8 #	20 #	13 #	12 #
Minimum:	0.6	12.7	294.9	0.5	1.5	0	0	0
Maximum:	37.1	18.1	2,061.0	0.9	77.7	1	1	1
%SI	16.67	16.67	16.67	37.50	16.67	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:07 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit Unit CT1	> Limit Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/06/2022 00:00	1.1	13.2	1,947.5	0.9	3.7	1	1	1
02/06/2022 01:00	0.6	13.8	1,698.0	0.7	1.9	1	1	1
02/06/2022 02:00	0.7	13.8	1,639.8	0.6	2.1	1	1	1
02/06/2022 03:00	1.0	12.9	2,015.1	0.6	3.3	1	1	1
02/06/2022 04:00	0.9	13.2	1,943.3	0.7	3.0	1	1	1
02/06/2022 05:00	0.6	13.8	1,585.3	0.6	1.8	1	1	0
02/06/2022 06:00	0.9	13.9	1,333.8	0.7	2.3	1	1	0
02/06/2022 07:00	0.6	13.8	1,573.7	0.6	1.8	1	1	0
02/06/2022 08:00	26.3	15.9	468.5	0.0	5.9	1	0	0
02/06/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/06/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/06/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/06/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/06/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/06/2022 14:00	20.8	17.9	314.7	0.0	13.0	1	0	0
02/06/2022 15:00	36.4	15.5	848.0	0.0	75.5	1	0	0
02/06/2022 16:00	0.6	13.9	1,398.6	0.0	1.6	1	0	0
02/06/2022 17:00	1.2	13.2	1,882.9	0.0	3.9	1	0	1
02/06/2022 18:00	1.3	13.0	1,945.2	0.8	4.2	1	0	1
02/06/2022 19:00	1.3	13.1	1,944.8	1.0	4.3	1	0	1
02/06/2022 20:00	1.3	13.1	1,943.8	1.0	4.3	1	0	1
02/06/2022 21:00	1.3	13.1	1,933.6	1.0	4.3	1	0	1
02/06/2022 22:00	0.7	13.8	1,659.3	0.9	2.2	1	0	0
02/06/2022 23:00	38.6	16.1	421.3	0.0	8.0	1	0	0
Average/Sum#:	7.2	14.1	1,499.9	0.8	147.1 #	19 #	8 #	10 #
Minimum:	0.6	12.9	314.7	0.6	1.6	0	0	0
Maximum:	38.6	17.9	2,015.1	1.0	75.5	1	1	1
%SI	20.83	20.83	20.83	45.83	20.83	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:07 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit	> Limit	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT1	Unit CT1	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	CO, _3Hr, Ppmvdc	CO, Lb	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/07/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/07/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/07/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/07/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/07/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/07/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/07/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/07/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/07/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/07/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/07/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/07/2022 11:00	49.5	17.9	291.8	0.0	44.5	1	0	0
02/07/2022 12:00	26.2	17.5	332.8	0.0	33.9	1	0	0
02/07/2022 13:00	51.3	15.7	796.3	0.0	103.8	1	0	0
02/07/2022 14:00	0.7	13.9	1,385.1	0.0	1.8	1	0	0
02/07/2022 15:00	0.7	13.9	1,384.8	0.0	1.8	1	0	0
02/07/2022 16:00	0.6	13.7	1,656.0	0.6	1.8	1	0	0
02/07/2022 17:00	0.7	13.9	1,583.3	0.6	2.1	1	0	0
02/07/2022 18:00	0.7	13.9	1,422.9	0.6	1.9	1	1	0
02/07/2022 19:00	0.7	13.8	1,596.4	0.6	2.1	1	1	1
02/07/2022 20:00	1.4	12.6	2,078.8	0.7	4.6	1	1	1
02/07/2022 21:00	1.3	12.5	2,103.3	0.8	4.3	1	1	1
02/07/2022 22:00	1.2	12.6	2,089.7	0.9	4.0	1	1	1
02/07/2022 23:00	11.2	14.3	1,231.5	0.0	13.2	1	0	1
Average/Sum#:	11.2	14.3	1,381.0	0.7	219.8 #	13 #	5 #	5 #
Minimum:	0.6	12.5	291.8	0.6	1.8	0	0	0
Maximum:	51.3	17.9	2,103.3	0.9	103.8	1	1	1
%SI	45.83	45.83	45.83	70.83	45.83	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:07 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit Unit CT1	> Limit Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/08/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2022 03:00	18.2	17.7	359.4	0.0	18.9	1	0	0
02/08/2022 04:00	22.0	14.5	1,227.9	0.0	55.7	1	0	0
02/08/2022 05:00	0.7	13.9	1,408.0	0.0	1.9	1	0	0
02/08/2022 06:00	0.7	13.9	1,399.1	0.0	1.8	1	0	0
02/08/2022 07:00	0.7	13.9	1,297.0	0.6	1.7	1	1	0
02/08/2022 08:00	0.5	13.8	1,823.6	0.5	1.7	1	1	0
02/08/2022 09:00	0.6	13.7	1,842.9	0.5	2.0	1	1	0
02/08/2022 10:00	0.6	13.7	1,843.3	0.5	2.0	1	1	0
02/08/2022 11:00	0.6	13.7	1,841.3	0.5	2.0	1	1	0
02/08/2022 12:00	0.6	13.6	1,853.5	0.5	2.0	1	1	0
02/08/2022 13:00	0.6	13.6	1,854.8	0.5	2.0	1	1	0
02/08/2022 14:00	0.6	13.6	1,856.2	0.5	2.0	1	1	0
02/08/2022 15:00	0.6	13.7	1,830.2	0.5	2.0	1	1	0
02/08/2022 16:00	0.6	13.7	1,825.9	0.5	2.0	1	1	0
02/08/2022 17:00	1.2	13.2	1,939.9	0.6	4.0	1	1	1
02/08/2022 18:00	1.2	12.9	2,018.1	0.8	4.0	1	1	1
02/08/2022 19:00	1.2	13.1	1,983.1	0.9	4.0	1	1	1
02/08/2022 20:00	1.3	13.1	1,990.6	0.9	4.4	1	1	1
02/08/2022 21:00	0.9	13.5	1,719.2	0.9	2.8	1	1	1
02/08/2022 22:00	0.6	13.9	1,427.9	0.7	1.6	1	0	0
02/08/2022 23:00	0.6	13.9	1,385.9	0.6	1.6	1	0	0
Average/Sum#:	2.6	13.8	1,653.7	0.6	120.1 #	21 #	15 #	5 #
Minimum:	0.5	12.9	359.4	0.5	1.6	0	0	0
Maximum:	22.0	17.7	2,018.1	0.9	55.7	1	1	1
%SI	12.50	12.50	12.50	29.17	12.50	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:07 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit Unit CT1	> Limit Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/09/2022 00:00	0.6	13.9	1,390.8	0.5	1.6	1	0	0
02/09/2022 01:00	0.6	13.9	1,398.1	0.5	1.6	1	0	0
02/09/2022 02:00	0.6	13.9	1,394.6	0.5	1.6	1	0	0
02/09/2022 03:00	0.6	13.9	1,390.2	0.5	1.6	1	0	0
02/09/2022 04:00	0.7	13.9	1,389.2	0.5	1.8	1	0	0
02/09/2022 05:00	0.7	13.9	1,386.7	0.6	1.8	1	0	0
02/09/2022 06:00	0.8	13.9	1,416.6	0.6	2.1	1	0	0
02/09/2022 07:00	0.6	13.7	1,839.7	0.6	2.0	1	0	0
02/09/2022 08:00	0.6	13.7	1,853.6	0.6	2.0	1	0	0
02/09/2022 09:00	0.6	13.6	1,872.2	0.5	2.0	1	0	0
02/09/2022 10:00	0.6	13.6	1,864.0	0.5	2.0	1	0	1
02/09/2022 11:00	1.2	12.1	2,199.8	0.6	4.0	1	0	1
02/09/2022 12:00	1.1	12.2	2,109.9	0.7	3.5	1	0	1
02/09/2022 13:00	0.6	13.6	1,843.8	0.7	2.0	1	0	0
02/09/2022 14:00	0.6	13.6	1,844.5	0.6	2.0	1	0	0
02/09/2022 15:00	0.6	13.8	1,651.5	0.5	1.8	1	0	0
02/09/2022 16:00	0.6	13.7	1,749.8	0.5	1.9	1	0	0
02/09/2022 17:00	0.6	13.7	1,723.5	0.5	1.9	1	0	0
02/09/2022 18:00	0.6	13.7	1,828.1	0.5	2.0	1	1	1
02/09/2022 19:00	1.1	12.8	2,039.5	0.6	3.7	1	1	1
02/09/2022 20:00	1.2	12.5	2,112.4	0.7	4.0	1	1	1
02/09/2022 21:00	1.1	12.4	2,117.3	0.8	3.6	1	1	1
02/09/2022 22:00	1.0	12.7	2,043.9	0.8	3.3	1	1	1
02/09/2022 23:00	0.8	13.7	1,546.5	0.7	2.3	1	1	1
Average/Sum#:	0.8	13.4	1,750.3	0.6	56.1 #	24 #	6 #	9 #
Minimum:	0.6	12.1	1,386.7	0.5	1.6	1	0	0
Maximum:	1.2	13.9	2,199.8	0.8	4.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:07 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit Unit CT1	> Limit Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/10/2022 00:00	0.7	13.9	1,383.3	0.7	1.8	1	1	0
02/10/2022 01:00	0.6	13.7	1,624.4	0.6	1.8	1	1	1
02/10/2022 02:00	1.3	13.0	1,995.6	0.7	4.3	1	1	1
02/10/2022 03:00	1.2	12.9	2,005.0	0.8	4.0	1	1	1
02/10/2022 04:00	0.6	13.8	1,631.2	0.8	1.8	1	1	1
02/10/2022 05:00	0.7	13.7	1,617.8	0.7	2.1	1	1	1
02/10/2022 06:00	1.3	12.6	2,087.3	0.7	4.3	1	1	1
02/10/2022 07:00	1.2	12.6	2,054.1	0.8	3.9	1	1	1
02/10/2022 08:00	22.6	15.6	622.6	0.0	8.1	1	0	0
02/10/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/10/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/10/2022 11:00	6.7	18.9	145.9	0.0	1.1	1	0	0
02/10/2022 12:00	40.2	15.7	810.5	0.0	82.8	1	0	0
02/10/2022 13:00	0.5	13.9	1,397.4	0.0	1.3	1	0	0
02/10/2022 14:00	0.5	13.9	1,393.4	0.0	1.3	1	0	0
02/10/2022 15:00	0.6	13.7	1,646.0	0.4	1.8	1	0	0
02/10/2022 16:00	0.6	13.8	1,607.0	0.5	1.8	1	0	0
02/10/2022 17:00	0.9	13.2	1,587.8	0.6	2.5	1	1	1
02/10/2022 18:00	1.2	11.5	2,315.1	0.7	3.9	1	1	1
02/10/2022 19:00	1.1	11.7	2,278.8	0.7	3.6	1	1	1
02/10/2022 20:00	1.2	12.0	2,193.6	0.8	3.9	1	1	1
02/10/2022 21:00	1.2	12.6	2,074.4	0.8	4.0	1	1	1
02/10/2022 22:00	1.2	12.7	2,040.5	0.9	3.9	1	1	1
02/10/2022 23:00	0.9	13.6	1,539.0	0.8	2.5	1	1	1
Average/Sum#:	4.0	13.6	1,638.7	0.7	146.5 #	22 #	15 #	14 #
Minimum:	0.5	11.5	145.9	0.4	1.1	0	0	0
Maximum:	40.2	18.9	2,315.1	0.9	82.8	1	1	1
%SI	8.33	8.33	8.33	29.17	8.33	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:07 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit Unit CT1	> Limit Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/11/2022 00:00	0.9	13.9	1,324.4	0.8	2.2	1	1	0
02/11/2022 01:00	28.7	16.3	362.2	0.0	5.1	1	0	0
02/11/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/11/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/11/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/11/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/11/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/11/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/11/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/11/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/11/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/11/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/11/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/11/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/11/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/11/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/11/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/11/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/11/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/11/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/11/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/11/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/11/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/11/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	14.8	15.1	843.3	0.8	7.3 #	2 #	1 #	0 #
Minimum:	0.9	13.9	362.2	0.8	2.2	0	0	0
Maximum:	28.7	16.3	1,324.4	0.8	5.1	1	1	0
%SI	91.67	91.67	91.67	95.83	91.67	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:07 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit Unit CT1	> Limit Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/12/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/12/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/12/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/12/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/12/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/12/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/12/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/12/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/12/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/12/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/12/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/12/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/12/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/12/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/12/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/12/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/12/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/12/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/12/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/12/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/12/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/12/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/12/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/12/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:07 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit	> Limit	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT1	Unit CT1	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	CO, _3Hr, Ppmvdc	CO, Lb	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/13/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/13/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/13/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/13/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/13/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/13/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/13/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/13/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/13/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/13/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/13/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/13/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/13/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/13/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/13/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/13/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/13/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/13/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/13/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/13/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/13/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/13/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/13/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/13/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:07 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit Unit CT1	> Limit Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/14/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:07 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/15/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:07 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit Unit CT1	> Limit Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/16/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:07 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit Unit CT1	> Limit Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/17/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:07 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit	> Limit	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT1	Unit CT1	UnitOn, TF	NormalOp, TF	DBOn, TF
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/18/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/18/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/18/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/18/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/18/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/18/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/18/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/18/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/18/2022 08:00	113.1	19.3	116.9	0.0	18.5	1	0	0
02/18/2022 09:00	45.3	17.2	379.6	0.0	61.4	1	0	0
02/18/2022 10:00	18.4	17.2	393.2	0.0	25.8	1	0	0
02/18/2022 11:00	73.0	16.2	684.0	0.0	140.3	1	0	0
02/18/2022 12:00	43.8	15.0	1,006.2	0.0	98.7	1	0	0
02/18/2022 13:00	0.6	13.9	1,394.1	0.0	1.6	1	0	0
02/18/2022 14:00	0.6	13.9	1,395.8	0.0	1.6	1	0	0
02/18/2022 15:00	0.6	13.8	1,751.9	0.5	2.0	1	0	0
02/18/2022 16:00	0.7	13.8	1,597.5	0.5	2.1	1	0	0
02/18/2022 17:00	0.6	13.9	1,658.4	0.5	1.9	1	1	0
02/18/2022 18:00	0.7	13.8	1,594.8	0.6	2.1	1	1	1
02/18/2022 19:00	1.3	12.8	2,037.3	0.7	4.3	1	1	1
02/18/2022 20:00	1.2	13.1	1,958.5	0.8	4.0	1	1	1
02/18/2022 21:00	0.7	13.8	1,578.7	0.8	2.1	1	1	0
02/18/2022 22:00	0.7	13.8	1,609.8	0.7	2.1	1	1	1
02/18/2022 23:00	1.2	12.9	2,034.1	0.7	4.0	1	1	1
Average/Sum#:	18.9	14.7	1,324.4	0.6	372.5 #	16 #	7 #	5 #
Minimum:	0.6	12.8	116.9	0.5	1.6	0	0	0
Maximum:	113.1	19.3	2,037.3	0.8	140.3	1	1	1
%SI	33.33	33.33	33.33	62.50	33.33	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:07 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit	> Limit	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/19/2022 00:00	11.4	14.3	1,260.4	0.0	13.8	1	0	1
02/19/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/19/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/19/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/19/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/19/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/19/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/19/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/19/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/19/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/19/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/19/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/19/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/19/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/19/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/19/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/19/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/19/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/19/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/19/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/19/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/19/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/19/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/19/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	11.4	14.3	1,260.4	0.0	13.8 #	1 #	0 #	1 #
Minimum:	11.4	14.3	1,260.4	0.0	13.8	0	0	0
Maximum:	11.4	14.3	1,260.4	0.0	13.8	1	0	1
%SI	95.83	95.83	95.83	100.00	95.83	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:07 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit Unit CT1	> Limit Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/20/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:07 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit	> Limit	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/21/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2022 23:00	75.0	17.6	324.7	0.0	68.3	1	0	0
Average/Sum#:	75.0	17.6	324.7	0.0	68.3 #	1 #	0 #	0 #
Minimum:	75.0	17.6	324.7	0.0	68.3	0	0	0
Maximum:	75.0	17.6	324.7	0.0	68.3	1	0	0
%SI	95.83	95.83	95.83	100.00	95.83	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:07 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit	> Limit	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT1	Unit CT1	UnitOn, TF	NormalOp, TF	DBOn, TF
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/22/2022 00:00	22.7	17.2	381.3	0.0	30.9	1	0	0
02/22/2022 01:00	43.3	16.1	705.1	0.0	84.0	1	0	0
02/22/2022 02:00	0.9	13.8	1,453.2	0.0	2.4	1	0	0
02/22/2022 03:00	0.9	13.8	1,460.4	0.0	2.4	1	0	0
02/22/2022 04:00	0.9	13.7	1,697.2	0.7	2.8	1	0	0
02/22/2022 05:00	0.9	13.8	1,582.8	0.7	2.6	1	0	0
02/22/2022 06:00	0.7	13.8	1,764.2	0.7	2.3	1	1	0
02/22/2022 07:00	0.8	13.8	1,602.1	0.7	2.4	1	1	0
02/22/2022 08:00	0.7	13.8	1,669.2	0.6	2.2	1	1	0
02/22/2022 09:00	0.8	13.8	1,568.6	0.7	2.3	1	1	0
02/22/2022 10:00	0.7	13.8	1,547.1	0.6	2.0	1	1	0
02/22/2022 11:00	0.7	13.8	1,547.9	0.6	2.0	1	1	0
02/22/2022 12:00	0.6	13.8	1,626.2	0.6	1.8	1	1	0
02/22/2022 13:00	0.7	13.8	1,611.1	0.6	2.1	1	1	0
02/22/2022 14:00	0.6	13.8	1,631.0	0.5	1.8	1	1	0
02/22/2022 15:00	0.7	13.8	1,645.7	0.6	2.1	1	1	0
02/22/2022 16:00	0.7	13.8	1,652.3	0.6	2.2	1	1	1
02/22/2022 17:00	1.4	12.8	2,095.9	0.7	4.8	1	1	1
02/22/2022 18:00	1.3	12.7	2,105.6	0.8	4.4	1	1	1
02/22/2022 19:00	1.3	12.4	2,199.4	0.9	4.4	1	1	1
02/22/2022 20:00	1.2	11.8	2,337.7	0.9	4.1	1	1	1
02/22/2022 21:00	1.3	12.4	2,183.6	0.9	4.4	1	1	1
02/22/2022 22:00	1.3	12.4	2,174.0	0.9	4.4	1	1	1
02/22/2022 23:00	1.3	12.2	2,220.4	0.9	4.4	1	1	1
Average/Sum#:	3.6	13.6	1,685.9	0.7	179.2 #	24 #	18 #	8 #
Minimum:	0.6	11.8	381.3	0.5	1.8	1	0	0
Maximum:	43.3	17.2	2,337.7	0.9	84.0	1	1	1
%SI	0.00	0.00	0.00	16.67	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:07 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit Unit CT1	> Limit Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/23/2022 00:00	1.2	11.9	2,302.6	0.9	4.1	1	1	1
02/23/2022 01:00	1.3	12.1	2,240.7	0.9	4.4	1	1	1
02/23/2022 02:00	1.3	12.2	2,223.9	0.9	4.4	1	1	1
02/23/2022 03:00	1.2	12.7	2,092.5	0.9	4.0	1	1	1
02/23/2022 04:00	0.6	13.8	1,735.7	0.8	1.9	1	1	0
02/23/2022 05:00	1.1	13.3	1,902.1	0.8	3.6	1	1	1
02/23/2022 06:00	1.3	12.3	2,247.5	0.8	4.5	1	1	1
02/23/2022 07:00	1.3	12.2	2,247.8	0.9	4.4	1	1	1
02/23/2022 08:00	0.7	13.6	1,730.6	0.8	2.2	1	1	1
02/23/2022 09:00	0.7	13.8	1,565.1	0.7	2.0	1	1	0
02/23/2022 10:00	0.7	13.8	1,627.6	0.6	2.1	1	1	0
02/23/2022 11:00	0.6	13.8	1,691.9	0.6	1.9	1	1	0
02/23/2022 12:00	0.7	13.9	1,557.1	0.6	2.1	1	1	0
02/23/2022 13:00	0.7	13.9	1,459.5	0.6	1.9	1	1	0
02/23/2022 14:00	0.6	13.8	1,670.8	0.6	1.9	1	1	0
02/23/2022 15:00	0.6	13.8	1,638.1	0.5	1.8	1	1	0
02/23/2022 16:00	0.7	13.8	1,662.2	0.5	2.2	1	1	1
02/23/2022 17:00	1.2	13.0	2,048.2	0.7	4.1	1	1	1
02/23/2022 18:00	1.2	12.8	2,093.4	0.8	4.1	1	1	1
02/23/2022 19:00	1.1	12.9	2,094.3	0.9	3.8	1	1	1
02/23/2022 20:00	1.2	12.4	2,194.8	0.8	4.1	1	1	1
02/23/2022 21:00	1.1	11.7	2,355.2	0.8	3.7	1	1	1
02/23/2022 22:00	1.2	12.3	2,217.2	0.8	4.1	1	1	1
02/23/2022 23:00	1.2	12.6	2,170.8	0.8	4.1	1	1	1
Average/Sum#:	1.0	13.0	1,948.7	0.8	77.4 #	24 #	24 #	16 #
Minimum:	0.6	11.7	1,459.5	0.5	1.8	1	1	0
Maximum:	1.3	13.9	2,355.2	0.9	4.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit Unit CT1	> Limit Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/24/2022 00:00	1.2	12.0	2,310.2	0.8	4.1	1	1	1
02/24/2022 01:00	1.2	12.0	2,301.4	0.8	4.1	1	1	1
02/24/2022 02:00	1.2	11.9	2,330.9	0.8	4.1	1	1	1
02/24/2022 03:00	1.1	11.7	2,357.2	0.8	3.7	1	1	1
02/24/2022 04:00	1.2	11.9	2,354.3	0.8	4.1	1	1	1
02/24/2022 05:00	1.2	11.8	2,360.9	0.8	4.1	1	1	1
02/24/2022 06:00	1.2	11.8	2,361.4	0.8	4.1	1	1	1
02/24/2022 07:00	1.2	12.2	2,279.1	0.8	4.2	1	1	1
02/24/2022 08:00	1.2	12.8	2,116.0	0.8	4.1	1	1	1
02/24/2022 09:00	1.1	13.1	2,020.2	0.8	3.8	1	1	1
02/24/2022 10:00	0.7	13.8	1,604.3	0.8	2.1	1	1	0
02/24/2022 11:00	0.8	13.9	1,464.1	0.7	2.2	1	1	0
02/24/2022 12:00	0.9	13.9	1,369.7	0.7	2.3	1	1	0
02/24/2022 13:00	0.7	13.9	1,419.0	0.7	1.9	1	1	0
02/24/2022 14:00	0.7	13.9	1,502.8	0.7	2.0	1	1	0
02/24/2022 15:00	0.7	13.9	1,498.2	0.6	2.0	1	1	0
02/24/2022 16:00	0.8	13.8	1,608.5	0.6	2.4	1	1	1
02/24/2022 17:00	1.2	12.9	2,054.7	0.7	4.1	1	1	1
02/24/2022 18:00	1.2	11.9	2,302.0	0.8	4.1	1	1	1
02/24/2022 19:00	1.1	11.6	2,358.8	0.8	3.7	1	1	1
02/24/2022 20:00	1.1	12.0	2,276.3	0.7	3.7	1	1	1
02/24/2022 21:00	1.1	11.8	2,316.4	0.7	3.7	1	1	1
02/24/2022 22:00	1.2	12.0	2,306.8	0.7	4.1	1	1	1
02/24/2022 23:00	1.3	12.2	2,245.5	0.8	4.4	1	1	1
Average/Sum#:	1.1	12.6	2,046.6	0.8	83.1 #	24 #	24 #	18 #
Minimum:	0.7	11.6	1,369.7	0.6	1.9	1	1	0
Maximum:	1.3	13.9	2,361.4	0.8	4.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:07 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit Unit CT1	> Limit Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/25/2022 00:00	1.2	12.6	2,144.7	0.9	4.1	1	1	1
02/25/2022 01:00	1.1	12.9	2,075.0	0.9	3.8	1	1	1
02/25/2022 02:00	1.1	12.9	2,079.4	0.8	3.8	1	1	1
02/25/2022 03:00	1.1	12.9	2,092.3	0.8	3.8	1	1	1
02/25/2022 04:00	1.2	12.7	2,140.5	0.8	4.1	1	1	1
02/25/2022 05:00	1.2	12.8	2,099.4	0.9	4.1	1	1	1
02/25/2022 06:00	1.2	12.0	2,288.7	0.9	4.1	1	1	1
02/25/2022 07:00	1.2	12.8	2,106.7	0.9	4.1	1	1	1
02/25/2022 08:00	1.1	13.1	1,995.7	0.8	3.7	1	1	1
02/25/2022 09:00	0.7	13.8	1,555.8	0.8	2.0	1	1	0
02/25/2022 10:00	0.6	13.9	1,543.5	0.6	1.7	1	1	0
02/25/2022 11:00	0.6	13.8	1,659.5	0.5	1.9	1	1	0
02/25/2022 12:00	0.6	13.8	1,632.3	0.5	1.8	1	1	0
02/25/2022 13:00	0.6	13.9	1,642.0	0.5	1.9	1	1	0
02/25/2022 14:00	0.6	13.9	1,625.8	0.5	1.8	1	1	0
02/25/2022 15:00	0.6	13.9	1,585.3	0.5	1.8	1	1	0
02/25/2022 16:00	0.6	13.8	1,683.4	0.5	1.9	1	1	1
02/25/2022 17:00	1.2	12.9	2,036.2	0.6	4.0	1	1	1
02/25/2022 18:00	1.0	13.0	1,991.9	0.7	3.3	1	1	1
02/25/2022 19:00	1.0	13.1	1,979.3	0.8	3.4	1	1	1
02/25/2022 20:00	1.1	13.0	2,021.8	0.8	3.7	1	1	1
02/25/2022 21:00	1.1	12.8	2,058.0	0.8	3.7	1	1	1
02/25/2022 22:00	1.2	12.7	2,102.3	0.8	4.1	1	1	1
02/25/2022 23:00	1.2	12.7	2,105.2	0.9	4.1	1	1	1
Average/Sum#:	1.0	13.2	1,926.9	0.7	76.7 #	24 #	24 #	17 #
Minimum:	0.6	12.0	1,543.5	0.5	1.7	1	1	0
Maximum:	1.2	13.9	2,288.7	0.9	4.1	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:07 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit	> Limit	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT1	Unit CT1	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	CO, _3Hr, Ppmvdc	CO, Lb	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/26/2022 00:00	1.2	12.7	2,136.2	0.9	4.1	1	1	1
02/26/2022 01:00	1.2	12.6	2,147.3	0.9	4.1	1	1	1
02/26/2022 02:00	1.1	13.1	2,008.5	0.9	3.7	1	1	1
02/26/2022 03:00	1.2	13.2	2,006.3	0.9	4.1	1	1	1
02/26/2022 04:00	1.1	12.8	2,089.7	0.8	3.7	1	1	1
02/26/2022 05:00	1.1	12.9	2,085.7	0.8	3.8	1	1	1
02/26/2022 06:00	1.1	12.9	2,068.3	0.8	3.8	1	1	1
02/26/2022 07:00	10.8	14.4	1,244.5	0.0	13.1	1	0	1
02/26/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/26/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/26/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/26/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/26/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/26/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/26/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/26/2022 15:00	30.3	18.0	303.4	0.0	15.9	1	0	0
02/26/2022 16:00	51.5	15.7	817.8	0.0	107.0	1	0	0
02/26/2022 17:00	0.7	13.8	1,526.7	0.0	2.0	1	0	1
02/26/2022 18:00	1.3	13.1	1,990.5	0.0	4.4	1	0	1
02/26/2022 19:00	1.2	13.1	2,000.5	0.8	4.1	1	0	1
02/26/2022 20:00	1.2	13.1	1,999.3	0.9	4.1	1	0	1
02/26/2022 21:00	1.4	12.6	2,124.5	0.9	4.7	1	0	1
02/26/2022 22:00	1.3	12.8	2,072.8	0.9	4.4	1	0	1
02/26/2022 23:00	13.1	14.1	1,314.2	0.0	16.0	1	0	1
Average/Sum#:	7.1	13.6	1,761.0	0.9	203.0 #	17 #	7 #	15 #
Minimum:	0.7	12.6	303.4	0.8	2.0	0	0	0
Maximum:	51.5	18.0	2,147.3	0.9	107.0	1	1	1
%SI	29.17	29.17	29.17	54.17	29.17	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:07 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit Unit CT1	> Limit Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/27/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:07 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit	> Limit	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT1	Unit CT1	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	CO, _3Hr, Ppmvdc	CO, Lb	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/28/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2022 13:00	61.5	17.6	332.4	0.0	63.8	1	0	0
02/28/2022 14:00	19.4	17.2	392.9	0.0	27.2	1	0	0
02/28/2022 15:00	33.1	15.6	830.2	0.0	68.5	1	0	0
02/28/2022 16:00	0.6	13.9	1,499.6	0.0	1.7	1	0	0
02/28/2022 17:00	1.1	13.1	1,979.3	0.0	3.7	1	0	1
02/28/2022 18:00	1.4	12.3	2,134.2	0.8	4.6	1	0	1
02/28/2022 19:00	1.2	12.8	2,016.0	0.9	3.9	1	0	1
02/28/2022 20:00	1.2	12.9	2,000.9	0.9	4.0	1	0	1
02/28/2022 21:00	1.2	13.0	1,966.4	0.9	3.9	1	0	1
02/28/2022 22:00	27.6	15.6	605.1	0.0	9.6	1	0	0
02/28/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	14.8	14.4	1,375.7	0.9	190.9 #	10 #	0 #	5 #
Minimum:	0.6	12.3	332.4	0.8	1.7	0	0	0
Maximum:	61.5	17.6	2,134.2	0.9	68.5	1	0	1
%SI	58.33	58.33	58.33	83.33	58.33	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:07 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit	> Limit	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT1	Unit CT1	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	CO, _3Hr, Ppmvdc	CO, Lb	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/01/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:07 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit Unit CT1	> Limit Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/02/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:07 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit	> Limit	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/03/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:07 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit	> Limit	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT1	Unit CT1	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	CO, _3Hr, Ppmvdc	CO, Lb	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/04/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/04/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/04/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/04/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/04/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/04/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/04/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/04/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/04/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/04/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/04/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/04/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/04/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/04/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/04/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/04/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/04/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/04/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/04/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/04/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/04/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/04/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/04/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/04/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:07 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit Unit CT1	> Limit Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/05/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/05/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/05/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/05/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/05/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/05/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/05/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/05/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/05/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/05/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/05/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/05/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/05/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/05/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/05/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/05/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/05/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/05/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/05/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/05/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/05/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/05/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/05/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/05/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:07 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit	> Limit	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/06/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/06/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/06/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/06/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/06/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/06/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/06/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/06/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/06/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/06/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/06/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/06/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/06/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/06/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/06/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/06/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/06/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/06/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/06/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/06/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/06/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/06/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/06/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/06/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:07 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit Unit CT1	> Limit Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/07/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:07 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit	> Limit	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/08/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:07 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit Unit CT1	> Limit Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/09/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/09/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/09/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/09/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/09/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/09/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/09/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/09/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/09/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/09/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/09/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/09/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/09/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/09/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/09/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/09/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/09/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/09/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/09/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/09/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/09/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/09/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/09/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/09/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:07 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit Unit CT1	> Limit Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/10/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/10/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/10/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/10/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/10/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/10/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/10/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/10/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/10/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/10/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/10/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/10/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/10/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/10/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/10/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/10/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/10/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/10/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/10/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/10/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/10/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/10/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/10/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/10/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:07 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit Unit CT1	> Limit Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/11/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/11/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/11/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/11/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/11/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/11/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/11/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/11/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/11/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/11/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/11/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/11/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/11/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/11/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/11/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/11/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/11/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/11/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/11/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/11/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/11/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/11/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/11/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/11/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:07 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit	> Limit	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT1	Unit CT1	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	CO, _3Hr, Ppmvdc	CO, Lb	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/12/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/12/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/12/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/12/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/12/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/12/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/12/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/12/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/12/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/12/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/12/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/12/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/12/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/12/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/12/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/12/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/12/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/12/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/12/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/12/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/12/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/12/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/12/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/12/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:07 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit	> Limit	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT1	Unit CT1	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	CO, _3Hr, Ppmvdc	CO, Lb	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/13/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/13/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/13/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/13/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/13/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/13/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/13/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/13/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/13/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/13/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/13/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/13/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/13/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/13/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/13/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/13/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/13/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/13/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/13/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/13/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/13/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/13/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/13/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/13/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:07 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit Unit CT1	> Limit Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/14/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/14/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/14/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/14/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/14/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/14/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/14/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/14/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/14/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/14/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/14/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/14/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/14/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/14/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/14/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/14/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/14/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/14/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/14/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/14/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/14/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/14/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/14/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/14/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:07 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit Unit CT1	> Limit Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/15/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/15/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/15/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/15/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/15/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/15/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/15/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/15/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/15/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/15/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/15/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/15/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/15/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/15/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/15/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/15/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/15/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/15/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/15/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/15/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/15/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/15/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/15/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/15/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:07 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit Unit CT1	> Limit Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/16/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/16/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/16/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/16/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/16/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/16/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/16/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/16/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/16/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/16/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/16/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/16/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/16/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/16/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/16/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/16/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/16/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/16/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/16/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/16/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/16/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/16/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/16/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/16/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:07 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit Unit CT1	> Limit Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/17/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/17/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/17/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/17/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/17/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/17/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/17/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/17/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/17/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/17/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/17/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/17/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/17/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/17/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/17/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/17/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/17/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/17/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/17/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/17/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/17/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/17/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/17/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/17/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:07 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit Unit CT1	> Limit Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/18/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/18/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/18/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/18/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/18/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/18/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/18/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/18/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/18/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/18/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/18/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/18/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/18/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/18/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/18/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/18/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/18/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/18/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/18/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/18/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/18/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/18/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/18/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/18/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:07 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit	> Limit	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT1	Unit CT1	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	CO, _3Hr, Ppmvdc	CO, Lb	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/19/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/19/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/19/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/19/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/19/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/19/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/19/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/19/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/19/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/19/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/19/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/19/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/19/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/19/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/19/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/19/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/19/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/19/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/19/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/19/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/19/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/19/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/19/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/19/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:07 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit Unit CT1	> Limit Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/20/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/20/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/20/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/20/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/20/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/20/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/20/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/20/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/20/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/20/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/20/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/20/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/20/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/20/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/20/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/20/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/20/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/20/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/20/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/20/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/20/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/20/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/20/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/20/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:07 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit Unit CT1	> Limit Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/21/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:07 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit Unit CT1	> Limit Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/22/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:07 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/23/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:07 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit	> Limit	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/24/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:07 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit Unit CT1	> Limit Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/25/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:07 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit Unit CT1	> Limit Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/26/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:07 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit Unit CT1	> Limit Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/27/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:07 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit Unit CT1	> Limit Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/28/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:07 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit Unit CT1	> Limit Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/29/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:07 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit	> Limit	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT1	Unit CT1	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	CO, _3Hr, Ppmvdc	CO, Lb	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/30/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:07 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	> Limit Unit CT1	> Limit Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/31/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:09 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit Unit CT2	> Limit Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/01/2022 00:00	0.6	13.3	1,909.9	0.4	2.0	1	1	1
01/01/2022 01:00	0.3	13.9	1,589.2	0.4	0.9	1	1	0
01/01/2022 02:00	0.4	13.9	1,542.9	0.4	1.2	1	1	0
01/01/2022 03:00	0.4	13.9	1,743.3	0.3	1.3	1	1	0
01/01/2022 04:00	0.5	13.6	1,842.3	0.3	1.7	1	1	1
01/01/2022 05:00	0.5	13.5	1,839.7	0.4	1.6	1	1	1
01/01/2022 06:00	0.4	13.8	1,792.0	0.4	1.3	1	1	1
01/01/2022 07:00	0.6	13.2	1,977.6	0.4	2.0	1	1	1
01/01/2022 08:00	0.4	13.6	1,666.2	0.4	1.2	1	1	1
01/01/2022 09:00	9.9	15.0	889.4	0.0	8.3	1	0	0
01/01/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/01/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/01/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/01/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/01/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/01/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/01/2022 16:00	14.2	18.4	273.7	0.0	6.2	1	0	0
01/01/2022 17:00	29.7	15.8	812.6	0.0	62.5	1	0	0
01/01/2022 18:00	0.3	13.9	1,765.4	0.0	1.0	1	1	0
01/01/2022 19:00	0.4	13.8	1,796.6	0.0	1.3	1	1	1
01/01/2022 20:00	0.7	12.8	2,066.2	0.4	2.4	1	1	1
01/01/2022 21:00	0.6	12.6	2,108.0	0.4	2.0	1	1	1
01/01/2022 22:00	0.6	12.7	2,090.2	0.4	2.0	1	1	1
01/01/2022 23:00	0.6	12.8	2,068.4	0.4	2.0	1	1	1
Average/Sum#:	3.4	13.9	1,654.1	0.4	100.9 #	18 #	15 #	11 #
Minimum:	0.3	12.6	273.7	0.3	0.9	0	0	0
Maximum:	29.7	18.4	2,108.0	0.4	62.5	1	1	1
%SI	25.00	25.00	25.00	45.83	25.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:09 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT2	Unit CT2	UnitOn, TF	NormalOp, TF	DBOn, TF
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/02/2022 00:00	0.8	13.2	1,934.3	0.5	2.7	1	1	1
01/02/2022 01:00	0.3	13.9	1,522.0	0.4	0.9	1	1	0
01/02/2022 02:00	0.4	13.9	1,396.8	0.4	1.1	1	1	0
01/02/2022 03:00	0.4	13.8	1,714.4	0.3	1.3	1	1	0
01/02/2022 04:00	0.7	13.5	1,832.8	0.4	2.3	1	1	1
01/02/2022 05:00	0.7	13.4	1,836.6	0.5	2.3	1	1	1
01/02/2022 06:00	0.4	13.8	1,771.7	0.5	1.3	1	1	1
01/02/2022 07:00	0.5	13.2	1,981.4	0.4	1.7	1	1	1
01/02/2022 08:00	0.4	13.6	1,668.3	0.3	1.2	1	1	1
01/02/2022 09:00	10.4	15.0	896.5	0.0	8.8	1	0	0
01/02/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/02/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/02/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/02/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/02/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/02/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/02/2022 16:00	16.0	18.4	240.6	0.0	6.1	1	0	0
01/02/2022 17:00	30.7	15.7	829.9	0.0	64.7	1	0	0
01/02/2022 18:00	0.4	13.7	1,769.2	0.0	1.3	1	1	1
01/02/2022 19:00	0.8	12.9	2,024.3	0.0	2.7	1	1	1
01/02/2022 20:00	0.6	12.4	2,138.0	0.4	2.0	1	1	1
01/02/2022 21:00	0.6	12.7	2,061.8	0.5	2.0	1	1	1
01/02/2022 22:00	0.6	12.7	2,056.6	0.4	2.0	1	1	1
01/02/2022 23:00	0.8	13.1	1,970.3	0.5	2.7	1	1	1
Average/Sum#:	3.6	13.8	1,647.0	0.4	107.1 #	18 #	15 #	12 #
Minimum:	0.3	12.4	240.6	0.3	0.9	0	0	0
Maximum:	30.7	18.4	2,138.0	0.5	64.7	1	1	1
%SI	25.00	25.00	25.00	45.83	25.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT2	Unit CT2	UnitOn, TF	NormalOp, TF	DBOn, TF
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/03/2022 00:00	0.9	13.3	1,908.5	0.6	3.0	1	1	1
01/03/2022 01:00	0.4	13.9	1,628.6	0.5	1.2	1	1	0
01/03/2022 02:00	0.4	13.8	1,648.2	0.4	1.2	1	1	1
01/03/2022 03:00	0.7	13.2	1,971.1	0.4	2.4	1	1	1
01/03/2022 04:00	0.7	13.2	1,965.4	0.4	2.4	1	1	1
01/03/2022 05:00	0.6	12.9	2,033.5	0.5	2.0	1	1	1
01/03/2022 06:00	0.5	12.3	2,173.3	0.4	1.7	1	1	1
01/03/2022 07:00	0.5	12.8	2,052.1	0.4	1.7	1	1	1
01/03/2022 08:00	0.6	13.1	1,971.7	0.4	2.0	1	1	1
01/03/2022 09:00	0.7	13.3	1,919.9	0.5	2.3	1	1	1
01/03/2022 10:00	0.4	13.8	1,680.4	0.4	1.3	1	1	1
01/03/2022 11:00	0.4	13.9	1,408.9	0.4	1.1	1	1	0
01/03/2022 12:00	0.4	13.8	1,723.4	0.3	1.3	1	1	0
01/03/2022 13:00	0.6	13.4	1,842.7	0.4	1.9	1	1	1
01/03/2022 14:00	0.6	13.3	1,847.4	0.4	1.9	1	1	1
01/03/2022 15:00	0.4	13.8	1,621.1	0.4	1.2	1	1	0
01/03/2022 16:00	0.7	13.3	1,870.0	0.4	2.3	1	1	1
01/03/2022 17:00	0.6	12.6	2,065.2	0.4	2.0	1	1	1
01/03/2022 18:00	0.6	12.4	2,092.8	0.4	2.0	1	1	1
01/03/2022 19:00	0.5	12.3	2,124.9	0.4	1.6	1	1	1
01/03/2022 20:00	0.6	12.6	2,035.6	0.4	1.9	1	1	1
01/03/2022 21:00	0.6	12.8	2,004.7	0.4	2.0	1	1	1
01/03/2022 22:00	0.8	13.1	1,934.6	0.5	2.6	1	1	1
01/03/2022 23:00	0.6	12.8	1,996.3	0.5	2.0	1	1	1
Average/Sum#:	0.6	13.2	1,896.7	0.4	45.0 #	24 #	24 #	20 #
Minimum:	0.4	12.3	1,408.9	0.3	1.1	1	1	0
Maximum:	0.9	13.9	2,173.3	0.6	3.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/04/2022 00:00	0.6	12.8	1,978.6	0.5	1.9	1	1	1
01/04/2022 01:00	0.3	13.9	1,541.5	0.4	0.9	1	1	0
01/04/2022 02:00	0.4	13.8	1,650.0	0.3	1.2	1	1	1
01/04/2022 03:00	0.6	13.2	1,893.1	0.4	1.9	1	1	1
01/04/2022 04:00	0.6	13.2	1,913.3	0.4	2.0	1	1	1
01/04/2022 05:00	0.3	13.9	1,637.6	0.4	0.9	1	1	0
01/04/2022 06:00	0.4	13.8	1,750.2	0.4	1.3	1	1	0
01/04/2022 07:00	0.7	13.1	1,951.4	0.4	2.3	1	1	1
01/04/2022 08:00	0.6	12.9	1,980.4	0.4	2.0	1	1	1
01/04/2022 09:00	0.8	13.2	1,911.3	0.5	2.6	1	1	1
01/04/2022 10:00	0.4	13.8	1,425.8	0.4	1.1	1	1	1
01/04/2022 11:00	0.4	13.9	1,321.2	0.4	1.0	1	1	0
01/04/2022 12:00	0.4	13.8	1,693.1	0.3	1.3	1	1	0
01/04/2022 13:00	0.6	13.6	1,796.6	0.4	2.0	1	1	1
01/04/2022 14:00	0.8	13.4	1,792.3	0.5	2.5	1	1	1
01/04/2022 15:00	0.3	13.8	1,560.4	0.4	0.9	1	1	0
01/04/2022 16:00	0.8	13.0	1,971.7	0.5	2.6	1	1	1
01/04/2022 17:00	0.6	12.4	2,092.2	0.4	2.0	1	1	1
01/04/2022 18:00	0.6	12.3	2,109.5	0.5	1.9	1	1	1
01/04/2022 19:00	0.6	12.4	2,097.2	0.4	2.0	1	1	1
01/04/2022 20:00	0.6	12.7	2,042.7	0.4	2.0	1	1	1
01/04/2022 21:00	0.6	12.8	2,013.5	0.4	2.0	1	1	1
01/04/2022 22:00	0.7	12.9	1,979.5	0.4	2.3	1	1	1
01/04/2022 23:00	0.6	12.9	1,996.3	0.4	2.0	1	1	1
Average/Sum#:	0.6	13.2	1,837.5	0.4	42.6 #	24 #	24 #	18 #
Minimum:	0.3	12.3	1,321.2	0.3	0.9	1	1	0
Maximum:	0.8	13.9	2,109.5	0.5	2.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:09 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT2	Unit CT2	UnitOn, TF	NormalOp, TF	DBOn, TF
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/05/2022 00:00	0.7	13.4	1,794.1	0.5	2.2	1	1	1
01/05/2022 01:00	0.4	13.9	1,289.5	0.4	1.0	1	1	0
01/05/2022 02:00	0.4	13.9	1,319.7	0.4	1.0	1	1	0
01/05/2022 03:00	0.4	13.8	1,724.1	0.3	1.3	1	1	0
01/05/2022 04:00	0.8	13.5	1,832.7	0.4	2.6	1	1	1
01/05/2022 05:00	0.9	13.2	1,864.2	0.5	2.9	1	1	1
01/05/2022 06:00	0.4	13.8	1,651.5	0.5	1.2	1	1	1
01/05/2022 07:00	0.8	13.0	1,984.2	0.5	2.7	1	1	1
01/05/2022 08:00	0.8	13.1	1,975.2	0.5	2.7	1	1	1
01/05/2022 09:00	0.7	13.0	1,957.0	0.6	2.3	1	1	1
01/05/2022 10:00	0.3	13.9	1,455.8	0.5	0.8	1	1	0
01/05/2022 11:00	0.3	13.9	1,506.0	0.4	0.9	1	1	0
01/05/2022 12:00	0.3	13.8	1,702.2	0.3	0.9	1	1	0
01/05/2022 13:00	0.5	13.5	1,819.7	0.3	1.6	1	1	1
01/05/2022 14:00	0.5	13.4	1,822.9	0.3	1.6	1	1	1
01/05/2022 15:00	0.3	13.9	1,630.7	0.4	0.9	1	1	1
01/05/2022 16:00	0.6	13.0	1,984.0	0.4	2.0	1	1	1
01/05/2022 17:00	0.5	12.8	2,031.0	0.4	1.7	1	1	1
01/05/2022 18:00	0.5	12.6	2,080.5	0.4	1.7	1	1	1
01/05/2022 19:00	0.5	12.6	2,077.9	0.4	1.7	1	1	1
01/05/2022 20:00	0.4	12.6	2,075.8	0.4	1.3	1	1	1
01/05/2022 21:00	0.4	12.6	2,066.5	0.3	1.3	1	1	1
01/05/2022 22:00	0.6	13.2	1,927.2	0.4	2.0	1	1	1
01/05/2022 23:00	0.5	12.9	1,997.6	0.4	1.6	1	1	1
Average/Sum#:	0.5	13.3	1,815.4	0.4	39.9 #	24 #	24 #	18 #
Minimum:	0.3	12.6	1,289.5	0.3	0.8	1	1	0
Maximum:	0.9	13.9	2,080.5	0.6	2.9	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:09 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit Unit CT2	> Limit Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/06/2022 00:00	0.5	13.4	1,802.4	0.4	1.6	1	1	1
01/06/2022 01:00	0.3	13.9	1,306.9	0.4	0.7	1	1	0
01/06/2022 02:00	0.4	13.9	1,288.7	0.3	1.0	1	1	0
01/06/2022 03:00	0.4	13.8	1,527.6	0.3	1.1	1	1	0
01/06/2022 04:00	0.7	13.5	1,834.6	0.4	2.3	1	1	1
01/06/2022 05:00	0.8	13.3	1,829.1	0.5	2.5	1	1	1
01/06/2022 06:00	0.4	13.8	1,728.3	0.5	1.3	1	1	1
01/06/2022 07:00	0.7	13.1	1,975.1	0.5	2.3	1	1	1
01/06/2022 08:00	0.6	13.0	2,001.3	0.4	2.0	1	1	1
01/06/2022 09:00	0.6	13.2	1,917.8	0.5	2.0	1	1	1
01/06/2022 10:00	0.4	13.9	1,494.9	0.4	1.1	1	1	0
01/06/2022 11:00	0.4	13.9	1,559.2	0.4	1.2	1	1	0
01/06/2022 12:00	0.4	13.9	1,425.8	0.3	1.1	1	1	0
01/06/2022 13:00	0.4	13.9	1,312.0	0.3	1.0	1	1	0
01/06/2022 14:00	0.4	13.8	1,588.2	0.3	1.2	1	1	0
01/06/2022 15:00	0.4	13.9	1,417.2	0.3	1.1	1	1	0
01/06/2022 16:00	0.4	13.8	1,592.9	0.3	1.2	1	1	0
01/06/2022 17:00	0.4	13.8	1,708.7	0.3	1.3	1	1	1
01/06/2022 18:00	0.8	12.8	1,990.9	0.4	2.6	1	1	1
01/06/2022 19:00	0.6	12.6	2,038.6	0.4	1.9	1	1	1
01/06/2022 20:00	0.7	13.0	1,927.6	0.5	2.3	1	1	1
01/06/2022 21:00	0.4	13.8	1,642.4	0.4	1.2	1	1	0
01/06/2022 22:00	0.4	13.8	1,740.8	0.4	1.3	1	1	1
01/06/2022 23:00	0.7	13.0	1,959.5	0.4	2.3	1	1	1
Average/Sum#:	0.5	13.5	1,692.1	0.4	37.6 #	24 #	24 #	13 #
Minimum:	0.3	12.6	1,288.7	0.3	0.7	1	1	0
Maximum:	0.8	13.9	2,038.6	0.5	2.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:09 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit Unit CT2	> Limit Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/07/2022 00:00	0.7	13.4	1,799.2	0.5	2.2	1	1	1
01/07/2022 01:00	0.4	13.9	1,278.9	0.5	1.0	1	1	0
01/07/2022 02:00	0.4	13.8	1,598.4	0.4	1.2	1	1	1
01/07/2022 03:00	0.9	13.2	1,918.0	0.4	3.0	1	1	1
01/07/2022 04:00	0.9	13.1	1,896.8	0.6	2.9	1	1	1
01/07/2022 05:00	0.4	13.8	1,660.6	0.6	1.2	1	1	0
01/07/2022 06:00	0.4	13.8	1,568.4	0.4	1.2	1	1	1
01/07/2022 07:00	0.8	13.0	1,954.9	0.4	2.6	1	1	1
01/07/2022 08:00	0.9	13.1	1,919.2	0.5	2.9	1	1	1
01/07/2022 09:00	0.3	13.9	1,558.9	0.5	0.9	1	1	0
01/07/2022 10:00	0.4	13.9	1,518.0	0.4	1.1	1	1	0
01/07/2022 11:00	0.3	13.9	1,535.4	0.3	0.9	1	1	0
01/07/2022 12:00	0.3	13.9	1,525.6	0.3	0.9	1	1	0
01/07/2022 13:00	0.4	13.9	1,495.3	0.3	1.1	1	1	0
01/07/2022 14:00	0.3	13.9	1,467.8	0.3	0.8	1	1	0
01/07/2022 15:00	0.4	13.9	1,512.7	0.3	1.1	1	1	0
01/07/2022 16:00	0.4	13.9	1,515.8	0.3	1.1	1	1	0
01/07/2022 17:00	0.4	13.9	1,601.0	0.3	1.2	1	1	0
01/07/2022 18:00	0.8	13.4	1,824.9	0.4	2.6	1	1	1
01/07/2022 19:00	0.8	13.4	1,803.4	0.5	2.5	1	1	1
01/07/2022 20:00	0.4	13.8	1,553.0	0.5	1.2	1	1	1
01/07/2022 21:00	1.0	13.1	1,942.1	0.6	3.3	1	1	1
01/07/2022 22:00	8.4	14.5	1,190.3	0.0	10.3	1	0	1
01/07/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.9	13.7	1,636.5	0.4	47.2 #	23 #	22 #	12 #
Minimum:	0.3	13.0	1,190.3	0.3	0.8	0	0	0
Maximum:	8.4	14.5	1,954.9	0.6	10.3	1	1	1
%SI	4.17	4.17	4.17	8.33	4.17	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:09 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT2	Unit CT2	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	CO, _3Hr, Ppmvdc	CO, Lb	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/08/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2022 15:00	45.5	17.6	356.7	0.0	58.5	1	0	0
01/08/2022 16:00	22.0	14.9	1,098.8	0.0	53.2	1	0	0
01/08/2022 17:00	0.3	13.9	1,600.9	0.0	0.9	1	1	0
01/08/2022 18:00	0.4	13.8	1,760.8	0.0	1.3	1	1	1
01/08/2022 19:00	0.8	13.0	1,995.8	0.4	2.7	1	1	1
01/08/2022 20:00	0.6	12.8	2,000.7	0.4	2.0	1	1	1
01/08/2022 21:00	0.3	13.9	1,689.8	0.4	1.0	1	1	0
01/08/2022 22:00	0.3	13.8	1,765.5	0.3	1.0	1	1	1
01/08/2022 23:00	0.7	13.0	1,980.7	0.3	2.3	1	1	1
Average/Sum#:	7.9	14.1	1,583.3	0.4	122.9 #	9 #	7 #	5 #
Minimum:	0.3	12.8	356.7	0.3	0.9	0	0	0
Maximum:	45.5	17.6	2,000.7	0.4	58.5	1	1	1
%SI	62.50	62.50	62.50	79.17	62.50	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:09 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit Unit CT2	> Limit Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/09/2022 00:00	0.7	13.2	1,923.2	0.4	2.3	1	1	1
01/09/2022 01:00	0.3	13.9	1,506.4	0.4	0.9	1	1	0
01/09/2022 02:00	0.4	13.8	1,565.9	0.4	1.2	1	1	1
01/09/2022 03:00	0.9	13.3	1,921.4	0.4	3.0	1	1	1
01/09/2022 04:00	0.9	13.3	1,912.5	0.6	3.0	1	1	1
01/09/2022 05:00	0.3	13.9	1,631.5	0.6	0.9	1	1	0
01/09/2022 06:00	0.4	13.8	1,645.5	0.4	1.2	1	1	1
01/09/2022 07:00	0.9	13.1	1,998.0	0.4	3.0	1	1	1
01/09/2022 08:00	0.9	13.2	1,938.3	0.6	3.0	1	1	1
01/09/2022 09:00	0.3	13.9	1,559.8	0.6	0.9	1	1	0
01/09/2022 10:00	0.3	13.9	1,502.4	0.4	0.9	1	1	0
01/09/2022 11:00	0.3	13.9	1,583.6	0.3	0.9	1	1	0
01/09/2022 12:00	0.3	13.9	1,443.6	0.3	0.8	1	1	0
01/09/2022 13:00	0.3	13.9	1,493.7	0.3	0.8	1	1	0
01/09/2022 14:00	0.3	13.9	1,621.8	0.3	0.9	1	1	0
01/09/2022 15:00	0.3	13.9	1,647.8	0.3	0.9	1	1	0
01/09/2022 16:00	0.4	13.9	1,606.7	0.3	1.2	1	1	1
01/09/2022 17:00	0.8	13.1	1,951.9	0.4	2.6	1	1	1
01/09/2022 18:00	0.6	12.8	2,020.7	0.4	2.0	1	1	1
01/09/2022 19:00	0.8	13.2	1,926.2	0.5	2.6	1	1	1
01/09/2022 20:00	0.7	13.0	1,974.9	0.5	2.3	1	1	1
01/09/2022 21:00	0.7	13.1	1,956.5	0.5	2.3	1	1	1
01/09/2022 22:00	0.6	12.9	2,013.0	0.5	2.0	1	1	1
01/09/2022 23:00	1.0	13.3	1,919.6	0.6	3.3	1	1	1
Average/Sum#:	0.6	13.5	1,761.0	0.4	42.9 #	24 #	24 #	15 #
Minimum:	0.3	12.8	1,443.6	0.3	0.8	1	1	0
Maximum:	1.0	13.9	2,020.7	0.6	3.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:09 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/10/2022 00:00	0.8	13.4	1,829.0	0.6	2.6	1	1	1
01/10/2022 01:00	4.5	14.4	1,165.6	0.0	9.8	1	0	0
01/10/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/10/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/10/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/10/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/10/2022 06:00	31.6	17.0	441.8	0.0	34.1	1	0	0
01/10/2022 07:00	22.6	14.6	1,237.4	0.0	58.6	1	0	0
01/10/2022 08:00	0.3	13.9	1,639.2	0.0	0.9	1	1	0
01/10/2022 09:00	0.3	13.9	1,570.4	0.0	0.9	1	1	0
01/10/2022 10:00	0.3	13.9	1,618.8	0.3	0.9	1	1	1
01/10/2022 11:00	0.9	13.1	1,949.8	0.4	3.0	1	1	1
01/10/2022 12:00	0.9	13.2	1,901.3	0.6	2.9	1	1	1
01/10/2022 13:00	0.3	13.9	1,531.1	0.6	0.9	1	1	0
01/10/2022 14:00	0.3	13.9	1,632.3	0.4	0.9	1	1	0
01/10/2022 15:00	0.7	13.0	1,956.2	0.4	2.3	1	1	1
01/10/2022 16:00	0.6	12.7	2,027.1	0.4	2.0	1	1	1
01/10/2022 17:00	0.5	12.6	2,067.0	0.4	1.6	1	1	1
01/10/2022 18:00	0.5	12.5	2,090.3	0.4	1.6	1	1	1
01/10/2022 19:00	0.5	12.5	2,084.1	0.4	1.6	1	1	1
01/10/2022 20:00	0.5	12.5	2,087.9	0.4	1.6	1	1	1
01/10/2022 21:00	0.5	12.6	2,074.0	0.4	1.7	1	1	1
01/10/2022 22:00	0.6	12.9	1,976.4	0.4	2.0	1	1	1
01/10/2022 23:00	0.7	13.1	1,958.4	0.4	2.3	1	1	1
Average/Sum#:	3.4	13.5	1,741.9	0.4	132.2 #	20 #	17 #	13 #
Minimum:	0.3	12.5	441.8	0.3	0.9	0	0	0
Maximum:	31.6	17.0	2,090.3	0.6	58.6	1	1	1
%SI	16.67	16.67	16.67	37.50	16.67	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:09 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit Unit CT2	> Limit Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/11/2022 00:00	0.8	13.4	1,810.0	0.5	2.5	1	1	1
01/11/2022 01:00	0.3	14.0	1,288.8	0.5	0.7	1	1	0
01/11/2022 02:00	0.4	13.9	1,559.9	0.4	1.2	1	1	1
01/11/2022 03:00	0.6	13.3	1,922.6	0.4	2.0	1	1	1
01/11/2022 04:00	0.6	13.3	1,910.4	0.4	2.0	1	1	1
01/11/2022 05:00	0.3	13.9	1,594.2	0.4	0.9	1	1	0
01/11/2022 06:00	0.4	13.9	1,574.4	0.4	1.2	1	1	1
01/11/2022 07:00	0.8	13.2	1,958.2	0.4	2.7	1	1	1
01/11/2022 08:00	0.7	13.4	1,807.6	0.5	2.2	1	1	1
01/11/2022 09:00	0.3	13.9	1,300.9	0.5	0.7	1	1	0
01/11/2022 10:00	0.3	14.0	1,294.5	0.4	0.7	1	1	0
01/11/2022 11:00	0.3	14.0	1,357.4	0.3	0.8	1	1	0
01/11/2022 12:00	0.3	14.0	1,341.2	0.3	0.8	1	1	0
01/11/2022 13:00	0.3	14.0	1,337.0	0.3	0.8	1	1	0
01/11/2022 14:00	0.3	14.0	1,293.2	0.3	0.7	1	1	0
01/11/2022 15:00	0.3	14.0	1,361.7	0.3	0.8	1	1	0
01/11/2022 16:00	0.3	13.9	1,605.9	0.3	0.9	1	1	0
01/11/2022 17:00	0.4	13.8	1,648.8	0.3	1.2	1	1	1
01/11/2022 18:00	1.0	13.1	1,947.0	0.5	3.3	1	1	1
01/11/2022 19:00	0.9	13.2	1,932.6	0.6	3.0	1	1	1
01/11/2022 20:00	0.9	13.3	1,915.0	0.7	3.0	1	1	1
01/11/2022 21:00	0.9	13.2	1,929.1	0.7	3.0	1	1	1
01/11/2022 22:00	0.8	13.0	1,977.4	0.7	2.6	1	1	1
01/11/2022 23:00	0.6	13.5	1,654.0	0.6	1.8	1	1	1
Average/Sum#:	0.5	13.6	1,638.4	0.4	39.5 #	24 #	24 #	14 #
Minimum:	0.3	13.0	1,288.8	0.3	0.7	1	1	0
Maximum:	1.0	14.0	1,977.4	0.7	3.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:09 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT2	Unit CT2	UnitOn, TF	NormalOp, TF	DBOn, TF
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/12/2022 00:00	10.3	14.9	904.8	0.0	8.2	1	0	0
01/12/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2022 09:00	18.9	18.1	310.1	0.0	9.1	1	0	0
01/12/2022 10:00	36.8	15.9	755.2	0.0	73.4	1	0	0
01/12/2022 11:00	0.3	13.9	1,378.4	0.0	0.8	1	1	0
01/12/2022 12:00	0.3	13.9	1,517.0	0.0	0.9	1	1	0
01/12/2022 13:00	0.3	13.9	1,569.1	0.3	0.9	1	1	0
01/12/2022 14:00	0.3	13.9	1,548.1	0.3	0.9	1	1	0
01/12/2022 15:00	0.4	13.9	1,616.2	0.3	1.2	1	1	1
01/12/2022 16:00	0.7	13.0	1,976.7	0.4	2.3	1	1	1
01/12/2022 17:00	0.6	12.6	2,041.8	0.4	1.9	1	1	1
01/12/2022 18:00	0.6	12.8	2,017.2	0.4	2.0	1	1	1
01/12/2022 19:00	0.6	12.8	1,998.2	0.4	2.0	1	1	1
01/12/2022 20:00	0.7	13.1	1,925.8	0.4	2.3	1	1	1
01/12/2022 21:00	0.3	13.9	1,651.5	0.4	0.9	1	1	0
01/12/2022 22:00	0.4	13.8	1,767.8	0.4	1.3	1	1	1
01/12/2022 23:00	0.9	13.2	1,942.1	0.4	3.0	1	1	1
Average/Sum#:	4.5	14.0	1,557.5	0.4	111.1 #	16 #	13 #	8 #
Minimum:	0.3	12.6	310.1	0.3	0.8	0	0	0
Maximum:	36.8	18.1	2,041.8	0.4	73.4	1	1	1
%SI	33.33	33.33	33.33	54.17	33.33	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:09 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT2	Unit CT2	UnitOn, TF	NormalOp, TF	DBOn, TF
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/13/2022 00:00	0.7	13.4	1,804.4	0.5	2.2	1	1	1
01/13/2022 01:00	0.4	13.9	1,289.7	0.5	1.0	1	1	0
01/13/2022 02:00	0.4	13.8	1,565.0	0.4	1.2	1	1	1
01/13/2022 03:00	1.0	13.3	1,933.3	0.5	3.4	1	1	1
01/13/2022 04:00	1.0	13.3	1,916.5	0.6	3.3	1	1	1
01/13/2022 05:00	0.4	13.9	1,664.6	0.6	1.3	1	1	0
01/13/2022 06:00	0.4	13.8	1,600.3	0.5	1.2	1	1	1
01/13/2022 07:00	0.6	13.0	1,987.4	0.3	2.0	1	1	1
01/13/2022 08:00	0.6	13.3	1,906.7	0.4	2.0	1	1	1
01/13/2022 09:00	0.4	13.9	1,630.0	0.4	1.2	1	1	0
01/13/2022 10:00	0.4	13.9	1,378.8	0.4	1.0	1	1	0
01/13/2022 11:00	0.3	13.9	1,611.2	0.3	0.9	1	1	0
01/13/2022 12:00	0.7	13.5	1,836.1	0.4	2.3	1	1	1
01/13/2022 13:00	0.6	12.9	1,964.6	0.4	1.9	1	1	1
01/13/2022 14:00	0.3	13.9	1,535.2	0.4	0.9	1	1	0
01/13/2022 15:00	0.3	13.9	1,549.3	0.3	0.9	1	1	1
01/13/2022 16:00	0.7	13.0	1,968.7	0.4	2.3	1	1	1
01/13/2022 17:00	0.6	12.8	1,999.9	0.4	2.0	1	1	1
01/13/2022 18:00	0.6	12.7	2,029.3	0.4	2.0	1	1	1
01/13/2022 19:00	0.8	13.1	1,929.5	0.5	2.6	1	1	1
01/13/2022 20:00	0.3	13.9	1,577.5	0.4	0.9	1	1	0
01/13/2022 21:00	0.4	13.9	1,617.7	0.4	1.2	1	1	1
01/13/2022 22:00	0.8	13.0	1,950.6	0.4	2.6	1	1	1
01/13/2022 23:00	7.9	14.5	1,185.2	0.0	9.3	1	0	1
Average/Sum#:	0.9	13.5	1,726.3	0.4	49.6 #	24 #	23 #	17 #
Minimum:	0.3	12.7	1,185.2	0.3	0.9	1	0	0
Maximum:	7.9	14.5	2,029.3	0.6	9.3	1	1	1
%SI	0.00	0.00	0.00	4.17	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:09 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit Unit CT2	> Limit Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/14/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/14/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/14/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/14/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/14/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/14/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/14/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/14/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/14/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/14/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/14/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/14/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/14/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/14/2022 13:00	23.1	17.7	335.2	0.0	22.4	1	0	0
01/14/2022 14:00	20.6	15.3	971.1	0.0	47.2	1	0	0
01/14/2022 15:00	0.3	13.9	1,506.0	0.0	0.9	1	1	0
01/14/2022 16:00	0.3	14.0	1,407.7	0.0	0.8	1	1	0
01/14/2022 17:00	0.3	13.9	1,568.6	0.3	0.9	1	1	0
01/14/2022 18:00	0.3	13.9	1,596.1	0.3	0.9	1	1	0
01/14/2022 19:00	0.5	13.4	1,827.7	0.3	1.6	1	1	1
01/14/2022 20:00	0.5	13.3	1,849.1	0.4	1.6	1	1	1
01/14/2022 21:00	0.4	13.8	1,693.2	0.4	1.3	1	1	1
01/14/2022 22:00	0.7	13.0	1,986.6	0.4	2.3	1	1	1
01/14/2022 23:00	8.4	14.4	1,207.3	0.0	9.9	1	0	1
Average/Sum#:	5.0	14.2	1,449.9	0.4	89.8 #	11 #	8 #	5 #
Minimum:	0.3	13.0	335.2	0.3	0.8	0	0	0
Maximum:	23.1	17.7	1,986.6	0.4	47.2	1	1	1
%SI	54.17	54.17	54.17	75.00	54.17	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:09 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit Unit CT2	> Limit Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/15/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/15/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/15/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/15/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/15/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/15/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/15/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/15/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/15/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/15/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/15/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/15/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/15/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/15/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/15/2022 14:00	20.6	17.6	351.2	0.0	26.1	1	0	0
01/15/2022 15:00	21.7	15.1	1,058.7	0.0	52.3	1	0	0
01/15/2022 16:00	0.3	13.9	1,567.4	0.0	0.9	1	1	0
01/15/2022 17:00	0.3	13.8	1,653.4	0.0	0.9	1	1	0
01/15/2022 18:00	0.6	13.5	1,838.8	0.3	2.0	1	1	1
01/15/2022 19:00	0.9	13.1	1,930.0	0.5	2.9	1	1	1
01/15/2022 20:00	0.4	13.8	1,671.2	0.5	1.2	1	1	1
01/15/2022 21:00	0.4	13.8	1,750.1	0.4	1.3	1	1	1
01/15/2022 22:00	1.0	13.1	1,950.9	0.5	3.3	1	1	1
01/15/2022 23:00	5.8	14.1	1,441.0	0.0	11.8	1	0	1
Average/Sum#:	5.2	14.2	1,521.3	0.4	102.7 #	10 #	7 #	6 #
Minimum:	0.3	13.1	351.2	0.3	0.9	0	0	0
Maximum:	21.7	17.6	1,950.9	0.5	52.3	1	1	1
%SI	58.33	58.33	58.33	79.17	58.33	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:09 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT2	Unit CT2	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	CO, _3Hr, Ppmvdc	CO, Lb	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/16/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/16/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/16/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/16/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/16/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/16/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/16/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/16/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/16/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/16/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/16/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/16/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/16/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/16/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/16/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/16/2022 15:00	44.7	18.0	289.9	0.0	24.8	1	0	0
01/16/2022 16:00	32.0	16.4	611.9	0.0	57.5	1	0	0
01/16/2022 17:00	0.3	13.9	1,440.9	0.0	0.8	1	0	0
01/16/2022 18:00	0.4	13.8	1,687.8	0.0	1.3	1	1	0
01/16/2022 19:00	0.8	13.3	1,876.4	0.0	2.6	1	1	1
01/16/2022 20:00	0.7	13.0	1,970.4	0.5	2.3	1	1	1
01/16/2022 21:00	0.3	13.9	1,676.1	0.5	0.9	1	1	0
01/16/2022 22:00	0.3	14.0	1,383.3	0.4	0.8	1	1	0
01/16/2022 23:00	0.3	13.9	1,596.5	0.3	0.9	1	1	0
Average/Sum#:	8.9	14.5	1,392.6	0.4	91.9 #	9 #	6 #	2 #
Minimum:	0.3	13.0	289.9	0.3	0.8	0	0	0
Maximum:	44.7	18.0	1,970.4	0.5	57.5	1	1	1
%SI	62.50	62.50	62.50	83.33	62.50	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:09 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/17/2022 00:00	0.7	13.5	1,798.6	0.4	2.2	1	1	1
01/17/2022 01:00	0.8	13.4	1,826.8	0.5	2.6	1	1	1
01/17/2022 02:00	0.4	13.9	1,396.3	0.5	1.1	1	1	0
01/17/2022 03:00	0.4	13.8	1,722.3	0.4	1.3	1	1	0
01/17/2022 04:00	0.6	13.5	1,820.8	0.4	1.9	1	1	1
01/17/2022 05:00	0.7	13.4	1,795.2	0.5	2.2	1	1	1
01/17/2022 06:00	0.4	13.8	1,672.6	0.5	1.2	1	1	1
01/17/2022 07:00	0.7	12.9	1,984.6	0.5	2.3	1	1	1
01/17/2022 08:00	0.6	12.9	2,003.7	0.4	2.0	1	1	1
01/17/2022 09:00	0.8	13.1	1,935.0	0.5	2.6	1	1	1
01/17/2022 10:00	0.3	13.9	1,561.7	0.4	0.9	1	1	0
01/17/2022 11:00	0.3	13.9	1,563.0	0.4	0.9	1	1	0
01/17/2022 12:00	0.4	13.8	1,633.9	0.3	1.2	1	1	1
01/17/2022 13:00	0.9	13.1	1,920.4	0.4	2.9	1	1	1
01/17/2022 14:00	0.8	13.1	1,893.2	0.5	2.6	1	1	1
01/17/2022 15:00	0.3	13.9	1,588.4	0.5	0.9	1	1	0
01/17/2022 16:00	0.3	13.9	1,574.5	0.4	0.9	1	1	1
01/17/2022 17:00	0.8	13.1	1,946.0	0.4	2.6	1	1	1
01/17/2022 18:00	0.6	12.9	1,965.1	0.4	1.9	1	1	1
01/17/2022 19:00	0.6	12.8	2,000.1	0.5	2.0	1	1	1
01/17/2022 20:00	0.7	13.1	1,908.0	0.4	2.3	1	1	1
01/17/2022 21:00	0.3	13.9	1,627.2	0.4	0.9	1	1	0
01/17/2022 22:00	0.3	14.0	1,395.3	0.4	0.8	1	1	0
01/17/2022 23:00	0.4	13.9	1,599.9	0.3	1.2	1	1	0
Average/Sum#:	0.5	13.5	1,755.5	0.4	41.4 #	24 #	24 #	16 #
Minimum:	0.3	12.8	1,395.3	0.3	0.8	1	1	0
Maximum:	0.9	14.0	2,003.7	0.5	2.9	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:09 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit Unit CT2	> Limit Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/18/2022 00:00	0.4	13.8	1,751.0	0.3	1.3	1	1	1
01/18/2022 01:00	0.8	13.3	1,820.2	0.4	2.5	1	1	1
01/18/2022 02:00	0.4	13.9	1,602.3	0.4	1.2	1	1	0
01/18/2022 03:00	0.6	13.3	1,913.4	0.5	2.0	1	1	1
01/18/2022 04:00	0.6	13.3	1,919.1	0.4	2.0	1	1	1
01/18/2022 05:00	0.4	13.8	1,550.3	0.4	1.2	1	1	1
01/18/2022 06:00	0.4	13.8	1,574.5	0.4	1.2	1	1	1
01/18/2022 07:00	0.6	13.3	1,937.6	0.4	2.0	1	1	1
01/18/2022 08:00	0.5	13.1	1,978.0	0.4	1.7	1	1	1
01/18/2022 09:00	0.6	13.3	1,912.7	0.5	2.0	1	1	1
01/18/2022 10:00	0.3	13.9	1,424.7	0.4	0.8	1	1	0
01/18/2022 11:00	0.0	0.0	1,388.0	0.0	0.0	1	1	0
01/18/2022 12:00	0.0	0.0	1,288.8	0.0	0.0	1	1	0
01/18/2022 13:00	0.0	0.0	1,297.7	0.0	0.0	1	1	0
01/18/2022 14:00	0.3	14.0	1,338.1	0.0	0.8	1	1	0
01/18/2022 15:00	0.3	13.9	1,510.9	0.0	0.9	1	1	0
01/18/2022 16:00	0.4	13.9	1,610.3	0.3	1.2	1	1	1
01/18/2022 17:00	0.7	12.9	1,984.1	0.4	2.3	1	1	1
01/18/2022 18:00	0.6	12.8	1,990.1	0.4	1.9	1	1	1
01/18/2022 19:00	0.6	12.7	2,017.1	0.4	1.9	1	1	1
01/18/2022 20:00	0.7	13.2	1,913.8	0.4	2.3	1	1	1
01/18/2022 21:00	0.3	13.8	1,571.8	0.4	0.9	1	1	1
01/18/2022 22:00	0.4	13.9	1,574.3	0.3	1.2	1	1	1
01/18/2022 23:00	0.9	13.1	1,948.2	0.4	3.0	1	1	1
Average/Sum#:	0.5	13.5	1,700.7	0.4	34.3 #	24 #	24 #	17 #
Minimum:	0.3	12.7	1,288.8	0.3	0.8	1	1	0
Maximum:	0.9	14.0	2,017.1	0.5	3.0	1	1	1
%SI	12.50	12.50	0.00	20.83	12.50	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:09 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit Unit CT2	> Limit Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/19/2022 00:00	0.7	13.4	1,808.1	0.5	2.2	1	1	1
01/19/2022 01:00	0.3	14.0	1,286.5	0.5	0.7	1	1	0
01/19/2022 02:00	0.4	13.9	1,566.8	0.4	1.2	1	1	1
01/19/2022 03:00	0.9	13.3	1,932.6	0.4	3.0	1	1	1
01/19/2022 04:00	0.8	13.3	1,905.0	0.5	2.6	1	1	1
01/19/2022 05:00	0.4	13.9	1,556.8	0.5	1.2	1	1	0
01/19/2022 06:00	0.5	13.8	1,576.0	0.4	1.5	1	1	1
01/19/2022 07:00	0.9	13.2	1,940.1	0.5	3.0	1	1	1
01/19/2022 08:00	0.0	0.0	1,918.7	0.0	0.0	1	1	1
01/19/2022 09:00	0.5	13.9	1,488.7	0.0	1.4	1	1	0
01/19/2022 10:00	0.0	0.0	1,339.8	0.0	0.0	1	1	0
01/19/2022 11:00	0.3	14.0	1,403.5	0.0	0.8	1	1	0
01/19/2022 12:00	0.5	14.0	1,307.0	0.0	1.3	1	1	0
01/19/2022 13:00	0.4	14.0	1,359.5	0.3	1.0	1	1	0
01/19/2022 14:00	0.3	14.0	1,335.7	0.3	0.8	1	1	0
01/19/2022 15:00	0.0	0.0	1,552.9	0.0	0.0	1	1	1
01/19/2022 16:00	0.5	12.8	2,008.1	0.0	1.6	1	1	1
01/19/2022 17:00	0.4	12.7	2,030.9	0.0	1.3	1	1	1
01/19/2022 18:00	0.4	12.8	2,012.3	0.3	1.3	1	1	1
01/19/2022 19:00	0.5	12.6	2,027.9	0.3	1.6	1	1	1
01/19/2022 20:00	0.5	12.8	1,967.8	0.4	1.6	1	1	1
01/19/2022 21:00	0.3	13.9	1,672.9	0.4	0.9	1	1	0
01/19/2022 22:00	0.3	13.8	1,764.6	0.3	1.0	1	1	1
01/19/2022 23:00	0.5	13.1	1,952.2	0.3	1.7	1	1	1
Average/Sum#:	0.5	13.5	1,696.4	0.4	31.7 #	24 #	24 #	15 #
Minimum:	0.3	12.6	1,286.5	0.3	0.7	1	1	0
Maximum:	0.9	14.0	2,030.9	0.5	3.0	1	1	1
%SI	12.50	12.50	0.00	33.33	12.50	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:09 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit Unit CT2	> Limit Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/20/2022 00:00	0.4	13.2	1,821.6	0.3	1.2	1	1	1
01/20/2022 01:00	0.3	14.0	1,290.4	0.3	0.7	1	1	0
01/20/2022 02:00	0.3	14.0	1,299.6	0.3	0.7	1	1	0
01/20/2022 03:00	0.3	13.9	1,710.7	0.3	1.0	1	1	0
01/20/2022 04:00	0.5	13.5	1,824.8	0.3	1.6	1	1	1
01/20/2022 05:00	0.5	13.4	1,830.3	0.4	1.6	1	1	1
01/20/2022 06:00	0.4	13.8	1,691.9	0.4	1.3	1	1	1
01/20/2022 07:00	0.6	13.2	1,947.8	0.4	2.0	1	1	1
01/20/2022 08:00	0.4	13.6	1,669.1	0.4	1.2	1	1	1
01/20/2022 09:00	9.5	14.8	935.8	0.0	8.3	1	0	0
01/20/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/20/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/20/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/20/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/20/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/20/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/20/2022 16:00	17.8	17.9	340.4	0.0	14.2	1	0	0
01/20/2022 17:00	26.6	14.8	1,120.8	0.0	64.5	1	0	0
01/20/2022 18:00	0.3	13.9	1,598.9	0.0	0.9	1	1	0
01/20/2022 19:00	0.4	13.8	1,696.8	0.0	1.3	1	1	1
01/20/2022 20:00	0.7	12.9	1,975.1	0.4	2.3	1	1	1
01/20/2022 21:00	0.7	13.0	1,975.1	0.4	2.3	1	1	1
01/20/2022 22:00	0.6	12.8	2,006.6	0.5	2.0	1	1	1
01/20/2022 23:00	8.9	14.3	1,229.5	0.0	10.3	1	0	1
Average/Sum#:	3.8	13.9	1,553.6	0.4	117.4 #	18 #	14 #	11 #
Minimum:	0.3	12.8	340.4	0.3	0.7	0	0	0
Maximum:	26.6	17.9	2,006.6	0.5	64.5	1	1	1
%SI	25.00	25.00	25.00	50.00	25.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:09 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT2	Unit CT2	UnitOn, TF	NormalOp, TF	DBOn, TF
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/21/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/21/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/21/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/21/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/21/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/21/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/21/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/21/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/21/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/21/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/21/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/21/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/21/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/21/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/21/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/21/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/21/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/21/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/21/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/21/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/21/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/21/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/21/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/21/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:09 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/22/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/22/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/22/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/22/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/22/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/22/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/22/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/22/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/22/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/22/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/22/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/22/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/22/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/22/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/22/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/22/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/22/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/22/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/22/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/22/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/22/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/22/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/22/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/22/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:09 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit Unit CT2	> Limit Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/23/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/23/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/23/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/23/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/23/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/23/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/23/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/23/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/23/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/23/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/23/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/23/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/23/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/23/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/23/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/23/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/23/2022 16:00	86.0	17.9	291.0	0.0	51.8	1	0	0
01/23/2022 17:00	30.8	15.8	749.9	0.0	59.8	1	0	0
01/23/2022 18:00	0.3	13.8	1,712.2	0.0	1.0	1	1	1
01/23/2022 19:00	0.7	13.1	1,954.9	0.0	2.3	1	1	1
01/23/2022 20:00	0.6	12.7	2,019.1	0.4	2.0	1	1	1
01/23/2022 21:00	0.6	13.0	1,992.3	0.4	2.0	1	1	1
01/23/2022 22:00	0.8	13.1	1,958.4	0.5	2.7	1	1	1
01/23/2022 23:00	7.9	14.5	1,191.0	0.0	9.3	1	0	1
Average/Sum#:	16.0	14.2	1,483.6	0.4	130.9 #	8 #	5 #	6 #
Minimum:	0.3	12.7	291.0	0.4	1.0	0	0	0
Maximum:	86.0	17.9	2,019.1	0.5	59.8	1	1	1
%SI	66.67	66.67	66.67	87.50	66.67	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:09 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT2	Unit CT2	UnitOn, TF	NormalOp, TF	DBOn, TF
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/24/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/24/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/24/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/24/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/24/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/24/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/24/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/24/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/24/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/24/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/24/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/24/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/24/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/24/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/24/2022 14:00	22.1	17.6	354.3	0.0	28.8	1	0	0
01/24/2022 15:00	20.9	14.8	1,083.8	0.0	49.0	1	0	0
01/24/2022 16:00	0.3	13.9	1,649.1	0.0	0.9	1	1	0
01/24/2022 17:00	0.4	13.8	1,635.3	0.0	1.2	1	1	1
01/24/2022 18:00	0.7	13.1	1,941.1	0.4	2.3	1	1	1
01/24/2022 19:00	0.6	12.8	2,005.5	0.4	2.0	1	1	1
01/24/2022 20:00	0.6	13.1	1,917.9	0.5	1.9	1	1	1
01/24/2022 21:00	0.3	13.9	1,593.6	0.4	0.9	1	1	0
01/24/2022 22:00	0.4	13.8	1,711.8	0.4	1.3	1	1	1
01/24/2022 23:00	0.8	13.1	1,948.0	0.4	2.6	1	1	1
Average/Sum#:	4.7	14.0	1,584.0	0.4	90.9 #	10 #	8 #	6 #
Minimum:	0.3	12.8	354.3	0.4	0.9	0	0	0
Maximum:	22.1	17.6	2,005.5	0.5	49.0	1	1	1
%SI	58.33	58.33	58.33	75.00	58.33	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:09 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit Unit CT2	> Limit Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/25/2022 00:00	0.8	13.3	1,896.4	0.5	2.6	1	1	1
01/25/2022 01:00	0.4	13.9	1,535.3	0.5	1.2	1	1	0
01/25/2022 02:00	0.4	13.8	1,642.7	0.4	1.2	1	1	1
01/25/2022 03:00	0.6	13.3	1,928.8	0.4	2.0	1	1	1
01/25/2022 04:00	0.6	13.3	1,910.4	0.4	2.0	1	1	1
01/25/2022 05:00	0.4	13.9	1,644.5	0.4	1.2	1	1	0
01/25/2022 06:00	0.4	13.8	1,745.0	0.4	1.3	1	1	1
01/25/2022 07:00	0.7	13.0	1,978.0	0.4	2.3	1	1	1
01/25/2022 08:00	4.3	13.8	1,481.9	0.0	8.9	1	0	1
01/25/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2022 11:00	8.5	18.7	211.4	0.0	2.4	1	0	0
01/25/2022 12:00	20.0	16.0	764.8	0.0	41.2	1	0	0
01/25/2022 13:00	0.3	14.0	1,370.6	0.0	0.8	1	1	0
01/25/2022 14:00	0.3	14.0	1,355.8	0.0	0.8	1	1	0
01/25/2022 15:00	0.3	13.8	1,715.9	0.3	1.0	1	1	0
01/25/2022 16:00	0.3	14.0	1,559.4	0.3	0.9	1	1	0
01/25/2022 17:00	0.3	14.0	1,635.7	0.3	0.9	1	1	0
01/25/2022 18:00	0.3	13.9	1,706.5	0.3	1.0	1	1	0
01/25/2022 19:00	0.7	13.3	1,884.4	0.4	2.3	1	1	1
01/25/2022 20:00	0.7	13.2	1,900.7	0.4	2.3	1	1	1
01/25/2022 21:00	0.3	14.0	1,515.9	0.4	0.9	1	1	0
01/25/2022 22:00	0.4	13.8	1,688.2	0.4	1.3	1	1	1
01/25/2022 23:00	0.5	13.3	1,919.9	0.3	1.7	1	1	1
Average/Sum#:	1.9	14.0	1,590.6	0.4	80.2 #	22 #	19 #	11 #
Minimum:	0.3	13.0	211.4	0.3	0.8	0	0	0
Maximum:	20.0	18.7	1,978.0	0.5	41.2	1	1	1
%SI	8.33	8.33	8.33	29.17	8.33	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:09 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit Unit CT2	> Limit Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/26/2022 00:00	0.5	13.2	1,924.8	0.4	1.7	1	1	1
01/26/2022 01:00	0.3	13.9	1,679.3	0.4	1.0	1	1	0
01/26/2022 02:00	0.4	13.9	1,681.1	0.3	1.3	1	1	1
01/26/2022 03:00	0.6	13.3	1,949.6	0.4	2.0	1	1	1
01/26/2022 04:00	0.5	13.3	1,938.2	0.4	1.7	1	1	1
01/26/2022 05:00	0.3	13.9	1,570.0	0.4	0.9	1	1	0
01/26/2022 06:00	0.4	13.8	1,780.7	0.3	1.3	1	1	1
01/26/2022 07:00	0.5	13.2	1,956.3	0.3	1.7	1	1	1
01/26/2022 08:00	5.6	14.1	1,440.7	0.0	11.5	1	0	1
01/26/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2022 11:00	8.2	18.7	222.7	0.0	2.4	1	0	0
01/26/2022 12:00	18.6	15.9	790.0	0.0	38.8	1	0	0
01/26/2022 13:00	0.3	14.0	1,353.7	0.0	0.8	1	1	0
01/26/2022 14:00	0.3	14.0	1,346.1	0.0	0.8	1	1	0
01/26/2022 15:00	0.3	13.9	1,686.0	0.3	1.0	1	1	0
01/26/2022 16:00	0.3	14.0	1,556.1	0.3	0.9	1	1	0
01/26/2022 17:00	0.3	13.9	1,695.5	0.3	1.0	1	1	0
01/26/2022 18:00	0.4	13.8	1,778.2	0.3	1.3	1	1	0
01/26/2022 19:00	0.6	13.3	1,877.1	0.4	2.0	1	1	1
01/26/2022 20:00	0.6	12.9	1,981.6	0.4	2.0	1	1	1
01/26/2022 21:00	0.3	13.9	1,648.9	0.4	0.9	1	1	0
01/26/2022 22:00	0.3	13.8	1,768.1	0.3	1.0	1	1	0
01/26/2022 23:00	0.7	13.1	1,971.1	0.3	2.3	1	1	1
Average/Sum#:	1.8	14.0	1,618.0	0.3	78.3 #	22 #	19 #	10 #
Minimum:	0.3	12.9	222.7	0.3	0.8	0	0	0
Maximum:	18.6	18.7	1,981.6	0.4	38.8	1	1	1
%SI	8.33	8.33	8.33	29.17	8.33	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:09 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit Unit CT2	> Limit Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/27/2022 00:00	0.7	13.2	1,935.0	0.4	2.3	1	1	1
01/27/2022 01:00	0.4	13.9	1,502.8	0.4	1.1	1	1	1
01/27/2022 02:00	0.4	13.9	1,675.8	0.4	1.3	1	1	0
01/27/2022 03:00	0.6	13.3	1,934.7	0.4	2.0	1	1	1
01/27/2022 04:00	0.5	13.3	1,917.5	0.4	1.7	1	1	1
01/27/2022 05:00	0.3	13.9	1,565.4	0.4	0.9	1	1	0
01/27/2022 06:00	0.6	13.3	1,834.3	0.4	1.9	1	1	1
01/27/2022 07:00	0.6	13.0	1,979.5	0.4	2.0	1	1	1
01/27/2022 08:00	0.7	13.2	1,941.1	0.5	2.3	1	1	1
01/27/2022 09:00	0.5	13.6	1,658.5	0.4	1.5	1	1	1
01/27/2022 10:00	0.3	14.0	1,360.0	0.4	0.8	1	1	0
01/27/2022 11:00	0.3	14.0	1,349.3	0.3	0.8	1	1	0
01/27/2022 12:00	0.3	14.0	1,352.3	0.3	0.8	1	1	0
01/27/2022 13:00	0.3	14.0	1,353.7	0.3	0.8	1	1	0
01/27/2022 14:00	0.3	14.0	1,356.2	0.3	0.8	1	1	0
01/27/2022 15:00	0.3	13.9	1,684.2	0.3	1.0	1	1	0
01/27/2022 16:00	0.3	13.9	1,560.7	0.3	0.9	1	1	0
01/27/2022 17:00	0.3	14.0	1,514.3	0.3	0.9	1	1	0
01/27/2022 18:00	0.4	13.7	1,783.4	0.3	1.3	1	1	1
01/27/2022 19:00	0.8	13.0	1,985.3	0.4	2.7	1	1	1
01/27/2022 20:00	0.7	13.0	1,964.1	0.5	2.3	1	1	1
01/27/2022 21:00	0.3	13.9	1,672.3	0.5	0.9	1	1	0
01/27/2022 22:00	0.3	14.0	1,466.1	0.4	0.8	1	1	0
01/27/2022 23:00	0.6	13.4	1,881.2	0.4	2.0	1	1	1
Average/Sum#:	0.5	13.6	1,676.2	0.4	33.8 #	24 #	24 #	12 #
Minimum:	0.3	13.0	1,349.3	0.3	0.8	1	1	0
Maximum:	0.8	14.0	1,985.3	0.5	2.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:09 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit Unit CT2	> Limit Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/28/2022 00:00	0.6	12.9	2,011.2	0.4	2.0	1	1	1
01/28/2022 01:00	0.6	12.9	1,997.3	0.4	2.0	1	1	1
01/28/2022 02:00	0.3	13.9	1,487.4	0.4	0.8	1	1	1
01/28/2022 03:00	0.4	13.9	1,500.7	0.3	1.1	1	1	0
01/28/2022 04:00	0.4	13.9	1,736.7	0.3	1.3	1	1	1
01/28/2022 05:00	0.5	13.2	1,964.9	0.3	1.7	1	1	1
01/28/2022 06:00	0.5	12.8	2,069.9	0.4	1.7	1	1	1
01/28/2022 07:00	0.5	12.8	2,057.3	0.4	1.7	1	1	1
01/28/2022 08:00	0.5	13.2	1,941.8	0.4	1.7	1	1	1
01/28/2022 09:00	0.3	14.0	1,515.3	0.4	0.9	1	1	0
01/28/2022 10:00	0.3	14.0	1,408.8	0.3	0.8	1	1	0
01/28/2022 11:00	0.3	14.0	1,479.2	0.3	0.8	1	1	0
01/28/2022 12:00	0.3	14.0	1,438.2	0.3	0.8	1	1	0
01/28/2022 13:00	0.3	14.0	1,418.6	0.3	0.8	1	1	0
01/28/2022 14:00	0.3	14.0	1,613.2	0.3	0.9	1	1	0
01/28/2022 15:00	0.3	14.0	1,539.9	0.3	0.9	1	1	0
01/28/2022 16:00	0.3	13.9	1,587.8	0.3	0.9	1	1	1
01/28/2022 17:00	0.7	13.3	1,904.9	0.4	2.3	1	1	1
01/28/2022 18:00	0.7	12.8	2,019.0	0.4	2.3	1	1	1
01/28/2022 19:00	0.6	12.5	2,087.9	0.5	2.0	1	1	1
01/28/2022 20:00	0.5	12.7	2,017.3	0.4	1.6	1	1	1
01/28/2022 21:00	0.3	14.0	1,522.1	0.4	0.9	1	1	0
01/28/2022 22:00	0.4	13.8	1,784.8	0.3	1.3	1	1	1
01/28/2022 23:00	0.7	13.1	1,946.1	0.4	2.3	1	1	1
Average/Sum#:	0.4	13.5	1,752.1	0.4	33.5 #	24 #	24 #	15 #
Minimum:	0.3	12.5	1,408.8	0.3	0.8	1	1	0
Maximum:	0.7	14.0	2,087.9	0.5	2.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:09 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT2	Unit CT2	UnitOn, TF	NormalOp, TF	DBOn, TF
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/29/2022 00:00	0.8	13.3	1,897.9	0.5	2.6	1	1	1
01/29/2022 01:00	0.3	13.9	1,551.0	0.5	0.9	1	1	0
01/29/2022 02:00	0.4	13.9	1,563.3	0.4	1.2	1	1	1
01/29/2022 03:00	0.8	13.3	1,918.2	0.4	2.7	1	1	1
01/29/2022 04:00	0.8	13.3	1,895.6	0.5	2.6	1	1	1
01/29/2022 05:00	0.3	13.9	1,586.3	0.5	0.9	1	1	0
01/29/2022 06:00	0.4	13.8	1,604.1	0.4	1.2	1	1	1
01/29/2022 07:00	0.8	13.2	1,964.3	0.4	2.7	1	1	1
01/29/2022 08:00	0.7	13.0	2,008.7	0.5	2.4	1	1	1
01/29/2022 09:00	0.8	13.3	1,904.4	0.6	2.6	1	1	1
01/29/2022 10:00	0.3	14.0	1,395.6	0.5	0.8	1	1	0
01/29/2022 11:00	0.3	13.9	1,514.2	0.4	0.9	1	1	0
01/29/2022 12:00	0.3	14.0	1,364.2	0.3	0.8	1	1	0
01/29/2022 13:00	0.3	14.0	1,384.3	0.3	0.8	1	1	0
01/29/2022 14:00	0.3	14.0	1,591.9	0.3	0.9	1	1	0
01/29/2022 15:00	0.3	14.0	1,367.5	0.3	0.8	1	1	0
01/29/2022 16:00	0.3	14.0	1,572.6	0.3	0.9	1	1	0
01/29/2022 17:00	0.3	13.9	1,603.5	0.3	0.9	1	1	0
01/29/2022 18:00	0.6	13.5	1,786.3	0.4	1.9	1	1	1
01/29/2022 19:00	0.6	13.2	1,859.9	0.4	1.9	1	1	1
01/29/2022 20:00	0.4	13.8	1,767.4	0.4	1.3	1	1	1
01/29/2022 21:00	0.5	13.0	1,980.7	0.4	1.7	1	1	1
01/29/2022 22:00	0.5	12.7	2,052.7	0.4	1.7	1	1	1
01/29/2022 23:00	0.5	13.4	1,816.1	0.4	1.6	1	1	1
Average/Sum#:	0.5	13.6	1,706.3	0.4	36.7 #	24 #	24 #	14 #
Minimum:	0.3	12.7	1,364.2	0.3	0.8	1	1	0
Maximum:	0.8	14.0	2,052.7	0.6	2.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:09 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT2	Unit CT2	UnitOn, TF	NormalOp, TF	DBOn, TF
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/30/2022 00:00	0.3	13.9	1,572.5	0.4	0.9	1	1	0
01/30/2022 01:00	0.4	14.0	1,373.3	0.3	1.1	1	1	0
01/30/2022 02:00	0.4	13.9	1,716.3	0.3	1.3	1	1	0
01/30/2022 03:00	0.5	13.6	1,837.1	0.3	1.7	1	1	1
01/30/2022 04:00	0.5	13.5	1,822.2	0.4	1.6	1	1	1
01/30/2022 05:00	0.4	13.9	1,589.8	0.4	1.2	1	1	1
01/30/2022 06:00	0.7	13.0	1,970.9	0.4	2.3	1	1	1
01/30/2022 07:00	5.5	13.8	1,493.2	0.0	11.8	1	0	1
01/30/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/30/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/30/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/30/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/30/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/30/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/30/2022 14:00	16.0	18.6	223.8	0.0	4.7	1	0	0
01/30/2022 15:00	37.8	15.8	790.6	0.0	77.4	1	0	0
01/30/2022 16:00	0.3	13.9	1,518.4	0.0	0.9	1	1	0
01/30/2022 17:00	0.9	13.2	1,915.9	0.0	3.0	1	1	1
01/30/2022 18:00	0.8	13.2	1,908.4	0.5	2.6	1	1	1
01/30/2022 19:00	0.8	13.2	1,905.0	0.6	2.6	1	1	1
01/30/2022 20:00	0.7	12.7	2,027.8	0.6	2.3	1	1	1
01/30/2022 21:00	0.8	13.3	1,878.4	0.6	2.6	1	1	1
01/30/2022 22:00	0.4	14.0	1,379.9	0.5	1.1	1	1	0
01/30/2022 23:00	0.4	14.0	1,355.9	0.4	1.0	1	1	0
Average/Sum#:	3.8	14.0	1,571.1	0.4	120.1 #	18 #	15 #	10 #
Minimum:	0.3	12.7	223.8	0.3	0.9	0	0	0
Maximum:	37.8	18.6	2,027.8	0.6	77.4	1	1	1
%SI	25.00	25.00	25.00	45.83	25.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:09 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit Unit CT2	> Limit Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/31/2022 00:00	0.4	13.9	1,349.4	0.3	1.0	1	1	0
01/31/2022 01:00	0.4	13.9	1,347.3	0.3	1.0	1	1	0
01/31/2022 02:00	0.4	13.9	1,564.4	0.3	1.2	1	1	0
01/31/2022 03:00	0.4	13.9	1,535.5	0.3	1.2	1	1	0
01/31/2022 04:00	0.4	13.9	1,454.8	0.3	1.1	1	1	0
01/31/2022 05:00	0.4	13.9	1,569.4	0.3	1.2	1	1	1
01/31/2022 06:00	0.8	13.0	1,961.3	0.4	2.6	1	1	1
01/31/2022 07:00	0.7	12.9	2,010.6	0.5	2.3	1	1	1
01/31/2022 08:00	0.8	13.3	1,924.6	0.6	2.7	1	1	1
01/31/2022 09:00	0.4	13.9	1,575.0	0.5	1.2	1	1	1
01/31/2022 10:00	0.4	13.9	1,458.7	0.4	1.1	1	1	0
01/31/2022 11:00	0.3	13.9	1,531.3	0.3	0.9	1	1	0
01/31/2022 12:00	0.3	13.9	1,569.9	0.3	0.9	1	1	0
01/31/2022 13:00	0.3	14.0	1,417.0	0.3	0.8	1	1	0
01/31/2022 14:00	0.3	14.0	1,529.0	0.3	0.9	1	1	0
01/31/2022 15:00	0.4	13.9	1,626.5	0.3	1.2	1	1	1
01/31/2022 16:00	0.7	13.0	1,959.3	0.4	2.3	1	1	1
01/31/2022 17:00	0.6	12.6	2,053.2	0.4	2.0	1	1	1
01/31/2022 18:00	0.6	12.6	2,054.9	0.4	2.0	1	1	1
01/31/2022 19:00	0.7	13.2	1,902.2	0.4	2.3	1	1	1
01/31/2022 20:00	0.3	14.0	1,585.7	0.4	0.9	1	1	0
01/31/2022 21:00	0.4	13.9	1,655.2	0.4	1.2	1	1	1
01/31/2022 22:00	0.9	13.1	1,958.9	0.4	3.0	1	1	1
01/31/2022 23:00	7.2	14.5	1,196.9	0.0	8.5	1	0	1
Average/Sum#:	0.8	13.6	1,658.0	0.4	43.5 #	24 #	23 #	13 #
Minimum:	0.3	12.6	1,196.9	0.3	0.8	1	0	0
Maximum:	7.2	14.5	2,054.9	0.6	8.5	1	1	1
%SI	0.00	0.00	0.00	4.17	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:09 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT2	Unit CT2	UnitOn, TF	NormalOp, TF	DBOn, TF
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/01/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2022 03:00	22.8	17.3	446.9	0.0	34.4	1	0	0
02/01/2022 04:00	8.5	14.3	1,264.2	0.0	21.5	1	0	0
02/01/2022 05:00	0.3	14.0	1,317.4	0.0	0.8	1	1	0
02/01/2022 06:00	0.3	14.0	1,286.6	0.0	0.7	1	1	0
02/01/2022 07:00	0.4	13.9	1,640.7	0.3	1.2	1	1	1
02/01/2022 08:00	0.5	11.9	2,272.8	0.3	1.7	1	1	1
02/01/2022 09:00	0.4	11.9	2,265.9	0.3	1.3	1	1	1
02/01/2022 10:00	0.4	13.3	1,829.9	0.3	1.3	1	1	1
02/01/2022 11:00	0.3	14.0	1,540.4	0.3	0.9	1	1	0
02/01/2022 12:00	0.3	14.0	1,288.3	0.3	0.7	1	1	0
02/01/2022 13:00	0.3	14.0	1,288.9	0.3	0.7	1	1	0
02/01/2022 14:00	0.3	14.0	1,289.1	0.3	0.7	1	1	0
02/01/2022 15:00	0.3	14.0	1,311.7	0.3	0.8	1	1	0
02/01/2022 16:00	0.3	13.9	1,527.3	0.3	0.9	1	1	0
02/01/2022 17:00	0.4	13.9	1,781.3	0.3	1.3	1	1	0
02/01/2022 18:00	0.7	13.3	1,896.4	0.4	2.3	1	1	1
02/01/2022 19:00	0.6	13.0	1,993.5	0.4	2.0	1	1	1
02/01/2022 20:00	0.7	13.1	1,949.2	0.5	2.3	1	1	1
02/01/2022 21:00	0.3	13.9	1,582.9	0.4	0.9	1	1	0
02/01/2022 22:00	0.4	13.8	1,760.5	0.4	1.3	1	1	1
02/01/2022 23:00	0.5	13.1	1,987.0	0.3	1.7	1	1	1
Average/Sum#:	1.9	13.7	1,596.2	0.3	79.4 #	21 #	19 #	9 #
Minimum:	0.3	11.9	446.9	0.3	0.7	0	0	0
Maximum:	22.8	17.3	2,272.8	0.5	34.4	1	1	1
%SI	12.50	12.50	12.50	29.17	12.50	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:09 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/02/2022 00:00	0.4	12.6	2,111.6	0.3	1.3	1	1	1
02/02/2022 01:00	0.4	13.8	1,713.4	0.3	1.3	1	1	1
02/02/2022 02:00	0.3	13.9	1,573.4	0.3	0.9	1	1	1
02/02/2022 03:00	0.6	13.2	1,966.6	0.4	2.0	1	1	1
02/02/2022 04:00	0.6	13.3	1,943.0	0.4	2.0	1	1	1
02/02/2022 05:00	0.6	13.1	1,992.0	0.5	2.0	1	1	1
02/02/2022 06:00	0.5	12.8	2,054.2	0.5	1.7	1	1	1
02/02/2022 07:00	0.5	13.0	2,021.5	0.4	1.7	1	1	1
02/02/2022 08:00	0.5	13.1	1,994.1	0.4	1.7	1	1	1
02/02/2022 09:00	0.5	13.7	1,645.1	0.4	1.5	1	1	1
02/02/2022 10:00	0.3	14.0	1,336.7	0.4	0.8	1	1	0
02/02/2022 11:00	0.3	14.0	1,341.3	0.3	0.8	1	1	0
02/02/2022 12:00	0.3	14.0	1,346.6	0.3	0.8	1	1	0
02/02/2022 13:00	0.3	14.0	1,358.1	0.3	0.8	1	1	0
02/02/2022 14:00	0.3	14.0	1,360.7	0.3	0.8	1	1	0
02/02/2022 15:00	0.4	13.9	1,626.5	0.3	1.2	1	1	0
02/02/2022 16:00	0.3	13.9	1,608.5	0.3	0.9	1	1	0
02/02/2022 17:00	0.4	13.8	1,687.2	0.3	1.3	1	1	1
02/02/2022 18:00	0.7	12.8	2,027.7	0.4	2.3	1	1	1
02/02/2022 19:00	0.5	12.1	2,205.2	0.4	1.7	1	1	1
02/02/2022 20:00	0.4	12.0	2,215.8	0.4	1.3	1	1	1
02/02/2022 21:00	0.5	12.4	2,131.5	0.3	1.7	1	1	1
02/02/2022 22:00	0.5	12.7	2,038.4	0.3	1.6	1	1	1
02/02/2022 23:00	0.5	12.9	2,007.3	0.4	1.7	1	1	1
Average/Sum#:	0.4	13.3	1,804.4	0.4	33.8 #	24 #	24 #	17 #
Minimum:	0.3	12.0	1,336.7	0.3	0.8	1	1	0
Maximum:	0.7	14.0	2,215.8	0.5	2.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:09 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT2	Unit CT2	UnitOn, TF	NormalOp, TF	DBOn, TF
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/03/2022 00:00	0.8	13.3	1,905.8	0.5	2.6	1	1	1
02/03/2022 01:00	0.3	13.9	1,647.6	0.4	0.9	1	1	0
02/03/2022 02:00	0.3	13.9	1,775.6	0.4	1.0	1	1	1
02/03/2022 03:00	0.7	13.0	1,990.0	0.4	2.3	1	1	1
02/03/2022 04:00	0.7	13.1	1,971.2	0.4	2.3	1	1	1
02/03/2022 05:00	0.7	13.1	1,987.1	0.5	2.4	1	1	1
02/03/2022 06:00	0.6	12.4	2,136.7	0.5	2.0	1	1	1
02/03/2022 07:00	0.6	12.7	2,075.7	0.4	2.0	1	1	1
02/03/2022 08:00	0.9	13.3	1,913.9	0.5	3.0	1	1	1
02/03/2022 09:00	0.4	13.9	1,448.4	0.5	1.1	1	1	1
02/03/2022 10:00	0.3	13.9	1,656.2	0.4	0.9	1	1	0
02/03/2022 11:00	0.3	13.9	1,665.7	0.3	0.9	1	1	0
02/03/2022 12:00	0.3	14.0	1,378.1	0.3	0.8	1	1	0
02/03/2022 13:00	0.3	14.0	1,540.7	0.3	0.9	1	1	0
02/03/2022 14:00	0.3	14.0	1,466.2	0.3	0.8	1	1	0
02/03/2022 15:00	0.4	13.9	1,524.7	0.3	1.2	1	1	1
02/03/2022 16:00	0.8	13.0	1,956.6	0.4	2.6	1	1	1
02/03/2022 17:00	0.6	12.7	2,038.7	0.4	2.0	1	1	1
02/03/2022 18:00	0.5	12.5	2,082.2	0.5	1.6	1	1	1
02/03/2022 19:00	0.5	12.5	2,084.0	0.4	1.6	1	1	1
02/03/2022 20:00	0.5	12.5	2,084.4	0.4	1.6	1	1	1
02/03/2022 21:00	0.5	12.3	2,135.7	0.4	1.6	1	1	1
02/03/2022 22:00	0.5	12.6	2,057.7	0.4	1.6	1	1	1
02/03/2022 23:00	0.5	12.8	2,035.7	0.4	1.7	1	1	1
Average/Sum#:	0.5	13.2	1,856.6	0.4	39.4 #	24 #	24 #	18 #
Minimum:	0.3	12.3	1,378.1	0.3	0.8	1	1	0
Maximum:	0.9	14.0	2,136.7	0.5	3.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:09 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/04/2022 00:00	0.6	12.9	2,000.8	0.4	2.0	1	1	1
02/04/2022 01:00	0.9	13.3	1,899.3	0.5	3.0	1	1	1
02/04/2022 02:00	0.3	13.9	1,596.2	0.5	0.9	1	1	0
02/04/2022 03:00	0.3	13.9	1,527.3	0.4	0.9	1	1	0
02/04/2022 04:00	0.4	13.9	1,582.9	0.3	1.2	1	1	1
02/04/2022 05:00	0.7	13.1	1,975.2	0.4	2.3	1	1	1
02/04/2022 06:00	0.6	12.5	2,117.4	0.4	2.0	1	1	1
02/04/2022 07:00	0.6	12.8	2,032.3	0.4	2.0	1	1	1
02/04/2022 08:00	7.6	14.6	1,184.3	0.0	9.1	1	0	1
02/04/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/04/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/04/2022 11:00	12.2	17.9	332.2	0.0	9.3	1	0	0
02/04/2022 12:00	29.1	15.6	845.9	0.0	61.3	1	0	0
02/04/2022 13:00	0.3	14.0	1,355.6	0.0	0.8	1	1	0
02/04/2022 14:00	0.3	14.0	1,350.1	0.0	0.8	1	1	0
02/04/2022 15:00	0.3	13.9	1,493.6	0.3	0.8	1	1	0
02/04/2022 16:00	0.3	14.0	1,605.4	0.3	0.9	1	1	0
02/04/2022 17:00	0.3	13.9	1,567.7	0.3	0.9	1	1	0
02/04/2022 18:00	0.3	14.0	1,456.5	0.3	0.8	1	1	0
02/04/2022 19:00	0.7	13.3	1,869.9	0.4	2.3	1	1	1
02/04/2022 20:00	0.7	13.2	1,913.9	0.4	2.3	1	1	1
02/04/2022 21:00	0.7	13.3	1,911.2	0.5	2.3	1	1	1
02/04/2022 22:00	0.7	13.2	1,934.0	0.5	2.3	1	1	1
02/04/2022 23:00	0.6	12.9	1,994.0	0.5	2.0	1	1	1
Average/Sum#:	2.7	13.8	1,615.7	0.4	110.2 #	22 #	19 #	12 #
Minimum:	0.3	12.5	332.2	0.3	0.8	0	0	0
Maximum:	29.1	17.9	2,117.4	0.5	61.3	1	1	1
%SI	8.33	8.33	8.33	29.17	8.33	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:09 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit Unit CT2	> Limit Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/05/2022 00:00	0.7	13.3	1,905.9	0.5	2.3	1	1	1
02/05/2022 01:00	0.4	13.8	1,680.5	0.4	1.3	1	1	1
02/05/2022 02:00	0.4	14.0	1,394.3	0.4	1.1	1	1	0
02/05/2022 03:00	0.8	13.4	1,871.4	0.4	2.6	1	1	1
02/05/2022 04:00	0.9	13.3	1,915.1	0.5	3.0	1	1	1
02/05/2022 05:00	0.4	13.8	1,697.4	0.5	1.3	1	1	1
02/05/2022 06:00	0.4	13.9	1,585.6	0.4	1.2	1	1	1
02/05/2022 07:00	0.7	13.0	1,985.6	0.4	2.3	1	1	1
02/05/2022 08:00	7.7	14.4	1,212.6	0.0	9.1	1	0	1
02/05/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/05/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/05/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/05/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/05/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/05/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/05/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/05/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/05/2022 17:00	16.3	18.0	307.4	0.0	10.3	1	0	0
02/05/2022 18:00	20.1	16.2	689.7	0.0	39.0	1	0	0
02/05/2022 19:00	0.3	14.0	1,294.5	0.0	0.7	1	1	0
02/05/2022 20:00	0.4	13.9	1,548.5	0.0	1.2	1	1	1
02/05/2022 21:00	0.7	12.9	1,984.5	0.4	2.3	1	1	1
02/05/2022 22:00	0.6	12.9	1,998.6	0.4	2.0	1	1	1
02/05/2022 23:00	0.6	12.9	2,002.2	0.4	2.0	1	1	1
Average/Sum#:	3.2	14.0	1,567.1	0.4	81.7 #	16 #	13 #	12 #
Minimum:	0.3	12.9	307.4	0.4	0.7	0	0	0
Maximum:	20.1	18.0	2,002.2	0.5	39.0	1	1	1
%SI	33.33	33.33	33.33	54.17	33.33	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:09 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit Unit CT2	> Limit Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/06/2022 00:00	0.9	13.3	1,905.9	0.5	3.0	1	1	1
02/06/2022 01:00	0.4	13.9	1,661.5	0.5	1.3	1	1	1
02/06/2022 02:00	0.4	13.9	1,600.0	0.4	1.2	1	1	1
02/06/2022 03:00	0.8	13.1	1,960.0	0.4	2.7	1	1	1
02/06/2022 04:00	0.9	13.3	1,897.3	0.5	3.0	1	1	1
02/06/2022 05:00	0.4	13.9	1,547.6	0.5	1.2	1	1	0
02/06/2022 06:00	0.4	14.0	1,305.9	0.4	1.0	1	1	0
02/06/2022 07:00	0.4	13.9	1,537.9	0.3	1.2	1	1	0
02/06/2022 08:00	18.8	16.1	452.6	0.0	4.2	1	0	0
02/06/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/06/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/06/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/06/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/06/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/06/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/06/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/06/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/06/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/06/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/06/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/06/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/06/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/06/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/06/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	2.6	13.9	1,541.0	0.4	18.8 #	9 #	8 #	5 #
Minimum:	0.4	13.1	452.6	0.3	1.0	0	0	0
Maximum:	18.8	16.1	1,960.0	0.5	4.2	1	1	1
%SI	62.50	62.50	62.50	66.67	62.50	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:09 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT2	Unit CT2	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	CO, _3Hr, Ppmvdc	CO, Lb	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/07/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/07/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/07/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/07/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/07/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/07/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/07/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/07/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/07/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/07/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/07/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/07/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/07/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/07/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/07/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/07/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/07/2022 16:00	48.9	17.7	330.2	0.0	46.6	1	0	0
02/07/2022 17:00	27.6	15.7	821.9	0.0	57.6	1	0	0
02/07/2022 18:00	0.3	14.0	1,381.2	0.0	0.8	1	1	0
02/07/2022 19:00	0.4	13.9	1,549.4	0.0	1.2	1	1	1
02/07/2022 20:00	0.7	12.8	2,015.9	0.4	2.3	1	1	1
02/07/2022 21:00	0.6	12.7	2,036.8	0.4	2.0	1	1	1
02/07/2022 22:00	0.6	12.8	2,021.2	0.4	2.0	1	1	1
02/07/2022 23:00	7.5	14.4	1,196.7	0.0	8.7	1	0	1
Average/Sum#:	10.8	14.3	1,419.2	0.4	121.2 #	8 #	5 #	5 #
Minimum:	0.3	12.7	330.2	0.4	0.8	0	0	0
Maximum:	48.9	17.7	2,036.8	0.4	57.6	1	1	1
%SI	66.67	66.67	66.67	87.50	66.67	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:09 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT2	Unit CT2	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	CO, _3Hr, Ppmvdc	CO, Lb	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/08/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2022 05:00	18.0	17.8	330.0	0.0	14.7	1	0	0
02/08/2022 06:00	25.5	15.6	869.8	0.0	55.3	1	0	0
02/08/2022 07:00	0.3	14.0	1,260.1	0.0	0.7	1	1	0
02/08/2022 08:00	0.4	13.8	1,775.9	0.0	1.3	1	1	0
02/08/2022 09:00	0.4	13.8	1,795.8	0.3	1.3	1	1	0
02/08/2022 10:00	0.4	13.7	1,797.2	0.3	1.3	1	1	0
02/08/2022 11:00	0.3	13.7	1,793.5	0.3	1.0	1	1	0
02/08/2022 12:00	0.4	13.7	1,797.8	0.3	1.3	1	1	0
02/08/2022 13:00	0.4	13.7	1,795.4	0.3	1.3	1	1	0
02/08/2022 14:00	0.4	13.7	1,789.5	0.3	1.3	1	1	0
02/08/2022 15:00	0.4	13.8	1,769.9	0.3	1.3	1	1	0
02/08/2022 16:00	0.3	13.8	1,776.5	0.3	1.0	1	1	0
02/08/2022 17:00	0.7	13.3	1,884.8	0.3	2.3	1	1	1
02/08/2022 18:00	0.6	13.1	1,955.6	0.4	2.0	1	1	1
02/08/2022 19:00	0.7	13.2	1,929.8	0.5	2.3	1	1	1
02/08/2022 20:00	0.7	13.2	1,932.3	0.5	2.3	1	1	1
02/08/2022 21:00	0.5	13.6	1,673.9	0.5	1.5	1	1	1
02/08/2022 22:00	9.3	15.1	872.7	0.0	7.8	1	0	0
02/08/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	3.3	14.0	1,600.0	0.4	100.0 #	18 #	15 #	5 #
Minimum:	0.3	13.1	330.0	0.3	0.7	0	0	0
Maximum:	25.5	17.8	1,955.6	0.5	55.3	1	1	1
%SI	25.00	25.00	25.00	45.83	25.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:09 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT2	Unit CT2	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	CO, _3Hr, Ppmvdc	CO, Lb	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/09/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2022 16:00	41.8	17.0	499.7	0.0	61.5	1	0	0
02/09/2022 17:00	0.3	13.9	1,657.8	0.0	0.9	1	0	0
02/09/2022 18:00	0.3	13.7	1,788.3	0.0	1.0	1	1	1
02/09/2022 19:00	0.6	13.0	1,967.4	0.0	2.0	1	1	1
02/09/2022 20:00	0.5	12.8	2,033.7	0.3	1.7	1	1	1
02/09/2022 21:00	0.4	12.8	2,036.9	0.4	1.3	1	1	1
02/09/2022 22:00	0.5	13.0	1,977.7	0.4	1.7	1	1	1
02/09/2022 23:00	0.4	13.8	1,504.7	0.3	1.1	1	1	1
Average/Sum#:	5.6	13.8	1,683.3	0.4	71.2 #	8 #	6 #	6 #
Minimum:	0.3	12.8	499.7	0.3	0.9	0	0	0
Maximum:	41.8	17.0	2,036.9	0.4	61.5	1	1	1
%SI	66.67	66.67	66.67	83.33	66.67	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:09 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit Unit CT2	> Limit Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/10/2022 00:00	0.3	14.0	1,343.6	0.3	0.8	1	1	0
02/10/2022 01:00	0.4	13.9	1,574.3	0.3	1.2	1	1	1
02/10/2022 02:00	1.1	13.1	1,933.0	0.5	3.6	1	1	1
02/10/2022 03:00	0.9	13.1	1,940.8	0.6	3.0	1	1	1
02/10/2022 04:00	0.3	13.9	1,581.8	0.6	0.9	1	1	1
02/10/2022 05:00	0.4	13.9	1,576.2	0.4	1.2	1	1	1
02/10/2022 06:00	0.7	12.7	2,014.9	0.4	2.3	1	1	1
02/10/2022 07:00	0.7	12.8	1,986.6	0.4	2.3	1	1	1
02/10/2022 08:00	14.8	15.7	599.4	0.0	5.2	1	0	0
02/10/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/10/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/10/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/10/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/10/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/10/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/10/2022 15:00	5.2	19.1	97.3	0.0	0.6	1	0	0
02/10/2022 16:00	29.8	15.8	779.3	0.0	60.1	1	0	0
02/10/2022 17:00	0.4	13.5	1,535.8	0.0	1.1	1	1	1
02/10/2022 18:00	0.5	11.9	2,195.2	0.0	1.6	1	1	1
02/10/2022 19:00	0.5	12.1	2,169.8	0.3	1.6	1	1	1
02/10/2022 20:00	0.5	12.3	2,100.9	0.3	1.6	1	1	1
02/10/2022 21:00	0.6	12.8	1,999.4	0.3	2.0	1	1	1
02/10/2022 22:00	0.8	12.9	1,974.2	0.4	2.6	1	1	1
02/10/2022 23:00	0.5	13.7	1,499.0	0.5	1.4	1	1	1
Average/Sum#:	3.2	13.7	1,605.6	0.4	93.1 #	18 #	15 #	14 #
Minimum:	0.3	11.9	97.3	0.3	0.6	0	0	0
Maximum:	29.8	19.1	2,195.2	0.6	60.1	1	1	1
%SI	25.00	25.00	25.00	45.83	25.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:09 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT2	Unit CT2	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	CO, _3Hr, Ppmvdc	CO, Lb	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/11/2022 00:00	0.4	14.0	1,272.7	0.4	1.0	1	1	0
02/11/2022 01:00	26.6	16.7	264.2	0.0	2.9	1	0	0
02/11/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/11/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/11/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/11/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/11/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/11/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/11/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/11/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/11/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/11/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/11/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/11/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/11/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/11/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/11/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/11/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/11/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/11/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/11/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/11/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/11/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/11/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	13.5	15.4	768.5	0.4	3.9 #	2 #	1 #	0 #
Minimum:	0.4	14.0	264.2	0.4	1.0	0	0	0
Maximum:	26.6	16.7	1,272.7	0.4	2.9	1	1	0
%SI	91.67	91.67	91.67	95.83	91.67	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:09 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT2	Unit CT2	UnitOn, TF	NormalOp, TF	DBOn, TF
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/12/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/12/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/12/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/12/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/12/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/12/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/12/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/12/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/12/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/12/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/12/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/12/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/12/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/12/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/12/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/12/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/12/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/12/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/12/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/12/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/12/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/12/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/12/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/12/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:09 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/13/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/13/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/13/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/13/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/13/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/13/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/13/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/13/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/13/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/13/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/13/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/13/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/13/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/13/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/13/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/13/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/13/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/13/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/13/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/13/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/13/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/13/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/13/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/13/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:09 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT2	Unit CT2	UnitOn, TF	NormalOp, TF	DBOn, TF
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/14/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:09 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit Unit CT2	> Limit Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/15/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:09 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT2	Unit CT2	UnitOn, TF	NormalOp, TF	DBOn, TF
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/16/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:09 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/17/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:09 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT2	Unit CT2	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	CO, _3Hr, Ppmvdc	CO, Lb	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/18/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/18/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/18/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/18/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/18/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/18/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/18/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/18/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/18/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/18/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/18/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/18/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/18/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/18/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/18/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/18/2022 15:00	55.6	17.7	334.1	0.0	71.3	1	0	0
02/18/2022 16:00	31.4	15.4	875.8	0.0	66.0	1	0	0
02/18/2022 17:00	0.3	14.0	1,609.4	0.0	0.9	1	1	0
02/18/2022 18:00	0.4	13.9	1,553.7	0.0	1.2	1	1	1
02/18/2022 19:00	0.7	13.1	1,972.3	0.4	2.3	1	1	1
02/18/2022 20:00	1.0	13.2	1,907.0	0.5	3.3	1	1	1
02/18/2022 21:00	0.3	13.9	1,533.5	0.5	0.9	1	1	0
02/18/2022 22:00	0.4	13.9	1,562.7	0.5	1.2	1	1	1
02/18/2022 23:00	0.7	13.1	1,965.8	0.4	2.3	1	1	1
Average/Sum#:	10.1	14.2	1,479.4	0.5	149.4 #	9 #	7 #	5 #
Minimum:	0.3	13.1	334.1	0.4	0.9	0	0	0
Maximum:	55.6	17.7	1,972.3	0.5	71.3	1	1	1
%SI	62.50	62.50	62.50	79.17	62.50	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:09 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/19/2022 00:00	8.0	14.5	1,208.5	0.0	9.6	1	0	1
02/19/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/19/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/19/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/19/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/19/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/19/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/19/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/19/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/19/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/19/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/19/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/19/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/19/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/19/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/19/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/19/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/19/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/19/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/19/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/19/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/19/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/19/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/19/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	8.0	14.5	1,208.5	0.0	9.6 #	1 #	0 #	1 #
Minimum:	8.0	14.5	1,208.5	0.0	9.6	0	0	0
Maximum:	8.0	14.5	1,208.5	0.0	9.6	1	0	1
%SI	95.83	95.83	95.83	100.00	95.83	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:09 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/20/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:09 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/21/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:09 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/22/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2022 04:00	93.3	17.9	299.7	0.0	67.7	1	0	0
02/22/2022 05:00	28.1	15.8	820.3	0.0	59.7	1	0	0
02/22/2022 06:00	0.4	13.9	1,706.2	0.0	1.3	1	1	0
02/22/2022 07:00	0.4	13.9	1,559.6	0.0	1.2	1	1	0
02/22/2022 08:00	0.4	13.9	1,615.1	0.3	1.2	1	1	0
02/22/2022 09:00	0.4	13.9	1,516.2	0.3	1.1	1	1	0
02/22/2022 10:00	0.4	14.0	1,499.6	0.3	1.1	1	1	0
02/22/2022 11:00	0.4	14.0	1,499.1	0.3	1.1	1	1	0
02/22/2022 12:00	0.4	14.0	1,574.7	0.3	1.2	1	1	0
02/22/2022 13:00	0.4	14.0	1,563.0	0.3	1.2	1	1	0
02/22/2022 14:00	0.4	13.9	1,577.7	0.3	1.2	1	1	0
02/22/2022 15:00	0.4	13.9	1,591.5	0.3	1.2	1	1	0
02/22/2022 16:00	0.4	13.9	1,599.1	0.3	1.2	1	1	1
02/22/2022 17:00	0.8	13.0	2,008.1	0.4	2.7	1	1	1
02/22/2022 18:00	0.7	12.9	2,019.2	0.5	2.3	1	1	1
02/22/2022 19:00	0.6	12.7	2,097.9	0.5	2.0	1	1	1
02/22/2022 20:00	0.5	12.1	2,214.7	0.4	1.7	1	1	1
02/22/2022 21:00	0.6	12.7	2,085.3	0.4	2.0	1	1	1
02/22/2022 22:00	0.6	12.7	2,079.8	0.4	2.0	1	1	1
02/22/2022 23:00	0.6	12.5	2,128.8	0.4	2.0	1	1	1
Average/Sum#:	6.5	13.8	1,652.8	0.4	155.1 #	20 #	18 #	8 #
Minimum:	0.4	12.1	299.7	0.3	1.1	0	0	0
Maximum:	93.3	17.9	2,214.7	0.5	67.7	1	1	1
%SI	16.67	16.67	16.67	33.33	16.67	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:09 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT2	Unit CT2	UnitOn, TF	NormalOp, TF	DBOn, TF
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/23/2022 00:00	0.5	12.3	2,198.7	0.4	1.7	1	1	1
02/23/2022 01:00	0.6	12.5	2,149.8	0.4	2.0	1	1	1
02/23/2022 02:00	0.6	12.6	2,132.6	0.4	2.0	1	1	1
02/23/2022 03:00	0.7	12.9	2,016.1	0.4	2.3	1	1	1
02/23/2022 04:00	0.3	13.9	1,684.9	0.4	1.0	1	1	0
02/23/2022 05:00	0.7	13.6	1,844.4	0.5	2.3	1	1	1
02/23/2022 06:00	0.7	12.5	2,156.2	0.5	2.4	1	1	1
02/23/2022 07:00	0.6	12.5	2,157.1	0.5	2.0	1	1	1
02/23/2022 08:00	0.4	13.8	1,676.2	0.4	1.2	1	1	1
02/23/2022 09:00	0.3	14.0	1,522.7	0.3	0.9	1	1	0
02/23/2022 10:00	0.3	14.0	1,577.8	0.3	0.9	1	1	0
02/23/2022 11:00	0.3	13.9	1,639.3	0.3	0.9	1	1	0
02/23/2022 12:00	0.3	14.0	1,511.7	0.3	0.9	1	1	0
02/23/2022 13:00	0.3	14.0	1,415.6	0.3	0.8	1	1	0
02/23/2022 14:00	0.3	14.0	1,619.6	0.3	0.9	1	1	0
02/23/2022 15:00	0.3	14.0	1,587.3	0.3	0.9	1	1	0
02/23/2022 16:00	0.4	14.0	1,611.3	0.3	1.2	1	1	1
02/23/2022 17:00	0.8	13.1	1,977.6	0.4	2.7	1	1	1
02/23/2022 18:00	0.6	13.0	2,007.4	0.4	2.0	1	1	1
02/23/2022 19:00	0.6	13.1	2,007.7	0.5	2.0	1	1	1
02/23/2022 20:00	0.6	12.7	2,106.4	0.4	2.0	1	1	1
02/23/2022 21:00	0.5	12.1	2,235.4	0.4	1.7	1	1	1
02/23/2022 22:00	0.6	12.6	2,124.7	0.4	2.0	1	1	1
02/23/2022 23:00	0.6	12.9	2,085.2	0.4	2.1	1	1	1
Average/Sum#:	0.5	13.3	1,876.9	0.4	38.8 #	24 #	24 #	16 #
Minimum:	0.3	12.1	1,415.6	0.3	0.8	1	1	0
Maximum:	0.8	14.0	2,235.4	0.5	2.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:09 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT2	Unit CT2	UnitOn, TF	NormalOp, TF	DBOn, TF
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/24/2022 00:00	0.6	12.3	2,203.4	0.4	2.0	1	1	1
02/24/2022 01:00	0.6	12.3	2,197.9	0.4	2.0	1	1	1
02/24/2022 02:00	0.6	12.3	2,214.0	0.4	2.0	1	1	1
02/24/2022 03:00	0.5	12.1	2,239.1	0.4	1.7	1	1	1
02/24/2022 04:00	0.6	12.3	2,239.6	0.4	2.1	1	1	1
02/24/2022 05:00	0.6	12.2	2,242.3	0.4	2.0	1	1	1
02/24/2022 06:00	0.6	12.2	2,243.8	0.4	2.0	1	1	1
02/24/2022 07:00	0.6	12.5	2,177.8	0.4	2.1	1	1	1
02/24/2022 08:00	0.8	13.1	2,036.2	0.5	2.8	1	1	1
02/24/2022 09:00	0.8	13.3	1,952.9	0.5	2.7	1	1	1
02/24/2022 10:00	0.3	13.9	1,561.0	0.5	0.9	1	1	0
02/24/2022 11:00	0.3	14.0	1,430.3	0.4	0.8	1	1	0
02/24/2022 12:00	0.3	14.0	1,331.4	0.3	0.8	1	1	0
02/24/2022 13:00	0.3	14.0	1,379.1	0.3	0.8	1	1	0
02/24/2022 14:00	0.3	14.0	1,460.6	0.3	0.8	1	1	0
02/24/2022 15:00	0.3	14.0	1,456.1	0.3	0.8	1	1	0
02/24/2022 16:00	0.4	13.9	1,561.9	0.3	1.2	1	1	1
02/24/2022 17:00	0.6	13.1	1,974.4	0.4	2.0	1	1	1
02/24/2022 18:00	0.6	12.4	2,172.5	0.4	2.0	1	1	1
02/24/2022 19:00	0.5	12.2	2,214.2	0.4	1.7	1	1	1
02/24/2022 20:00	0.6	12.4	2,164.0	0.4	2.0	1	1	1
02/24/2022 21:00	0.5	12.3	2,189.9	0.3	1.7	1	1	1
02/24/2022 22:00	0.5	12.4	2,186.1	0.3	1.7	1	1	1
02/24/2022 23:00	0.6	12.6	2,143.6	0.3	2.0	1	1	1
Average/Sum#:	0.5	12.9	1,957.2	0.4	40.6 #	24 #	24 #	18 #
Minimum:	0.3	12.1	1,331.4	0.3	0.8	1	1	0
Maximum:	0.8	14.0	2,243.8	0.5	2.8	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:09 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/25/2022 00:00	0.6	12.9	2,050.8	0.4	2.0	1	1	1
02/25/2022 01:00	0.6	13.1	2,002.0	0.4	2.0	1	1	1
02/25/2022 02:00	0.6	13.1	1,999.0	0.5	2.0	1	1	1
02/25/2022 03:00	0.6	13.1	2,000.8	0.5	2.0	1	1	1
02/25/2022 04:00	0.6	13.0	2,040.3	0.5	2.0	1	1	1
02/25/2022 05:00	0.6	13.1	2,008.1	0.5	2.0	1	1	1
02/25/2022 06:00	0.6	12.5	2,161.3	0.4	2.0	1	1	1
02/25/2022 07:00	0.6	13.1	2,021.7	0.5	2.1	1	1	1
02/25/2022 08:00	0.6	13.4	1,923.1	0.5	2.0	1	1	1
02/25/2022 09:00	0.3	14.0	1,512.8	0.4	0.9	1	1	0
02/25/2022 10:00	0.3	14.0	1,504.3	0.4	0.9	1	1	0
02/25/2022 11:00	0.3	14.0	1,606.9	0.3	0.9	1	1	0
02/25/2022 12:00	0.3	14.0	1,587.5	0.3	0.9	1	1	0
02/25/2022 13:00	0.3	14.0	1,599.2	0.3	0.9	1	1	0
02/25/2022 14:00	0.3	14.0	1,575.8	0.3	0.9	1	1	0
02/25/2022 15:00	0.3	14.0	1,552.1	0.3	0.9	1	1	0
02/25/2022 16:00	0.3	13.9	1,641.1	0.3	0.9	1	1	1
02/25/2022 17:00	0.8	13.1	1,994.9	0.4	2.7	1	1	1
02/25/2022 18:00	0.9	13.2	1,938.0	0.5	3.0	1	1	1
02/25/2022 19:00	0.8	13.3	1,921.8	0.6	2.7	1	1	1
02/25/2022 20:00	0.7	13.2	1,958.0	0.6	2.4	1	1	1
02/25/2022 21:00	0.7	13.0	1,986.5	0.5	2.3	1	1	1
02/25/2022 22:00	0.6	12.9	2,022.4	0.5	2.0	1	1	1
02/25/2022 23:00	0.6	13.0	2,029.4	0.4	2.0	1	1	1
Average/Sum#:	0.5	13.4	1,859.9	0.4	42.4 #	24 #	24 #	17 #
Minimum:	0.3	12.5	1,504.3	0.3	0.9	1	1	0
Maximum:	0.9	14.0	2,161.3	0.6	3.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:09 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit Unit CT2	> Limit Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/26/2022 00:00	0.7	12.9	2,058.5	0.4	2.4	1	1	1
02/26/2022 01:00	0.6	12.9	2,059.7	0.4	2.0	1	1	1
02/26/2022 02:00	1.0	13.3	1,936.3	0.6	3.4	1	1	1
02/26/2022 03:00	1.1	13.4	1,932.8	0.7	3.7	1	1	1
02/26/2022 04:00	0.6	13.1	2,008.5	0.7	2.0	1	1	1
02/26/2022 05:00	0.7	13.1	2,006.2	0.6	2.4	1	1	1
02/26/2022 06:00	0.9	13.2	1,994.2	0.6	3.1	1	1	1
02/26/2022 07:00	8.1	14.6	1,200.5	0.0	9.8	1	0	1
02/26/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/26/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/26/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/26/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/26/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/26/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/26/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/26/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/26/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/26/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/26/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/26/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/26/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/26/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/26/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/26/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	1.7	13.3	1,899.6	0.6	28.8 #	8 #	7 #	8 #
Minimum:	0.6	12.9	1,200.5	0.4	2.0	0	0	0
Maximum:	8.1	14.6	2,059.7	0.7	9.8	1	1	1
%SI	66.67	66.67	66.67	70.83	66.67	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:09 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/27/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:09 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit Unit CT2	> Limit Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/28/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:09 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/01/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:09 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/02/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:09 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit Unit CT2	> Limit Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/03/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:09 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/04/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/04/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/04/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/04/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/04/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/04/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/04/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/04/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/04/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/04/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/04/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/04/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/04/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/04/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/04/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/04/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/04/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/04/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/04/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/04/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/04/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/04/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/04/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/04/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:09 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/05/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/05/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/05/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/05/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/05/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/05/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/05/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/05/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/05/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/05/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/05/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/05/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/05/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/05/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/05/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/05/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/05/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/05/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/05/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/05/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/05/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/05/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/05/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/05/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:09 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/06/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/06/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/06/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/06/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/06/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/06/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/06/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/06/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/06/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/06/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/06/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/06/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/06/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/06/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/06/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/06/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/06/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/06/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/06/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/06/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/06/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/06/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/06/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/06/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:09 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/07/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:09 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit Unit CT2	> Limit Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/08/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:09 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/09/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/09/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/09/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/09/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/09/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/09/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/09/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/09/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/09/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/09/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/09/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/09/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/09/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/09/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/09/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/09/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/09/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/09/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/09/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/09/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/09/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/09/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/09/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/09/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:09 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit Unit CT2	> Limit Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/10/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/10/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/10/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/10/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/10/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/10/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/10/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/10/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/10/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/10/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/10/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/10/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/10/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/10/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/10/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/10/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/10/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/10/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/10/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/10/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/10/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/10/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/10/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/10/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:09 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit Unit CT2	> Limit Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/11/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/11/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/11/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/11/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/11/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/11/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/11/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/11/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/11/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/11/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/11/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/11/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/11/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/11/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/11/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/11/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/11/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/11/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/11/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/11/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/11/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/11/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/11/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/11/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:09 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	Unit CT2	Unit CT2	UnitOn, TF	NormalOp, TF	DBOn, TF
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/12/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/12/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/12/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/12/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/12/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/12/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/12/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/12/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/12/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/12/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/12/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/12/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/12/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/12/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/12/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/12/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/12/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/12/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/12/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/12/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/12/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/12/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/12/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/12/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:09 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/13/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/13/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/13/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/13/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/13/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/13/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/13/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/13/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/13/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/13/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/13/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/13/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/13/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/13/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/13/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/13/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/13/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/13/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/13/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/13/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/13/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/13/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/13/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/13/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:09 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit Unit CT2	> Limit Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/14/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/14/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/14/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/14/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/14/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/14/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/14/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/14/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/14/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/14/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/14/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/14/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/14/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/14/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/14/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/14/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/14/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/14/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/14/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/14/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/14/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/14/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/14/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/14/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:09 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/15/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/15/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/15/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/15/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/15/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/15/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/15/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/15/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/15/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/15/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/15/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/15/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/15/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/15/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/15/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/15/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/15/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/15/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/15/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/15/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/15/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/15/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/15/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/15/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:09 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/16/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/16/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/16/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/16/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/16/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/16/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/16/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/16/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/16/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/16/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/16/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/16/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/16/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/16/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/16/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/16/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/16/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/16/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/16/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/16/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/16/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/16/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/16/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/16/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:09 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/17/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/17/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/17/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/17/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/17/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/17/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/17/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/17/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/17/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/17/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/17/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/17/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/17/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/17/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/17/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/17/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/17/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/17/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/17/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/17/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/17/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/17/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/17/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/17/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:09 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/18/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/18/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/18/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/18/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/18/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/18/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/18/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/18/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/18/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/18/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/18/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/18/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/18/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/18/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/18/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/18/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/18/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/18/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/18/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/18/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/18/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/18/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/18/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/18/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:09 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit Unit CT2	> Limit Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/19/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/19/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/19/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/19/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/19/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/19/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/19/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/19/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/19/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/19/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/19/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/19/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/19/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/19/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/19/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/19/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/19/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/19/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/19/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/19/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/19/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/19/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/19/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/19/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:09 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/20/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/20/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/20/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/20/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/20/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/20/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/20/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/20/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/20/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/20/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/20/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/20/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/20/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/20/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/20/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/20/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/20/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/20/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/20/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/20/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/20/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/20/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/20/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/20/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:09 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/21/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:09 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/22/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:09 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/23/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:09 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/24/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:09 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/25/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:09 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/26/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:09 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/27/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:09 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/28/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:09 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit Unit CT2	> Limit Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/29/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:09 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit Unit CT2	> Limit Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/30/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:09 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	> Limit	> Limit	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/31/2022 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2022 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2022 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2022 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2022 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2022 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2022 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2022 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2022 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2022 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2022 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2022 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2022 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2022 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2022 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2022 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2022 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2022 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2022 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2022 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2022 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2022 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2022 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2022 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Excess Emission Report



CT1 - CO Lb 1-Day Block Average

From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:10 Location: Maxwell, CA

Tag Name: CT1_CO_Lb_1D
Total Operating Time: 960.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 1,200.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	960.00 Hour(s)
Total Duration (Online only):	0.00 Day(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report

CT2 - CO Lb 1-Day Block Average



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:11 Location: Maxwell, CA

Tag Name: CT2_CO_Lb_1D
Total Operating Time: 848.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 1,312.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	848.00 Hour(s)
Total Duration (Online only):	0.00 Day(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

ATTACHMENT 8
Hourly Emissions NH3

FCD:	AQ-18
Title V:	#6

Daily Summary Report

CT1 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm	Unit CT1 O2Dry, Inlet, Pct	Unit CT1 NOx, Inlet, Ppmvdc	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 HI, MBtuPerHr	Unit CT1 NH3, Slip, Ppmvdc	Unit CT1 NH3Slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/01/2022 00:00	9.9	13.5	7.9	163.6	3,481,717.0	1,957.7	1.6	1.2
01/01/2022 01:00	10.5	13.7	8.6	141.2	3,134,245.9	1,625.0	1.5	1.0
01/01/2022 02:00	10.7	13.7	8.8	141.0	3,034,721.6	1,573.4	1.6	0.9
01/01/2022 03:00	9.8	13.7	8.0	152.4	3,444,391.6	1,785.8	1.5	1.1
01/01/2022 04:00	9.3	13.6	7.5	146.2	3,503,690.8	1,893.3	1.4	0.9
01/01/2022 05:00	9.6	13.5	7.7	149.9	3,444,558.8	1,886.5	1.5	1.1
01/01/2022 06:00	9.7	13.7	7.9	152.3	3,554,138.5	1,842.7	1.5	1.1
01/01/2022 07:00	9.7	13.4	7.6	151.6	3,546,984.7	2,020.3	1.5	1.2
01/01/2022 08:00	10.1	13.6	8.2	143.8	3,162,074.9	1,708.7	1.5	1.0
01/01/2022 09:00	10.9	13.8	9.1	120.0	2,701,483.0	1,380.9	1.5	0.8
01/01/2022 10:00	10.9	13.8	9.1	119.8	2,706,373.8	1,383.4	1.5	0.8
01/01/2022 11:00	10.9	13.8	9.1	121.7	2,705,200.1	1,382.8	1.5	0.8
01/01/2022 12:00	10.9	13.8	9.1	119.9	2,706,765.1	1,383.6	1.5	0.8
01/01/2022 13:00	10.9	13.8	9.1	119.4	2,698,939.8	1,379.6	1.5	0.8
01/01/2022 14:00	10.9	13.8	9.1	118.1	2,699,526.7	1,379.9	1.5	0.8
01/01/2022 15:00	10.9	13.8	9.1	120.6	2,684,854.3	1,372.4	1.5	0.8
01/01/2022 16:00	10.2	13.7	8.4	143.5	3,107,629.0	1,611.2	1.6	1.0
01/01/2022 17:00	10.3	13.8	8.6	129.8	3,068,667.9	1,591.0	1.4	0.8
01/01/2022 18:00	9.4	13.7	7.7	143.4	3,481,231.1	1,804.9	1.4	0.9
01/01/2022 19:00	9.2	13.7	7.5	136.8	3,549,702.3	1,840.4	1.3	0.9
01/01/2022 20:00	10.0	13.3	7.8	168.0	3,511,996.1	2,128.6	1.6	1.3
01/01/2022 21:00	9.9	13.2	7.6	178.8	3,501,698.7	2,173.5	1.8	1.5
01/01/2022 22:00	9.9	13.2	7.6	181.1	3,510,454.2	2,153.3	1.8	1.5
01/01/2022 23:00	9.8	13.2	7.5	175.5	3,556,328.3	2,129.5	1.7	1.5
Average/Sum#:	10.2	13.6	8.3	143.3	3,187,390.6	1,724.5	1.5	1.0
Minimum:	9.2	13.2	7.5	118.1	2,684,854.3	1,372.4	1.3	0.8
Maximum:	10.9	13.8	9.1	181.1	3,556,328.3	2,173.5	1.8	1.5
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm	Unit CT1 O2Dry, Inlet, Pct	Unit CT1 NOx, Inlet, Ppmvdc	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 HI, MBtuPerHr	Unit CT1 NH3, Slip, Ppmvdc	Unit CT1 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/02/2022 00:00	9.6	13.5	7.7	163.0	3,480,971.4	1,982.7	1.6	1.2
01/02/2022 01:00	10.5	13.7	8.6	130.8	2,992,674.5	1,551.6	1.5	0.9
01/02/2022 02:00	10.8	13.8	9.0	118.8	2,754,086.0	1,427.9	1.4	0.7
01/02/2022 03:00	10.3	13.7	8.4	166.7	3,396,365.3	1,760.9	1.7	1.2
01/02/2022 04:00	10.0	13.6	8.1	161.4	3,491,477.0	1,886.7	1.6	1.1
01/02/2022 05:00	10.2	13.5	8.1	192.4	3,513,313.8	1,898.5	1.9	1.3
01/02/2022 06:00	10.3	13.7	8.4	159.4	3,516,334.6	1,823.1	1.5	1.1
01/02/2022 07:00	9.7	13.4	7.6	151.8	3,549,267.1	2,021.6	1.5	1.2
01/02/2022 08:00	10.1	13.6	8.2	146.1	3,161,704.8	1,708.5	1.6	1.0
01/02/2022 09:00	10.8	13.8	9.0	124.7	2,746,949.6	1,424.2	1.5	0.9
01/02/2022 10:00	10.9	13.8	9.1	123.7	2,752,347.4	1,406.9	1.5	0.8
01/02/2022 11:00	11.0	13.8	9.1	117.7	2,677,420.3	1,368.6	1.5	0.8
01/02/2022 12:00	11.0	13.8	9.1	118.1	2,675,268.4	1,367.5	1.5	0.8
01/02/2022 13:00	11.0	13.8	9.1	120.9	2,674,681.5	1,367.2	1.5	0.8
01/02/2022 14:00	11.0	13.8	9.1	119.6	2,674,094.6	1,366.9	1.5	0.8
01/02/2022 15:00	11.0	13.8	9.1	117.4	2,698,157.3	1,379.2	1.5	0.8
01/02/2022 16:00	10.2	13.7	8.4	146.1	3,227,598.3	1,673.4	1.5	1.0
01/02/2022 17:00	10.7	13.7	8.8	141.3	3,070,403.8	1,591.9	1.6	1.0
01/02/2022 18:00	9.9	13.7	8.1	159.2	3,436,114.0	1,806.6	1.6	1.1
01/02/2022 19:00	10.2	13.3	7.9	167.8	3,475,665.9	2,081.2	1.7	1.5
01/02/2022 20:00	10.3	13.1	7.8	189.7	3,450,638.2	2,217.4	1.9	1.6
01/02/2022 21:00	10.1	13.2	7.7	178.3	3,455,514.2	2,119.6	1.8	1.5
01/02/2022 22:00	9.9	13.2	7.6	170.9	3,485,102.6	2,112.3	1.7	1.5
01/02/2022 23:00	9.7	13.4	7.6	168.8	3,497,925.9	2,017.9	1.7	1.4
Average/Sum#:	10.4	13.6	8.4	148.1	3,160,586.5	1,723.4	1.6	1.1
Minimum:	9.6	13.1	7.6	117.4	2,674,094.6	1,366.9	1.4	0.7
Maximum:	11.0	13.8	9.1	192.4	3,549,267.1	2,217.4	1.9	1.6
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm	Unit CT1 O2Dry, Inlet, Pct	Unit CT1 NOx, Inlet, Ppmvdc	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 HI, MBtuPerHr	Unit CT1 NH3, Slip, Ppmvdc	Unit CT1 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/03/2022 00:00	9.6	13.5	7.7	152.0	3,455,395.6	1,942.9	1.5	1.2
01/03/2022 01:00	10.4	13.7	8.5	150.8	3,202,910.0	1,660.6	1.6	1.0
01/03/2022 02:00	10.3	13.7	8.4	149.5	3,204,262.9	1,684.7	1.6	1.0
01/03/2022 03:00	9.8	13.3	7.6	153.5	3,491,858.8	2,014.4	1.5	1.2
01/03/2022 04:00	9.8	13.3	7.6	157.0	3,522,054.2	2,006.1	1.5	1.2
01/03/2022 05:00	10.0	13.2	7.7	167.2	3,479,507.0	2,083.5	1.7	1.5
01/03/2022 06:00	10.7	13.0	8.0	199.1	3,471,947.3	2,281.8	2.0	1.8
01/03/2022 07:00	10.0	13.2	7.7	178.7	3,445,895.6	2,113.7	1.8	1.5
01/03/2022 08:00	9.7	13.3	7.5	156.3	3,492,205.5	2,014.6	1.5	1.2
01/03/2022 09:00	9.6	13.5	7.7	156.5	3,485,274.0	1,959.7	1.5	1.2
01/03/2022 10:00	10.2	13.7	8.4	157.0	3,305,134.7	1,713.6	1.6	1.0
01/03/2022 11:00	10.8	13.8	9.0	119.1	2,774,723.8	1,438.6	1.4	0.7
01/03/2022 12:00	9.9	13.7	8.1	155.9	3,381,706.7	1,753.3	1.6	1.1
01/03/2022 13:00	9.7	13.5	7.7	144.1	3,375,811.3	1,873.5	1.5	1.1
01/03/2022 14:00	9.9	13.4	7.8	159.3	3,326,296.7	1,894.6	1.6	1.1
01/03/2022 15:00	10.1	13.7	8.3	138.2	3,185,744.0	1,651.7	1.5	1.0
01/03/2022 16:00	10.1	13.4	7.9	155.8	3,396,528.2	1,909.8	1.6	1.1
01/03/2022 17:00	10.4	13.1	7.9	176.6	3,382,796.7	2,124.4	1.8	1.5
01/03/2022 18:00	10.4	13.1	7.9	185.6	3,361,314.4	2,160.0	1.9	1.5
01/03/2022 19:00	10.4	13.1	7.9	195.1	3,356,307.0	2,205.8	2.0	1.8
01/03/2022 20:00	10.2	13.2	7.8	172.4	3,372,328.4	2,093.2	1.8	1.5
01/03/2022 21:00	10.0	13.3	7.8	168.0	3,383,138.2	2,050.5	1.7	1.4
01/03/2022 22:00	9.8	13.4	7.7	155.8	3,407,613.2	1,965.8	1.6	1.2
01/03/2022 23:00	10.2	13.2	7.8	168.8	3,420,220.9	2,048.0	1.7	1.4
Average/Sum#:	10.1	13.4	7.9	161.3	3,361,707.3	1,943.5	1.6	1.3
Minimum:	9.6	13.0	7.5	119.1	2,774,723.8	1,438.6	1.4	0.7
Maximum:	10.8	13.8	9.0	199.1	3,522,054.2	2,281.8	2.0	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm	Unit CT1 O2Dry, Inlet, Pct	Unit CT1 NOx, Inlet, Ppmvdc	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 HI, MBtuPerHr	Unit CT1 NH3, Slip, Ppmvdc	Unit CT1 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/04/2022 00:00	10.1	13.3	7.8	173.6	3,352,119.9	2,031.7	1.8	1.4
01/04/2022 01:00	10.6	13.7	8.7	128.4	3,013,119.4	1,562.2	1.4	0.8
01/04/2022 02:00	10.3	13.6	8.3	144.0	3,188,476.4	1,676.4	1.5	1.0
01/04/2022 03:00	10.1	13.4	7.9	157.3	3,403,019.6	1,938.3	1.6	1.2
01/04/2022 04:00	9.8	13.4	7.7	153.3	3,383,171.6	1,951.7	1.6	1.2
01/04/2022 05:00	10.5	13.7	8.6	149.0	3,223,740.7	1,671.4	1.6	1.0
01/04/2022 06:00	10.1	13.6	8.2	149.5	3,401,307.8	1,788.3	1.5	1.1
01/04/2022 07:00	10.4	13.3	8.1	163.0	3,416,029.1	1,995.6	1.6	1.2
01/04/2022 08:00	10.3	13.3	8.0	162.7	3,425,251.6	2,026.0	1.6	1.2
01/04/2022 09:00	10.0	13.5	8.0	168.3	3,473,536.1	1,953.1	1.7	1.4
01/04/2022 10:00	10.9	13.7	8.9	127.9	2,763,194.1	1,452.8	1.6	0.9
01/04/2022 11:00	10.8	13.8	9.0	112.8	2,598,434.5	1,347.2	1.5	0.8
01/04/2022 12:00	10.4	13.7	8.5	163.8	3,330,980.2	1,727.0	1.7	1.2
01/04/2022 13:00	9.9	13.5	7.9	149.0	3,380,812.7	1,826.9	1.5	1.1
01/04/2022 14:00	10.2	13.5	8.1	160.1	3,284,636.5	1,822.9	1.7	1.3
01/04/2022 15:00	10.3	13.7	8.4	132.5	3,062,302.9	1,587.7	1.5	1.0
01/04/2022 16:00	10.3	13.3	8.0	161.5	3,400,737.2	2,011.5	1.6	1.2
01/04/2022 17:00	10.5	13.1	7.9	182.6	3,392,709.6	2,155.4	1.9	1.5
01/04/2022 18:00	10.4	13.1	7.9	188.6	3,389,947.8	2,178.4	1.9	1.5
01/04/2022 19:00	10.3	13.1	7.8	185.0	3,400,737.2	2,160.5	1.9	1.5
01/04/2022 20:00	10.1	13.2	7.7	174.0	3,379,094.9	2,097.4	1.8	1.5
01/04/2022 21:00	10.2	13.2	7.8	169.3	3,404,587.0	2,063.5	1.7	1.4
01/04/2022 22:00	10.0	13.3	7.8	172.0	3,429,647.3	2,028.6	1.7	1.4
01/04/2022 23:00	10.0	13.2	7.7	165.0	3,421,556.9	2,048.8	1.7	1.4
Average/Sum#:	10.3	13.4	8.1	158.1	3,288,298.0	1,879.3	1.7	1.2
Minimum:	9.8	13.1	7.7	112.8	2,598,434.5	1,347.2	1.4	0.8
Maximum:	10.9	13.8	9.0	188.6	3,473,536.1	2,178.4	1.9	1.5
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm	Unit CT1 O2Dry, Inlet, Pct	Unit CT1 NOx, Inlet, Ppmvdc	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 HI, MBtuPerHr	Unit CT1 NH3, Slip, Ppmvdc	Unit CT1 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/05/2022 00:00	9.7	13.5	7.7	159.4	3,305,898.6	1,834.7	1.7	1.3
01/05/2022 01:00	10.8	13.8	9.0	108.5	2,536,135.4	1,314.9	1.4	0.7
01/05/2022 02:00	10.8	13.8	9.0	116.2	2,596,120.0	1,346.0	1.5	0.8
01/05/2022 03:00	10.1	13.7	8.3	164.8	3,354,709.3	1,763.8	1.7	1.2
01/05/2022 04:00	9.7	13.6	7.8	153.4	3,421,552.5	1,873.9	1.5	1.1
01/05/2022 05:00	9.9	13.5	7.9	173.7	3,386,746.6	1,904.3	1.8	1.3
01/05/2022 06:00	10.7	13.7	8.8	159.5	3,210,539.4	1,688.0	1.7	1.2
01/05/2022 07:00	10.4	13.2	8.0	165.3	3,433,873.9	2,031.1	1.7	1.4
01/05/2022 08:00	10.1	13.2	7.7	168.4	3,462,418.4	2,022.7	1.7	1.4
01/05/2022 09:00	10.0	13.3	7.8	171.4	3,431,948.7	2,004.9	1.7	1.4
01/05/2022 10:00	10.6	13.8	8.8	123.2	2,866,340.2	1,486.1	1.4	0.7
01/05/2022 11:00	10.9	13.7	8.9	152.2	2,962,200.0	1,535.8	1.8	1.1
01/05/2022 12:00	10.6	13.7	8.7	167.1	3,310,963.8	1,740.8	1.7	1.2
01/05/2022 13:00	10.2	13.5	8.1	165.5	3,391,242.5	1,857.3	1.7	1.3
01/05/2022 14:00	10.1	13.5	8.1	170.3	3,337,791.7	1,852.4	1.8	1.3
01/05/2022 15:00	10.4	13.7	8.5	155.5	3,190,758.8	1,654.3	1.7	1.2
01/05/2022 16:00	10.3	13.3	8.0	161.5	3,437,086.1	2,033.0	1.6	1.2
01/05/2022 17:00	10.3	13.2	7.9	176.3	3,421,441.6	2,098.7	1.8	1.5
01/05/2022 18:00	10.3	13.1	7.8	185.9	3,406,089.0	2,163.9	1.9	1.5
01/05/2022 19:00	10.3	13.1	7.8	187.1	3,402,783.5	2,161.8	1.9	1.5
01/05/2022 20:00	10.2	13.1	7.7	186.4	3,407,977.9	2,165.1	1.9	1.5
01/05/2022 21:00	10.2	13.1	7.7	183.8	3,389,404.1	2,153.3	1.9	1.5
01/05/2022 22:00	9.6	13.4	7.6	159.4	3,417,320.5	1,971.4	1.6	1.2
01/05/2022 23:00	10.2	13.2	7.8	174.2	3,398,482.3	2,059.8	1.8	1.4
Average/Sum#:	10.3	13.4	8.1	162.0	3,269,992.7	1,863.3	1.7	1.2
Minimum:	9.6	13.1	7.6	108.5	2,536,135.4	1,314.9	1.4	0.7
Maximum:	10.9	13.8	9.0	187.1	3,462,418.4	2,165.1	1.9	1.5
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm	Unit CT1 O2Dry, Inlet, Pct	Unit CT1 NOx, Inlet, Ppmvdc	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 HI, MBtuPerHr	Unit CT1 NH3, Slip, Ppmvdc	Unit CT1 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/06/2022 00:00	10.0	13.5	8.0	161.8	3,319,953.2	1,842.5	1.7	1.3
01/06/2022 01:00	10.8	13.8	9.0	110.4	2,569,503.0	1,332.2	1.4	0.7
01/06/2022 02:00	10.7	13.8	8.9	112.4	2,534,785.2	1,314.2	1.5	0.8
01/06/2022 03:00	10.3	13.7	8.4	144.1	3,006,754.5	1,558.9	1.6	0.9
01/06/2022 04:00	9.4	13.5	7.5	146.7	3,423,926.1	1,875.2	1.5	1.1
01/06/2022 05:00	9.8	13.4	7.7	180.1	3,410,597.1	1,867.9	1.8	1.3
01/06/2022 06:00	10.3	13.7	8.4	156.8	3,368,974.2	1,771.3	1.6	1.1
01/06/2022 07:00	10.0	13.3	7.8	156.0	3,496,019.1	2,016.8	1.5	1.2
01/06/2022 08:00	10.0	13.2	7.7	169.4	3,460,755.2	2,047.0	1.7	1.4
01/06/2022 09:00	9.8	13.4	7.7	160.3	3,430,232.5	1,953.8	1.6	1.2
01/06/2022 10:00	10.6	13.7	8.7	132.5	2,929,796.7	1,519.0	1.5	0.9
01/06/2022 11:00	10.6	13.7	8.7	140.2	3,053,237.7	1,583.0	1.6	0.9
01/06/2022 12:00	11.0	13.7	9.0	124.4	2,790,539.7	1,446.8	1.5	0.9
01/06/2022 13:00	11.1	13.8	9.2	113.3	2,580,689.9	1,338.0	1.5	0.8
01/06/2022 14:00	10.6	13.7	8.7	149.8	3,083,677.4	1,621.3	1.7	1.1
01/06/2022 15:00	10.7	13.8	8.9	126.6	2,787,067.9	1,445.0	1.5	0.9
01/06/2022 16:00	10.7	13.7	8.8	148.2	3,095,469.7	1,627.5	1.6	1.0
01/06/2022 17:00	9.9	13.6	8.0	148.5	3,313,626.6	1,742.2	1.5	1.0
01/06/2022 18:00	10.2	13.2	7.8	161.3	3,406,359.7	2,039.7	1.6	1.2
01/06/2022 19:00	10.2	13.2	7.8	176.4	3,373,939.5	2,094.2	1.8	1.5
01/06/2022 20:00	9.7	13.4	7.6	157.1	3,357,828.6	1,961.6	1.6	1.2
01/06/2022 21:00	10.2	13.7	8.4	152.1	3,183,531.3	1,673.8	1.6	1.0
01/06/2022 22:00	9.8	13.6	7.9	148.6	3,366,882.0	1,770.2	1.5	1.1
01/06/2022 23:00	10.1	13.2	7.7	160.4	3,382,140.1	2,000.5	1.6	1.2
Average/Sum#:	10.3	13.6	8.3	147.4	3,155,262.0	1,726.8	1.6	1.1
Minimum:	9.4	13.2	7.5	110.4	2,534,785.2	1,314.2	1.4	0.7
Maximum:	11.1	13.8	9.2	180.1	3,496,019.1	2,094.2	1.8	1.5
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm	Unit CT1 O2Dry, Inlet, Pct	Unit CT1 NOx, Inlet, Ppmvdc	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 HI, MBtuPerHr	Unit CT1 NH3, Slip, Ppmvdc	Unit CT1 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/07/2022 00:00	9.7	13.5	7.7	144.3	3,296,348.6	1,829.4	1.5	1.1
01/07/2022 01:00	10.9	13.8	9.1	120.4	2,515,304.7	1,304.1	1.6	0.8
01/07/2022 02:00	10.2	13.6	8.2	171.5	3,098,893.3	1,629.3	1.9	1.1
01/07/2022 03:00	9.7	13.4	7.6	188.8	3,424,263.2	1,950.4	1.9	1.4
01/07/2022 04:00	9.7	13.4	7.6	188.3	3,388,798.6	1,930.2	1.9	1.4
01/07/2022 05:00	10.3	13.7	8.4	163.4	3,203,311.9	1,684.2	1.7	1.2
01/07/2022 06:00	10.7	13.6	8.6	133.9	3,037,649.6	1,597.1	1.5	1.0
01/07/2022 07:00	10.3	13.3	8.0	158.4	3,385,690.5	2,002.6	1.6	1.2
01/07/2022 08:00	9.8	13.4	7.7	155.0	3,367,743.9	1,942.8	1.6	1.2
01/07/2022 09:00	10.5	13.7	8.6	134.9	3,051,694.7	1,582.2	1.5	0.9
01/07/2022 10:00	10.8	13.7	8.9	136.0	2,967,793.4	1,538.7	1.5	0.9
01/07/2022 11:00	10.6	13.7	8.7	139.0	3,013,312.3	1,562.3	1.6	0.9
01/07/2022 12:00	10.7	13.7	8.8	140.2	2,987,659.7	1,549.0	1.6	0.9
01/07/2022 13:00	10.6	13.7	8.7	130.8	2,922,467.4	1,515.2	1.5	0.9
01/07/2022 14:00	10.6	13.7	8.7	130.2	2,888,521.1	1,497.6	1.5	0.9
01/07/2022 15:00	10.5	13.7	8.6	136.6	2,969,722.1	1,539.7	1.6	0.9
01/07/2022 16:00	10.5	13.7	8.6	136.7	2,977,437.2	1,543.7	1.6	0.9
01/07/2022 17:00	10.8	13.7	8.9	152.2	3,168,770.9	1,642.9	1.6	1.0
01/07/2022 18:00	10.0	13.4	7.9	154.1	3,362,477.4	1,866.1	1.6	1.1
01/07/2022 19:00	10.0	13.5	8.0	162.5	3,316,169.3	1,840.4	1.7	1.3
01/07/2022 20:00	10.4	13.7	8.5	135.0	3,019,771.0	1,587.7	1.5	1.0
01/07/2022 21:00	10.1	13.3	7.8	157.8	3,463,603.6	1,998.1	1.6	1.2
01/07/2022 22:00	16.1	14.7	15.3	161.8	2,560,191.6	1,215.2	2.1	1.0
01/07/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	10.6	13.6	8.6	149.2	3,103,808.5	1,667.3	1.6	1.1
Minimum:	9.7	13.3	7.6	120.4	2,515,304.7	1,215.2	1.5	0.8
Maximum:	16.1	14.7	15.3	188.8	3,463,603.6	2,002.6	2.1	1.4
%SI	4.17	4.17	4.17	4.17	4.17	4.17	4.17	4.17

Daily Summary Report

CT1 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm	Unit CT1 O2Dry, Inlet, Pct	Unit CT1 NOx, Inlet, Ppmvdc	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 HI, MBtuPerHr	Unit CT1 NH3, Slip, Ppmvdc	Unit CT1 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/08/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/08/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/08/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/08/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/08/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/08/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/08/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/08/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/08/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/08/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/08/2022 10:00	35.8	17.6	64.0	0.0	1,468,022.9	321.6	0.0	0.0
01/08/2022 11:00	40.1	17.2	63.9	238.5	1,437,525.5	388.4	5.2	0.8
01/08/2022 12:00	34.0	15.6	37.8	246.6	2,143,149.2	813.8	3.7	1.1
01/08/2022 13:00	10.9	13.8	9.1	122.9	2,747,065.3	1,404.2	1.5	0.8
01/08/2022 14:00	11.2	13.8	9.3	122.5	2,687,984.4	1,374.0	1.5	0.8
01/08/2022 15:00	9.7	13.7	7.9	138.4	3,334,837.7	1,729.0	1.4	0.9
01/08/2022 16:00	10.8	13.7	8.9	143.1	2,997,689.3	1,554.2	1.6	0.9
01/08/2022 17:00	10.6	13.7	8.7	143.0	3,154,112.2	1,635.3	1.5	1.0
01/08/2022 18:00	9.7	13.6	7.8	149.6	3,405,492.2	1,790.5	1.5	1.1
01/08/2022 19:00	10.2	13.3	7.9	165.2	3,467,517.8	2,051.0	1.6	1.2
01/08/2022 20:00	10.0	13.3	7.8	166.8	3,389,407.8	2,054.3	1.7	1.4
01/08/2022 21:00	9.8	13.7	8.0	147.3	3,318,057.4	1,720.3	1.5	1.0
01/08/2022 22:00	9.4	13.7	7.7	137.0	3,471,394.4	1,799.8	1.3	0.9
01/08/2022 23:00	10.1	13.3	7.8	162.3	3,441,820.0	2,035.8	1.6	1.2
Average/Sum#:	15.9	14.3	18.3	148.8	2,890,291.2	1,476.6	1.8	0.9
Minimum:	9.4	13.3	7.7	0.0	1,437,525.5	321.6	0.0	0.0
Maximum:	40.1	17.6	64.0	246.6	3,471,394.4	2,054.3	5.2	1.4
%SI	41.67	41.67	41.67	41.67	41.67	41.67	41.67	41.67

Daily Summary Report

CT1 - NH3 Slip



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm	Unit CT1 O2Dry, Inlet, Pct	Unit CT1 NOx, Inlet, Ppmvdc	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 HI, MBtuPerHr	Unit CT1 NH3, Slip, Ppmvdc	Unit CT1 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/09/2022 00:00	9.7	13.4	7.6	154.0	3,452,529.6	1,966.5	1.5	1.2
01/09/2022 01:00	10.6	13.7	8.7	129.1	2,963,550.1	1,536.5	1.5	0.9
01/09/2022 02:00	10.2	13.7	8.4	134.3	3,090,655.8	1,602.4	1.5	1.0
01/09/2022 03:00	9.3	13.5	7.4	144.5	3,502,703.0	1,969.5	1.4	1.0
01/09/2022 04:00	9.2	13.5	7.3	149.4	3,473,536.1	1,953.1	1.5	1.2
01/09/2022 05:00	10.3	13.7	8.4	145.5	3,216,990.0	1,667.9	1.5	1.0
01/09/2022 06:00	10.5	13.7	8.6	145.8	3,205,023.7	1,685.1	1.5	1.0
01/09/2022 07:00	10.1	13.3	7.8	158.7	3,544,382.3	2,044.7	1.5	1.2
01/09/2022 08:00	9.9	13.4	7.8	164.2	3,491,329.9	1,988.6	1.6	1.2
01/09/2022 09:00	10.3	13.7	8.4	133.1	3,075,418.6	1,594.5	1.5	1.0
01/09/2022 10:00	10.7	13.7	8.8	133.7	2,960,271.2	1,534.8	1.5	0.9
01/09/2022 11:00	10.7	13.7	8.8	144.7	3,120,744.6	1,618.0	1.6	1.0
01/09/2022 12:00	11.0	13.7	9.0	124.3	2,831,815.3	1,468.2	1.5	0.9
01/09/2022 13:00	10.8	13.7	8.9	128.5	2,934,232.8	1,521.3	1.5	0.9
01/09/2022 14:00	10.2	13.7	8.4	145.1	3,187,672.8	1,652.7	1.5	1.0
01/09/2022 15:00	10.3	13.7	8.4	151.4	3,235,120.4	1,677.3	1.6	1.0
01/09/2022 16:00	10.0	13.7	8.2	131.6	3,152,955.0	1,634.7	1.4	0.8
01/09/2022 17:00	9.9	13.4	7.8	160.7	3,448,869.3	1,989.6	1.6	1.2
01/09/2022 18:00	10.1	13.3	7.8	166.5	3,462,305.6	2,073.2	1.7	1.5
01/09/2022 19:00	9.5	13.5	7.6	151.9	3,451,651.7	1,966.0	1.5	1.2
01/09/2022 20:00	9.9	13.3	7.7	165.9	3,446,498.8	2,013.4	1.7	1.4
01/09/2022 21:00	9.7	13.4	7.6	162.1	3,467,243.9	2,000.2	1.6	1.2
01/09/2022 22:00	10.1	13.3	7.8	165.7	3,439,927.3	2,059.8	1.7	1.4
01/09/2022 23:00	9.9	13.5	7.9	168.7	3,495,233.4	1,965.3	1.7	1.4
Average/Sum#:	10.1	13.6	8.1	148.3	3,277,110.9	1,799.3	1.5	1.1
Minimum:	9.2	13.3	7.3	124.3	2,831,815.3	1,468.2	1.4	0.8
Maximum:	11.0	13.7	9.0	168.7	3,544,382.3	2,073.2	1.7	1.5
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm	Unit CT1 O2Dry, Inlet, Pct	Unit CT1 NOx, Inlet, Ppmvdc	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 HI, MBtuPerHr	Unit CT1 NH3, Slip, Ppmvdc	Unit CT1 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/10/2022 00:00	9.9	13.6	8.0	164.7	3,364,279.3	1,867.1	1.7	1.3
01/10/2022 01:00	10.7	13.8	8.9	120.4	2,772,497.5	1,417.2	1.5	0.9
01/10/2022 02:00	10.8	13.8	9.0	118.6	2,707,938.9	1,384.2	1.5	0.8
01/10/2022 03:00	10.8	13.8	9.0	122.0	2,750,228.5	1,425.9	1.5	0.9
01/10/2022 04:00	10.8	13.7	8.9	132.0	2,900,093.7	1,503.6	1.5	0.9
01/10/2022 05:00	10.8	13.7	8.9	138.6	2,951,591.7	1,530.3	1.6	0.9
01/10/2022 06:00	9.8	13.7	8.0	150.1	3,447,091.9	1,787.2	1.5	1.1
01/10/2022 07:00	10.6	13.7	8.7	139.2	3,094,320.5	1,604.3	1.5	1.0
01/10/2022 08:00	10.0	13.7	8.2	134.8	3,227,598.3	1,673.4	1.4	0.8
01/10/2022 09:00	10.7	13.7	8.8	141.4	3,092,198.8	1,603.2	1.5	1.0
01/10/2022 10:00	10.2	13.7	8.4	135.4	3,178,993.3	1,648.2	1.4	0.8
01/10/2022 11:00	10.2	13.3	7.9	163.1	3,500,986.1	1,994.1	1.6	1.2
01/10/2022 12:00	9.6	13.4	7.6	150.9	3,440,990.0	1,934.8	1.5	1.2
01/10/2022 13:00	10.2	13.8	8.5	126.4	3,035,231.3	1,551.5	1.4	0.8
01/10/2022 14:00	9.9	13.7	8.1	138.4	3,194,230.6	1,656.1	1.5	1.0
01/10/2022 15:00	10.2	13.3	7.9	160.0	3,428,525.1	2,002.9	1.6	1.2
01/10/2022 16:00	10.2	13.3	7.9	173.1	3,436,595.2	2,082.9	1.7	1.5
01/10/2022 17:00	10.2	13.2	7.8	180.8	3,398,242.5	2,134.1	1.8	1.5
01/10/2022 18:00	10.2	13.2	7.8	189.6	3,403,570.5	2,162.3	1.9	1.5
01/10/2022 19:00	10.2	13.2	7.8	188.1	3,395,542.9	2,157.2	1.9	1.5
01/10/2022 20:00	10.2	13.2	7.8	193.0	3,404,829.8	2,163.1	2.0	1.7
01/10/2022 21:00	10.1	13.2	7.7	186.8	3,419,261.6	2,147.3	1.9	1.5
01/10/2022 22:00	9.9	13.3	7.7	169.6	3,429,309.2	2,028.4	1.7	1.4
01/10/2022 23:00	9.9	13.3	7.7	163.2	3,479,551.3	2,007.3	1.6	1.2
Average/Sum#:	10.3	13.5	8.2	153.3	3,227,237.4	1,811.1	1.6	1.2
Minimum:	9.6	13.2	7.6	118.6	2,707,938.9	1,384.2	1.4	0.8
Maximum:	10.8	13.8	9.0	193.0	3,500,986.1	2,163.1	2.0	1.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm	Unit CT1 O2Dry, Inlet, Pct	Unit CT1 NOx, Inlet, Ppmvdc	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 HI, MBtuPerHr	Unit CT1 NH3, Slip, Ppmvdc	Unit CT1 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/11/2022 00:00	9.5	13.5	7.6	155.3	3,333,647.4	1,850.1	1.6	1.1
01/11/2022 01:00	10.7	13.9	9.0	107.1	2,570,213.9	1,313.8	1.4	0.7
01/11/2022 02:00	9.9	13.8	8.2	130.4	3,073,875.6	1,593.7	1.4	0.8
01/11/2022 03:00	9.4	13.5	7.5	149.3	3,496,834.1	1,966.2	1.5	1.2
01/11/2022 04:00	9.2	13.5	7.3	147.2	3,467,844.9	1,949.9	1.5	1.2
01/11/2022 05:00	10.1	13.7	8.3	135.5	3,143,118.3	1,629.6	1.5	1.0
01/11/2022 06:00	10.2	13.8	8.5	131.5	3,102,807.1	1,608.7	1.4	0.8
01/11/2022 07:00	9.8	13.4	7.7	156.4	3,471,924.2	2,002.9	1.5	1.2
01/11/2022 08:00	9.6	13.6	7.8	149.2	3,328,241.8	1,847.1	1.5	1.1
01/11/2022 09:00	10.8	13.8	9.0	110.5	2,594,472.3	1,326.2	1.4	0.7
01/11/2022 10:00	10.7	13.9	9.0	114.4	2,583,321.3	1,320.5	1.5	0.8
01/11/2022 11:00	10.8	13.8	9.0	121.5	2,704,613.2	1,382.5	1.5	0.8
01/11/2022 12:00	10.8	13.8	9.0	118.4	2,673,703.3	1,366.7	1.5	0.8
01/11/2022 13:00	10.7	13.9	9.0	118.4	2,668,616.9	1,364.1	1.5	0.8
01/11/2022 14:00	10.6	13.9	8.9	112.1	2,581,365.0	1,319.5	1.5	0.8
01/11/2022 15:00	10.7	13.8	8.9	123.1	2,716,938.0	1,388.8	1.5	0.8
01/11/2022 16:00	10.6	13.7	8.7	150.6	3,159,898.5	1,638.3	1.6	1.0
01/11/2022 17:00	10.2	13.7	8.4	142.2	3,243,414.1	1,681.6	1.5	1.0
01/11/2022 18:00	10.2	13.3	7.9	167.7	3,452,162.9	1,991.5	1.7	1.4
01/11/2022 19:00	9.7	13.5	7.7	153.4	3,449,720.5	1,964.9	1.5	1.2
01/11/2022 20:00	9.6	13.5	7.7	151.7	3,433,217.2	1,955.5	1.5	1.2
01/11/2022 21:00	9.5	13.5	7.6	156.0	3,460,956.8	1,971.3	1.5	1.2
01/11/2022 22:00	9.9	13.3	7.7	168.8	3,462,931.9	2,023.0	1.7	1.4
01/11/2022 23:00	10.0	13.6	8.1	138.3	3,088,691.1	1,691.6	1.5	1.0
Average/Sum#:	10.1	13.7	8.3	137.9	3,094,272.1	1,672.8	1.5	1.0
Minimum:	9.2	13.3	7.3	107.1	2,570,213.9	1,313.8	1.4	0.7
Maximum:	10.8	13.9	9.0	168.8	3,496,834.1	2,023.0	1.7	1.4
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm	Unit CT1 O2Dry, Inlet, Pct	Unit CT1 NOx, Inlet, Ppmvdc	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 HI, MBtuPerHr	Unit CT1 NH3, Slip, Ppmvdc	Unit CT1 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/12/2022 00:00	10.8	13.8	9.0	120.4	2,658,804.9	1,378.5	1.5	0.8
01/12/2022 01:00	10.9	13.8	9.1	120.5	2,636,431.3	1,366.9	1.5	0.8
01/12/2022 02:00	10.9	13.8	9.1	119.5	2,630,837.8	1,364.0	1.5	0.8
01/12/2022 03:00	11.0	13.8	9.1	119.7	2,642,410.4	1,370.0	1.5	0.8
01/12/2022 04:00	11.0	13.8	9.1	121.2	2,643,374.8	1,370.5	1.5	0.8
01/12/2022 05:00	11.0	13.8	9.1	143.6	2,772,987.9	1,437.7	1.8	1.0
01/12/2022 06:00	9.9	13.5	7.9	166.3	3,494,344.2	1,964.8	1.6	1.2
01/12/2022 07:00	9.5	13.5	7.6	159.8	3,495,411.3	1,965.4	1.6	1.2
01/12/2022 08:00	9.4	13.5	7.5	154.5	3,492,743.6	1,963.9	1.5	1.2
01/12/2022 09:00	9.8	13.7	8.0	151.7	3,322,946.3	1,747.1	1.6	1.0
01/12/2022 10:00	10.6	13.7	8.7	144.2	3,084,869.5	1,599.4	1.6	1.0
01/12/2022 11:00	11.0	13.8	9.1	117.5	2,742,957.0	1,402.1	1.4	0.7
01/12/2022 12:00	10.9	13.7	8.9	142.6	2,979,366.0	1,544.7	1.6	0.9
01/12/2022 13:00	10.7	13.7	8.8	149.8	3,079,469.0	1,596.6	1.7	1.1
01/12/2022 14:00	10.7	13.7	8.8	140.7	3,049,380.2	1,581.0	1.6	0.9
01/12/2022 15:00	10.2	13.7	8.4	145.0	3,177,836.1	1,647.6	1.5	1.0
01/12/2022 16:00	10.4	13.3	8.1	162.7	3,420,517.8	2,023.2	1.6	1.2
01/12/2022 17:00	10.4	13.2	8.0	181.0	3,375,550.6	2,095.2	1.9	1.5
01/12/2022 18:00	10.3	13.2	7.9	180.3	3,415,806.4	2,070.3	1.8	1.4
01/12/2022 19:00	10.2	13.2	7.8	175.7	3,397,162.4	2,059.0	1.8	1.4
01/12/2022 20:00	9.7	13.4	7.6	158.7	3,419,574.0	1,972.7	1.6	1.2
01/12/2022 21:00	10.3	13.7	8.4	153.3	3,259,230.0	1,689.8	1.6	1.0
01/12/2022 22:00	9.4	13.7	7.7	146.6	3,486,053.0	1,807.4	1.4	0.9
01/12/2022 23:00	9.7	13.4	7.6	156.0	3,485,536.2	1,985.3	1.5	1.2
Average/Sum#:	10.4	13.6	8.4	147.1	3,131,816.7	1,708.5	1.6	1.0
Minimum:	9.4	13.2	7.5	117.5	2,630,837.8	1,364.0	1.4	0.7
Maximum:	11.0	13.8	9.1	181.0	3,495,411.3	2,095.2	1.9	1.5
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm	Unit CT1 O2Dry, Inlet, Pct	Unit CT1 NOx, Inlet, Ppmvdc	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 HI, MBtuPerHr	Unit CT1 NH3, Slip, Ppmvdc	Unit CT1 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/13/2022 00:00	9.5	13.6	7.7	151.8	3,367,688.4	1,844.4	1.5	1.1
01/13/2022 01:00	10.8	13.8	9.0	108.6	2,574,322.2	1,315.9	1.4	0.7
01/13/2022 02:00	10.1	13.7	8.3	137.3	3,087,376.9	1,600.7	1.5	1.0
01/13/2022 03:00	9.6	13.5	7.7	153.5	3,516,930.8	1,977.5	1.5	1.2
01/13/2022 04:00	9.5	13.5	7.6	155.0	3,482,250.6	1,958.0	1.5	1.2
01/13/2022 05:00	10.1	13.7	8.3	144.6	3,267,138.0	1,693.9	1.5	1.0
01/13/2022 06:00	10.3	13.7	8.4	130.0	3,156,619.6	1,636.6	1.4	0.8
01/13/2022 07:00	10.2	13.3	7.9	166.7	3,439,284.0	2,034.3	1.7	1.4
01/13/2022 08:00	9.6	13.5	7.7	160.0	3,421,805.3	1,949.0	1.6	1.2
01/13/2022 09:00	10.4	13.7	8.5	146.5	3,222,583.5	1,670.8	1.5	1.0
01/13/2022 10:00	10.9	13.8	9.1	119.5	2,714,932.1	1,407.6	1.5	0.8
01/13/2022 11:00	10.8	13.7	8.9	158.1	3,177,643.2	1,647.5	1.7	1.2
01/13/2022 12:00	9.9	13.5	7.9	156.9	3,419,361.4	1,872.7	1.6	1.1
01/13/2022 13:00	10.3	13.3	8.0	169.2	3,360,934.8	2,012.5	1.7	1.4
01/13/2022 14:00	10.4	13.7	8.5	135.8	3,015,048.2	1,563.2	1.5	0.9
01/13/2022 15:00	10.0	13.8	8.3	132.7	3,047,065.7	1,579.8	1.5	0.9
01/13/2022 16:00	10.1	13.3	7.8	164.3	3,403,949.5	2,013.4	1.7	1.4
01/13/2022 17:00	10.3	13.2	7.9	174.5	3,423,394.0	2,049.9	1.8	1.4
01/13/2022 18:00	10.2	13.2	7.8	178.6	3,400,248.1	2,085.7	1.8	1.5
01/13/2022 19:00	9.6	13.4	7.6	154.6	3,413,507.0	1,969.2	1.6	1.2
01/13/2022 20:00	10.0	13.7	8.2	136.5	3,107,821.8	1,611.3	1.5	1.0
01/13/2022 21:00	10.0	13.7	8.2	138.5	3,180,150.6	1,648.8	1.5	1.0
01/13/2022 22:00	10.0	13.3	7.8	153.4	3,419,966.2	1,997.9	1.5	1.2
01/13/2022 23:00	16.4	14.8	15.9	159.6	2,558,084.7	1,214.2	2.0	1.0
Average/Sum#:	10.4	13.6	8.5	149.4	3,215,754.4	1,764.8	1.6	1.1
Minimum:	9.5	13.2	7.6	108.6	2,558,084.7	1,214.2	1.4	0.7
Maximum:	16.4	14.8	15.9	178.6	3,516,930.8	2,085.7	2.0	1.5
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm	Unit CT1 O2Dry, Inlet, Pct	Unit CT1 NOx, Inlet, Ppmvdc	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 HI, MBtuPerHr	Unit CT1 NH3, Slip, Ppmvdc	Unit CT1 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/14/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/14/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/14/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/14/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/14/2022 04:00	31.7	17.7	58.4	205.7	1,433,838.0	282.7	4.2	0.5
01/14/2022 05:00	44.1	15.9	52.0	256.7	2,051,503.1	779.0	3.8	1.2
01/14/2022 06:00	10.7	13.7	8.8	129.0	2,880,034.5	1,493.2	1.5	0.9
01/14/2022 07:00	10.1	13.5	8.1	179.5	3,467,832.8	1,848.6	1.8	1.3
01/14/2022 08:00	11.1	13.8	9.2	114.4	2,710,090.9	1,385.3	1.4	0.7
01/14/2022 09:00	11.3	13.8	9.4	115.3	2,674,094.6	1,366.9	1.4	0.7
01/14/2022 10:00	11.3	13.8	9.4	121.3	2,676,833.4	1,368.3	1.5	0.8
01/14/2022 11:00	11.2	13.8	9.3	120.4	2,680,159.2	1,370.0	1.5	0.8
01/14/2022 12:00	11.1	13.8	9.2	121.6	2,701,483.0	1,380.9	1.5	0.8
01/14/2022 13:00	10.4	13.6	8.4	165.4	3,333,977.8	1,752.9	1.7	1.2
01/14/2022 14:00	10.5	13.8	8.7	122.6	2,995,518.0	1,531.2	1.4	0.8
01/14/2022 15:00	10.3	13.8	8.6	129.8	2,998,061.2	1,532.5	1.5	0.9
01/14/2022 16:00	10.8	13.8	9.0	124.3	2,803,603.0	1,433.1	1.5	0.9
01/14/2022 17:00	10.7	13.8	8.9	142.5	3,084,869.5	1,599.4	1.6	1.0
01/14/2022 18:00	10.7	13.8	8.9	141.6	3,139,260.7	1,627.6	1.5	1.0
01/14/2022 19:00	10.1	13.4	7.9	154.9	3,370,946.2	1,870.8	1.6	1.1
01/14/2022 20:00	10.0	13.4	7.9	161.9	3,362,025.8	1,890.4	1.7	1.3
01/14/2022 21:00	10.0	13.7	8.2	144.2	3,337,152.2	1,730.2	1.5	1.0
01/14/2022 22:00	10.1	13.3	7.8	158.7	3,488,095.1	2,037.7	1.6	1.2
01/14/2022 23:00	16.6	14.8	16.1	171.1	2,598,535.4	1,233.4	2.2	1.0
Average/Sum#:	13.6	14.1	13.7	149.0	2,889,395.7	1,475.7	1.8	1.0
Minimum:	10.0	13.3	7.8	114.4	1,433,838.0	282.7	1.4	0.5
Maximum:	44.1	17.7	58.4	256.7	3,488,095.1	2,037.7	4.2	1.3
%SI	16.67	16.67	16.67	16.67	16.67	16.67	16.67	16.67

Daily Summary Report

CT1 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm	Unit CT1 O2Dry, Inlet, Pct	Unit CT1 NOx, Inlet, Ppmvdc	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 HI, MBtuPerHr	Unit CT1 NH3, Slip, Ppmvdc	Unit CT1 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/15/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/15/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/15/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/15/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/15/2022 04:00	28.8	17.8	54.8	214.8	1,391,335.2	254.0	4.6	0.5
01/15/2022 05:00	43.8	15.8	50.7	254.8	2,083,442.3	760.7	3.7	1.1
01/15/2022 06:00	10.6	13.7	8.7	129.4	2,928,253.7	1,518.2	1.5	0.9
01/15/2022 07:00	10.7	13.7	8.8	139.3	3,017,555.6	1,564.5	1.6	0.9
01/15/2022 08:00	11.1	13.8	9.2	121.2	2,772,888.7	1,417.4	1.5	0.9
01/15/2022 09:00	11.2	13.7	9.2	135.6	2,955,063.5	1,532.1	1.5	0.9
01/15/2022 10:00	11.4	13.8	9.5	118.6	2,682,702.4	1,371.3	1.5	0.8
01/15/2022 11:00	11.3	13.8	9.4	118.7	2,685,832.5	1,372.9	1.5	0.8
01/15/2022 12:00	11.2	13.8	9.3	119.6	2,678,985.4	1,369.4	1.5	0.8
01/15/2022 13:00	11.1	13.8	9.2	122.1	2,691,310.2	1,375.7	1.5	0.8
01/15/2022 14:00	9.8	13.8	8.1	152.2	3,346,603.2	1,735.1	1.5	1.0
01/15/2022 15:00	10.4	13.8	8.6	134.4	3,045,908.4	1,579.2	1.5	0.9
01/15/2022 16:00	10.5	13.7	8.6	137.1	3,084,483.8	1,599.2	1.5	1.0
01/15/2022 17:00	10.1	13.7	8.3	141.6	3,244,185.7	1,682.0	1.5	1.0
01/15/2022 18:00	10.2	13.4	8.0	159.7	3,393,649.8	1,883.4	1.6	1.1
01/15/2022 19:00	10.1	13.4	7.9	157.1	3,423,907.6	1,975.2	1.6	1.2
01/15/2022 20:00	10.5	13.7	8.6	161.6	3,294,140.7	1,707.9	1.7	1.2
01/15/2022 21:00	9.8	13.7	8.0	147.8	3,399,976.4	1,787.6	1.5	1.1
01/15/2022 22:00	10.0	13.4	7.9	160.0	3,460,136.7	1,996.1	1.6	1.2
01/15/2022 23:00	14.2	14.3	12.7	163.2	2,926,598.8	1,474.6	1.8	1.0
Average/Sum#:	13.3	14.0	13.3	149.4	2,925,348.0	1,497.8	1.8	1.0
Minimum:	9.8	13.4	7.9	118.6	1,391,335.2	254.0	1.5	0.5
Maximum:	43.8	17.8	54.8	254.8	3,460,136.7	1,996.1	4.6	1.2
%SI	16.67	16.67	16.67	16.67	16.67	16.67	16.67	16.67

Daily Summary Report

CT1 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm	Unit CT1 O2Dry, Inlet, Pct	Unit CT1 NOx, Inlet, Ppmvdc	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 HI, MBtuPerHr	Unit CT1 NH3, Slip, Ppmvdc	Unit CT1 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/16/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/16/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/16/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/16/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/16/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/16/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/16/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/16/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/16/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/16/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/16/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/16/2022 11:00	39.4	17.3	64.6	101.8	1,433,465.1	355.9	0.0	0.0
01/16/2022 12:00	40.5	16.0	48.8	262.3	1,948,006.2	682.8	4.2	1.1
01/16/2022 13:00	11.2	13.8	9.3	126.4	2,670,570.4	1,384.6	1.6	0.8
01/16/2022 14:00	11.3	13.8	9.4	125.1	2,685,636.8	1,372.8	1.6	0.8
01/16/2022 15:00	10.6	13.7	8.7	162.8	3,225,669.5	1,672.4	1.7	1.2
01/16/2022 16:00	10.5	13.7	8.6	155.3	3,210,046.5	1,664.3	1.6	1.0
01/16/2022 17:00	11.0	13.8	9.1	128.6	2,848,011.5	1,455.8	1.5	0.9
01/16/2022 18:00	10.4	13.6	8.4	150.6	3,276,157.6	1,722.5	1.6	1.0
01/16/2022 19:00	10.1	13.4	7.9	150.8	3,417,158.5	1,921.4	1.5	1.2
01/16/2022 20:00	10.2	13.3	7.9	166.7	3,382,812.2	2,025.6	1.7	1.4
01/16/2022 21:00	10.3	13.7	8.4	155.3	3,302,820.2	1,712.4	1.6	1.0
01/16/2022 22:00	11.0	13.8	9.1	117.5	2,757,433.8	1,409.5	1.4	0.7
01/16/2022 23:00	10.8	13.7	8.9	153.8	3,152,183.5	1,634.3	1.7	1.1
Average/Sum#:	15.2	14.1	16.1	150.5	2,869,997.8	1,462.6	1.7	0.9
Minimum:	10.1	13.3	7.9	101.8	1,433,465.1	355.9	0.0	0.0
Maximum:	40.5	17.3	64.6	262.3	3,417,158.5	2,025.6	4.2	1.4
%SI	45.83	45.83	45.83	45.83	45.83	45.83	45.83	45.83

Daily Summary Report

CT1 - NH3 Slip



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm	Unit CT1 O2Dry, Inlet, Pct	Unit CT1 NOx, Inlet, Ppmvdc	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 HI, MBtuPerHr	Unit CT1 NH3, Slip, Ppmvdc	Unit CT1 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/17/2022 00:00	9.8	13.6	7.9	147.3	3,361,297.8	1,840.9	1.5	1.1
01/17/2022 01:00	10.1	13.5	8.1	168.5	3,369,504.7	1,870.0	1.7	1.3
01/17/2022 02:00	11.1	13.8	9.2	118.5	2,749,457.0	1,425.5	1.4	0.7
01/17/2022 03:00	10.0	13.7	8.2	158.6	3,401,958.8	1,763.8	1.6	1.1
01/17/2022 04:00	9.6	13.6	7.8	149.8	3,448,728.8	1,863.6	1.5	1.1
01/17/2022 05:00	10.2	13.5	8.1	155.7	3,411,902.3	1,843.7	1.6	1.1
01/17/2022 06:00	10.4	13.7	8.5	146.9	3,258,659.4	1,713.3	1.5	1.0
01/17/2022 07:00	10.3	13.3	8.0	161.4	3,446,384.7	2,038.5	1.6	1.2
01/17/2022 08:00	10.1	13.3	7.8	167.2	3,478,168.9	2,057.3	1.7	1.4
01/17/2022 09:00	9.7	13.4	7.6	164.1	3,432,401.5	1,980.1	1.6	1.2
01/17/2022 10:00	10.5	13.7	8.6	137.3	3,074,068.4	1,593.8	1.5	1.0
01/17/2022 11:00	10.7	13.7	8.8	142.6	3,078,697.5	1,596.2	1.6	1.0
01/17/2022 12:00	10.2	13.7	8.4	140.9	3,206,188.9	1,662.3	1.5	1.0
01/17/2022 13:00	10.2	13.3	7.9	156.4	3,402,759.6	1,963.0	1.6	1.2
01/17/2022 14:00	10.1	13.3	7.8	163.3	3,361,676.8	1,939.3	1.7	1.4
01/17/2022 15:00	10.2	13.7	8.4	138.1	3,113,029.5	1,614.0	1.5	1.0
01/17/2022 16:00	10.1	13.7	8.3	132.6	3,097,792.3	1,606.1	1.4	0.8
01/17/2022 17:00	10.0	13.4	7.9	158.0	3,398,740.1	1,985.5	1.6	1.2
01/17/2022 18:00	9.9	13.3	7.7	166.6	3,417,136.5	2,021.2	1.7	1.4
01/17/2022 19:00	10.0	13.3	7.8	167.1	3,402,442.1	2,062.2	1.7	1.4
01/17/2022 20:00	9.5	13.4	7.5	152.1	3,383,691.6	1,952.0	1.5	1.2
01/17/2022 21:00	10.3	13.7	8.4	148.5	3,201,367.0	1,659.8	1.6	1.0
01/17/2022 22:00	10.8	13.8	9.0	120.6	2,782,279.1	1,422.2	1.4	0.7
01/17/2022 23:00	10.8	13.7	8.9	152.0	3,171,085.4	1,644.1	1.6	1.0
Average/Sum#:	10.2	13.5	8.2	150.6	3,268,725.8	1,796.6	1.6	1.1
Minimum:	9.5	13.3	7.5	118.5	2,749,457.0	1,422.2	1.4	0.7
Maximum:	11.1	13.8	9.2	168.5	3,478,168.9	2,062.2	1.7	1.4
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm	Unit CT1 O2Dry, Inlet, Pct	Unit CT1 NOx, Inlet, Ppmvdc	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 HI, MBtuPerHr	Unit CT1 NH3, Slip, Ppmvdc	Unit CT1 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/18/2022 00:00	10.1	13.6	8.2	158.2	3,414,241.3	1,795.1	1.6	1.1
01/18/2022 01:00	9.7	13.5	7.7	148.4	3,303,514.0	1,857.5	1.5	1.1
01/18/2022 02:00	10.0	13.7	8.2	130.3	3,161,827.3	1,639.3	1.4	0.8
01/18/2022 03:00	9.6	13.4	7.6	152.8	3,489,898.0	1,962.3	1.5	1.2
01/18/2022 04:00	9.4	13.4	7.4	143.0	3,486,163.2	1,960.2	1.4	1.0
01/18/2022 05:00	10.6	13.7	8.7	151.0	3,059,216.9	1,586.1	1.7	1.1
01/18/2022 06:00	10.8	13.7	8.9	143.9	3,106,857.5	1,610.8	1.6	1.0
01/18/2022 07:00	10.1	13.5	8.1	158.7	3,528,313.0	1,983.9	1.5	1.2
01/18/2022 08:00	10.3	13.3	8.0	172.3	3,469,607.9	2,026.9	1.7	1.4
01/18/2022 09:00	9.7	13.5	7.7	154.7	3,463,576.6	1,947.5	1.5	1.2
01/18/2022 10:00	10.8	13.8	9.0	117.7	946,934.0	1,445.2	4.5	2.5
01/18/2022 11:00	11.0	13.8	9.1	121.2	2,721,875.6	1,411.2	1.5	0.8
01/18/2022 12:00	10.9	13.9	9.2	107.7	2,570,409.6	1,313.9	1.4	0.7
01/18/2022 13:00	10.9	13.8	9.1	105.0	866,996.3	1,323.2	4.3	2.2
01/18/2022 14:00	11.0	13.8	9.1	103.5	2,665,095.5	1,362.3	1.3	0.7
01/18/2022 15:00	10.8	13.7	8.9	147.0	2,974,929.8	1,542.4	1.7	1.1
01/18/2022 16:00	10.1	13.7	8.3	135.9	3,113,918.9	1,637.2	1.5	1.0
01/18/2022 17:00	10.2	13.3	7.9	162.0	3,393,500.4	2,032.0	1.6	1.2
01/18/2022 18:00	10.1	13.3	7.8	174.6	3,420,053.9	2,047.9	1.8	1.4
01/18/2022 19:00	10.1	13.2	7.7	172.2	3,394,868.3	2,082.4	1.8	1.5
01/18/2022 20:00	9.6	13.4	7.6	154.2	3,427,774.6	1,952.4	1.5	1.2
01/18/2022 21:00	10.4	13.7	8.5	146.9	3,045,067.3	1,601.0	1.6	1.0
01/18/2022 22:00	10.1	13.7	8.3	138.7	3,098,178.0	1,606.3	1.5	1.0
01/18/2022 23:00	10.0	13.3	7.8	158.9	3,453,029.6	1,992.0	1.6	1.2
Average/Sum#:	10.3	13.6	8.3	144.1	3,216,450.8	1,738.3	1.6	1.1
Minimum:	9.4	13.2	7.4	103.5	2,570,409.6	1,313.9	1.3	0.7
Maximum:	11.0	13.9	9.2	174.6	3,528,313.0	2,082.4	1.8	1.5
%SI	0.00	0.00	0.00	0.00	8.33	0.00	8.33	8.33

Daily Summary Report

CT1 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm	Unit CT1 O2Dry, Inlet, Pct	Unit CT1 NOx, Inlet, Ppmvdc	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 HI, MBtuPerHr	Unit CT1 NH3, Slip, Ppmvdc	Unit CT1 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/19/2022 00:00	9.8	13.5	7.8	158.4	3,326,620.1	1,846.2	1.6	1.1
01/19/2022 01:00	11.1	13.8	9.2	114.4	2,566,301.3	1,311.8	1.5	0.8
01/19/2022 02:00	10.3	13.7	8.4	139.4	3,086,219.7	1,600.1	1.5	1.0
01/19/2022 03:00	9.5	13.5	7.6	152.8	3,512,662.5	1,975.1	1.5	1.2
01/19/2022 04:00	9.2	13.5	7.3	149.4	3,458,241.2	1,944.5	1.5	1.2
01/19/2022 05:00	10.4	13.7	8.5	139.0	3,073,682.7	1,593.6	1.5	1.0
01/19/2022 06:00	10.5	13.7	8.6	131.8	3,106,857.5	1,610.8	1.4	0.8
01/19/2022 07:00	9.7	13.4	7.6	165.3	3,477,460.1	1,980.7	1.6	1.2
01/19/2022 08:00	9.6	13.4	7.6	173.3	3,489,364.5	1,962.0	1.7	1.4
01/19/2022 09:00	10.7	13.7	8.8	126.2	2,928,446.5	1,518.3	1.4	0.8
01/19/2022 10:00	11.8	13.8	9.8	123.4	2,668,225.6	1,363.9	1.5	0.8
01/19/2022 11:00	11.6	13.8	9.6	127.0	2,794,995.2	1,428.7	1.5	0.9
01/19/2022 12:00	11.6	13.8	9.6	115.7	2,607,188.4	1,332.7	1.5	0.8
01/19/2022 13:00	11.2	13.8	9.3	120.7	2,710,090.9	1,385.3	1.5	0.8
01/19/2022 14:00	11.1	13.8	9.2	118.7	2,662,747.9	1,361.1	1.5	0.8
01/19/2022 15:00	10.7	13.6	8.6	144.7	3,014,255.2	1,584.8	1.6	1.0
01/19/2022 16:00	10.6	13.2	8.1	169.6	3,392,422.9	2,080.9	1.7	1.5
01/19/2022 17:00	10.4	13.2	8.0	180.1	3,353,975.1	2,106.3	1.9	1.5
01/19/2022 18:00	10.3	13.3	8.0	178.5	3,393,890.1	2,081.8	1.8	1.5
01/19/2022 19:00	10.2	13.2	7.8	182.6	3,377,483.9	2,096.4	1.9	1.5
01/19/2022 20:00	10.1	13.3	7.8	176.6	3,344,530.3	2,027.1	1.8	1.4
01/19/2022 21:00	10.0	13.7	8.2	146.2	3,279,675.0	1,700.4	1.5	1.0
01/19/2022 22:00	9.6	13.7	7.9	147.3	3,415,382.5	1,795.7	1.5	1.1
01/19/2022 23:00	10.3	13.3	8.0	164.5	3,423,389.8	1,999.9	1.6	1.2
Average/Sum#:	10.4	13.6	8.4	147.7	3,144,337.9	1,737.0	1.6	1.1
Minimum:	9.2	13.2	7.3	114.4	2,566,301.3	1,311.8	1.4	0.8
Maximum:	11.8	13.8	9.8	182.6	3,512,662.5	2,106.3	1.9	1.5
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm	Unit CT1 O2Dry, Inlet, Pct	Unit CT1 NOx, Inlet, Ppmvdc	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 HI, MBtuPerHr	Unit CT1 NH3, Slip, Ppmvdc	Unit CT1 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/20/2022 00:00	10.2	13.4	8.0	165.9	3,266,603.9	1,860.6	1.7	1.3
01/20/2022 01:00	10.7	13.9	9.0	110.8	2,573,148.4	1,315.3	1.4	0.7
01/20/2022 02:00	10.8	13.9	9.1	115.2	2,593,298.5	1,325.6	1.5	0.8
01/20/2022 03:00	10.1	13.7	8.3	163.0	3,371,870.0	1,748.2	1.7	1.2
01/20/2022 04:00	9.6	13.5	7.7	149.0	3,402,928.3	1,863.7	1.5	1.1
01/20/2022 05:00	10.0	13.4	7.9	153.5	3,416,257.4	1,871.0	1.5	1.1
01/20/2022 06:00	10.2	13.7	8.4	147.0	3,330,787.3	1,726.9	1.5	1.0
01/20/2022 07:00	10.2	13.4	8.0	160.0	3,459,616.7	1,995.8	1.6	1.2
01/20/2022 08:00	10.3	13.6	8.3	146.8	3,153,747.3	1,704.2	1.6	1.0
01/20/2022 09:00	11.0	13.8	9.1	125.0	2,721,437.5	1,391.1	1.5	0.8
01/20/2022 10:00	11.0	13.8	9.1	121.9	2,677,029.0	1,368.4	1.5	0.8
01/20/2022 11:00	10.9	13.8	9.1	125.0	2,686,615.0	1,373.3	1.6	0.8
01/20/2022 12:00	11.0	13.8	9.1	122.6	2,690,527.7	1,375.3	1.5	0.8
01/20/2022 13:00	11.0	13.8	9.1	121.3	2,692,484.0	1,376.3	1.5	0.8
01/20/2022 14:00	11.0	13.8	9.1	121.6	2,699,526.7	1,379.9	1.5	0.8
01/20/2022 15:00	11.0	13.8	9.1	123.8	2,704,808.8	1,382.6	1.5	0.8
01/20/2022 16:00	10.2	13.6	8.2	156.2	3,256,567.3	1,712.2	1.6	1.0
01/20/2022 17:00	10.9	13.8	9.1	144.0	2,954,677.8	1,531.9	1.6	0.9
01/20/2022 18:00	10.8	13.7	8.9	148.5	3,130,002.7	1,622.8	1.6	1.0
01/20/2022 19:00	10.3	13.6	8.3	152.9	3,286,618.5	1,728.0	1.6	1.0
01/20/2022 20:00	10.4	13.3	8.1	168.7	3,430,323.5	2,029.0	1.7	1.4
01/20/2022 21:00	10.3	13.3	8.0	173.0	3,434,043.0	2,031.2	1.7	1.4
01/20/2022 22:00	10.3	13.2	7.9	172.8	3,407,226.9	2,065.1	1.7	1.4
01/20/2022 23:00	14.0	14.4	12.7	141.9	2,550,195.2	1,247.7	1.8	0.9
Average/Sum#:	10.7	13.7	8.7	142.9	3,037,097.6	1,626.1	1.6	1.0
Minimum:	9.6	13.2	7.7	110.8	2,550,195.2	1,247.7	1.4	0.7
Maximum:	14.0	14.4	12.7	173.0	3,459,616.7	2,065.1	1.8	1.4
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm	Unit CT1 O2Dry, Inlet, Pct	Unit CT1 NOx, Inlet, Ppmvdc	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 HI, MBtuPerHr	Unit CT1 NH3, Slip, Ppmvdc	Unit CT1 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/21/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/21/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/21/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/21/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/21/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/21/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/21/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/21/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/21/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/21/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/21/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/21/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/21/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/21/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/21/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/21/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/21/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/21/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/21/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/21/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/21/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/21/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/21/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/21/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm	Unit CT1 O2Dry, Inlet, Pct	Unit CT1 NOx, Inlet, Ppmvdc	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 HI, MBtuPerHr	Unit CT1 NH3, Slip, Ppmvdc	Unit CT1 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/22/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/22/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/22/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/22/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/22/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/22/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/22/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/22/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/22/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/22/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/22/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/22/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/22/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/22/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/22/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/22/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/22/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/22/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/22/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/22/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/22/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/22/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/22/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/22/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm	Unit CT1 O2Dry, Inlet, Pct	Unit CT1 NOx, Inlet, Ppmvdc	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 HI, MBtuPerHr	Unit CT1 NH3, Slip, Ppmvdc	Unit CT1 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/23/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/23/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/23/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/23/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/23/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/23/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/23/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/23/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/23/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/23/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/23/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/23/2022 11:00	39.5	17.4	66.6	0.0	1,342,035.9	323.4	0.0	0.0
01/23/2022 12:00	39.3	17.2	62.7	228.3	1,419,760.0	383.6	5.2	0.8
01/23/2022 13:00	42.9	15.5	46.9	256.1	2,093,669.0	810.3	4.0	1.2
01/23/2022 14:00	10.2	13.8	8.5	119.4	2,778,562.1	1,420.3	1.4	0.7
01/23/2022 15:00	10.5	13.9	8.9	116.1	2,700,504.9	1,380.4	1.4	0.7
01/23/2022 16:00	10.0	13.8	8.3	150.8	3,144,082.7	1,630.1	1.6	1.0
01/23/2022 17:00	10.0	13.8	8.3	138.6	3,141,263.9	1,605.7	1.5	1.0
01/23/2022 18:00	9.7	13.6	7.8	150.0	3,378,103.7	1,776.1	1.5	1.1
01/23/2022 19:00	10.0	13.4	7.9	155.7	3,443,322.3	1,986.4	1.5	1.2
01/23/2022 20:00	10.0	13.3	7.8	173.6	3,437,585.2	2,083.5	1.7	1.5
01/23/2022 21:00	9.8	13.3	7.6	169.8	3,421,890.9	2,049.0	1.7	1.4
01/23/2022 22:00	9.8	13.3	7.6	160.0	3,477,297.9	2,006.0	1.6	1.2
01/23/2022 23:00	16.3	14.8	15.8	162.9	2,551,343.0	1,211.0	2.1	1.0
Average/Sum#:	17.5	14.4	20.4	152.4	2,794,570.9	1,435.8	1.9	1.0
Minimum:	9.7	13.3	7.6	0.0	1,342,035.9	323.4	0.0	0.0
Maximum:	42.9	17.4	66.6	256.1	3,477,297.9	2,083.5	5.2	1.5
%SI	45.83	45.83	45.83	45.83	45.83	45.83	45.83	45.83

Daily Summary Report

CT1 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm	Unit CT1 O2Dry, Inlet, Pct	Unit CT1 NOx, Inlet, Ppmvdc	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 HI, MBtuPerHr	Unit CT1 NH3, Slip, Ppmvdc	Unit CT1 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/24/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/24/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/24/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/24/2022 03:00	24.0	17.9	47.2	201.3	1,338,301.1	215.0	4.6	0.4
01/24/2022 04:00	41.0	15.5	44.8	248.9	2,179,193.4	843.4	3.5	1.1
01/24/2022 05:00	11.1	13.7	9.1	139.8	2,944,455.3	1,526.6	1.6	0.9
01/24/2022 06:00	10.3	13.3	8.0	203.4	3,483,515.0	2,085.9	2.0	1.7
01/24/2022 07:00	10.5	13.2	8.0	198.8	3,458,433.5	2,171.9	2.0	1.7
01/24/2022 08:00	10.4	13.6	8.4	180.3	3,308,961.8	1,836.4	1.9	1.3
01/24/2022 09:00	11.9	13.8	9.9	122.5	2,659,962.2	1,379.1	1.5	0.8
01/24/2022 10:00	11.7	13.8	9.7	127.5	2,648,968.2	1,373.4	1.6	0.8
01/24/2022 11:00	11.7	13.8	9.7	130.0	2,628,716.2	1,362.9	1.7	1.0
01/24/2022 12:00	11.4	13.8	9.5	127.0	2,652,247.1	1,375.1	1.6	0.8
01/24/2022 13:00	11.2	13.8	9.3	123.6	2,659,769.3	1,379.0	1.6	0.8
01/24/2022 14:00	10.0	13.6	8.1	158.4	3,341,585.7	1,756.9	1.6	1.1
01/24/2022 15:00	10.9	13.8	9.1	129.7	2,827,572.0	1,466.0	1.5	0.9
01/24/2022 16:00	10.6	13.7	8.7	158.9	3,216,797.2	1,667.8	1.7	1.2
01/24/2022 17:00	10.1	13.7	8.3	140.6	3,167,554.7	1,665.4	1.5	1.0
01/24/2022 18:00	10.1	13.3	7.8	159.1	3,415,173.2	1,995.1	1.6	1.2
01/24/2022 19:00	10.2	13.2	7.8	174.6	3,414,651.5	2,069.6	1.8	1.4
01/24/2022 20:00	10.0	13.3	7.8	167.3	3,374,261.7	1,971.2	1.7	1.4
01/24/2022 21:00	10.4	13.7	8.5	144.0	3,145,818.5	1,631.0	1.6	1.0
01/24/2022 22:00	10.1	13.6	8.2	147.7	3,334,358.2	1,753.1	1.5	1.1
01/24/2022 23:00	10.0	13.3	7.8	162.0	3,426,984.5	2,002.0	1.6	1.2
Average/Sum#:	12.7	13.9	12.2	159.3	2,982,251.4	1,596.5	1.9	1.1
Minimum:	10.0	13.2	7.8	122.5	1,338,301.1	215.0	1.5	0.4
Maximum:	41.0	17.9	47.2	248.9	3,483,515.0	2,171.9	4.6	1.7
%SI	12.50	12.50	12.50	12.50	12.50	12.50	12.50	12.50

Daily Summary Report

CT1 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm	Unit CT1 O2Dry, Inlet, Pct	Unit CT1 NOx, Inlet, Ppmvdc	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 HI, MBtuPerHr	Unit CT1 NH3, Slip, Ppmvdc	Unit CT1 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/25/2022 00:00	10.0	13.5	8.0	167.0	3,411,973.5	1,943.4	1.7	1.4
01/25/2022 01:00	10.6	13.7	8.7	139.7	3,034,528.7	1,573.3	1.6	0.9
01/25/2022 02:00	10.3	13.7	8.4	148.8	3,198,937.3	1,681.9	1.6	1.0
01/25/2022 03:00	9.6	13.5	7.7	150.2	3,468,506.2	1,975.6	1.5	1.2
01/25/2022 04:00	9.9	13.5	7.9	168.3	3,431,110.4	1,954.3	1.7	1.4
01/25/2022 05:00	10.2	13.7	8.4	157.2	3,229,141.3	1,674.2	1.7	1.2
01/25/2022 06:00	9.7	13.7	7.9	143.3	3,396,362.7	1,785.7	1.4	0.9
01/25/2022 07:00	10.1	13.3	7.8	157.1	3,491,176.3	2,039.5	1.5	1.2
01/25/2022 08:00	14.7	14.2	12.9	167.5	2,862,097.0	1,525.7	2.0	1.2
01/25/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/25/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/25/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/25/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/25/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/25/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/25/2022 15:00	37.8	17.6	67.6	120.6	1,422,831.9	311.7	0.0	0.0
01/25/2022 16:00	34.2	15.4	36.7	228.5	2,400,550.2	946.6	3.0	1.1
01/25/2022 17:00	10.1	13.8	8.4	148.1	3,226,441.0	1,672.8	1.6	1.0
01/25/2022 18:00	9.9	13.7	8.1	152.0	3,317,430.6	1,744.2	1.6	1.0
01/25/2022 19:00	10.3	13.4	8.1	166.2	3,394,943.5	1,933.7	1.7	1.4
01/25/2022 20:00	10.2	13.4	8.0	169.3	3,410,920.1	1,942.8	1.7	1.4
01/25/2022 21:00	10.4	13.8	8.6	129.2	3,024,862.8	1,546.2	1.4	0.8
01/25/2022 22:00	10.0	13.7	8.2	144.7	3,271,022.3	1,719.8	1.5	1.0
01/25/2022 23:00	9.8	13.4	7.7	156.0	3,492,565.7	1,963.8	1.5	1.2
Average/Sum#:	13.2	13.9	13.3	156.3	3,138,077.9	1,663.1	1.6	1.1
Minimum:	9.6	13.3	7.7	120.6	1,422,831.9	311.7	0.0	0.0
Maximum:	37.8	17.6	67.6	228.5	3,492,565.7	2,039.5	3.0	1.4
%SI	25.00	25.00	25.00	25.00	25.00	25.00	25.00	25.00

Daily Summary Report

CT1 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm	Unit CT1 O2Dry, Inlet, Pct	Unit CT1 NOx, Inlet, Ppmvdc	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 HI, MBtuPerHr	Unit CT1 NH3, Slip, Ppmvdc	Unit CT1 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/26/2022 00:00	9.9	13.4	7.8	157.7	3,464,819.3	1,973.5	1.6	1.2
01/26/2022 01:00	10.2	13.7	8.4	159.2	3,308,413.6	1,715.3	1.6	1.0
01/26/2022 02:00	10.1	13.7	8.3	148.1	3,314,007.0	1,718.2	1.5	1.0
01/26/2022 03:00	9.7	13.4	7.6	155.3	3,518,367.3	2,004.0	1.5	1.2
01/26/2022 04:00	9.7	13.4	7.6	160.7	3,504,497.5	1,996.1	1.6	1.2
01/26/2022 05:00	10.6	13.7	8.7	155.5	3,095,284.9	1,604.8	1.7	1.1
01/26/2022 06:00	9.9	13.7	8.1	156.7	3,509,776.8	1,819.7	1.5	1.1
01/26/2022 07:00	9.9	13.4	7.8	156.1	3,490,818.8	2,013.8	1.5	1.2
01/26/2022 08:00	14.4	14.4	13.1	162.9	2,919,454.0	1,471.0	1.8	1.0
01/26/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/26/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/26/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/26/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/26/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/26/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/26/2022 15:00	37.9	17.5	65.8	163.7	1,472,587.7	322.6	0.0	0.0
01/26/2022 16:00	33.5	15.3	35.3	229.9	2,398,521.4	945.8	3.0	1.1
01/26/2022 17:00	9.7	13.8	8.1	143.0	3,314,007.0	1,718.2	1.5	1.0
01/26/2022 18:00	9.6	13.6	7.8	152.1	3,464,073.1	1,821.3	1.5	1.1
01/26/2022 19:00	10.0	13.4	7.9	161.6	3,405,653.1	1,939.8	1.6	1.2
01/26/2022 20:00	10.0	13.3	7.8	164.6	3,396,506.5	2,033.8	1.7	1.4
01/26/2022 21:00	10.1	13.7	8.3	150.4	3,261,930.3	1,691.2	1.6	1.0
01/26/2022 22:00	9.4	13.7	7.7	144.2	3,490,103.4	1,809.5	1.4	0.9
01/26/2022 23:00	9.9	13.4	7.8	159.0	3,503,299.6	2,021.0	1.6	1.2
Average/Sum#:	13.0	13.9	13.0	160.0	3,212,895.6	1,701.1	1.6	1.1
Minimum:	9.4	13.3	7.6	143.0	1,472,587.7	322.6	0.0	0.0
Maximum:	37.9	17.5	65.8	229.9	3,518,367.3	2,033.8	3.0	1.4
%SI	25.00	25.00	25.00	25.00	25.00	25.00	25.00	25.00

Daily Summary Report

CT1 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm	Unit CT1 O2Dry, Inlet, Pct	Unit CT1 NOx, Inlet, Ppmvdc	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 HI, MBtuPerHr	Unit CT1 NH3, Slip, Ppmvdc	Unit CT1 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/27/2022 00:00	9.7	13.4	7.6	155.3	3,481,849.3	1,983.2	1.5	1.2
01/27/2022 01:00	10.7	13.7	8.8	136.7	2,967,600.5	1,538.6	1.6	0.9
01/27/2022 02:00	10.1	13.7	8.3	148.0	3,312,849.7	1,717.6	1.5	1.0
01/27/2022 03:00	9.7	13.5	7.7	151.5	3,490,965.1	1,962.9	1.5	1.2
01/27/2022 04:00	9.5	13.5	7.6	150.6	3,490,253.7	1,962.5	1.5	1.2
01/27/2022 05:00	10.4	13.8	8.6	153.8	3,084,483.8	1,599.2	1.7	1.1
01/27/2022 06:00	10.1	13.5	8.1	150.3	3,388,604.6	1,880.6	1.5	1.1
01/27/2022 07:00	10.3	13.3	8.0	174.3	3,484,329.2	2,035.5	1.7	1.4
01/27/2022 08:00	9.8	13.5	7.8	157.8	3,488,169.7	1,986.8	1.5	1.2
01/27/2022 09:00	10.2	13.6	8.2	146.6	3,137,462.3	1,695.4	1.6	1.0
01/27/2022 10:00	18.1	15.2	18.7	145.6	2,067,602.6	905.9	2.3	0.8
01/27/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/27/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/27/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/27/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/27/2022 15:00	37.7	17.5	65.4	168.6	1,461,632.3	320.2	0.0	0.0
01/27/2022 16:00	32.4	15.3	34.1	228.9	2,412,215.7	951.2	3.0	1.1
01/27/2022 17:00	10.5	13.8	8.7	134.9	3,017,428.8	1,542.4	1.5	0.9
01/27/2022 18:00	9.6	13.6	7.8	156.5	3,457,986.8	1,818.1	1.5	1.1
01/27/2022 19:00	10.2	13.3	7.9	170.4	3,426,435.1	2,026.7	1.7	1.4
01/27/2022 20:00	10.0	13.3	7.8	166.8	3,428,353.9	2,002.8	1.7	1.4
01/27/2022 21:00	10.5	13.7	8.6	164.3	3,270,802.6	1,695.8	1.7	1.2
01/27/2022 22:00	10.6	13.8	8.8	124.4	2,920,786.6	1,493.0	1.4	0.7
01/27/2022 23:00	9.7	13.4	7.6	150.9	3,478,518.1	1,930.5	1.5	1.2
Average/Sum#:	13.0	13.9	12.8	156.8	3,113,416.5	1,652.4	1.6	1.1
Minimum:	9.5	13.3	7.6	124.4	1,461,632.3	320.2	0.0	0.0
Maximum:	37.7	17.5	65.4	228.9	3,490,965.1	2,035.5	3.0	1.4
%SI	16.67	16.67	16.67	16.67	16.67	16.67	16.67	16.67

Daily Summary Report

CT1 - NH3 Slip



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm	Unit CT1 O2Dry, Inlet, Pct	Unit CT1 NOx, Inlet, Ppmvdc	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 HI, MBtuPerHr	Unit CT1 NH3, Slip, Ppmvdc	Unit CT1 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/28/2022 00:00	9.9	13.3	7.7	172.9	3,498,118.5	2,069.1	1.7	1.4
01/28/2022 01:00	9.9	13.3	7.7	168.4	3,437,088.2	2,058.1	1.7	1.4
01/28/2022 02:00	10.6	13.7	8.7	129.3	2,938,090.4	1,523.3	1.5	0.9
01/28/2022 03:00	10.8	13.7	8.9	133.0	2,965,478.9	1,537.5	1.5	0.9
01/28/2022 04:00	9.6	13.7	7.9	147.0	3,433,397.7	1,780.1	1.5	1.1
01/28/2022 05:00	9.6	13.4	7.6	174.7	3,492,378.9	2,014.7	1.7	1.4
01/28/2022 06:00	10.3	13.3	8.0	178.5	3,491,217.0	2,141.5	1.8	1.5
01/28/2022 07:00	10.0	13.3	7.8	176.6	3,465,947.9	2,126.0	1.8	1.5
01/28/2022 08:00	9.7	13.4	7.6	162.3	3,487,116.3	1,986.2	1.6	1.2
01/28/2022 09:00	10.4	13.8	8.6	136.8	3,016,841.9	1,542.1	1.5	0.9
01/28/2022 10:00	10.8	13.8	9.0	129.1	2,809,080.7	1,435.9	1.5	0.9
01/28/2022 11:00	10.7	13.8	8.9	136.8	2,947,979.4	1,506.9	1.6	0.9
01/28/2022 12:00	10.7	13.8	8.9	124.4	2,868,944.1	1,466.5	1.5	0.9
01/28/2022 13:00	10.7	13.8	8.9	126.3	2,833,143.4	1,448.2	1.5	0.9
01/28/2022 14:00	10.3	13.8	8.6	146.8	3,227,146.4	1,649.6	1.5	1.0
01/28/2022 15:00	10.4	13.8	8.6	138.1	3,078,857.3	1,573.8	1.5	0.9
01/28/2022 16:00	10.0	13.8	8.3	136.3	3,111,486.5	1,613.2	1.5	1.0
01/28/2022 17:00	9.9	13.5	7.9	157.0	3,444,902.6	1,937.0	1.6	1.2
01/28/2022 18:00	10.1	13.3	7.8	169.9	3,429,239.1	2,053.4	1.7	1.4
01/28/2022 19:00	10.2	13.2	7.8	189.8	3,413,329.6	2,168.5	1.9	1.5
01/28/2022 20:00	9.9	13.3	7.7	180.4	3,361,695.2	2,086.6	1.9	1.5
01/28/2022 21:00	10.2	13.8	8.5	130.6	3,021,145.8	1,544.3	1.5	0.9
01/28/2022 22:00	9.3	13.7	7.6	145.6	3,521,156.6	1,825.6	1.4	0.9
01/28/2022 23:00	10.1	13.3	7.8	166.0	3,464,643.7	1,998.7	1.6	1.2
Average/Sum#:	10.2	13.6	8.2	152.4	3,239,934.4	1,795.3	1.6	1.1
Minimum:	9.3	13.2	7.6	124.4	2,809,080.7	1,435.9	1.4	0.9
Maximum:	10.8	13.8	9.0	189.8	3,521,156.6	2,168.5	1.9	1.5
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm	Unit CT1 O2Dry, Inlet, Pct	Unit CT1 NOx, Inlet, Ppmvdc	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 HI, MBtuPerHr	Unit CT1 NH3, Slip, Ppmvdc	Unit CT1 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/29/2022 00:00	9.6	13.5	7.7	153.1	3,457,707.6	1,944.2	1.5	1.2
01/29/2022 01:00	10.5	13.7	8.6	145.3	3,064,424.6	1,588.8	1.6	1.0
01/29/2022 02:00	10.1	13.7	8.3	179.5	3,085,255.3	1,599.6	2.0	1.3
01/29/2022 03:00	9.4	13.5	7.5	201.2	3,494,699.9	1,965.0	2.0	1.6
01/29/2022 04:00	9.4	13.5	7.5	201.2	3,462,509.5	1,946.9	2.0	1.6
01/29/2022 05:00	10.1	13.7	8.3	155.0	3,133,667.3	1,624.7	1.7	1.1
01/29/2022 06:00	10.5	13.7	8.6	147.6	3,172,435.5	1,644.8	1.6	1.0
01/29/2022 07:00	10.0	13.4	7.9	155.6	3,540,488.7	2,016.6	1.5	1.2
01/29/2022 08:00	10.1	13.3	7.8	167.5	3,529,006.6	2,061.6	1.6	1.2
01/29/2022 09:00	9.5	13.5	7.6	157.8	3,468,912.0	1,950.5	1.6	1.2
01/29/2022 10:00	10.6	13.8	8.8	126.1	2,783,061.6	1,422.6	1.5	0.9
01/29/2022 11:00	10.7	13.7	8.8	142.8	3,015,081.2	1,541.2	1.6	0.9
01/29/2022 12:00	10.8	13.8	9.0	117.7	2,719,089.9	1,389.9	1.4	0.7
01/29/2022 13:00	10.6	13.9	8.9	120.8	2,761,933.4	1,411.8	1.5	0.8
01/29/2022 14:00	10.2	13.8	8.5	147.1	3,182,151.0	1,626.6	1.6	1.0
01/29/2022 15:00	10.6	13.9	8.9	120.3	2,726,915.2	1,393.9	1.5	0.8
01/29/2022 16:00	10.3	13.8	8.6	136.8	3,144,589.6	1,607.4	1.5	1.0
01/29/2022 17:00	10.2	13.8	8.5	143.0	3,156,041.0	1,636.3	1.5	1.0
01/29/2022 18:00	9.9	13.5	7.9	152.0	3,332,266.0	1,825.0	1.6	1.1
01/29/2022 19:00	10.0	13.4	7.9	161.1	3,296,845.9	1,901.9	1.7	1.3
01/29/2022 20:00	9.3	13.7	7.6	145.2	3,483,352.7	1,806.0	1.4	0.9
01/29/2022 21:00	10.2	13.3	7.9	166.4	3,445,370.3	2,037.9	1.7	1.4
01/29/2022 22:00	10.3	13.2	7.9	193.0	3,389,484.6	2,128.6	2.0	1.7
01/29/2022 23:00	9.6	13.6	7.8	151.9	3,344,819.1	1,856.3	1.6	1.1
Average/Sum#:	10.1	13.6	8.2	153.7	3,216,254.5	1,747.0	1.6	1.1
Minimum:	9.3	13.2	7.5	117.7	2,719,089.9	1,389.9	1.4	0.7
Maximum:	10.8	13.9	9.0	201.2	3,540,488.7	2,128.6	2.0	1.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm	Unit CT1 O2Dry, Inlet, Pct	Unit CT1 NOx, Inlet, Ppmvdc	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 HI, MBtuPerHr	Unit CT1 NH3, Slip, Ppmvdc	Unit CT1 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/30/2022 00:00	10.6	13.7	8.7	142.2	3,103,578.6	1,609.1	1.5	1.0
01/30/2022 01:00	10.8	13.8	9.0	118.2	2,741,000.7	1,401.1	1.4	0.7
01/30/2022 02:00	10.2	13.7	8.4	168.4	3,387,107.3	1,756.1	1.7	1.2
01/30/2022 03:00	9.6	13.6	7.8	151.1	3,446,932.5	1,887.8	1.5	1.1
01/30/2022 04:00	9.6	13.5	7.7	153.0	3,366,982.1	1,868.6	1.6	1.1
01/30/2022 05:00	10.7	13.7	8.8	147.6	3,137,524.9	1,626.7	1.6	1.0
01/30/2022 06:00	10.4	13.4	8.2	167.6	3,507,113.2	2,023.2	1.6	1.2
01/30/2022 07:00	14.4	14.2	12.7	170.3	2,922,199.5	1,536.4	1.9	1.1
01/30/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/30/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/30/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/30/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/30/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/30/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/30/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/30/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/30/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/30/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/30/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/30/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/30/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/30/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/30/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/30/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	10.8	13.7	8.9	152.3	3,201,554.9	1,713.6	1.6	1.1
Minimum:	9.6	13.4	7.7	118.2	2,741,000.7	1,401.1	1.4	0.7
Maximum:	14.4	14.2	12.7	170.3	3,507,113.2	2,023.2	1.9	1.2
%SI	66.67	66.67	66.67	66.67	66.67	66.67	66.67	66.67

Daily Summary Report

CT1 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm	Unit CT1 O2Dry, Inlet, Pct	Unit CT1 NOx, Inlet, Ppmvdc	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 HI, MBtuPerHr	Unit CT1 NH3, Slip, Ppmvdc	Unit CT1 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/31/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/31/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/31/2022 02:00	38.2	17.4	64.4	18.4	1,422,541.5	342.8	0.0	0.0
01/31/2022 03:00	37.8	15.4	40.5	236.2	2,195,390.2	865.7	3.4	1.1
01/31/2022 04:00	10.6	13.7	8.7	131.5	2,868,847.6	1,487.4	1.5	0.9
01/31/2022 05:00	10.3	13.7	8.4	140.7	3,098,370.9	1,606.4	1.5	1.0
01/31/2022 06:00	9.8	13.4	7.7	150.5	3,451,469.5	1,991.1	1.5	1.2
01/31/2022 07:00	10.4	13.2	8.0	163.2	3,534,484.3	2,064.8	1.6	1.2
01/31/2022 08:00	10.2	13.5	8.1	176.0	3,487,052.5	1,960.7	1.7	1.4
01/31/2022 09:00	10.8	13.7	8.9	144.3	3,105,507.3	1,610.1	1.6	1.0
01/31/2022 10:00	10.9	13.7	8.9	136.9	2,875,212.6	1,490.7	1.6	0.9
01/31/2022 11:00	10.8	13.7	8.9	144.1	3,014,662.4	1,563.0	1.6	0.9
01/31/2022 12:00	10.6	13.7	8.7	143.3	3,087,184.0	1,600.6	1.6	1.0
01/31/2022 13:00	10.8	13.8	9.0	125.3	2,822,579.3	1,442.8	1.5	0.9
01/31/2022 14:00	10.4	13.8	8.6	134.3	3,054,207.6	1,561.2	1.5	0.9
01/31/2022 15:00	10.3	13.7	8.4	143.7	3,156,333.0	1,659.5	1.5	1.0
01/31/2022 16:00	10.5	13.3	8.2	164.7	3,398,539.4	2,010.2	1.7	1.4
01/31/2022 17:00	10.4	13.3	8.1	182.5	3,412,605.6	2,118.2	1.8	1.5
01/31/2022 18:00	10.4	13.2	8.0	191.0	3,415,505.5	2,120.0	1.9	1.5
01/31/2022 19:00	9.7	13.4	7.6	158.4	3,403,897.4	1,938.8	1.6	1.2
01/31/2022 20:00	10.2	13.8	8.5	134.2	3,116,694.2	1,615.9	1.4	0.8
01/31/2022 21:00	10.1	13.7	8.3	148.2	3,256,915.5	1,688.6	1.5	1.0
01/31/2022 22:00	10.3	13.4	8.1	169.6	3,442,048.2	2,010.8	1.7	1.4
01/31/2022 23:00	17.3	14.7	16.5	163.6	2,536,962.4	1,222.7	2.1	1.0
Average/Sum#:	13.2	13.9	12.8	150.0	3,052,591.4	1,635.1	1.6	1.1
Minimum:	9.7	13.2	7.6	18.4	1,422,541.5	342.8	0.0	0.0
Maximum:	38.2	17.4	64.4	236.2	3,534,484.3	2,120.0	3.4	1.5
%SI	8.33	8.33	8.33	8.33	8.33	8.33	8.33	8.33

Daily Summary Report

CT1 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm	Unit CT1 O2Dry, Inlet, Pct	Unit CT1 NOx, Inlet, Ppmvdc	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 HI, MBtuPerHr	Unit CT1 NH3, Slip, Ppmvdc	Unit CT1 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/01/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/01/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/01/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/01/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/01/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/01/2022 05:00	44.0	16.9	64.9	202.8	1,482,800.0	465.6	4.1	0.7
02/01/2022 06:00	27.4	14.4	24.9	188.1	2,427,732.7	1,134.6	2.6	1.1
02/01/2022 07:00	10.8	13.5	8.6	171.7	2,939,522.1	1,674.3	2.0	1.3
02/01/2022 08:00	10.8	13.1	8.2	224.5	3,475,392.9	2,360.2	2.3	2.1
02/01/2022 09:00	10.7	13.1	8.1	256.7	3,431,427.9	2,355.4	2.6	2.4
02/01/2022 10:00	10.0	13.5	8.0	177.1	3,458,166.7	1,868.7	1.8	1.3
02/01/2022 11:00	10.8	13.8	9.0	133.1	3,070,053.8	1,569.3	1.4	0.8
02/01/2022 12:00	10.8	13.9	9.1	111.6	2,567,866.4	1,312.6	1.5	0.8
02/01/2022 13:00	10.8	13.9	9.1	113.6	2,567,083.8	1,312.2	1.5	0.8
02/01/2022 14:00	10.8	13.9	9.1	113.1	2,568,648.9	1,313.0	1.5	0.8
02/01/2022 15:00	10.9	13.9	9.2	118.3	2,612,079.2	1,335.2	1.5	0.8
02/01/2022 16:00	10.3	13.8	8.6	136.7	3,049,903.7	1,559.0	1.5	0.9
02/01/2022 17:00	9.4	13.7	7.7	144.8	3,508,040.9	1,818.8	1.4	0.9
02/01/2022 18:00	10.2	13.4	8.0	165.6	3,470,868.3	1,951.6	1.6	1.2
02/01/2022 19:00	10.5	13.3	8.2	176.6	3,480,366.7	2,058.6	1.7	1.4
02/01/2022 20:00	10.1	13.4	7.9	174.9	3,432,804.6	2,005.4	1.8	1.4
02/01/2022 21:00	10.4	13.8	8.6	141.1	3,115,344.0	1,615.2	1.5	1.0
02/01/2022 22:00	9.7	13.7	7.9	147.8	3,469,465.6	1,798.8	1.4	0.9
02/01/2022 23:00	10.4	13.3	8.1	180.9	3,508,465.3	2,049.6	1.8	1.4
Average/Sum#:	13.1	13.8	12.3	162.1	3,033,475.4	1,661.0	1.9	1.2
Minimum:	9.4	13.1	7.7	111.6	1,482,800.0	465.6	1.4	0.7
Maximum:	44.0	16.9	64.9	256.7	3,508,465.3	2,360.2	4.1	2.4
%SI	20.83	20.83	20.83	20.83	20.83	20.83	20.83	20.83

Daily Summary Report

CT1 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm	Unit CT1 O2Dry, Inlet, Pct	Unit CT1 NOx, Inlet, Ppmvdc	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 HI, MBtuPerHr	Unit CT1 NH3, Slip, Ppmvdc	Unit CT1 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/02/2022 00:00	10.4	13.2	8.0	194.4	3,455,199.4	2,195.1	2.0	1.8
02/02/2022 01:00	9.6	13.7	7.9	151.6	3,330,173.8	1,750.9	1.6	1.1
02/02/2022 02:00	10.2	13.8	8.5	135.6	3,103,578.6	1,609.1	1.5	1.0
02/02/2022 03:00	10.3	13.3	8.0	176.1	3,518,380.6	2,029.7	1.7	1.4
02/02/2022 04:00	9.8	13.5	7.8	158.1	3,505,902.0	1,996.9	1.5	1.2
02/02/2022 05:00	10.2	13.3	7.9	194.1	3,471,744.4	2,053.5	1.9	1.4
02/02/2022 06:00	10.5	13.3	8.2	178.4	3,531,277.9	2,114.5	1.7	1.5
02/02/2022 07:00	10.1	13.3	7.8	172.0	3,499,132.9	2,069.7	1.7	1.4
02/02/2022 08:00	10.0	13.4	7.9	172.4	3,533,461.6	2,038.4	1.7	1.4
02/02/2022 09:00	9.8	13.7	8.0	135.5	3,143,297.9	1,675.6	1.5	1.0
02/02/2022 10:00	18.7	15.2	19.4	141.3	2,071,026.1	907.4	2.2	0.7
02/02/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/02/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/02/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/02/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/02/2022 15:00	26.2	18.0	53.3	146.8	1,329,586.6	213.6	0.0	0.0
02/02/2022 16:00	49.9	15.8	57.7	246.2	1,938,283.3	707.7	3.9	1.1
02/02/2022 17:00	9.9	13.6	8.0	159.0	3,286,238.1	1,727.8	1.7	1.2
02/02/2022 18:00	10.4	13.3	8.1	182.4	3,478,671.9	2,083.0	1.8	1.5
02/02/2022 19:00	10.7	13.1	8.1	216.3	3,445,623.9	2,264.5	2.2	1.8
02/02/2022 20:00	10.6	13.1	8.0	221.8	3,423,711.4	2,275.1	2.3	2.0
02/02/2022 21:00	10.4	13.2	8.0	208.2	3,410,956.0	2,191.9	2.1	1.8
02/02/2022 22:00	10.2	13.3	7.9	196.2	3,413,453.3	2,093.8	2.0	1.7
02/02/2022 23:00	10.3	13.3	8.0	177.4	3,446,607.4	2,063.8	1.8	1.4
Average/Sum#:	13.4	13.8	13.3	178.2	3,166,815.4	1,803.1	1.8	1.3
Minimum:	9.6	13.1	7.8	135.5	1,329,586.6	213.6	0.0	0.0
Maximum:	49.9	18.0	57.7	246.2	3,533,461.6	2,275.1	3.9	2.0
%SI	16.67	16.67	16.67	16.67	16.67	16.67	16.67	16.67

Daily Summary Report

CT1 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm	Unit CT1 O2Dry, Inlet, Pct	Unit CT1 NOx, Inlet, Ppmvdc	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 HI, MBtuPerHr	Unit CT1 NH3, Slip, Ppmvdc	Unit CT1 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/03/2022 00:00	9.4	13.5	7.5	159.8	3,460,908.9	1,946.0	1.6	1.2
02/03/2022 01:00	10.2	13.7	8.4	149.1	3,253,058.0	1,686.6	1.6	1.0
02/03/2022 02:00	9.4	13.7	7.7	148.3	3,506,112.2	1,817.8	1.4	0.9
02/03/2022 03:00	10.3	13.3	8.0	173.3	3,451,287.6	2,041.4	1.7	1.4
02/03/2022 04:00	10.2	13.3	7.9	175.8	3,459,508.3	2,021.0	1.8	1.4
02/03/2022 05:00	9.9	13.4	7.8	172.8	3,434,719.2	2,031.6	1.7	1.4
02/03/2022 06:00	10.8	13.1	8.2	196.2	3,479,611.8	2,185.2	2.0	1.7
02/03/2022 07:00	10.3	13.2	7.9	192.1	3,469,045.4	2,127.9	1.9	1.5
02/03/2022 08:00	9.5	13.5	7.6	153.7	3,474,603.1	1,953.7	1.5	1.2
02/03/2022 09:00	10.7	13.8	8.9	131.8	2,849,560.0	1,477.4	1.6	0.9
02/03/2022 10:00	10.3	13.7	8.4	159.8	3,259,037.2	1,689.7	1.7	1.2
02/03/2022 11:00	10.1	13.7	8.3	147.0	3,270,609.8	1,695.7	1.5	1.0
02/03/2022 12:00	10.8	13.8	9.0	115.5	2,749,804.2	1,405.6	1.4	0.7
02/03/2022 13:00	10.4	13.8	8.6	134.3	3,079,835.4	1,574.3	1.5	0.9
02/03/2022 14:00	10.5	13.8	8.7	126.3	2,922,742.9	1,494.0	1.5	0.9
02/03/2022 15:00	10.7	13.7	8.8	144.3	3,000,582.4	1,555.7	1.6	0.9
02/03/2022 16:00	10.7	13.3	8.3	169.1	3,394,820.0	2,008.0	1.7	1.4
02/03/2022 17:00	10.5	13.3	8.2	184.9	3,380,383.8	2,098.2	1.9	1.5
02/03/2022 18:00	10.4	13.2	8.0	195.9	3,420,694.7	2,148.2	2.0	1.7
02/03/2022 19:00	10.4	13.2	8.0	199.4	3,425,471.8	2,151.2	2.0	1.7
02/03/2022 20:00	10.4	13.2	8.0	190.8	3,429,452.7	2,153.7	1.9	1.5
02/03/2022 21:00	10.4	13.2	8.0	207.0	3,409,251.2	2,215.7	2.1	1.8
02/03/2022 22:00	10.3	13.2	7.9	192.9	3,425,816.5	2,126.4	2.0	1.7
02/03/2022 23:00	10.3	13.3	8.0	184.8	3,426,332.4	2,101.7	1.9	1.5
Average/Sum#:	10.3	13.5	8.2	166.9	3,309,718.7	1,904.4	1.7	1.3
Minimum:	9.4	13.1	7.5	115.5	2,749,804.2	1,405.6	1.4	0.7
Maximum:	10.8	13.8	9.0	207.0	3,506,112.2	2,215.7	2.1	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm	Unit CT1 O2Dry, Inlet, Pct	Unit CT1 NOx, Inlet, Ppmvdc	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 HI, MBtuPerHr	Unit CT1 NH3, Slip, Ppmvdc	Unit CT1 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/04/2022 00:00	10.2	13.3	7.9	176.3	3,444,269.3	2,062.4	1.8	1.4
02/04/2022 01:00	9.5	13.5	7.6	157.7	3,450,060.2	1,939.9	1.6	1.2
02/04/2022 02:00	10.5	13.7	8.6	146.5	3,142,925.4	1,629.5	1.6	1.0
02/04/2022 03:00	10.7	13.7	8.8	140.1	3,004,825.7	1,557.9	1.6	0.9
02/04/2022 04:00	10.1	13.7	8.3	134.2	3,121,516.1	1,618.4	1.5	1.0
02/04/2022 05:00	9.7	13.4	7.6	159.6	3,436,578.9	2,032.7	1.6	1.2
02/04/2022 06:00	10.6	13.2	8.1	190.3	3,453,782.7	2,194.2	1.9	1.5
02/04/2022 07:00	9.9	13.3	7.7	179.4	3,461,508.9	2,098.0	1.8	1.5
02/04/2022 08:00	17.0	14.9	16.7	162.7	2,610,166.3	1,200.8	2.0	1.0
02/04/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/04/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/04/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/04/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/04/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/04/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/04/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/04/2022 16:00	49.0	16.1	60.2	198.9	1,866,585.0	627.0	3.2	0.8
02/04/2022 17:00	14.5	13.8	12.0	180.1	3,076,441.6	1,550.1	2.0	1.2
02/04/2022 18:00	10.5	13.8	8.7	133.9	2,909,635.6	1,487.3	1.6	0.9
02/04/2022 19:00	10.0	13.4	7.9	157.9	3,396,172.5	1,909.6	1.6	1.1
02/04/2022 20:00	9.9	13.5	7.9	160.3	3,428,652.4	1,952.9	1.6	1.2
02/04/2022 21:00	9.7	13.5	7.7	153.7	3,464,999.4	1,948.3	1.5	1.2
02/04/2022 22:00	9.9	13.4	7.8	166.0	3,468,330.6	1,975.5	1.6	1.2
02/04/2022 23:00	10.4	13.3	8.1	177.6	3,433,080.1	2,055.7	1.8	1.4
Average/Sum#:	13.1	13.7	11.9	163.2	3,186,443.0	1,755.3	1.8	1.2
Minimum:	9.5	13.2	7.6	133.9	1,866,585.0	627.0	1.5	0.8
Maximum:	49.0	16.1	60.2	198.9	3,468,330.6	2,194.2	3.2	1.5
%SI	29.17	29.17	29.17	29.17	29.17	29.17	29.17	29.17

Daily Summary Report

CT1 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm	Unit CT1 O2Dry, Inlet, Pct	Unit CT1 NOx, Inlet, Ppmvdc	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 HI, MBtuPerHr	Unit CT1 NH3, Slip, Ppmvdc	Unit CT1 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/05/2022 00:00	9.6	13.5	7.7	154.2	3,471,757.6	1,952.1	1.5	1.2
02/05/2022 01:00	10.1	13.7	8.3	157.8	3,270,641.9	1,719.6	1.7	1.2
02/05/2022 02:00	10.6	13.8	8.8	131.3	2,787,952.4	1,425.1	1.6	0.9
02/05/2022 03:00	9.6	13.5	7.7	147.1	3,455,634.3	1,917.8	1.4	1.0
02/05/2022 04:00	9.6	13.5	7.7	156.9	3,490,253.7	1,962.5	1.5	1.2
02/05/2022 05:00	9.9	13.6	8.0	164.6	3,352,196.6	1,738.0	1.7	1.2
02/05/2022 06:00	10.3	13.8	8.6	131.8	3,127,302.4	1,621.4	1.4	0.8
02/05/2022 07:00	10.4	13.3	8.1	173.5	3,451,625.7	2,041.6	1.7	1.4
02/05/2022 08:00	16.7	14.7	15.9	153.1	2,598,114.1	1,233.2	1.9	0.9
02/05/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/05/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/05/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/05/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/05/2022 13:00	37.2	17.6	66.5	193.5	1,442,297.3	294.9	0.0	0.0
02/05/2022 14:00	42.2	15.4	45.3	244.9	2,172,566.4	856.7	3.6	1.2
02/05/2022 15:00	10.6	13.8	8.8	114.2	2,689,549.5	1,374.8	1.4	0.7
02/05/2022 16:00	10.7	13.8	8.9	127.9	2,799,103.4	1,430.8	1.5	0.9
02/05/2022 17:00	10.3	13.7	8.4	147.9	3,129,038.3	1,622.3	1.6	1.0
02/05/2022 18:00	10.3	13.7	8.4	138.9	3,104,928.7	1,609.8	1.5	1.0
02/05/2022 19:00	10.8	13.9	9.1	114.4	2,618,974.5	1,319.6	1.5	0.8
02/05/2022 20:00	10.3	13.7	8.4	140.6	3,034,914.5	1,573.5	1.6	0.9
02/05/2022 21:00	10.6	13.3	8.2	176.9	3,403,854.6	2,038.2	1.8	1.4
02/05/2022 22:00	10.5	13.3	8.2	184.5	3,430,742.1	2,054.3	1.9	1.4
02/05/2022 23:00	10.3	13.3	8.0	172.2	3,441,931.3	2,061.0	1.7	1.4
Average/Sum#:	13.5	13.9	13.5	156.3	3,013,669.0	1,592.4	1.6	1.0
Minimum:	9.6	13.3	7.7	114.2	1,442,297.3	294.9	0.0	0.0
Maximum:	42.2	17.6	66.5	244.9	3,490,253.7	2,061.0	3.6	1.4
%SI	16.67	16.67	16.67	16.67	16.67	16.67	16.67	16.67

Daily Summary Report

CT1 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm	Unit CT1 O2Dry, Inlet, Pct	Unit CT1 NOx, Inlet, Ppmvdc	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 HI, MBtuPerHr	Unit CT1 NH3, Slip, Ppmvdc	Unit CT1 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/06/2022 00:00	9.7	13.5	7.7	160.7	3,463,576.6	1,947.5	1.6	1.2
02/06/2022 01:00	10.4	13.7	8.5	155.5	3,275,045.9	1,698.0	1.6	1.0
02/06/2022 02:00	10.2	13.7	8.4	139.6	3,162,791.7	1,639.8	1.5	1.0
02/06/2022 03:00	10.1	13.3	7.8	169.3	3,449,408.8	2,015.1	1.7	1.4
02/06/2022 04:00	9.5	13.5	7.6	148.7	3,456,107.0	1,943.3	1.5	1.2
02/06/2022 05:00	10.5	13.7	8.6	148.9	3,057,673.9	1,585.3	1.7	1.1
02/06/2022 06:00	11.3	13.8	9.4	114.0	2,609,340.3	1,333.8	1.5	0.8
02/06/2022 07:00	10.9	13.7	8.9	145.3	3,035,300.2	1,573.7	1.6	0.9
02/06/2022 08:00	29.4	16.5	39.4	188.2	1,283,150.6	468.5	4.7	0.8
02/06/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/06/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/06/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/06/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/06/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/06/2022 14:00	39.1	17.5	67.9	180.3	1,436,526.2	314.7	0.0	0.0
02/06/2022 15:00	40.5	15.4	43.4	241.5	2,150,503.5	848.0	3.6	1.2
02/06/2022 16:00	10.6	13.8	8.8	117.4	2,736,109.9	1,398.6	1.4	0.7
02/06/2022 17:00	10.4	13.4	8.2	177.0	3,348,687.2	1,882.9	1.8	1.3
02/06/2022 18:00	10.3	13.3	8.0	177.6	3,371,904.2	1,945.2	1.8	1.4
02/06/2022 19:00	10.0	13.4	7.9	172.0	3,414,431.5	1,944.8	1.7	1.4
02/06/2022 20:00	10.0	13.4	7.9	170.5	3,412,675.8	1,943.8	1.7	1.4
02/06/2022 21:00	10.0	13.4	7.9	168.9	3,394,767.9	1,933.6	1.7	1.4
02/06/2022 22:00	10.3	13.7	8.4	139.0	3,200,402.6	1,659.3	1.5	1.0
02/06/2022 23:00	28.1	16.6	38.6	192.5	1,201,955.2	421.3	5.3	0.8
Average/Sum#:	15.3	14.2	16.5	163.5	2,866,334.7	1,499.9	2.0	1.1
Minimum:	9.5	13.3	7.6	114.0	1,201,955.2	314.7	0.0	0.0
Maximum:	40.5	17.5	67.9	241.5	3,463,576.6	2,015.1	5.3	1.4
%SI	20.83	20.83	20.83	20.83	20.83	20.83	20.83	20.83

Daily Summary Report

CT1 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm	Unit CT1 O2Dry, Inlet, Pct	Unit CT1 NOx, Inlet, Ppmvdc	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 HI, MBtuPerHr	Unit CT1 NH3, Slip, Ppmvdc	Unit CT1 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/07/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/07/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/07/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/07/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/07/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/07/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/07/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/07/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/07/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/07/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/07/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/07/2022 11:00	35.8	17.6	64.0	28.9	1,331,993.5	291.8	0.0	0.0
02/07/2022 12:00	37.4	17.4	63.0	250.2	1,340,424.8	332.8	5.9	0.8
02/07/2022 13:00	39.2	15.6	43.6	250.4	2,097,062.8	796.3	3.8	1.2
02/07/2022 14:00	10.8	13.8	9.0	117.1	2,709,699.6	1,385.1	1.4	0.7
02/07/2022 15:00	11.0	13.8	9.1	117.7	2,709,112.7	1,384.8	1.5	0.8
02/07/2022 16:00	10.5	13.7	8.6	157.3	3,149,676.1	1,656.0	1.7	1.2
02/07/2022 17:00	10.4	13.8	8.6	129.8	3,097,442.3	1,583.3	1.4	0.8
02/07/2022 18:00	11.0	13.8	9.1	123.2	2,783,648.5	1,422.9	1.5	0.9
02/07/2022 19:00	10.4	13.7	8.5	142.8	3,079,083.2	1,596.4	1.6	1.0
02/07/2022 20:00	10.4	13.3	8.1	168.5	3,429,830.6	2,078.8	1.7	1.5
02/07/2022 21:00	10.3	13.3	8.0	182.5	3,428,940.8	2,103.3	1.8	1.5
02/07/2022 22:00	10.2	13.3	7.9	179.3	3,447,814.6	2,089.7	1.8	1.5
02/07/2022 23:00	17.3	14.7	16.5	166.1	2,555,221.4	1,231.5	2.1	1.0
Average/Sum#:	17.3	14.4	20.3	154.9	2,704,611.6	1,381.0	2.0	1.0
Minimum:	10.2	13.3	7.9	28.9	1,331,993.5	291.8	0.0	0.0
Maximum:	39.2	17.6	64.0	250.4	3,447,814.6	2,103.3	5.9	1.5
%SI	45.83	45.83	45.83	45.83	45.83	45.83	45.83	45.83

Daily Summary Report

CT1 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm	Unit CT1 O2Dry, Inlet, Pct	Unit CT1 NOx, Inlet, Ppmvdc	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 HI, MBtuPerHr	Unit CT1 NH3, Slip, Ppmvdc	Unit CT1 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/08/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/08/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/08/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/08/2022 03:00	37.9	17.4	63.9	243.7	1,538,034.8	359.4	4.7	0.6
02/08/2022 04:00	24.2	14.4	22.0	187.0	2,627,369.1	1,227.9	2.3	1.1
02/08/2022 05:00	10.7	13.8	8.9	123.2	2,754,499.3	1,408.0	1.5	0.8
02/08/2022 06:00	10.9	13.8	9.1	120.7	2,737,088.1	1,399.1	1.5	0.8
02/08/2022 07:00	10.8	13.9	9.1	107.0	2,537,347.8	1,297.0	1.4	0.6
02/08/2022 08:00	10.1	13.7	8.3	146.2	3,517,299.0	1,823.6	1.4	0.9
02/08/2022 09:00	9.9	13.6	8.0	152.7	3,505,155.8	1,842.9	1.5	1.1
02/08/2022 10:00	10.1	13.5	8.1	158.4	3,505,916.6	1,843.3	1.5	1.1
02/08/2022 11:00	10.0	13.5	8.0	156.0	3,502,112.7	1,841.3	1.5	1.1
02/08/2022 12:00	10.1	13.5	8.1	159.6	3,477,024.8	1,853.5	1.6	1.1
02/08/2022 13:00	10.1	13.5	8.1	160.4	3,479,463.5	1,854.8	1.6	1.1
02/08/2022 14:00	10.1	13.5	8.1	159.4	3,482,089.8	1,856.2	1.6	1.1
02/08/2022 15:00	9.8	13.6	7.9	149.5	3,481,000.7	1,830.2	1.5	1.1
02/08/2022 16:00	9.9	13.6	8.0	154.7	3,472,822.2	1,825.9	1.5	1.1
02/08/2022 17:00	10.2	13.4	8.0	155.2	3,450,060.2	1,939.9	1.5	1.2
02/08/2022 18:00	10.2	13.3	7.9	169.0	3,454,544.2	2,018.1	1.7	1.4
02/08/2022 19:00	9.9	13.4	7.8	155.4	3,481,673.7	1,983.1	1.5	1.2
02/08/2022 20:00	9.9	13.4	7.8	164.5	3,494,841.3	1,990.6	1.6	1.2
02/08/2022 21:00	10.1	13.6	8.2	139.8	3,181,505.9	1,719.2	1.5	1.0
02/08/2022 22:00	10.5	13.8	8.7	117.8	2,793,430.1	1,427.9	1.4	0.7
02/08/2022 23:00	10.7	13.8	8.9	118.8	2,711,264.6	1,385.9	1.5	0.8
Average/Sum#:	12.2	13.8	11.6	152.3	3,151,645.0	1,653.7	1.7	1.0
Minimum:	9.8	13.3	7.8	107.0	1,538,034.8	359.4	1.4	0.6
Maximum:	37.9	17.4	63.9	243.7	3,517,299.0	2,018.1	4.7	1.4
%SI	12.50	12.50	12.50	12.50	12.50	12.50	12.50	12.50

Daily Summary Report

CT1 - NH3 Slip



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm	Unit CT1 O2Dry, Inlet, Pct	Unit CT1 NOx, Inlet, Ppmvdc	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 HI, MBtuPerHr	Unit CT1 NH3, Slip, Ppmvdc	Unit CT1 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/09/2022 00:00	10.7	13.8	8.9	116.7	2,720,850.6	1,390.8	1.4	0.7
02/09/2022 01:00	10.7	13.8	8.9	114.4	2,735,131.8	1,398.1	1.4	0.7
02/09/2022 02:00	10.7	13.8	8.9	116.9	2,728,284.6	1,394.6	1.4	0.7
02/09/2022 03:00	10.7	13.8	8.9	117.9	2,719,676.8	1,390.2	1.5	0.8
02/09/2022 04:00	10.7	13.8	8.9	114.3	2,717,720.5	1,389.2	1.4	0.7
02/09/2022 05:00	10.7	13.8	8.9	114.6	2,712,829.7	1,386.7	1.4	0.7
02/09/2022 06:00	11.1	13.8	9.2	122.2	2,771,323.7	1,416.6	1.5	0.8
02/09/2022 07:00	10.0	13.6	8.1	168.0	3,499,069.5	1,839.7	1.6	1.1
02/09/2022 08:00	9.9	13.6	8.0	156.5	3,525,507.0	1,853.6	1.5	1.1
02/09/2022 09:00	10.3	13.5	8.2	171.9	3,512,104.6	1,872.2	1.7	1.3
02/09/2022 10:00	10.2	13.5	8.1	178.9	3,496,722.0	1,864.0	1.8	1.3
02/09/2022 11:00	11.0	13.0	8.2	235.6	3,423,249.7	2,199.8	2.4	2.0
02/09/2022 12:00	10.8	13.1	8.2	220.9	3,321,090.2	2,109.9	2.3	1.9
02/09/2022 13:00	9.9	13.5	7.9	163.5	3,458,828.3	1,843.8	1.6	1.1
02/09/2022 14:00	10.1	13.5	8.1	170.4	3,460,141.5	1,844.5	1.7	1.3
02/09/2022 15:00	10.5	13.7	8.6	146.0	3,185,358.3	1,651.5	1.6	1.0
02/09/2022 16:00	10.2	13.6	8.2	159.9	3,328,081.6	1,749.8	1.6	1.0
02/09/2022 17:00	10.1	13.6	8.2	155.3	3,278,059.6	1,723.5	1.6	1.0
02/09/2022 18:00	9.7	13.6	7.8	156.0	3,477,006.6	1,828.1	1.5	1.1
02/09/2022 19:00	10.4	13.2	8.0	169.3	3,448,075.3	2,039.5	1.7	1.4
02/09/2022 20:00	10.4	13.2	8.0	183.1	3,443,776.3	2,112.4	1.8	1.5
02/09/2022 21:00	10.3	13.1	7.8	181.0	3,411,155.6	2,117.3	1.8	1.5
02/09/2022 22:00	10.0	13.3	7.8	177.7	3,413,373.8	2,043.9	1.8	1.4
02/09/2022 23:00	10.3	13.7	8.4	130.2	2,941,409.5	1,546.5	1.5	0.9
Average/Sum#:	10.4	13.5	8.3	155.9	3,197,034.5	1,750.3	1.6	1.1
Minimum:	9.7	13.0	7.8	114.3	2,712,829.7	1,386.7	1.4	0.7
Maximum:	11.1	13.8	9.2	235.6	3,525,507.0	2,199.8	2.4	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm	Unit CT1 O2Dry, Inlet, Pct	Unit CT1 NOx, Inlet, Ppmvdc	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 HI, MBtuPerHr	Unit CT1 NH3, Slip, Ppmvdc	Unit CT1 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/10/2022 00:00	10.6	13.8	8.8	119.3	2,706,178.2	1,383.3	1.5	0.8
02/10/2022 01:00	10.4	13.7	8.5	152.9	3,089,573.6	1,624.4	1.7	1.1
02/10/2022 02:00	10.1	13.3	7.8	169.5	3,459,270.0	1,995.6	1.7	1.4
02/10/2022 03:00	10.1	13.3	7.8	166.9	3,432,119.9	2,005.0	1.7	1.4
02/10/2022 04:00	10.7	13.7	8.8	154.4	3,146,204.3	1,631.2	1.7	1.1
02/10/2022 05:00	10.8	13.7	8.9	162.6	3,077,020.5	1,617.8	1.8	1.1
02/10/2022 06:00	10.6	13.2	8.1	168.5	3,443,854.8	2,087.3	1.7	1.5
02/10/2022 07:00	10.2	13.3	7.9	178.9	3,389,077.9	2,054.1	1.8	1.4
02/10/2022 08:00	24.7	16.0	29.7	176.5	1,608,686.1	622.6	3.5	0.8
02/10/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/10/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/10/2022 11:00	20.8	18.0	42.3	197.8	998,995.1	145.9	6.5	0.4
02/10/2022 12:00	44.7	15.5	48.8	261.2	2,134,458.6	810.5	3.8	1.2
02/10/2022 13:00	10.3	13.8	8.6	111.9	2,733,762.3	1,397.4	1.4	0.7
02/10/2022 14:00	10.5	13.8	8.7	116.7	2,725,937.1	1,393.4	1.4	0.7
02/10/2022 15:00	10.4	13.7	8.5	154.4	3,130,656.3	1,646.0	1.7	1.2
02/10/2022 16:00	10.6	13.7	8.7	148.8	3,099,528.1	1,607.0	1.6	1.0
02/10/2022 17:00	10.7	13.6	8.6	140.0	2,823,859.8	1,587.8	1.7	1.1
02/10/2022 18:00	10.6	13.0	7.9	220.7	3,372,717.4	2,315.1	2.3	2.1
02/10/2022 19:00	10.4	13.0	7.8	215.6	3,392,004.7	2,278.8	2.2	1.8
02/10/2022 20:00	10.3	13.1	7.8	199.3	3,375,246.4	2,193.6	2.1	1.8
02/10/2022 21:00	10.2	13.2	7.8	184.5	3,422,571.0	2,074.4	1.9	1.5
02/10/2022 22:00	10.0	13.2	7.7	173.7	3,407,695.7	2,040.5	1.8	1.4
02/10/2022 23:00	10.5	13.7	8.6	138.1	2,887,046.7	1,539.0	1.6	0.9
Average/Sum#:	13.1	13.9	12.6	168.7	2,948,021.1	1,638.7	2.1	1.2
Minimum:	10.0	13.0	7.7	111.9	998,995.1	145.9	1.4	0.4
Maximum:	44.7	18.0	48.8	261.2	3,459,270.0	2,315.1	6.5	2.1
%SI	8.33	8.33	8.33	8.33	8.33	8.33	8.33	8.33

Daily Summary Report

CT1 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm	Unit CT1 O2Dry, Inlet, Pct	Unit CT1 NOx, Inlet, Ppmvdc	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 HI, MBtuPerHr	Unit CT1 NH3, Slip, Ppmvdc	Unit CT1 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/11/2022 00:00	10.8	13.8	9.0	114.8	2,590,950.9	1,324.4	1.5	0.8
02/11/2022 01:00	27.7	16.9	40.9	195.3	1,078,272.9	362.2	6.0	0.8
02/11/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/11/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/11/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/11/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/11/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/11/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/11/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/11/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/11/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/11/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/11/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/11/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/11/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/11/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/11/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/11/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/11/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/11/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/11/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/11/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/11/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/11/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	19.3	15.4	25.0	155.1	1,834,611.9	843.3	3.8	0.8
Minimum:	10.8	13.8	9.0	114.8	1,078,272.9	362.2	1.5	0.8
Maximum:	27.7	16.9	40.9	195.3	2,590,950.9	1,324.4	6.0	0.8
%SI	91.67	91.67	91.67	91.67	91.67	91.67	91.67	91.67

Daily Summary Report

CT1 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm	Unit CT1 O2Dry, Inlet, Pct	Unit CT1 NOx, Inlet, Ppmvdc	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 HI, MBtuPerHr	Unit CT1 NH3, Slip, Ppmvdc	Unit CT1 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/12/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/12/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/12/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/12/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/12/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/12/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/12/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/12/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/12/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/12/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/12/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/12/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/12/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/12/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/12/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/12/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/12/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/12/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/12/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/12/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/12/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/12/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/12/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/12/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm	Unit CT1 O2Dry, Inlet, Pct	Unit CT1 NOx, Inlet, Ppmvdc	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 HI, MBtuPerHr	Unit CT1 NH3, Slip, Ppmvdc	Unit CT1 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/13/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/13/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/13/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/13/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/13/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/13/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/13/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/13/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/13/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/13/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/13/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/13/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/13/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/13/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/13/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/13/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/13/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/13/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/13/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/13/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/13/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/13/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/13/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/13/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm	Unit CT1 O2Dry, Inlet, Pct	Unit CT1 NOx, Inlet, Ppmvdc	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 HI, MBtuPerHr	Unit CT1 NH3, Slip, Ppmvdc	Unit CT1 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/14/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/14/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/14/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/14/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/14/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/14/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/14/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/14/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/14/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/14/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/14/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/14/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/14/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/14/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/14/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/14/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/14/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/14/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/14/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/14/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/14/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/14/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/14/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/14/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm	Unit CT1 O2Dry, Inlet, Pct	Unit CT1 NOx, Inlet, Ppmvdc	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 HI, MBtuPerHr	Unit CT1 NH3, Slip, Ppmvdc	Unit CT1 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/15/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm	Unit CT1 O2Dry, Inlet, Pct	Unit CT1 NOx, Inlet, Ppmvdc	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 HI, MBtuPerHr	Unit CT1 NH3, Slip, Ppmvdc	Unit CT1 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/16/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm	Unit CT1 O2Dry, Inlet, Pct	Unit CT1 NOx, Inlet, Ppmvdc	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 HI, MBtuPerHr	Unit CT1 NH3, Slip, Ppmvdc	Unit CT1 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/17/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/17/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/17/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/17/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/17/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/17/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/17/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/17/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/17/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/17/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/17/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/17/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/17/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/17/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/17/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/17/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/17/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/17/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/17/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/17/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/17/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/17/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/17/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/17/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm	Unit CT1 O2Dry, Inlet, Pct	Unit CT1 NOx, Inlet, Ppmvdc	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 HI, MBtuPerHr	Unit CT1 NH3, Slip, Ppmvdc	Unit CT1 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/18/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/18/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/18/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/18/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/18/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/18/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/18/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/18/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/18/2022 08:00	16.4	18.4	38.7	0.0	1,000,535.7	116.9	0.0	0.0
02/18/2022 09:00	41.7	17.2	66.5	52.1	1,404,955.4	379.6	0.0	0.0
02/18/2022 10:00	37.3	17.2	59.5	264.9	1,455,291.0	393.2	5.8	0.9
02/18/2022 11:00	47.4	16.1	58.3	261.8	1,992,949.5	684.0	4.1	1.1
02/18/2022 12:00	37.1	14.9	36.5	230.6	2,335,448.8	1,006.2	3.2	1.2
02/18/2022 13:00	10.0	13.9	8.4	123.6	2,727,306.5	1,394.1	1.5	0.8
02/18/2022 14:00	10.2	13.9	8.6	121.4	2,730,632.2	1,395.8	1.5	0.8
02/18/2022 15:00	9.4	13.7	7.7	160.8	3,379,006.4	1,751.9	1.6	1.1
02/18/2022 16:00	10.7	13.7	8.8	161.9	3,081,204.9	1,597.5	1.8	1.1
02/18/2022 17:00	9.8	13.8	8.1	146.9	3,244,362.0	1,658.4	1.5	1.0
02/18/2022 18:00	10.1	13.7	8.3	141.4	3,075,997.2	1,594.8	1.6	1.0
02/18/2022 19:00	10.2	13.3	7.9	183.9	3,444,355.9	2,037.3	1.8	1.4
02/18/2022 20:00	9.6	13.4	7.6	164.6	3,438,484.2	1,958.5	1.6	1.2
02/18/2022 21:00	10.8	13.7	8.9	152.0	3,044,944.0	1,578.7	1.7	1.1
02/18/2022 22:00	10.1	13.7	8.3	141.5	3,104,928.7	1,609.8	1.5	1.0
02/18/2022 23:00	9.9	13.3	7.7	174.3	3,481,932.7	2,034.1	1.7	1.4
Average/Sum#:	18.2	14.6	21.9	155.1	2,683,895.9	1,324.4	1.9	0.9
Minimum:	9.4	13.3	7.6	0.0	1,000,535.7	116.9	0.0	0.0
Maximum:	47.4	18.4	66.5	264.9	3,481,932.7	2,037.3	5.8	1.4
%SI	33.33	33.33	33.33	33.33	33.33	33.33	33.33	33.33

Daily Summary Report

CT1 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm	Unit CT1 O2Dry, Inlet, Pct	Unit CT1 NOx, Inlet, Ppmvdc	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 HI, MBtuPerHr	Unit CT1 NH3, Slip, Ppmvdc	Unit CT1 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/19/2022 00:00	16.7	14.7	15.9	164.5	2,615,185.6	1,260.4	2.1	1.0
02/19/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/19/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/19/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/19/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/19/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/19/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/19/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/19/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/19/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/19/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/19/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/19/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/19/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/19/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/19/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/19/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/19/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/19/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/19/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/19/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/19/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/19/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/19/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	16.7	14.7	15.9	164.5	2,615,185.6	1,260.4	2.1	1.0
Minimum:	16.7	14.7	15.9	164.5	2,615,185.6	1,260.4	2.1	1.0
Maximum:	16.7	14.7	15.9	164.5	2,615,185.6	1,260.4	2.1	1.0
%SI	95.83	95.83	95.83	95.83	95.83	95.83	95.83	95.83

Daily Summary Report

CT1 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm	Unit CT1 O2Dry, Inlet, Pct	Unit CT1 NOx, Inlet, Ppmvdc	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 HI, MBtuPerHr	Unit CT1 NH3, Slip, Ppmvdc	Unit CT1 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/20/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/20/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/20/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/20/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/20/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/20/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/20/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/20/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/20/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/20/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/20/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/20/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/20/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/20/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/20/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/20/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/20/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/20/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/20/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/20/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/20/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/20/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/20/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/20/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm	Unit CT1 O2Dry, Inlet, Pct	Unit CT1 NOx, Inlet, Ppmvdc	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 HI, MBtuPerHr	Unit CT1 NH3, Slip, Ppmvdc	Unit CT1 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/21/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/21/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/21/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/21/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/21/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/21/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/21/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/21/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/21/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/21/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/21/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/21/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/21/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/21/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/21/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/21/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/21/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/21/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/21/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/21/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/21/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/21/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/21/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/21/2022 23:00	38.4	17.5	66.6	0.1	1,347,430.6	324.7	0.0	0.0
Average/Sum#:	38.4	17.5	66.6	0.1	1,347,430.6	324.7	0.0	0.0
Minimum:	38.4	17.5	66.6	0.1	1,347,430.6	324.7	0.0	0.0
Maximum:	38.4	17.5	66.6	0.1	1,347,430.6	324.7	0.0	0.0
%SI	95.83	95.83	95.83	95.83	95.83	95.83	95.83	95.83

Daily Summary Report

CT1 - NH3 Slip



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm	Unit CT1 O2Dry, Inlet, Pct	Unit CT1 NOx, Inlet, Ppmvdc	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 HI, MBtuPerHr	Unit CT1 NH3, Slip, Ppmvdc	Unit CT1 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/22/2022 00:00	39.6	17.2	63.1	193.5	1,411,247.3	381.3	0.0	0.0
02/22/2022 01:00	40.2	16.0	48.4	262.3	2,011,627.4	705.1	4.1	1.1
02/22/2022 02:00	10.6	13.8	8.8	135.4	2,802,883.8	1,453.2	1.6	0.9
02/22/2022 03:00	10.9	13.8	9.1	144.3	2,816,770.9	1,460.4	1.7	1.0
02/22/2022 04:00	10.2	13.7	8.4	166.0	3,228,037.6	1,697.2	1.8	1.2
02/22/2022 05:00	10.5	13.7	8.6	162.5	3,052,852.0	1,582.8	1.8	1.1
02/22/2022 06:00	9.8	13.7	8.0	145.4	3,402,730.3	1,764.2	1.4	0.9
02/22/2022 07:00	10.6	13.7	8.7	137.8	3,090,077.2	1,602.1	1.5	1.0
02/22/2022 08:00	10.8	13.7	8.9	160.8	3,219,497.4	1,669.2	1.7	1.2
02/22/2022 09:00	10.9	13.7	8.9	142.4	3,025,463.5	1,568.6	1.6	0.9
02/22/2022 10:00	10.8	13.7	8.9	136.5	2,983,995.0	1,547.1	1.5	0.9
02/22/2022 11:00	10.8	13.7	8.9	136.0	2,985,538.0	1,547.9	1.5	0.9
02/22/2022 12:00	10.5	13.7	8.6	146.9	3,136,560.5	1,626.2	1.6	1.0
02/22/2022 13:00	10.5	13.7	8.6	149.6	3,107,436.1	1,611.1	1.6	1.0
02/22/2022 14:00	10.6	13.7	8.7	149.2	3,145,818.5	1,631.0	1.6	1.0
02/22/2022 15:00	10.6	13.7	8.7	153.0	3,174,171.4	1,645.7	1.6	1.0
02/22/2022 16:00	10.3	13.7	8.4	145.5	3,186,901.3	1,652.3	1.5	1.0
02/22/2022 17:00	10.0	13.3	7.8	173.4	3,543,427.9	2,095.9	1.7	1.5
02/22/2022 18:00	9.7	13.3	7.5	167.3	3,516,414.6	2,105.6	1.6	1.3
02/22/2022 19:00	10.1	13.2	7.7	193.0	3,543,425.9	2,199.4	1.9	1.5
02/22/2022 20:00	10.2	13.1	7.7	220.7	3,517,915.8	2,337.7	2.2	1.9
02/22/2022 21:00	9.9	13.2	7.6	183.4	3,517,970.7	2,183.6	1.8	1.5
02/22/2022 22:00	9.9	13.2	7.6	185.8	3,502,504.2	2,174.0	1.8	1.5
02/22/2022 23:00	9.9	13.2	7.6	198.4	3,495,022.9	2,220.4	2.0	1.8
Average/Sum#:	12.8	13.8	12.3	166.2	3,100,762.1	1,685.9	1.7	1.1
Minimum:	9.7	13.1	7.5	135.4	1,411,247.3	381.3	0.0	0.0
Maximum:	40.2	17.2	63.1	262.3	3,543,427.9	2,337.7	4.1	1.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm	Unit CT1 O2Dry, Inlet, Pct	Unit CT1 NOx, Inlet, Ppmvdc	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 HI, MBtuPerHr	Unit CT1 NH3, Slip, Ppmvdc	Unit CT1 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/23/2022 00:00	10.1	13.1	7.6	212.9	3,503,596.2	2,302.6	2.1	1.8
02/23/2022 01:00	9.9	13.2	7.6	198.8	3,486,896.8	2,240.7	2.0	1.8
02/23/2022 02:00	9.9	13.2	7.6	200.1	3,500,532.1	2,223.9	2.0	1.8
02/23/2022 03:00	9.8	13.3	7.6	176.8	3,494,537.2	2,092.5	1.8	1.5
02/23/2022 04:00	10.1	13.7	8.3	159.1	3,347,760.4	1,735.7	1.6	1.0
02/23/2022 05:00	9.6	13.6	7.8	152.5	3,427,344.9	1,902.1	1.5	1.1
02/23/2022 06:00	10.4	13.2	8.0	202.3	3,578,815.5	2,247.5	2.0	1.8
02/23/2022 07:00	10.2	13.2	7.8	197.1	3,538,151.9	2,247.8	1.9	1.6
02/23/2022 08:00	10.2	13.6	8.2	157.3	3,246,473.8	1,730.6	1.7	1.2
02/23/2022 09:00	10.6	13.7	8.7	142.4	3,018,712.8	1,565.1	1.6	0.9
02/23/2022 10:00	10.4	13.7	8.5	136.8	3,139,260.7	1,627.6	1.5	1.0
02/23/2022 11:00	10.3	13.7	8.4	154.1	3,263,280.4	1,691.9	1.6	1.0
02/23/2022 12:00	10.6	13.8	8.8	142.4	3,046,186.7	1,557.1	1.6	0.9
02/23/2022 13:00	10.7	13.8	8.9	119.7	2,855,249.8	1,459.5	1.4	0.7
02/23/2022 14:00	10.3	13.8	8.6	155.5	3,222,583.5	1,670.8	1.6	1.0
02/23/2022 15:00	10.3	13.8	8.6	140.7	3,159,512.8	1,638.1	1.5	1.0
02/23/2022 16:00	10.1	13.8	8.4	148.3	3,205,996.1	1,662.2	1.6	1.0
02/23/2022 17:00	9.9	13.4	7.8	177.1	3,550,449.4	2,048.2	1.7	1.4
02/23/2022 18:00	10.1	13.3	7.8	181.4	3,539,201.2	2,093.4	1.8	1.5
02/23/2022 19:00	10.0	13.3	7.8	182.9	3,584,981.9	2,094.3	1.8	1.5
02/23/2022 20:00	10.2	13.2	7.8	193.3	3,536,014.9	2,194.8	1.9	1.5
02/23/2022 21:00	10.4	13.1	7.9	235.7	3,505,726.4	2,355.2	2.4	2.1
02/23/2022 22:00	10.0	13.2	7.7	195.5	3,530,567.1	2,217.2	1.9	1.6
02/23/2022 23:00	9.7	13.3	7.5	188.3	3,581,622.2	2,170.8	1.8	1.5
Average/Sum#:	10.2	13.5	8.1	173.0	3,369,310.6	1,948.7	1.8	1.3
Minimum:	9.6	13.1	7.5	119.7	2,855,249.8	1,459.5	1.4	0.7
Maximum:	10.7	13.8	8.9	235.7	3,584,981.9	2,355.2	2.4	2.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm	Unit CT1 O2Dry, Inlet, Pct	Unit CT1 NOx, Inlet, Ppmvdc	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 HI, MBtuPerHr	Unit CT1 NH3, Slip, Ppmvdc	Unit CT1 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/24/2022 00:00	10.1	13.1	7.6	218.0	3,554,656.4	2,310.2	2.2	1.8
02/24/2022 01:00	10.2	13.2	7.8	215.1	3,541,116.0	2,301.4	2.1	1.8
02/24/2022 02:00	10.1	13.2	7.7	228.8	3,546,657.0	2,330.9	2.3	2.1
02/24/2022 03:00	10.0	13.1	7.6	223.0	3,508,703.4	2,357.2	2.2	1.9
02/24/2022 04:00	9.9	13.1	7.5	219.7	3,582,262.0	2,354.3	2.2	1.9
02/24/2022 05:00	10.0	13.1	7.6	193.2	3,552,828.6	2,360.9	1.9	1.7
02/24/2022 06:00	10.4	13.1	7.9	215.1	3,553,581.0	2,361.4	2.1	1.9
02/24/2022 07:00	9.9	13.2	7.6	209.4	3,587,419.7	2,279.1	2.0	1.8
02/24/2022 08:00	9.6	13.3	7.5	172.0	3,577,409.9	2,116.0	1.7	1.5
02/24/2022 09:00	9.5	13.5	7.6	164.4	3,546,809.2	2,020.2	1.6	1.2
02/24/2022 10:00	10.2	13.7	8.4	143.1	3,094,320.5	1,604.3	1.6	1.0
02/24/2022 11:00	10.7	13.8	8.9	126.6	2,864,248.9	1,464.1	1.5	0.9
02/24/2022 12:00	10.7	13.9	9.0	118.3	2,679,572.3	1,369.7	1.5	0.8
02/24/2022 13:00	10.7	13.9	9.0	124.1	2,776,018.9	1,419.0	1.5	0.9
02/24/2022 14:00	10.7	13.8	8.9	131.6	2,939,958.5	1,502.8	1.5	0.9
02/24/2022 15:00	10.4	13.8	8.6	129.3	2,930,959.4	1,498.2	1.5	0.9
02/24/2022 16:00	10.0	13.8	8.3	142.2	3,102,421.3	1,608.5	1.6	1.0
02/24/2022 17:00	10.2	13.3	7.9	185.3	3,517,195.4	2,054.7	1.8	1.4
02/24/2022 18:00	10.5	13.1	7.9	216.4	3,502,683.3	2,302.0	2.2	1.8
02/24/2022 19:00	10.4	13.1	7.9	230.2	3,473,331.4	2,358.8	2.3	2.1
02/24/2022 20:00	10.1	13.2	7.7	209.2	3,502,495.2	2,276.3	2.1	1.8
02/24/2022 21:00	10.1	13.1	7.6	225.9	3,485,862.2	2,316.4	2.3	2.1
02/24/2022 22:00	9.8	13.1	7.4	207.2	3,549,424.9	2,306.8	2.0	1.8
02/24/2022 23:00	9.8	13.2	7.5	202.6	3,534,531.6	2,245.5	2.0	1.8
Average/Sum#:	10.2	13.4	8.0	185.4	3,354,352.8	2,046.6	1.9	1.5
Minimum:	9.5	13.1	7.4	118.3	2,679,572.3	1,369.7	1.5	0.8
Maximum:	10.7	13.9	9.0	230.2	3,587,419.7	2,361.4	2.3	2.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm	Unit CT1 O2Dry, Inlet, Pct	Unit CT1 NOx, Inlet, Ppmvdc	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 HI, MBtuPerHr	Unit CT1 NH3, Slip, Ppmvdc	Unit CT1 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/25/2022 00:00	9.8	13.3	7.6	183.9	3,538,559.6	2,144.7	1.8	1.5
02/25/2022 01:00	9.9	13.3	7.7	180.7	3,551,944.5	2,075.0	1.8	1.5
02/25/2022 02:00	9.9	13.3	7.7	173.6	3,559,476.3	2,079.4	1.7	1.5
02/25/2022 03:00	9.9	13.3	7.7	181.1	3,581,558.3	2,092.3	1.7	1.5
02/25/2022 04:00	9.9	13.3	7.7	180.7	3,574,698.7	2,140.5	1.7	1.5
02/25/2022 05:00	9.8	13.3	7.6	199.3	3,549,345.1	2,099.4	2.0	1.7
02/25/2022 06:00	10.5	13.2	8.0	207.3	3,521,574.8	2,288.7	2.1	1.8
02/25/2022 07:00	9.7	13.3	7.5	176.1	3,561,686.9	2,106.7	1.7	1.5
02/25/2022 08:00	9.4	13.5	7.5	156.9	3,503,795.2	1,995.7	1.5	1.2
02/25/2022 09:00	10.3	13.8	8.6	135.3	3,000,775.3	1,555.8	1.5	0.9
02/25/2022 10:00	10.6	13.8	8.8	137.6	3,019,580.8	1,543.5	1.5	0.9
02/25/2022 11:00	10.3	13.8	8.6	149.0	3,200,788.4	1,659.5	1.6	1.0
02/25/2022 12:00	10.3	13.8	8.6	150.7	3,148,325.9	1,632.3	1.6	1.0
02/25/2022 13:00	10.0	13.8	8.3	135.3	3,212,278.3	1,642.0	1.4	0.8
02/25/2022 14:00	10.0	13.8	8.3	137.4	3,180,585.9	1,625.8	1.5	1.0
02/25/2022 15:00	10.1	13.8	8.4	134.2	3,101,355.0	1,585.3	1.5	1.0
02/25/2022 16:00	9.9	13.7	8.1	144.3	3,246,885.9	1,683.4	1.5	1.0
02/25/2022 17:00	10.2	13.3	7.9	178.0	3,485,527.4	2,036.2	1.8	1.4
02/25/2022 18:00	9.9	13.4	7.8	168.7	3,452,856.2	1,991.9	1.7	1.4
02/25/2022 19:00	9.4	13.5	7.5	159.3	3,475,002.2	1,979.3	1.6	1.2
02/25/2022 20:00	9.8	13.4	7.7	174.4	3,504,686.4	2,021.8	1.7	1.4
02/25/2022 21:00	9.8	13.4	7.7	175.4	3,479,352.3	2,058.0	1.7	1.4
02/25/2022 22:00	10.0	13.3	7.8	186.3	3,510,903.5	2,102.3	1.8	1.5
02/25/2022 23:00	9.8	13.3	7.6	177.3	3,515,746.6	2,105.2	1.7	1.5
Average/Sum#:	10.0	13.5	7.9	166.0	3,394,887.1	1,926.9	1.7	1.3
Minimum:	9.4	13.2	7.5	134.2	3,000,775.3	1,543.5	1.4	0.8
Maximum:	10.6	13.8	8.8	207.3	3,581,558.3	2,288.7	2.1	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm	Unit CT1 O2Dry, Inlet, Pct	Unit CT1 NOx, Inlet, Ppmvdc	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 HI, MBtuPerHr	Unit CT1 NH3, Slip, Ppmvdc	Unit CT1 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/26/2022 00:00	9.8	13.2	7.5	179.1	3,567,517.5	2,136.2	1.7	1.5
02/26/2022 01:00	9.8	13.2	7.5	184.2	3,542,849.4	2,147.3	1.8	1.5
02/26/2022 02:00	9.1	13.5	7.3	150.3	3,526,267.8	2,008.5	1.5	1.2
02/26/2022 03:00	9.2	13.5	7.3	157.2	3,568,150.8	2,006.3	1.5	1.2
02/26/2022 04:00	9.9	13.3	7.7	176.6	3,532,945.8	2,089.7	1.7	1.5
02/26/2022 05:00	9.7	13.3	7.5	184.2	3,570,260.5	2,085.7	1.8	1.5
02/26/2022 06:00	9.8	13.4	7.7	134.3	3,540,475.6	2,068.3	1.3	1.0
02/26/2022 07:00	16.6	14.8	16.1	147.2	2,621,921.0	1,244.5	1.8	0.9
02/26/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/26/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/26/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/26/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/26/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/26/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/26/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/26/2022 15:00	35.7	17.6	63.8	43.4	1,432,701.2	303.4	0.0	0.0
02/26/2022 16:00	40.3	15.6	44.9	230.0	2,153,683.2	817.8	3.4	1.1
02/26/2022 17:00	10.5	13.7	8.6	115.9	2,944,648.2	1,526.7	1.3	0.8
02/26/2022 18:00	9.8	13.4	7.7	129.2	3,494,665.7	1,990.5	1.2	1.0
02/26/2022 19:00	9.9	13.4	7.8	130.5	3,512,222.4	2,000.5	1.3	1.0
02/26/2022 20:00	9.8	13.5	7.8	130.3	3,510,115.6	1,999.3	1.3	1.0
02/26/2022 21:00	10.4	13.3	8.1	142.3	3,505,231.5	2,124.5	1.4	1.1
02/26/2022 22:00	10.2	13.3	7.9	137.2	3,504,373.9	2,072.8	1.3	1.0
02/26/2022 23:00	17.4	14.6	16.3	154.8	2,646,614.0	1,314.2	1.9	0.9
Average/Sum#:	14.0	13.9	14.2	148.6	3,186,743.8	1,761.0	1.5	1.1
Minimum:	9.1	13.2	7.3	43.4	1,432,701.2	303.4	0.0	0.0
Maximum:	40.3	17.6	63.8	230.0	3,570,260.5	2,147.3	3.4	1.5
%SI	29.17	29.17	29.17	29.17	29.17	29.17	29.17	29.17

Daily Summary Report

CT1 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm	Unit CT1 O2Dry, Inlet, Pct	Unit CT1 NOx, Inlet, Ppmvdc	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 HI, MBtuPerHr	Unit CT1 NH3, Slip, Ppmvdc	Unit CT1 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/27/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/27/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/27/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/27/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/27/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/27/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/27/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/27/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/27/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/27/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/27/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/27/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/27/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/27/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/27/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/27/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/27/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/27/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/27/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/27/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/27/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/27/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/27/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/27/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm	Unit CT1 O2Dry, Inlet, Pct	Unit CT1 NOx, Inlet, Ppmvdc	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 HI, MBtuPerHr	Unit CT1 NH3, Slip, Ppmvdc	Unit CT1 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/28/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/28/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/28/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/28/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/28/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/28/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/28/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/28/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/28/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/28/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/28/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/28/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/28/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/28/2022 13:00	39.7	17.4	66.9	5.4	1,379,383.8	332.4	0.0	0.0
02/28/2022 14:00	40.0	17.2	63.8	248.2	1,454,180.6	392.9	5.4	0.8
02/28/2022 15:00	37.0	15.6	41.2	246.4	2,145,087.0	830.2	3.7	1.2
02/28/2022 16:00	10.2	13.8	8.5	126.1	2,933,698.3	1,499.6	1.4	0.7
02/28/2022 17:00	10.2	13.4	8.0	199.3	3,475,002.2	1,979.3	2.0	1.6
02/28/2022 18:00	10.5	13.3	8.2	208.0	3,398,401.8	2,134.2	2.1	1.7
02/28/2022 19:00	10.3	13.3	8.0	188.5	3,408,345.1	2,016.0	1.9	1.4
02/28/2022 20:00	10.3	13.4	8.1	187.9	3,425,101.6	2,000.9	1.9	1.4
02/28/2022 21:00	10.0	13.4	7.9	175.2	3,408,653.3	1,966.4	1.8	1.4
02/28/2022 22:00	24.9	16.1	30.6	191.1	1,563,469.2	605.1	4.0	0.9
02/28/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	20.3	14.7	25.1	177.6	2,659,132.3	1,375.7	2.4	1.1
Minimum:	10.0	13.3	7.9	5.4	1,379,383.8	332.4	0.0	0.0
Maximum:	40.0	17.4	66.9	248.2	3,475,002.2	2,134.2	5.4	1.7
%SI	58.33	58.33	58.33	58.33	58.33	58.33	58.33	58.33

Daily Summary Report

CT1 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm	Unit CT1 O2Dry, Inlet, Pct	Unit CT1 NOx, Inlet, Ppmvdc	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 HI, MBtuPerHr	Unit CT1 NH3, Slip, Ppmvdc	Unit CT1 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/01/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/01/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/01/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/01/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/01/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/01/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/01/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/01/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/01/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/01/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/01/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/01/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/01/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/01/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/01/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/01/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/01/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/01/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/01/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/01/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/01/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/01/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/01/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/01/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm	Unit CT1 O2Dry, Inlet, Pct	Unit CT1 NOx, Inlet, Ppmvdc	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 HI, MBtuPerHr	Unit CT1 NH3, Slip, Ppmvdc	Unit CT1 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/02/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm	Unit CT1 O2Dry, Inlet, Pct	Unit CT1 NOx, Inlet, Ppmvdc	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 HI, MBtuPerHr	Unit CT1 NH3, Slip, Ppmvdc	Unit CT1 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/03/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/03/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/03/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/03/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/03/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/03/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/03/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/03/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/03/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/03/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/03/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/03/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/03/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/03/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/03/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/03/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/03/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/03/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/03/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/03/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/03/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/03/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/03/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/03/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm	Unit CT1 O2Dry, Inlet, Pct	Unit CT1 NOx, Inlet, Ppmvdc	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 HI, MBtuPerHr	Unit CT1 NH3, Slip, Ppmvdc	Unit CT1 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/04/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/04/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/04/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/04/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/04/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/04/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/04/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/04/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/04/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/04/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/04/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/04/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/04/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/04/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/04/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/04/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/04/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/04/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/04/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/04/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/04/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/04/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/04/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/04/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm	Unit CT1 O2Dry, Inlet, Pct	Unit CT1 NOx, Inlet, Ppmvdc	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 HI, MBtuPerHr	Unit CT1 NH3, Slip, Ppmvdc	Unit CT1 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/05/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/05/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/05/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/05/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/05/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/05/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/05/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/05/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/05/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/05/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/05/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/05/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/05/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/05/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/05/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/05/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/05/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/05/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/05/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/05/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/05/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/05/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/05/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/05/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm	Unit CT1 O2Dry, Inlet, Pct	Unit CT1 NOx, Inlet, Ppmvdc	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 HI, MBtuPerHr	Unit CT1 NH3, Slip, Ppmvdc	Unit CT1 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/06/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/06/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/06/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/06/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/06/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/06/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/06/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/06/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/06/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/06/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/06/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/06/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/06/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/06/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/06/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/06/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/06/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/06/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/06/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/06/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/06/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/06/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/06/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/06/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm	Unit CT1 O2Dry, Inlet, Pct	Unit CT1 NOx, Inlet, Ppmvdc	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 HI, MBtuPerHr	Unit CT1 NH3, Slip, Ppmvdc	Unit CT1 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/07/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm	Unit CT1 O2Dry, Inlet, Pct	Unit CT1 NOx, Inlet, Ppmvdc	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 HI, MBtuPerHr	Unit CT1 NH3, Slip, Ppmvdc	Unit CT1 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/08/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm	Unit CT1 O2Dry, Inlet, Pct	Unit CT1 NOx, Inlet, Ppmvdc	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 HI, MBtuPerHr	Unit CT1 NH3, Slip, Ppmvdc	Unit CT1 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/09/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/09/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/09/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/09/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/09/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/09/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/09/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/09/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/09/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/09/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/09/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/09/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/09/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/09/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/09/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/09/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/09/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/09/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/09/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/09/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/09/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/09/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/09/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/09/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm	Unit CT1 O2Dry, Inlet, Pct	Unit CT1 NOx, Inlet, Ppmvdc	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 HI, MBtuPerHr	Unit CT1 NH3, Slip, Ppmvdc	Unit CT1 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/10/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/10/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/10/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/10/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/10/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/10/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/10/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/10/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/10/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/10/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/10/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/10/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/10/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/10/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/10/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/10/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/10/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/10/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/10/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/10/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/10/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/10/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/10/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/10/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm	Unit CT1 O2Dry, Inlet, Pct	Unit CT1 NOx, Inlet, Ppmvdc	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 HI, MBtuPerHr	Unit CT1 NH3, Slip, Ppmvdc	Unit CT1 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/11/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/11/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/11/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/11/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/11/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/11/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/11/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/11/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/11/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/11/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/11/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/11/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/11/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/11/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/11/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/11/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/11/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/11/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/11/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/11/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/11/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/11/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/11/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/11/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm	Unit CT1 O2Dry, Inlet, Pct	Unit CT1 NOx, Inlet, Ppmvdc	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 HI, MBtuPerHr	Unit CT1 NH3, Slip, Ppmvdc	Unit CT1 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/12/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/12/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/12/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/12/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/12/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/12/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/12/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/12/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/12/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/12/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/12/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/12/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/12/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/12/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/12/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/12/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/12/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/12/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/12/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/12/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/12/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/12/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/12/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/12/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm	Unit CT1 O2Dry, Inlet, Pct	Unit CT1 NOx, Inlet, Ppmvdc	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 HI, MBtuPerHr	Unit CT1 NH3, Slip, Ppmvdc	Unit CT1 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/13/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/13/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/13/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/13/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/13/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/13/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/13/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/13/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/13/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/13/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/13/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/13/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/13/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/13/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/13/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/13/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/13/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/13/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/13/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/13/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/13/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/13/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/13/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/13/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm	Unit CT1 O2Dry, Inlet, Pct	Unit CT1 NOx, Inlet, Ppmvdc	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 HI, MBtuPerHr	Unit CT1 NH3, Slip, Ppmvdc	Unit CT1 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/14/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/14/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/14/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/14/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/14/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/14/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/14/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/14/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/14/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/14/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/14/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/14/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/14/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/14/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/14/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/14/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/14/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/14/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/14/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/14/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/14/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/14/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/14/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/14/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm	Unit CT1 O2Dry, Inlet, Pct	Unit CT1 NOx, Inlet, Ppmvdc	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 HI, MBtuPerHr	Unit CT1 NH3, Slip, Ppmvdc	Unit CT1 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/15/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/15/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/15/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/15/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/15/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/15/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/15/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/15/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/15/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/15/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/15/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/15/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/15/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/15/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/15/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/15/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/15/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/15/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/15/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/15/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/15/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/15/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/15/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/15/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm	Unit CT1 O2Dry, Inlet, Pct	Unit CT1 NOx, Inlet, Ppmvdc	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 HI, MBtuPerHr	Unit CT1 NH3, Slip, Ppmvdc	Unit CT1 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/16/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/16/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/16/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/16/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/16/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/16/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/16/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/16/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/16/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/16/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/16/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/16/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/16/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/16/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/16/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/16/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/16/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/16/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/16/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/16/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/16/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/16/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/16/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/16/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm	Unit CT1 O2Dry, Inlet, Pct	Unit CT1 NOx, Inlet, Ppmvdc	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 HI, MBtuPerHr	Unit CT1 NH3, Slip, Ppmvdc	Unit CT1 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/17/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/17/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/17/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/17/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/17/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/17/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/17/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/17/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/17/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/17/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/17/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/17/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/17/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/17/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/17/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/17/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/17/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/17/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/17/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/17/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/17/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/17/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/17/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/17/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm	Unit CT1 O2Dry, Inlet, Pct	Unit CT1 NOx, Inlet, Ppmvdc	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 HI, MBtuPerHr	Unit CT1 NH3, Slip, Ppmvdc	Unit CT1 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/18/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/18/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/18/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/18/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/18/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/18/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/18/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/18/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/18/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/18/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/18/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/18/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/18/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/18/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/18/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/18/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/18/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/18/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/18/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/18/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/18/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/18/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/18/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/18/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm	Unit CT1 O2Dry, Inlet, Pct	Unit CT1 NOx, Inlet, Ppmvdc	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 HI, MBtuPerHr	Unit CT1 NH3, Slip, Ppmvdc	Unit CT1 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/19/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/19/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/19/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/19/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/19/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/19/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/19/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/19/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/19/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/19/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/19/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/19/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/19/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/19/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/19/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/19/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/19/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/19/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/19/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/19/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/19/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/19/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/19/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/19/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm	Unit CT1 O2Dry, Inlet, Pct	Unit CT1 NOx, Inlet, Ppmvdc	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 HI, MBtuPerHr	Unit CT1 NH3, Slip, Ppmvdc	Unit CT1 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/20/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/20/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/20/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/20/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/20/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/20/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/20/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/20/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/20/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/20/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/20/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/20/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/20/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/20/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/20/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/20/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/20/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/20/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/20/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/20/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/20/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/20/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/20/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/20/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm	Unit CT1 O2Dry, Inlet, Pct	Unit CT1 NOx, Inlet, Ppmvdc	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 HI, MBtuPerHr	Unit CT1 NH3, Slip, Ppmvdc	Unit CT1 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/21/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/21/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/21/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/21/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/21/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/21/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/21/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/21/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/21/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/21/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/21/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/21/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/21/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/21/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/21/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/21/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/21/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/21/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/21/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/21/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/21/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/21/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/21/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/21/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm	Unit CT1 O2Dry, Inlet, Pct	Unit CT1 NOx, Inlet, Ppmvdc	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 HI, MBtuPerHr	Unit CT1 NH3, Slip, Ppmvdc	Unit CT1 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/22/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/22/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/22/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/22/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/22/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/22/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/22/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/22/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/22/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/22/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/22/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/22/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/22/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/22/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/22/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/22/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/22/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/22/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/22/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/22/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/22/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/22/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/22/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/22/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm	Unit CT1 O2Dry, Inlet, Pct	Unit CT1 NOx, Inlet, Ppmvdc	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 HI, MBtuPerHr	Unit CT1 NH3, Slip, Ppmvdc	Unit CT1 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/23/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm	Unit CT1 O2Dry, Inlet, Pct	Unit CT1 NOx, Inlet, Ppmvdc	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 HI, MBtuPerHr	Unit CT1 NH3, Slip, Ppmvdc	Unit CT1 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/24/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm	Unit CT1 O2Dry, Inlet, Pct	Unit CT1 NOx, Inlet, Ppmvdc	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 HI, MBtuPerHr	Unit CT1 NH3, Slip, Ppmvdc	Unit CT1 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/25/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm	Unit CT1 O2Dry, Inlet, Pct	Unit CT1 NOx, Inlet, Ppmvdc	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 HI, MBtuPerHr	Unit CT1 NH3, Slip, Ppmvdc	Unit CT1 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/26/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm	Unit CT1 O2Dry, Inlet, Pct	Unit CT1 NOx, Inlet, Ppmvdc	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 HI, MBtuPerHr	Unit CT1 NH3, Slip, Ppmvdc	Unit CT1 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/27/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm	Unit CT1 O2Dry, Inlet, Pct	Unit CT1 NOx, Inlet, Ppmvdc	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 HI, MBtuPerHr	Unit CT1 NH3, Slip, Ppmvdc	Unit CT1 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/28/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/28/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/28/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/28/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/28/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/28/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/28/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/28/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/28/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/28/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/28/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/28/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/28/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/28/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/28/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/28/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/28/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/28/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/28/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/28/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/28/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/28/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/28/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/28/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:12 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm	Unit CT1 O2Dry, Inlet, Pct	Unit CT1 NOx, Inlet, Ppmvdc	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 HI, MBtuPerHr	Unit CT1 NH3, Slip, Ppmvdc	Unit CT1 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/29/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/29/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/29/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/29/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/29/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/29/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/29/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/29/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/29/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/29/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/29/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/29/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/29/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/29/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/29/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/29/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/29/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/29/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/29/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/29/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/29/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/29/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/29/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/29/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm	Unit CT1 O2Dry, Inlet, Pct	Unit CT1 NOx, Inlet, Ppmvdc	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 HI, MBtuPerHr	Unit CT1 NH3, Slip, Ppmvdc	Unit CT1 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/30/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/30/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/30/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/30/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/30/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/30/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/30/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/30/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/30/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/30/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/30/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/30/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/30/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/30/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/30/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/30/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/30/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/30/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/30/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/30/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/30/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/30/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/30/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/30/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm	Unit CT1 O2Dry, Inlet, Pct	Unit CT1 NOx, Inlet, Ppmvdc	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 HI, MBtuPerHr	Unit CT1 NH3, Slip, Ppmvdc	Unit CT1 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/31/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:13 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm	Unit CT2 O2Dry, Inlet, Pct	Unit CT2 NOx, Inlet, Ppmvdc	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 HI, MBtuPerHr	Unit CT2 NH3, Slip, Ppmvdc	Unit CT2 NH3Slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/01/2022 00:00	6.5	13.4	5.1	103.4	3,441,399.5	1,909.9	1.0	0.8
01/01/2022 01:00	6.2	13.7	5.1	91.8	3,108,984.6	1,589.2	0.9	0.5
01/01/2022 02:00	6.3	13.7	5.2	89.1	3,018,407.0	1,542.9	0.9	0.5
01/01/2022 03:00	6.3	13.7	5.2	99.7	3,410,453.6	1,743.3	0.9	0.5
01/01/2022 04:00	6.5	13.5	5.2	103.8	3,456,014.4	1,842.3	1.0	0.7
01/01/2022 05:00	6.4	13.5	5.1	102.1	3,404,500.1	1,839.7	1.0	0.7
01/01/2022 06:00	6.1	13.7	5.0	100.4	3,456,350.0	1,792.0	0.9	0.5
01/01/2022 07:00	7.4	13.3	5.7	108.1	3,517,108.7	1,977.6	1.0	0.8
01/01/2022 08:00	6.3	13.6	5.1	95.7	3,125,664.3	1,666.2	1.0	0.7
01/01/2022 09:00	14.1	15.1	14.3	118.5	2,064,349.2	889.4	1.8	0.6
01/01/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/01/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/01/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/01/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/01/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/01/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/01/2022 16:00	28.2	17.9	55.5	9.4	1,499,245.8	273.7	-0.2	0.0
01/01/2022 17:00	35.0	15.6	39.0	199.1	2,181,949.5	812.6	2.8	0.9
01/01/2022 18:00	6.0	13.7	4.9	102.0	3,453,688.3	1,765.4	1.0	0.7
01/01/2022 19:00	6.2	13.7	5.1	101.4	3,465,222.3	1,796.6	0.9	0.5
01/01/2022 20:00	7.5	13.2	5.7	117.9	3,493,215.6	2,066.2	1.1	0.8
01/01/2022 21:00	7.5	13.1	5.7	125.2	3,478,008.0	2,108.0	1.2	1.1
01/01/2022 22:00	7.4	13.1	5.6	122.4	3,490,696.2	2,090.2	1.1	0.8
01/01/2022 23:00	7.3	13.2	5.6	117.8	3,496,935.1	2,068.4	1.1	0.8
Average/Sum#:	9.8	13.9	10.5	106.0	3,142,344.0	1,654.1	1.1	0.7
Minimum:	6.0	13.1	4.9	9.4	1,499,245.8	273.7	-0.2	0.0
Maximum:	35.0	17.9	55.5	199.1	3,517,108.7	2,108.0	2.8	1.1
%SI	25.00	25.00	25.00	25.00	25.00	25.00	25.00	25.00

Daily Summary Report

CT2 - NH3 slip



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm	Unit CT2 O2Dry, Inlet, Pct	Unit CT2 NOx, Inlet, Ppmvdc	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 HI, MBtuPerHr	Unit CT2 NH3, Slip, Ppmvdc	Unit CT2 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/02/2022 00:00	6.6	13.4	5.2	106.7	3,440,100.8	1,934.3	1.0	0.8
01/02/2022 01:00	6.1	13.8	5.1	87.7	2,977,519.9	1,522.0	0.9	0.5
01/02/2022 02:00	6.3	13.8	5.2	80.9	2,732,588.5	1,396.8	0.9	0.4
01/02/2022 03:00	6.3	13.7	5.2	97.8	3,306,677.7	1,714.4	0.9	0.5
01/02/2022 04:00	6.5	13.5	5.2	102.9	3,391,731.1	1,832.8	1.0	0.7
01/02/2022 05:00	6.3	13.5	5.0	101.7	3,353,446.4	1,836.6	1.0	0.7
01/02/2022 06:00	6.2	13.7	5.1	97.9	3,417,196.0	1,771.7	0.9	0.5
01/02/2022 07:00	7.5	13.3	5.8	108.2	3,523,866.8	1,981.4	1.0	0.8
01/02/2022 08:00	6.4	13.6	5.2	95.9	3,129,603.7	1,668.3	1.0	0.7
01/02/2022 09:00	14.0	15.1	14.2	117.0	2,080,828.7	896.5	1.7	0.6
01/02/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/02/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/02/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/02/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/02/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/02/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/02/2022 16:00	24.4	18.0	49.6	11.1	1,317,934.0	240.6	-0.1	0.0
01/02/2022 17:00	32.9	15.6	36.6	190.9	2,185,548.6	829.9	2.6	0.8
01/02/2022 18:00	6.2	13.7	5.1	102.8	3,364,980.0	1,769.2	1.0	0.7
01/02/2022 19:00	7.2	13.2	5.5	114.7	3,465,157.2	2,024.3	1.1	0.8
01/02/2022 20:00	7.7	13.0	5.8	130.6	3,444,505.1	2,138.0	1.2	1.1
01/02/2022 21:00	7.4	13.1	5.6	120.5	3,443,267.3	2,061.8	1.1	0.8
01/02/2022 22:00	7.3	13.1	5.5	118.2	3,434,583.2	2,056.6	1.1	0.8
01/02/2022 23:00	7.0	13.3	5.4	108.5	3,459,201.1	1,970.3	1.0	0.8
Average/Sum#:	9.6	13.9	10.0	105.2	3,081,596.5	1,647.0	1.1	0.7
Minimum:	6.1	13.0	5.0	11.1	1,317,934.0	240.6	-0.1	0.0
Maximum:	32.9	18.0	49.6	190.9	3,523,866.8	2,138.0	2.6	1.1
%SI	25.00	25.00	25.00	25.00	25.00	25.00	25.00	25.00

Daily Summary Report

CT2 - NH3 Slip



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm	Unit CT2 O2Dry, Inlet, Pct	Unit CT2 NOx, Inlet, Ppmvdc	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 HI, MBtuPerHr	Unit CT2 NH3, Slip, Ppmvdc	Unit CT2 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/03/2022 00:00	6.5	13.4	5.1	103.4	3,438,876.9	1,908.5	1.0	0.8
01/03/2022 01:00	6.2	13.7	5.1	94.5	3,186,063.6	1,628.6	1.0	0.7
01/03/2022 02:00	6.4	13.7	5.2	95.3	3,178,993.3	1,648.2	1.0	0.7
01/03/2022 03:00	7.2	13.3	5.6	108.4	3,505,548.6	1,971.1	1.0	0.8
01/03/2022 04:00	7.1	13.3	5.5	107.9	3,495,411.3	1,965.4	1.0	0.8
01/03/2022 05:00	7.3	13.1	5.5	114.3	3,480,905.6	2,033.5	1.1	0.8
01/03/2022 06:00	7.8	12.9	5.8	137.7	3,460,662.8	2,173.3	1.3	1.1
01/03/2022 07:00	7.6	13.1	5.7	120.8	3,469,377.5	2,052.1	1.1	0.8
01/03/2022 08:00	7.2	13.2	5.5	108.8	3,461,659.0	1,971.7	1.0	0.8
01/03/2022 09:00	6.6	13.4	5.2	104.0	3,459,418.3	1,919.9	1.0	0.8
01/03/2022 10:00	6.2	13.7	5.1	96.4	3,241,099.6	1,680.4	1.0	0.7
01/03/2022 11:00	6.4	13.8	5.3	84.4	2,756,260.0	1,408.9	1.0	0.6
01/03/2022 12:00	6.5	13.7	5.3	98.7	3,324,036.6	1,723.4	0.9	0.5
01/03/2022 13:00	7.1	13.4	5.6	106.0	3,364,584.4	1,842.7	1.0	0.7
01/03/2022 14:00	6.9	13.4	5.4	104.0	3,328,782.4	1,847.4	1.0	0.7
01/03/2022 15:00	6.5	13.7	5.3	94.1	3,126,723.8	1,621.1	1.0	0.6
01/03/2022 16:00	7.2	13.4	5.7	107.4	3,369,504.7	1,870.0	1.0	0.7
01/03/2022 17:00	7.6	13.1	5.7	119.8	3,407,391.9	2,065.2	1.1	0.8
01/03/2022 18:00	7.5	13.0	5.6	123.2	3,371,683.9	2,092.8	1.2	1.0
01/03/2022 19:00	7.6	13.0	5.7	128.6	3,383,592.9	2,124.9	1.2	1.1
01/03/2022 20:00	7.3	13.1	5.5	116.8	3,358,554.5	2,035.6	1.1	0.8
01/03/2022 21:00	7.1	13.2	5.4	114.1	3,389,240.8	2,004.7	1.1	0.8
01/03/2022 22:00	6.8	13.3	5.3	105.4	3,396,523.6	1,934.6	1.0	0.8
01/03/2022 23:00	7.4	13.2	5.7	113.2	3,375,039.4	1,996.3	1.1	0.8
Average/Sum#:	7.0	13.3	5.5	108.6	3,347,080.6	1,896.7	1.1	0.8
Minimum:	6.2	12.9	5.1	84.4	2,756,260.0	1,408.9	0.9	0.5
Maximum:	7.8	13.8	5.8	137.7	3,505,548.6	2,173.3	1.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm	Unit CT2 O2Dry, Inlet, Pct	Unit CT2 NOx, Inlet, Ppmvdc	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 HI, MBtuPerHr	Unit CT2 NH3, Slip, Ppmvdc	Unit CT2 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/04/2022 00:00	7.2	13.2	5.5	114.4	3,345,114.9	1,978.6	1.1	0.8
01/04/2022 01:00	6.3	13.7	5.2	89.8	3,015,668.1	1,541.5	1.0	0.6
01/04/2022 02:00	6.6	13.6	5.3	95.3	3,182,465.1	1,650.0	1.0	0.7
01/04/2022 03:00	7.2	13.3	5.6	105.7	3,366,827.7	1,893.1	1.0	0.8
01/04/2022 04:00	6.9	13.3	5.4	106.1	3,402,752.8	1,913.3	1.0	0.8
01/04/2022 05:00	6.3	13.7	5.2	95.3	3,203,670.5	1,637.6	1.0	0.7
01/04/2022 06:00	6.7	13.6	5.4	101.6	3,375,727.5	1,750.2	1.0	0.7
01/04/2022 07:00	7.7	13.2	5.9	109.7	3,426,018.9	1,951.4	1.0	0.8
01/04/2022 08:00	7.5	13.2	5.7	111.6	3,390,010.1	1,980.4	1.1	0.8
01/04/2022 09:00	6.6	13.4	5.2	103.6	3,399,195.9	1,911.3	1.0	0.8
01/04/2022 10:00	6.2	13.7	5.1	83.4	2,750,035.6	1,425.8	1.0	0.6
01/04/2022 11:00	6.5	13.8	5.4	79.7	2,584,690.7	1,321.2	1.0	0.5
01/04/2022 12:00	6.5	13.7	5.3	97.9	3,265,595.0	1,693.1	1.0	0.7
01/04/2022 13:00	6.8	13.5	5.4	104.1	3,370,284.7	1,796.6	1.0	0.7
01/04/2022 14:00	6.7	13.5	5.3	101.3	3,272,559.1	1,792.3	1.0	0.7
01/04/2022 15:00	6.5	13.7	5.3	90.9	3,009,647.6	1,560.4	1.0	0.6
01/04/2022 16:00	7.4	13.2	5.7	110.6	3,417,840.6	1,971.7	1.0	0.8
01/04/2022 17:00	7.6	13.0	5.7	121.9	3,370,717.3	2,092.2	1.2	1.0
01/04/2022 18:00	7.5	13.0	5.6	124.0	3,359,070.6	2,109.5	1.2	1.1
01/04/2022 19:00	7.4	13.0	5.5	122.3	3,378,772.7	2,097.2	1.2	1.0
01/04/2022 20:00	7.2	13.1	5.4	117.3	3,411,369.7	2,042.7	1.1	0.8
01/04/2022 21:00	7.3	13.2	5.6	113.8	3,404,118.5	2,013.5	1.1	0.8
01/04/2022 22:00	7.0	13.2	5.4	110.3	3,388,469.5	1,979.5	1.1	0.8
01/04/2022 23:00	7.3	13.2	5.6	112.0	3,417,227.4	1,996.3	1.1	0.8
Average/Sum#:	7.0	13.4	5.4	105.1	3,271,160.4	1,837.5	1.1	0.8
Minimum:	6.2	13.0	5.1	79.7	2,584,690.7	1,321.2	1.0	0.5
Maximum:	7.7	13.8	5.9	124.0	3,426,018.9	2,109.5	1.2	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm	Unit CT2 O2Dry, Inlet, Pct	Unit CT2 NOx, Inlet, Ppmvdc	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 HI, MBtuPerHr	Unit CT2 NH3, Slip, Ppmvdc	Unit CT2 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/05/2022 00:00	6.4	13.5	5.1	100.8	3,275,845.7	1,794.1	1.0	0.7
01/05/2022 01:00	6.5	13.8	5.4	79.6	2,522,675.3	1,289.5	1.0	0.5
01/05/2022 02:00	6.6	13.8	5.5	80.4	2,581,756.2	1,319.7	1.0	0.5
01/05/2022 03:00	6.5	13.7	5.3	99.7	3,325,386.7	1,724.1	1.0	0.7
01/05/2022 04:00	6.7	13.5	5.3	104.0	3,391,546.0	1,832.7	1.0	0.7
01/05/2022 05:00	6.6	13.4	5.2	102.2	3,315,429.8	1,864.2	1.0	0.7
01/05/2022 06:00	6.4	13.7	5.2	93.7	3,185,358.3	1,651.5	0.9	0.5
01/05/2022 07:00	7.6	13.2	5.8	110.7	3,439,508.7	1,984.2	1.0	0.8
01/05/2022 08:00	7.3	13.2	5.6	109.8	3,467,803.9	1,975.2	1.0	0.8
01/05/2022 09:00	7.0	13.3	5.4	109.6	3,392,358.9	1,957.0	1.0	0.8
01/05/2022 10:00	6.2	13.8	5.2	85.2	2,848,011.5	1,455.8	1.0	0.6
01/05/2022 11:00	6.3	13.8	5.2	86.5	2,946,218.7	1,506.0	0.9	0.5
01/05/2022 12:00	6.4	13.7	5.2	98.8	3,283,146.7	1,702.2	1.0	0.7
01/05/2022 13:00	6.7	13.5	5.3	103.8	3,367,488.6	1,819.7	1.0	0.7
01/05/2022 14:00	6.7	13.4	5.3	102.9	3,328,431.6	1,822.9	1.0	0.7
01/05/2022 15:00	6.4	13.7	5.2	93.4	3,190,171.9	1,630.7	0.9	0.5
01/05/2022 16:00	7.5	13.2	5.7	111.7	3,439,162.0	1,984.0	1.0	0.8
01/05/2022 17:00	7.5	13.1	5.7	117.1	3,433,704.8	2,031.0	1.1	0.8
01/05/2022 18:00	7.5	13.0	5.6	122.4	3,432,635.5	2,080.5	1.2	1.0
01/05/2022 19:00	7.5	13.0	5.6	122.3	3,428,345.7	2,077.9	1.2	1.0
01/05/2022 20:00	7.6	13.0	5.7	123.1	3,424,880.9	2,075.8	1.2	1.0
01/05/2022 21:00	7.5	13.0	5.6	121.9	3,409,536.7	2,066.5	1.2	1.0
01/05/2022 22:00	6.7	13.3	5.2	104.9	3,427,473.6	1,927.2	1.0	0.8
01/05/2022 23:00	7.4	13.1	5.6	113.6	3,419,452.7	1,997.6	1.1	0.8
Average/Sum#:	6.9	13.4	5.4	104.1	3,261,513.8	1,815.4	1.0	0.7
Minimum:	6.2	13.0	5.1	79.6	2,522,675.3	1,289.5	0.9	0.5
Maximum:	7.6	13.8	5.8	123.1	3,467,803.9	2,080.5	1.2	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm	Unit CT2 O2Dry, Inlet, Pct	Unit CT2 NOx, Inlet, Ppmvdc	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 HI, MBtuPerHr	Unit CT2 NH3, Slip, Ppmvdc	Unit CT2 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/06/2022 00:00	6.3	13.5	5.0	100.7	3,291,000.7	1,802.4	1.0	0.7
01/06/2022 01:00	6.3	13.8	5.2	78.9	2,556,715.3	1,306.9	1.0	0.5
01/06/2022 02:00	6.6	13.8	5.5	79.4	2,521,110.3	1,288.7	1.0	0.5
01/06/2022 03:00	6.6	13.7	5.4	89.8	2,946,384.1	1,527.6	1.0	0.6
01/06/2022 04:00	6.7	13.5	5.3	104.1	3,395,062.1	1,834.6	1.0	0.7
01/06/2022 05:00	6.7	13.4	5.3	103.6	3,295,808.1	1,829.1	1.0	0.7
01/06/2022 06:00	6.2	13.7	5.1	97.5	3,333,487.6	1,728.3	0.9	0.5
01/06/2022 07:00	7.5	13.2	5.7	108.9	3,467,628.3	1,975.1	1.0	0.8
01/06/2022 08:00	7.4	13.2	5.7	112.2	3,469,150.7	2,001.3	1.0	0.8
01/06/2022 09:00	6.7	13.4	5.3	105.1	3,410,756.0	1,917.8	1.0	0.8
01/06/2022 10:00	6.2	13.7	5.1	86.6	2,924,503.6	1,494.9	0.9	0.4
01/06/2022 11:00	6.4	13.7	5.2	90.5	3,050,295.0	1,559.2	0.9	0.5
01/06/2022 12:00	6.4	13.8	5.3	83.9	2,789,321.8	1,425.8	1.0	0.6
01/06/2022 13:00	6.5	13.8	5.4	79.3	2,566,692.6	1,312.0	1.0	0.5
01/06/2022 14:00	6.4	13.7	5.2	92.2	3,063,267.3	1,588.2	1.0	0.6
01/06/2022 15:00	6.5	13.8	5.4	84.4	2,772,497.5	1,417.2	1.0	0.6
01/06/2022 16:00	6.5	13.7	5.3	95.0	3,072,332.5	1,592.9	1.0	0.6
01/06/2022 17:00	6.5	13.6	5.3	100.0	3,295,683.7	1,708.7	1.0	0.7
01/06/2022 18:00	7.6	13.2	5.8	114.1	3,365,909.9	1,990.9	1.1	0.8
01/06/2022 19:00	7.6	13.1	5.7	119.2	3,363,504.3	2,038.6	1.2	1.0
01/06/2022 20:00	6.8	13.3	5.3	108.1	3,341,395.5	1,927.6	1.0	0.8
01/06/2022 21:00	6.2	13.7	5.1	95.5	3,167,806.5	1,642.4	1.0	0.7
01/06/2022 22:00	6.5	13.6	5.3	101.0	3,357,597.1	1,740.8	1.0	0.7
01/06/2022 23:00	7.5	13.2	5.7	111.1	3,396,692.5	1,959.5	1.1	0.8
Average/Sum#:	6.7	13.5	5.4	97.5	3,133,941.8	1,692.1	1.0	0.7
Minimum:	6.2	13.1	5.0	78.9	2,521,110.3	1,288.7	0.9	0.4
Maximum:	7.6	13.8	5.8	119.2	3,469,150.7	2,038.6	1.2	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:13 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm	Unit CT2 O2Dry, Inlet, Pct	Unit CT2 NOx, Inlet, Ppmvdc	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 HI, MBtuPerHr	Unit CT2 NH3, Slip, Ppmvdc	Unit CT2 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/07/2022 00:00	6.5	13.5	5.2	101.4	3,285,157.8	1,799.2	1.0	0.7
01/07/2022 01:00	6.5	13.8	5.4	79.6	2,501,938.3	1,278.9	1.0	0.5
01/07/2022 02:00	6.7	13.7	5.5	93.9	3,082,940.8	1,598.4	1.0	0.6
01/07/2022 03:00	6.9	13.3	5.4	105.3	3,411,111.6	1,918.0	1.0	0.8
01/07/2022 04:00	6.9	13.3	5.4	105.0	3,330,159.2	1,896.8	1.0	0.8
01/07/2022 05:00	6.2	13.7	5.1	96.1	3,202,910.0	1,660.6	1.0	0.7
01/07/2022 06:00	6.7	13.7	5.5	93.8	3,025,077.8	1,568.4	1.0	0.6
01/07/2022 07:00	7.8	13.2	6.0	110.4	3,388,718.6	1,954.9	1.0	0.8
01/07/2022 08:00	7.4	13.3	5.7	108.2	3,369,486.3	1,919.2	1.0	0.8
01/07/2022 09:00	6.4	13.7	5.2	91.9	3,049,708.1	1,558.9	1.0	0.6
01/07/2022 10:00	6.6	13.7	5.4	89.6	2,969,694.6	1,518.0	1.0	0.6
01/07/2022 11:00	6.6	13.7	5.4	91.2	3,003,734.6	1,535.4	1.0	0.6
01/07/2022 12:00	6.5	13.7	5.3	89.9	2,984,562.6	1,525.6	1.0	0.6
01/07/2022 13:00	6.5	13.8	5.4	88.4	2,925,286.1	1,495.3	1.0	0.6
01/07/2022 14:00	6.5	13.8	5.4	87.5	2,871,487.3	1,467.8	1.0	0.6
01/07/2022 15:00	6.5	13.8	5.4	89.7	2,959,326.1	1,512.7	1.0	0.6
01/07/2022 16:00	6.5	13.8	5.4	89.5	2,965,390.7	1,515.8	1.0	0.6
01/07/2022 17:00	6.5	13.7	5.3	95.0	3,132,069.2	1,601.0	1.0	0.6
01/07/2022 18:00	7.4	13.4	5.8	106.8	3,332,083.4	1,824.9	1.0	0.7
01/07/2022 19:00	6.6	13.5	5.3	102.0	3,292,826.6	1,803.4	1.0	0.7
01/07/2022 20:00	6.7	13.7	5.5	91.9	2,995,374.7	1,553.0	1.0	0.6
01/07/2022 21:00	7.4	13.3	5.7	108.5	3,409,691.1	1,942.1	1.0	0.8
01/07/2022 22:00	12.5	14.7	11.9	124.3	2,546,915.4	1,190.3	1.5	0.7
01/07/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	7.0	13.6	5.7	97.4	3,088,506.6	1,636.5	1.0	0.7
Minimum:	6.2	13.2	5.1	79.6	2,501,938.3	1,190.3	1.0	0.5
Maximum:	12.5	14.7	11.9	124.3	3,411,111.6	1,954.9	1.5	0.8
%SI	4.17	4.17	4.17	4.17	4.17	4.17	4.17	4.17

Daily Summary Report

CT2 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:13 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm	Unit CT2 O2Dry, Inlet, Pct	Unit CT2 NOx, Inlet, Ppmvdc	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 HI, MBtuPerHr	Unit CT2 NH3, Slip, Ppmvdc	Unit CT2 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/08/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/08/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/08/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/08/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/08/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/08/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/08/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/08/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/08/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/08/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/08/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/08/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/08/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/08/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/08/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/08/2022 15:00	33.0	17.4	55.6	58.6	1,480,223.3	356.7	1.2	0.2
01/08/2022 16:00	25.1	14.8	24.3	190.7	2,507,872.5	1,098.8	2.3	1.0
01/08/2022 17:00	6.2	13.8	5.2	93.4	3,131,873.6	1,600.9	1.0	0.6
01/08/2022 18:00	6.8	13.6	5.5	102.4	3,396,172.5	1,760.8	1.0	0.7
01/08/2022 19:00	7.6	13.2	5.8	114.4	3,459,616.7	1,995.8	1.1	0.8
01/08/2022 20:00	7.5	13.2	5.7	119.9	3,382,478.2	2,000.7	1.2	1.0
01/08/2022 21:00	6.2	13.8	5.2	97.1	3,305,790.5	1,689.8	0.9	0.5
01/08/2022 22:00	6.7	13.7	5.5	102.0	3,405,237.7	1,765.5	1.0	0.7
01/08/2022 23:00	7.6	13.2	5.8	114.0	3,433,441.6	1,980.7	1.1	0.8
Average/Sum#:	11.9	14.1	13.2	110.3	3,055,856.3	1,583.3	1.2	0.7
Minimum:	6.2	13.2	5.2	58.6	1,480,223.3	356.7	0.9	0.2
Maximum:	33.0	17.4	55.6	190.7	3,459,616.7	2,000.7	2.3	1.0
%SI	62.50	62.50	62.50	62.50	62.50	62.50	62.50	62.50

Daily Summary Report

CT2 - NH3 Slip



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm	Unit CT2 O2Dry, Inlet, Pct	Unit CT2 NOx, Inlet, Ppmvdc	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 HI, MBtuPerHr	Unit CT2 NH3, Slip, Ppmvdc	Unit CT2 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/09/2022 00:00	6.9	13.4	5.4	108.1	3,420,359.7	1,923.2	1.0	0.8
01/09/2022 01:00	6.2	13.8	5.2	87.6	2,947,001.3	1,506.4	1.0	0.6
01/09/2022 02:00	6.4	13.7	5.2	90.7	3,020,255.8	1,565.9	1.0	0.6
01/09/2022 03:00	6.6	13.4	5.2	103.7	3,462,121.1	1,921.4	1.0	0.8
01/09/2022 04:00	6.4	13.4	5.0	102.8	3,446,084.4	1,912.5	1.0	0.8
01/09/2022 05:00	6.1	13.7	5.0	94.2	3,191,737.0	1,631.5	0.9	0.5
01/09/2022 06:00	6.2	13.7	5.1	93.2	3,173,785.7	1,645.5	0.9	0.5
01/09/2022 07:00	7.4	13.2	5.7	108.7	3,507,833.2	1,998.0	1.0	0.8
01/09/2022 08:00	6.8	13.3	5.3	105.7	3,447,214.7	1,938.3	1.0	0.8
01/09/2022 09:00	6.2	13.8	5.2	90.6	3,051,468.8	1,559.8	1.0	0.6
01/09/2022 10:00	6.3	13.8	5.2	87.3	2,939,176.0	1,502.4	1.0	0.6
01/09/2022 11:00	6.4	13.8	5.3	92.6	3,098,029.2	1,583.6	1.0	0.6
01/09/2022 12:00	6.4	13.8	5.3	84.3	2,824,144.3	1,443.6	1.0	0.6
01/09/2022 13:00	6.4	13.8	5.3	87.1	2,922,156.0	1,493.7	1.0	0.6
01/09/2022 14:00	6.4	13.8	5.3	94.2	3,172,760.7	1,621.8	0.9	0.5
01/09/2022 15:00	6.3	13.8	5.2	95.5	3,223,625.0	1,647.8	0.9	0.5
01/09/2022 16:00	6.6	13.7	5.4	94.0	3,143,220.2	1,606.7	1.0	0.6
01/09/2022 17:00	7.3	13.3	5.7	108.4	3,426,896.7	1,951.9	1.0	0.8
01/09/2022 18:00	7.4	13.2	5.7	115.4	3,416,291.2	2,020.7	1.1	0.8
01/09/2022 19:00	6.6	13.4	5.2	104.7	3,425,695.1	1,926.2	1.0	0.8
01/09/2022 20:00	7.2	13.3	5.6	110.3	3,423,387.6	1,974.9	1.0	0.8
01/09/2022 21:00	6.9	13.3	5.4	108.2	3,434,972.8	1,956.5	1.0	0.8
01/09/2022 22:00	7.3	13.2	5.6	114.7	3,445,814.1	2,013.0	1.1	0.8
01/09/2022 23:00	6.3	13.4	5.0	102.2	3,458,877.7	1,919.6	1.0	0.8
Average/Sum#:	6.6	13.5	5.3	99.3	3,250,954.5	1,761.0	1.0	0.7
Minimum:	6.1	13.2	5.0	84.3	2,824,144.3	1,443.6	0.9	0.5
Maximum:	7.4	13.8	5.7	115.4	3,507,833.2	2,020.7	1.1	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:13 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm	Unit CT2 O2Dry, Inlet, Pct	Unit CT2 NOx, Inlet, Ppmvdc	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 HI, MBtuPerHr	Unit CT2 NH3, Slip, Ppmvdc	Unit CT2 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/10/2022 00:00	6.3	13.5	5.0	100.1	3,339,569.6	1,829.0	1.0	0.7
01/10/2022 01:00	9.7	14.4	8.8	98.3	2,455,693.9	1,165.6	1.3	0.6
01/10/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/10/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/10/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/10/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/10/2022 06:00	34.4	17.2	54.9	148.2	1,551,312.0	441.8	2.7	0.4
01/10/2022 07:00	26.2	14.6	24.5	179.5	2,689,723.4	1,237.4	2.0	1.0
01/10/2022 08:00	6.4	13.8	5.3	95.8	3,206,800.6	1,639.2	1.0	0.7
01/10/2022 09:00	6.3	13.8	5.2	90.5	3,072,205.8	1,570.4	0.9	0.5
01/10/2022 10:00	6.5	13.7	5.3	92.8	3,166,891.7	1,618.8	0.9	0.5
01/10/2022 11:00	7.6	13.3	5.9	109.8	3,423,209.8	1,949.8	1.0	0.8
01/10/2022 12:00	7.1	13.4	5.6	106.1	3,381,411.1	1,901.3	1.0	0.8
01/10/2022 13:00	6.2	13.8	5.2	88.7	2,995,322.4	1,531.1	0.9	0.5
01/10/2022 14:00	6.5	13.8	5.4	93.6	3,193,302.0	1,632.3	0.9	0.5
01/10/2022 15:00	7.7	13.3	6.0	113.4	3,390,972.1	1,956.2	1.1	0.8
01/10/2022 16:00	7.6	13.2	5.8	121.9	3,385,317.3	2,027.1	1.2	1.0
01/10/2022 17:00	7.7	13.1	5.8	126.7	3,410,361.7	2,067.0	1.2	1.0
01/10/2022 18:00	7.7	13.1	5.8	129.7	3,407,747.4	2,090.3	1.2	1.0
01/10/2022 19:00	7.6	13.1	5.7	129.8	3,397,639.7	2,084.1	1.2	1.0
01/10/2022 20:00	7.6	13.1	5.7	132.2	3,403,834.7	2,087.9	1.3	1.0
01/10/2022 21:00	7.6	13.1	5.7	130.0	3,421,911.1	2,074.0	1.2	1.0
01/10/2022 22:00	7.4	13.2	5.7	121.1	3,383,162.9	1,976.4	1.2	1.0
01/10/2022 23:00	7.4	13.3	5.7	114.8	3,438,308.6	1,958.4	1.1	0.8
Average/Sum#:	9.6	13.7	9.2	116.2	3,155,734.9	1,741.9	1.2	0.8
Minimum:	6.2	13.1	5.0	88.7	1,551,312.0	441.8	0.9	0.4
Maximum:	34.4	17.2	54.9	179.5	3,438,308.6	2,090.3	2.7	1.0
%SI	16.67	16.67	16.67	16.67	16.67	16.67	16.67	16.67

Daily Summary Report

CT2 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:13 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm	Unit CT2 O2Dry, Inlet, Pct	Unit CT2 NOx, Inlet, Ppmvdc	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 HI, MBtuPerHr	Unit CT2 NH3, Slip, Ppmvdc	Unit CT2 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/11/2022 00:00	6.4	13.5	5.1	101.3	3,304,877.5	1,810.0	1.0	0.7
01/11/2022 01:00	6.4	13.8	5.3	78.9	2,557,846.6	1,288.8	1.0	0.5
01/11/2022 02:00	6.4	13.7	5.2	89.4	3,051,664.4	1,559.9	0.9	0.5
01/11/2022 03:00	6.6	13.4	5.2	103.6	3,464,283.3	1,922.6	1.0	0.8
01/11/2022 04:00	6.5	13.4	5.1	102.8	3,442,300.5	1,910.4	1.0	0.8
01/11/2022 05:00	6.1	13.8	5.1	92.4	3,118,766.2	1,594.2	1.0	0.6
01/11/2022 06:00	6.3	13.8	5.2	88.4	3,080,031.1	1,574.4	0.9	0.5
01/11/2022 07:00	7.4	13.3	5.7	107.5	3,482,606.3	1,958.2	1.0	0.8
01/11/2022 08:00	6.4	13.5	5.1	101.5	3,300,495.4	1,807.6	1.0	0.7
01/11/2022 09:00	6.5	13.8	5.4	79.8	2,544,977.4	1,300.9	1.0	0.5
01/11/2022 10:00	6.6	13.8	5.5	79.5	2,569,159.2	1,294.5	1.0	0.5
01/11/2022 11:00	6.3	13.8	5.2	78.7	2,693,995.2	1,357.4	0.9	0.4
01/11/2022 12:00	6.5	13.8	5.4	79.4	2,661,843.5	1,341.2	0.9	0.4
01/11/2022 13:00	6.6	13.8	5.5	81.3	2,653,507.8	1,337.0	1.0	0.5
01/11/2022 14:00	6.7	13.9	5.6	79.9	2,566,579.1	1,293.2	1.0	0.5
01/11/2022 15:00	6.6	13.9	5.6	81.1	2,702,529.3	1,361.7	1.0	0.5
01/11/2022 16:00	6.4	13.8	5.3	93.4	3,141,655.2	1,605.9	0.9	0.5
01/11/2022 17:00	6.5	13.7	5.3	95.6	3,180,150.6	1,648.8	1.0	0.7
01/11/2022 18:00	7.4	13.3	5.7	108.7	3,418,293.9	1,947.0	1.0	0.8
01/11/2022 19:00	6.7	13.4	5.3	104.8	3,437,077.4	1,932.6	1.0	0.8
01/11/2022 20:00	6.5	13.4	5.1	102.4	3,450,589.1	1,915.0	1.0	0.8
01/11/2022 21:00	6.7	13.4	5.3	104.3	3,430,852.7	1,929.1	1.0	0.8
01/11/2022 22:00	7.3	13.2	5.6	110.1	3,427,721.2	1,977.4	1.0	0.8
01/11/2022 23:00	6.6	13.5	5.3	97.5	3,060,848.6	1,654.0	1.0	0.7
Average/Sum#:	6.6	13.6	5.3	93.4	3,072,610.5	1,638.4	1.0	0.6
Minimum:	6.1	13.2	5.1	78.7	2,544,977.4	1,288.8	0.9	0.4
Maximum:	7.4	13.9	5.7	110.1	3,482,606.3	1,977.4	1.0	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:13 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm	Unit CT2 O2Dry, Inlet, Pct	Unit CT2 NOx, Inlet, Ppmvdc	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 HI, MBtuPerHr	Unit CT2 NH3, Slip, Ppmvdc	Unit CT2 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/12/2022 00:00	14.1	15.0	14.1	119.9	2,065,092.0	904.8	1.8	0.6
01/12/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/12/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/12/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/12/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/12/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/12/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/12/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/12/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/12/2022 09:00	30.4	17.6	54.4	0.0	1,516,637.5	310.1	-0.3	0.0
01/12/2022 10:00	37.2	15.8	43.0	202.0	2,068,378.6	755.2	3.0	0.9
01/12/2022 11:00	6.2	13.8	5.2	87.2	2,696,592.2	1,378.4	1.0	0.6
01/12/2022 12:00	6.4	13.8	5.3	87.8	2,967,738.3	1,517.0	0.9	0.5
01/12/2022 13:00	6.5	13.8	5.4	90.7	3,069,662.6	1,569.1	0.9	0.5
01/12/2022 14:00	6.5	13.8	5.4	91.7	3,028,579.8	1,548.1	1.0	0.6
01/12/2022 15:00	6.8	13.7	5.6	94.2	3,161,805.3	1,616.2	0.9	0.5
01/12/2022 16:00	7.7	13.2	5.9	111.9	3,426,507.8	1,976.7	1.0	0.8
01/12/2022 17:00	7.6	13.1	5.7	118.7	3,368,784.0	2,041.8	1.1	0.8
01/12/2022 18:00	7.5	13.2	5.7	117.2	3,410,373.9	2,017.2	1.1	0.8
01/12/2022 19:00	7.5	13.2	5.7	115.4	3,378,251.6	1,998.2	1.1	0.8
01/12/2022 20:00	6.8	13.3	5.3	107.6	3,381,073.7	1,925.8	1.0	0.8
01/12/2022 21:00	6.2	13.7	5.1	95.4	3,230,863.4	1,651.5	0.9	0.5
01/12/2022 22:00	6.5	13.7	5.3	101.5	3,409,673.8	1,767.8	1.0	0.7
01/12/2022 23:00	7.2	13.3	5.6	107.1	3,453,972.9	1,942.1	1.0	0.8
Average/Sum#:	10.7	14.0	11.4	103.0	2,977,124.2	1,557.5	1.1	0.6
Minimum:	6.2	13.1	5.1	0.0	1,516,637.5	310.1	-0.3	0.0
Maximum:	37.2	17.6	54.4	202.0	3,453,972.9	2,041.8	3.0	0.9
%SI	33.33	33.33	33.33	33.33	33.33	33.33	33.33	33.33

Daily Summary Report

CT2 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:13 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm	Unit CT2 O2Dry, Inlet, Pct	Unit CT2 NOx, Inlet, Ppmvdc	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 HI, MBtuPerHr	Unit CT2 NH3, Slip, Ppmvdc	Unit CT2 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/13/2022 00:00	6.5	13.5	5.2	101.3	3,294,652.5	1,804.4	1.0	0.7
01/13/2022 01:00	6.5	13.8	5.4	79.8	2,523,066.6	1,289.7	1.0	0.5
01/13/2022 02:00	6.5	13.7	5.3	90.6	3,018,519.9	1,565.0	1.0	0.6
01/13/2022 03:00	6.7	13.4	5.3	104.3	3,483,563.4	1,933.3	1.0	0.8
01/13/2022 04:00	6.6	13.4	5.2	103.4	3,453,291.9	1,916.5	1.0	0.8
01/13/2022 05:00	6.4	13.7	5.2	96.4	3,256,491.2	1,664.6	0.9	0.5
01/13/2022 06:00	6.4	13.7	5.2	88.5	3,086,605.4	1,600.3	0.9	0.5
01/13/2022 07:00	7.9	13.2	6.1	111.9	3,445,055.7	1,987.4	1.0	0.8
01/13/2022 08:00	6.7	13.4	5.3	104.2	3,435,633.5	1,906.7	1.0	0.8
01/13/2022 09:00	6.2	13.7	5.1	95.1	3,188,802.5	1,630.0	1.0	0.7
01/13/2022 10:00	6.4	13.8	5.3	81.9	2,697,374.8	1,378.8	1.0	0.6
01/13/2022 11:00	6.5	13.7	5.3	94.2	3,152,023.7	1,611.2	1.0	0.6
01/13/2022 12:00	7.0	13.5	5.6	105.1	3,397,838.0	1,836.1	1.0	0.7
01/13/2022 13:00	7.4	13.2	5.7	112.5	3,362,963.9	1,964.6	1.1	0.8
01/13/2022 14:00	6.2	13.8	5.2	89.9	3,003,343.3	1,535.2	1.0	0.6
01/13/2022 15:00	6.5	13.7	5.3	90.4	3,030,927.4	1,549.3	1.0	0.6
01/13/2022 16:00	7.5	13.2	5.7	110.5	3,412,640.2	1,968.7	1.0	0.8
01/13/2022 17:00	7.4	13.2	5.7	113.4	3,381,125.7	1,999.9	1.1	0.8
01/13/2022 18:00	7.4	13.1	5.6	117.1	3,388,991.3	2,029.3	1.1	0.8
01/13/2022 19:00	7.0	13.3	5.4	107.0	3,387,569.7	1,929.5	1.0	0.8
01/13/2022 20:00	6.1	13.8	5.1	91.1	3,086,095.7	1,577.5	0.9	0.5
01/13/2022 21:00	6.6	13.7	5.4	93.8	3,164,739.8	1,617.7	0.9	0.5
01/13/2022 22:00	7.5	13.3	5.8	110.0	3,381,264.8	1,950.6	1.0	0.8
01/13/2022 23:00	13.5	14.7	12.8	127.6	2,536,002.8	1,185.2	1.6	0.7
Average/Sum#:	7.1	13.6	5.7	100.8	3,190,357.7	1,726.3	1.0	0.7
Minimum:	6.1	13.1	5.1	79.8	2,523,066.6	1,185.2	0.9	0.5
Maximum:	13.5	14.7	12.8	127.6	3,483,563.4	2,029.3	1.6	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:13 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm	Unit CT2 O2Dry, Inlet, Pct	Unit CT2 NOx, Inlet, Ppmvdc	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 HI, MBtuPerHr	Unit CT2 NH3, Slip, Ppmvdc	Unit CT2 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/14/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/14/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/14/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/14/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/14/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/14/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/14/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/14/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/14/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/14/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/14/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/14/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/14/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/14/2022 13:00	35.6	17.5	61.8	47.9	1,434,472.0	335.2	0.9	0.1
01/14/2022 14:00	27.4	15.1	27.9	197.5	2,374,728.6	971.1	2.6	1.0
01/14/2022 15:00	6.2	13.8	5.2	88.5	2,946,218.7	1,506.0	1.0	0.6
01/14/2022 16:00	6.4	13.8	5.3	83.0	2,793,824.2	1,407.7	0.9	0.4
01/14/2022 17:00	6.3	13.8	5.2	91.3	3,068,684.4	1,568.6	1.0	0.6
01/14/2022 18:00	6.2	13.8	5.2	92.7	3,122,483.2	1,596.1	1.0	0.6
01/14/2022 19:00	7.6	13.4	6.0	107.3	3,337,195.9	1,827.7	1.0	0.7
01/14/2022 20:00	7.1	13.4	5.6	106.6	3,331,845.6	1,849.1	1.0	0.7
01/14/2022 21:00	6.5	13.7	5.3	97.6	3,265,787.8	1,693.2	1.0	0.7
01/14/2022 22:00	7.4	13.2	5.7	111.2	3,443,669.0	1,986.6	1.0	0.8
01/14/2022 23:00	12.9	14.7	12.3	125.4	2,543,547.8	1,207.3	1.5	0.7
Average/Sum#:	11.8	14.2	13.2	104.5	2,878,405.2	1,449.9	1.2	0.6
Minimum:	6.2	13.2	5.2	47.9	1,434,472.0	335.2	0.9	0.1
Maximum:	35.6	17.5	61.8	197.5	3,443,669.0	1,986.6	2.6	1.0
%SI	54.17	54.17	54.17	54.17	54.17	54.17	54.17	54.17

Daily Summary Report

CT2 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:13 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm	Unit CT2 O2Dry, Inlet, Pct	Unit CT2 NOx, Inlet, Ppmvdc	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 HI, MBtuPerHr	Unit CT2 NH3, Slip, Ppmvdc	Unit CT2 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/15/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/15/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/15/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/15/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/15/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/15/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/15/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/15/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/15/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/15/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/15/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/15/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/15/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/15/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/15/2022 14:00	34.4	17.4	58.0	93.3	1,457,399.5	351.2	1.9	0.2
01/15/2022 15:00	27.5	15.0	27.5	199.9	2,499,671.7	1,058.7	2.5	1.1
01/15/2022 16:00	6.1	13.8	5.1	91.4	3,066,336.8	1,567.4	1.0	0.6
01/15/2022 17:00	6.6	13.7	5.4	95.8	3,189,022.9	1,653.4	1.0	0.7
01/15/2022 18:00	7.2	13.4	5.7	104.2	3,402,834.5	1,838.8	1.0	0.7
01/15/2022 19:00	7.3	13.3	5.7	110.7	3,388,447.5	1,930.0	1.1	0.8
01/15/2022 20:00	6.3	13.7	5.2	97.2	3,223,355.0	1,671.2	1.0	0.7
01/15/2022 21:00	6.5	13.7	5.3	101.2	3,375,534.7	1,750.1	1.0	0.7
01/15/2022 22:00	7.3	13.3	5.7	108.0	3,425,141.1	1,950.9	1.0	0.8
01/15/2022 23:00	10.8	14.2	9.5	118.8	2,901,971.4	1,441.0	1.3	0.7
Average/Sum#:	12.0	14.2	13.3	112.1	2,992,971.5	1,521.3	1.3	0.7
Minimum:	6.1	13.3	5.1	91.4	1,457,399.5	351.2	1.0	0.2
Maximum:	34.4	17.4	58.0	199.9	3,425,141.1	1,950.9	2.5	1.1
%SI	58.33	58.33	58.33	58.33	58.33	58.33	58.33	58.33

Daily Summary Report

CT2 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:13 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm	Unit CT2 O2Dry, Inlet, Pct	Unit CT2 NOx, Inlet, Ppmvdc	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 HI, MBtuPerHr	Unit CT2 NH3, Slip, Ppmvdc	Unit CT2 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/16/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/16/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/16/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/16/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/16/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/16/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/16/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/16/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/16/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/16/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/16/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/16/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/16/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/16/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/16/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/16/2022 15:00	31.4	17.6	56.1	0.0	1,368,952.2	289.9	-0.1	0.0
01/16/2022 16:00	39.0	16.2	49.0	201.9	1,862,112.8	611.9	3.3	0.8
01/16/2022 17:00	6.1	13.8	5.1	101.6	2,818,862.3	1,440.9	1.2	0.7
01/16/2022 18:00	6.6	13.7	5.4	98.1	3,255,372.5	1,687.8	1.0	0.7
01/16/2022 19:00	7.3	13.4	5.7	107.4	3,381,036.7	1,876.4	1.0	0.8
01/16/2022 20:00	7.4	13.2	5.7	115.4	3,415,587.1	1,970.4	1.1	0.8
01/16/2022 21:00	6.2	13.7	5.1	97.3	3,278,988.9	1,676.1	1.0	0.7
01/16/2022 22:00	6.3	13.8	5.2	82.2	2,745,398.2	1,383.3	1.0	0.6
01/16/2022 23:00	6.4	13.8	5.3	93.4	3,123,265.8	1,596.5	1.0	0.6
Average/Sum#:	13.0	14.4	15.8	99.7	2,805,508.5	1,392.6	1.2	0.6
Minimum:	6.1	13.2	5.1	0.0	1,368,952.2	289.9	-0.1	0.0
Maximum:	39.0	17.6	56.1	201.9	3,415,587.1	1,970.4	3.3	0.8
%SI	62.50	62.50	62.50	62.50	62.50	62.50	62.50	62.50

Daily Summary Report

CT2 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:13 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm	Unit CT2 O2Dry, Inlet, Pct	Unit CT2 NOx, Inlet, Ppmvdc	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 HI, MBtuPerHr	Unit CT2 NH3, Slip, Ppmvdc	Unit CT2 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/17/2022 00:00	6.8	13.5	5.4	103.4	3,328,441.5	1,798.6	1.0	0.7
01/17/2022 01:00	6.5	13.5	5.2	101.9	3,335,552.6	1,826.8	1.0	0.7
01/17/2022 02:00	6.3	13.8	5.2	81.8	2,731,610.4	1,396.3	1.0	0.6
01/17/2022 03:00	6.4	13.7	5.2	98.6	3,321,915.0	1,722.3	1.0	0.7
01/17/2022 04:00	6.7	13.5	5.3	103.9	3,369,524.2	1,820.8	1.0	0.7
01/17/2022 05:00	6.4	13.5	5.1	100.7	3,277,854.2	1,795.2	1.0	0.7
01/17/2022 06:00	6.4	13.7	5.2	93.1	3,226,055.2	1,672.6	0.9	0.5
01/17/2022 07:00	7.8	13.2	6.0	112.1	3,397,199.5	1,984.6	1.1	0.8
01/17/2022 08:00	7.4	13.2	5.7	114.1	3,429,894.5	2,003.7	1.1	0.8
01/17/2022 09:00	7.0	13.3	5.4	120.0	3,397,225.9	1,935.0	1.2	1.0
01/17/2022 10:00	6.3	13.7	5.2	91.3	3,055,185.8	1,561.7	1.0	0.6
01/17/2022 11:00	6.4	13.7	5.2	91.4	3,057,729.0	1,563.0	1.0	0.6
01/17/2022 12:00	6.5	13.7	5.3	94.9	3,151,412.0	1,633.9	1.0	0.7
01/17/2022 13:00	7.5	13.3	5.8	107.5	3,371,593.1	1,920.4	1.0	0.8
01/17/2022 14:00	7.3	13.3	5.7	108.8	3,323,838.8	1,893.2	1.1	0.8
01/17/2022 15:00	6.2	13.8	5.2	92.1	3,107,419.6	1,588.4	1.0	0.6
01/17/2022 16:00	6.6	13.7	5.4	92.5	3,080,226.7	1,574.5	1.0	0.6
01/17/2022 17:00	7.3	13.3	5.7	108.5	3,416,538.3	1,946.0	1.0	0.8
01/17/2022 18:00	7.3	13.2	5.6	112.2	3,363,819.8	1,965.1	1.1	0.8
01/17/2022 19:00	7.4	13.2	5.7	116.1	3,381,463.8	2,000.1	1.1	0.8
01/17/2022 20:00	6.7	13.4	5.3	106.5	3,349,822.7	1,908.0	1.0	0.8
01/17/2022 21:00	6.2	13.7	5.1	94.0	3,183,324.8	1,627.2	0.9	0.5
01/17/2022 22:00	6.4	13.8	5.3	83.6	2,769,214.3	1,395.3	1.0	0.6
01/17/2022 23:00	6.4	13.8	5.3	93.4	3,129,917.2	1,599.9	1.0	0.6
Average/Sum#:	6.8	13.5	5.4	100.9	3,231,532.5	1,755.5	1.0	0.7
Minimum:	6.2	13.2	5.1	81.8	2,731,610.4	1,395.3	0.9	0.5
Maximum:	7.8	13.8	6.0	120.0	3,429,894.5	2,003.7	1.2	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:13 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm	Unit CT2 O2Dry, Inlet, Pct	Unit CT2 NOx, Inlet, Ppmvdc	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 HI, MBtuPerHr	Unit CT2 NH3, Slip, Ppmvdc	Unit CT2 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/18/2022 00:00	6.9	13.6	5.6	102.8	3,377,270.6	1,751.0	1.0	0.7
01/18/2022 01:00	6.6	13.5	5.3	101.5	3,279,771.4	1,820.2	1.0	0.7
01/18/2022 02:00	6.4	13.7	5.2	92.5	3,134,612.4	1,602.3	0.9	0.5
01/18/2022 03:00	6.7	13.4	5.3	104.8	3,447,706.1	1,913.4	1.0	0.8
01/18/2022 04:00	6.5	13.4	5.1	103.3	3,457,976.8	1,919.1	1.0	0.8
01/18/2022 05:00	6.3	13.7	5.2	91.1	2,990,167.1	1,550.3	1.0	0.6
01/18/2022 06:00	6.4	13.8	5.3	88.8	3,036,843.2	1,574.5	0.9	0.5
01/18/2022 07:00	7.1	13.4	5.6	105.4	3,491,311.4	1,937.6	1.0	0.8
01/18/2022 08:00	7.5	13.2	5.7	111.5	3,472,719.8	1,978.0	1.0	0.8
01/18/2022 09:00	6.6	13.4	5.2	103.5	3,446,444.8	1,912.7	1.0	0.8
01/18/2022 10:00	6.2	13.8	5.2	83.2	2,787,169.9	1,424.7	1.0	0.6
01/18/2022 11:00	0.0	0.0	0.0	79.5	909,455.0	1,388.0	3.1	1.7
01/18/2022 12:00	0.0	0.0	0.0	76.9	844,456.5	1,288.8	3.2	1.5
01/18/2022 13:00	0.0	0.0	0.0	76.9	850,288.0	1,297.7	3.2	1.6
01/18/2022 14:00	6.5	13.8	5.4	78.4	2,655,691.0	1,338.1	0.9	0.4
01/18/2022 15:00	6.4	13.8	5.3	87.5	2,955,804.7	1,510.9	0.9	0.5
01/18/2022 16:00	6.6	13.7	5.4	93.5	3,150,263.0	1,610.3	0.9	0.5
01/18/2022 17:00	7.5	13.2	5.7	112.0	3,396,343.7	1,984.1	1.1	0.8
01/18/2022 18:00	7.4	13.2	5.7	114.1	3,364,557.4	1,990.1	1.1	0.8
01/18/2022 19:00	7.4	13.1	5.6	118.1	3,368,617.0	2,017.1	1.1	0.8
01/18/2022 20:00	6.7	13.3	5.2	104.9	3,403,642.1	1,913.8	1.0	0.8
01/18/2022 21:00	6.2	13.8	5.2	91.4	3,031,635.6	1,571.8	1.0	0.6
01/18/2022 22:00	6.4	13.7	5.2	90.9	3,079,835.4	1,574.3	0.9	0.5
01/18/2022 23:00	7.2	13.3	5.6	107.4	3,420,400.7	1,948.2	1.0	0.8
Average/Sum#:	6.7	13.5	5.4	96.7	3,226,132.6	1,700.7	1.0	0.7
Minimum:	6.2	13.1	5.1	76.9	2,655,691.0	1,288.8	0.9	0.4
Maximum:	7.5	13.8	5.7	118.1	3,491,311.4	2,017.1	1.1	0.8
%SI	12.50	12.50	12.50	0.00	12.50	0.00	12.50	12.50

Daily Summary Report

CT2 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:13 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm	Unit CT2 O2Dry, Inlet, Pct	Unit CT2 NOx, Inlet, Ppmvdc	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 HI, MBtuPerHr	Unit CT2 NH3, Slip, Ppmvdc	Unit CT2 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/19/2022 00:00	6.5	13.5	5.2	101.4	3,301,408.3	1,808.1	1.0	0.7
01/19/2022 01:00	6.5	13.8	5.4	79.6	2,553,281.8	1,286.5	1.0	0.5
01/19/2022 02:00	6.5	13.7	5.3	90.5	3,065,163.0	1,566.8	0.9	0.5
01/19/2022 03:00	6.6	13.4	5.2	103.7	3,482,302.1	1,932.6	1.0	0.8
01/19/2022 04:00	6.5	13.4	5.1	103.0	3,432,570.3	1,905.0	1.0	0.8
01/19/2022 05:00	6.2	13.8	5.2	90.4	3,045,599.8	1,556.8	1.0	0.6
01/19/2022 06:00	6.4	13.8	5.3	89.1	3,039,736.4	1,576.0	0.9	0.5
01/19/2022 07:00	7.1	13.4	5.6	106.0	3,450,415.9	1,940.1	1.0	0.8
01/19/2022 08:00	7.7	13.4	6.1	119.0	1,257,184.0	1,918.7	3.2	2.3
01/19/2022 09:00	6.7	13.8	5.6	113.7	2,912,374.4	1,488.7	1.3	0.7
01/19/2022 10:00	6.9	13.8	5.7	83.0	877,873.1	1,339.8	3.2	1.6
01/19/2022 11:00	6.9	13.8	5.7	84.7	2,785,488.6	1,403.5	1.0	0.6
01/19/2022 12:00	7.1	13.8	5.9	81.7	2,593,967.6	1,307.0	1.0	0.5
01/19/2022 13:00	6.9	13.8	5.7	82.1	2,698,163.0	1,359.5	1.0	0.5
01/19/2022 14:00	6.9	13.8	5.7	81.0	2,650,927.8	1,335.7	1.0	0.5
01/19/2022 15:00	7.5	13.7	6.1	95.2	1,017,502.0	1,552.9	3.2	1.9
01/19/2022 16:00	8.4	13.1	6.4	119.8	3,394,989.0	2,008.1	1.1	0.8
01/19/2022 17:00	8.3	13.1	6.3	122.6	3,391,663.4	2,030.9	1.2	1.0
01/19/2022 18:00	8.2	13.1	6.2	121.3	3,402,089.7	2,012.3	1.1	0.8
01/19/2022 19:00	8.1	13.1	6.1	124.9	3,345,850.3	2,027.9	1.2	1.0
01/19/2022 20:00	7.9	13.2	6.1	122.0	3,326,855.9	1,967.8	1.2	1.0
01/19/2022 21:00	6.6	13.8	5.5	99.0	3,272,728.6	1,672.9	1.0	0.7
01/19/2022 22:00	7.4	13.7	6.1	106.3	3,403,501.8	1,764.6	1.0	0.7
01/19/2022 23:00	8.2	13.2	6.3	113.3	3,427,423.4	1,952.2	1.1	0.8
Average/Sum#:	7.2	13.5	5.7	101.4	3,141,738.1	1,696.4	1.0	0.7
Minimum:	6.2	13.1	5.1	79.6	2,553,281.8	1,286.5	0.9	0.5
Maximum:	8.4	13.8	6.4	124.9	3,482,302.1	2,030.9	1.3	1.0
%SI	0.00	0.00	0.00	0.00	12.50	0.00	12.50	12.50

Daily Summary Report

CT2 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:13 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm	Unit CT2 O2Dry, Inlet, Pct	Unit CT2 NOx, Inlet, Ppmvdc	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 HI, MBtuPerHr	Unit CT2 NH3, Slip, Ppmvdc	Unit CT2 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/20/2022 00:00	7.5	13.4	5.9	109.1	3,239,666.8	1,821.6	1.1	0.7
01/20/2022 01:00	6.9	13.9	5.8	81.6	2,561,022.1	1,290.4	1.0	0.5
01/20/2022 02:00	7.1	13.8	5.9	81.6	2,579,281.1	1,299.6	1.0	0.5
01/20/2022 03:00	6.9	13.7	5.7	100.9	3,346,677.6	1,710.7	1.0	0.7
01/20/2022 04:00	7.4	13.5	5.9	107.2	3,376,926.5	1,824.8	1.0	0.7
01/20/2022 05:00	7.3	13.4	5.7	106.7	3,341,943.3	1,830.3	1.0	0.7
01/20/2022 06:00	6.7	13.7	5.5	95.2	3,263,280.4	1,691.9	0.9	0.5
01/20/2022 07:00	8.2	13.3	6.4	111.0	3,464,110.1	1,947.8	1.0	0.8
01/20/2022 08:00	7.2	13.5	5.7	100.9	3,131,104.4	1,669.1	1.0	0.7
01/20/2022 09:00	14.3	14.9	14.1	120.7	2,100,831.7	935.8	1.8	0.7
01/20/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/20/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/20/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/20/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/20/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/20/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/20/2022 16:00	33.6	17.5	58.3	81.2	1,553,840.2	340.4	1.3	0.2
01/20/2022 17:00	28.2	14.7	26.8	192.6	2,516,148.9	1,120.8	2.3	1.0
01/20/2022 18:00	6.7	13.8	5.6	96.3	3,127,960.9	1,598.9	1.0	0.6
01/20/2022 19:00	7.1	13.7	5.8	101.6	3,272,731.4	1,696.8	1.0	0.7
01/20/2022 20:00	8.0	13.2	6.1	114.0	3,380,937.6	1,975.1	1.1	0.8
01/20/2022 21:00	7.9	13.2	6.1	113.7	3,423,734.3	1,975.1	1.1	0.8
01/20/2022 22:00	8.0	13.1	6.1	118.3	3,392,453.0	2,006.6	1.1	0.8
01/20/2022 23:00	14.1	14.6	13.2	132.6	2,551,071.6	1,229.5	1.6	0.7
Average/Sum#:	10.7	13.9	10.8	109.2	2,979,095.7	1,553.6	1.2	0.7
Minimum:	6.7	13.1	5.5	81.2	1,553,840.2	340.4	0.9	0.2
Maximum:	33.6	17.5	58.3	192.6	3,464,110.1	2,006.6	2.3	1.0
%SI	25.00	25.00	25.00	25.00	25.00	25.00	25.00	25.00

Daily Summary Report

CT2 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:13 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm	Unit CT2 O2Dry, Inlet, Pct	Unit CT2 NOx, Inlet, Ppmvdc	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 HI, MBtuPerHr	Unit CT2 NH3, Slip, Ppmvdc	Unit CT2 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/21/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/21/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/21/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/21/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/21/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/21/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/21/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/21/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/21/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/21/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/21/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/21/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/21/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/21/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/21/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/21/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/21/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/21/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/21/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/21/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/21/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/21/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/21/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/21/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm	Unit CT2 O2Dry, Inlet, Pct	Unit CT2 NOx, Inlet, Ppmvdc	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 HI, MBtuPerHr	Unit CT2 NH3, Slip, Ppmvdc	Unit CT2 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/22/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/22/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/22/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/22/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/22/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/22/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/22/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/22/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/22/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/22/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/22/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/22/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/22/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/22/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/22/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/22/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/22/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/22/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/22/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/22/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/22/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/22/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/22/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/22/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:13 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm	Unit CT2 O2Dry, Inlet, Pct	Unit CT2 NOx, Inlet, Ppmvdc	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 HI, MBtuPerHr	Unit CT2 NH3, Slip, Ppmvdc	Unit CT2 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/23/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/23/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/23/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/23/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/23/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/23/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/23/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/23/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/23/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/23/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/23/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/23/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/23/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/23/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/23/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/23/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/23/2022 16:00	31.2	17.6	55.8	0.0	1,328,341.7	291.0	-0.1	0.0
01/23/2022 17:00	42.2	15.7	47.9	156.9	2,013,590.9	749.9	2.5	0.7
01/23/2022 18:00	6.6	13.7	5.4	106.3	3,302,434.4	1,712.2	1.0	0.7
01/23/2022 19:00	7.3	13.3	5.7	109.1	3,432,163.8	1,954.9	1.0	0.8
01/23/2022 20:00	7.9	13.2	6.1	122.0	3,371,957.0	2,019.1	1.2	1.0
01/23/2022 21:00	7.7	13.2	5.9	116.5	3,453,549.6	1,992.3	1.1	0.8
01/23/2022 22:00	7.6	13.3	5.9	111.4	3,438,308.6	1,958.4	1.0	0.8
01/23/2022 23:00	13.3	14.8	12.9	126.4	2,548,413.2	1,191.0	1.6	0.7
Average/Sum#:	15.5	14.4	18.2	106.1	2,861,094.9	1,483.6	1.2	0.7
Minimum:	6.6	13.2	5.4	0.0	1,328,341.7	291.0	-0.1	0.0
Maximum:	42.2	17.6	55.8	156.9	3,453,549.6	2,019.1	2.5	1.0
%SI	66.67	66.67	66.67	66.67	66.67	66.67	66.67	66.67

Daily Summary Report

CT2 - NH3 Slip



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm	Unit CT2 O2Dry, Inlet, Pct	Unit CT2 NOx, Inlet, Ppmvdc	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 HI, MBtuPerHr	Unit CT2 NH3, Slip, Ppmvdc	Unit CT2 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/24/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/24/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/24/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/24/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/24/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/24/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/24/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/24/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/24/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/24/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/24/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/24/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/24/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/24/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/24/2022 14:00	35.1	17.4	59.2	95.3	1,470,263.8	354.3	1.9	0.2
01/24/2022 15:00	25.2	14.6	23.6	182.3	2,433,085.5	1,083.8	2.3	1.0
01/24/2022 16:00	6.4	13.7	5.2	96.0	3,226,168.2	1,649.1	1.0	0.7
01/24/2022 17:00	6.9	13.7	5.7	96.9	3,154,112.2	1,635.3	1.0	0.7
01/24/2022 18:00	7.7	13.2	5.9	110.6	3,407,935.5	1,941.1	1.0	0.8
01/24/2022 19:00	7.9	13.1	6.0	117.5	3,390,593.3	2,005.5	1.1	0.8
01/24/2022 20:00	7.6	13.3	5.9	110.7	3,367,203.9	1,917.9	1.1	0.8
01/24/2022 21:00	6.8	13.7	5.6	98.1	3,117,592.4	1,593.6	1.0	0.6
01/24/2022 22:00	7.0	13.6	5.7	101.6	3,301,662.9	1,711.8	1.0	0.7
01/24/2022 23:00	7.8	13.3	6.1	110.9	3,420,049.6	1,948.0	1.0	0.8
Average/Sum#:	11.8	14.0	12.9	112.0	3,028,866.7	1,584.0	1.2	0.7
Minimum:	6.4	13.1	5.2	95.3	1,470,263.8	354.3	1.0	0.2
Maximum:	35.1	17.4	59.2	182.3	3,420,049.6	2,005.5	2.3	1.0
%SI	58.33	58.33	58.33	58.33	58.33	58.33	58.33	58.33

Daily Summary Report

CT2 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:13 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm	Unit CT2 O2Dry, Inlet, Pct	Unit CT2 NOx, Inlet, Ppmvdc	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 HI, MBtuPerHr	Unit CT2 NH3, Slip, Ppmvdc	Unit CT2 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/25/2022 00:00	6.9	13.4	5.4	105.7	3,417,074.2	1,896.4	1.0	0.8
01/25/2022 01:00	6.7	13.7	5.5	92.6	3,003,538.9	1,535.3	1.0	0.6
01/25/2022 02:00	6.9	13.7	5.7	97.2	3,168,385.1	1,642.7	1.0	0.7
01/25/2022 03:00	7.2	13.3	5.6	107.1	3,475,454.9	1,928.8	1.0	0.8
01/25/2022 04:00	7.0	13.4	5.5	105.9	3,442,300.5	1,910.4	1.0	0.8
01/25/2022 05:00	6.6	13.7	5.4	97.5	3,217,169.1	1,644.5	1.0	0.7
01/25/2022 06:00	6.8	13.7	5.6	98.1	3,365,698.0	1,745.0	0.9	0.5
01/25/2022 07:00	8.1	13.3	6.3	113.0	3,428,761.3	1,978.0	1.0	0.8
01/25/2022 08:00	12.2	14.1	10.6	127.3	2,858,239.4	1,481.9	1.4	0.7
01/25/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/25/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/25/2022 11:00	22.4	18.1	47.2	190.2	1,315,892.3	211.4	4.2	0.3
01/25/2022 12:00	34.4	15.8	39.8	230.3	2,137,419.9	764.8	3.2	0.9
01/25/2022 13:00	6.4	13.9	5.4	83.9	2,720,192.8	1,370.6	1.0	0.5
01/25/2022 14:00	6.7	13.9	5.6	80.1	2,690,819.7	1,355.8	0.9	0.4
01/25/2022 15:00	7.8	13.7	6.4	104.3	3,309,570.8	1,715.9	1.0	0.7
01/25/2022 16:00	7.0	13.8	5.8	95.6	3,094,899.1	1,559.4	1.0	0.6
01/25/2022 17:00	6.7	13.8	5.6	97.2	3,246,329.7	1,635.7	1.0	0.7
01/25/2022 18:00	7.5	13.7	6.1	103.4	3,338,461.0	1,706.5	1.0	0.7
01/25/2022 19:00	8.0	13.4	6.3	112.3	3,395,451.7	1,884.4	1.1	0.8
01/25/2022 20:00	8.1	13.3	6.3	116.1	3,380,344.1	1,900.7	1.1	0.8
01/25/2022 21:00	6.6	13.8	5.5	91.0	3,008,565.8	1,515.9	1.0	0.6
01/25/2022 22:00	7.4	13.7	6.1	101.1	3,256,144.0	1,688.2	1.0	0.7
01/25/2022 23:00	7.7	13.3	6.0	109.0	3,459,418.3	1,919.9	1.0	0.8
Average/Sum#:	9.3	13.9	9.4	111.8	3,078,642.3	1,590.6	1.3	0.7
Minimum:	6.4	13.3	5.4	80.1	1,315,892.3	211.4	0.9	0.3
Maximum:	34.4	18.1	47.2	230.3	3,475,454.9	1,978.0	4.2	0.9
%SI	8.33	8.33	8.33	8.33	8.33	8.33	8.33	8.33

Daily Summary Report

CT2 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:13 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm	Unit CT2 O2Dry, Inlet, Pct	Unit CT2 NOx, Inlet, Ppmvdc	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 HI, MBtuPerHr	Unit CT2 NH3, Slip, Ppmvdc	Unit CT2 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/26/2022 00:00	7.6	13.3	5.9	111.0	3,423,205.3	1,924.8	1.0	0.8
01/26/2022 01:00	6.5	13.8	5.4	98.7	3,285,249.1	1,679.3	1.0	0.7
01/26/2022 02:00	6.8	13.7	5.6	99.0	3,288,770.5	1,681.1	1.0	0.7
01/26/2022 03:00	7.4	13.3	5.7	108.7	3,512,933.9	1,949.6	1.0	0.8
01/26/2022 04:00	7.5	13.3	5.8	109.4	3,492,392.6	1,938.2	1.0	0.8
01/26/2022 05:00	6.5	13.8	5.4	93.2	3,071,423.3	1,570.0	1.0	0.6
01/26/2022 06:00	6.7	13.7	5.5	102.3	3,434,554.9	1,780.7	0.9	0.5
01/26/2022 07:00	8.2	13.3	6.4	111.8	3,479,227.2	1,956.3	1.0	0.8
01/26/2022 08:00	12.0	14.3	10.7	121.1	2,901,367.2	1,440.7	1.3	0.7
01/26/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/26/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/26/2022 11:00	22.9	18.1	48.3	186.5	1,386,231.0	222.7	3.8	0.3
01/26/2022 12:00	33.7	15.8	39.0	223.6	2,163,690.5	790.0	3.1	0.9
01/26/2022 13:00	6.4	13.9	5.4	82.8	2,686,651.9	1,353.7	1.0	0.5
01/26/2022 14:00	6.7	13.9	5.6	79.6	2,671,568.4	1,346.1	0.9	0.4
01/26/2022 15:00	7.4	13.7	6.1	99.8	3,298,356.4	1,686.0	1.0	0.7
01/26/2022 16:00	6.8	13.8	5.7	93.8	3,088,349.7	1,556.1	1.0	0.6
01/26/2022 17:00	6.7	13.8	5.6	98.6	3,316,941.5	1,695.5	0.9	0.5
01/26/2022 18:00	7.5	13.6	6.1	107.0	3,429,733.0	1,778.2	1.0	0.7
01/26/2022 19:00	7.8	13.4	6.1	110.8	3,382,298.0	1,877.1	1.0	0.8
01/26/2022 20:00	7.7	13.3	6.0	115.5	3,392,064.2	1,981.6	1.1	0.8
01/26/2022 21:00	6.4	13.8	5.3	97.2	3,225,777.0	1,648.9	1.0	0.7
01/26/2022 22:00	7.0	13.7	5.7	104.7	3,410,252.5	1,768.1	1.0	0.7
01/26/2022 23:00	7.7	13.3	6.0	111.7	3,460,605.6	1,971.1	1.0	0.8
Average/Sum#:	9.3	13.9	9.4	112.1	3,127,347.4	1,618.0	1.2	0.7
Minimum:	6.4	13.3	5.3	79.6	1,386,231.0	222.7	0.9	0.3
Maximum:	33.7	18.1	48.3	223.6	3,512,933.9	1,981.6	3.8	0.9
%SI	8.33	8.33	8.33	8.33	8.33	8.33	8.33	8.33

Daily Summary Report

CT2 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:13 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm	Unit CT2 O2Dry, Inlet, Pct	Unit CT2 NOx, Inlet, Ppmvdc	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 HI, MBtuPerHr	Unit CT2 NH3, Slip, Ppmvdc	Unit CT2 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/27/2022 00:00	7.3	13.4	5.7	108.5	3,441,345.7	1,935.0	1.0	0.8
01/27/2022 01:00	6.5	13.8	5.4	89.4	2,939,958.5	1,502.8	1.0	0.6
01/27/2022 02:00	6.8	13.7	5.6	98.5	3,278,402.0	1,675.8	1.0	0.7
01/27/2022 03:00	7.3	13.4	5.7	108.0	3,486,086.0	1,934.7	1.0	0.8
01/27/2022 04:00	7.1	13.4	5.6	106.4	3,455,093.8	1,917.5	1.0	0.8
01/27/2022 05:00	6.5	13.8	5.4	92.6	3,062,424.2	1,565.4	1.0	0.6
01/27/2022 06:00	7.4	13.5	5.9	108.1	3,305,177.8	1,834.3	1.0	0.7
01/27/2022 07:00	8.3	13.3	6.4	118.3	3,431,361.5	1,979.5	1.1	0.8
01/27/2022 08:00	7.5	13.4	5.9	111.5	3,452,194.4	1,941.1	1.0	0.8
01/27/2022 09:00	7.0	13.6	5.7	100.3	3,111,219.6	1,658.5	1.0	0.7
01/27/2022 10:00	6.8	13.8	5.7	83.0	2,699,155.3	1,360.0	1.0	0.5
01/27/2022 11:00	6.8	13.8	5.7	80.7	2,677,919.3	1,349.3	1.0	0.5
01/27/2022 12:00	6.8	13.9	5.7	80.6	2,683,873.3	1,352.3	1.0	0.5
01/27/2022 13:00	6.8	13.9	5.7	80.6	2,686,651.9	1,353.7	0.9	0.4
01/27/2022 14:00	6.8	13.9	5.7	80.8	2,691,613.5	1,356.2	0.9	0.4
01/27/2022 15:00	7.9	13.7	6.5	102.9	3,294,835.1	1,684.2	1.0	0.7
01/27/2022 16:00	7.0	13.8	5.8	95.4	3,053,229.5	1,560.7	1.0	0.6
01/27/2022 17:00	6.8	13.8	5.7	90.7	3,005,390.4	1,514.3	1.0	0.6
01/27/2022 18:00	7.8	13.6	6.3	107.9	3,391,988.1	1,783.4	1.0	0.7
01/27/2022 19:00	8.0	13.3	6.2	114.1	3,441,415.5	1,985.3	1.1	0.8
01/27/2022 20:00	7.7	13.3	6.0	113.0	3,404,666.4	1,964.1	1.1	0.8
01/27/2022 21:00	6.6	13.8	5.5	98.3	3,271,554.9	1,672.3	1.0	0.7
01/27/2022 22:00	6.8	13.8	5.7	88.2	2,909,729.1	1,466.1	1.0	0.6
01/27/2022 23:00	7.5	13.4	5.9	108.5	3,434,881.5	1,881.2	1.0	0.8
Average/Sum#:	7.2	13.6	5.8	98.6	3,150,423.6	1,676.2	1.0	0.7
Minimum:	6.5	13.3	5.4	80.6	2,677,919.3	1,349.3	0.9	0.4
Maximum:	8.3	13.9	6.5	118.3	3,486,086.0	1,985.3	1.1	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:13 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm	Unit CT2 O2Dry, Inlet, Pct	Unit CT2 NOx, Inlet, Ppmvdc	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 HI, MBtuPerHr	Unit CT2 NH3, Slip, Ppmvdc	Unit CT2 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/28/2022 00:00	8.0	13.2	6.1	118.3	3,442,732.9	2,011.2	1.1	0.8
01/28/2022 01:00	7.8	13.2	6.0	119.6	3,418,939.2	1,997.3	1.1	0.8
01/28/2022 02:00	6.5	13.8	5.4	88.7	2,909,831.2	1,487.4	1.0	0.6
01/28/2022 03:00	6.7	13.8	5.6	89.3	2,935,850.2	1,500.7	1.0	0.6
01/28/2022 04:00	6.7	13.7	5.5	101.0	3,397,541.9	1,736.7	0.9	0.5
01/28/2022 05:00	7.7	13.3	6.0	111.1	3,494,522.0	1,964.9	1.0	0.8
01/28/2022 06:00	8.1	13.1	6.1	132.2	3,499,471.0	2,069.9	1.2	1.0
01/28/2022 07:00	8.3	13.2	6.4	124.2	3,478,168.9	2,057.3	1.1	0.8
01/28/2022 08:00	7.6	13.4	6.0	113.2	3,453,439.3	1,941.8	1.1	0.8
01/28/2022 09:00	6.5	13.8	5.4	89.1	3,007,375.0	1,515.3	0.9	0.5
01/28/2022 10:00	6.8	13.9	5.7	85.3	2,796,007.4	1,408.8	1.0	0.6
01/28/2022 11:00	6.7	13.8	5.6	87.7	2,935,728.3	1,479.2	0.9	0.4
01/28/2022 12:00	6.7	13.9	5.6	85.8	2,854,356.7	1,438.2	1.0	0.6
01/28/2022 13:00	6.8	13.9	5.7	85.1	2,815,457.1	1,418.6	1.0	0.6
01/28/2022 14:00	6.8	13.8	5.7	96.7	3,201,674.5	1,613.2	1.0	0.6
01/28/2022 15:00	6.7	13.8	5.6	91.9	3,056,198.0	1,539.9	1.0	0.6
01/28/2022 16:00	7.3	13.8	6.1	95.2	3,106,245.8	1,587.8	1.0	0.6
01/28/2022 17:00	7.4	13.4	5.8	106.5	3,432,390.1	1,904.9	1.0	0.8
01/28/2022 18:00	7.9	13.1	6.0	117.3	3,413,417.1	2,019.0	1.1	0.8
01/28/2022 19:00	8.3	13.0	6.2	131.1	3,403,834.7	2,087.9	1.2	1.0
01/28/2022 20:00	7.9	13.1	6.0	127.3	3,368,951.0	2,017.3	1.2	1.0
01/28/2022 21:00	6.4	13.8	5.3	89.6	3,020,870.8	1,522.1	0.9	0.5
01/28/2022 22:00	6.8	13.7	5.6	103.5	3,442,462.9	1,784.8	1.0	0.7
01/28/2022 23:00	7.8	13.3	6.1	111.0	3,416,713.8	1,946.1	1.0	0.8
Average/Sum#:	7.3	13.5	5.8	104.2	3,220,924.2	1,752.1	1.0	0.7
Minimum:	6.4	13.0	5.3	85.1	2,796,007.4	1,408.8	0.9	0.4
Maximum:	8.3	13.9	6.4	132.2	3,499,471.0	2,087.9	1.2	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:13 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm	Unit CT2 O2Dry, Inlet, Pct	Unit CT2 NOx, Inlet, Ppmvdc	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 HI, MBtuPerHr	Unit CT2 NH3, Slip, Ppmvdc	Unit CT2 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/29/2022 00:00	7.1	13.4	5.6	106.3	3,419,777.0	1,897.9	1.0	0.8
01/29/2022 01:00	6.5	13.8	5.4	92.0	3,034,253.2	1,551.0	1.0	0.6
01/29/2022 02:00	6.9	13.7	5.7	92.7	3,058,315.9	1,563.3	1.0	0.6
01/29/2022 03:00	7.4	13.4	5.8	107.5	3,456,355.1	1,918.2	1.0	0.8
01/29/2022 04:00	7.4	13.4	5.8	108.0	3,415,632.7	1,895.6	1.0	0.8
01/29/2022 05:00	6.5	13.8	5.4	94.2	3,103,311.3	1,586.3	1.0	0.6
01/29/2022 06:00	6.6	13.7	5.4	90.2	3,093,934.7	1,604.1	0.9	0.5
01/29/2022 07:00	7.7	13.3	6.0	109.1	3,493,455.0	1,964.3	1.0	0.8
01/29/2022 08:00	7.8	13.2	6.0	113.8	3,481,978.2	2,008.7	1.0	0.8
01/29/2022 09:00	7.1	13.4	5.6	106.6	3,431,489.2	1,904.4	1.0	0.8
01/29/2022 10:00	6.7	13.8	5.6	85.4	2,769,809.7	1,395.6	1.0	0.6
01/29/2022 11:00	6.7	13.8	5.6	88.9	2,962,260.6	1,514.2	1.0	0.6
01/29/2022 12:00	6.8	13.9	5.7	82.5	2,707,490.9	1,364.2	1.0	0.5
01/29/2022 13:00	6.9	13.9	5.8	84.4	2,747,382.9	1,384.3	1.0	0.6
01/29/2022 14:00	6.8	13.8	5.7	93.6	3,159,401.0	1,591.9	0.9	0.5
01/29/2022 15:00	6.9	13.9	5.8	83.5	2,714,040.4	1,367.5	1.0	0.5
01/29/2022 16:00	6.8	13.8	5.7	93.8	3,121,096.8	1,572.6	1.0	0.6
01/29/2022 17:00	6.8	13.8	5.7	95.4	3,136,960.0	1,603.5	1.0	0.6
01/29/2022 18:00	7.6	13.5	6.1	105.9	3,305,679.4	1,786.3	1.0	0.7
01/29/2022 19:00	7.7	13.4	6.1	111.6	3,307,782.4	1,859.9	1.1	0.7
01/29/2022 20:00	6.7	13.7	5.5	103.4	3,408,902.3	1,767.4	1.0	0.7
01/29/2022 21:00	8.1	13.2	6.2	115.4	3,433,441.6	1,980.7	1.1	0.8
01/29/2022 22:00	8.2	13.1	6.2	124.2	3,428,070.0	2,052.7	1.2	1.0
01/29/2022 23:00	6.8	13.5	5.4	103.5	3,316,015.5	1,816.1	1.0	0.7
Average/Sum#:	7.1	13.6	5.7	99.7	3,187,784.8	1,706.3	1.0	0.7
Minimum:	6.5	13.1	5.4	82.5	2,707,490.9	1,364.2	0.9	0.5
Maximum:	8.2	13.9	6.2	124.2	3,493,455.0	2,052.7	1.2	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm	Unit CT2 O2Dry, Inlet, Pct	Unit CT2 NOx, Inlet, Ppmvdc	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 HI, MBtuPerHr	Unit CT2 NH3, Slip, Ppmvdc	Unit CT2 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/30/2022 00:00	6.5	13.8	5.4	92.9	3,076,314.1	1,572.5	1.0	0.6
01/30/2022 01:00	6.8	13.8	5.7	83.9	2,725,551.5	1,373.3	1.0	0.5
01/30/2022 02:00	6.7	13.7	5.5	100.2	3,357,633.0	1,716.3	1.0	0.7
01/30/2022 03:00	7.0	13.5	5.6	105.1	3,446,259.6	1,837.1	1.0	0.7
01/30/2022 04:00	6.9	13.5	5.5	104.2	3,372,115.0	1,822.2	1.0	0.7
01/30/2022 05:00	6.8	13.7	5.6	93.7	3,110,158.4	1,589.8	1.0	0.6
01/30/2022 06:00	7.5	13.3	5.8	112.6	3,416,453.8	1,970.9	1.1	0.8
01/30/2022 07:00	12.7	14.3	11.4	126.2	2,880,034.5	1,493.2	1.4	0.7
01/30/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/30/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/30/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/30/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/30/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/30/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/30/2022 14:00	25.1	18.0	51.1	0.0	1,332,509.5	223.8	-0.4	0.0
01/30/2022 15:00	39.3	15.6	43.7	156.4	2,122,876.3	790.6	2.3	0.7
01/30/2022 16:00	6.7	13.8	5.6	93.7	2,970,477.1	1,518.4	1.0	0.6
01/30/2022 17:00	7.4	13.4	5.8	107.0	3,407,376.9	1,915.9	1.0	0.8
01/30/2022 18:00	7.5	13.4	5.9	107.2	3,394,038.3	1,908.4	1.0	0.8
01/30/2022 19:00	7.4	13.4	5.8	107.2	3,387,991.5	1,905.0	1.0	0.8
01/30/2022 20:00	8.4	13.1	6.4	130.1	3,386,486.3	2,027.8	1.2	1.0
01/30/2022 21:00	7.1	13.4	5.6	106.1	3,384,640.5	1,878.4	1.0	0.8
01/30/2022 22:00	6.8	13.8	5.7	84.0	2,738,650.3	1,379.9	1.0	0.6
01/30/2022 23:00	6.9	13.8	5.7	81.2	2,691,018.1	1,355.9	1.0	0.5
Average/Sum#:	10.2	14.0	10.7	99.5	3,011,143.6	1,571.1	1.0	0.7
Minimum:	6.5	13.1	5.4	0.0	1,332,509.5	223.8	-0.4	0.0
Maximum:	39.3	18.0	51.1	156.4	3,446,259.6	2,027.8	2.3	1.0
%SI	25.00	25.00	25.00	25.00	25.00	25.00	25.00	25.00

Daily Summary Report

CT2 - NH3 Slip



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm	Unit CT2 O2Dry, Inlet, Pct	Unit CT2 NOx, Inlet, Ppmvdc	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 HI, MBtuPerHr	Unit CT2 NH3, Slip, Ppmvdc	Unit CT2 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/31/2022 00:00	6.9	13.8	5.7	81.1	2,639,858.9	1,349.4	1.0	0.5
01/31/2022 01:00	6.9	13.8	5.7	81.2	2,635,750.7	1,347.3	1.0	0.5
01/31/2022 02:00	7.0	13.7	5.7	92.6	3,060,467.9	1,564.4	1.0	0.6
01/31/2022 03:00	6.9	13.8	5.7	92.9	3,003,930.2	1,535.5	1.0	0.6
01/31/2022 04:00	6.9	13.8	5.7	87.4	2,846,055.1	1,454.8	1.0	0.6
01/31/2022 05:00	7.1	13.7	5.8	93.8	3,070,249.5	1,569.4	1.0	0.6
01/31/2022 06:00	7.6	13.3	5.9	112.2	3,399,812.7	1,961.3	1.1	0.8
01/31/2022 07:00	8.1	13.2	6.2	116.0	3,441,705.8	2,010.6	1.1	0.8
01/31/2022 08:00	7.1	13.4	5.6	106.5	3,467,887.1	1,924.6	1.0	0.8
01/31/2022 09:00	6.8	13.7	5.6	94.9	3,081,204.9	1,575.0	1.0	0.6
01/31/2022 10:00	7.0	13.8	5.8	88.7	2,853,684.8	1,458.7	1.0	0.6
01/31/2022 11:00	6.9	13.8	5.7	93.0	2,995,713.7	1,531.3	1.0	0.6
01/31/2022 12:00	6.9	13.8	5.7	94.4	3,071,227.6	1,569.9	1.0	0.6
01/31/2022 13:00	6.9	13.8	5.7	86.6	2,812,281.7	1,417.0	1.0	0.6
01/31/2022 14:00	6.9	13.8	5.7	92.0	3,034,565.0	1,529.0	1.0	0.6
01/31/2022 15:00	7.5	13.7	6.1	97.9	3,181,955.4	1,626.5	1.0	0.7
01/31/2022 16:00	8.3	13.3	6.4	115.5	3,396,345.8	1,959.3	1.1	0.8
01/31/2022 17:00	8.2	13.2	6.3	128.8	3,387,592.9	2,053.2	1.2	1.0
01/31/2022 18:00	8.1	13.2	6.2	128.7	3,390,397.8	2,054.9	1.2	1.0
01/31/2022 19:00	7.8	13.4	6.1	114.2	3,383,011.8	1,902.2	1.1	0.8
01/31/2022 20:00	6.6	13.8	5.5	95.1	3,147,096.0	1,585.7	1.0	0.6
01/31/2022 21:00	7.3	13.7	6.0	99.1	3,238,101.8	1,655.2	1.0	0.7
01/31/2022 22:00	8.1	13.4	6.4	114.3	3,439,186.4	1,958.9	1.1	0.8
01/31/2022 23:00	14.3	14.7	13.6	132.6	2,561,037.6	1,196.9	1.6	0.7
Average/Sum#:	7.6	13.7	6.2	101.6	3,105,796.7	1,658.0	1.1	0.7
Minimum:	6.6	13.2	5.5	81.1	2,561,037.6	1,196.9	1.0	0.5
Maximum:	14.3	14.7	13.6	132.6	3,467,887.1	2,054.9	1.6	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:13 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm	Unit CT2 O2Dry, Inlet, Pct	Unit CT2 NOx, Inlet, Ppmvdc	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 HI, MBtuPerHr	Unit CT2 NH3, Slip, Ppmvdc	Unit CT2 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/01/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/01/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/01/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/01/2022 03:00	37.0	17.1	57.4	228.5	1,699,988.2	446.9	3.8	0.7
02/01/2022 04:00	14.2	14.1	12.3	134.5	2,623,070.2	1,264.2	1.6	0.8
02/01/2022 05:00	6.7	13.8	5.6	79.8	2,614,608.2	1,317.4	1.0	0.5
02/01/2022 06:00	7.0	13.9	5.9	81.1	2,553,480.3	1,286.6	1.0	0.5
02/01/2022 07:00	8.1	13.4	6.4	99.6	3,209,735.1	1,640.7	1.0	0.7
02/01/2022 08:00	8.7	12.9	6.4	166.6	3,458,253.0	2,272.8	1.6	1.4
02/01/2022 09:00	8.5	12.9	6.3	168.3	3,447,754.1	2,265.9	1.6	1.4
02/01/2022 10:00	7.2	13.5	5.7	121.4	3,297,249.6	1,829.9	1.2	0.9
02/01/2022 11:00	6.6	13.8	5.5	92.0	3,057,190.3	1,540.4	1.0	0.6
02/01/2022 12:00	7.0	13.9	5.9	81.5	2,556,854.3	1,288.3	1.0	0.5
02/01/2022 13:00	7.1	13.9	6.0	81.3	2,558,045.1	1,288.9	1.0	0.5
02/01/2022 14:00	7.1	13.9	6.0	81.4	2,558,442.0	1,289.1	1.0	0.5
02/01/2022 15:00	7.0	13.9	5.9	81.2	2,603,295.6	1,311.7	1.0	0.5
02/01/2022 16:00	7.2	13.8	6.0	92.1	2,987,888.4	1,527.3	1.0	0.6
02/01/2022 17:00	7.3	13.7	6.0	106.8	3,484,793.8	1,781.3	1.0	0.7
02/01/2022 18:00	7.8	13.4	6.1	111.3	3,417,074.2	1,896.4	1.0	0.8
02/01/2022 19:00	8.0	13.3	6.2	120.7	3,455,629.8	1,993.5	1.1	0.8
02/01/2022 20:00	7.7	13.4	6.1	115.7	3,422,156.4	1,949.2	1.1	0.8
02/01/2022 21:00	6.5	13.8	5.4	94.3	3,096,659.8	1,582.9	1.0	0.6
02/01/2022 22:00	7.2	13.7	5.9	104.3	3,395,593.8	1,760.5	1.0	0.7
02/01/2022 23:00	8.2	13.3	6.4	116.4	3,488,520.8	1,987.0	1.1	0.8
Average/Sum#:	9.1	13.8	8.7	112.3	2,999,346.8	1,596.2	1.2	0.7
Minimum:	6.5	12.9	5.4	79.8	1,699,988.2	446.9	1.0	0.5
Maximum:	37.0	17.1	57.4	228.5	3,488,520.8	2,272.8	3.8	1.4
%SI	12.50	12.50	12.50	12.50	12.50	12.50	12.50	12.50

Daily Summary Report

CT2 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:13 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm	Unit CT2 O2Dry, Inlet, Pct	Unit CT2 NOx, Inlet, Ppmvdc	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 HI, MBtuPerHr	Unit CT2 NH3, Slip, Ppmvdc	Unit CT2 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/02/2022 00:00	8.4	13.1	6.4	133.3	3,483,947.6	2,111.6	1.2	1.1
02/02/2022 01:00	6.5	13.7	5.3	100.6	3,304,748.9	1,713.4	1.0	0.7
02/02/2022 02:00	6.9	13.8	5.7	93.6	3,078,074.8	1,573.4	1.0	0.6
02/02/2022 03:00	8.0	13.3	6.2	113.1	3,497,545.4	1,966.6	1.0	0.8
02/02/2022 04:00	7.3	13.4	5.7	109.5	3,501,041.5	1,943.0	1.0	0.8
02/02/2022 05:00	7.8	13.3	6.1	116.7	3,497,299.2	1,992.0	1.1	0.8
02/02/2022 06:00	7.8	13.2	6.0	123.1	3,472,927.9	2,054.2	1.1	0.8
02/02/2022 07:00	7.8	13.3	6.1	117.9	3,504,166.3	2,021.5	1.1	0.8
02/02/2022 08:00	7.9	13.3	6.1	115.6	3,500,986.1	1,994.1	1.1	0.8
02/02/2022 09:00	6.8	13.7	5.6	97.7	3,128,944.5	1,645.1	1.0	0.7
02/02/2022 10:00	6.7	13.9	5.6	80.0	2,652,912.4	1,336.7	1.0	0.5
02/02/2022 11:00	6.8	13.9	5.7	80.1	2,662,041.9	1,341.3	1.0	0.5
02/02/2022 12:00	6.8	13.9	5.7	80.4	2,672,560.7	1,346.6	1.0	0.5
02/02/2022 13:00	6.9	13.9	5.8	80.5	2,695,384.4	1,358.1	0.9	0.4
02/02/2022 14:00	6.9	13.8	5.7	80.9	2,700,544.6	1,360.7	0.9	0.4
02/02/2022 15:00	7.5	13.7	6.1	97.2	3,181,955.4	1,626.5	1.0	0.7
02/02/2022 16:00	6.8	13.8	5.7	96.5	3,146,741.6	1,608.5	1.0	0.6
02/02/2022 17:00	7.5	13.7	6.1	101.4	3,254,215.2	1,687.2	1.0	0.7
02/02/2022 18:00	8.1	13.2	6.2	119.5	3,428,125.7	2,027.7	1.1	0.8
02/02/2022 19:00	8.5	13.0	6.3	150.9	3,431,653.0	2,205.2	1.4	1.1
02/02/2022 20:00	8.4	13.0	6.3	159.6	3,409,405.1	2,215.8	1.5	1.3
02/02/2022 21:00	8.1	13.1	6.1	141.6	3,434,033.0	2,131.5	1.3	1.1
02/02/2022 22:00	7.9	13.2	6.1	128.7	3,404,188.6	2,038.4	1.2	1.0
02/02/2022 23:00	7.9	13.3	6.1	124.2	3,436,057.0	2,007.3	1.2	1.0
Average/Sum#:	7.5	13.5	5.9	110.1	3,228,312.5	1,804.4	1.1	0.8
Minimum:	6.5	13.0	5.3	80.0	2,652,912.4	1,336.7	0.9	0.4
Maximum:	8.5	13.9	6.4	159.6	3,504,166.3	2,215.8	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:13 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm	Unit CT2 O2Dry, Inlet, Pct	Unit CT2 NOx, Inlet, Ppmvdc	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 HI, MBtuPerHr	Unit CT2 NH3, Slip, Ppmvdc	Unit CT2 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/03/2022 00:00	7.2	13.5	5.7	106.8	3,434,011.8	1,905.8	1.0	0.8
02/03/2022 01:00	6.5	13.8	5.4	97.0	3,223,233.7	1,647.6	1.0	0.7
02/03/2022 02:00	6.7	13.7	5.5	103.4	3,473,642.8	1,775.6	0.9	0.5
02/03/2022 03:00	8.0	13.3	6.2	115.4	3,449,562.7	1,990.0	1.1	0.8
02/03/2022 04:00	7.7	13.3	6.0	115.9	3,460,781.2	1,971.2	1.1	0.8
02/03/2022 05:00	7.3	13.3	5.7	113.6	3,488,696.4	1,987.1	1.0	0.8
02/03/2022 06:00	8.0	13.1	6.1	139.1	3,442,410.7	2,136.7	1.3	1.1
02/03/2022 07:00	8.1	13.2	6.2	128.1	3,466,480.7	2,075.7	1.2	1.0
02/03/2022 08:00	7.1	13.5	5.7	106.4	3,448,607.0	1,913.9	1.0	0.8
02/03/2022 09:00	6.7	13.8	5.6	88.0	2,833,534.7	1,448.4	1.0	0.6
02/03/2022 10:00	6.7	13.8	5.6	97.7	3,240,058.1	1,656.2	1.0	0.7
02/03/2022 11:00	6.8	13.8	5.7	99.5	3,258,643.1	1,665.7	1.0	0.7
02/03/2022 12:00	6.8	13.9	5.7	84.7	2,735,077.9	1,378.1	1.0	0.6
02/03/2022 13:00	6.8	13.8	5.7	91.8	3,057,785.7	1,540.7	1.0	0.6
02/03/2022 14:00	6.8	13.9	5.7	88.5	2,909,927.6	1,466.2	1.0	0.6
02/03/2022 15:00	7.7	13.8	6.4	94.7	2,982,801.9	1,524.7	1.0	0.6
02/03/2022 16:00	8.5	13.3	6.6	119.6	3,391,665.5	1,956.6	1.1	0.8
02/03/2022 17:00	8.2	13.2	6.3	129.8	3,404,689.6	2,038.7	1.2	1.0
02/03/2022 18:00	8.2	13.2	6.3	138.1	3,394,542.2	2,082.2	1.3	1.0
02/03/2022 19:00	8.1	13.2	6.2	135.8	3,397,476.7	2,084.0	1.3	1.0
02/03/2022 20:00	8.1	13.2	6.2	133.7	3,398,128.8	2,084.4	1.3	1.0
02/03/2022 21:00	8.2	13.1	6.2	143.7	3,400,790.3	2,135.7	1.4	1.1
02/03/2022 22:00	7.9	13.2	6.1	130.4	3,395,017.5	2,057.7	1.2	1.0
02/03/2022 23:00	7.9	13.2	6.1	127.0	3,441,650.9	2,035.7	1.2	1.0
Average/Sum#:	7.5	13.5	6.0	113.7	3,297,050.7	1,856.6	1.1	0.8
Minimum:	6.5	13.1	5.4	84.7	2,735,077.9	1,378.1	0.9	0.5
Maximum:	8.5	13.9	6.6	143.7	3,488,696.4	2,136.7	1.4	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:13 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm	Unit CT2 O2Dry, Inlet, Pct	Unit CT2 NOx, Inlet, Ppmvdc	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 HI, MBtuPerHr	Unit CT2 NH3, Slip, Ppmvdc	Unit CT2 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/04/2022 00:00	7.8	13.3	6.1	121.6	3,424,930.4	2,000.8	1.1	0.8
02/04/2022 01:00	7.1	13.5	5.7	107.0	3,422,299.6	1,899.3	1.0	0.8
02/04/2022 02:00	6.5	13.8	5.4	93.9	3,122,678.9	1,596.2	1.0	0.6
02/04/2022 03:00	6.7	13.8	5.6	90.7	2,987,888.4	1,527.3	1.0	0.6
02/04/2022 04:00	6.9	13.7	5.7	93.7	3,096,659.8	1,582.9	1.0	0.6
02/04/2022 05:00	7.7	13.3	6.0	112.7	3,467,803.9	1,975.2	1.0	0.8
02/04/2022 06:00	8.2	13.1	6.2	139.5	3,451,927.6	2,117.4	1.3	1.1
02/04/2022 07:00	7.9	13.3	6.1	124.1	3,435,902.7	2,032.3	1.2	1.0
02/04/2022 08:00	13.8	14.8	13.3	127.1	2,574,300.5	1,184.3	1.5	0.7
02/04/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/04/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/04/2022 11:00	31.0	17.7	57.2	222.3	1,516,409.3	332.2	4.1	0.5
02/04/2022 12:00	33.4	15.5	36.5	223.0	2,185,653.0	845.9	3.1	1.0
02/04/2022 13:00	6.5	13.9	5.5	82.4	2,690,422.7	1,355.6	1.0	0.5
02/04/2022 14:00	6.7	13.9	5.6	80.2	2,679,507.0	1,350.1	0.9	0.4
02/04/2022 15:00	7.3	13.8	6.1	94.6	2,921,960.4	1,493.6	1.0	0.6
02/04/2022 16:00	7.1	13.8	5.9	98.3	3,186,194.1	1,605.4	1.0	0.6
02/04/2022 17:00	6.9	13.8	5.7	93.2	3,066,923.7	1,567.7	1.0	0.6
02/04/2022 18:00	7.0	13.8	5.8	89.5	2,890,676.3	1,456.5	1.0	0.6
02/04/2022 19:00	7.9	13.4	6.2	109.4	3,369,324.5	1,869.9	1.0	0.7
02/04/2022 20:00	7.6	13.4	6.0	108.6	3,403,819.9	1,913.9	1.0	0.8
02/04/2022 21:00	7.3	13.4	5.7	107.0	3,443,742.0	1,911.2	1.0	0.8
02/04/2022 22:00	7.4	13.4	5.8	109.3	3,439,567.2	1,934.0	1.0	0.8
02/04/2022 23:00	7.9	13.2	6.1	118.7	3,413,290.3	1,994.0	1.1	0.8
Average/Sum#:	9.8	13.9	9.9	115.8	3,054,176.5	1,615.7	1.3	0.7
Minimum:	6.5	13.1	5.4	80.2	1,516,409.3	332.2	0.9	0.4
Maximum:	33.4	17.7	57.2	223.0	3,467,803.9	2,117.4	4.1	1.1
%SI	8.33	8.33	8.33	8.33	8.33	8.33	8.33	8.33

Daily Summary Report

CT2 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:13 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm	Unit CT2 O2Dry, Inlet, Pct	Unit CT2 NOx, Inlet, Ppmvdc	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 HI, MBtuPerHr	Unit CT2 NH3, Slip, Ppmvdc	Unit CT2 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/05/2022 00:00	7.0	13.4	5.5	106.5	3,434,192.0	1,905.9	1.0	0.8
02/05/2022 01:00	6.7	13.7	5.5	100.0	3,241,292.5	1,680.5	1.0	0.7
02/05/2022 02:00	6.9	13.9	5.8	86.1	2,767,229.6	1,394.3	1.0	0.6
02/05/2022 03:00	7.2	13.5	5.7	106.6	3,416,987.7	1,871.4	1.0	0.7
02/05/2022 04:00	7.0	13.5	5.6	106.0	3,450,769.3	1,915.1	1.0	0.8
02/05/2022 05:00	6.7	13.7	5.5	100.8	3,273,888.7	1,697.4	1.0	0.7
02/05/2022 06:00	6.8	13.8	5.7	90.6	3,101,941.9	1,585.6	0.9	0.5
02/05/2022 07:00	8.3	13.2	6.4	115.3	3,441,935.5	1,985.6	1.1	0.8
02/05/2022 08:00	13.8	14.7	13.1	129.5	2,554,713.9	1,212.6	1.6	0.7
02/05/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/05/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/05/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/05/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/05/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/05/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/05/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/05/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/05/2022 17:00	35.7	17.6	63.8	37.8	1,451,589.8	307.4	0.6	0.1
02/05/2022 18:00	36.1	16.1	44.4	231.6	2,009,557.4	689.7	3.5	0.9
02/05/2022 19:00	6.4	13.9	5.4	84.8	2,569,159.2	1,294.5	1.1	0.5
02/05/2022 20:00	7.3	13.8	6.1	93.5	3,029,362.4	1,548.5	1.0	0.6
02/05/2022 21:00	8.2	13.3	6.4	119.7	3,397,028.4	1,984.5	1.1	0.8
02/05/2022 22:00	8.0	13.2	6.1	123.3	3,421,164.5	1,998.6	1.2	1.0
02/05/2022 23:00	7.8	13.3	6.1	120.6	3,427,326.9	2,002.2	1.1	0.8
Average/Sum#:	11.2	14.0	12.3	109.5	2,999,258.7	1,567.1	1.2	0.7
Minimum:	6.4	13.2	5.4	37.8	1,451,589.8	307.4	0.6	0.1
Maximum:	36.1	17.6	63.8	231.6	3,450,769.3	2,002.2	3.5	1.0
%SI	33.33	33.33	33.33	33.33	33.33	33.33	33.33	33.33

Daily Summary Report

CT2 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:13 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm	Unit CT2 O2Dry, Inlet, Pct	Unit CT2 NOx, Inlet, Ppmvdc	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 HI, MBtuPerHr	Unit CT2 NH3, Slip, Ppmvdc	Unit CT2 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/06/2022 00:00	7.1	13.5	5.7	107.0	3,434,192.0	1,905.9	1.0	0.8
02/06/2022 01:00	6.5	13.8	5.4	97.8	3,250,426.6	1,661.5	1.0	0.7
02/06/2022 02:00	6.9	13.7	5.7	94.9	3,130,112.9	1,600.0	1.0	0.6
02/06/2022 03:00	7.8	13.3	6.1	112.5	3,441,117.7	1,960.0	1.0	0.8
02/06/2022 04:00	6.9	13.5	5.5	105.5	3,418,695.9	1,897.3	1.0	0.8
02/06/2022 05:00	6.6	13.8	5.5	92.9	3,027,601.7	1,547.6	1.0	0.6
02/06/2022 06:00	7.0	13.8	5.8	81.8	2,591,784.5	1,305.9	1.0	0.5
02/06/2022 07:00	7.1	13.8	5.9	91.0	3,008,625.4	1,537.9	1.0	0.6
02/06/2022 08:00	26.2	16.4	34.4	173.5	1,291,253.1	452.6	4.1	0.7
02/06/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/06/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/06/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/06/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/06/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/06/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/06/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/06/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/06/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/06/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/06/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/06/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/06/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/06/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/06/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	9.1	14.0	8.9	106.3	2,954,867.8	1,541.0	1.3	0.7
Minimum:	6.5	13.3	5.4	81.8	1,291,253.1	452.6	1.0	0.5
Maximum:	26.2	16.4	34.4	173.5	3,441,117.7	1,960.0	4.1	0.8
%SI	62.50	62.50	62.50	62.50	62.50	62.50	62.50	62.50

Daily Summary Report

CT2 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:13 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm	Unit CT2 O2Dry, Inlet, Pct	Unit CT2 NOx, Inlet, Ppmvdc	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 HI, MBtuPerHr	Unit CT2 NH3, Slip, Ppmvdc	Unit CT2 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/07/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/07/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/07/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/07/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/07/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/07/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/07/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/07/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/07/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/07/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/07/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/07/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/07/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/07/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/07/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/07/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/07/2022 16:00	35.5	17.5	61.6	15.0	1,413,074.8	330.2	0.3	0.0
02/07/2022 17:00	34.3	15.5	37.5	218.9	2,164,480.6	821.9	3.1	1.0
02/07/2022 18:00	6.6	13.9	5.6	87.3	2,741,230.4	1,381.2	1.0	0.6
02/07/2022 19:00	7.4	13.7	6.1	93.8	3,031,123.1	1,549.4	1.0	0.6
02/07/2022 20:00	8.3	13.2	6.4	120.2	3,408,176.1	2,015.9	1.1	0.8
02/07/2022 21:00	8.0	13.2	6.1	124.4	3,401,516.6	2,036.8	1.2	1.0
02/07/2022 22:00	7.9	13.2	6.1	123.9	3,417,136.5	2,021.2	1.2	1.0
02/07/2022 23:00	14.3	14.7	13.6	134.2	2,521,215.6	1,196.7	1.7	0.8
Average/Sum#:	15.3	14.4	17.9	114.7	2,762,244.2	1,419.2	1.3	0.7
Minimum:	6.6	13.2	5.6	15.0	1,413,074.8	330.2	0.3	0.0
Maximum:	35.5	17.5	61.6	218.9	3,417,136.5	2,036.8	3.1	1.0
%SI	66.67	66.67	66.67	66.67	66.67	66.67	66.67	66.67

Daily Summary Report

CT2 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:13 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm	Unit CT2 O2Dry, Inlet, Pct	Unit CT2 NOx, Inlet, Ppmvdc	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 HI, MBtuPerHr	Unit CT2 NH3, Slip, Ppmvdc	Unit CT2 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/08/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/08/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/08/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/08/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/08/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/08/2022 05:00	32.3	17.6	57.7	168.9	1,457,774.3	330.0	3.2	0.4
02/08/2022 06:00	33.5	15.7	38.0	208.4	2,247,406.3	869.8	2.7	0.9
02/08/2022 07:00	7.1	13.9	6.0	87.9	2,500,886.5	1,260.1	1.1	0.5
02/08/2022 08:00	6.9	13.6	5.6	103.2	3,425,296.8	1,775.9	1.0	0.7
02/08/2022 09:00	7.0	13.6	5.7	105.8	3,463,679.3	1,795.8	1.0	0.7
02/08/2022 10:00	7.2	13.6	5.8	106.5	3,418,235.4	1,797.2	1.0	0.7
02/08/2022 11:00	7.2	13.6	5.8	106.9	3,411,198.1	1,793.5	1.0	0.7
02/08/2022 12:00	7.5	13.5	6.0	108.4	3,419,376.6	1,797.8	1.0	0.7
02/08/2022 13:00	7.5	13.5	6.0	108.4	3,414,811.9	1,795.4	1.0	0.7
02/08/2022 14:00	7.5	13.5	6.0	108.1	3,403,590.2	1,789.5	1.0	0.7
02/08/2022 15:00	6.9	13.6	5.6	104.5	3,413,724.2	1,769.9	1.0	0.7
02/08/2022 16:00	7.1	13.6	5.7	105.2	3,426,454.1	1,776.5	1.0	0.7
02/08/2022 17:00	7.6	13.4	6.0	108.8	3,396,172.5	1,884.8	1.0	0.8
02/08/2022 18:00	7.7	13.3	6.0	110.8	3,433,392.7	1,955.6	1.0	0.8
02/08/2022 19:00	7.0	13.3	5.4	106.5	3,432,097.6	1,929.8	1.0	0.8
02/08/2022 20:00	7.3	13.3	5.7	107.3	3,436,543.8	1,932.3	1.0	0.8
02/08/2022 21:00	6.9	13.6	5.6	99.1	3,140,108.9	1,673.9	1.0	0.7
02/08/2022 22:00	15.6	15.2	16.1	123.8	2,060,511.5	872.7	1.8	0.6
02/08/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	10.5	14.0	11.0	115.5	3,105,625.6	1,600.0	1.3	0.7
Minimum:	6.9	13.3	5.4	87.9	1,457,774.3	330.0	1.0	0.4
Maximum:	33.5	17.6	57.7	208.4	3,463,679.3	1,955.6	3.2	0.9
%SI	25.00	25.00	25.00	25.00	25.00	25.00	25.00	25.00

Daily Summary Report

CT2 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:13 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm	Unit CT2 O2Dry, Inlet, Pct	Unit CT2 NOx, Inlet, Ppmvdc	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 HI, MBtuPerHr	Unit CT2 NH3, Slip, Ppmvdc	Unit CT2 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/09/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/09/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/09/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/09/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/09/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/09/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/09/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/09/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/09/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/09/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/09/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/09/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/09/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/09/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/09/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/09/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/09/2022 16:00	42.1	16.7	59.1	72.3	1,754,618.9	499.7	1.2	0.2
02/09/2022 17:00	6.9	13.7	5.7	122.4	3,243,188.2	1,657.8	1.2	0.8
02/09/2022 18:00	7.2	13.5	5.7	105.9	3,401,307.8	1,788.3	1.0	0.7
02/09/2022 19:00	7.6	13.2	5.8	111.9	3,410,386.8	1,967.4	1.1	0.8
02/09/2022 20:00	7.8	13.1	5.9	119.2	3,438,269.6	2,033.7	1.1	0.8
02/09/2022 21:00	7.8	13.1	5.9	119.5	3,443,679.7	2,036.9	1.1	0.8
02/09/2022 22:00	7.5	13.2	5.7	112.8	3,428,241.3	1,977.7	1.1	0.8
02/09/2022 23:00	6.9	13.7	5.7	92.1	2,902,215.3	1,504.7	1.0	0.6
Average/Sum#:	11.7	13.8	12.4	107.0	3,127,738.5	1,683.3	1.1	0.7
Minimum:	6.9	13.1	5.7	72.3	1,754,618.9	499.7	1.0	0.2
Maximum:	42.1	16.7	59.1	122.4	3,443,679.7	2,036.9	1.2	0.8
%SI	66.67	66.67	66.67	66.67	66.67	66.67	66.67	66.67

Daily Summary Report

CT2 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:13 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm	Unit CT2 O2Dry, Inlet, Pct	Unit CT2 NOx, Inlet, Ppmvdc	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 HI, MBtuPerHr	Unit CT2 NH3, Slip, Ppmvdc	Unit CT2 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/10/2022 00:00	6.8	13.9	5.7	81.5	2,666,606.7	1,343.6	1.0	0.5
02/10/2022 01:00	7.6	13.7	6.2	95.4	3,079,835.4	1,574.3	1.0	0.6
02/10/2022 02:00	7.7	13.3	6.0	109.2	3,393,714.5	1,933.0	1.0	0.8
02/10/2022 03:00	7.5	13.3	5.8	109.7	3,407,408.8	1,940.8	1.0	0.8
02/10/2022 04:00	6.8	13.7	5.6	95.0	3,094,507.8	1,581.8	1.0	0.6
02/10/2022 05:00	7.3	13.7	6.0	94.7	3,083,552.4	1,576.2	1.0	0.6
02/10/2022 06:00	7.8	13.2	6.0	114.3	3,364,942.9	2,014.9	1.1	0.8
02/10/2022 07:00	7.8	13.2	6.0	115.2	3,358,640.1	1,986.6	1.1	0.8
02/10/2022 08:00	21.8	16.0	26.2	158.8	1,578,525.0	599.4	3.1	0.7
02/10/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/10/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/10/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/10/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/10/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/10/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/10/2022 15:00	17.5	18.1	36.9	0.1	740,250.0	97.3	-0.6	0.0
02/10/2022 16:00	39.6	15.6	44.1	181.6	2,092,534.2	779.3	2.7	0.8
02/10/2022 17:00	7.0	13.6	5.7	100.6	2,842,110.8	1,535.8	1.1	0.6
02/10/2022 18:00	7.9	12.9	5.8	133.9	3,340,178.2	2,195.2	1.3	1.1
02/10/2022 19:00	7.9	12.9	5.8	132.8	3,376,564.8	2,169.8	1.3	1.1
02/10/2022 20:00	7.8	13.0	5.8	126.1	3,345,376.4	2,100.9	1.2	1.1
02/10/2022 21:00	7.6	13.2	5.8	114.6	3,380,280.4	1,999.4	1.1	0.8
02/10/2022 22:00	7.5	13.2	5.7	112.5	3,379,397.0	1,974.2	1.1	0.8
02/10/2022 23:00	7.0	13.7	5.7	91.9	2,851,065.5	1,499.0	1.0	0.6
Average/Sum#:	10.6	13.9	10.8	109.3	2,909,749.5	1,605.6	1.2	0.7
Minimum:	6.8	12.9	5.6	0.1	740,250.0	97.3	-0.6	0.0
Maximum:	39.6	18.1	44.1	181.6	3,407,408.8	2,195.2	3.1	1.1
%SI	25.00	25.00	25.00	25.00	25.00	25.00	25.00	25.00

Daily Summary Report

CT2 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:13 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm	Unit CT2 O2Dry, Inlet, Pct	Unit CT2 NOx, Inlet, Ppmvdc	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 HI, MBtuPerHr	Unit CT2 NH3, Slip, Ppmvdc	Unit CT2 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/11/2022 00:00	7.2	13.8	6.0	84.1	2,525,893.4	1,272.7	1.1	0.5
02/11/2022 01:00	29.0	17.2	46.2	186.5	861,433.1	264.2	6.9	0.7
02/11/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/11/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/11/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/11/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/11/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/11/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/11/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/11/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/11/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/11/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/11/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/11/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/11/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/11/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/11/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/11/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/11/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/11/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/11/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/11/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/11/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/11/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	18.1	15.5	26.1	135.3	1,693,663.3	768.5	4.0	0.6
Minimum:	7.2	13.8	6.0	84.1	861,433.1	264.2	1.1	0.5
Maximum:	29.0	17.2	46.2	186.5	2,525,893.4	1,272.7	6.9	0.7
%SI	91.67	91.67	91.67	91.67	91.67	91.67	91.67	91.67

Daily Summary Report

CT2 - NH3 Slip



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm	Unit CT2 O2Dry, Inlet, Pct	Unit CT2 NOx, Inlet, Ppmvdc	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 HI, MBtuPerHr	Unit CT2 NH3, Slip, Ppmvdc	Unit CT2 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/12/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/12/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/12/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/12/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/12/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/12/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/12/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/12/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/12/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/12/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/12/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/12/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/12/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/12/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/12/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/12/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/12/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/12/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/12/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/12/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/12/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/12/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/12/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/12/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm	Unit CT2 O2Dry, Inlet, Pct	Unit CT2 NOx, Inlet, Ppmvdc	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 HI, MBtuPerHr	Unit CT2 NH3, Slip, Ppmvdc	Unit CT2 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/13/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/13/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/13/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/13/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/13/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/13/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/13/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/13/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/13/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/13/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/13/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/13/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/13/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/13/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/13/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/13/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/13/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/13/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/13/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/13/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/13/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/13/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/13/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/13/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm	Unit CT2 O2Dry, Inlet, Pct	Unit CT2 NOx, Inlet, Ppmvdc	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 HI, MBtuPerHr	Unit CT2 NH3, Slip, Ppmvdc	Unit CT2 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/14/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/14/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/14/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/14/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/14/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/14/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/14/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/14/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/14/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/14/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/14/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/14/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/14/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/14/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/14/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/14/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/14/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/14/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/14/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/14/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/14/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/14/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/14/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/14/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm	Unit CT2 O2Dry, Inlet, Pct	Unit CT2 NOx, Inlet, Ppmvdc	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 HI, MBtuPerHr	Unit CT2 NH3, Slip, Ppmvdc	Unit CT2 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/15/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm	Unit CT2 O2Dry, Inlet, Pct	Unit CT2 NOx, Inlet, Ppmvdc	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 HI, MBtuPerHr	Unit CT2 NH3, Slip, Ppmvdc	Unit CT2 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/16/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:13 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm	Unit CT2 O2Dry, Inlet, Pct	Unit CT2 NOx, Inlet, Ppmvdc	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 HI, MBtuPerHr	Unit CT2 NH3, Slip, Ppmvdc	Unit CT2 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/17/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/17/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/17/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/17/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/17/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/17/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/17/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/17/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/17/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/17/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/17/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/17/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/17/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/17/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/17/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/17/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/17/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/17/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/17/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/17/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/17/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/17/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/17/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/17/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:13 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm	Unit CT2 O2Dry, Inlet, Pct	Unit CT2 NOx, Inlet, Ppmvdc	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 HI, MBtuPerHr	Unit CT2 NH3, Slip, Ppmvdc	Unit CT2 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/18/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/18/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/18/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/18/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/18/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/18/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/18/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/18/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/18/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/18/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/18/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/18/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/18/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/18/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/18/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/18/2022 15:00	35.8	17.5	62.1	11.3	1,429,764.6	334.1	0.4	0.1
02/18/2022 16:00	39.7	15.2	41.1	223.8	2,180,621.6	875.8	3.2	1.1
02/18/2022 17:00	6.2	13.8	5.2	97.3	3,194,132.8	1,609.4	1.0	0.6
02/18/2022 18:00	7.3	13.8	6.1	94.9	3,039,535.2	1,553.7	1.0	0.6
02/18/2022 19:00	7.8	13.3	6.1	114.1	3,462,712.5	1,972.3	1.1	0.8
02/18/2022 20:00	7.1	13.4	5.6	107.8	3,391,548.4	1,907.0	1.0	0.8
02/18/2022 21:00	6.7	13.8	5.6	92.0	3,000,017.6	1,533.5	1.0	0.6
02/18/2022 22:00	7.1	13.8	5.9	94.2	3,057,142.1	1,562.7	1.0	0.6
02/18/2022 23:00	7.9	13.3	6.1	113.3	3,451,300.6	1,965.8	1.1	0.8
Average/Sum#:	14.0	14.2	16.0	105.4	2,911,863.9	1,479.4	1.2	0.7
Minimum:	6.2	13.3	5.2	11.3	1,429,764.6	334.1	0.4	0.1
Maximum:	39.7	17.5	62.1	223.8	3,462,712.5	1,972.3	3.2	1.1
%SI	62.50	62.50	62.50	62.50	62.50	62.50	62.50	62.50

Daily Summary Report

CT2 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:13 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm	Unit CT2 O2Dry, Inlet, Pct	Unit CT2 NOx, Inlet, Ppmvdc	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 HI, MBtuPerHr	Unit CT2 NH3, Slip, Ppmvdc	Unit CT2 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/19/2022 00:00	13.8	14.7	13.1	128.7	2,585,858.4	1,208.5	1.5	0.7
02/19/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/19/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/19/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/19/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/19/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/19/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/19/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/19/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/19/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/19/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/19/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/19/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/19/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/19/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/19/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/19/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/19/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/19/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/19/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/19/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/19/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/19/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/19/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	13.8	14.7	13.1	128.7	2,585,858.4	1,208.5	1.5	0.7
Minimum:	13.8	14.7	13.1	128.7	2,585,858.4	1,208.5	1.5	0.7
Maximum:	13.8	14.7	13.1	128.7	2,585,858.4	1,208.5	1.5	0.7
%SI	95.83	95.83	95.83	95.83	95.83	95.83	95.83	95.83

Daily Summary Report

CT2 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:13 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm	Unit CT2 O2Dry, Inlet, Pct	Unit CT2 NOx, Inlet, Ppmvdc	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 HI, MBtuPerHr	Unit CT2 NH3, Slip, Ppmvdc	Unit CT2 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/20/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/20/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/20/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/20/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/20/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/20/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/20/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/20/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/20/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/20/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/20/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/20/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/20/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/20/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/20/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/20/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/20/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/20/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/20/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/20/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/20/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/20/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/20/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/20/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:13 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm	Unit CT2 O2Dry, Inlet, Pct	Unit CT2 NOx, Inlet, Ppmvdc	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 HI, MBtuPerHr	Unit CT2 NH3, Slip, Ppmvdc	Unit CT2 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/21/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/21/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/21/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/21/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/21/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/21/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/21/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/21/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/21/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/21/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/21/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/21/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/21/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/21/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/21/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/21/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/21/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/21/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/21/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/21/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/21/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/21/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/21/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/21/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm	Unit CT2 O2Dry, Inlet, Pct	Unit CT2 NOx, Inlet, Ppmvdc	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 HI, MBtuPerHr	Unit CT2 NH3, Slip, Ppmvdc	Unit CT2 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/22/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/22/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/22/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/22/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/22/2022 04:00	29.7	17.6	53.1	0.0	1,368,055.0	299.7	0.0	0.0
02/22/2022 05:00	31.8	15.6	35.4	145.0	2,202,625.1	820.3	2.1	0.7
02/22/2022 06:00	6.3	13.7	5.2	100.2	3,337,874.1	1,706.2	1.0	0.7
02/22/2022 07:00	6.7	13.8	5.6	93.9	3,051,077.5	1,559.6	1.0	0.6
02/22/2022 08:00	6.7	13.7	5.5	95.7	3,159,653.3	1,615.1	1.0	0.6
02/22/2022 09:00	6.7	13.8	5.6	92.0	2,966,173.2	1,516.2	1.0	0.6
02/22/2022 10:00	6.8	13.8	5.7	90.1	2,976,215.7	1,499.6	1.0	0.6
02/22/2022 11:00	6.8	13.8	5.7	89.5	2,975,223.3	1,499.1	1.0	0.6
02/22/2022 12:00	6.7	13.8	5.6	94.2	3,125,264.6	1,574.7	1.0	0.6
02/22/2022 13:00	6.7	13.8	5.6	92.6	3,102,043.9	1,563.0	0.9	0.5
02/22/2022 14:00	6.7	13.8	5.6	94.4	3,086,486.9	1,577.7	1.0	0.6
02/22/2022 15:00	6.8	13.8	5.7	94.5	3,113,484.2	1,591.5	1.0	0.6
02/22/2022 16:00	7.0	13.7	5.7	95.9	3,128,352.2	1,599.1	1.0	0.6
02/22/2022 17:00	7.9	13.3	6.1	115.5	3,480,938.1	2,008.1	1.1	0.8
02/22/2022 18:00	7.5	13.3	5.8	115.8	3,456,427.1	2,019.2	1.1	0.8
02/22/2022 19:00	7.8	13.2	6.0	125.2	3,503,555.4	2,097.9	1.2	1.0
02/22/2022 20:00	8.1	13.0	6.0	146.4	3,446,436.6	2,214.7	1.4	1.1
02/22/2022 21:00	7.7	13.2	5.9	125.0	3,482,513.0	2,085.3	1.2	1.0
02/22/2022 22:00	7.6	13.2	5.8	124.8	3,473,327.8	2,079.8	1.2	1.0
02/22/2022 23:00	7.8	13.1	5.9	131.3	3,470,512.7	2,128.8	1.2	1.1
Average/Sum#:	9.5	13.9	9.6	103.1	3,095,312.0	1,652.8	1.1	0.7
Minimum:	6.3	13.0	5.2	0.0	1,368,055.0	299.7	0.0	0.0
Maximum:	31.8	17.6	53.1	146.4	3,503,555.4	2,214.7	2.1	1.1
%SI	16.67	16.67	16.67	16.67	16.67	16.67	16.67	16.67

Daily Summary Report

CT2 - NH3 Slip



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm	Unit CT2 O2Dry, Inlet, Pct	Unit CT2 NOx, Inlet, Ppmvdc	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 HI, MBtuPerHr	Unit CT2 NH3, Slip, Ppmvdc	Unit CT2 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/23/2022 00:00	8.0	13.0	6.0	143.8	3,501,108.6	2,198.7	1.3	1.1
02/23/2022 01:00	7.8	13.1	5.9	133.3	3,504,748.3	2,149.8	1.2	1.1
02/23/2022 02:00	7.7	13.1	5.8	130.7	3,518,595.7	2,132.6	1.2	1.1
02/23/2022 03:00	7.4	13.3	5.7	118.1	3,451,120.6	2,016.1	1.1	0.8
02/23/2022 04:00	6.3	13.8	5.2	97.6	3,296,204.5	1,684.9	0.9	0.5
02/23/2022 05:00	6.8	13.6	5.5	105.2	3,459,953.9	1,844.4	1.0	0.7
02/23/2022 06:00	7.8	13.1	5.9	134.7	3,515,182.0	2,156.2	1.2	1.1
02/23/2022 07:00	8.0	13.1	6.1	131.9	3,516,649.2	2,157.1	1.2	1.1
02/23/2022 08:00	6.5	13.7	5.3	100.5	3,232,998.8	1,676.2	1.0	0.7
02/23/2022 09:00	6.5	13.8	5.4	89.3	3,022,061.6	1,522.7	0.9	0.5
02/23/2022 10:00	6.6	13.8	5.5	93.1	3,131,417.1	1,577.8	0.9	0.5
02/23/2022 11:00	6.6	13.8	5.5	96.6	3,206,996.3	1,639.3	1.0	0.7
02/23/2022 12:00	6.7	13.8	5.6	89.7	3,000,230.2	1,511.7	0.9	0.5
02/23/2022 13:00	6.7	13.9	5.6	85.1	2,809,503.1	1,415.6	1.0	0.6
02/23/2022 14:00	6.6	13.8	5.5	95.0	3,214,376.4	1,619.6	0.9	0.5
02/23/2022 15:00	6.7	13.8	5.6	94.7	3,150,271.5	1,587.3	1.0	0.6
02/23/2022 16:00	6.7	13.8	5.6	94.3	3,197,903.6	1,611.3	0.9	0.5
02/23/2022 17:00	7.8	13.4	6.1	112.4	3,472,017.5	1,977.6	1.0	0.8
02/23/2022 18:00	7.7	13.3	6.0	118.5	3,479,724.7	2,007.4	1.1	0.8
02/23/2022 19:00	7.7	13.3	6.0	118.4	3,524,863.3	2,007.7	1.1	0.8
02/23/2022 20:00	7.8	13.2	6.0	132.1	3,517,750.6	2,106.4	1.2	1.1
02/23/2022 21:00	8.1	13.0	6.0	155.7	3,478,649.2	2,235.4	1.5	1.3
02/23/2022 22:00	7.8	13.2	6.0	133.2	3,505,561.4	2,124.7	1.2	1.1
02/23/2022 23:00	7.4	13.2	5.7	120.9	3,569,404.7	2,085.2	1.1	0.8
Average/Sum#:	7.2	13.5	5.7	113.5	3,344,887.2	1,876.9	1.1	0.8
Minimum:	6.3	13.0	5.2	85.1	2,809,503.1	1,415.6	0.9	0.5
Maximum:	8.1	13.9	6.1	155.7	3,569,404.7	2,235.4	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm	Unit CT2 O2Dry, Inlet, Pct	Unit CT2 NOx, Inlet, Ppmvdc	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 HI, MBtuPerHr	Unit CT2 NH3, Slip, Ppmvdc	Unit CT2 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/24/2022 00:00	7.9	13.1	6.0	144.4	3,508,592.7	2,203.4	1.3	1.1
02/24/2022 01:00	7.9	13.1	6.0	145.6	3,499,834.7	2,197.9	1.4	1.1
02/24/2022 02:00	7.9	13.0	5.9	147.7	3,525,471.6	2,214.0	1.4	1.1
02/24/2022 03:00	7.9	13.0	5.9	152.9	3,484,407.0	2,239.1	1.4	1.1
02/24/2022 04:00	7.7	13.0	5.8	143.5	3,566,235.9	2,239.6	1.3	1.1
02/24/2022 05:00	7.8	13.0	5.8	145.2	3,529,494.6	2,242.3	1.4	1.1
02/24/2022 06:00	7.8	13.0	5.8	149.0	3,531,855.7	2,243.8	1.4	1.1
02/24/2022 07:00	7.9	13.1	6.0	131.4	3,550,395.7	2,177.8	1.2	1.1
02/24/2022 08:00	7.4	13.3	5.7	116.9	3,574,899.9	2,036.2	1.1	0.8
02/24/2022 09:00	7.1	13.4	5.6	110.5	3,518,880.1	1,952.9	1.0	0.8
02/24/2022 10:00	6.4	13.8	5.3	91.1	3,053,816.4	1,561.0	1.0	0.6
02/24/2022 11:00	6.5	13.8	5.4	83.6	2,838,677.8	1,430.3	0.9	0.4
02/24/2022 12:00	6.7	13.9	5.6	80.4	2,642,393.7	1,331.4	1.0	0.5
02/24/2022 13:00	6.6	13.9	5.6	81.4	2,737,062.6	1,379.1	0.9	0.4
02/24/2022 14:00	6.6	13.8	5.5	86.2	2,898,813.4	1,460.6	0.9	0.4
02/24/2022 15:00	6.7	13.9	5.6	87.4	2,889,882.4	1,456.1	1.0	0.6
02/24/2022 16:00	7.2	13.8	6.0	93.6	3,055,577.1	1,561.9	1.0	0.6
02/24/2022 17:00	8.1	13.3	6.3	116.2	3,466,399.4	1,974.4	1.1	0.8
02/24/2022 18:00	8.3	13.0	6.2	147.2	3,500,087.6	2,172.5	1.4	1.1
02/24/2022 19:00	8.3	13.0	6.2	153.8	3,485,263.8	2,214.2	1.4	1.1
02/24/2022 20:00	8.0	13.1	6.1	142.4	3,486,393.4	2,164.0	1.3	1.1
02/24/2022 21:00	8.0	13.0	6.0	146.2	3,487,095.9	2,189.9	1.4	1.1
02/24/2022 22:00	7.8	13.0	5.8	139.8	3,521,998.4	2,186.1	1.3	1.1
02/24/2022 23:00	7.7	13.1	5.8	131.5	3,536,744.7	2,143.6	1.2	1.1
Average/Sum#:	7.5	13.3	5.8	123.7	3,328,761.4	1,957.2	1.2	0.9
Minimum:	6.4	13.0	5.3	80.4	2,642,393.7	1,331.4	0.9	0.4
Maximum:	8.3	13.9	6.3	153.8	3,574,899.9	2,243.8	1.4	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm	Unit CT2 O2Dry, Inlet, Pct	Unit CT2 NOx, Inlet, Ppmvdc	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 HI, MBtuPerHr	Unit CT2 NH3, Slip, Ppmvdc	Unit CT2 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/25/2022 00:00	7.6	13.2	5.8	122.6	3,510,519.4	2,050.8	1.1	0.8
02/25/2022 01:00	7.5	13.3	5.8	116.8	3,514,855.9	2,002.0	1.1	0.8
02/25/2022 02:00	7.6	13.3	5.9	116.8	3,509,588.9	1,999.0	1.1	0.8
02/25/2022 03:00	7.6	13.3	5.9	117.3	3,512,749.1	2,000.8	1.1	0.8
02/25/2022 04:00	7.7	13.2	5.9	121.5	3,536,755.2	2,040.3	1.1	0.8
02/25/2022 05:00	7.5	13.3	5.8	118.0	3,525,565.5	2,008.1	1.1	0.8
02/25/2022 06:00	8.0	13.1	6.1	143.9	3,523,496.3	2,161.3	1.3	1.1
02/25/2022 07:00	7.6	13.3	5.9	117.6	3,549,442.7	2,021.7	1.1	0.8
02/25/2022 08:00	7.2	13.4	5.7	110.5	3,511,386.7	1,923.1	1.0	0.8
02/25/2022 09:00	6.5	13.8	5.4	89.7	3,002,413.3	1,512.8	1.0	0.6
02/25/2022 10:00	6.5	13.8	5.4	88.0	2,985,543.6	1,504.3	0.9	0.5
02/25/2022 11:00	6.6	13.8	5.5	94.7	3,189,171.1	1,606.9	0.9	0.5
02/25/2022 12:00	6.6	13.8	5.5	93.4	3,150,668.4	1,587.5	0.9	0.5
02/25/2022 13:00	6.5	13.8	5.4	94.0	3,173,889.1	1,599.2	0.9	0.5
02/25/2022 14:00	6.6	13.9	5.6	93.2	3,127,447.7	1,575.8	0.9	0.5
02/25/2022 15:00	6.6	13.9	5.6	90.7	3,080,411.0	1,552.1	0.9	0.5
02/25/2022 16:00	7.1	13.8	5.9	97.4	3,210,517.7	1,641.1	1.0	0.7
02/25/2022 17:00	7.4	13.3	5.7	111.8	3,502,390.6	1,994.9	1.0	0.8
02/25/2022 18:00	6.9	13.4	5.4	106.4	3,446,681.1	1,938.0	1.0	0.8
02/25/2022 19:00	7.3	13.5	5.8	107.4	3,462,841.8	1,921.8	1.0	0.8
02/25/2022 20:00	7.7	13.4	6.1	122.1	3,482,250.6	1,958.0	1.1	0.8
02/25/2022 21:00	7.5	13.3	5.8	118.2	3,443,495.6	1,986.5	1.1	0.8
02/25/2022 22:00	7.6	13.3	5.9	121.8	3,461,904.8	2,022.4	1.1	0.8
02/25/2022 23:00	7.5	13.3	5.8	120.6	3,517,860.6	2,029.4	1.1	0.8
Average/Sum#:	7.2	13.5	5.7	109.8	3,372,160.3	1,859.9	1.0	0.7
Minimum:	6.5	13.1	5.4	88.0	2,985,543.6	1,504.3	0.9	0.5
Maximum:	8.0	13.9	6.1	143.9	3,549,442.7	2,161.3	1.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:13 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm	Unit CT2 O2Dry, Inlet, Pct	Unit CT2 NOx, Inlet, Ppmvdc	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 HI, MBtuPerHr	Unit CT2 NH3, Slip, Ppmvdc	Unit CT2 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/26/2022 00:00	7.4	13.2	5.7	120.0	3,523,700.1	2,058.5	1.1	0.8
02/26/2022 01:00	7.4	13.2	5.7	121.3	3,525,754.3	2,059.7	1.1	0.8
02/26/2022 02:00	6.7	13.5	5.3	106.8	3,488,969.0	1,936.3	1.0	0.8
02/26/2022 03:00	6.7	13.5	5.3	104.5	3,529,097.9	1,932.8	0.9	0.6
02/26/2022 04:00	7.6	13.3	5.9	118.0	3,526,267.8	2,008.5	1.1	0.8
02/26/2022 05:00	7.4	13.3	5.7	114.6	3,522,229.7	2,006.2	1.0	0.8
02/26/2022 06:00	7.2	13.3	5.6	114.0	3,546,631.3	1,994.2	1.0	0.8
02/26/2022 07:00	16.2	15.2	16.8	127.0	2,609,514.2	1,200.5	1.4	0.6
02/26/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/26/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/26/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/26/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/26/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/26/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/26/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/26/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/26/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/26/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/26/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/26/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/26/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/26/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/26/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/26/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	8.3	13.6	7.0	115.8	3,409,020.5	1,899.6	1.1	0.8
Minimum:	6.7	13.2	5.3	104.5	2,609,514.2	1,200.5	0.9	0.6
Maximum:	16.2	15.2	16.8	127.0	3,546,631.3	2,059.7	1.4	0.8
%SI	66.67	66.67	66.67	66.67	66.67	66.67	66.67	66.67

Daily Summary Report

CT2 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:13 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm	Unit CT2 O2Dry, Inlet, Pct	Unit CT2 NOx, Inlet, Ppmvdc	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 HI, MBtuPerHr	Unit CT2 NH3, Slip, Ppmvdc	Unit CT2 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/27/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/27/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/27/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/27/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/27/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/27/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/27/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/27/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/27/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/27/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/27/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/27/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/27/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/27/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/27/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/27/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/27/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/27/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/27/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/27/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/27/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/27/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/27/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/27/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:13 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm	Unit CT2 O2Dry, Inlet, Pct	Unit CT2 NOx, Inlet, Ppmvdc	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 HI, MBtuPerHr	Unit CT2 NH3, Slip, Ppmvdc	Unit CT2 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/28/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/28/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/28/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/28/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/28/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/28/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/28/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/28/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/28/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/28/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/28/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/28/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/28/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/28/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/28/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/28/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/28/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/28/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/28/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/28/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/28/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/28/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/28/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/28/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm	Unit CT2 O2Dry, Inlet, Pct	Unit CT2 NOx, Inlet, Ppmvdc	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 HI, MBtuPerHr	Unit CT2 NH3, Slip, Ppmvdc	Unit CT2 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/01/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/01/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/01/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/01/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/01/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/01/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/01/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/01/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/01/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/01/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/01/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/01/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/01/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/01/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/01/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/01/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/01/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/01/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/01/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/01/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/01/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/01/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/01/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/01/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm	Unit CT2 O2Dry, Inlet, Pct	Unit CT2 NOx, Inlet, Ppmvdc	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 HI, MBtuPerHr	Unit CT2 NH3, Slip, Ppmvdc	Unit CT2 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/02/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:13 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm	Unit CT2 O2Dry, Inlet, Pct	Unit CT2 NOx, Inlet, Ppmvdc	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 HI, MBtuPerHr	Unit CT2 NH3, Slip, Ppmvdc	Unit CT2 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/03/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/03/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/03/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/03/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/03/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/03/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/03/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/03/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/03/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/03/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/03/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/03/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/03/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/03/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/03/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/03/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/03/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/03/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/03/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/03/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/03/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/03/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/03/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/03/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:13 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm	Unit CT2 O2Dry, Inlet, Pct	Unit CT2 NOx, Inlet, Ppmvdc	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 HI, MBtuPerHr	Unit CT2 NH3, Slip, Ppmvdc	Unit CT2 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/04/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/04/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/04/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/04/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/04/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/04/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/04/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/04/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/04/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/04/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/04/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/04/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/04/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/04/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/04/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/04/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/04/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/04/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/04/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/04/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/04/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/04/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/04/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/04/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:13 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm	Unit CT2 O2Dry, Inlet, Pct	Unit CT2 NOx, Inlet, Ppmvdc	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 HI, MBtuPerHr	Unit CT2 NH3, Slip, Ppmvdc	Unit CT2 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/05/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/05/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/05/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/05/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/05/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/05/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/05/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/05/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/05/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/05/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/05/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/05/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/05/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/05/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/05/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/05/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/05/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/05/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/05/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/05/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/05/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/05/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/05/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/05/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm	Unit CT2 O2Dry, Inlet, Pct	Unit CT2 NOx, Inlet, Ppmvdc	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 HI, MBtuPerHr	Unit CT2 NH3, Slip, Ppmvdc	Unit CT2 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/06/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/06/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/06/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/06/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/06/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/06/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/06/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/06/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/06/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/06/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/06/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/06/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/06/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/06/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/06/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/06/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/06/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/06/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/06/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/06/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/06/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/06/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/06/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/06/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:13 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm	Unit CT2 O2Dry, Inlet, Pct	Unit CT2 NOx, Inlet, Ppmvdc	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 HI, MBtuPerHr	Unit CT2 NH3, Slip, Ppmvdc	Unit CT2 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/07/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm	Unit CT2 O2Dry, Inlet, Pct	Unit CT2 NOx, Inlet, Ppmvdc	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 HI, MBtuPerHr	Unit CT2 NH3, Slip, Ppmvdc	Unit CT2 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/08/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:13 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm	Unit CT2 O2Dry, Inlet, Pct	Unit CT2 NOx, Inlet, Ppmvdc	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 HI, MBtuPerHr	Unit CT2 NH3, Slip, Ppmvdc	Unit CT2 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/09/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/09/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/09/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/09/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/09/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/09/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/09/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/09/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/09/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/09/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/09/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/09/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/09/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/09/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/09/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/09/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/09/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/09/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/09/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/09/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/09/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/09/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/09/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/09/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:13 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm	Unit CT2 O2Dry, Inlet, Pct	Unit CT2 NOx, Inlet, Ppmvdc	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 HI, MBtuPerHr	Unit CT2 NH3, Slip, Ppmvdc	Unit CT2 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/10/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/10/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/10/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/10/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/10/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/10/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/10/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/10/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/10/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/10/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/10/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/10/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/10/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/10/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/10/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/10/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/10/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/10/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/10/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/10/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/10/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/10/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/10/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/10/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm	Unit CT2 O2Dry, Inlet, Pct	Unit CT2 NOx, Inlet, Ppmvdc	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 HI, MBtuPerHr	Unit CT2 NH3, Slip, Ppmvdc	Unit CT2 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/11/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/11/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/11/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/11/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/11/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/11/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/11/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/11/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/11/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/11/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/11/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/11/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/11/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/11/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/11/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/11/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/11/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/11/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/11/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/11/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/11/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/11/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/11/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/11/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:13 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm	Unit CT2 O2Dry, Inlet, Pct	Unit CT2 NOx, Inlet, Ppmvdc	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 HI, MBtuPerHr	Unit CT2 NH3, Slip, Ppmvdc	Unit CT2 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/12/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/12/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/12/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/12/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/12/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/12/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/12/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/12/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/12/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/12/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/12/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/12/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/12/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/12/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/12/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/12/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/12/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/12/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/12/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/12/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/12/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/12/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/12/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/12/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:13 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm	Unit CT2 O2Dry, Inlet, Pct	Unit CT2 NOx, Inlet, Ppmvdc	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 HI, MBtuPerHr	Unit CT2 NH3, Slip, Ppmvdc	Unit CT2 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/13/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/13/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/13/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/13/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/13/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/13/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/13/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/13/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/13/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/13/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/13/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/13/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/13/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/13/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/13/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/13/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/13/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/13/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/13/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/13/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/13/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/13/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/13/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/13/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:13 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm	Unit CT2 O2Dry, Inlet, Pct	Unit CT2 NOx, Inlet, Ppmvdc	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 HI, MBtuPerHr	Unit CT2 NH3, Slip, Ppmvdc	Unit CT2 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/14/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/14/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/14/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/14/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/14/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/14/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/14/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/14/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/14/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/14/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/14/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/14/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/14/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/14/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/14/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/14/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/14/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/14/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/14/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/14/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/14/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/14/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/14/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/14/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm	Unit CT2 O2Dry, Inlet, Pct	Unit CT2 NOx, Inlet, Ppmvdc	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 HI, MBtuPerHr	Unit CT2 NH3, Slip, Ppmvdc	Unit CT2 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/15/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/15/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/15/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/15/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/15/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/15/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/15/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/15/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/15/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/15/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/15/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/15/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/15/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/15/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/15/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/15/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/15/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/15/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/15/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/15/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/15/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/15/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/15/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/15/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:13 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm	Unit CT2 O2Dry, Inlet, Pct	Unit CT2 NOx, Inlet, Ppmvdc	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 HI, MBtuPerHr	Unit CT2 NH3, Slip, Ppmvdc	Unit CT2 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/16/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/16/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/16/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/16/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/16/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/16/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/16/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/16/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/16/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/16/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/16/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/16/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/16/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/16/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/16/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/16/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/16/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/16/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/16/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/16/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/16/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/16/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/16/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/16/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:13 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm	Unit CT2 O2Dry, Inlet, Pct	Unit CT2 NOx, Inlet, Ppmvdc	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 HI, MBtuPerHr	Unit CT2 NH3, Slip, Ppmvdc	Unit CT2 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/17/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/17/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/17/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/17/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/17/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/17/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/17/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/17/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/17/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/17/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/17/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/17/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/17/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/17/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/17/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/17/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/17/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/17/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/17/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/17/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/17/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/17/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/17/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/17/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm	Unit CT2 O2Dry, Inlet, Pct	Unit CT2 NOx, Inlet, Ppmvdc	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 HI, MBtuPerHr	Unit CT2 NH3, Slip, Ppmvdc	Unit CT2 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/18/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/18/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/18/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/18/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/18/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/18/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/18/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/18/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/18/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/18/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/18/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/18/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/18/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/18/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/18/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/18/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/18/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/18/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/18/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/18/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/18/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/18/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/18/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/18/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:13 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm	Unit CT2 O2Dry, Inlet, Pct	Unit CT2 NOx, Inlet, Ppmvdc	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 HI, MBtuPerHr	Unit CT2 NH3, Slip, Ppmvdc	Unit CT2 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/19/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/19/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/19/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/19/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/19/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/19/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/19/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/19/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/19/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/19/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/19/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/19/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/19/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/19/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/19/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/19/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/19/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/19/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/19/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/19/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/19/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/19/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/19/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/19/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:13 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm	Unit CT2 O2Dry, Inlet, Pct	Unit CT2 NOx, Inlet, Ppmvdc	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 HI, MBtuPerHr	Unit CT2 NH3, Slip, Ppmvdc	Unit CT2 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/20/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/20/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/20/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/20/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/20/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/20/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/20/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/20/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/20/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/20/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/20/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/20/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/20/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/20/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/20/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/20/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/20/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/20/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/20/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/20/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/20/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/20/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/20/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/20/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:13 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm	Unit CT2 O2Dry, Inlet, Pct	Unit CT2 NOx, Inlet, Ppmvdc	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 HI, MBtuPerHr	Unit CT2 NH3, Slip, Ppmvdc	Unit CT2 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/21/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/21/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/21/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/21/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/21/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/21/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/21/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/21/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/21/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/21/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/21/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/21/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/21/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/21/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/21/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/21/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/21/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/21/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/21/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/21/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/21/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/21/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/21/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/21/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:13 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm	Unit CT2 O2Dry, Inlet, Pct	Unit CT2 NOx, Inlet, Ppmvdc	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 HI, MBtuPerHr	Unit CT2 NH3, Slip, Ppmvdc	Unit CT2 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/22/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/22/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/22/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/22/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/22/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/22/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/22/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/22/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/22/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/22/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/22/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/22/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/22/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/22/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/22/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/22/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/22/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/22/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/22/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/22/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/22/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/22/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/22/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/22/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:13 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm	Unit CT2 O2Dry, Inlet, Pct	Unit CT2 NOx, Inlet, Ppmvdc	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 HI, MBtuPerHr	Unit CT2 NH3, Slip, Ppmvdc	Unit CT2 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/23/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm	Unit CT2 O2Dry, Inlet, Pct	Unit CT2 NOx, Inlet, Ppmvdc	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 HI, MBtuPerHr	Unit CT2 NH3, Slip, Ppmvdc	Unit CT2 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/24/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:13 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm	Unit CT2 O2Dry, Inlet, Pct	Unit CT2 NOx, Inlet, Ppmvdc	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 HI, MBtuPerHr	Unit CT2 NH3, Slip, Ppmvdc	Unit CT2 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/25/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:13 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm	Unit CT2 O2Dry, Inlet, Pct	Unit CT2 NOx, Inlet, Ppmvdc	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 HI, MBtuPerHr	Unit CT2 NH3, Slip, Ppmvdc	Unit CT2 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/26/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm	Unit CT2 O2Dry, Inlet, Pct	Unit CT2 NOx, Inlet, Ppmvdc	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 HI, MBtuPerHr	Unit CT2 NH3, Slip, Ppmvdc	Unit CT2 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/27/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm	Unit CT2 O2Dry, Inlet, Pct	Unit CT2 NOx, Inlet, Ppmvdc	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 HI, MBtuPerHr	Unit CT2 NH3, Slip, Ppmvdc	Unit CT2 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/28/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/28/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/28/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/28/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/28/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/28/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/28/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/28/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/28/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/28/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/28/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/28/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/28/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/28/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/28/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/28/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/28/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/28/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/28/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/28/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/28/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/28/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/28/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/28/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm	Unit CT2 O2Dry, Inlet, Pct	Unit CT2 NOx, Inlet, Ppmvdc	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 HI, MBtuPerHr	Unit CT2 NH3, Slip, Ppmvdc	Unit CT2 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/29/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/29/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/29/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/29/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/29/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/29/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/29/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/29/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/29/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/29/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/29/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/29/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/29/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/29/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/29/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/29/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/29/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/29/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/29/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/29/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/29/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/29/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/29/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/29/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:13 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm	Unit CT2 O2Dry, Inlet, Pct	Unit CT2 NOx, Inlet, Ppmvdc	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 HI, MBtuPerHr	Unit CT2 NH3, Slip, Ppmvdc	Unit CT2 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/30/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/30/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/30/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/30/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/30/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/30/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/30/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/30/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/30/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/30/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/30/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/30/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/30/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/30/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/30/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/30/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/30/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/30/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/30/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/30/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/30/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/30/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/30/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/30/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm	Unit CT2 O2Dry, Inlet, Pct	Unit CT2 NOx, Inlet, Ppmvdc	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 HI, MBtuPerHr	Unit CT2 NH3, Slip, Ppmvdc	Unit CT2 NH3slip, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/31/2022 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2022 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2022 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2022 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2022 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2022 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2022 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2022 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2022 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2022 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2022 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2022 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2022 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2022 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2022 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2022 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2022 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2022 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2022 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2022 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2022 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2022 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2022 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2022 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Excess Emission Report



CT1 - NH3 LbPerHr 1-Hour Block Average

From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:13 Location: Maxwell, CA

Tag Name: CT1_NH3slip_LbPerHr_1H
Total Operating Time: 960.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 1,200.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	960.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report



CT1 - NH3 Ppmvdc 1-Hour Block Average

From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:14 Location: Maxwell, CA

Tag Name: CT1_NH3Slip_Ppmvdc_1H
Total Operating Time: 960.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 1,200.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	960.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report



CT2 - NH3 LbPerHr 1-Hour Block Average

From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:20 Location: Maxwell, CA

Tag Name: CT2_NH3slip_LbPerHr_1H
Total Operating Time: 848.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 1,312.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	848.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report



CT2 - NH3 Ppmvdc 1-Hour Block Average

From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:21 Location: Maxwell, CA

Tag Name: CT2_NH3Slip_Ppmvdc_1H
Total Operating Time: 848.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 1,312.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	848.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

ATTACHMENT 9
Quarterly/Annual Emissions
(Fuel Use, Hours of Operation and NH3 Injection)

FCD: AQ-23, 26
Title V: #6, 13

Emissions Limits Per AQ-26

Quarterly and Annual Combustion Emissions from CGS Facility					
Pollutant	1 st Quarter Emissions (tons)	2 nd Quarter Emissions (tons)	3 rd Quarter Emissions (tons)	4 th Quarter Emissions (tons)	Annual Emissions (tons)
NO _x	45.56	43.58	51.30	44.27	184.7
CO	54.29	52.49	107.15	53.95	267.9
VOC's	12.30	11.63	11.84	11.76	47.5
PM10	25.54	25.78	26.02	26.02	103.4
SO ₂	4.07	3.85	3.89	3.89	15.7

Notes

1. Emissions are based on CT1 and CT2.
2. VOC Mass Emissions are based on Average Souce Test Results for lbs/MMBtu.
CT1 EF = .0009 Prior to 10/30/2013 and .0007 After 10/30/2013. CT2 EF =
.0007 Prior to 11/01/2014 and .0003 after 11/01/2014.
3. PM10 is based on 2010 lb/MMBtu Source Test Results. CT1 EF = .0025; CT2
EF = .003

Quarterly Emissions

Monthly Summary by Day (Pounds)

Quarterly Plant Rollup (Tons)

Annual Fuel Use, NH₃ Injection and Operating Hours

Cumulative Emissions Report



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:22 **Location:** Maxwell, CA

Month	Plantwide NOx, Tons 1 Day(s)	Plantwide CO, Tons 1 Day(s)	Plantwide VOC, Tons 1 Day(s)	Plantwide PM10, Tons 1 Day(s)	Plantwide SO2, Tons 1 Day(s)
January	4.0	2.5	0.5	2.7	0.0
February	2.6	2.0	0.3	1.4	0.0
March	0.0	0.0	0.0	0.0	0.0
Quarter 1	6.6	4.5	0.8	4.1	0.0
YTD	6.6	4.5	0.8	4.1	0.0

Cumulative Emissions Report

CT1



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:22 **Location:** Maxwelll, CA

Month	Unit CT1 GasFlowCT, 100scf 1 Day(s)	Unit CT1 GasFlowDB, 100scf 1 Day(s)	Unit CT1 GasFlow, Total, 100scf 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)
January	9,648,604	414,181	10,062,783.0	618	151.4
February	5,158,897	352,367	5,511,263.1	342	164.7
March	0	0	0.0	0	0.0
Quarter 1	14,807,501	766,548	15,574,046.1	960	158.1
YTD	14,807,501	766,548	15,574,046.1	960	158.1

Cumulative Emissions Report

CT2



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:23 Location: Maxwell, CA

Month	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlowCT, 100scf	GasFlowDB, 100scf	GasFlow, Total, 100scf	UnitOn, TF	NH3, Inj, LbPerHr
	1 Day(s)	1 Day(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
January	8,823,028	399,749	9,222,775.5	568	58,712.9
February	4,322,812	308,326	4,631,136.4	280	31,470.0
March	0	0	0.0	0	0.0
Quarter 1	13,145,840	708,075	13,853,911.9	848	90,182.9
YTD	13,145,840	708,075	13,853,911.9	848	90,182.9

Monthly Summary By Day Report

VOC PM10



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:25 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 VOC, Lb 1 Day(s)	Unit CT1 PM10, Lb 1 Day(s)	Unit CT2 VOC, Lb 1 Day(s)	Unit CT2 PM10, Lb 1 Day(s)
01/01/2022	29.2	103.5	8.6	87.0
01/02/2022	29.3	103.4	8.5	86.8
01/03/2022	32.7	116.5	13.8	136.5
01/04/2022	31.6	112.9	13.2	132.3
01/05/2022	31.1	111.7	12.9	131.0
01/06/2022	28.8	103.6	12.2	122.0
01/07/2022	26.7	94.5	11.4	111.3
01/08/2022	14.4	51.2	4.2	42.7
01/09/2022	30.4	107.8	13.0	126.9
01/10/2022	30.7	108.7	10.4	103.9
01/11/2022	28.2	100.4	12.0	117.9
01/12/2022	29.0	102.4	7.3	72.5
01/13/2022	29.3	104.0	12.6	122.4
01/14/2022	20.1	71.6	4.7	45.6
01/15/2022	20.7	73.1	4.5	44.5
01/16/2022	13.3	47.6	3.7	37.0
01/17/2022	30.2	108.0	12.7	126.6
01/18/2022	29.2	104.4	12.5	122.5
01/19/2022	29.5	104.4	12.3	122.2
01/20/2022	27.2	97.1	7.9	79.8
01/21/2022	0.0	0.0	0.0	0.0
01/22/2022	0.0	0.0	0.0	0.0
01/23/2022	12.6	44.9	3.3	33.3
01/24/2022	23.5	83.3	4.8	47.4
01/25/2022	20.8	73.7	10.5	103.2
01/26/2022	21.1	75.1	10.5	104.9
01/27/2022	22.8	80.9	12.3	120.8
01/28/2022	30.2	107.7	12.6	126.2
01/29/2022	29.4	105.1	12.5	123.0
01/30/2022	9.2	33.4	8.4	83.3
01/31/2022	24.5	87.9	12.0	117.7
Monthly Avg/Sum*:	735.7 *	2,618.8 *	285.3 *	2,831.2 *
Daily Min:	0.0	0.0	0.0	0.0
Daily Max:	32.7	116.5	13.8	136.5
Jan 2022 - Jan 2022	735.7	2,618.8	285.3	2,831.2
QTD:	735.7 *	2,618.8 *	285.3 *	2,831.2 *
YTD 2022:	735.7 *	2,618.8 *	285.3 *	2,831.2 *

Monthly Summary By Day Report

VOC PM10



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:25 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 VOC, Lb 1 Day(s)	Unit CT1 PM10, Lb 1 Day(s)	Unit CT2 VOC, Lb 1 Day(s)	Unit CT2 PM10, Lb 1 Day(s)
02/01/2022	22.0	78.7	10.2	100.5
02/02/2022	24.6	88.6	13.0	129.8
02/03/2022	32.1	114.2	13.2	133.6
02/04/2022	20.3	73.0	10.7	104.3
02/05/2022	21.6	77.7	7.4	72.8
02/06/2022	19.6	69.0	4.2	40.5
02/07/2022	12.2	43.2	3.2	31.8
02/08/2022	24.5	86.5	8.3	84.6
02/09/2022	29.6	105.2	4.0	40.2
02/10/2022	24.8	88.7	8.6	84.8
02/11/2022	1.0	3.5	0.4	3.9
02/12/2022	0.0	0.0	0.0	0.0
02/13/2022	0.0	0.0	0.0	0.0
02/14/2022	0.0	0.0	0.0	0.0
02/15/2022	0.0	0.0	0.0	0.0
02/16/2022	0.0	0.0	0.0	0.0
02/17/2022	0.0	0.0	0.0	0.0
02/18/2022	14.8	52.7	4.2	39.8
02/19/2022	0.4	1.5	0.2	1.7
02/20/2022	0.0	0.0	0.0	0.0
02/21/2022	0.1	0.6	0.0	0.0
02/22/2022	28.3	101.3	9.9	98.7
02/23/2022	32.8	116.8	13.5	135.0
02/24/2022	34.4	122.9	14.4	140.8
02/25/2022	32.5	115.8	13.6	134.1
02/26/2022	20.0	71.0	4.4	43.7
02/27/2022	0.0	0.0	0.0	0.0
02/28/2022	9.3	32.8	0.0	0.0
Monthly Avg/Sum*:	404.9 *	1,443.7 *	143.4 *	1,420.6 *
Daily Min:	0.0	0.0	0.0	0.0
Daily Max:	34.4	122.9	14.4	140.8
Jan 2022 - Feb 2022	1,140.6	4,062.5	428.7	4,251.8
QTD:	1,140.6 *	4,062.5 *	428.7 *	4,251.8 *
YTD 2022:	1,140.6 *	4,062.5 *	428.7 *	4,251.8 *

Monthly Summary By Day Report

VOC PM10



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:25 Location: Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 VOC, Lb 1 Day(s)	Unit CT1 PM10, Lb 1 Day(s)	Unit CT2 VOC, Lb 1 Day(s)	Unit CT2 PM10, Lb 1 Day(s)
03/01/2022	0.0	0.0	0.0	0.0
03/02/2022	0.0	0.0	0.0	0.0
03/03/2022	0.0	0.0	0.0	0.0
03/04/2022	0.0	0.0	0.0	0.0
03/05/2022	0.0	0.0	0.0	0.0
03/06/2022	0.0	0.0	0.0	0.0
03/07/2022	0.0	0.0	0.0	0.0
03/08/2022	0.0	0.0	0.0	0.0
03/09/2022	0.0	0.0	0.0	0.0
03/10/2022	0.0	0.0	0.0	0.0
03/11/2022	0.0	0.0	0.0	0.0
03/12/2022	0.0	0.0	0.0	0.0
03/13/2022	0.0	0.0	0.0	0.0
03/14/2022	0.0	0.0	0.0	0.0
03/15/2022	0.0	0.0	0.0	0.0
03/16/2022	0.0	0.0	0.0	0.0
03/17/2022	0.0	0.0	0.0	0.0
03/18/2022	0.0	0.0	0.0	0.0
03/19/2022	0.0	0.0	0.0	0.0
03/20/2022	0.0	0.0	0.0	0.0
03/21/2022	0.0	0.0	0.0	0.0
03/22/2022	0.0	0.0	0.0	0.0
03/23/2022	0.0	0.0	0.0	0.0
03/24/2022	0.0	0.0	0.0	0.0
03/25/2022	0.0	0.0	0.0	0.0
03/26/2022	0.0	0.0	0.0	0.0
03/27/2022	0.0	0.0	0.0	0.0
03/28/2022	0.0	0.0	0.0	0.0
03/29/2022	0.0	0.0	0.0	0.0
03/30/2022	0.0	0.0	0.0	0.0
03/31/2022	0.0	0.0	0.0	0.0
Monthly Avg/Sum*:	0.0 *	0.0 *	0.0 *	0.0 *
Daily Min:	0.0	0.0	0.0	0.0
Daily Max:	0.0	0.0	0.0	0.0
Jan 2022 - Mar 2022	1,140.6	4,062.5	428.7	4,251.8
QTD:	1,140.6 *	4,062.5 *	428.7 *	4,251.8 *
YTD 2022:	1,140.6 *	4,062.5 *	428.7 *	4,251.8 *

Monthly Summary By Day Report

CT1 and CT2 - Pounds



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:26 Location: Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)
01/01/2022	63.6	131.30	24.7	100.9	164.60	17.4
01/02/2022	68.6	135.30	24.7	107.1	155.67	17.3
01/03/2022	82.8	148.00	28.1	45.0	161.50	27.3
01/04/2022	76.4	141.00	27.1	42.6	155.80	26.6
01/05/2022	75.6	138.30	26.7	39.9	147.30	26.1
01/06/2022	68.9	128.10	24.9	37.6	122.80	24.6
01/07/2022	72.2	121.25	22.7	47.2	110.95	22.4
01/08/2022	162.6	139.80	12.1	122.9	134.16	8.7
01/09/2022	70.3	139.60	26.0	42.9	130.60	25.7
01/10/2022	66.6	140.50	26.2	132.2	179.31	20.8
01/11/2022	62.9	126.20	24.2	39.5	112.20	23.8
01/12/2022	65.4	126.40	24.5	111.1	151.57	14.6
01/13/2022	76.9	133.93	25.0	49.6	138.62	24.5
01/14/2022	142.8	122.39	17.2	89.8	130.00	9.0
01/15/2022	154.6	124.48	17.4	102.7	139.07	8.9
01/16/2022	160.7	132.50	11.3	91.9	112.14	7.5
01/17/2022	68.0	142.70	26.1	41.4	139.70	25.3
01/18/2022	64.4	122.20	25.2	34.3	119.60	24.5
01/19/2022	70.8	135.60	25.2	31.7	113.40	24.4
01/20/2022	68.2	126.45	22.8	117.4	153.41	16.0
01/21/2022	0.0	0.00	0.0	0.0	0.00	0.0
01/22/2022	0.0	0.00	0.0	0.0	0.00	0.0
01/23/2022	197.5	196.76	10.8	130.9	163.81	6.6
01/24/2022	163.5	133.13	20.0	90.9	129.19	9.7
01/25/2022	128.9	144.96	17.7	80.2	140.95	20.5
01/26/2022	135.0	138.44	18.0	78.3	148.78	21.1
01/27/2022	130.4	141.56	19.4	33.8	124.10	24.2
01/28/2022	65.6	131.00	25.9	33.5	139.10	25.3
01/29/2022	64.5	128.30	25.3	36.7	128.30	24.5
01/30/2022	36.3	44.13	8.0	120.1	179.71	16.4
01/31/2022	212.8	202.68	21.3	43.5	122.64	23.4
Monthly Avg/Sum*:	2,876.8 *	3,916.96 *	628.5 *	2,075.6 *	4,048.98 *	567.1 *
Daily Min:	36.3	44.13	8.0	31.7	110.95	6.6
Daily Max:	212.8	202.68	28.1	132.2	179.71	27.3
Jan 2022 - Jan 2022	2,876.8	3,916.96	628.5	2,075.6	4,048.98	567.1
QTD:	2,876.8 *	3,916.96 *	628.5 *	2,075.6 *	4,048.98 *	567.1 *
YTD 2022:	2,876.8 *	3,916.96 *	628.5 *	2,075.6 *	4,048.98 *	567.1 *

Monthly Summary By Day Report

CT1 and CT2 - Pounds



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:26 Location: Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOX, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOX, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)
02/01/2022	190.1	160.79	18.8	79.4	137.35	20.3
02/02/2022	215.4	159.46	21.1	33.8	149.90	25.9
02/03/2022	68.0	147.70	27.4	39.4	161.10	26.7
02/04/2022	270.0	165.98	17.5	110.2	156.26	20.7
02/05/2022	145.8	145.69	18.7	81.7	154.35	14.4
02/06/2022	147.1	139.77	16.7	18.8	41.34	8.0
02/07/2022	219.8	137.86	10.5	121.2	134.14	6.2
02/08/2022	120.1	153.93	20.7	100.0	130.34	17.2
02/09/2022	56.1	133.50	24.9	71.2	122.50	8.1
02/10/2022	146.5	137.05	21.3	93.1	171.27	17.0
02/11/2022	7.3	4.99	0.8	3.9	4.05	0.8
02/12/2022	0.0	0.00	0.0	0.0	0.00	0.0
02/13/2022	0.0	0.00	0.0	0.0	0.00	0.0
02/14/2022	0.0	0.00	0.0	0.0	0.00	0.0
02/15/2022	0.0	0.00	0.0	0.0	0.00	0.0
02/16/2022	0.0	0.00	0.0	0.0	0.00	0.0
02/17/2022	0.0	0.00	0.0	0.0	0.00	0.0
02/18/2022	372.5	262.66	12.6	149.4	194.42	7.9
02/19/2022	13.8	4.22	0.4	9.6	6.38	0.3
02/20/2022	0.0	0.00	0.0	0.0	0.00	0.0
02/21/2022	68.3	49.77	0.1	0.0	0.00	0.0
02/22/2022	179.2	194.60	24.3	155.1	208.59	19.7
02/23/2022	77.4	140.40	27.8	38.8	157.50	27.1
02/24/2022	83.1	149.60	29.6	40.6	172.40	27.9
02/25/2022	76.7	138.80	27.9	42.4	165.90	26.9
02/26/2022	203.0	187.68	17.2	28.8	60.24	8.7
02/27/2022	0.0	0.00	0.0	0.0	0.00	0.0
02/28/2022	190.9	164.67	8.0	0.0	0.00	0.0
Monthly Avg/Sum*:	2,851.1 *	2,779.12 *	346.3 *	1,217.4 *	2,328.03 *	283.8 *
Daily Min:	7.3	4.22	0.1	3.9	4.05	0.3
Daily Max:	372.5	262.66	29.6	155.1	208.59	27.9
Jan 2022 - Feb 2022	5,727.9	6,696.08	974.8	3,293.0	6,377.01	850.9
QTD:	5,727.9 *	6,696.08 *	974.8 *	3,293.0 *	6,377.01 *	850.9 *
YTD 2022:	5,727.9 *	6,696.08 *	974.8 *	3,293.0 *	6,377.01 *	850.9 *

Monthly Summary By Day Report

CT1 and CT2 - Pounds



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:26 Location: Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)
03/01/2022	0.0	0.00	0.0	0.0	0.00	0.0
03/02/2022	0.0	0.00	0.0	0.0	0.00	0.0
03/03/2022	0.0	0.00	0.0	0.0	0.00	0.0
03/04/2022	0.0	0.00	0.0	0.0	0.00	0.0
03/05/2022	0.0	0.00	0.0	0.0	0.00	0.0
03/06/2022	0.0	0.00	0.0	0.0	0.00	0.0
03/07/2022	0.0	0.00	0.0	0.0	0.00	0.0
03/08/2022	0.0	0.00	0.0	0.0	0.00	0.0
03/09/2022	0.0	0.00	0.0	0.0	0.00	0.0
03/10/2022	0.0	0.00	0.0	0.0	0.00	0.0
03/11/2022	0.0	0.00	0.0	0.0	0.00	0.0
03/12/2022	0.0	0.00	0.0	0.0	0.00	0.0
03/13/2022	0.0	0.00	0.0	0.0	0.00	0.0
03/14/2022	0.0	0.00	0.0	0.0	0.00	0.0
03/15/2022	0.0	0.00	0.0	0.0	0.00	0.0
03/16/2022	0.0	0.00	0.0	0.0	0.00	0.0
03/17/2022	0.0	0.00	0.0	0.0	0.00	0.0
03/18/2022	0.0	0.00	0.0	0.0	0.00	0.0
03/19/2022	0.0	0.00	0.0	0.0	0.00	0.0
03/20/2022	0.0	0.00	0.0	0.0	0.00	0.0
03/21/2022	0.0	0.00	0.0	0.0	0.00	0.0
03/22/2022	0.0	0.00	0.0	0.0	0.00	0.0
03/23/2022	0.0	0.00	0.0	0.0	0.00	0.0
03/24/2022	0.0	0.00	0.0	0.0	0.00	0.0
03/25/2022	0.0	0.00	0.0	0.0	0.00	0.0
03/26/2022	0.0	0.00	0.0	0.0	0.00	0.0
03/27/2022	0.0	0.00	0.0	0.0	0.00	0.0
03/28/2022	0.0	0.00	0.0	0.0	0.00	0.0
03/29/2022	0.0	0.00	0.0	0.0	0.00	0.0
03/30/2022	0.0	0.00	0.0	0.0	0.00	0.0
03/31/2022	0.0	0.00	0.0	0.0	0.00	0.0
Monthly Avg/Sum*:	- *	- *	- *	- *	- *	- *
Daily Min:	-	-	-	-	-	-
Daily Max:	-	-	-	-	-	-
Jan 2022 - Mar 2022	5,727.9	6,696.08	974.8	3,293.0	6,377.01	850.9
QTD:	5,727.9 *	6,696.08 *	974.8 *	3,293.0 *	6,377.01 *	850.9 *
YTD 2022:	5,727.9 *	6,696.08 *	974.8 *	3,293.0 *	6,377.01 *	850.9 *

Monthly Summary By Day Report



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:30 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 OperatingTime, Hr	Unit CT1 GasFlowCT, 100scf	Unit CT1 DBOn, Hr	Unit CT1 GasFlowDB, 100scf	Unit CT1 GasFlow, Total, 100scf	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 HI, MBtu
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/01/2022	24.00	384,111.4	7.81	13,471.5	397,582.9	3,438.4	41,388.400
01/02/2022	24.00	381,950.5	8.86	15,382.2	397,332.7	3,554.6	41,362.300
01/03/2022	24.00	413,801.3	17.28	34,275.1	448,076.4	3,872.3	46,644.800
01/04/2022	24.00	404,337.0	15.04	28,932.0	433,269.0	3,793.2	45,103.300
01/05/2022	24.00	402,236.1	14.50	27,332.2	429,568.3	3,889.0	44,718.000
01/06/2022	24.00	384,606.5	9.01	13,498.3	398,104.8	3,537.4	41,442.600
01/07/2022	22.50	354,016.3	7.20	8,530.3	362,546.6	3,431.8	37,741.300
01/08/2022	13.50	191,109.1	3.11	5,926.1	197,035.2	2,083.2	20,511.400
01/09/2022	24.00	396,978.7	12.16	17,846.2	414,824.9	3,559.4	43,183.300
01/10/2022	24.00	391,760.4	11.64	25,786.1	417,546.5	3,680.2	43,466.600
01/11/2022	24.00	373,028.8	10.00	12,641.5	385,670.3	3,309.0	40,148.000
01/12/2022	24.00	378,825.1	9.27	15,058.7	393,883.8	3,531.3	41,003.100
01/13/2022	23.48	383,393.5	11.55	17,407.4	400,800.9	3,586.2	41,723.416
01/14/2022	18.78	272,376.9	2.56	3,076.9	275,453.9	2,980.9	28,674.842
01/15/2022	18.96	278,563.9	3.04	3,499.9	282,063.8	2,988.8	29,362.778
01/16/2022	13.00	179,892.3	1.75	2,763.2	182,655.5	1,957.0	19,014.300
01/17/2022	24.00	397,705.6	11.54	16,495.9	414,201.5	3,614.1	43,118.400
01/18/2022	24.00	384,322.5	11.25	16,438.9	400,761.4	3,458.8	41,719.000
01/19/2022	24.00	380,398.7	10.86	20,063.4	400,462.1	3,545.6	41,688.100
01/20/2022	23.82	363,462.4	6.77	9,269.8	372,732.2	3,430.4	38,801.514
01/21/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
01/22/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
01/23/2022	12.23	165,190.2	4.27	7,290.9	172,481.1	1,981.3	17,955.230
01/24/2022	20.18	308,134.6	6.82	12,235.9	320,370.5	3,345.4	33,350.500
01/25/2022	17.22	272,817.0	7.45	9,494.0	282,310.9	2,813.7	29,388.574
01/26/2022	17.20	278,157.5	7.35	10,521.2	288,678.7	2,880.7	30,051.452
01/27/2022	18.90	298,863.8	8.76	12,018.5	310,882.3	3,136.2	32,362.831
01/28/2022	24.00	391,712.5	11.07	22,186.2	413,898.7	3,656.6	43,086.800
01/29/2022	24.00	388,375.3	10.12	14,393.1	402,768.4	3,688.0	41,928.100
01/30/2022	7.77	124,817.4	2.91	3,478.5	128,295.9	1,218.4	13,355.628
01/31/2022	21.20	323,657.3	8.22	14,866.5	338,523.8	3,300.6	35,240.212
Monthly Avg/Sum*:	608.74 *	9,648,602.6 *	252.17 *	414,180.4 *	10,062,783.0 *	93,262.5 *	1,047,534.777 *
Daily Min:	7.77	124,817.4	1.75	2,763.2	128,295.9	1,218.4	13,355.628
Daily Max:	24.00	413,801.3	17.28	34,275.1	448,076.4	3,889.0	46,644.800
Jan 2022 - Jan 2022	608.74	9,648,602.6	252.17	414,180.4	10,062,783.0	93,262.5	1,047,534.777
QTD:	608.74 *	9,648,602.6 *	252.17 *	414,180.4 *	10,062,783.0 *	93,262.5 *	1,047,534.777 *
YTD 2022:	608.74 *	9,648,602.6 *	252.17 *	414,180.4 *	10,062,783.0 *	93,262.5 *	1,047,534.777 *

Monthly Summary By Day Report



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:30 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 OperatingTime, Hr	Unit CT1 GasFlowCT, 100scf	Unit CT1 DBOn, Hr	Unit CT1 GasFlowDB, 100scf	Unit CT1 GasFlow, Total, 100scf	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 HI, MBtu
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/01/2022	18.88	285,801.6	6.56	16,812.9	302,614.5	3,079.0	31,502.228
02/02/2022	18.65	307,739.1	13.75	32,041.8	339,780.9	3,563.8	35,371.236
02/03/2022	24.00	403,151.2	15.26	35,914.3	439,065.5	4,004.9	45,706.700
02/04/2022	16.48	263,051.3	10.10	17,599.6	280,651.0	2,775.2	29,215.784
02/05/2022	18.88	286,435.4	7.52	11,815.7	298,251.1	3,126.2	31,047.762
02/06/2022	16.81	254,822.3	7.80	10,253.6	265,075.9	3,106.9	27,594.479
02/07/2022	12.18	156,637.7	3.27	7,499.6	164,137.2	2,013.8	17,224.780
02/08/2022	20.70	324,163.2	4.28	5,238.6	329,401.8	3,199.0	34,619.980
02/09/2022	24.00	385,462.4	6.13	14,216.8	399,679.2	3,741.2	42,006.200
02/10/2022	20.40	313,959.6	9.70	23,337.1	337,296.7	3,712.2	35,450.201
02/11/2022	1.17	13,186.9	0.00	0.0	13,186.9	310.1	1,385.974
02/12/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
02/13/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
02/14/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
02/15/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
02/16/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
02/17/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
02/18/2022	15.17	196,164.3	3.08	4,538.6	200,702.9	2,481.7	21,093.773
02/19/2022	0.48	5,622.2	0.22	134.3	5,756.5	164.5	604.992
02/20/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
02/21/2022	0.70	2,162.4	0.00	0.0	2,162.4	0.1	227.290
02/22/2022	24.00	365,658.9	7.07	19,329.5	384,988.4	3,989.1	40,462.000
02/23/2022	24.00	408,598.3	13.71	36,404.0	445,002.3	4,151.0	46,769.600
02/24/2022	24.00	408,959.8	17.02	58,393.5	467,353.3	4,450.7	49,118.700
02/25/2022	24.00	410,436.8	16.02	29,570.0	440,006.8	3,982.8	46,244.700
02/26/2022	15.34	250,363.6	12.40	20,021.4	270,385.1	2,526.7	28,417.568
02/27/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
02/28/2022	9.01	116,521.4	4.75	9,243.3	125,764.7	1,776.1	13,217.945
Monthly Avg/Sum*:	328.85 *	5,158,898.4 *	158.64 *	352,364.6 *	5,511,263.1 *	56,155.0 *	577,281.892 *
Daily Min:	0.48	2,162.4	0.00	0.0	2,162.4	0.1	227.290
Daily Max:	24.00	410,436.8	17.02	58,393.5	467,353.3	4,450.7	49,118.700
Jan 2022 - Feb 2022	937.59	14,807,501.0	410.81	766,545.0	15,574,046.1	149,417.5	1,624,816.669
QTD:	937.59 *	14,807,501.0 *	410.81 *	766,545.0 *	15,574,046.1 *	149,417.5 *	1,624,816.669 *
YTD 2022:	937.59 *	14,807,501.0 *	410.81 *	766,545.0 *	15,574,046.1 *	149,417.5 *	1,624,816.669 *

Monthly Summary By Day Report



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:30 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 OperatingTime, Hr	Unit CT1 GasFlowCT, 100scf	Unit CT1 DBOn, Hr	Unit CT1 GasFlowDB, 100scf	Unit CT1 GasFlow, Total, 100scf	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 HI, MBtu
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/01/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
03/02/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
03/03/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
03/04/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
03/05/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
03/06/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
03/07/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
03/08/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
03/09/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
03/10/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
03/11/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
03/12/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
03/13/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
03/14/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
03/15/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
03/16/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
03/17/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
03/18/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
03/19/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
03/20/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
03/21/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
03/22/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
03/23/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
03/24/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
03/25/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
03/26/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
03/27/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
03/28/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
03/29/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
03/30/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
03/31/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
Monthly Avg/Sum*:	- *	- *	- *	- *	- *	- *	- *
Daily Min:	-	-	-	-	-	-	-
Daily Max:	-	-	-	-	-	-	-
Jan 2022 - Mar 2022	937.59	14,807,501.0	410.81	766,545.0	15,574,046.1	149,417.5	1,624,816.669
QTD:	937.59 *	14,807,501.0 *	410.81 *	766,545.0 *	15,574,046.1 *	149,417.5 *	1,624,816.669 *
YTD 2022:	937.59 *	14,807,501.0 *	410.81 *	766,545.0 *	15,574,046.1 *	149,417.5 *	1,624,816.669 *

Monthly Summary By Day Report



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:31 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT2 OperatingTime, Hr	Unit CT2 GasFlowCT, 100scf	Unit CT2 DBOn, Hr	Unit CT2 GasFlowDB, 100scf	Unit CT2 GasFlow, Total, 100scf	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 HI, MBtu
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/01/2022	16.72	271,010.8	7.81	13,116.3	284,127.1	1,907.8	29,066.158
01/02/2022	16.72	268,184.2	8.86	14,875.5	283,059.7	1,894.0	28,957.110
01/03/2022	24.00	412,550.4	17.21	32,419.9	444,970.3	2,607.2	45,520.300
01/04/2022	24.00	403,404.3	15.02	27,675.7	431,080.0	2,522.6	44,099.400
01/05/2022	24.00	400,213.1	14.50	25,690.8	425,903.9	2,498.1	43,570.000
01/06/2022	24.00	383,544.3	9.03	13,431.6	396,975.9	2,341.1	40,610.500
01/07/2022	22.50	353,474.6	7.21	8,630.0	362,104.7	2,239.9	37,043.450
01/08/2022	8.90	133,177.2	3.11	5,767.0	138,944.2	992.5	14,214.030
01/09/2022	24.00	395,438.4	12.16	17,707.5	413,145.9	2,384.2	42,264.900
01/10/2022	19.64	314,041.1	11.64	24,385.6	338,426.7	2,323.0	34,621.148
01/11/2022	24.00	371,694.9	10.02	12,684.9	384,379.8	2,242.3	39,321.800
01/12/2022	14.73	225,320.4	6.07	10,940.4	236,260.8	1,648.3	24,169.353
01/13/2022	23.48	381,738.9	11.55	17,237.2	398,976.2	2,420.0	40,815.196
01/14/2022	10.18	145,748.9	2.56	3,029.9	148,778.8	1,149.0	15,220.244
01/15/2022	9.63	141,105.5	3.04	3,454.6	144,560.2	1,120.5	14,788.510
01/16/2022	8.42	118,156.8	1.75	2,712.2	120,869.0	897.3	12,365.058
01/17/2022	24.00	395,648.6	11.57	16,205.8	411,854.4	2,422.4	42,132.600
01/18/2022	24.00	382,763.3	11.25	16,229.9	398,993.2	2,319.9	40,817.000
01/19/2022	24.00	378,981.1	10.88	19,008.1	397,989.2	2,433.3	40,714.400
01/20/2022	16.43	251,105.0	6.77	9,111.3	260,216.3	1,965.2	26,620.171
01/21/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
01/22/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
01/23/2022	6.95	101,344.7	4.27	7,114.1	108,458.8	848.6	11,095.250
01/24/2022	9.92	148,154.3	4.08	6,410.5	154,564.8	1,119.9	15,812.056
01/25/2022	20.97	327,423.8	7.45	9,396.1	336,819.9	2,458.9	34,456.833
01/26/2022	20.95	332,260.9	7.28	10,193.8	342,454.7	2,466.8	35,033.105
01/27/2022	24.00	381,195.4	8.81	12,037.4	393,232.8	2,366.3	40,227.700
01/28/2022	24.00	390,295.2	11.08	20,754.6	411,049.8	2,500.7	42,050.300
01/29/2022	24.00	386,350.8	10.10	13,953.0	400,303.8	2,391.9	40,950.700
01/30/2022	17.00	260,652.5	7.83	10,742.1	271,394.7	1,791.7	27,763.638
01/31/2022	23.48	368,049.2	8.33	14,830.6	382,879.9	2,439.5	39,168.612
Monthly Avg/Sum*:	554.62 *	8,823,028.6 *	251.24 *	399,746.4 *	9,222,775.5 *	58,712.9 *	943,489.522 *
Daily Min:	6.95	101,344.7	1.75	2,712.2	108,458.8	848.6	11,095.250
Daily Max:	24.00	412,550.4	17.21	32,419.9	444,970.3	2,607.2	45,520.300
Jan 2022 - Jan 2022	554.62	8,823,028.6	251.24	399,746.4	9,222,775.5	58,712.9	943,489.522
QTD:	554.62 *	8,823,028.6 *	251.24 *	399,746.4 *	9,222,775.5 *	58,712.9 *	943,489.522 *
YTD 2022:	554.62 *	8,823,028.6 *	251.24 *	399,746.4 *	9,222,775.5 *	58,712.9 *	943,489.522 *

Monthly Summary By Day Report



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:31 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT2 OperatingTime, Hr	Unit CT2 GasFlowCT, 100scf	Unit CT2 DBOn, Hr	Unit CT2 GasFlowDB, 100scf	Unit CT2 GasFlow, Total, 100scf	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 HI, MBtu
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/01/2022	20.92	311,353.9	6.58	15,966.1	327,320.0	2,358.8	33,485.148
02/02/2022	24.00	391,885.7	13.77	31,443.0	423,328.7	2,642.6	43,306.400
02/03/2022	24.00	400,579.7	15.25	34,988.7	435,568.4	2,728.7	44,558.600
02/04/2022	21.00	322,837.6	10.09	17,047.3	339,884.9	2,546.8	34,770.408
02/05/2022	14.93	225,645.0	7.52	11,638.2	237,283.2	1,752.7	24,274.178
02/06/2022	8.18	127,821.7	3.03	4,119.4	131,941.1	956.9	13,497.568
02/07/2022	7.18	96,671.9	3.27	7,257.1	103,929.0	917.7	10,631.956
02/08/2022	17.00	270,106.4	4.27	5,122.9	275,229.3	2,078.5	28,155.734
02/09/2022	7.87	122,776.6	4.25	8,222.8	130,999.4	856.1	13,401.239
02/10/2022	16.38	255,142.2	9.70	22,057.1	277,199.3	1,967.9	28,357.257
02/11/2022	1.13	12,776.9	0.00	0.0	12,776.9	270.6	1,307.046
02/12/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
02/13/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
02/14/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
02/15/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
02/16/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
02/17/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
02/18/2022	8.93	125,446.3	3.08	4,474.8	129,921.1	948.7	13,290.913
02/19/2022	0.48	5,536.6	0.22	133.7	5,670.3	128.7	580.080
02/20/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
02/21/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
02/22/2022	19.55	303,440.3	7.07	18,362.9	321,803.2	2,062.0	32,920.735
02/23/2022	24.00	405,784.4	13.71	34,545.8	440,330.2	2,724.8	45,045.700
02/24/2022	24.00	405,858.8	17.02	53,301.5	459,160.3	2,967.9	46,972.100
02/25/2022	24.00	408,127.3	16.02	28,214.9	436,342.2	2,634.4	44,637.800
02/26/2022	7.48	131,019.9	7.18	11,429.0	142,448.9	926.2	14,572.440
02/27/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
02/28/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
Monthly Avg/Sum*:	271.03 *	4,322,811.2 *	142.03 *	308,325.2 *	4,631,136.4 *	31,470.0 *	473,765.302 *
Daily Min:	0.48	5,536.6	0.00	0.0	5,670.3	128.7	580.080
Daily Max:	24.00	408,127.3	17.02	53,301.5	459,160.3	2,967.9	46,972.100
Jan 2022 - Feb 2022	825.65	13,145,839.8	393.27	708,071.6	13,853,911.9	90,182.9	1,417,254.824
QTD:	825.65 *	13,145,839.8 *	393.27 *	708,071.6 *	13,853,911.9 *	90,182.9 *	1,417,254.824 *
YTD 2022:	825.65 *	13,145,839.8 *	393.27 *	708,071.6 *	13,853,911.9 *	90,182.9 *	1,417,254.824 *

Monthly Summary By Day Report



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:31 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT2 OperatingTime, Hr	Unit CT2 GasFlowCT, 100scf	Unit CT2 DBOn, Hr	Unit CT2 GasFlowDB, 100scf	Unit CT2 GasFlow, Total, 100scf	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 HI, MBtu
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/01/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
03/02/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
03/03/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
03/04/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
03/05/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
03/06/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
03/07/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
03/08/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
03/09/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
03/10/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
03/11/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
03/12/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
03/13/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
03/14/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
03/15/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
03/16/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
03/17/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
03/18/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
03/19/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
03/20/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
03/21/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
03/22/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
03/23/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
03/24/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
03/25/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
03/26/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
03/27/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
03/28/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
03/29/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
03/30/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
03/31/2022	0.00	0.0	0.00	0.0	0.0	0.0	0.000
Monthly Avg/Sum*:	- *	- *	- *	- *	- *	- *	- *
Daily Min:	-	-	-	-	-	-	-
Daily Max:	-	-	-	-	-	-	-
Jan 2022 - Mar 2022	825.65	13,145,839.8	393.27	708,071.6	13,853,911.9	90,182.9	1,417,254.824
QTD:	825.65 *	13,145,839.8 *	393.27 *	708,071.6 *	13,853,911.9 *	90,182.9 *	1,417,254.824 *
YTD 2022:	825.65 *	13,145,839.8 *	393.27 *	708,071.6 *	13,853,911.9 *	90,182.9 *	1,417,254.824 *

ATTACHMENT 10

Maximum Emissions

FCD: AQ-25

AQ-25 Emission Limits

Maximum Emissions Both Turbines (lbs)		
Pollutant	1-Hour Emissions	24-Hour Emissions
NO _x	666.60	2,994.60
CO	967.00	7,659.00
VOC	55.40	630.60
PM10	27.00	648.00
SO ₂	14.80	355.20

Excess Emission Report



CT1 and CT2 SO2 Lb/Day

From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:44 Location: Maxwell, CA

Tag Name: ALL_SO2_Lb_1D
Total Operating Time: 49.00 Day(s) No Exclusions Allowed
Non-Operating Time: 41.00 Day(s) Report Time: 90.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	49.00 Day(s)
Total Duration (Online only):	0.00 Day(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Monthly Summary By Day Report

AQ-25



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:32 Location: Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:	Plantwide NOx, Lb 1 Day(s)	Plantwide CO, Lb 1 Day(s)	Plantwide VOC, Lb 1 Day(s)	Plantwide PM10, Lb 1 Day(s)	Plantwide SO2, Lb 1 Day(s)
01/01/2022	295.9	164.5	37.8	190.5	17.4
01/02/2022	291.0	175.7	37.8	190.2	17.3
01/03/2022	309.5	127.8	46.5	253.0	27.3
01/04/2022	296.8	119.0	44.8	245.2	26.6
01/05/2022	285.6	115.5	44.0	242.7	26.1
01/06/2022	250.9	106.5	41.0	225.6	24.6
01/07/2022	232.3	119.4	38.1	205.8	22.4
01/08/2022	274.0	285.5	18.6	93.9	8.7
01/09/2022	270.2	113.2	43.4	234.7	25.7
01/10/2022	319.8	198.8	41.1	212.6	20.8
01/11/2022	238.4	102.4	40.2	218.3	23.8
01/12/2022	278.0	176.5	36.3	174.9	14.6
01/13/2022	272.5	126.5	41.9	226.4	24.5
01/14/2022	252.4	232.6	24.8	117.2	9.0
01/15/2022	263.6	257.3	25.2	117.6	8.9
01/16/2022	244.6	252.6	17.0	84.6	7.5
01/17/2022	282.4	109.4	42.9	234.6	25.3
01/18/2022	241.8	98.7	41.7	226.9	24.5
01/19/2022	249.0	102.5	41.8	226.6	24.4
01/20/2022	279.9	185.6	35.1	176.9	16.0
01/21/2022	0.0	0.0	0.0	0.0	0.0
01/22/2022	0.0	0.0	0.0	0.0	0.0
01/23/2022	360.6	328.4	15.9	78.2	6.6
01/24/2022	262.3	254.4	28.3	130.7	9.7
01/25/2022	286.0	209.1	31.3	176.9	20.5
01/26/2022	287.2	213.3	31.6	180.0	21.1
01/27/2022	265.7	164.2	35.1	201.7	24.2
01/28/2022	270.1	99.1	42.8	233.9	25.3
01/29/2022	256.6	101.2	41.9	228.1	24.5
01/30/2022	223.8	156.4	17.6	116.7	16.4
01/31/2022	325.3	256.3	36.5	205.6	23.4
Monthly Avg/Sum*:	7,966.2 *	4,952.4 *	1,021.0 *	5,450.0 *	- *
Daily Min:	0.0	0.0	0.0	0.0	-
Daily Max:	360.6	328.4	46.5	253.0	-
Jan 2022 - Jan 2022	7,966.2	4,952.4	1,021.0	5,450.0	-
QTD:	7,966.2 *	4,952.4 *	1,021.0 *	5,450.0 *	0.0 *
YTD 2022:	7,966.2 *	4,952.4 *	1,021.0 *	5,450.0 *	0.0 *

Monthly Summary By Day Report

AQ-25



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:32 Location: Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:	Plantwide NOx, Lb 1 Day(s)	Plantwide CO, Lb 1 Day(s)	Plantwide VOC, Lb 1 Day(s)	Plantwide PM10, Lb 1 Day(s)	Plantwide SO2, Lb 1 Day(s)
02/01/2022	298.2	269.5	32.2	179.2	20.3
02/02/2022	309.4	249.2	37.6	218.4	25.9
02/03/2022	308.8	107.4	45.3	247.8	26.7
02/04/2022	322.3	380.2	31.0	177.3	20.7
02/05/2022	300.1	227.5	29.0	150.5	14.4
02/06/2022	181.1	165.9	23.8	109.5	8.0
02/07/2022	272.0	341.0	15.4	75.0	6.2
02/08/2022	284.2	220.1	32.8	171.1	17.2
02/09/2022	256.0	127.3	33.6	145.4	8.1
02/10/2022	308.4	239.6	33.4	173.5	17.0
02/11/2022	9.1	11.2	1.4	7.4	0.8
02/12/2022	0.0	0.0	0.0	0.0	0.0
02/13/2022	0.0	0.0	0.0	0.0	0.0
02/14/2022	0.0	0.0	0.0	0.0	0.0
02/15/2022	0.0	0.0	0.0	0.0	0.0
02/16/2022	0.0	0.0	0.0	0.0	0.0
02/17/2022	0.0	0.0	0.0	0.0	0.0
02/18/2022	457.1	521.9	19.0	92.5	7.9
02/19/2022	10.6	23.4	0.6	3.2	0.3
02/20/2022	0.0	0.0	0.0	0.0	0.0
02/21/2022	49.8	68.3	0.1	0.6	0.0
02/22/2022	403.2	334.3	38.2	200.0	19.7
02/23/2022	297.9	116.2	46.3	251.8	27.1
02/24/2022	322.0	123.7	48.8	263.7	27.9
02/25/2022	304.7	119.1	46.1	249.9	26.9
02/26/2022	247.9	231.8	24.4	114.7	8.7
02/27/2022	0.0	0.0	0.0	0.0	0.0
02/28/2022	164.7	190.9	9.3	32.8	0.0
Monthly Avg/Sum*:	5,107.5 *	4,068.5 *	548.3 *	2,864.3 *	- *
Daily Min:	0.0	0.0	0.0	0.0	-
Daily Max:	457.1	521.9	48.8	263.7	-
Jan 2022 - Feb 2022	13,073.7	9,020.9	1,569.3	8,314.3	-
QTD:	13,073.7 *	9,020.9 *	1,569.3 *	8,314.3 *	0.0 *
YTD 2022:	13,073.7 *	9,020.9 *	1,569.3 *	8,314.3 *	0.0 *

Monthly Summary By Day Report

AQ-25



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:32 Location: Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Plantwide NOx, Lb 1 Day(s)	Plantwide CO, Lb 1 Day(s)	Plantwide VOC, Lb 1 Day(s)	Plantwide PM10, Lb 1 Day(s)	Plantwide SO2, Lb 1 Day(s)
03/01/2022	0.0	0.0	0.0	0.0	0.0
03/02/2022	0.0	0.0	0.0	0.0	0.0
03/03/2022	0.0	0.0	0.0	0.0	0.0
03/04/2022	0.0	0.0	0.0	0.0	0.0
03/05/2022	0.0	0.0	0.0	0.0	0.0
03/06/2022	0.0	0.0	0.0	0.0	0.0
03/07/2022	0.0	0.0	0.0	0.0	0.0
03/08/2022	0.0	0.0	0.0	0.0	0.0
03/09/2022	0.0	0.0	0.0	0.0	0.0
03/10/2022	0.0	0.0	0.0	0.0	0.0
03/11/2022	0.0	0.0	0.0	0.0	0.0
03/12/2022	0.0	0.0	0.0	0.0	0.0
03/13/2022	0.0	0.0	0.0	0.0	0.0
03/14/2022	0.0	0.0	0.0	0.0	0.0
03/15/2022	0.0	0.0	0.0	0.0	0.0
03/16/2022	0.0	0.0	0.0	0.0	0.0
03/17/2022	0.0	0.0	0.0	0.0	0.0
03/18/2022	0.0	0.0	0.0	0.0	0.0
03/19/2022	0.0	0.0	0.0	0.0	0.0
03/20/2022	0.0	0.0	0.0	0.0	0.0
03/21/2022	0.0	0.0	0.0	0.0	0.0
03/22/2022	0.0	0.0	0.0	0.0	0.0
03/23/2022	0.0	0.0	0.0	0.0	0.0
03/24/2022	0.0	0.0	0.0	0.0	0.0
03/25/2022	0.0	0.0	0.0	0.0	0.0
03/26/2022	0.0	0.0	0.0	0.0	0.0
03/27/2022	0.0	0.0	0.0	0.0	0.0
03/28/2022	0.0	0.0	0.0	0.0	0.0
03/29/2022	0.0	0.0	0.0	0.0	0.0
03/30/2022	0.0	0.0	0.0	0.0	0.0
03/31/2022	0.0	0.0	0.0	0.0	0.0
Monthly Avg/Sum*:	0.0 *	0.0 *	0.0 *	0.0 *	- *
Daily Min:	0.0	0.0	0.0	0.0	-
Daily Max:	0.0	0.0	0.0	0.0	-
Jan 2022 - Mar 2022	13,073.7	9,020.9	1,569.3	8,314.3	-
QTD:	13,073.7 *	9,020.9 *	1,569.3 *	8,314.3 *	0.0 *
YTD 2022:	13,073.7 *	9,020.9 *	1,569.3 *	8,314.3 *	0.0 *

Daily Summary Report

AQ-25 Hourly



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
01/01/2022 00:00	11.6	6.0	2.0	10.6	2.3
01/01/2022 01:00	9.7	2.7	1.6	8.9	2.0
01/01/2022 02:00	7.8	3.2	1.6	8.5	1.8
01/01/2022 03:00	12.3	3.0	1.8	9.7	2.1
01/01/2022 04:00	13.1	4.7	1.9	10.2	2.2
01/01/2022 05:00	13.0	4.9	1.9	10.2	2.2
01/01/2022 06:00	10.9	3.4	1.8	10.0	2.2
01/01/2022 07:00	14.0	6.8	2.0	11.0	2.4
01/01/2022 08:00	11.8	3.9	1.7	9.3	2.0
01/01/2022 09:00	7.5	10.4	1.1	4.6	1.0
01/01/2022 10:00	4.2	2.1	1.0	3.5	0.8
01/01/2022 11:00	4.1	1.8	1.0	3.5	0.8
01/01/2022 12:00	4.2	1.8	1.0	3.5	0.8
01/01/2022 13:00	4.1	1.8	1.0	3.4	0.8
01/01/2022 14:00	4.1	1.8	1.0	3.4	0.8
01/01/2022 15:00	4.1	1.8	1.0	3.4	0.8
01/01/2022 16:00	16.1	8.0	1.1	4.2	1.0
01/01/2022 17:00	62.5	64.6	1.3	6.4	1.5
01/01/2022 18:00	10.7	2.7	1.8	9.8	2.2
01/01/2022 19:00	10.9	3.4	1.8	10.0	2.2
01/01/2022 20:00	14.7	6.8	2.1	11.5	2.5
01/01/2022 21:00	14.9	6.4	2.1	11.7	2.6
01/01/2022 22:00	14.9	6.4	2.1	11.7	2.6
01/01/2022 23:00	14.7	6.1	2.1	11.5	2.5
Average/Sum#:	295.9 #	164.5 #	37.8 #	190.5 #	42.1 #
Minimum:	4.1	1.8	1.0	3.4	0.8
Maximum:	62.5	64.6	2.1	11.7	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
01/02/2022 00:00	13.6	6.7	2.0	10.8	2.4
01/02/2022 01:00	7.7	2.9	1.6	8.5	1.8
01/02/2022 02:00	7.1	3.2	1.4	7.8	1.7
01/02/2022 03:00	10.4	2.9	1.7	9.5	2.1
01/02/2022 04:00	13.0	6.7	1.8	10.2	2.2
01/02/2022 05:00	11.2	5.7	1.9	10.2	2.2
01/02/2022 06:00	12.6	3.0	1.8	9.9	2.2
01/02/2022 07:00	16.0	5.8	2.0	11.0	2.4
01/02/2022 08:00	10.1	3.9	1.7	9.3	2.0
01/02/2022 09:00	7.7	10.9	1.1	4.7	1.1
01/02/2022 10:00	4.2	2.4	1.0	3.5	0.8
01/02/2022 11:00	4.1	2.1	1.0	3.4	0.8
01/02/2022 12:00	4.1	2.1	1.0	3.4	0.8
01/02/2022 13:00	4.1	2.1	1.0	3.4	0.8
01/02/2022 14:00	4.1	2.1	1.0	3.4	0.8
01/02/2022 15:00	4.1	2.1	1.0	3.4	0.8
01/02/2022 16:00	15.1	8.0	1.2	4.4	1.0
01/02/2022 17:00	54.6	66.8	1.3	6.5	1.5
01/02/2022 18:00	12.5	3.6	1.8	9.8	2.2
01/02/2022 19:00	14.3	7.7	2.1	11.3	2.4
01/02/2022 20:00	15.3	6.3	2.2	11.9	2.6
01/02/2022 21:00	14.6	6.0	2.1	11.5	2.5
01/02/2022 22:00	14.5	6.0	2.1	11.5	2.5
01/02/2022 23:00	16.0	6.7	2.0	10.9	2.4
Average/Sum#:	291.0 #	175.7 #	37.8 #	190.2 #	42.0 #
Minimum:	4.1	2.1	1.0	3.4	0.8
Maximum:	54.6	66.8	2.2	11.9	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
01/03/2022 00:00	11.5	7.0	2.0	10.6	2.3
01/03/2022 01:00	9.9	3.1	1.7	9.1	2.0
01/03/2022 02:00	10.0	3.4	1.7	9.1	2.0
01/03/2022 03:00	16.0	5.8	2.0	10.9	2.4
01/03/2022 04:00	13.9	5.8	2.0	10.9	2.4
01/03/2022 05:00	14.4	5.7	2.1	11.3	2.5
01/03/2022 06:00	15.5	5.4	2.3	12.2	2.7
01/03/2022 07:00	14.5	5.7	2.1	11.5	2.5
01/03/2022 08:00	16.0	6.4	2.0	10.9	2.4
01/03/2022 09:00	11.7	7.0	2.0	10.7	2.4
01/03/2022 10:00	11.9	3.2	1.7	9.3	2.0
01/03/2022 11:00	7.1	3.5	1.4	7.8	1.7
01/03/2022 12:00	10.5	3.3	1.7	9.6	2.1
01/03/2022 13:00	11.1	5.5	1.9	10.2	2.2
01/03/2022 14:00	11.2	6.1	1.9	10.2	2.2
01/03/2022 15:00	9.9	3.0	1.7	9.0	2.0
01/03/2022 16:00	11.3	6.2	1.9	10.4	2.2
01/03/2022 17:00	16.8	6.2	2.1	11.5	2.5
01/03/2022 18:00	14.9	6.2	2.1	11.7	2.6
01/03/2022 19:00	15.1	5.5	2.1	11.9	2.6
01/03/2022 20:00	14.4	5.8	2.1	11.3	2.5
01/03/2022 21:00	14.2	5.9	2.0	11.1	2.4
01/03/2022 22:00	13.6	6.5	2.0	10.7	2.4
01/03/2022 23:00	14.1	5.6	2.0	11.1	2.4
Average/Sum#:	309.5 #	127.8 #	46.5 #	253.0 #	55.4 #
Minimum:	7.1	3.0	1.4	7.8	1.7
Maximum:	16.8	7.0	2.3	12.2	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
01/04/2022 00:00	14.0	5.8	2.0	11.0	2.4
01/04/2022 01:00	9.3	2.6	1.6	8.5	1.8
01/04/2022 02:00	10.0	3.0	1.7	9.2	2.0
01/04/2022 03:00	11.5	6.2	2.0	10.5	2.3
01/04/2022 04:00	13.6	5.9	2.0	10.6	2.3
01/04/2022 05:00	9.9	2.5	1.7	9.1	2.0
01/04/2022 06:00	10.7	2.9	1.8	9.8	2.2
01/04/2022 07:00	15.8	6.3	2.0	10.9	2.4
01/04/2022 08:00	14.0	5.6	2.0	11.0	2.4
01/04/2022 09:00	13.5	6.6	2.0	10.6	2.3
01/04/2022 10:00	7.3	3.2	1.4	7.9	1.8
01/04/2022 11:00	6.6	3.3	1.3	7.4	1.6
01/04/2022 12:00	12.0	3.2	1.7	9.4	2.0
01/04/2022 13:00	12.7	4.6	1.8	10.0	2.2
01/04/2022 14:00	10.9	6.0	1.8	10.0	2.2
01/04/2022 15:00	9.5	3.0	1.6	8.7	1.9
01/04/2022 16:00	13.9	6.9	2.0	10.9	2.4
01/04/2022 17:00	14.9	6.3	2.1	11.7	2.6
01/04/2022 18:00	14.9	5.8	2.1	11.7	2.6
01/04/2022 19:00	14.9	5.9	2.1	11.7	2.6
01/04/2022 20:00	14.5	5.9	2.1	11.3	2.5
01/04/2022 21:00	14.3	5.6	2.0	11.2	2.4
01/04/2022 22:00	14.0	6.3	2.0	11.0	2.4
01/04/2022 23:00	14.1	5.6	2.0	11.1	2.4
Average/Sum#:	296.8 #	119.0 #	44.8 #	245.2 #	53.7 #
Minimum:	6.6	2.5	1.3	7.4	1.6
Maximum:	15.8	6.9	2.1	11.7	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
01/05/2022 00:00	10.9	5.7	1.8	10.0	2.2
01/05/2022 01:00	6.5	3.4	1.3	7.2	1.6
01/05/2022 02:00	6.6	3.5	1.3	7.4	1.6
01/05/2022 03:00	10.5	3.2	1.7	9.6	2.1
01/05/2022 04:00	11.1	5.9	1.8	10.2	2.2
01/05/2022 05:00	11.3	6.8	1.9	10.4	2.2
01/05/2022 06:00	10.1	3.4	1.7	9.2	2.0
01/05/2022 07:00	14.0	6.3	2.0	11.1	2.4
01/05/2022 08:00	16.0	6.4	2.0	11.0	2.4
01/05/2022 09:00	15.8	5.9	2.0	10.9	2.4
01/05/2022 10:00	7.4	3.0	1.4	8.1	1.8
01/05/2022 11:00	7.6	2.9	1.6	8.3	1.8
01/05/2022 12:00	10.3	2.8	1.7	9.5	2.0
01/05/2022 13:00	11.1	3.9	1.8	10.1	2.2
01/05/2022 14:00	11.1	4.2	1.8	10.1	2.2
01/05/2022 15:00	9.9	2.7	1.7	9.0	2.0
01/05/2022 16:00	14.0	6.0	2.0	11.1	2.4
01/05/2022 17:00	14.4	6.0	2.1	11.3	2.5
01/05/2022 18:00	14.8	6.0	2.1	11.6	2.5
01/05/2022 19:00	14.8	5.6	2.1	11.6	2.5
01/05/2022 20:00	14.8	5.2	2.1	11.6	2.5
01/05/2022 21:00	14.8	5.2	2.1	11.6	2.5
01/05/2022 22:00	13.6	6.0	2.0	10.7	2.4
01/05/2022 23:00	14.2	5.5	2.0	11.1	2.4
Average/Sum#:	285.6 #	115.5 #	44.0 #	242.7 #	52.8 #
Minimum:	6.5	2.7	1.3	7.2	1.6
Maximum:	16.0	6.8	2.1	11.6	2.5
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
01/06/2022 00:00	10.9	5.1	1.8	10.0	2.2
01/06/2022 01:00	6.6	2.7	1.3	7.2	1.6
01/06/2022 02:00	6.5	3.2	1.3	7.2	1.6
01/06/2022 03:00	7.8	3.1	1.6	8.5	1.8
01/06/2022 04:00	11.1	5.9	1.9	10.2	2.2
01/06/2022 05:00	11.1	6.1	1.8	10.2	2.2
01/06/2022 06:00	10.5	3.2	1.7	9.6	2.1
01/06/2022 07:00	16.0	6.7	2.0	10.9	2.4
01/06/2022 08:00	14.1	6.0	2.0	11.1	2.4
01/06/2022 09:00	13.6	6.3	2.0	10.7	2.4
01/06/2022 10:00	7.6	3.4	1.5	8.3	1.8
01/06/2022 11:00	7.8	3.3	1.6	8.7	1.8
01/06/2022 12:00	7.2	3.3	1.4	7.9	1.8
01/06/2022 13:00	6.6	3.5	1.3	7.2	1.6
01/06/2022 14:00	9.7	3.3	1.6	8.9	2.0
01/06/2022 15:00	7.1	3.3	1.4	7.9	1.8
01/06/2022 16:00	8.1	3.0	1.6	8.9	2.0
01/06/2022 17:00	10.3	3.2	1.7	9.5	2.0
01/06/2022 18:00	14.1	7.2	2.0	11.1	2.4
01/06/2022 19:00	14.5	6.1	2.1	11.3	2.5
01/06/2022 20:00	15.5	6.2	2.0	10.7	2.4
01/06/2022 21:00	9.9	3.0	1.7	9.1	2.0
01/06/2022 22:00	10.5	3.2	1.7	9.6	2.1
01/06/2022 23:00	13.8	6.2	2.0	10.9	2.4
Average/Sum#:	250.9 #	106.5 #	41.0 #	225.6 #	49.5 #
Minimum:	6.5	2.7	1.3	7.2	1.6
Maximum:	16.0	7.2	2.1	11.3	2.5
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
01/07/2022 00:00	10.9	5.7	1.8	10.0	2.2
01/07/2022 01:00	6.5	3.2	1.3	7.1	1.6
01/07/2022 02:00	9.7	3.3	1.6	8.9	2.0
01/07/2022 03:00	11.7	7.3	2.0	10.7	2.4
01/07/2022 04:00	13.4	7.1	2.0	10.5	2.3
01/07/2022 05:00	10.1	3.1	1.7	9.2	2.0
01/07/2022 06:00	9.5	3.3	1.6	8.7	1.9
01/07/2022 07:00	13.8	6.8	2.0	10.9	2.4
01/07/2022 08:00	15.5	7.1	2.0	10.7	2.4
01/07/2022 09:00	9.4	2.7	1.6	8.7	1.8
01/07/2022 10:00	7.6	2.8	1.6	8.4	1.8
01/07/2022 11:00	7.8	2.6	1.6	8.5	1.8
01/07/2022 12:00	7.7	2.6	1.6	8.5	1.8
01/07/2022 13:00	7.5	2.8	1.5	8.3	1.8
01/07/2022 14:00	7.4	2.8	1.4	8.1	1.8
01/07/2022 15:00	7.6	2.8	1.6	8.3	1.8
01/07/2022 16:00	7.6	2.8	1.6	8.4	1.8
01/07/2022 17:00	9.8	3.0	1.7	8.9	2.0
01/07/2022 18:00	11.1	6.5	1.8	10.2	2.2
01/07/2022 19:00	10.9	6.0	1.8	10.0	2.2
01/07/2022 20:00	9.5	3.2	1.6	8.7	1.9
01/07/2022 21:00	15.8	8.0	2.0	10.8	2.4
01/07/2022 22:00	11.4	23.9	0.7	3.3	0.8
01/07/2022 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	232.2 #	119.4 #	38.1 #	205.8 #	45.1 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	15.8	23.9	2.0	10.9	2.4
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
01/08/2022 00:00	0.0	0.0	0.0	0.0	0.0
01/08/2022 01:00	0.0	0.0	0.0	0.0	0.0
01/08/2022 02:00	0.0	0.0	0.0	0.0	0.0
01/08/2022 03:00	0.0	0.0	0.0	0.0	0.0
01/08/2022 04:00	0.0	0.0	0.0	0.0	0.0
01/08/2022 05:00	0.0	0.0	0.0	0.0	0.0
01/08/2022 06:00	0.0	0.0	0.0	0.0	0.0
01/08/2022 07:00	0.0	0.0	0.0	0.0	0.0
01/08/2022 08:00	0.0	0.0	0.0	0.0	0.0
01/08/2022 09:00	0.0	0.0	0.0	0.0	0.0
01/08/2022 10:00	29.9	40.4	0.1	0.4	0.1
01/08/2022 11:00	24.5	29.9	0.3	1.0	0.2
01/08/2022 12:00	26.0	65.1	0.6	2.0	0.5
01/08/2022 13:00	4.2	1.9	1.0	3.5	0.8
01/08/2022 14:00	4.1	2.1	1.0	3.4	0.8
01/08/2022 15:00	61.4	60.1	1.3	5.3	1.2
01/08/2022 16:00	39.9	55.2	1.4	7.2	1.6
01/08/2022 17:00	8.1	2.7	1.6	8.9	2.0
01/08/2022 18:00	12.5	3.3	1.8	9.8	2.2
01/08/2022 19:00	14.2	7.0	2.0	11.1	2.4
01/08/2022 20:00	14.2	5.9	2.0	11.1	2.4
01/08/2022 21:00	10.3	2.6	1.7	9.4	2.0
01/08/2022 22:00	10.7	3.0	1.8	9.8	2.2
01/08/2022 23:00	14.0	6.3	2.0	11.0	2.4
Average/Sum#:	274.0 #	285.5 #	18.6 #	93.9 #	20.8 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	61.4	65.1	2.0	11.1	2.4
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
01/09/2022 00:00	13.6	6.0	2.0	10.7	2.4
01/09/2022 01:00	7.6	2.6	1.6	8.3	1.8
01/09/2022 02:00	9.5	3.3	1.6	8.7	1.9
01/09/2022 03:00	11.7	7.1	2.0	10.7	2.4
01/09/2022 04:00	11.6	7.0	2.0	10.6	2.3
01/09/2022 05:00	10.0	2.8	1.7	9.1	2.0
01/09/2022 06:00	10.0	3.4	1.7	9.1	2.0
01/09/2022 07:00	16.2	7.4	2.0	11.1	2.4
01/09/2022 08:00	13.8	7.4	2.0	10.8	2.4
01/09/2022 09:00	7.9	2.7	1.6	8.7	1.9
01/09/2022 10:00	7.6	2.9	1.6	8.3	1.8
01/09/2022 11:00	8.1	2.7	1.6	8.8	2.0
01/09/2022 12:00	7.3	2.7	1.4	8.0	1.8
01/09/2022 13:00	7.6	2.5	1.5	8.3	1.8
01/09/2022 14:00	8.2	2.4	1.7	9.0	2.0
01/09/2022 15:00	8.3	2.5	1.7	9.1	2.0
01/09/2022 16:00	9.7	3.3	1.6	8.9	2.0
01/09/2022 17:00	15.8	6.6	2.0	10.9	2.4
01/09/2022 18:00	14.3	6.0	2.1	11.3	2.4
01/09/2022 19:00	13.6	6.6	2.0	10.7	2.4
01/09/2022 20:00	16.0	6.0	2.0	10.9	2.4
01/09/2022 21:00	15.8	6.0	2.0	10.9	2.4
01/09/2022 22:00	14.3	5.6	2.0	11.1	2.4
01/09/2022 23:00	11.7	7.7	2.0	10.7	2.4
Average/Sum#:	270.2 #	113.2 #	43.4 #	234.7 #	51.7 #
Minimum:	7.3	2.4	1.4	8.0	1.8
Maximum:	16.2	7.7	2.1	11.3	2.4
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
01/10/2022 00:00	11.1	6.2	1.8	10.2	2.2
01/10/2022 01:00	9.6	11.7	1.3	6.7	1.5
01/10/2022 02:00	4.2	1.8	1.0	3.5	0.8
01/10/2022 03:00	4.3	2.1	1.0	3.6	0.9
01/10/2022 04:00	4.5	2.0	1.1	3.8	0.9
01/10/2022 05:00	4.6	1.7	1.1	3.8	0.9
01/10/2022 06:00	34.2	35.8	1.4	5.4	1.3
01/10/2022 07:00	38.2	60.7	1.5	7.7	1.7
01/10/2022 08:00	8.3	2.8	1.7	9.1	2.0
01/10/2022 09:00	7.9	2.7	1.6	8.7	1.9
01/10/2022 10:00	9.8	2.7	1.7	9.0	2.0
01/10/2022 11:00	13.8	6.4	2.0	10.8	2.4
01/10/2022 12:00	13.4	5.9	2.0	10.5	2.3
01/10/2022 13:00	7.8	2.7	1.6	8.5	1.8
01/10/2022 14:00	9.9	2.4	1.7	9.0	2.0
01/10/2022 15:00	15.8	5.9	2.0	10.9	2.4
01/10/2022 16:00	14.3	6.0	2.1	11.3	2.4
01/10/2022 17:00	16.8	5.5	2.1	11.5	2.5
01/10/2022 18:00	14.9	5.5	2.1	11.7	2.6
01/10/2022 19:00	14.8	5.5	2.1	11.7	2.6
01/10/2022 20:00	14.9	5.5	2.1	11.7	2.6
01/10/2022 21:00	16.9	5.7	2.1	11.6	2.5
01/10/2022 22:00	14.0	5.6	2.0	11.0	2.4
01/10/2022 23:00	15.8	6.0	2.0	10.9	2.4
Average/Sum#:	319.8 #	198.8 #	41.1 #	212.6 #	47.0 #
Minimum:	4.2	1.7	1.0	3.5	0.8
Maximum:	38.2	60.7	2.1	11.7	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
01/11/2022 00:00	11.0	5.7	1.8	10.0	2.2
01/11/2022 01:00	6.5	2.9	1.3	7.2	1.6
01/11/2022 02:00	7.9	3.6	1.6	8.7	1.9
01/11/2022 03:00	11.7	6.7	2.0	10.7	2.4
01/11/2022 04:00	11.5	6.0	2.0	10.6	2.3
01/11/2022 05:00	8.1	2.7	1.6	8.9	2.0
01/11/2022 06:00	9.5	3.3	1.6	8.7	1.9
01/11/2022 07:00	13.8	6.7	2.0	10.9	2.4
01/11/2022 08:00	10.9	5.4	1.8	10.0	2.2
01/11/2022 09:00	6.6	2.7	1.3	7.2	1.6
01/11/2022 10:00	6.6	2.7	1.3	7.2	1.6
01/11/2022 11:00	6.8	2.6	1.4	7.6	1.6
01/11/2022 12:00	6.8	2.6	1.4	7.4	1.6
01/11/2022 13:00	6.8	2.6	1.4	7.4	1.6
01/11/2022 14:00	6.6	2.2	1.3	7.2	1.6
01/11/2022 15:00	6.9	2.6	1.4	7.6	1.6
01/11/2022 16:00	8.1	2.7	1.6	8.9	2.0
01/11/2022 17:00	11.6	3.1	1.7	9.1	2.0
01/11/2022 18:00	13.8	6.6	2.0	10.8	2.4
01/11/2022 19:00	15.6	6.3	2.0	10.7	2.4
01/11/2022 20:00	11.6	6.3	2.0	10.6	2.3
01/11/2022 21:00	13.6	6.3	2.0	10.7	2.4
01/11/2022 22:00	16.0	5.9	2.0	11.0	2.4
01/11/2022 23:00	10.1	4.2	1.7	9.2	2.0
Average/Sum#:	238.4 #	102.4 #	40.2 #	218.3 #	48.0 #
Minimum:	6.5	2.2	1.3	7.2	1.6
Maximum:	16.0	6.7	2.0	11.0	2.4
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
01/12/2022 00:00	7.7	10.3	1.1	4.5	1.0
01/12/2022 01:00	4.1	2.0	1.0	3.4	0.8
01/12/2022 02:00	4.1	2.0	1.0	3.4	0.8
01/12/2022 03:00	4.1	2.0	1.0	3.4	0.8
01/12/2022 04:00	4.1	2.0	1.0	3.4	0.8
01/12/2022 05:00	5.8	1.9	1.0	3.6	0.9
01/12/2022 06:00	5.9	5.1	1.4	4.9	1.2
01/12/2022 07:00	5.9	4.7	1.4	4.9	1.2
01/12/2022 08:00	5.9	4.7	1.4	4.9	1.2
01/12/2022 09:00	21.0	11.7	1.2	4.7	1.1
01/12/2022 10:00	62.2	75.5	1.3	6.3	1.5
01/12/2022 11:00	7.0	2.9	1.4	7.6	1.6
01/12/2022 12:00	7.6	2.6	1.6	8.5	1.8
01/12/2022 13:00	7.9	2.7	1.6	8.7	1.9
01/12/2022 14:00	7.8	2.7	1.6	8.6	1.8
01/12/2022 15:00	9.7	3.0	1.7	8.9	2.0
01/12/2022 16:00	14.0	5.9	2.0	11.0	2.4
01/12/2022 17:00	14.5	5.5	2.1	11.3	2.5
01/12/2022 18:00	14.3	5.6	2.0	11.3	2.4
01/12/2022 19:00	14.2	5.6	2.0	11.1	2.4
01/12/2022 20:00	15.6	5.6	2.0	10.7	2.4
01/12/2022 21:00	10.1	2.5	1.7	9.2	2.0
01/12/2022 22:00	10.7	3.0	1.8	9.8	2.2
01/12/2022 23:00	13.8	7.0	2.0	10.8	2.4
Average/Sum#:	278.0 #	176.5 #	36.3 #	174.9 #	39.1 #
Minimum:	4.1	1.9	1.0	3.4	0.8
Maximum:	62.2	75.5	2.1	11.3	2.5
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
01/13/2022 00:00	10.9	5.4	1.8	10.0	2.2
01/13/2022 01:00	6.5	3.5	1.3	7.2	1.6
01/13/2022 02:00	9.5	3.6	1.6	8.7	1.9
01/13/2022 03:00	11.7	7.8	2.0	10.7	2.4
01/13/2022 04:00	11.6	7.3	2.0	10.6	2.3
01/13/2022 05:00	11.8	3.2	1.7	9.2	2.0
01/13/2022 06:00	9.7	3.3	1.6	8.9	2.0
01/13/2022 07:00	14.0	5.3	2.0	11.1	2.4
01/13/2022 08:00	11.5	4.6	2.0	10.6	2.3
01/13/2022 09:00	9.9	3.1	1.7	9.1	2.0
01/13/2022 10:00	7.0	3.1	1.4	7.6	1.6
01/13/2022 11:00	9.7	2.7	1.7	8.9	2.0
01/13/2022 12:00	11.1	5.3	1.9	10.2	2.2
01/13/2022 13:00	13.9	5.8	2.0	10.9	2.4
01/13/2022 14:00	9.3	2.6	1.6	8.5	1.8
01/13/2022 15:00	9.3	3.0	1.6	8.5	1.8
01/13/2022 16:00	13.9	5.9	2.0	10.9	2.4
01/13/2022 17:00	14.1	5.6	2.0	11.1	2.4
01/13/2022 18:00	14.4	5.6	2.1	11.3	2.5
01/13/2022 19:00	15.6	5.9	2.0	10.7	2.4
01/13/2022 20:00	9.5	2.4	1.6	8.7	1.9
01/13/2022 21:00	9.8	3.0	1.7	9.0	2.0
01/13/2022 22:00	15.8	6.6	2.0	10.9	2.4
01/13/2022 23:00	12.1	21.9	0.6	3.1	0.6
Average/Sum#:	272.6 #	126.5 #	41.9 #	226.4 #	49.5 #
Minimum:	6.5	2.4	0.6	3.1	0.6
Maximum:	15.8	21.9	2.1	11.3	2.5
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
01/14/2022 00:00	0.0	0.0	0.0	0.0	0.0
01/14/2022 01:00	0.0	0.0	0.0	0.0	0.0
01/14/2022 02:00	0.0	0.0	0.0	0.0	0.0
01/14/2022 03:00	0.0	0.0	0.0	0.0	0.0
01/14/2022 04:00	1.3	6.8	0.1	0.2	0.1
01/14/2022 05:00	29.6	85.7	0.5	1.9	0.5
01/14/2022 06:00	4.5	1.9	1.0	3.7	0.9
01/14/2022 07:00	7.4	2.0	1.3	4.6	1.1
01/14/2022 08:00	4.2	2.1	1.0	3.5	0.8
01/14/2022 09:00	4.1	2.1	1.0	3.4	0.8
01/14/2022 10:00	4.1	2.1	1.0	3.4	0.8
01/14/2022 11:00	4.1	1.8	1.0	3.4	0.8
01/14/2022 12:00	4.1	1.8	1.0	3.5	0.8
01/14/2022 13:00	50.2	24.3	1.3	5.1	1.2
01/14/2022 14:00	44.4	48.9	1.4	6.7	1.5
01/14/2022 15:00	7.6	2.6	1.6	8.3	1.8
01/14/2022 16:00	8.5	2.4	1.4	7.8	1.7
01/14/2022 17:00	7.9	2.4	1.6	8.7	1.9
01/14/2022 18:00	8.1	2.4	1.6	8.9	2.0
01/14/2022 19:00	12.9	4.5	1.8	10.2	2.2
01/14/2022 20:00	13.1	5.2	1.9	10.2	2.2
01/14/2022 21:00	10.3	3.2	1.7	9.4	2.0
01/14/2022 22:00	16.1	6.3	2.0	11.1	2.4
01/14/2022 23:00	9.9	24.1	0.6	3.2	0.7
Average/Sum#:	252.4 #	232.6 #	24.8 #	117.2 #	26.2 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	50.2	85.7	2.0	11.1	2.4
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
01/15/2022 00:00	0.0	0.0	0.0	0.0	0.0
01/15/2022 01:00	0.0	0.0	0.0	0.0	0.0
01/15/2022 02:00	0.0	0.0	0.0	0.0	0.0
01/15/2022 03:00	0.0	0.0	0.0	0.0	0.0
01/15/2022 04:00	0.6	4.9	0.0	0.1	0.0
01/15/2022 05:00	30.4	94.0	0.5	1.9	0.5
01/15/2022 06:00	4.6	1.7	1.1	3.8	0.9
01/15/2022 07:00	4.7	1.7	1.1	3.9	0.9
01/15/2022 08:00	4.3	1.9	1.0	3.5	0.9
01/15/2022 09:00	4.6	1.7	1.1	3.8	0.9
01/15/2022 10:00	4.1	1.8	1.0	3.4	0.8
01/15/2022 11:00	4.1	1.8	1.0	3.4	0.8
01/15/2022 12:00	4.1	1.8	1.0	3.4	0.8
01/15/2022 13:00	4.1	2.1	1.0	3.4	0.8
01/15/2022 14:00	52.3	28.0	1.3	5.3	1.2
01/15/2022 15:00	47.0	54.1	1.4	7.1	1.5
01/15/2022 16:00	7.9	2.7	1.6	8.7	1.9
01/15/2022 17:00	11.7	2.8	1.7	9.2	2.0
01/15/2022 18:00	13.1	5.6	1.9	10.2	2.2
01/15/2022 19:00	15.6	7.2	2.0	10.7	2.4
01/15/2022 20:00	10.1	3.1	1.7	9.3	2.0
01/15/2022 21:00	10.7	3.3	1.8	9.8	2.2
01/15/2022 22:00	15.8	7.6	2.0	10.9	2.4
01/15/2022 23:00	13.8	29.5	1.0	5.8	1.2
Average/Sum#:	263.6 #	257.3 #	25.2 #	117.6 #	26.3 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	52.3	94.0	2.0	10.9	2.4
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
01/16/2022 00:00	0.0	0.0	0.0	0.0	0.0
01/16/2022 01:00	0.0	0.0	0.0	0.0	0.0
01/16/2022 02:00	0.0	0.0	0.0	0.0	0.0
01/16/2022 03:00	0.0	0.0	0.0	0.0	0.0
01/16/2022 04:00	0.0	0.0	0.0	0.0	0.0
01/16/2022 05:00	0.0	0.0	0.0	0.0	0.0
01/16/2022 06:00	0.0	0.0	0.0	0.0	0.0
01/16/2022 07:00	0.0	0.0	0.0	0.0	0.0
01/16/2022 08:00	0.0	0.0	0.0	0.0	0.0
01/16/2022 09:00	0.0	0.0	0.0	0.0	0.0
01/16/2022 10:00	0.0	0.0	0.0	0.0	0.0
01/16/2022 11:00	48.8	51.0	0.2	0.9	0.2
01/16/2022 12:00	28.0	83.4	0.5	1.7	0.4
01/16/2022 13:00	4.2	2.3	1.0	3.5	0.8
01/16/2022 14:00	4.1	2.3	1.0	3.4	0.8
01/16/2022 15:00	27.6	27.0	1.2	4.6	1.1
01/16/2022 16:00	60.1	59.4	1.4	6.0	1.4
01/16/2022 17:00	7.3	2.7	1.4	7.9	1.8
01/16/2022 18:00	10.3	3.2	1.7	9.4	2.0
01/16/2022 19:00	13.3	6.9	1.9	10.4	2.3
01/16/2022 20:00	14.0	6.5	2.0	11.0	2.4
01/16/2022 21:00	11.8	2.5	1.7	9.3	2.0
01/16/2022 22:00	7.0	2.7	1.4	7.6	1.6
01/16/2022 23:00	8.1	2.7	1.6	8.9	2.0
Average/Sum#:	244.6 #	252.6 #	17.0 #	84.6 #	18.8 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	60.1	83.4	2.0	11.0	2.4
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
01/17/2022 00:00	10.9	5.4	1.8	10.0	2.2
01/17/2022 01:00	11.1	6.2	1.8	10.2	2.2
01/17/2022 02:00	7.1	3.5	1.4	7.8	1.7
01/17/2022 03:00	10.5	3.3	1.7	9.6	2.1
01/17/2022 04:00	13.0	4.9	1.8	10.2	2.2
01/17/2022 05:00	12.8	5.5	1.8	10.0	2.2
01/17/2022 06:00	10.1	3.4	1.7	9.3	2.0
01/17/2022 07:00	14.0	6.6	2.0	11.1	2.4
01/17/2022 08:00	14.2	6.0	2.0	11.1	2.4
01/17/2022 09:00	15.6	6.9	2.0	10.8	2.4
01/17/2022 10:00	9.5	3.0	1.6	8.7	1.9
01/17/2022 11:00	7.9	2.7	1.6	8.7	1.9
01/17/2022 12:00	11.5	3.1	1.7	9.1	2.0
01/17/2022 13:00	15.6	6.2	2.0	10.7	2.4
01/17/2022 14:00	15.4	5.5	2.0	10.5	2.3
01/17/2022 15:00	9.6	2.4	1.6	8.8	2.0
01/17/2022 16:00	9.5	2.7	1.6	8.7	1.9
01/17/2022 17:00	15.7	6.5	2.0	10.8	2.4
01/17/2022 18:00	14.0	5.5	2.0	11.0	2.4
01/17/2022 19:00	14.2	5.9	2.0	11.2	2.4
01/17/2022 20:00	13.5	5.9	2.0	10.6	2.3
01/17/2022 21:00	9.9	2.4	1.7	9.0	2.0
01/17/2022 22:00	7.1	2.9	1.4	7.8	1.7
01/17/2022 23:00	9.7	3.0	1.7	8.9	2.0
Average/Sum#:	282.4 #	109.4 #	42.9 #	234.6 #	51.4 #
Minimum:	7.1	2.4	1.4	7.8	1.7
Maximum:	15.7	6.9	2.0	11.2	2.4
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
01/18/2022 00:00	12.5	3.3	1.8	9.8	2.2
01/18/2022 01:00	11.1	6.0	1.8	10.1	2.2
01/18/2022 02:00	9.7	3.3	1.6	8.9	2.0
01/18/2022 03:00	11.6	4.7	2.0	10.6	2.3
01/18/2022 04:00	11.7	4.7	2.0	10.7	2.4
01/18/2022 05:00	9.5	3.3	1.6	8.7	1.9
01/18/2022 06:00	9.5	3.6	1.6	8.7	1.9
01/18/2022 07:00	11.8	6.4	2.0	10.8	2.4
01/18/2022 08:00	16.0	5.7	2.0	11.0	2.4
01/18/2022 09:00	11.5	6.3	2.0	10.6	2.3
01/18/2022 10:00	2.8	0.8	1.4	7.9	1.8
01/18/2022 11:00	4.2	2.4	1.4	7.7	1.6
01/18/2022 12:00	3.9	2.2	1.3	7.2	1.6
01/18/2022 13:00	0.0	0.0	1.3	7.2	1.6
01/18/2022 14:00	6.8	2.6	1.4	7.4	1.6
01/18/2022 15:00	9.1	2.9	1.6	8.4	1.8
01/18/2022 16:00	11.3	3.0	1.6	8.9	2.0
01/18/2022 17:00	14.0	6.6	2.0	11.1	2.4
01/18/2022 18:00	14.1	5.9	2.0	11.1	2.4
01/18/2022 19:00	14.3	5.8	2.1	11.3	2.4
01/18/2022 20:00	13.6	5.9	2.0	10.6	2.3
01/18/2022 21:00	9.5	2.7	1.6	8.7	1.9
01/18/2022 22:00	9.5	3.3	1.6	8.7	1.9
01/18/2022 23:00	13.8	7.3	2.0	10.8	2.4
Average/Sum#:	230.9 #	93.3 #	41.7 #	226.9 #	49.7 #
Minimum:	6.8	2.6	1.3	7.2	1.6
Maximum:	16.0	7.3	2.1	11.3	2.4
%SI	16.67	16.67	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
01/19/2022 00:00	10.9	5.4	1.8	10.0	2.2
01/19/2022 01:00	6.5	3.2	1.3	7.2	1.6
01/19/2022 02:00	9.5	3.6	1.6	8.7	1.9
01/19/2022 03:00	11.7	7.1	2.0	10.7	2.4
01/19/2022 04:00	11.5	6.6	2.0	10.6	2.3
01/19/2022 05:00	9.5	3.6	1.6	8.7	1.9
01/19/2022 06:00	11.1	4.2	1.6	8.7	1.9
01/19/2022 07:00	13.7	7.4	2.0	10.8	2.4
01/19/2022 08:00	7.8	4.4	2.0	10.7	2.4
01/19/2022 09:00	9.1	3.7	1.5	8.3	1.8
01/19/2022 10:00	4.1	2.3	1.4	7.4	1.6
01/19/2022 11:00	7.1	3.0	1.4	7.8	1.7
01/19/2022 12:00	6.6	3.3	1.3	7.2	1.6
01/19/2022 13:00	6.9	2.8	1.4	7.6	1.6
01/19/2022 14:00	6.8	2.9	1.4	7.4	1.6
01/19/2022 15:00	6.3	2.0	1.6	8.7	1.9
01/19/2022 16:00	16.3	5.9	2.1	11.2	2.4
01/19/2022 17:00	14.4	5.2	2.1	11.4	2.5
01/19/2022 18:00	14.2	5.2	2.1	11.2	2.4
01/19/2022 19:00	14.4	5.5	2.1	11.3	2.5
01/19/2022 20:00	14.0	5.1	2.0	11.0	2.4
01/19/2022 21:00	10.1	2.5	1.7	9.3	2.0
01/19/2022 22:00	10.7	2.6	1.8	9.8	2.2
01/19/2022 23:00	15.8	5.0	2.0	10.9	2.4
Average/Sum#:	230.8 #	93.8 #	41.8 #	226.6 #	49.6 #
Minimum:	6.5	2.5	1.3	7.2	1.6
Maximum:	16.3	7.4	2.1	11.4	2.5
%SI	12.50	12.50	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
01/20/2022 00:00	12.9	4.0	1.8	10.2	2.2
01/20/2022 01:00	6.5	2.4	1.3	7.2	1.6
01/20/2022 02:00	6.6	2.7	1.3	7.2	1.6
01/20/2022 03:00	10.3	2.6	1.7	9.5	2.0
01/20/2022 04:00	11.1	4.6	1.8	10.2	2.2
01/20/2022 05:00	11.1	4.6	1.8	10.2	2.2
01/20/2022 06:00	10.3	3.2	1.7	9.4	2.0
01/20/2022 07:00	15.8	6.0	2.0	10.8	2.4
01/20/2022 08:00	11.8	3.9	1.7	9.3	2.0
01/20/2022 09:00	7.8	10.4	1.1	4.7	1.0
01/20/2022 10:00	4.1	2.1	1.0	3.4	0.8
01/20/2022 11:00	4.1	1.8	1.0	3.4	0.8
01/20/2022 12:00	4.1	1.8	1.0	3.4	0.8
01/20/2022 13:00	4.1	1.8	1.0	3.4	0.8
01/20/2022 14:00	4.1	1.8	1.0	3.4	0.8
01/20/2022 15:00	4.1	1.8	1.0	3.5	0.8
01/20/2022 16:00	29.5	16.1	1.3	4.8	1.1
01/20/2022 17:00	46.1	66.5	1.4	7.2	1.6
01/20/2022 18:00	8.1	2.7	1.6	8.9	2.0
01/20/2022 19:00	12.0	3.2	1.7	9.4	2.0
01/20/2022 20:00	14.0	6.6	2.0	11.0	2.4
01/20/2022 21:00	14.0	6.3	2.0	11.0	2.4
01/20/2022 22:00	14.2	5.9	2.0	11.2	2.4
01/20/2022 23:00	13.1	22.8	0.9	4.2	0.9
Average/Sum#:	279.8 #	185.6 #	35.1 #	176.9 #	38.8 #
Minimum:	4.1	1.8	0.9	3.4	0.8
Maximum:	46.1	66.5	2.0	11.2	2.4
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
01/21/2022 00:00	0.0	0.0	0.0	0.0	0.0
01/21/2022 01:00	0.0	0.0	0.0	0.0	0.0
01/21/2022 02:00	0.0	0.0	0.0	0.0	0.0
01/21/2022 03:00	0.0	0.0	0.0	0.0	0.0
01/21/2022 04:00	0.0	0.0	0.0	0.0	0.0
01/21/2022 05:00	0.0	0.0	0.0	0.0	0.0
01/21/2022 06:00	0.0	0.0	0.0	0.0	0.0
01/21/2022 07:00	0.0	0.0	0.0	0.0	0.0
01/21/2022 08:00	0.0	0.0	0.0	0.0	0.0
01/21/2022 09:00	0.0	0.0	0.0	0.0	0.0
01/21/2022 10:00	0.0	0.0	0.0	0.0	0.0
01/21/2022 11:00	0.0	0.0	0.0	0.0	0.0
01/21/2022 12:00	0.0	0.0	0.0	0.0	0.0
01/21/2022 13:00	0.0	0.0	0.0	0.0	0.0
01/21/2022 14:00	0.0	0.0	0.0	0.0	0.0
01/21/2022 15:00	0.0	0.0	0.0	0.0	0.0
01/21/2022 16:00	0.0	0.0	0.0	0.0	0.0
01/21/2022 17:00	0.0	0.0	0.0	0.0	0.0
01/21/2022 18:00	0.0	0.0	0.0	0.0	0.0
01/21/2022 19:00	0.0	0.0	0.0	0.0	0.0
01/21/2022 20:00	0.0	0.0	0.0	0.0	0.0
01/21/2022 21:00	0.0	0.0	0.0	0.0	0.0
01/21/2022 22:00	0.0	0.0	0.0	0.0	0.0
01/21/2022 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
01/22/2022 00:00	0.0	0.0	0.0	0.0	0.0
01/22/2022 01:00	0.0	0.0	0.0	0.0	0.0
01/22/2022 02:00	0.0	0.0	0.0	0.0	0.0
01/22/2022 03:00	0.0	0.0	0.0	0.0	0.0
01/22/2022 04:00	0.0	0.0	0.0	0.0	0.0
01/22/2022 05:00	0.0	0.0	0.0	0.0	0.0
01/22/2022 06:00	0.0	0.0	0.0	0.0	0.0
01/22/2022 07:00	0.0	0.0	0.0	0.0	0.0
01/22/2022 08:00	0.0	0.0	0.0	0.0	0.0
01/22/2022 09:00	0.0	0.0	0.0	0.0	0.0
01/22/2022 10:00	0.0	0.0	0.0	0.0	0.0
01/22/2022 11:00	0.0	0.0	0.0	0.0	0.0
01/22/2022 12:00	0.0	0.0	0.0	0.0	0.0
01/22/2022 13:00	0.0	0.0	0.0	0.0	0.0
01/22/2022 14:00	0.0	0.0	0.0	0.0	0.0
01/22/2022 15:00	0.0	0.0	0.0	0.0	0.0
01/22/2022 16:00	0.0	0.0	0.0	0.0	0.0
01/22/2022 17:00	0.0	0.0	0.0	0.0	0.0
01/22/2022 18:00	0.0	0.0	0.0	0.0	0.0
01/22/2022 19:00	0.0	0.0	0.0	0.0	0.0
01/22/2022 20:00	0.0	0.0	0.0	0.0	0.0
01/22/2022 21:00	0.0	0.0	0.0	0.0	0.0
01/22/2022 22:00	0.0	0.0	0.0	0.0	0.0
01/22/2022 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
01/23/2022 00:00	0.0	0.0	0.0	0.0	0.0
01/23/2022 01:00	0.0	0.0	0.0	0.0	0.0
01/23/2022 02:00	0.0	0.0	0.0	0.0	0.0
01/23/2022 03:00	0.0	0.0	0.0	0.0	0.0
01/23/2022 04:00	0.0	0.0	0.0	0.0	0.0
01/23/2022 05:00	0.0	0.0	0.0	0.0	0.0
01/23/2022 06:00	0.0	0.0	0.0	0.0	0.0
01/23/2022 07:00	0.0	0.0	0.0	0.0	0.0
01/23/2022 08:00	0.0	0.0	0.0	0.0	0.0
01/23/2022 09:00	0.0	0.0	0.0	0.0	0.0
01/23/2022 10:00	0.0	0.0	0.0	0.0	0.0
01/23/2022 11:00	55.3	61.7	0.2	0.6	0.1
01/23/2022 12:00	33.4	24.1	0.3	1.0	0.2
01/23/2022 13:00	54.3	76.3	0.6	2.0	0.5
01/23/2022 14:00	4.3	1.3	1.0	3.6	0.9
01/23/2022 15:00	4.1	1.3	1.0	3.5	0.8
01/23/2022 16:00	30.2	53.3	1.1	4.5	1.1
01/23/2022 17:00	98.5	61.3	1.3	6.2	1.4
01/23/2022 18:00	10.4	3.0	1.7	9.5	2.1
01/23/2022 19:00	15.7	6.0	2.0	10.9	2.4
01/23/2022 20:00	14.4	6.3	2.1	11.3	2.5
01/23/2022 21:00	14.1	5.6	2.0	11.1	2.4
01/23/2022 22:00	13.8	6.1	2.0	10.9	2.4
01/23/2022 23:00	12.1	22.1	0.6	3.1	0.6
Average/Sum#:	360.6 #	328.4 #	15.9 #	78.2 #	17.4 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	98.5	76.3	2.1	11.3	2.5
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
01/24/2022 00:00	0.0	0.0	0.0	0.0	0.0
01/24/2022 01:00	0.0	0.0	0.0	0.0	0.0
01/24/2022 02:00	0.0	0.0	0.0	0.0	0.0
01/24/2022 03:00	0.2	2.6	0.0	0.1	0.0
01/24/2022 04:00	27.8	109.3	0.6	2.1	0.5
01/24/2022 05:00	4.6	2.3	1.1	3.8	0.9
01/24/2022 06:00	6.3	4.0	1.5	5.2	1.3
01/24/2022 07:00	6.5	4.0	1.5	5.4	1.3
01/24/2022 08:00	5.5	2.9	1.3	4.6	1.1
01/24/2022 09:00	4.1	2.3	1.0	3.4	0.8
01/24/2022 10:00	4.1	2.3	1.0	3.4	0.8
01/24/2022 11:00	4.1	2.0	1.0	3.4	0.8
01/24/2022 12:00	4.1	2.3	1.0	3.4	0.8
01/24/2022 13:00	4.1	2.1	1.0	3.4	0.8
01/24/2022 14:00	54.3	30.7	1.3	5.4	1.3
01/24/2022 15:00	36.9	50.9	1.3	7.0	1.6
01/24/2022 16:00	9.9	2.8	1.7	9.1	2.0
01/24/2022 17:00	9.9	3.3	1.7	9.1	2.0
01/24/2022 18:00	15.8	6.3	2.0	10.8	2.4
01/24/2022 19:00	14.2	6.3	2.0	11.2	2.4
01/24/2022 20:00	15.6	5.5	2.0	10.7	2.4
01/24/2022 21:00	8.1	2.7	1.6	8.9	2.0
01/24/2022 22:00	10.4	3.2	1.7	9.5	2.1
01/24/2022 23:00	15.8	6.6	2.0	10.8	2.4
Average/Sum#:	262.3 #	254.4 #	28.3 #	130.7 #	29.7 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	54.3	109.3	2.0	11.2	2.4
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
01/25/2022 00:00	11.5	6.5	2.0	10.6	2.3
01/25/2022 01:00	7.8	3.2	1.6	8.5	1.8
01/25/2022 02:00	9.9	3.4	1.7	9.1	2.0
01/25/2022 03:00	11.7	6.0	2.0	10.7	2.4
01/25/2022 04:00	11.6	6.0	2.0	10.6	2.3
01/25/2022 05:00	8.3	3.4	1.7	9.1	2.0
01/25/2022 06:00	10.6	3.3	1.7	9.7	2.1
01/25/2022 07:00	16.1	6.3	2.0	11.0	2.4
01/25/2022 08:00	17.0	23.4	1.1	6.2	1.4
01/25/2022 09:00	0.0	0.0	0.0	0.0	0.0
01/25/2022 10:00	0.0	0.0	0.0	0.0	0.0
01/25/2022 11:00	0.4	2.4	0.0	0.1	0.0
01/25/2022 12:00	30.6	41.2	0.2	2.3	0.5
01/25/2022 13:00	2.7	0.8	0.4	4.1	0.8
01/25/2022 14:00	2.7	0.8	0.4	4.1	0.8
01/25/2022 15:00	20.5	16.4	0.6	5.5	1.1
01/25/2022 16:00	42.6	58.5	1.2	7.1	1.5
01/25/2022 17:00	9.9	2.5	1.7	9.1	2.0
01/25/2022 18:00	10.3	2.6	1.7	9.5	2.0
01/25/2022 19:00	13.3	5.9	2.0	10.5	2.3
01/25/2022 20:00	15.4	5.9	2.0	10.6	2.3
01/25/2022 21:00	9.1	2.7	1.6	8.4	1.8
01/25/2022 22:00	10.3	3.2	1.7	9.4	2.0
01/25/2022 23:00	13.6	4.7	2.0	10.7	2.4
Average/Sum#:	285.9 #	209.1 #	31.3 #	176.9 #	38.2 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	42.6	58.5	2.0	11.0	2.4
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
01/26/2022 00:00	13.6	5.0	2.0	10.7	2.4
01/26/2022 01:00	10.1	2.6	1.7	9.3	2.0
01/26/2022 02:00	8.6	3.2	1.7	9.3	2.0
01/26/2022 03:00	11.8	5.7	2.0	10.8	2.4
01/26/2022 04:00	15.8	5.4	2.0	10.8	2.4
01/26/2022 05:00	7.9	2.7	1.6	8.7	1.9
01/26/2022 06:00	10.8	3.3	1.8	9.8	2.2
01/26/2022 07:00	13.8	6.1	2.0	10.9	2.4
01/26/2022 08:00	17.0	28.9	1.0	5.8	1.2
01/26/2022 09:00	0.0	0.0	0.0	0.0	0.0
01/26/2022 10:00	0.0	0.0	0.0	0.0	0.0
01/26/2022 11:00	0.3	2.4	0.0	0.2	0.0
01/26/2022 12:00	34.0	38.8	0.2	2.4	0.5
01/26/2022 13:00	2.7	0.8	0.4	4.1	0.8
01/26/2022 14:00	2.7	0.8	0.4	4.0	0.8
01/26/2022 15:00	13.4	16.6	0.6	5.5	1.1
01/26/2022 16:00	37.8	62.7	1.2	7.1	1.5
01/26/2022 17:00	10.3	2.6	1.7	9.4	2.0
01/26/2022 18:00	12.6	3.3	1.8	9.9	2.2
01/26/2022 19:00	13.3	5.3	2.0	10.4	2.3
01/26/2022 20:00	14.0	5.9	2.0	11.0	2.4
01/26/2022 21:00	10.0	2.5	1.7	9.1	2.0
01/26/2022 22:00	10.7	2.7	1.8	9.8	2.2
01/26/2022 23:00	16.0	6.0	2.0	11.0	2.4
Average/Sum#:	287.2 #	213.3 #	31.6 #	180.0 #	39.1 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	37.8	62.7	2.0	11.0	2.4
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
01/27/2022 00:00	13.6	6.0	2.0	10.8	2.4
01/27/2022 01:00	7.6	3.1	1.6	8.3	1.8
01/27/2022 02:00	10.2	3.2	1.7	9.3	2.0
01/27/2022 03:00	11.7	5.7	2.0	10.7	2.4
01/27/2022 04:00	11.7	5.4	2.0	10.7	2.4
01/27/2022 05:00	7.9	2.7	1.6	8.7	1.9
01/27/2022 06:00	12.9	4.5	1.9	10.2	2.2
01/27/2022 07:00	16.0	5.7	2.0	11.0	2.4
01/27/2022 08:00	13.8	5.7	2.0	10.8	2.4
01/27/2022 09:00	11.8	4.2	1.7	9.2	2.0
01/27/2022 10:00	6.6	13.1	0.7	5.1	1.0
01/27/2022 11:00	2.7	0.8	0.4	4.0	0.8
01/27/2022 12:00	2.7	0.8	0.4	4.1	0.8
01/27/2022 13:00	2.7	0.8	0.4	4.1	0.8
01/27/2022 14:00	2.7	0.8	0.4	4.1	0.8
01/27/2022 15:00	13.8	14.8	0.6	5.5	1.1
01/27/2022 16:00	33.5	59.3	1.2	7.1	1.5
01/27/2022 17:00	9.1	2.6	1.6	8.4	1.8
01/27/2022 18:00	14.4	3.3	1.8	9.9	2.2
01/27/2022 19:00	14.0	6.0	2.0	11.1	2.4
01/27/2022 20:00	15.9	5.3	2.0	10.9	2.4
01/27/2022 21:00	10.1	2.5	1.7	9.2	2.0
01/27/2022 22:00	8.9	2.5	1.4	8.1	1.8
01/27/2022 23:00	11.4	5.4	2.0	10.4	2.3
Average/Sum#:	265.7 #	164.2 #	35.1 #	201.7 #	43.6 #
Minimum:	2.7	0.8	0.4	4.0	0.8
Maximum:	33.5	59.3	2.0	11.1	2.4
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
01/28/2022 00:00	14.2	6.0	2.0	11.2	2.4
01/28/2022 01:00	14.2	6.0	2.0	11.1	2.4
01/28/2022 02:00	7.6	2.8	1.5	8.3	1.8
01/28/2022 03:00	7.6	2.8	1.6	8.3	1.8
01/28/2022 04:00	10.5	3.0	1.7	9.7	2.1
01/28/2022 05:00	13.9	5.4	2.0	10.9	2.4
01/28/2022 06:00	14.7	5.7	2.1	11.6	2.5
01/28/2022 07:00	14.6	5.7	2.1	11.5	2.5
01/28/2022 08:00	15.7	5.1	2.0	10.8	2.4
01/28/2022 09:00	9.1	2.9	1.6	8.4	1.8
01/28/2022 10:00	7.1	2.7	1.4	7.8	1.7
01/28/2022 11:00	8.9	2.5	1.5	8.2	1.8
01/28/2022 12:00	7.3	2.5	1.4	8.0	1.8
01/28/2022 13:00	7.1	2.4	1.4	7.9	1.8
01/28/2022 14:00	9.7	2.5	1.7	8.9	2.0
01/28/2022 15:00	9.3	2.4	1.6	8.5	1.8
01/28/2022 16:00	9.6	2.7	1.6	8.8	2.0
01/28/2022 17:00	11.5	6.3	2.0	10.5	2.3
01/28/2022 18:00	14.3	6.3	2.0	11.2	2.4
01/28/2022 19:00	14.9	6.3	2.1	11.7	2.6
01/28/2022 20:00	14.4	5.5	2.1	11.3	2.5
01/28/2022 21:00	9.2	2.6	1.6	8.5	1.8
01/28/2022 22:00	10.9	3.0	1.8	10.0	2.2
01/28/2022 23:00	13.8	6.0	2.0	10.8	2.4
Average/Sum#:	270.1 #	99.1 #	42.8 #	233.9 #	51.2 #
Minimum:	7.1	2.4	1.4	7.8	1.7
Maximum:	15.7	6.3	2.1	11.7	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
01/29/2022 00:00	13.4	6.3	2.0	10.6	2.3
01/29/2022 01:00	7.9	2.7	1.6	8.7	1.9
01/29/2022 02:00	6.3	3.6	1.6	8.7	1.9
01/29/2022 03:00	13.6	6.7	2.0	10.7	2.4
01/29/2022 04:00	13.4	6.3	2.0	10.6	2.3
01/29/2022 05:00	8.1	3.0	1.6	8.9	2.0
01/29/2022 06:00	9.7	3.6	1.7	8.9	2.0
01/29/2022 07:00	16.0	7.1	2.0	10.9	2.4
01/29/2022 08:00	16.2	6.1	2.0	11.2	2.4
01/29/2022 09:00	13.5	6.6	2.0	10.6	2.3
01/29/2022 10:00	8.5	2.7	1.4	7.8	1.7
01/29/2022 11:00	7.6	2.6	1.6	8.4	1.8
01/29/2022 12:00	6.9	2.4	1.4	7.6	1.6
01/29/2022 13:00	7.0	2.4	1.4	7.7	1.6
01/29/2022 14:00	9.7	2.4	1.6	8.9	2.0
01/29/2022 15:00	6.9	2.6	1.4	7.6	1.6
01/29/2022 16:00	9.5	2.7	1.6	8.7	1.9
01/29/2022 17:00	8.1	2.7	1.6	8.9	2.0
01/29/2022 18:00	10.9	4.8	1.8	10.0	2.2
01/29/2022 19:00	13.1	5.4	1.9	10.4	2.2
01/29/2022 20:00	10.7	3.3	1.8	9.8	2.2
01/29/2022 21:00	14.0	5.4	2.0	11.0	2.4
01/29/2022 22:00	14.6	5.3	2.1	11.5	2.5
01/29/2022 23:00	11.0	4.5	1.8	10.0	2.2
Average/Sum#:	256.6 #	101.2 #	41.9 #	228.1 #	49.8 #
Minimum:	6.3	2.4	1.4	7.6	1.6
Maximum:	16.2	7.1	2.1	11.5	2.5
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
01/30/2022 00:00	7.9	2.7	1.6	8.7	1.9
01/30/2022 01:00	6.9	3.5	1.4	7.6	1.6
01/30/2022 02:00	10.4	3.3	1.7	9.5	2.1
01/30/2022 03:00	11.2	5.0	1.9	10.2	2.2
01/30/2022 04:00	11.1	5.2	1.8	10.2	2.2
01/30/2022 05:00	9.7	3.3	1.6	8.9	2.0
01/30/2022 06:00	14.0	6.7	2.0	11.0	2.4
01/30/2022 07:00	16.3	28.5	1.1	6.4	1.4
01/30/2022 08:00	0.0	0.0	0.0	0.0	0.0
01/30/2022 09:00	0.0	0.0	0.0	0.0	0.0
01/30/2022 10:00	0.0	0.0	0.0	0.0	0.0
01/30/2022 11:00	0.0	0.0	0.0	0.0	0.0
01/30/2022 12:00	0.0	0.0	0.0	0.0	0.0
01/30/2022 13:00	0.0	0.0	0.0	0.0	0.0
01/30/2022 14:00	6.4	4.7	0.0	0.2	0.0
01/30/2022 15:00	83.0	77.4	0.2	2.4	0.5
01/30/2022 16:00	3.0	0.9	0.5	4.6	0.9
01/30/2022 17:00	7.7	3.0	0.6	5.7	1.1
01/30/2022 18:00	7.6	2.6	0.6	5.7	1.1
01/30/2022 19:00	7.6	2.6	0.6	5.7	1.1
01/30/2022 20:00	8.1	2.3	0.6	6.1	1.2
01/30/2022 21:00	7.5	2.6	0.6	5.6	1.1
01/30/2022 22:00	2.8	1.1	0.4	4.1	0.8
01/30/2022 23:00	2.7	1.0	0.4	4.1	0.8
Average/Sum#:	223.9 #	156.4 #	17.6 #	116.7 #	24.4 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	83.0	77.4	2.0	11.0	2.4
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
01/31/2022 00:00	2.7	1.0	0.4	4.0	0.8
01/31/2022 01:00	2.7	1.0	0.4	4.0	0.8
01/31/2022 02:00	56.3	62.0	0.6	5.3	1.0
01/31/2022 03:00	43.8	91.6	1.1	6.8	1.4
01/31/2022 04:00	7.4	3.3	1.4	8.1	1.8
01/31/2022 05:00	7.9	3.3	1.6	8.7	1.9
01/31/2022 06:00	15.8	5.6	2.0	10.9	2.4
01/31/2022 07:00	14.2	5.7	2.0	11.2	2.4
01/31/2022 08:00	11.7	5.7	2.0	10.7	2.4
01/31/2022 09:00	9.5	3.3	1.6	8.7	1.9
01/31/2022 10:00	7.4	3.3	1.4	8.1	1.8
01/31/2022 11:00	7.8	2.6	1.6	8.5	1.8
01/31/2022 12:00	7.9	2.7	1.6	8.7	1.9
01/31/2022 13:00	7.1	2.4	1.4	7.9	1.8
01/31/2022 14:00	9.3	2.7	1.6	8.5	1.8
01/31/2022 15:00	11.5	3.3	1.7	9.0	2.0
01/31/2022 16:00	13.8	6.2	2.0	10.9	2.4
01/31/2022 17:00	14.6	6.3	2.1	11.5	2.5
01/31/2022 18:00	14.6	6.0	2.1	11.5	2.5
01/31/2022 19:00	13.4	5.6	2.0	10.5	2.3
01/31/2022 20:00	9.6	2.4	1.6	8.8	2.0
01/31/2022 21:00	10.1	2.8	1.7	9.2	2.0
01/31/2022 22:00	15.8	7.0	2.0	10.9	2.4
01/31/2022 23:00	10.5	20.5	0.6	3.2	0.7
Average/Sum#:	325.4 #	256.3 #	36.5 #	205.6 #	44.7 #
Minimum:	2.7	1.0	0.4	3.2	0.7
Maximum:	56.3	91.6	2.1	11.5	2.5
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
02/01/2022 00:00	0.0	0.0	0.0	0.0	0.0
02/01/2022 01:00	0.0	0.0	0.0	0.0	0.0
02/01/2022 02:00	0.0	0.0	0.0	0.0	0.0
02/01/2022 03:00	19.0	34.4	0.1	1.2	0.2
02/01/2022 04:00	21.5	21.5	0.4	3.8	0.8
02/01/2022 05:00	31.3	66.4	0.7	5.1	1.0
02/01/2022 06:00	38.9	84.3	1.2	6.7	1.5
02/01/2022 07:00	8.3	4.0	1.7	9.1	2.0
02/01/2022 08:00	16.2	5.4	2.4	12.7	2.8
02/01/2022 09:00	16.2	4.6	2.3	12.7	2.8
02/01/2022 10:00	13.0	3.3	1.8	10.2	2.2
02/01/2022 11:00	9.3	2.4	1.6	8.5	1.8
02/01/2022 12:00	6.5	2.4	1.3	7.2	1.6
02/01/2022 13:00	6.5	2.4	1.3	7.2	1.6
02/01/2022 14:00	6.5	2.4	1.3	7.2	1.6
02/01/2022 15:00	6.6	2.3	1.3	7.2	1.6
02/01/2022 16:00	9.3	2.7	1.6	8.5	1.8
02/01/2022 17:00	10.8	3.0	1.8	9.8	2.2
02/01/2022 18:00	13.5	5.6	2.0	10.6	2.3
02/01/2022 19:00	14.2	5.7	2.0	11.1	2.4
02/01/2022 20:00	15.8	5.9	2.0	10.8	2.4
02/01/2022 21:00	8.0	2.4	1.6	8.7	1.9
02/01/2022 22:00	10.7	3.0	1.8	9.8	2.2
02/01/2022 23:00	16.1	5.4	2.0	11.1	2.4
Average/Sum#:	298.2 #	269.5 #	32.2 #	179.2 #	39.1 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	38.9	84.3	2.4	12.7	2.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
02/02/2022 00:00	15.0	5.3	2.1	11.8	2.6
02/02/2022 01:00	10.4	3.2	1.7	9.5	2.1
02/02/2022 02:00	9.5	3.0	1.6	8.7	1.9
02/02/2022 03:00	16.0	5.7	2.0	11.0	2.4
02/02/2022 04:00	13.8	5.4	2.0	10.8	2.4
02/02/2022 05:00	14.2	6.0	2.0	11.1	2.4
02/02/2022 06:00	14.5	5.8	2.1	11.5	2.5
02/02/2022 07:00	14.3	5.7	2.0	11.3	2.4
02/02/2022 08:00	16.2	5.1	2.0	11.1	2.4
02/02/2022 09:00	9.9	4.2	1.7	9.1	2.0
02/02/2022 10:00	6.5	12.4	0.7	5.0	1.0
02/02/2022 11:00	2.7	0.8	0.4	4.0	0.8
02/02/2022 12:00	2.7	0.8	0.4	4.0	0.8
02/02/2022 13:00	2.7	0.8	0.4	4.1	0.8
02/02/2022 14:00	2.7	0.8	0.4	4.1	0.8
02/02/2022 15:00	5.6	5.5	0.5	5.0	1.0
02/02/2022 16:00	52.9	145.0	1.0	6.6	1.4
02/02/2022 17:00	10.3	3.5	1.7	9.4	2.0
02/02/2022 18:00	14.3	6.3	2.1	11.3	2.4
02/02/2022 19:00	15.6	5.0	2.3	12.3	2.7
02/02/2022 20:00	15.7	4.3	2.3	12.3	2.7
02/02/2022 21:00	15.1	5.0	2.1	11.9	2.6
02/02/2022 22:00	14.5	4.6	2.1	11.3	2.5
02/02/2022 23:00	14.2	5.0	2.0	11.2	2.4
Average/Sum#:	309.3 #	249.2 #	37.6 #	218.4 #	47.0 #
Minimum:	2.7	0.8	0.4	4.0	0.8
Maximum:	52.9	145.0	2.3	12.3	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
02/03/2022 00:00	13.4	5.3	2.0	10.6	2.3
02/03/2022 01:00	10.0	2.5	1.7	9.1	2.0
02/03/2022 02:00	10.8	2.7	1.8	9.8	2.2
02/03/2022 03:00	14.1	5.3	2.0	11.1	2.4
02/03/2022 04:00	16.0	5.3	2.0	11.0	2.4
02/03/2022 05:00	16.0	5.4	2.0	11.1	2.4
02/03/2022 06:00	15.1	5.4	2.1	11.9	2.6
02/03/2022 07:00	14.7	5.0	2.1	11.5	2.5
02/03/2022 08:00	13.6	5.7	2.0	10.6	2.3
02/03/2022 09:00	7.3	3.0	1.4	8.0	1.8
02/03/2022 10:00	10.1	2.8	1.7	9.2	2.0
02/03/2022 11:00	10.1	2.5	1.7	9.2	2.0
02/03/2022 12:00	7.0	2.4	1.4	7.6	1.6
02/03/2022 13:00	9.3	2.7	1.6	8.5	1.8
02/03/2022 14:00	8.9	2.5	1.4	8.1	1.8
02/03/2022 15:00	9.3	2.9	1.6	8.5	1.8
02/03/2022 16:00	13.8	6.5	2.0	10.9	2.4
02/03/2022 17:00	14.5	6.2	2.1	11.3	2.5
02/03/2022 18:00	16.9	5.6	2.1	11.6	2.5
02/03/2022 19:00	16.9	5.6	2.1	11.7	2.6
02/03/2022 20:00	16.9	5.6	2.1	11.7	2.6
02/03/2022 21:00	15.1	5.2	2.2	11.9	2.6
02/03/2022 22:00	14.6	5.6	2.1	11.5	2.5
02/03/2022 23:00	14.4	5.7	2.1	11.4	2.5
Average/Sum#:	308.8 #	107.4 #	45.3 #	247.8 #	54.1 #
Minimum:	7.0	2.4	1.4	7.6	1.6
Maximum:	16.9	6.5	2.2	11.9	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
02/04/2022 00:00	14.2	5.7	2.0	11.2	2.4
02/04/2022 01:00	13.4	6.3	2.0	10.5	2.3
02/04/2022 02:00	8.1	2.7	1.6	8.9	2.0
02/04/2022 03:00	7.8	2.6	1.6	8.5	1.8
02/04/2022 04:00	8.1	3.3	1.6	8.7	1.9
02/04/2022 05:00	14.0	6.6	2.0	11.0	2.4
02/04/2022 06:00	15.1	6.3	2.1	11.9	2.6
02/04/2022 07:00	14.4	5.7	2.1	11.3	2.5
02/04/2022 08:00	11.4	21.4	0.6	3.1	0.6
02/04/2022 09:00	0.0	0.0	0.0	0.0	0.0
02/04/2022 10:00	0.0	0.0	0.0	0.0	0.0
02/04/2022 11:00	3.1	9.3	0.1	0.5	0.1
02/04/2022 12:00	38.1	61.3	0.3	2.5	0.5
02/04/2022 13:00	2.7	0.8	0.4	4.1	0.8
02/04/2022 14:00	2.7	0.8	0.4	4.1	0.8
02/04/2022 15:00	4.5	0.8	0.4	4.5	0.9
02/04/2022 16:00	62.5	187.8	0.9	6.4	1.4
02/04/2022 17:00	24.8	25.8	1.6	8.6	1.8
02/04/2022 18:00	7.4	2.8	1.4	8.1	1.8
02/04/2022 19:00	13.2	5.9	1.9	10.4	2.2
02/04/2022 20:00	15.5	6.3	2.0	10.6	2.3
02/04/2022 21:00	13.4	6.0	2.0	10.6	2.3
02/04/2022 22:00	13.6	6.0	2.0	10.7	2.4
02/04/2022 23:00	14.2	6.0	2.0	11.1	2.4
Average/Sum#:	322.2 #	380.2 #	31.0 #	177.3 #	38.2 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	62.5	187.8	2.1	11.9	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
02/05/2022 00:00	13.5	6.0	2.0	10.6	2.3
02/05/2022 01:00	11.9	3.5	1.7	9.3	2.0
02/05/2022 02:00	7.1	3.3	1.4	7.8	1.7
02/05/2022 03:00	11.4	5.9	1.9	10.4	2.3
02/05/2022 04:00	11.6	6.7	2.0	10.6	2.3
02/05/2022 05:00	10.3	3.2	1.7	9.4	2.0
02/05/2022 06:00	9.7	3.3	1.6	8.9	2.0
02/05/2022 07:00	14.0	6.3	2.0	11.1	2.4
02/05/2022 08:00	11.3	22.8	0.7	3.3	0.7
02/05/2022 09:00	0.0	0.0	0.0	0.0	0.0
02/05/2022 10:00	0.0	0.0	0.0	0.0	0.0
02/05/2022 11:00	0.0	0.0	0.0	0.0	0.0
02/05/2022 12:00	0.0	0.0	0.0	0.0	0.0
02/05/2022 13:00	4.1	8.7	0.1	0.3	0.1
02/05/2022 14:00	46.3	77.7	0.6	2.1	0.5
02/05/2022 15:00	4.1	1.6	1.0	3.4	0.8
02/05/2022 16:00	4.3	1.6	1.0	3.6	0.9
02/05/2022 17:00	30.4	12.1	1.1	4.5	1.1
02/05/2022 18:00	51.7	40.8	1.3	6.1	1.4
02/05/2022 19:00	6.6	2.2	1.3	7.2	1.6
02/05/2022 20:00	9.3	3.2	1.6	8.5	1.8
02/05/2022 21:00	14.0	6.6	2.0	11.1	2.4
02/05/2022 22:00	14.2	6.0	2.0	11.1	2.4
02/05/2022 23:00	14.2	6.0	2.0	11.2	2.4
Average/Sum#:	300.0 #	227.5 #	29.0 #	150.5 #	33.1 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	51.7	77.7	2.0	11.2	2.4
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
02/06/2022 00:00	13.4	6.7	2.0	10.6	2.3
02/06/2022 01:00	10.1	3.2	1.7	9.2	2.0
02/06/2022 02:00	9.7	3.3	1.6	8.9	2.0
02/06/2022 03:00	15.9	6.0	2.0	10.9	2.4
02/06/2022 04:00	11.5	6.0	2.0	10.6	2.3
02/06/2022 05:00	7.9	3.0	1.6	8.6	1.9
02/06/2022 06:00	6.6	3.3	1.3	7.2	1.6
02/06/2022 07:00	7.8	3.0	1.6	8.5	1.8
02/06/2022 08:00	3.2	10.1	0.1	0.5	0.1
02/06/2022 09:00	0.0	0.0	0.0	0.0	0.0
02/06/2022 10:00	0.0	0.0	0.0	0.0	0.0
02/06/2022 11:00	0.0	0.0	0.0	0.0	0.0
02/06/2022 12:00	0.0	0.0	0.0	0.0	0.0
02/06/2022 13:00	0.0	0.0	0.0	0.0	0.0
02/06/2022 14:00	6.7	13.0	0.1	0.4	0.1
02/06/2022 15:00	41.6	75.5	0.6	2.1	0.5
02/06/2022 16:00	4.2	1.6	1.0	3.5	0.8
02/06/2022 17:00	7.5	3.9	1.3	4.7	1.1
02/06/2022 18:00	7.8	4.2	1.4	4.9	1.2
02/06/2022 19:00	7.8	4.3	1.4	4.9	1.2
02/06/2022 20:00	5.8	4.3	1.4	4.9	1.2
02/06/2022 21:00	5.8	4.3	1.4	4.8	1.2
02/06/2022 22:00	6.6	2.2	1.2	4.1	1.0
02/06/2022 23:00	1.2	8.0	0.1	0.2	0.0
Average/Sum#:	181.1 #	165.9 #	23.8 #	109.5 #	24.7 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	41.6	75.5	2.0	10.9	2.4
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
02/07/2022 00:00	0.0	0.0	0.0	0.0	0.0
02/07/2022 01:00	0.0	0.0	0.0	0.0	0.0
02/07/2022 02:00	0.0	0.0	0.0	0.0	0.0
02/07/2022 03:00	0.0	0.0	0.0	0.0	0.0
02/07/2022 04:00	0.0	0.0	0.0	0.0	0.0
02/07/2022 05:00	0.0	0.0	0.0	0.0	0.0
02/07/2022 06:00	0.0	0.0	0.0	0.0	0.0
02/07/2022 07:00	0.0	0.0	0.0	0.0	0.0
02/07/2022 08:00	0.0	0.0	0.0	0.0	0.0
02/07/2022 09:00	0.0	0.0	0.0	0.0	0.0
02/07/2022 10:00	0.0	0.0	0.0	0.0	0.0
02/07/2022 11:00	36.3	44.5	0.1	0.5	0.1
02/07/2022 12:00	14.0	33.9	0.2	0.8	0.2
02/07/2022 13:00	35.8	103.8	0.6	2.0	0.5
02/07/2022 14:00	4.2	1.8	1.0	3.5	0.8
02/07/2022 15:00	4.2	1.8	1.0	3.5	0.8
02/07/2022 16:00	54.2	48.4	1.3	4.8	1.1
02/07/2022 17:00	53.2	59.7	1.3	6.5	1.5
02/07/2022 18:00	7.1	2.7	1.4	7.7	1.7
02/07/2022 19:00	9.4	3.3	1.6	8.6	1.9
02/07/2022 20:00	14.3	6.9	2.1	11.2	2.4
02/07/2022 21:00	14.4	6.3	2.1	11.4	2.5
02/07/2022 22:00	14.4	6.0	2.1	11.3	2.5
02/07/2022 23:00	10.5	21.9	0.6	3.2	0.7
Average/Sum#:	272.0 #	341.0 #	15.4 #	75.0 #	16.7 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	54.2	103.8	2.1	11.4	2.5
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
02/08/2022 00:00	0.0	0.0	0.0	0.0	0.0
02/08/2022 01:00	0.0	0.0	0.0	0.0	0.0
02/08/2022 02:00	0.0	0.0	0.0	0.0	0.0
02/08/2022 03:00	5.5	18.9	0.2	0.6	0.2
02/08/2022 04:00	24.6	55.7	0.9	3.1	0.7
02/08/2022 05:00	16.1	16.6	1.1	4.1	0.9
02/08/2022 06:00	38.1	57.1	1.3	6.1	1.3
02/08/2022 07:00	6.4	2.4	1.3	7.0	1.6
02/08/2022 08:00	12.6	3.0	1.8	9.9	2.2
02/08/2022 09:00	12.8	3.3	1.8	10.0	2.2
02/08/2022 10:00	12.8	3.3	1.8	10.0	2.2
02/08/2022 11:00	12.8	3.0	1.8	10.0	2.2
02/08/2022 12:00	12.8	3.3	1.8	10.0	2.2
02/08/2022 13:00	12.8	3.3	1.8	10.0	2.2
02/08/2022 14:00	12.8	3.3	1.8	10.0	2.2
02/08/2022 15:00	12.6	3.3	1.8	9.9	2.2
02/08/2022 16:00	12.6	3.0	1.8	9.9	2.2
02/08/2022 17:00	11.5	6.3	2.0	10.5	2.3
02/08/2022 18:00	15.9	6.0	2.0	10.9	2.4
02/08/2022 19:00	13.7	6.3	2.0	10.8	2.4
02/08/2022 20:00	13.8	6.7	2.0	10.8	2.4
02/08/2022 21:00	11.9	4.3	1.7	9.3	2.0
02/08/2022 22:00	8.0	9.4	1.1	4.7	1.1
02/08/2022 23:00	4.2	1.6	1.0	3.5	0.8
Average/Sum#:	284.3 #	220.1 #	32.8 #	171.1 #	37.9 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	38.1	57.1	2.0	10.9	2.4
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
02/09/2022 00:00	4.2	1.6	1.0	3.5	0.8
02/09/2022 01:00	4.2	1.6	1.0	3.5	0.8
02/09/2022 02:00	4.2	1.6	1.0	3.5	0.8
02/09/2022 03:00	4.2	1.6	1.0	3.5	0.8
02/09/2022 04:00	4.2	1.8	1.0	3.5	0.8
02/09/2022 05:00	4.2	1.8	1.0	3.5	0.8
02/09/2022 06:00	4.2	2.1	1.0	3.5	0.9
02/09/2022 07:00	7.4	2.0	1.3	4.6	1.1
02/09/2022 08:00	7.4	2.0	1.3	4.6	1.1
02/09/2022 09:00	7.5	2.0	1.3	4.7	1.1
02/09/2022 10:00	7.5	2.0	1.3	4.7	1.1
02/09/2022 11:00	6.6	4.0	1.5	5.5	1.3
02/09/2022 12:00	6.3	3.5	1.5	5.3	1.3
02/09/2022 13:00	5.5	2.0	1.3	4.6	1.1
02/09/2022 14:00	5.5	2.0	1.3	4.6	1.1
02/09/2022 15:00	5.0	1.8	1.2	4.1	1.0
02/09/2022 16:00	80.8	63.4	1.3	5.7	1.3
02/09/2022 17:00	10.2	2.8	1.7	9.3	2.0
02/09/2022 18:00	10.9	3.0	1.8	10.0	2.2
02/09/2022 19:00	14.0	5.7	2.0	11.0	2.4
02/09/2022 20:00	14.4	5.7	2.1	11.4	2.5
02/09/2022 21:00	14.5	4.9	2.1	11.4	2.5
02/09/2022 22:00	14.0	5.0	2.0	11.0	2.4
02/09/2022 23:00	9.1	3.4	1.6	8.4	1.8
Average/Sum#:	256.0 #	127.3 #	33.6 #	145.4 #	33.0 #
Minimum:	4.2	1.6	1.0	3.5	0.8
Maximum:	80.8	63.4	2.1	11.4	2.5
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
02/10/2022 00:00	6.8	2.6	1.4	7.5	1.6
02/10/2022 01:00	9.6	3.0	1.6	8.8	1.9
02/10/2022 02:00	13.7	7.9	2.0	10.8	2.4
02/10/2022 03:00	13.8	7.0	2.0	10.8	2.4
02/10/2022 04:00	8.1	2.7	1.6	8.8	1.9
02/10/2022 05:00	9.6	3.3	1.6	8.7	1.9
02/10/2022 06:00	14.4	6.6	2.1	11.2	2.5
02/10/2022 07:00	14.1	6.2	2.0	11.1	2.4
02/10/2022 08:00	5.0	13.3	0.1	0.8	0.2
02/10/2022 09:00	0.0	0.0	0.0	0.0	0.0
02/10/2022 10:00	0.0	0.0	0.0	0.0	0.0
02/10/2022 11:00	0.1	1.1	0.0	0.1	0.0
02/10/2022 12:00	31.6	82.8	0.6	2.0	0.5
02/10/2022 13:00	4.2	1.3	1.0	3.5	0.8
02/10/2022 14:00	4.2	1.3	1.0	3.5	0.8
02/10/2022 15:00	5.2	2.4	1.2	4.1	1.0
02/10/2022 16:00	76.5	61.9	1.3	6.3	1.5
02/10/2022 17:00	7.9	3.6	1.6	8.6	1.9
02/10/2022 18:00	15.7	5.5	2.3	12.4	2.7
02/10/2022 19:00	15.5	5.2	2.3	12.2	2.7
02/10/2022 20:00	15.0	5.5	2.1	11.8	2.6
02/10/2022 21:00	14.2	6.0	2.1	11.2	2.4
02/10/2022 22:00	14.0	6.5	2.0	11.0	2.4
02/10/2022 23:00	9.1	3.9	1.5	8.3	1.8
Average/Sum#:	308.3 #	239.6 #	33.4 #	173.5 #	38.3 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	76.5	82.8	2.3	12.4	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
02/11/2022 00:00	6.5	3.2	1.3	7.1	1.6
02/11/2022 01:00	2.5	8.0	0.1	0.3	0.0
02/11/2022 02:00	0.0	0.0	0.0	0.0	0.0
02/11/2022 03:00	0.0	0.0	0.0	0.0	0.0
02/11/2022 04:00	0.0	0.0	0.0	0.0	0.0
02/11/2022 05:00	0.0	0.0	0.0	0.0	0.0
02/11/2022 06:00	0.0	0.0	0.0	0.0	0.0
02/11/2022 07:00	0.0	0.0	0.0	0.0	0.0
02/11/2022 08:00	0.0	0.0	0.0	0.0	0.0
02/11/2022 09:00	0.0	0.0	0.0	0.0	0.0
02/11/2022 10:00	0.0	0.0	0.0	0.0	0.0
02/11/2022 11:00	0.0	0.0	0.0	0.0	0.0
02/11/2022 12:00	0.0	0.0	0.0	0.0	0.0
02/11/2022 13:00	0.0	0.0	0.0	0.0	0.0
02/11/2022 14:00	0.0	0.0	0.0	0.0	0.0
02/11/2022 15:00	0.0	0.0	0.0	0.0	0.0
02/11/2022 16:00	0.0	0.0	0.0	0.0	0.0
02/11/2022 17:00	0.0	0.0	0.0	0.0	0.0
02/11/2022 18:00	0.0	0.0	0.0	0.0	0.0
02/11/2022 19:00	0.0	0.0	0.0	0.0	0.0
02/11/2022 20:00	0.0	0.0	0.0	0.0	0.0
02/11/2022 21:00	0.0	0.0	0.0	0.0	0.0
02/11/2022 22:00	0.0	0.0	0.0	0.0	0.0
02/11/2022 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	9.0 #	11.2 #	1.4 #	7.4 #	1.6 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	6.5	8.0	1.3	7.1	1.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
02/12/2022 00:00	0.0	0.0	0.0	0.0	0.0
02/12/2022 01:00	0.0	0.0	0.0	0.0	0.0
02/12/2022 02:00	0.0	0.0	0.0	0.0	0.0
02/12/2022 03:00	0.0	0.0	0.0	0.0	0.0
02/12/2022 04:00	0.0	0.0	0.0	0.0	0.0
02/12/2022 05:00	0.0	0.0	0.0	0.0	0.0
02/12/2022 06:00	0.0	0.0	0.0	0.0	0.0
02/12/2022 07:00	0.0	0.0	0.0	0.0	0.0
02/12/2022 08:00	0.0	0.0	0.0	0.0	0.0
02/12/2022 09:00	0.0	0.0	0.0	0.0	0.0
02/12/2022 10:00	0.0	0.0	0.0	0.0	0.0
02/12/2022 11:00	0.0	0.0	0.0	0.0	0.0
02/12/2022 12:00	0.0	0.0	0.0	0.0	0.0
02/12/2022 13:00	0.0	0.0	0.0	0.0	0.0
02/12/2022 14:00	0.0	0.0	0.0	0.0	0.0
02/12/2022 15:00	0.0	0.0	0.0	0.0	0.0
02/12/2022 16:00	0.0	0.0	0.0	0.0	0.0
02/12/2022 17:00	0.0	0.0	0.0	0.0	0.0
02/12/2022 18:00	0.0	0.0	0.0	0.0	0.0
02/12/2022 19:00	0.0	0.0	0.0	0.0	0.0
02/12/2022 20:00	0.0	0.0	0.0	0.0	0.0
02/12/2022 21:00	0.0	0.0	0.0	0.0	0.0
02/12/2022 22:00	0.0	0.0	0.0	0.0	0.0
02/12/2022 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
02/13/2022 00:00	0.0	0.0	0.0	0.0	0.0
02/13/2022 01:00	0.0	0.0	0.0	0.0	0.0
02/13/2022 02:00	0.0	0.0	0.0	0.0	0.0
02/13/2022 03:00	0.0	0.0	0.0	0.0	0.0
02/13/2022 04:00	0.0	0.0	0.0	0.0	0.0
02/13/2022 05:00	0.0	0.0	0.0	0.0	0.0
02/13/2022 06:00	0.0	0.0	0.0	0.0	0.0
02/13/2022 07:00	0.0	0.0	0.0	0.0	0.0
02/13/2022 08:00	0.0	0.0	0.0	0.0	0.0
02/13/2022 09:00	0.0	0.0	0.0	0.0	0.0
02/13/2022 10:00	0.0	0.0	0.0	0.0	0.0
02/13/2022 11:00	0.0	0.0	0.0	0.0	0.0
02/13/2022 12:00	0.0	0.0	0.0	0.0	0.0
02/13/2022 13:00	0.0	0.0	0.0	0.0	0.0
02/13/2022 14:00	0.0	0.0	0.0	0.0	0.0
02/13/2022 15:00	0.0	0.0	0.0	0.0	0.0
02/13/2022 16:00	0.0	0.0	0.0	0.0	0.0
02/13/2022 17:00	0.0	0.0	0.0	0.0	0.0
02/13/2022 18:00	0.0	0.0	0.0	0.0	0.0
02/13/2022 19:00	0.0	0.0	0.0	0.0	0.0
02/13/2022 20:00	0.0	0.0	0.0	0.0	0.0
02/13/2022 21:00	0.0	0.0	0.0	0.0	0.0
02/13/2022 22:00	0.0	0.0	0.0	0.0	0.0
02/13/2022 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
02/14/2022 00:00	0.0	0.0	0.0	0.0	0.0
02/14/2022 01:00	0.0	0.0	0.0	0.0	0.0
02/14/2022 02:00	0.0	0.0	0.0	0.0	0.0
02/14/2022 03:00	0.0	0.0	0.0	0.0	0.0
02/14/2022 04:00	0.0	0.0	0.0	0.0	0.0
02/14/2022 05:00	0.0	0.0	0.0	0.0	0.0
02/14/2022 06:00	0.0	0.0	0.0	0.0	0.0
02/14/2022 07:00	0.0	0.0	0.0	0.0	0.0
02/14/2022 08:00	0.0	0.0	0.0	0.0	0.0
02/14/2022 09:00	0.0	0.0	0.0	0.0	0.0
02/14/2022 10:00	0.0	0.0	0.0	0.0	0.0
02/14/2022 11:00	0.0	0.0	0.0	0.0	0.0
02/14/2022 12:00	0.0	0.0	0.0	0.0	0.0
02/14/2022 13:00	0.0	0.0	0.0	0.0	0.0
02/14/2022 14:00	0.0	0.0	0.0	0.0	0.0
02/14/2022 15:00	0.0	0.0	0.0	0.0	0.0
02/14/2022 16:00	0.0	0.0	0.0	0.0	0.0
02/14/2022 17:00	0.0	0.0	0.0	0.0	0.0
02/14/2022 18:00	0.0	0.0	0.0	0.0	0.0
02/14/2022 19:00	0.0	0.0	0.0	0.0	0.0
02/14/2022 20:00	0.0	0.0	0.0	0.0	0.0
02/14/2022 21:00	0.0	0.0	0.0	0.0	0.0
02/14/2022 22:00	0.0	0.0	0.0	0.0	0.0
02/14/2022 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
02/15/2022 00:00	0.0	0.0	0.0	0.0	0.0
02/15/2022 01:00	0.0	0.0	0.0	0.0	0.0
02/15/2022 02:00	0.0	0.0	0.0	0.0	0.0
02/15/2022 03:00	0.0	0.0	0.0	0.0	0.0
02/15/2022 04:00	0.0	0.0	0.0	0.0	0.0
02/15/2022 05:00	0.0	0.0	0.0	0.0	0.0
02/15/2022 06:00	0.0	0.0	0.0	0.0	0.0
02/15/2022 07:00	0.0	0.0	0.0	0.0	0.0
02/15/2022 08:00	0.0	0.0	0.0	0.0	0.0
02/15/2022 09:00	0.0	0.0	0.0	0.0	0.0
02/15/2022 10:00	0.0	0.0	0.0	0.0	0.0
02/15/2022 11:00	0.0	0.0	0.0	0.0	0.0
02/15/2022 12:00	0.0	0.0	0.0	0.0	0.0
02/15/2022 13:00	0.0	0.0	0.0	0.0	0.0
02/15/2022 14:00	0.0	0.0	0.0	0.0	0.0
02/15/2022 15:00	0.0	0.0	0.0	0.0	0.0
02/15/2022 16:00	0.0	0.0	0.0	0.0	0.0
02/15/2022 17:00	0.0	0.0	0.0	0.0	0.0
02/15/2022 18:00	0.0	0.0	0.0	0.0	0.0
02/15/2022 19:00	0.0	0.0	0.0	0.0	0.0
02/15/2022 20:00	0.0	0.0	0.0	0.0	0.0
02/15/2022 21:00	0.0	0.0	0.0	0.0	0.0
02/15/2022 22:00	0.0	0.0	0.0	0.0	0.0
02/15/2022 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
02/16/2022 00:00	0.0	0.0	0.0	0.0	0.0
02/16/2022 01:00	0.0	0.0	0.0	0.0	0.0
02/16/2022 02:00	0.0	0.0	0.0	0.0	0.0
02/16/2022 03:00	0.0	0.0	0.0	0.0	0.0
02/16/2022 04:00	0.0	0.0	0.0	0.0	0.0
02/16/2022 05:00	0.0	0.0	0.0	0.0	0.0
02/16/2022 06:00	0.0	0.0	0.0	0.0	0.0
02/16/2022 07:00	0.0	0.0	0.0	0.0	0.0
02/16/2022 08:00	0.0	0.0	0.0	0.0	0.0
02/16/2022 09:00	0.0	0.0	0.0	0.0	0.0
02/16/2022 10:00	0.0	0.0	0.0	0.0	0.0
02/16/2022 11:00	0.0	0.0	0.0	0.0	0.0
02/16/2022 12:00	0.0	0.0	0.0	0.0	0.0
02/16/2022 13:00	0.0	0.0	0.0	0.0	0.0
02/16/2022 14:00	0.0	0.0	0.0	0.0	0.0
02/16/2022 15:00	0.0	0.0	0.0	0.0	0.0
02/16/2022 16:00	0.0	0.0	0.0	0.0	0.0
02/16/2022 17:00	0.0	0.0	0.0	0.0	0.0
02/16/2022 18:00	0.0	0.0	0.0	0.0	0.0
02/16/2022 19:00	0.0	0.0	0.0	0.0	0.0
02/16/2022 20:00	0.0	0.0	0.0	0.0	0.0
02/16/2022 21:00	0.0	0.0	0.0	0.0	0.0
02/16/2022 22:00	0.0	0.0	0.0	0.0	0.0
02/16/2022 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
02/17/2022 00:00	0.0	0.0	0.0	0.0	0.0
02/17/2022 01:00	0.0	0.0	0.0	0.0	0.0
02/17/2022 02:00	0.0	0.0	0.0	0.0	0.0
02/17/2022 03:00	0.0	0.0	0.0	0.0	0.0
02/17/2022 04:00	0.0	0.0	0.0	0.0	0.0
02/17/2022 05:00	0.0	0.0	0.0	0.0	0.0
02/17/2022 06:00	0.0	0.0	0.0	0.0	0.0
02/17/2022 07:00	0.0	0.0	0.0	0.0	0.0
02/17/2022 08:00	0.0	0.0	0.0	0.0	0.0
02/17/2022 09:00	0.0	0.0	0.0	0.0	0.0
02/17/2022 10:00	0.0	0.0	0.0	0.0	0.0
02/17/2022 11:00	0.0	0.0	0.0	0.0	0.0
02/17/2022 12:00	0.0	0.0	0.0	0.0	0.0
02/17/2022 13:00	0.0	0.0	0.0	0.0	0.0
02/17/2022 14:00	0.0	0.0	0.0	0.0	0.0
02/17/2022 15:00	0.0	0.0	0.0	0.0	0.0
02/17/2022 16:00	0.0	0.0	0.0	0.0	0.0
02/17/2022 17:00	0.0	0.0	0.0	0.0	0.0
02/17/2022 18:00	0.0	0.0	0.0	0.0	0.0
02/17/2022 19:00	0.0	0.0	0.0	0.0	0.0
02/17/2022 20:00	0.0	0.0	0.0	0.0	0.0
02/17/2022 21:00	0.0	0.0	0.0	0.0	0.0
02/17/2022 22:00	0.0	0.0	0.0	0.0	0.0
02/17/2022 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
02/18/2022 00:00	0.0	0.0	0.0	0.0	0.0
02/18/2022 01:00	0.0	0.0	0.0	0.0	0.0
02/18/2022 02:00	0.0	0.0	0.0	0.0	0.0
02/18/2022 03:00	0.0	0.0	0.0	0.0	0.0
02/18/2022 04:00	0.0	0.0	0.0	0.0	0.0
02/18/2022 05:00	0.0	0.0	0.0	0.0	0.0
02/18/2022 06:00	0.0	0.0	0.0	0.0	0.0
02/18/2022 07:00	0.0	0.0	0.0	0.0	0.0
02/18/2022 08:00	1.6	18.5	0.0	0.1	0.0
02/18/2022 09:00	83.9	61.4	0.3	0.9	0.2
02/18/2022 10:00	20.1	25.8	0.3	1.0	0.2
02/18/2022 11:00	47.9	140.3	0.5	1.7	0.4
02/18/2022 12:00	53.3	98.7	0.7	2.5	0.6
02/18/2022 13:00	4.2	1.6	1.0	3.5	0.8
02/18/2022 14:00	4.2	1.6	1.0	3.5	0.8
02/18/2022 15:00	84.8	73.3	1.3	5.3	1.3
02/18/2022 16:00	77.5	68.1	1.4	6.6	1.5
02/18/2022 17:00	9.8	2.8	1.7	8.9	2.0
02/18/2022 18:00	9.5	3.3	1.6	8.7	1.9
02/18/2022 19:00	14.0	6.6	2.0	11.0	2.4
02/18/2022 20:00	13.5	7.3	2.0	10.6	2.3
02/18/2022 21:00	9.3	3.0	1.6	8.5	1.8
02/18/2022 22:00	9.5	3.3	1.6	8.7	1.9
02/18/2022 23:00	14.0	6.3	2.0	11.0	2.4
Average/Sum#:	457.1 #	521.9 #	19.0 #	92.5 #	20.5 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	84.8	140.3	2.0	11.0	2.4
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
02/19/2022 00:00	10.6	23.4	0.6	3.2	0.7
02/19/2022 01:00	0.0	0.0	0.0	0.0	0.0
02/19/2022 02:00	0.0	0.0	0.0	0.0	0.0
02/19/2022 03:00	0.0	0.0	0.0	0.0	0.0
02/19/2022 04:00	0.0	0.0	0.0	0.0	0.0
02/19/2022 05:00	0.0	0.0	0.0	0.0	0.0
02/19/2022 06:00	0.0	0.0	0.0	0.0	0.0
02/19/2022 07:00	0.0	0.0	0.0	0.0	0.0
02/19/2022 08:00	0.0	0.0	0.0	0.0	0.0
02/19/2022 09:00	0.0	0.0	0.0	0.0	0.0
02/19/2022 10:00	0.0	0.0	0.0	0.0	0.0
02/19/2022 11:00	0.0	0.0	0.0	0.0	0.0
02/19/2022 12:00	0.0	0.0	0.0	0.0	0.0
02/19/2022 13:00	0.0	0.0	0.0	0.0	0.0
02/19/2022 14:00	0.0	0.0	0.0	0.0	0.0
02/19/2022 15:00	0.0	0.0	0.0	0.0	0.0
02/19/2022 16:00	0.0	0.0	0.0	0.0	0.0
02/19/2022 17:00	0.0	0.0	0.0	0.0	0.0
02/19/2022 18:00	0.0	0.0	0.0	0.0	0.0
02/19/2022 19:00	0.0	0.0	0.0	0.0	0.0
02/19/2022 20:00	0.0	0.0	0.0	0.0	0.0
02/19/2022 21:00	0.0	0.0	0.0	0.0	0.0
02/19/2022 22:00	0.0	0.0	0.0	0.0	0.0
02/19/2022 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	10.6 #	23.4 #	0.6 #	3.2 #	0.7 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	10.6	23.4	0.6	3.2	0.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
02/20/2022 00:00	0.0	0.0	0.0	0.0	0.0
02/20/2022 01:00	0.0	0.0	0.0	0.0	0.0
02/20/2022 02:00	0.0	0.0	0.0	0.0	0.0
02/20/2022 03:00	0.0	0.0	0.0	0.0	0.0
02/20/2022 04:00	0.0	0.0	0.0	0.0	0.0
02/20/2022 05:00	0.0	0.0	0.0	0.0	0.0
02/20/2022 06:00	0.0	0.0	0.0	0.0	0.0
02/20/2022 07:00	0.0	0.0	0.0	0.0	0.0
02/20/2022 08:00	0.0	0.0	0.0	0.0	0.0
02/20/2022 09:00	0.0	0.0	0.0	0.0	0.0
02/20/2022 10:00	0.0	0.0	0.0	0.0	0.0
02/20/2022 11:00	0.0	0.0	0.0	0.0	0.0
02/20/2022 12:00	0.0	0.0	0.0	0.0	0.0
02/20/2022 13:00	0.0	0.0	0.0	0.0	0.0
02/20/2022 14:00	0.0	0.0	0.0	0.0	0.0
02/20/2022 15:00	0.0	0.0	0.0	0.0	0.0
02/20/2022 16:00	0.0	0.0	0.0	0.0	0.0
02/20/2022 17:00	0.0	0.0	0.0	0.0	0.0
02/20/2022 18:00	0.0	0.0	0.0	0.0	0.0
02/20/2022 19:00	0.0	0.0	0.0	0.0	0.0
02/20/2022 20:00	0.0	0.0	0.0	0.0	0.0
02/20/2022 21:00	0.0	0.0	0.0	0.0	0.0
02/20/2022 22:00	0.0	0.0	0.0	0.0	0.0
02/20/2022 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
02/21/2022 00:00	0.0	0.0	0.0	0.0	0.0
02/21/2022 01:00	0.0	0.0	0.0	0.0	0.0
02/21/2022 02:00	0.0	0.0	0.0	0.0	0.0
02/21/2022 03:00	0.0	0.0	0.0	0.0	0.0
02/21/2022 04:00	0.0	0.0	0.0	0.0	0.0
02/21/2022 05:00	0.0	0.0	0.0	0.0	0.0
02/21/2022 06:00	0.0	0.0	0.0	0.0	0.0
02/21/2022 07:00	0.0	0.0	0.0	0.0	0.0
02/21/2022 08:00	0.0	0.0	0.0	0.0	0.0
02/21/2022 09:00	0.0	0.0	0.0	0.0	0.0
02/21/2022 10:00	0.0	0.0	0.0	0.0	0.0
02/21/2022 11:00	0.0	0.0	0.0	0.0	0.0
02/21/2022 12:00	0.0	0.0	0.0	0.0	0.0
02/21/2022 13:00	0.0	0.0	0.0	0.0	0.0
02/21/2022 14:00	0.0	0.0	0.0	0.0	0.0
02/21/2022 15:00	0.0	0.0	0.0	0.0	0.0
02/21/2022 16:00	0.0	0.0	0.0	0.0	0.0
02/21/2022 17:00	0.0	0.0	0.0	0.0	0.0
02/21/2022 18:00	0.0	0.0	0.0	0.0	0.0
02/21/2022 19:00	0.0	0.0	0.0	0.0	0.0
02/21/2022 20:00	0.0	0.0	0.0	0.0	0.0
02/21/2022 21:00	0.0	0.0	0.0	0.0	0.0
02/21/2022 22:00	0.0	0.0	0.0	0.0	0.0
02/21/2022 23:00	49.8	68.3	0.1	0.6	0.1
Average/Sum#:	49.8 #	68.3 #	0.1 #	0.6 #	0.1 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	49.8	68.3	0.1	0.6	0.1
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
02/22/2022 00:00	41.2	30.9	0.3	1.0	0.2
02/22/2022 01:00	35.3	84.0	0.5	1.8	0.4
02/22/2022 02:00	4.4	2.4	1.0	3.6	0.9
02/22/2022 03:00	4.4	2.4	1.0	3.7	0.9
02/22/2022 04:00	37.4	70.5	1.3	4.7	1.1
02/22/2022 05:00	81.8	62.3	1.3	6.5	1.4
02/22/2022 06:00	8.7	3.6	1.7	9.5	2.1
02/22/2022 07:00	7.9	3.6	1.6	8.7	1.9
02/22/2022 08:00	8.2	3.4	1.7	9.0	2.0
02/22/2022 09:00	7.7	3.4	1.6	8.4	1.8
02/22/2022 10:00	9.1	3.1	1.5	8.4	1.8
02/22/2022 11:00	9.1	3.1	1.5	8.4	1.8
02/22/2022 12:00	9.6	3.0	1.6	8.8	1.9
02/22/2022 13:00	9.5	3.3	1.6	8.7	1.9
02/22/2022 14:00	8.1	3.0	1.6	8.8	1.9
02/22/2022 15:00	8.1	3.3	1.7	8.9	2.0
02/22/2022 16:00	8.2	3.4	1.7	8.9	2.0
02/22/2022 17:00	14.3	7.5	2.1	11.2	2.5
02/22/2022 18:00	14.4	6.7	2.1	11.4	2.5
02/22/2022 19:00	15.0	6.4	2.1	11.8	2.6
02/22/2022 20:00	15.9	5.8	2.3	12.4	2.7
02/22/2022 21:00	14.9	6.4	2.1	11.8	2.6
02/22/2022 22:00	14.8	6.4	2.1	11.6	2.5
02/22/2022 23:00	15.2	6.4	2.2	12.0	2.6
Average/Sum#:	403.2 #	334.3 #	38.2 #	200.0 #	44.0 #
Minimum:	4.4	2.4	0.3	1.0	0.2
Maximum:	81.8	84.0	2.3	12.4	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
02/23/2022 00:00	15.7	5.8	2.3	12.4	2.7
02/23/2022 01:00	15.3	6.4	2.2	12.0	2.6
02/23/2022 02:00	15.2	6.4	2.2	12.0	2.6
02/23/2022 03:00	14.4	6.3	2.1	11.2	2.5
02/23/2022 04:00	8.6	2.9	1.7	9.4	2.0
02/23/2022 05:00	11.2	5.9	1.9	10.3	2.2
02/23/2022 06:00	15.3	6.9	2.2	12.1	2.6
02/23/2022 07:00	15.3	6.4	2.2	12.1	2.6
02/23/2022 08:00	10.2	3.4	1.7	9.3	2.0
02/23/2022 09:00	9.3	2.9	1.6	8.5	1.8
02/23/2022 10:00	9.6	3.0	1.6	8.8	1.9
02/23/2022 11:00	8.4	2.8	1.7	9.1	2.0
02/23/2022 12:00	9.2	3.0	1.6	8.4	1.8
02/23/2022 13:00	7.2	2.7	1.4	7.8	1.7
02/23/2022 14:00	9.9	2.8	1.7	9.1	2.0
02/23/2022 15:00	9.7	2.7	1.6	8.9	2.0
02/23/2022 16:00	9.8	3.4	1.7	9.0	2.0
02/23/2022 17:00	14.0	6.8	2.0	11.0	2.4
02/23/2022 18:00	14.3	6.1	2.1	11.2	2.5
02/23/2022 19:00	14.3	5.8	2.1	11.2	2.5
02/23/2022 20:00	15.0	6.1	2.1	11.8	2.6
02/23/2022 21:00	16.0	5.4	2.3	12.6	2.7
02/23/2022 22:00	15.2	6.1	2.2	11.9	2.6
02/23/2022 23:00	14.8	6.2	2.1	11.7	2.6
Average/Sum#:	297.9 #	116.2 #	46.3 #	251.8 #	54.9 #
Minimum:	7.2	2.7	1.4	7.8	1.7
Maximum:	16.0	6.9	2.3	12.6	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
02/24/2022 00:00	15.7	6.1	2.3	12.4	2.7
02/24/2022 01:00	15.7	6.1	2.3	12.4	2.7
02/24/2022 02:00	15.9	6.1	2.3	12.4	2.7
02/24/2022 03:00	16.1	5.4	2.4	12.6	2.7
02/24/2022 04:00	16.1	6.2	2.3	12.6	2.7
02/24/2022 05:00	18.4	6.1	2.4	12.6	2.7
02/24/2022 06:00	16.1	6.1	2.4	12.6	2.7
02/24/2022 07:00	15.5	6.3	2.3	12.2	2.7
02/24/2022 08:00	14.4	6.9	2.1	11.4	2.5
02/24/2022 09:00	13.9	6.5	2.0	11.0	2.4
02/24/2022 10:00	7.9	3.0	1.6	8.7	1.9
02/24/2022 11:00	7.3	3.0	1.4	8.0	1.8
02/24/2022 12:00	6.8	3.1	1.4	7.4	1.6
02/24/2022 13:00	7.1	2.7	1.4	7.6	1.7
02/24/2022 14:00	8.9	2.8	1.5	8.2	1.8
02/24/2022 15:00	8.9	2.8	1.4	8.1	1.8
02/24/2022 16:00	9.5	3.6	1.6	8.7	1.9
02/24/2022 17:00	14.1	6.1	2.0	11.0	2.4
02/24/2022 18:00	15.6	6.1	2.3	12.3	2.7
02/24/2022 19:00	16.0	5.4	2.4	12.5	2.7
02/24/2022 20:00	15.5	5.7	2.2	12.2	2.7
02/24/2022 21:00	15.7	5.4	2.3	12.4	2.7
02/24/2022 22:00	15.6	5.8	2.3	12.4	2.7
02/24/2022 23:00	15.3	6.4	2.2	12.0	2.6
Average/Sum#:	322.0 #	123.7 #	48.8 #	263.7 #	57.5 #
Minimum:	6.8	2.7	1.4	7.4	1.6
Maximum:	18.4	6.9	2.4	12.6	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
02/25/2022 00:00	14.6	6.1	2.1	11.6	2.5
02/25/2022 01:00	14.2	5.8	2.1	11.2	2.4
02/25/2022 02:00	14.2	5.8	2.1	11.2	2.4
02/25/2022 03:00	14.3	5.8	2.1	11.2	2.5
02/25/2022 04:00	14.6	6.1	2.1	11.5	2.5
02/25/2022 05:00	14.3	6.1	2.1	11.2	2.5
02/25/2022 06:00	15.5	6.1	2.2	12.2	2.7
02/25/2022 07:00	14.4	6.2	2.1	11.4	2.5
02/25/2022 08:00	13.7	5.7	2.0	10.8	2.4
02/25/2022 09:00	9.2	2.9	1.6	8.4	1.8
02/25/2022 10:00	9.1	2.6	1.6	8.4	1.8
02/25/2022 11:00	9.8	2.8	1.7	8.9	2.0
02/25/2022 12:00	9.7	2.7	1.6	8.9	2.0
02/25/2022 13:00	9.7	2.8	1.6	8.9	2.0
02/25/2022 14:00	9.6	2.7	1.6	8.8	1.9
02/25/2022 15:00	9.5	2.7	1.6	8.7	1.9
02/25/2022 16:00	10.0	2.8	1.7	9.1	2.0
02/25/2022 17:00	14.1	6.7	2.0	11.1	2.4
02/25/2022 18:00	13.8	6.3	2.0	10.8	2.4
02/25/2022 19:00	13.6	6.1	2.0	10.7	2.4
02/25/2022 20:00	13.9	6.1	2.0	11.0	2.4
02/25/2022 21:00	14.1	6.0	2.0	11.1	2.4
02/25/2022 22:00	14.4	6.1	2.1	11.4	2.5
02/25/2022 23:00	14.4	6.1	2.1	11.4	2.5
Average/Sum#:	304.7 #	119.1 #	46.1 #	249.9 #	54.8 #
Minimum:	9.1	2.6	1.6	8.4	1.8
Maximum:	15.5	6.7	2.2	12.2	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
02/26/2022 00:00	14.6	6.5	2.1	11.5	2.5
02/26/2022 01:00	14.6	6.1	2.1	11.6	2.5
02/26/2022 02:00	13.7	7.1	2.0	10.8	2.4
02/26/2022 03:00	11.8	7.8	2.0	10.8	2.4
02/26/2022 04:00	14.3	5.7	2.1	11.2	2.5
02/26/2022 05:00	14.3	6.2	2.1	11.2	2.5
02/26/2022 06:00	16.3	6.9	2.0	11.2	2.4
02/26/2022 07:00	12.9	22.9	0.6	3.2	0.7
02/26/2022 08:00	0.0	0.0	0.0	0.0	0.0
02/26/2022 09:00	0.0	0.0	0.0	0.0	0.0
02/26/2022 10:00	0.0	0.0	0.0	0.0	0.0
02/26/2022 11:00	0.0	0.0	0.0	0.0	0.0
02/26/2022 12:00	0.0	0.0	0.0	0.0	0.0
02/26/2022 13:00	0.0	0.0	0.0	0.0	0.0
02/26/2022 14:00	0.0	0.0	0.0	0.0	0.0
02/26/2022 15:00	19.0	15.9	0.1	0.3	0.1
02/26/2022 16:00	52.3	107.0	0.6	2.0	0.5
02/26/2022 17:00	6.1	2.0	1.1	3.8	0.9
02/26/2022 18:00	10.0	4.4	1.4	5.0	1.2
02/26/2022 19:00	10.0	4.1	1.4	5.0	1.2
02/26/2022 20:00	10.0	4.1	1.4	5.0	1.2
02/26/2022 21:00	10.6	4.7	1.5	5.3	1.3
02/26/2022 22:00	10.4	4.4	1.5	5.2	1.2
02/26/2022 23:00	7.0	16.0	0.4	1.6	0.4
Average/Sum#:	247.9 #	231.8 #	24.4 #	114.7 #	25.9 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	52.3	107.0	2.1	11.6	2.5
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
02/27/2022 00:00	0.0	0.0	0.0	0.0	0.0
02/27/2022 01:00	0.0	0.0	0.0	0.0	0.0
02/27/2022 02:00	0.0	0.0	0.0	0.0	0.0
02/27/2022 03:00	0.0	0.0	0.0	0.0	0.0
02/27/2022 04:00	0.0	0.0	0.0	0.0	0.0
02/27/2022 05:00	0.0	0.0	0.0	0.0	0.0
02/27/2022 06:00	0.0	0.0	0.0	0.0	0.0
02/27/2022 07:00	0.0	0.0	0.0	0.0	0.0
02/27/2022 08:00	0.0	0.0	0.0	0.0	0.0
02/27/2022 09:00	0.0	0.0	0.0	0.0	0.0
02/27/2022 10:00	0.0	0.0	0.0	0.0	0.0
02/27/2022 11:00	0.0	0.0	0.0	0.0	0.0
02/27/2022 12:00	0.0	0.0	0.0	0.0	0.0
02/27/2022 13:00	0.0	0.0	0.0	0.0	0.0
02/27/2022 14:00	0.0	0.0	0.0	0.0	0.0
02/27/2022 15:00	0.0	0.0	0.0	0.0	0.0
02/27/2022 16:00	0.0	0.0	0.0	0.0	0.0
02/27/2022 17:00	0.0	0.0	0.0	0.0	0.0
02/27/2022 18:00	0.0	0.0	0.0	0.0	0.0
02/27/2022 19:00	0.0	0.0	0.0	0.0	0.0
02/27/2022 20:00	0.0	0.0	0.0	0.0	0.0
02/27/2022 21:00	0.0	0.0	0.0	0.0	0.0
02/27/2022 22:00	0.0	0.0	0.0	0.0	0.0
02/27/2022 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
02/28/2022 00:00	0.0	0.0	0.0	0.0	0.0
02/28/2022 01:00	0.0	0.0	0.0	0.0	0.0
02/28/2022 02:00	0.0	0.0	0.0	0.0	0.0
02/28/2022 03:00	0.0	0.0	0.0	0.0	0.0
02/28/2022 04:00	0.0	0.0	0.0	0.0	0.0
02/28/2022 05:00	0.0	0.0	0.0	0.0	0.0
02/28/2022 06:00	0.0	0.0	0.0	0.0	0.0
02/28/2022 07:00	0.0	0.0	0.0	0.0	0.0
02/28/2022 08:00	0.0	0.0	0.0	0.0	0.0
02/28/2022 09:00	0.0	0.0	0.0	0.0	0.0
02/28/2022 10:00	0.0	0.0	0.0	0.0	0.0
02/28/2022 11:00	0.0	0.0	0.0	0.0	0.0
02/28/2022 12:00	0.0	0.0	0.0	0.0	0.0
02/28/2022 13:00	60.4	63.8	0.2	0.6	0.2
02/28/2022 14:00	26.7	27.2	0.3	1.0	0.2
02/28/2022 15:00	41.5	68.5	0.6	2.1	0.5
02/28/2022 16:00	4.5	1.7	1.0	3.7	0.9
02/28/2022 17:00	5.9	3.7	1.4	4.9	1.2
02/28/2022 18:00	6.4	4.6	1.5	5.3	1.3
02/28/2022 19:00	6.0	3.9	1.4	5.0	1.2
02/28/2022 20:00	6.0	4.0	1.4	5.0	1.2
02/28/2022 21:00	5.9	3.9	1.4	4.9	1.2
02/28/2022 22:00	1.4	9.6	0.1	0.3	0.1
02/28/2022 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	164.7 #	190.9 #	9.3 #	32.8 #	8.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	60.4	68.5	1.5	5.3	1.3
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
03/01/2022 00:00	0.0	0.0	0.0	0.0	0.0
03/01/2022 01:00	0.0	0.0	0.0	0.0	0.0
03/01/2022 02:00	0.0	0.0	0.0	0.0	0.0
03/01/2022 03:00	0.0	0.0	0.0	0.0	0.0
03/01/2022 04:00	0.0	0.0	0.0	0.0	0.0
03/01/2022 05:00	0.0	0.0	0.0	0.0	0.0
03/01/2022 06:00	0.0	0.0	0.0	0.0	0.0
03/01/2022 07:00	0.0	0.0	0.0	0.0	0.0
03/01/2022 08:00	0.0	0.0	0.0	0.0	0.0
03/01/2022 09:00	0.0	0.0	0.0	0.0	0.0
03/01/2022 10:00	0.0	0.0	0.0	0.0	0.0
03/01/2022 11:00	0.0	0.0	0.0	0.0	0.0
03/01/2022 12:00	0.0	0.0	0.0	0.0	0.0
03/01/2022 13:00	0.0	0.0	0.0	0.0	0.0
03/01/2022 14:00	0.0	0.0	0.0	0.0	0.0
03/01/2022 15:00	0.0	0.0	0.0	0.0	0.0
03/01/2022 16:00	0.0	0.0	0.0	0.0	0.0
03/01/2022 17:00	0.0	0.0	0.0	0.0	0.0
03/01/2022 18:00	0.0	0.0	0.0	0.0	0.0
03/01/2022 19:00	0.0	0.0	0.0	0.0	0.0
03/01/2022 20:00	0.0	0.0	0.0	0.0	0.0
03/01/2022 21:00	0.0	0.0	0.0	0.0	0.0
03/01/2022 22:00	0.0	0.0	0.0	0.0	0.0
03/01/2022 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
03/02/2022 00:00	0.0	0.0	0.0	0.0	0.0
03/02/2022 01:00	0.0	0.0	0.0	0.0	0.0
03/02/2022 02:00	0.0	0.0	0.0	0.0	0.0
03/02/2022 03:00	0.0	0.0	0.0	0.0	0.0
03/02/2022 04:00	0.0	0.0	0.0	0.0	0.0
03/02/2022 05:00	0.0	0.0	0.0	0.0	0.0
03/02/2022 06:00	0.0	0.0	0.0	0.0	0.0
03/02/2022 07:00	0.0	0.0	0.0	0.0	0.0
03/02/2022 08:00	0.0	0.0	0.0	0.0	0.0
03/02/2022 09:00	0.0	0.0	0.0	0.0	0.0
03/02/2022 10:00	0.0	0.0	0.0	0.0	0.0
03/02/2022 11:00	0.0	0.0	0.0	0.0	0.0
03/02/2022 12:00	0.0	0.0	0.0	0.0	0.0
03/02/2022 13:00	0.0	0.0	0.0	0.0	0.0
03/02/2022 14:00	0.0	0.0	0.0	0.0	0.0
03/02/2022 15:00	0.0	0.0	0.0	0.0	0.0
03/02/2022 16:00	0.0	0.0	0.0	0.0	0.0
03/02/2022 17:00	0.0	0.0	0.0	0.0	0.0
03/02/2022 18:00	0.0	0.0	0.0	0.0	0.0
03/02/2022 19:00	0.0	0.0	0.0	0.0	0.0
03/02/2022 20:00	0.0	0.0	0.0	0.0	0.0
03/02/2022 21:00	0.0	0.0	0.0	0.0	0.0
03/02/2022 22:00	0.0	0.0	0.0	0.0	0.0
03/02/2022 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
03/03/2022 00:00	0.0	0.0	0.0	0.0	0.0
03/03/2022 01:00	0.0	0.0	0.0	0.0	0.0
03/03/2022 02:00	0.0	0.0	0.0	0.0	0.0
03/03/2022 03:00	0.0	0.0	0.0	0.0	0.0
03/03/2022 04:00	0.0	0.0	0.0	0.0	0.0
03/03/2022 05:00	0.0	0.0	0.0	0.0	0.0
03/03/2022 06:00	0.0	0.0	0.0	0.0	0.0
03/03/2022 07:00	0.0	0.0	0.0	0.0	0.0
03/03/2022 08:00	0.0	0.0	0.0	0.0	0.0
03/03/2022 09:00	0.0	0.0	0.0	0.0	0.0
03/03/2022 10:00	0.0	0.0	0.0	0.0	0.0
03/03/2022 11:00	0.0	0.0	0.0	0.0	0.0
03/03/2022 12:00	0.0	0.0	0.0	0.0	0.0
03/03/2022 13:00	0.0	0.0	0.0	0.0	0.0
03/03/2022 14:00	0.0	0.0	0.0	0.0	0.0
03/03/2022 15:00	0.0	0.0	0.0	0.0	0.0
03/03/2022 16:00	0.0	0.0	0.0	0.0	0.0
03/03/2022 17:00	0.0	0.0	0.0	0.0	0.0
03/03/2022 18:00	0.0	0.0	0.0	0.0	0.0
03/03/2022 19:00	0.0	0.0	0.0	0.0	0.0
03/03/2022 20:00	0.0	0.0	0.0	0.0	0.0
03/03/2022 21:00	0.0	0.0	0.0	0.0	0.0
03/03/2022 22:00	0.0	0.0	0.0	0.0	0.0
03/03/2022 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
03/04/2022 00:00	0.0	0.0	0.0	0.0	0.0
03/04/2022 01:00	0.0	0.0	0.0	0.0	0.0
03/04/2022 02:00	0.0	0.0	0.0	0.0	0.0
03/04/2022 03:00	0.0	0.0	0.0	0.0	0.0
03/04/2022 04:00	0.0	0.0	0.0	0.0	0.0
03/04/2022 05:00	0.0	0.0	0.0	0.0	0.0
03/04/2022 06:00	0.0	0.0	0.0	0.0	0.0
03/04/2022 07:00	0.0	0.0	0.0	0.0	0.0
03/04/2022 08:00	0.0	0.0	0.0	0.0	0.0
03/04/2022 09:00	0.0	0.0	0.0	0.0	0.0
03/04/2022 10:00	0.0	0.0	0.0	0.0	0.0
03/04/2022 11:00	0.0	0.0	0.0	0.0	0.0
03/04/2022 12:00	0.0	0.0	0.0	0.0	0.0
03/04/2022 13:00	0.0	0.0	0.0	0.0	0.0
03/04/2022 14:00	0.0	0.0	0.0	0.0	0.0
03/04/2022 15:00	0.0	0.0	0.0	0.0	0.0
03/04/2022 16:00	0.0	0.0	0.0	0.0	0.0
03/04/2022 17:00	0.0	0.0	0.0	0.0	0.0
03/04/2022 18:00	0.0	0.0	0.0	0.0	0.0
03/04/2022 19:00	0.0	0.0	0.0	0.0	0.0
03/04/2022 20:00	0.0	0.0	0.0	0.0	0.0
03/04/2022 21:00	0.0	0.0	0.0	0.0	0.0
03/04/2022 22:00	0.0	0.0	0.0	0.0	0.0
03/04/2022 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
03/05/2022 00:00	0.0	0.0	0.0	0.0	0.0
03/05/2022 01:00	0.0	0.0	0.0	0.0	0.0
03/05/2022 02:00	0.0	0.0	0.0	0.0	0.0
03/05/2022 03:00	0.0	0.0	0.0	0.0	0.0
03/05/2022 04:00	0.0	0.0	0.0	0.0	0.0
03/05/2022 05:00	0.0	0.0	0.0	0.0	0.0
03/05/2022 06:00	0.0	0.0	0.0	0.0	0.0
03/05/2022 07:00	0.0	0.0	0.0	0.0	0.0
03/05/2022 08:00	0.0	0.0	0.0	0.0	0.0
03/05/2022 09:00	0.0	0.0	0.0	0.0	0.0
03/05/2022 10:00	0.0	0.0	0.0	0.0	0.0
03/05/2022 11:00	0.0	0.0	0.0	0.0	0.0
03/05/2022 12:00	0.0	0.0	0.0	0.0	0.0
03/05/2022 13:00	0.0	0.0	0.0	0.0	0.0
03/05/2022 14:00	0.0	0.0	0.0	0.0	0.0
03/05/2022 15:00	0.0	0.0	0.0	0.0	0.0
03/05/2022 16:00	0.0	0.0	0.0	0.0	0.0
03/05/2022 17:00	0.0	0.0	0.0	0.0	0.0
03/05/2022 18:00	0.0	0.0	0.0	0.0	0.0
03/05/2022 19:00	0.0	0.0	0.0	0.0	0.0
03/05/2022 20:00	0.0	0.0	0.0	0.0	0.0
03/05/2022 21:00	0.0	0.0	0.0	0.0	0.0
03/05/2022 22:00	0.0	0.0	0.0	0.0	0.0
03/05/2022 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
03/06/2022 00:00	0.0	0.0	0.0	0.0	0.0
03/06/2022 01:00	0.0	0.0	0.0	0.0	0.0
03/06/2022 02:00	0.0	0.0	0.0	0.0	0.0
03/06/2022 03:00	0.0	0.0	0.0	0.0	0.0
03/06/2022 04:00	0.0	0.0	0.0	0.0	0.0
03/06/2022 05:00	0.0	0.0	0.0	0.0	0.0
03/06/2022 06:00	0.0	0.0	0.0	0.0	0.0
03/06/2022 07:00	0.0	0.0	0.0	0.0	0.0
03/06/2022 08:00	0.0	0.0	0.0	0.0	0.0
03/06/2022 09:00	0.0	0.0	0.0	0.0	0.0
03/06/2022 10:00	0.0	0.0	0.0	0.0	0.0
03/06/2022 11:00	0.0	0.0	0.0	0.0	0.0
03/06/2022 12:00	0.0	0.0	0.0	0.0	0.0
03/06/2022 13:00	0.0	0.0	0.0	0.0	0.0
03/06/2022 14:00	0.0	0.0	0.0	0.0	0.0
03/06/2022 15:00	0.0	0.0	0.0	0.0	0.0
03/06/2022 16:00	0.0	0.0	0.0	0.0	0.0
03/06/2022 17:00	0.0	0.0	0.0	0.0	0.0
03/06/2022 18:00	0.0	0.0	0.0	0.0	0.0
03/06/2022 19:00	0.0	0.0	0.0	0.0	0.0
03/06/2022 20:00	0.0	0.0	0.0	0.0	0.0
03/06/2022 21:00	0.0	0.0	0.0	0.0	0.0
03/06/2022 22:00	0.0	0.0	0.0	0.0	0.0
03/06/2022 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
03/07/2022 00:00	0.0	0.0	0.0	0.0	0.0
03/07/2022 01:00	0.0	0.0	0.0	0.0	0.0
03/07/2022 02:00	0.0	0.0	0.0	0.0	0.0
03/07/2022 03:00	0.0	0.0	0.0	0.0	0.0
03/07/2022 04:00	0.0	0.0	0.0	0.0	0.0
03/07/2022 05:00	0.0	0.0	0.0	0.0	0.0
03/07/2022 06:00	0.0	0.0	0.0	0.0	0.0
03/07/2022 07:00	0.0	0.0	0.0	0.0	0.0
03/07/2022 08:00	0.0	0.0	0.0	0.0	0.0
03/07/2022 09:00	0.0	0.0	0.0	0.0	0.0
03/07/2022 10:00	0.0	0.0	0.0	0.0	0.0
03/07/2022 11:00	0.0	0.0	0.0	0.0	0.0
03/07/2022 12:00	0.0	0.0	0.0	0.0	0.0
03/07/2022 13:00	0.0	0.0	0.0	0.0	0.0
03/07/2022 14:00	0.0	0.0	0.0	0.0	0.0
03/07/2022 15:00	0.0	0.0	0.0	0.0	0.0
03/07/2022 16:00	0.0	0.0	0.0	0.0	0.0
03/07/2022 17:00	0.0	0.0	0.0	0.0	0.0
03/07/2022 18:00	0.0	0.0	0.0	0.0	0.0
03/07/2022 19:00	0.0	0.0	0.0	0.0	0.0
03/07/2022 20:00	0.0	0.0	0.0	0.0	0.0
03/07/2022 21:00	0.0	0.0	0.0	0.0	0.0
03/07/2022 22:00	0.0	0.0	0.0	0.0	0.0
03/07/2022 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
03/08/2022 00:00	0.0	0.0	0.0	0.0	0.0
03/08/2022 01:00	0.0	0.0	0.0	0.0	0.0
03/08/2022 02:00	0.0	0.0	0.0	0.0	0.0
03/08/2022 03:00	0.0	0.0	0.0	0.0	0.0
03/08/2022 04:00	0.0	0.0	0.0	0.0	0.0
03/08/2022 05:00	0.0	0.0	0.0	0.0	0.0
03/08/2022 06:00	0.0	0.0	0.0	0.0	0.0
03/08/2022 07:00	0.0	0.0	0.0	0.0	0.0
03/08/2022 08:00	0.0	0.0	0.0	0.0	0.0
03/08/2022 09:00	0.0	0.0	0.0	0.0	0.0
03/08/2022 10:00	0.0	0.0	0.0	0.0	0.0
03/08/2022 11:00	0.0	0.0	0.0	0.0	0.0
03/08/2022 12:00	0.0	0.0	0.0	0.0	0.0
03/08/2022 13:00	0.0	0.0	0.0	0.0	0.0
03/08/2022 14:00	0.0	0.0	0.0	0.0	0.0
03/08/2022 15:00	0.0	0.0	0.0	0.0	0.0
03/08/2022 16:00	0.0	0.0	0.0	0.0	0.0
03/08/2022 17:00	0.0	0.0	0.0	0.0	0.0
03/08/2022 18:00	0.0	0.0	0.0	0.0	0.0
03/08/2022 19:00	0.0	0.0	0.0	0.0	0.0
03/08/2022 20:00	0.0	0.0	0.0	0.0	0.0
03/08/2022 21:00	0.0	0.0	0.0	0.0	0.0
03/08/2022 22:00	0.0	0.0	0.0	0.0	0.0
03/08/2022 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
03/09/2022 00:00	0.0	0.0	0.0	0.0	0.0
03/09/2022 01:00	0.0	0.0	0.0	0.0	0.0
03/09/2022 02:00	0.0	0.0	0.0	0.0	0.0
03/09/2022 03:00	0.0	0.0	0.0	0.0	0.0
03/09/2022 04:00	0.0	0.0	0.0	0.0	0.0
03/09/2022 05:00	0.0	0.0	0.0	0.0	0.0
03/09/2022 06:00	0.0	0.0	0.0	0.0	0.0
03/09/2022 07:00	0.0	0.0	0.0	0.0	0.0
03/09/2022 08:00	0.0	0.0	0.0	0.0	0.0
03/09/2022 09:00	0.0	0.0	0.0	0.0	0.0
03/09/2022 10:00	0.0	0.0	0.0	0.0	0.0
03/09/2022 11:00	0.0	0.0	0.0	0.0	0.0
03/09/2022 12:00	0.0	0.0	0.0	0.0	0.0
03/09/2022 13:00	0.0	0.0	0.0	0.0	0.0
03/09/2022 14:00	0.0	0.0	0.0	0.0	0.0
03/09/2022 15:00	0.0	0.0	0.0	0.0	0.0
03/09/2022 16:00	0.0	0.0	0.0	0.0	0.0
03/09/2022 17:00	0.0	0.0	0.0	0.0	0.0
03/09/2022 18:00	0.0	0.0	0.0	0.0	0.0
03/09/2022 19:00	0.0	0.0	0.0	0.0	0.0
03/09/2022 20:00	0.0	0.0	0.0	0.0	0.0
03/09/2022 21:00	0.0	0.0	0.0	0.0	0.0
03/09/2022 22:00	0.0	0.0	0.0	0.0	0.0
03/09/2022 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
03/10/2022 00:00	0.0	0.0	0.0	0.0	0.0
03/10/2022 01:00	0.0	0.0	0.0	0.0	0.0
03/10/2022 02:00	0.0	0.0	0.0	0.0	0.0
03/10/2022 03:00	0.0	0.0	0.0	0.0	0.0
03/10/2022 04:00	0.0	0.0	0.0	0.0	0.0
03/10/2022 05:00	0.0	0.0	0.0	0.0	0.0
03/10/2022 06:00	0.0	0.0	0.0	0.0	0.0
03/10/2022 07:00	0.0	0.0	0.0	0.0	0.0
03/10/2022 08:00	0.0	0.0	0.0	0.0	0.0
03/10/2022 09:00	0.0	0.0	0.0	0.0	0.0
03/10/2022 10:00	0.0	0.0	0.0	0.0	0.0
03/10/2022 11:00	0.0	0.0	0.0	0.0	0.0
03/10/2022 12:00	0.0	0.0	0.0	0.0	0.0
03/10/2022 13:00	0.0	0.0	0.0	0.0	0.0
03/10/2022 14:00	0.0	0.0	0.0	0.0	0.0
03/10/2022 15:00	0.0	0.0	0.0	0.0	0.0
03/10/2022 16:00	0.0	0.0	0.0	0.0	0.0
03/10/2022 17:00	0.0	0.0	0.0	0.0	0.0
03/10/2022 18:00	0.0	0.0	0.0	0.0	0.0
03/10/2022 19:00	0.0	0.0	0.0	0.0	0.0
03/10/2022 20:00	0.0	0.0	0.0	0.0	0.0
03/10/2022 21:00	0.0	0.0	0.0	0.0	0.0
03/10/2022 22:00	0.0	0.0	0.0	0.0	0.0
03/10/2022 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
03/11/2022 00:00	0.0	0.0	0.0	0.0	0.0
03/11/2022 01:00	0.0	0.0	0.0	0.0	0.0
03/11/2022 02:00	0.0	0.0	0.0	0.0	0.0
03/11/2022 03:00	0.0	0.0	0.0	0.0	0.0
03/11/2022 04:00	0.0	0.0	0.0	0.0	0.0
03/11/2022 05:00	0.0	0.0	0.0	0.0	0.0
03/11/2022 06:00	0.0	0.0	0.0	0.0	0.0
03/11/2022 07:00	0.0	0.0	0.0	0.0	0.0
03/11/2022 08:00	0.0	0.0	0.0	0.0	0.0
03/11/2022 09:00	0.0	0.0	0.0	0.0	0.0
03/11/2022 10:00	0.0	0.0	0.0	0.0	0.0
03/11/2022 11:00	0.0	0.0	0.0	0.0	0.0
03/11/2022 12:00	0.0	0.0	0.0	0.0	0.0
03/11/2022 13:00	0.0	0.0	0.0	0.0	0.0
03/11/2022 14:00	0.0	0.0	0.0	0.0	0.0
03/11/2022 15:00	0.0	0.0	0.0	0.0	0.0
03/11/2022 16:00	0.0	0.0	0.0	0.0	0.0
03/11/2022 17:00	0.0	0.0	0.0	0.0	0.0
03/11/2022 18:00	0.0	0.0	0.0	0.0	0.0
03/11/2022 19:00	0.0	0.0	0.0	0.0	0.0
03/11/2022 20:00	0.0	0.0	0.0	0.0	0.0
03/11/2022 21:00	0.0	0.0	0.0	0.0	0.0
03/11/2022 22:00	0.0	0.0	0.0	0.0	0.0
03/11/2022 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
03/12/2022 00:00	0.0	0.0	0.0	0.0	0.0
03/12/2022 01:00	0.0	0.0	0.0	0.0	0.0
03/12/2022 02:00	0.0	0.0	0.0	0.0	0.0
03/12/2022 03:00	0.0	0.0	0.0	0.0	0.0
03/12/2022 04:00	0.0	0.0	0.0	0.0	0.0
03/12/2022 05:00	0.0	0.0	0.0	0.0	0.0
03/12/2022 06:00	0.0	0.0	0.0	0.0	0.0
03/12/2022 07:00	0.0	0.0	0.0	0.0	0.0
03/12/2022 08:00	0.0	0.0	0.0	0.0	0.0
03/12/2022 09:00	0.0	0.0	0.0	0.0	0.0
03/12/2022 10:00	0.0	0.0	0.0	0.0	0.0
03/12/2022 11:00	0.0	0.0	0.0	0.0	0.0
03/12/2022 12:00	0.0	0.0	0.0	0.0	0.0
03/12/2022 13:00	0.0	0.0	0.0	0.0	0.0
03/12/2022 14:00	0.0	0.0	0.0	0.0	0.0
03/12/2022 15:00	0.0	0.0	0.0	0.0	0.0
03/12/2022 16:00	0.0	0.0	0.0	0.0	0.0
03/12/2022 17:00	0.0	0.0	0.0	0.0	0.0
03/12/2022 18:00	0.0	0.0	0.0	0.0	0.0
03/12/2022 19:00	0.0	0.0	0.0	0.0	0.0
03/12/2022 20:00	0.0	0.0	0.0	0.0	0.0
03/12/2022 21:00	0.0	0.0	0.0	0.0	0.0
03/12/2022 22:00	0.0	0.0	0.0	0.0	0.0
03/12/2022 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
03/13/2022 00:00	0.0	0.0	0.0	0.0	0.0
03/13/2022 01:00	0.0	0.0	0.0	0.0	0.0
03/13/2022 02:00	0.0	0.0	0.0	0.0	0.0
03/13/2022 03:00	0.0	0.0	0.0	0.0	0.0
03/13/2022 04:00	0.0	0.0	0.0	0.0	0.0
03/13/2022 05:00	0.0	0.0	0.0	0.0	0.0
03/13/2022 06:00	0.0	0.0	0.0	0.0	0.0
03/13/2022 07:00	0.0	0.0	0.0	0.0	0.0
03/13/2022 08:00	0.0	0.0	0.0	0.0	0.0
03/13/2022 09:00	0.0	0.0	0.0	0.0	0.0
03/13/2022 10:00	0.0	0.0	0.0	0.0	0.0
03/13/2022 11:00	0.0	0.0	0.0	0.0	0.0
03/13/2022 12:00	0.0	0.0	0.0	0.0	0.0
03/13/2022 13:00	0.0	0.0	0.0	0.0	0.0
03/13/2022 14:00	0.0	0.0	0.0	0.0	0.0
03/13/2022 15:00	0.0	0.0	0.0	0.0	0.0
03/13/2022 16:00	0.0	0.0	0.0	0.0	0.0
03/13/2022 17:00	0.0	0.0	0.0	0.0	0.0
03/13/2022 18:00	0.0	0.0	0.0	0.0	0.0
03/13/2022 19:00	0.0	0.0	0.0	0.0	0.0
03/13/2022 20:00	0.0	0.0	0.0	0.0	0.0
03/13/2022 21:00	0.0	0.0	0.0	0.0	0.0
03/13/2022 22:00	0.0	0.0	0.0	0.0	0.0
03/13/2022 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
03/14/2022 00:00	0.0	0.0	0.0	0.0	0.0
03/14/2022 01:00	0.0	0.0	0.0	0.0	0.0
03/14/2022 02:00	0.0	0.0	0.0	0.0	0.0
03/14/2022 03:00	0.0	0.0	0.0	0.0	0.0
03/14/2022 04:00	0.0	0.0	0.0	0.0	0.0
03/14/2022 05:00	0.0	0.0	0.0	0.0	0.0
03/14/2022 06:00	0.0	0.0	0.0	0.0	0.0
03/14/2022 07:00	0.0	0.0	0.0	0.0	0.0
03/14/2022 08:00	0.0	0.0	0.0	0.0	0.0
03/14/2022 09:00	0.0	0.0	0.0	0.0	0.0
03/14/2022 10:00	0.0	0.0	0.0	0.0	0.0
03/14/2022 11:00	0.0	0.0	0.0	0.0	0.0
03/14/2022 12:00	0.0	0.0	0.0	0.0	0.0
03/14/2022 13:00	0.0	0.0	0.0	0.0	0.0
03/14/2022 14:00	0.0	0.0	0.0	0.0	0.0
03/14/2022 15:00	0.0	0.0	0.0	0.0	0.0
03/14/2022 16:00	0.0	0.0	0.0	0.0	0.0
03/14/2022 17:00	0.0	0.0	0.0	0.0	0.0
03/14/2022 18:00	0.0	0.0	0.0	0.0	0.0
03/14/2022 19:00	0.0	0.0	0.0	0.0	0.0
03/14/2022 20:00	0.0	0.0	0.0	0.0	0.0
03/14/2022 21:00	0.0	0.0	0.0	0.0	0.0
03/14/2022 22:00	0.0	0.0	0.0	0.0	0.0
03/14/2022 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
03/15/2022 00:00	0.0	0.0	0.0	0.0	0.0
03/15/2022 01:00	0.0	0.0	0.0	0.0	0.0
03/15/2022 02:00	0.0	0.0	0.0	0.0	0.0
03/15/2022 03:00	0.0	0.0	0.0	0.0	0.0
03/15/2022 04:00	0.0	0.0	0.0	0.0	0.0
03/15/2022 05:00	0.0	0.0	0.0	0.0	0.0
03/15/2022 06:00	0.0	0.0	0.0	0.0	0.0
03/15/2022 07:00	0.0	0.0	0.0	0.0	0.0
03/15/2022 08:00	0.0	0.0	0.0	0.0	0.0
03/15/2022 09:00	0.0	0.0	0.0	0.0	0.0
03/15/2022 10:00	0.0	0.0	0.0	0.0	0.0
03/15/2022 11:00	0.0	0.0	0.0	0.0	0.0
03/15/2022 12:00	0.0	0.0	0.0	0.0	0.0
03/15/2022 13:00	0.0	0.0	0.0	0.0	0.0
03/15/2022 14:00	0.0	0.0	0.0	0.0	0.0
03/15/2022 15:00	0.0	0.0	0.0	0.0	0.0
03/15/2022 16:00	0.0	0.0	0.0	0.0	0.0
03/15/2022 17:00	0.0	0.0	0.0	0.0	0.0
03/15/2022 18:00	0.0	0.0	0.0	0.0	0.0
03/15/2022 19:00	0.0	0.0	0.0	0.0	0.0
03/15/2022 20:00	0.0	0.0	0.0	0.0	0.0
03/15/2022 21:00	0.0	0.0	0.0	0.0	0.0
03/15/2022 22:00	0.0	0.0	0.0	0.0	0.0
03/15/2022 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
03/16/2022 00:00	0.0	0.0	0.0	0.0	0.0
03/16/2022 01:00	0.0	0.0	0.0	0.0	0.0
03/16/2022 02:00	0.0	0.0	0.0	0.0	0.0
03/16/2022 03:00	0.0	0.0	0.0	0.0	0.0
03/16/2022 04:00	0.0	0.0	0.0	0.0	0.0
03/16/2022 05:00	0.0	0.0	0.0	0.0	0.0
03/16/2022 06:00	0.0	0.0	0.0	0.0	0.0
03/16/2022 07:00	0.0	0.0	0.0	0.0	0.0
03/16/2022 08:00	0.0	0.0	0.0	0.0	0.0
03/16/2022 09:00	0.0	0.0	0.0	0.0	0.0
03/16/2022 10:00	0.0	0.0	0.0	0.0	0.0
03/16/2022 11:00	0.0	0.0	0.0	0.0	0.0
03/16/2022 12:00	0.0	0.0	0.0	0.0	0.0
03/16/2022 13:00	0.0	0.0	0.0	0.0	0.0
03/16/2022 14:00	0.0	0.0	0.0	0.0	0.0
03/16/2022 15:00	0.0	0.0	0.0	0.0	0.0
03/16/2022 16:00	0.0	0.0	0.0	0.0	0.0
03/16/2022 17:00	0.0	0.0	0.0	0.0	0.0
03/16/2022 18:00	0.0	0.0	0.0	0.0	0.0
03/16/2022 19:00	0.0	0.0	0.0	0.0	0.0
03/16/2022 20:00	0.0	0.0	0.0	0.0	0.0
03/16/2022 21:00	0.0	0.0	0.0	0.0	0.0
03/16/2022 22:00	0.0	0.0	0.0	0.0	0.0
03/16/2022 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
03/17/2022 00:00	0.0	0.0	0.0	0.0	0.0
03/17/2022 01:00	0.0	0.0	0.0	0.0	0.0
03/17/2022 02:00	0.0	0.0	0.0	0.0	0.0
03/17/2022 03:00	0.0	0.0	0.0	0.0	0.0
03/17/2022 04:00	0.0	0.0	0.0	0.0	0.0
03/17/2022 05:00	0.0	0.0	0.0	0.0	0.0
03/17/2022 06:00	0.0	0.0	0.0	0.0	0.0
03/17/2022 07:00	0.0	0.0	0.0	0.0	0.0
03/17/2022 08:00	0.0	0.0	0.0	0.0	0.0
03/17/2022 09:00	0.0	0.0	0.0	0.0	0.0
03/17/2022 10:00	0.0	0.0	0.0	0.0	0.0
03/17/2022 11:00	0.0	0.0	0.0	0.0	0.0
03/17/2022 12:00	0.0	0.0	0.0	0.0	0.0
03/17/2022 13:00	0.0	0.0	0.0	0.0	0.0
03/17/2022 14:00	0.0	0.0	0.0	0.0	0.0
03/17/2022 15:00	0.0	0.0	0.0	0.0	0.0
03/17/2022 16:00	0.0	0.0	0.0	0.0	0.0
03/17/2022 17:00	0.0	0.0	0.0	0.0	0.0
03/17/2022 18:00	0.0	0.0	0.0	0.0	0.0
03/17/2022 19:00	0.0	0.0	0.0	0.0	0.0
03/17/2022 20:00	0.0	0.0	0.0	0.0	0.0
03/17/2022 21:00	0.0	0.0	0.0	0.0	0.0
03/17/2022 22:00	0.0	0.0	0.0	0.0	0.0
03/17/2022 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
03/18/2022 00:00	0.0	0.0	0.0	0.0	0.0
03/18/2022 01:00	0.0	0.0	0.0	0.0	0.0
03/18/2022 02:00	0.0	0.0	0.0	0.0	0.0
03/18/2022 03:00	0.0	0.0	0.0	0.0	0.0
03/18/2022 04:00	0.0	0.0	0.0	0.0	0.0
03/18/2022 05:00	0.0	0.0	0.0	0.0	0.0
03/18/2022 06:00	0.0	0.0	0.0	0.0	0.0
03/18/2022 07:00	0.0	0.0	0.0	0.0	0.0
03/18/2022 08:00	0.0	0.0	0.0	0.0	0.0
03/18/2022 09:00	0.0	0.0	0.0	0.0	0.0
03/18/2022 10:00	0.0	0.0	0.0	0.0	0.0
03/18/2022 11:00	0.0	0.0	0.0	0.0	0.0
03/18/2022 12:00	0.0	0.0	0.0	0.0	0.0
03/18/2022 13:00	0.0	0.0	0.0	0.0	0.0
03/18/2022 14:00	0.0	0.0	0.0	0.0	0.0
03/18/2022 15:00	0.0	0.0	0.0	0.0	0.0
03/18/2022 16:00	0.0	0.0	0.0	0.0	0.0
03/18/2022 17:00	0.0	0.0	0.0	0.0	0.0
03/18/2022 18:00	0.0	0.0	0.0	0.0	0.0
03/18/2022 19:00	0.0	0.0	0.0	0.0	0.0
03/18/2022 20:00	0.0	0.0	0.0	0.0	0.0
03/18/2022 21:00	0.0	0.0	0.0	0.0	0.0
03/18/2022 22:00	0.0	0.0	0.0	0.0	0.0
03/18/2022 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
03/19/2022 00:00	0.0	0.0	0.0	0.0	0.0
03/19/2022 01:00	0.0	0.0	0.0	0.0	0.0
03/19/2022 02:00	0.0	0.0	0.0	0.0	0.0
03/19/2022 03:00	0.0	0.0	0.0	0.0	0.0
03/19/2022 04:00	0.0	0.0	0.0	0.0	0.0
03/19/2022 05:00	0.0	0.0	0.0	0.0	0.0
03/19/2022 06:00	0.0	0.0	0.0	0.0	0.0
03/19/2022 07:00	0.0	0.0	0.0	0.0	0.0
03/19/2022 08:00	0.0	0.0	0.0	0.0	0.0
03/19/2022 09:00	0.0	0.0	0.0	0.0	0.0
03/19/2022 10:00	0.0	0.0	0.0	0.0	0.0
03/19/2022 11:00	0.0	0.0	0.0	0.0	0.0
03/19/2022 12:00	0.0	0.0	0.0	0.0	0.0
03/19/2022 13:00	0.0	0.0	0.0	0.0	0.0
03/19/2022 14:00	0.0	0.0	0.0	0.0	0.0
03/19/2022 15:00	0.0	0.0	0.0	0.0	0.0
03/19/2022 16:00	0.0	0.0	0.0	0.0	0.0
03/19/2022 17:00	0.0	0.0	0.0	0.0	0.0
03/19/2022 18:00	0.0	0.0	0.0	0.0	0.0
03/19/2022 19:00	0.0	0.0	0.0	0.0	0.0
03/19/2022 20:00	0.0	0.0	0.0	0.0	0.0
03/19/2022 21:00	0.0	0.0	0.0	0.0	0.0
03/19/2022 22:00	0.0	0.0	0.0	0.0	0.0
03/19/2022 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
03/20/2022 00:00	0.0	0.0	0.0	0.0	0.0
03/20/2022 01:00	0.0	0.0	0.0	0.0	0.0
03/20/2022 02:00	0.0	0.0	0.0	0.0	0.0
03/20/2022 03:00	0.0	0.0	0.0	0.0	0.0
03/20/2022 04:00	0.0	0.0	0.0	0.0	0.0
03/20/2022 05:00	0.0	0.0	0.0	0.0	0.0
03/20/2022 06:00	0.0	0.0	0.0	0.0	0.0
03/20/2022 07:00	0.0	0.0	0.0	0.0	0.0
03/20/2022 08:00	0.0	0.0	0.0	0.0	0.0
03/20/2022 09:00	0.0	0.0	0.0	0.0	0.0
03/20/2022 10:00	0.0	0.0	0.0	0.0	0.0
03/20/2022 11:00	0.0	0.0	0.0	0.0	0.0
03/20/2022 12:00	0.0	0.0	0.0	0.0	0.0
03/20/2022 13:00	0.0	0.0	0.0	0.0	0.0
03/20/2022 14:00	0.0	0.0	0.0	0.0	0.0
03/20/2022 15:00	0.0	0.0	0.0	0.0	0.0
03/20/2022 16:00	0.0	0.0	0.0	0.0	0.0
03/20/2022 17:00	0.0	0.0	0.0	0.0	0.0
03/20/2022 18:00	0.0	0.0	0.0	0.0	0.0
03/20/2022 19:00	0.0	0.0	0.0	0.0	0.0
03/20/2022 20:00	0.0	0.0	0.0	0.0	0.0
03/20/2022 21:00	0.0	0.0	0.0	0.0	0.0
03/20/2022 22:00	0.0	0.0	0.0	0.0	0.0
03/20/2022 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
03/21/2022 00:00	0.0	0.0	0.0	0.0	0.0
03/21/2022 01:00	0.0	0.0	0.0	0.0	0.0
03/21/2022 02:00	0.0	0.0	0.0	0.0	0.0
03/21/2022 03:00	0.0	0.0	0.0	0.0	0.0
03/21/2022 04:00	0.0	0.0	0.0	0.0	0.0
03/21/2022 05:00	0.0	0.0	0.0	0.0	0.0
03/21/2022 06:00	0.0	0.0	0.0	0.0	0.0
03/21/2022 07:00	0.0	0.0	0.0	0.0	0.0
03/21/2022 08:00	0.0	0.0	0.0	0.0	0.0
03/21/2022 09:00	0.0	0.0	0.0	0.0	0.0
03/21/2022 10:00	0.0	0.0	0.0	0.0	0.0
03/21/2022 11:00	0.0	0.0	0.0	0.0	0.0
03/21/2022 12:00	0.0	0.0	0.0	0.0	0.0
03/21/2022 13:00	0.0	0.0	0.0	0.0	0.0
03/21/2022 14:00	0.0	0.0	0.0	0.0	0.0
03/21/2022 15:00	0.0	0.0	0.0	0.0	0.0
03/21/2022 16:00	0.0	0.0	0.0	0.0	0.0
03/21/2022 17:00	0.0	0.0	0.0	0.0	0.0
03/21/2022 18:00	0.0	0.0	0.0	0.0	0.0
03/21/2022 19:00	0.0	0.0	0.0	0.0	0.0
03/21/2022 20:00	0.0	0.0	0.0	0.0	0.0
03/21/2022 21:00	0.0	0.0	0.0	0.0	0.0
03/21/2022 22:00	0.0	0.0	0.0	0.0	0.0
03/21/2022 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
03/22/2022 00:00	0.0	0.0	0.0	0.0	0.0
03/22/2022 01:00	0.0	0.0	0.0	0.0	0.0
03/22/2022 02:00	0.0	0.0	0.0	0.0	0.0
03/22/2022 03:00	0.0	0.0	0.0	0.0	0.0
03/22/2022 04:00	0.0	0.0	0.0	0.0	0.0
03/22/2022 05:00	0.0	0.0	0.0	0.0	0.0
03/22/2022 06:00	0.0	0.0	0.0	0.0	0.0
03/22/2022 07:00	0.0	0.0	0.0	0.0	0.0
03/22/2022 08:00	0.0	0.0	0.0	0.0	0.0
03/22/2022 09:00	0.0	0.0	0.0	0.0	0.0
03/22/2022 10:00	0.0	0.0	0.0	0.0	0.0
03/22/2022 11:00	0.0	0.0	0.0	0.0	0.0
03/22/2022 12:00	0.0	0.0	0.0	0.0	0.0
03/22/2022 13:00	0.0	0.0	0.0	0.0	0.0
03/22/2022 14:00	0.0	0.0	0.0	0.0	0.0
03/22/2022 15:00	0.0	0.0	0.0	0.0	0.0
03/22/2022 16:00	0.0	0.0	0.0	0.0	0.0
03/22/2022 17:00	0.0	0.0	0.0	0.0	0.0
03/22/2022 18:00	0.0	0.0	0.0	0.0	0.0
03/22/2022 19:00	0.0	0.0	0.0	0.0	0.0
03/22/2022 20:00	0.0	0.0	0.0	0.0	0.0
03/22/2022 21:00	0.0	0.0	0.0	0.0	0.0
03/22/2022 22:00	0.0	0.0	0.0	0.0	0.0
03/22/2022 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
03/23/2022 00:00	0.0	0.0	0.0	0.0	0.0
03/23/2022 01:00	0.0	0.0	0.0	0.0	0.0
03/23/2022 02:00	0.0	0.0	0.0	0.0	0.0
03/23/2022 03:00	0.0	0.0	0.0	0.0	0.0
03/23/2022 04:00	0.0	0.0	0.0	0.0	0.0
03/23/2022 05:00	0.0	0.0	0.0	0.0	0.0
03/23/2022 06:00	0.0	0.0	0.0	0.0	0.0
03/23/2022 07:00	0.0	0.0	0.0	0.0	0.0
03/23/2022 08:00	0.0	0.0	0.0	0.0	0.0
03/23/2022 09:00	0.0	0.0	0.0	0.0	0.0
03/23/2022 10:00	0.0	0.0	0.0	0.0	0.0
03/23/2022 11:00	0.0	0.0	0.0	0.0	0.0
03/23/2022 12:00	0.0	0.0	0.0	0.0	0.0
03/23/2022 13:00	0.0	0.0	0.0	0.0	0.0
03/23/2022 14:00	0.0	0.0	0.0	0.0	0.0
03/23/2022 15:00	0.0	0.0	0.0	0.0	0.0
03/23/2022 16:00	0.0	0.0	0.0	0.0	0.0
03/23/2022 17:00	0.0	0.0	0.0	0.0	0.0
03/23/2022 18:00	0.0	0.0	0.0	0.0	0.0
03/23/2022 19:00	0.0	0.0	0.0	0.0	0.0
03/23/2022 20:00	0.0	0.0	0.0	0.0	0.0
03/23/2022 21:00	0.0	0.0	0.0	0.0	0.0
03/23/2022 22:00	0.0	0.0	0.0	0.0	0.0
03/23/2022 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
03/24/2022 00:00	0.0	0.0	0.0	0.0	0.0
03/24/2022 01:00	0.0	0.0	0.0	0.0	0.0
03/24/2022 02:00	0.0	0.0	0.0	0.0	0.0
03/24/2022 03:00	0.0	0.0	0.0	0.0	0.0
03/24/2022 04:00	0.0	0.0	0.0	0.0	0.0
03/24/2022 05:00	0.0	0.0	0.0	0.0	0.0
03/24/2022 06:00	0.0	0.0	0.0	0.0	0.0
03/24/2022 07:00	0.0	0.0	0.0	0.0	0.0
03/24/2022 08:00	0.0	0.0	0.0	0.0	0.0
03/24/2022 09:00	0.0	0.0	0.0	0.0	0.0
03/24/2022 10:00	0.0	0.0	0.0	0.0	0.0
03/24/2022 11:00	0.0	0.0	0.0	0.0	0.0
03/24/2022 12:00	0.0	0.0	0.0	0.0	0.0
03/24/2022 13:00	0.0	0.0	0.0	0.0	0.0
03/24/2022 14:00	0.0	0.0	0.0	0.0	0.0
03/24/2022 15:00	0.0	0.0	0.0	0.0	0.0
03/24/2022 16:00	0.0	0.0	0.0	0.0	0.0
03/24/2022 17:00	0.0	0.0	0.0	0.0	0.0
03/24/2022 18:00	0.0	0.0	0.0	0.0	0.0
03/24/2022 19:00	0.0	0.0	0.0	0.0	0.0
03/24/2022 20:00	0.0	0.0	0.0	0.0	0.0
03/24/2022 21:00	0.0	0.0	0.0	0.0	0.0
03/24/2022 22:00	0.0	0.0	0.0	0.0	0.0
03/24/2022 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
03/25/2022 00:00	0.0	0.0	0.0	0.0	0.0
03/25/2022 01:00	0.0	0.0	0.0	0.0	0.0
03/25/2022 02:00	0.0	0.0	0.0	0.0	0.0
03/25/2022 03:00	0.0	0.0	0.0	0.0	0.0
03/25/2022 04:00	0.0	0.0	0.0	0.0	0.0
03/25/2022 05:00	0.0	0.0	0.0	0.0	0.0
03/25/2022 06:00	0.0	0.0	0.0	0.0	0.0
03/25/2022 07:00	0.0	0.0	0.0	0.0	0.0
03/25/2022 08:00	0.0	0.0	0.0	0.0	0.0
03/25/2022 09:00	0.0	0.0	0.0	0.0	0.0
03/25/2022 10:00	0.0	0.0	0.0	0.0	0.0
03/25/2022 11:00	0.0	0.0	0.0	0.0	0.0
03/25/2022 12:00	0.0	0.0	0.0	0.0	0.0
03/25/2022 13:00	0.0	0.0	0.0	0.0	0.0
03/25/2022 14:00	0.0	0.0	0.0	0.0	0.0
03/25/2022 15:00	0.0	0.0	0.0	0.0	0.0
03/25/2022 16:00	0.0	0.0	0.0	0.0	0.0
03/25/2022 17:00	0.0	0.0	0.0	0.0	0.0
03/25/2022 18:00	0.0	0.0	0.0	0.0	0.0
03/25/2022 19:00	0.0	0.0	0.0	0.0	0.0
03/25/2022 20:00	0.0	0.0	0.0	0.0	0.0
03/25/2022 21:00	0.0	0.0	0.0	0.0	0.0
03/25/2022 22:00	0.0	0.0	0.0	0.0	0.0
03/25/2022 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
03/26/2022 00:00	0.0	0.0	0.0	0.0	0.0
03/26/2022 01:00	0.0	0.0	0.0	0.0	0.0
03/26/2022 02:00	0.0	0.0	0.0	0.0	0.0
03/26/2022 03:00	0.0	0.0	0.0	0.0	0.0
03/26/2022 04:00	0.0	0.0	0.0	0.0	0.0
03/26/2022 05:00	0.0	0.0	0.0	0.0	0.0
03/26/2022 06:00	0.0	0.0	0.0	0.0	0.0
03/26/2022 07:00	0.0	0.0	0.0	0.0	0.0
03/26/2022 08:00	0.0	0.0	0.0	0.0	0.0
03/26/2022 09:00	0.0	0.0	0.0	0.0	0.0
03/26/2022 10:00	0.0	0.0	0.0	0.0	0.0
03/26/2022 11:00	0.0	0.0	0.0	0.0	0.0
03/26/2022 12:00	0.0	0.0	0.0	0.0	0.0
03/26/2022 13:00	0.0	0.0	0.0	0.0	0.0
03/26/2022 14:00	0.0	0.0	0.0	0.0	0.0
03/26/2022 15:00	0.0	0.0	0.0	0.0	0.0
03/26/2022 16:00	0.0	0.0	0.0	0.0	0.0
03/26/2022 17:00	0.0	0.0	0.0	0.0	0.0
03/26/2022 18:00	0.0	0.0	0.0	0.0	0.0
03/26/2022 19:00	0.0	0.0	0.0	0.0	0.0
03/26/2022 20:00	0.0	0.0	0.0	0.0	0.0
03/26/2022 21:00	0.0	0.0	0.0	0.0	0.0
03/26/2022 22:00	0.0	0.0	0.0	0.0	0.0
03/26/2022 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
03/27/2022 00:00	0.0	0.0	0.0	0.0	0.0
03/27/2022 01:00	0.0	0.0	0.0	0.0	0.0
03/27/2022 02:00	0.0	0.0	0.0	0.0	0.0
03/27/2022 03:00	0.0	0.0	0.0	0.0	0.0
03/27/2022 04:00	0.0	0.0	0.0	0.0	0.0
03/27/2022 05:00	0.0	0.0	0.0	0.0	0.0
03/27/2022 06:00	0.0	0.0	0.0	0.0	0.0
03/27/2022 07:00	0.0	0.0	0.0	0.0	0.0
03/27/2022 08:00	0.0	0.0	0.0	0.0	0.0
03/27/2022 09:00	0.0	0.0	0.0	0.0	0.0
03/27/2022 10:00	0.0	0.0	0.0	0.0	0.0
03/27/2022 11:00	0.0	0.0	0.0	0.0	0.0
03/27/2022 12:00	0.0	0.0	0.0	0.0	0.0
03/27/2022 13:00	0.0	0.0	0.0	0.0	0.0
03/27/2022 14:00	0.0	0.0	0.0	0.0	0.0
03/27/2022 15:00	0.0	0.0	0.0	0.0	0.0
03/27/2022 16:00	0.0	0.0	0.0	0.0	0.0
03/27/2022 17:00	0.0	0.0	0.0	0.0	0.0
03/27/2022 18:00	0.0	0.0	0.0	0.0	0.0
03/27/2022 19:00	0.0	0.0	0.0	0.0	0.0
03/27/2022 20:00	0.0	0.0	0.0	0.0	0.0
03/27/2022 21:00	0.0	0.0	0.0	0.0	0.0
03/27/2022 22:00	0.0	0.0	0.0	0.0	0.0
03/27/2022 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
03/28/2022 00:00	0.0	0.0	0.0	0.0	0.0
03/28/2022 01:00	0.0	0.0	0.0	0.0	0.0
03/28/2022 02:00	0.0	0.0	0.0	0.0	0.0
03/28/2022 03:00	0.0	0.0	0.0	0.0	0.0
03/28/2022 04:00	0.0	0.0	0.0	0.0	0.0
03/28/2022 05:00	0.0	0.0	0.0	0.0	0.0
03/28/2022 06:00	0.0	0.0	0.0	0.0	0.0
03/28/2022 07:00	0.0	0.0	0.0	0.0	0.0
03/28/2022 08:00	0.0	0.0	0.0	0.0	0.0
03/28/2022 09:00	0.0	0.0	0.0	0.0	0.0
03/28/2022 10:00	0.0	0.0	0.0	0.0	0.0
03/28/2022 11:00	0.0	0.0	0.0	0.0	0.0
03/28/2022 12:00	0.0	0.0	0.0	0.0	0.0
03/28/2022 13:00	0.0	0.0	0.0	0.0	0.0
03/28/2022 14:00	0.0	0.0	0.0	0.0	0.0
03/28/2022 15:00	0.0	0.0	0.0	0.0	0.0
03/28/2022 16:00	0.0	0.0	0.0	0.0	0.0
03/28/2022 17:00	0.0	0.0	0.0	0.0	0.0
03/28/2022 18:00	0.0	0.0	0.0	0.0	0.0
03/28/2022 19:00	0.0	0.0	0.0	0.0	0.0
03/28/2022 20:00	0.0	0.0	0.0	0.0	0.0
03/28/2022 21:00	0.0	0.0	0.0	0.0	0.0
03/28/2022 22:00	0.0	0.0	0.0	0.0	0.0
03/28/2022 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
03/29/2022 00:00	0.0	0.0	0.0	0.0	0.0
03/29/2022 01:00	0.0	0.0	0.0	0.0	0.0
03/29/2022 02:00	0.0	0.0	0.0	0.0	0.0
03/29/2022 03:00	0.0	0.0	0.0	0.0	0.0
03/29/2022 04:00	0.0	0.0	0.0	0.0	0.0
03/29/2022 05:00	0.0	0.0	0.0	0.0	0.0
03/29/2022 06:00	0.0	0.0	0.0	0.0	0.0
03/29/2022 07:00	0.0	0.0	0.0	0.0	0.0
03/29/2022 08:00	0.0	0.0	0.0	0.0	0.0
03/29/2022 09:00	0.0	0.0	0.0	0.0	0.0
03/29/2022 10:00	0.0	0.0	0.0	0.0	0.0
03/29/2022 11:00	0.0	0.0	0.0	0.0	0.0
03/29/2022 12:00	0.0	0.0	0.0	0.0	0.0
03/29/2022 13:00	0.0	0.0	0.0	0.0	0.0
03/29/2022 14:00	0.0	0.0	0.0	0.0	0.0
03/29/2022 15:00	0.0	0.0	0.0	0.0	0.0
03/29/2022 16:00	0.0	0.0	0.0	0.0	0.0
03/29/2022 17:00	0.0	0.0	0.0	0.0	0.0
03/29/2022 18:00	0.0	0.0	0.0	0.0	0.0
03/29/2022 19:00	0.0	0.0	0.0	0.0	0.0
03/29/2022 20:00	0.0	0.0	0.0	0.0	0.0
03/29/2022 21:00	0.0	0.0	0.0	0.0	0.0
03/29/2022 22:00	0.0	0.0	0.0	0.0	0.0
03/29/2022 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
03/30/2022 00:00	0.0	0.0	0.0	0.0	0.0
03/30/2022 01:00	0.0	0.0	0.0	0.0	0.0
03/30/2022 02:00	0.0	0.0	0.0	0.0	0.0
03/30/2022 03:00	0.0	0.0	0.0	0.0	0.0
03/30/2022 04:00	0.0	0.0	0.0	0.0	0.0
03/30/2022 05:00	0.0	0.0	0.0	0.0	0.0
03/30/2022 06:00	0.0	0.0	0.0	0.0	0.0
03/30/2022 07:00	0.0	0.0	0.0	0.0	0.0
03/30/2022 08:00	0.0	0.0	0.0	0.0	0.0
03/30/2022 09:00	0.0	0.0	0.0	0.0	0.0
03/30/2022 10:00	0.0	0.0	0.0	0.0	0.0
03/30/2022 11:00	0.0	0.0	0.0	0.0	0.0
03/30/2022 12:00	0.0	0.0	0.0	0.0	0.0
03/30/2022 13:00	0.0	0.0	0.0	0.0	0.0
03/30/2022 14:00	0.0	0.0	0.0	0.0	0.0
03/30/2022 15:00	0.0	0.0	0.0	0.0	0.0
03/30/2022 16:00	0.0	0.0	0.0	0.0	0.0
03/30/2022 17:00	0.0	0.0	0.0	0.0	0.0
03/30/2022 18:00	0.0	0.0	0.0	0.0	0.0
03/30/2022 19:00	0.0	0.0	0.0	0.0	0.0
03/30/2022 20:00	0.0	0.0	0.0	0.0	0.0
03/30/2022 21:00	0.0	0.0	0.0	0.0	0.0
03/30/2022 22:00	0.0	0.0	0.0	0.0	0.0
03/30/2022 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:33 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Plantwide NOx, Lb 1 Hour(s)	Plantwide CO, Lb 1 Hour(s)	Plantwide VOC, Lb 1 Hour(s)	Plantwide PM10, Lb 1 Hour(s)	Plantwide SO2, Lb 1 Hour(s)
03/31/2022 00:00	0.0	0.0	0.0	0.0	0.0
03/31/2022 01:00	0.0	0.0	0.0	0.0	0.0
03/31/2022 02:00	0.0	0.0	0.0	0.0	0.0
03/31/2022 03:00	0.0	0.0	0.0	0.0	0.0
03/31/2022 04:00	0.0	0.0	0.0	0.0	0.0
03/31/2022 05:00	0.0	0.0	0.0	0.0	0.0
03/31/2022 06:00	0.0	0.0	0.0	0.0	0.0
03/31/2022 07:00	0.0	0.0	0.0	0.0	0.0
03/31/2022 08:00	0.0	0.0	0.0	0.0	0.0
03/31/2022 09:00	0.0	0.0	0.0	0.0	0.0
03/31/2022 10:00	0.0	0.0	0.0	0.0	0.0
03/31/2022 11:00	0.0	0.0	0.0	0.0	0.0
03/31/2022 12:00	0.0	0.0	0.0	0.0	0.0
03/31/2022 13:00	0.0	0.0	0.0	0.0	0.0
03/31/2022 14:00	0.0	0.0	0.0	0.0	0.0
03/31/2022 15:00	0.0	0.0	0.0	0.0	0.0
03/31/2022 16:00	0.0	0.0	0.0	0.0	0.0
03/31/2022 17:00	0.0	0.0	0.0	0.0	0.0
03/31/2022 18:00	0.0	0.0	0.0	0.0	0.0
03/31/2022 19:00	0.0	0.0	0.0	0.0	0.0
03/31/2022 20:00	0.0	0.0	0.0	0.0	0.0
03/31/2022 21:00	0.0	0.0	0.0	0.0	0.0
03/31/2022 22:00	0.0	0.0	0.0	0.0	0.0
03/31/2022 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Excess Emission Report



CT1 and CT2 CO Lb/Day

From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:34 Location: Maxwell, CA

Tag Name: ALL_CO_Lb_1D
Total Operating Time: 49.00 Day(s) No Exclusions Allowed
Non-Operating Time: 41.00 Day(s) Report Time: 90.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	49.00 Day(s)
Total Duration (Online only):	0.00 Day(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report



CT1 and CT2 CO Lb/Hr

From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:35 Location: Maxwell, CA

Tag Name: ALL_CO_Lb_1H
Total Operating Time: 995.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 1,165.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	995.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report



CT1 and CT2 NOx Lb/Day

From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:35 Location: Maxwell, CA

Tag Name: ALL_NOX_Lb_1D
Total Operating Time: 49.00 Day(s) No Exclusions Allowed
Non-Operating Time: 41.00 Day(s) Report Time: 90.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	49.00 Day(s)
Total Duration (Online only):	0.00 Day(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report



CT1 and CT2 NOx Lb/Hr

From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:36 Location: Maxwell, CA

Tag Name: ALL_NOx_Lb_1H
Total Operating Time: 995.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 1,165.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	995.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report



CT1 and CT2 PM10 Lb/Day

From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:37 Location: Maxwell, CA

Tag Name: ALL_PM10_Lb_1D
Total Operating Time: 49.00 Day(s)
Non-Operating Time: 41.00 Day(s) Report Time: 90.00 Day(s)

No Exclusions Allowed

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	49.00 Day(s)
Total Duration (Online only):	0.00 Day(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report



CT1 and CT2 PM10 Lb/Hr

From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:42 Location: Maxwell, CA

Tag Name: ALL_PM10_Lb_1H
Total Operating Time: 995.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 1,165.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	995.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report



CT1 and CT2 SO2 Lb/Day

From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:44 Location: Maxwell, CA

Tag Name: ALL_SO2_Lb_1D
Total Operating Time: 49.00 Day(s) No Exclusions Allowed
Non-Operating Time: 41.00 Day(s) Report Time: 90.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	49.00 Day(s)
Total Duration (Online only):	0.00 Day(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report



CT1 and CT2 SO2 Lb/Hr

From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:44 Location: Maxwell, CA

Tag Name: ALL_SO2_Lb_1H
Total Operating Time: 995.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 1,165.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	995.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report



CT1 and CT2 VOC Lb/Day

From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:45 Location: Maxwell, CA

Tag Name: ALL_VOC_Lb_1D
Total Operating Time: 49.00 Day(s) No Exclusions Allowed
Non-Operating Time: 41.00 Day(s) Report Time: 90.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	49.00 Day(s)
Total Duration (Online only):	0.00 Day(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report



CT1 and CT2 VOC Lb/Hr

From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 06:46 Location: Maxwell, CA

Tag Name: ALL_VOC_Lb_1H
Total Operating Time: 995.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 1,165.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	995.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

ATTACHMENT 11
CGA/Linearity

FCD: AQ-19
Title V: #13

Linearity Report

01/21/2022

Page 1

ORIS Code: 56298 Facility Name: COLUSA GENERATION
EDR Site ID: CT1 Component ID: A11 ReasonForTest: QA
Component Type: NOXA Grace Period: 0
Instrument Name: CT1_NOXDualRg_P_Instrume Test End Date/Time: 01/18/2022 Scale: High
Performance Spec: 5 % Test No.: 110 Highest Error: 1.8
Status (Pass/Fail): **Passed**

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
01/18/2022	1031	L	200.0	50.2	50.8		25.1 %
01/18/2022	1037	M	200.0	111.4	111.8		55.7 %
01/18/2022	1043	H	200.0	181.3	184.7		90.7 %
01/18/2022	1052	L	200.0	50.2	51.1		25.1 %
01/18/2022	1058	M	200.0	111.4	111.3		55.7 %
01/18/2022	1104	H	200.0	181.3	186.4		90.7 %
01/18/2022	1112	L	200.0	50.2	51.0		25.1 %
01/18/2022	1118	M	200.0	111.4	112.4		55.7 %
01/18/2022	1124	H	200.0	181.3	182.8		90.7 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	50.200	50.967	No	1.5
M	111.400	111.833	No	0.4
H	181.300	184.633	No	1.8

Linearity Report

01/21/2022

Page 1

ORIS Code: 56298 Facility Name: COLUSA GENERATION
 EDR Site ID: CT1 Component ID: A12 ReasonForTest: QA
 Component Type: O2D Grace Period: 0
 Instrument Name: CT1_O2D_P_Instrument Test End Date/Time: 01/18/2022 Scale: High
 Performance Spec: 5 % Test No.: 111 Highest Error: 3.6
 Status (Pass/Fail): Passed

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
01/18/2022	1249	L	25.0	5.5	5.3		22.0 %
01/18/2022	1255	M	25.0	13.0	12.8		52.0 %
01/18/2022	1301	H	25.0	21.0	20.8		84.0 %
01/18/2022	1310	L	25.0	5.5	5.3		22.0 %
01/18/2022	1316	M	25.0	13.0	12.8		52.0 %
01/18/2022	1322	H	25.0	21.0	20.8		84.0 %
01/18/2022	1330	L	25.0	5.5	5.3		22.0 %
01/18/2022	1336	M	25.0	13.0	12.8		52.0 %
01/18/2022	1342	H	25.0	21.0	20.8		84.0 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	5.500	5.300	No	3.6
M	13.000	12.800	No	1.5
H	21.000	20.800	No	1.0

Cylinder Gas Audit

01/21/2022

Page 1

Facility: COLUSA GENERATION

Unit/Stack: CT1

Parameter/Scale: O2D / High

Test Date: 01/19/2022

Test Result: **Pass**

Instrument Name: CT1_O2DInlet_P_Instrum

Performance Spec: 15 Pct

Alternate Spec: 0 Pct

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
01/19/2022	11:32	L	25	5.500	5.300	22.0 %
01/19/2022	11:38	M	25	13.000	12.900	52.0 %
01/19/2022	11:47	L	25	5.500	5.300	22.0 %
01/19/2022	11:53	M	25	13.000	12.900	52.0 %
01/19/2022	12:01	L	25	5.500	5.300	22.0 %
01/19/2022	12:07	M	25	13.000	12.900	52.0 %

Summary Statistics:

Cal Gas Level	Reference	Mean	CEMS Mean	Specification Used	Results
L	5.500		5.300	Std	3.6
M	13.000		12.900	Std	0.8

Cylinder Gas Audit

01/21/2022

Page 1

Facility: COLUSA GENERATION

Unit/Stack: CT1

Parameter/Scale: NOX / High

Test Date: 01/19/2022

Test Result: Pass

Instrument Name: CT1_NOXInlet_P_Instrum

Performance Spec: 15 Pct

Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
01/19/2022	10:04	L	200	50.200	48.600	25.1 %
01/19/2022	10:10	M	200	111.400	108.700	55.7 %
01/19/2022	10:19	L	200	50.200	49.400	25.1 %
01/19/2022	10:25	M	200	111.400	109.700	55.7 %
01/19/2022	10:33	L	200	50.200	49.600	25.1 %
01/19/2022	10:39	M	200	111.400	110.200	55.7 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	50.200	49.200	Std	2.0
M	111.400	109.533	Std	1.7

Cylinder Gas Audit

01/21/2022

Page 1

Facility: COLUSA GENERATION

Unit/Stack: CT1

Parameter/Scale: CO / High

Test Date: 01/19/2022

Test Result: **Pass**

Instrument Name: CT1_CODualRg_P_Instrum

Performance Spec: 15 Pct

Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
01/19/2022	07:51	L	2000	499.400	469.700	25.0 %
01/19/2022	07:57	M	2000	1147.000	1130.300	57.4 %
01/19/2022	08:06	L	2000	499.400	470.300	25.0 %
01/19/2022	08:12	M	2000	1147.000	1131.100	57.4 %
01/19/2022	08:20	L	2000	499.400	470.800	25.0 %
01/19/2022	08:26	M	2000	1147.000	1131.900	57.4 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	499.400	470.267	Std	5.8
M	1147.000	1131.100	Std	1.4

Cylinder Gas Audit

01/21/2022

Page 1

Facility: COLUSA GENERATION

Unit/Stack: CT1

Parameter/Scale: CO / Low

Test Date: 01/18/2022

Test Result: **Pass**

Instrument Name: CT1_CODualRg_P_Instrum

Performance Spec: 15 Pct

Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
01/18/2022	16:09	L	20	4.700	5.000	23.5 %
01/18/2022	16:15	M	20	11.100	11.000	55.5 %
01/18/2022	16:24	L	20	4.700	5.000	23.5 %
01/18/2022	16:30	M	20	11.100	11.000	55.5 %
01/18/2022	16:38	L	20	4.700	4.900	23.5 %
01/18/2022	16:44	M	20	11.100	11.000	55.5 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	4.700	4.967	Std	5.7
M	11.100	11.000	Std	0.9

Cylinder Gas Audit

01/21/2022

Page 1

Facility: COLUSA GENERATION

Unit/Stack: CT1

Parameter/Scale: NOX / Low

Test Date: 01/18/2022

Test Result: Pass

Instrument Name: CT1_NOXDualRg_P_Instru

Performance Spec: 15 Pct

Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
01/18/2022	14:23	L	10	2.600	3.900	26.0 %
01/18/2022	14:29	M	10	5.500	6.700	55.0 %
01/18/2022	14:38	L	10	2.600	3.800	26.0 %
01/18/2022	14:44	M	10	5.500	6.700	55.0 %
01/18/2022	14:52	L	10	2.600	3.800	26.0 %
01/18/2022	14:58	M	10	5.500	6.700	55.0 %

Summary Statistics:

Cal Gas Level	Reference	Mean	CEMS Mean	Specification Used	Results
L	2.600		3.833	Alt	1.2
M	5.500		6.700	Alt	1.2

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number: E03NI99E15A42D0
Cylinder Number: ALM-061891
Laboratory: 124 - Tooele (SAP) - UT
PGVP Number: B72021
Gas Code: CO,NO,NOX,BALN

Reference Number: 153-402189289-1
Cylinder Volume: 144.4 Cubic Feet
Cylinder Pressure: 2015 PSIG
Valve Outlet: 660
Certification Date: Aug 23, 2021

Expiration Date: Aug 23, 2029

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	180.0 PPM	181.3 PPM	G1	+/- 0.9% NIST Traceable	08/16/2021, 08/23/2021
NITRIC OXIDE	180.0 PPM	181.1 PPM	G1	+/- 0.9% NIST Traceable	08/16/2021, 08/23/2021
CARBON MONOXIDE	1150 PPM	1147 PPM	G1	+/- 0.9% NIST Traceable	08/16/2021
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	20060332	EB0113126	250.3 PPM NITRIC OXIDE/NITROGEN	0.8%	Oct 19, 2026
PRM	12386	D685025	9.91 PPM NITROGEN DIOXIDE/AIR	2.0%	Feb 20, 2020
GMIS	401648675102	CC500959	5.074 PPM NITROGEN DIOXIDE/NITROGEN	2.1%	Feb 01, 2023
NTRM	14060137	CC436581	990.9 PPM CARBON MONOXIDE/NITROGEN	0.6%	Nov 15, 2025

The SRM, PRM or RGM noted above is only in reference to the GMIS used in the assay and not part of the analysis.

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Nicolet iS50 AUP2110269 CO HCO	FTIR	Aug 11, 2021
Nicolet iS50 AUP2110269 NO MNO	FTIR	Jul 29, 2021
Nicolet iS50 AUP2110269 NO2 impurity	FTIR NO2 impurity	Jul 29, 2021

Triad Data Available Upon Request



mo ul

Approved for Release

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number: E02NI79E15AC046
Cylinder Number: CC58446
Laboratory: 124 - Tooele (SAP) - UT
PGVP Number: B72021

Reference Number: 153-402226907-1
Cylinder Volume: 146.2 CF
Cylinder Pressure: 2015 PSIG
Valve Outlet: 590
Certification Date: Sep 20, 2021

CT1
CV2

Expiration Date: Sep 20, 2029

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
OXYGEN	21.00 %	20.97 %	G1	+/- 0.6% NIST Traceable	09/20/2021
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	12062008	CC367433	22.883 % OXYGEN/NITROGEN	0.2%	May 14, 2024

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Horiba MPA-510 W603MM58 O2	O2 Paramagnetic (Mason)	Sep 09, 2021

Triad Data Available Upon Request

PERMANENT NOTES:-NA-

NOTES:

Nitric Oxide: < 0.01PPM
Carbon Monoxide: < 0.01PPM
Carbon Dioxide: < 0.01PPM



[Signature]
Approved for Release

In Service 12/2/2021



Airgas Specialty Gases
Airgas USA, LLC
525 North Industrial Loop Road
Tooele, UT 84074
Airgas.com

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E03NI99E15A7635	Reference Number:	153-401995005-1
Cylinder Number:	CC741477	Cylinder Volume:	144.3 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72021	Valve Outlet:	660
Gas Code:	CO,NO,NOX,BALN	Certification Date:	Jan 06, 2021

CT1
CV3

Expiration Date: Jan 06, 2024

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS					
Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	9.000 PPM	9.118 PPM	G1	+/- 1.1% NIST Traceable	12/30/2020, 01/06/2021
NITRIC OXIDE	9.000 PPM	9.011 PPM	G1	+/- 1.2% NIST Traceable	12/30/2020, 01/06/2021
CARBON MONOXIDE	11.00 PPM	11.12 PPM	G1	+/- 0.8% NIST Traceable	12/30/2020
NITROGEN	Balance				

CALIBRATION STANDARDS					
Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	120102	AAL073426	10.04 PPM NITRIC OXIDE/NITROGEN	1.0%	Oct 16, 2022
NTRM	120102	AAL073426-NOX	10.04 PPM NOx/NITROGEN	1.0%	Oct 16, 2022
NTRM	08011130	KAL004049	9.855 PPM CARBON MONOXIDE/NITROGEN	0.5%	Jun 05, 2024

ANALYTICAL EQUIPMENT		
Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Thermo 48i-TLE 1163640031 CO	CO NDIR (Mason)	Dec 01, 2020
Thermo 42i-LS 1123749327 NO	Chemiluminescence (Mason)	Dec 21, 2020
Thermo 42i-LS 1123749327 NOx	Chemiluminescence (Mason)	Dec 21, 2020

Triad Data Available Upon Request




 Approved for Release

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number: E02NI99E15A0093 Reference Number: 153-401144291-1
Cylinder Number: CC476209 Cylinder Volume: 144.3 CF
Laboratory: 124 - Tooele (SAP) - UT Cylinder Pressure: 2015 PSIG
PGVP Number: B72018 Valve Outlet: 660
Gas Code: NO,NOX,BALN Certification Date: Mar 12, 2018

CTI
CV4

Expiration Date: Mar 12, 2026

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	110.0 PPM	111.4 PPM	G1	+/- 1.1% NIST Traceable	03/05/2018, 03/12/2018
NITRIC OXIDE	110.0 PPM	111.1 PPM	G1	+/- 1.1% NIST Traceable	03/05/2018, 03/12/2018
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	13010413	KAL004013	97.6 PPM NITRIC OXIDE/NITROGEN	0.8%	May 09, 2019
PRM	12367	APEX1099237	9.82 PPM NITROGEN DIOXIDE/NITROGEN	1.6%	May 29, 2016
GMIS	1114201604	CC507567	4.955 PPM NITROGEN DIOXIDE/NITROGEN	2.0%	Nov 14, 2019

The SRM, PRM or RGM noted above is only in reference to the GMIS used in the assay and not part of the analysis.

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Nicolet 6700 AHR0801550 NO LNO	FTIR	Mar 07, 2018
Nicolet 6700 AHR0801550 NO2 impurity	FTIR NO2 impurity	Mar 07, 2018

Triad Data Available Upon Request



[Signature]

Approved for Release

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E02NI99E15A0147	Reference Number:	153-401707980-1
Cylinder Number:	CC178727	Cylinder Volume:	144.3 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72020	Valve Outlet:	660
Gas Code:	NO,NOX,BALN	Certification Date:	Jan 28, 2020

CTI
CV5

Expiration Date: Jan 28, 2028

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	50.00 PPM	50.17 PPM	G1	+/- 1.0% NIST Traceable	01/21/2020, 01/28/2020
NITRIC OXIDE	50.00 PPM	50.17 PPM	G1	+/- 1.0% NIST Traceable	01/21/2020, 01/28/2020
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	12010719	KAL004397	50.03 PPM NITRIC OXIDE/NITROGEN	0.8%	Mar 12, 2024
PRM	12376	D562879	10.01 PPM NITROGEN DIOXIDE/NITROGEN	2.0%	Aug 17, 2018
GMIS	7301017103	CC506597	4.451 PPM NITROGEN DIOXIDE/NITROGEN	2.0%	Dec 18, 2020

The SRM, PRM or RGM noted above is only in reference to the GMIS used in the assay and not part of the analysis.

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Nicolet 6700 AMP0900119 NO LNO	FTIR	Jan 22, 2020
Nicolet 6700 AMP0900119 NO2 impurity	FTIR NO2 impurity	Jan 22, 2020

Triad Data Available Upon Request



mlz

Approved for Release

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number: E03NI99E15A42C9
Cylinder Number: CC347523
Laboratory: 124 - Los Angeles (SAP) - CA
PGVP Number: B32021
Gas Code: CO,NO,NOX,BALN

Reference Number: 48-402028993-1
Cylinder Volume: 144.3 CF
Cylinder Pressure: 2015 PSIG
Valve Outlet: 660
Certification Date: Feb 22, 2021

CTI
CV6

Expiration Date: Feb 22, 2024

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS					
Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	5.500 PPM	5.504 PPM	G1	+/- 1.1% NIST Traceable	02/15/2021, 02/22/2021
NITRIC OXIDE	5.500 PPM	5.456 PPM	G1	+/- 1.2% NIST Traceable	02/15/2021, 02/22/2021
CARBON MONOXIDE	500.0 PPM	499.4 PPM	G1	+/- 0.7% NIST Traceable	02/16/2021
NITROGEN	Balance				

CALIBRATION STANDARDS					
Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	08012106A	KAL004222	5.08 PPM NITRIC OXIDE/NITROGEN	+/- 1.0%	Jul 05, 2021
NTRM	08012106A	KAL004222-NOx	5.08 PPM NOx/NITROGEN	+/- 1.0%	Jul 05, 2021
NTRM	13010114	ND47902	495.4 PPM CARBON MONOXIDE/NITROGEN	+/- 0.6%	Jul 03, 2024

ANALYTICAL EQUIPMENT		
Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
SIEMENS 6E CO LOW	NDIR	Feb 04, 2021
Thermo 42-iLS 1115848421 NO	Chemiluminescence	Jan 22, 2021
Thermo 42-iLS 1115848421 NOx	Chemiluminescence	Jan 22, 2021

Triad Data Available Upon Request



Approved for Release

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number: E03NI99E15A73F4 Reference Number: 153-402028992-1
Cylinder Number: CC739556 Cylinder Volume: 144.3 CF
Laboratory: 124 - Tooele (SAP) - UT Cylinder Pressure: 2015 PSIG
PGVP Number: B72021 Valve Outlet: 660
Gas Code: CO,NO,NOX,BALN Certification Date: Feb 23, 2021

CTI
CV7

Expiration Date: Feb 23, 2024

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	2.500 PPM	2.613 PPM	G1	+/- 1.4% NIST Traceable	02/10/2021, 02/23/2021
NITRIC OXIDE	2.500 PPM	2.495 PPM	G1	+/- 1.1% NIST Traceable	02/10/2021, 02/23/2021
CARBON MONOXIDE	4.750 PPM	4.714 PPM	G1	+/- 0.7% NIST Traceable	02/10/2021
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	08012126	KAL004291	5.08 PPM NITRIC OXIDE/NITROGEN	1.0%	Jul 05, 2021
NTRM	08012126	KAL004291-NOX	5.08 PPM NOX/NITROGEN	1.0%	Jul 05, 2021
NTRM	08011130	KAL004049	9.855 PPM CARBON MONOXIDE/NITROGEN	0.5%	Jun 05, 2024

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Thermo 48i-TLE 1163640031 CO	CO NDIR (Mason)	Feb 01, 2021
Thermo 42i-LS 1123749327 NO	Chemiluminescence (Mason)	Feb 19, 2021
Thermo 42i-LS 1123749327 NOx	Chemiluminescence (Mason)	Feb 19, 2021

Triad Data Available Upon Request



[Signature]
Approved for Release

CT/
CV8

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E02NI87E15A0080	Reference Number:	153-402028995-1
Cylinder Number:	EB0088907	Cylinder Volume:	145.5 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72021	Valve Outlet:	590
Gas Code:	O2,BALN	Certification Date:	Feb 15, 2021

Expiration Date: Feb 15, 2029

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS					
Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
OXYGEN	13.00 %	13.03 %	G1	+/- 0.8% NIST Traceable	02/15/2021
NITROGEN	Balance				

CALIBRATION STANDARDS					
Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	98051010	SG9161286BAL	12.05 % OXYGEN/NITROGEN	0.7%	Dec 14, 2023

ANALYTICAL EQUIPMENT		
Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Horiba MPA-510 W603MM58 O2	O2 Paramagnetic (Mason)	Feb 01, 2021

Triad Data Available Upon Request



Dan FZ
Approved for Release

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number: E02NI94E15AC040 Reference Number: 153-402028994-1
Cylinder Number: CC222116 Cylinder Volume: 144.8 CF
Laboratory: 124 - Tooele (SAP) - UT Cylinder Pressure: 2015 PSIG
PGVP Number: B72021 Valve Outlet: 590
Gas Code: O2,BALN Certification Date: Feb 16, 2021

CT1
CV9

Expiration Date: Feb 16, 2029

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
OXYGEN	5.500 %	5.501 %	G1	+/- 0.5% NIST Traceable	02/16/2021
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	11060717	CC338451	4.861 % OXYGEN/NITROGEN	0.4%	Dec 13, 2022

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Horiba MPA-510 W603MM58 O2	O2 Paramagnetic (Mason)	Feb 01, 2021

Triad Data Available Upon Request

PERMANENT NOTES:-NA-

NOTES:NO: 0.01PPM

CO: 0.03PPM

CO2: 0.01PPM



[Signature]
Approved for Release

Linearity Report

01/21/2022

Page 1

ORIS Code: 56298 Facility Name: COLUSA GENERATION
 EDR Site ID: CT2 Component ID: A21 ReasonForTest: QA
 Component Type: NOXA Grace Period: 0
 Instrument Name: CT2_NOXDualRg_P_Instrume Test End Date/Time: 01/19/2022 Scale: High
 Performance Spec: 5 % Test No.: 112 Highest Error: 1.9
 Status (Pass/Fail): **Passed**

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
01/19/2022	0826	L	200.0	50.3	49.1		25.2 %
01/19/2022	0832	M	200.0	110.4	112.3		55.2 %
01/19/2022	0838	H	200.0	182.1	183.7		91.1 %
01/19/2022	0847	L	200.0	50.3	49.5		25.2 %
01/19/2022	0853	M	200.0	110.4	112.4		55.2 %
01/19/2022	0859	H	200.0	182.1	183.9		91.1 %
01/19/2022	0907	L	200.0	50.3	49.4		25.2 %
01/19/2022	0913	M	200.0	110.4	112.1		55.2 %
01/19/2022	0919	H	200.0	182.1	183.8		91.1 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	50.300	49.333	No	1.9
M	110.400	112.267	No	1.7
H	182.100	183.800	No	0.9

Linearity Report

01/21/2022

Page 1

ORIS Code: 56298 Facility Name: COLUSA GENERATION
 EDR Site ID: CT2 Component ID: A22 ReasonForTest: QA
 Component Type: O2D Grace Period: 0
 Instrument Name: CT2_O2D_P_Instrument Test End Date/Time: 01/19/2022 Scale: High
 Performance Spec: 5 % Test No.: 113 Highest Error: 0.0
 Status (Pass/Fail): **Passed**

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
01/19/2022	1005	L	25.0	5.5	5.5		22.0 %
01/19/2022	1011	M	25.0	13.0	13.0		52.0 %
01/19/2022	1017	H	25.0	21.0	21.0		84.0 %
01/19/2022	1026	L	25.0	5.5	5.5		22.0 %
01/19/2022	1032	M	25.0	13.0	13.0		52.0 %
01/19/2022	1038	H	25.0	21.0	21.0		84.0 %
01/19/2022	1046	L	25.0	5.5	5.5		22.0 %
01/19/2022	1052	M	25.0	13.0	13.0		52.0 %
01/19/2022	1058	H	25.0	21.0	21.0		84.0 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	5.500	5.500	No	0.0
M	13.000	13.000	No	0.0
H	21.000	21.000	No	0.0

Cylinder Gas Audit

01/21/2022

Page 1

Facility: COLUSA GENERATION

Unit/Stack: CT2

Parameter/Scale: O2D / High

Test Date: 01/20/2022

Test Result: Pass

Instrument Name: CT2_O2DInlet_P_Instrum

Performance Spec: 15 Pct

Alternate Spec: 0 Pct

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
01/20/2022	11:44	L	25	5.500	5.200	22.0 %
01/20/2022	11:50	M	25	13.000	12.900	52.0 %
01/20/2022	11:59	L	25	5.500	5.200	22.0 %
01/20/2022	12:05	M	25	13.000	12.900	52.0 %
01/20/2022	12:13	L	25	5.500	5.200	22.0 %
01/20/2022	12:19	M	25	13.000	12.900	52.0 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	5.500	5.200	Std	5.5
M	13.000	12.900	Std	0.8

Cylinder Gas Audit

01/21/2022

Page 1

Facility: COLUSA GENERATION

Unit/Stack: CT2

Parameter/Scale: NOX / High

Test Date: 01/20/2022

Test Result: **Pass**

Instrument Name: CT2_NOXInlet_P_Instrum

Performance Spec: 15 Pct

Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
01/20/2022	10:02	L	200	50.300	49.300	25.2 %
01/20/2022	10:08	M	200	110.400	110.800	55.2 %
01/20/2022	10:17	L	200	50.300	49.600	25.2 %
01/20/2022	10:23	M	200	110.400	111.200	55.2 %
01/20/2022	10:31	L	200	50.300	49.600	25.2 %
01/20/2022	10:37	M	200	110.400	111.600	55.2 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	50.300	49.500	Std	1.6
M	110.400	111.200	Std	0.7

Cylinder Gas Audit

01/21/2022

Page 1

Facility: COLUSA GENERATION

Unit/Stack: CT2

Parameter/Scale: NOX / Low

Test Date: 01/19/2022

Test Result: **Pass**

Instrument Name: CT2_NOXDualRg_P_Instru

Performance Spec: 15 Pct

Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
01/19/2022	15:05	L	10	2.500	2.200	25.0 %
01/19/2022	15:11	M	10	5.500	5.200	55.0 %
01/19/2022	15:20	L	10	2.500	2.200	25.0 %
01/19/2022	15:26	M	10	5.500	5.300	55.0 %
01/19/2022	15:34	L	10	2.500	2.200	25.0 %
01/19/2022	15:40	M	10	5.500	5.300	55.0 %

Summary Statistics:

Cal Gas Level	Reference	Mean	CEMS Mean	Specification Used	Results
L	2.500		2.200	Std	12.0
M	5.500		5.267	Std	4.2

Cylinder Gas Audit

01/21/2022

Page 1

Facility: COLUSA GENERATION

Unit/Stack: CT2

Parameter/Scale: CO / Low

Test Date: 01/19/2022

Test Result: Pass

Instrument Name: CT2_CODualRg_P_Instrum

Performance Spec: 15 Pct

Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
01/19/2022	13:38	L	20	4.600	4.900	23.0 %
01/19/2022	13:44	M	20	10.900	11.000	54.5 %
01/19/2022	13:53	L	20	4.600	4.700	23.0 %
01/19/2022	13:59	M	20	10.900	11.000	54.5 %
01/19/2022	14:07	L	20	4.600	4.700	23.0 %
01/19/2022	14:13	M	20	10.900	11.000	54.5 %

Summary Statistics:

Cal Gas Level	Reference	Mean	CEMS Mean	Specification Used	Results
L	4.600		4.767	Std	3.6
M	10.900		11.000	Std	0.9

Cylinder Gas Audit

01/21/2022

Page 1

Facility: COLUSA GENERATION

Unit/Stack: CT2

Parameter/Scale: CO / High

Test Date: 01/19/2022

Test Result: Pass

Instrument Name: CT2_CODualRg_P_Instrum

Performance Spec: 15 Pct

Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
01/19/2022	11:55	L	2000	511.100	508.100	25.6 %
01/19/2022	12:01	M	2000	1142.000	1143.900	57.1 %
01/19/2022	12:10	L	2000	511.100	507.800	25.6 %
01/19/2022	12:16	M	2000	1142.000	1143.600	57.1 %
01/19/2022	12:24	L	2000	511.100	508.300	25.6 %
01/19/2022	12:30	M	2000	1142.000	1143.900	57.1 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	511.100	508.067	Std	0.6
M	1142.000	1143.800	Std	0.2

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E03NI99E15A42D0	Reference Number:	153-401995003-1
Cylinder Number:	CC273595	Cylinder Volume:	144.4 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72021	Valve Outlet:	660
Gas Code:	CO,NO,NOX,BALN	Certification Date:	Jan 05, 2021

CT2
CV₁

Expiration Date: Jan 05, 2029

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	180.0 PPM	182.1 PPM	G1	+/- 0.8% NIST Traceable	12/29/2020, 01/05/2021
NITRIC OXIDE	180.0 PPM	181.9 PPM	G1	+/- 0.8% NIST Traceable	12/29/2020, 01/05/2021
CARBON MONOXIDE	1150 PPM	1142 PPM	G1	+/- 1.2% NIST Traceable	12/29/2020
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	13010322	KAL003863	243.4 PPM NITRIC OXIDE/NITROGEN	0.5%	May 04, 2026
PRM	12386	D685025	9.91 PPM NITROGEN DIOXIDE/AIR	2.0%	Feb 20, 2020
GMIS	401203436105	CC513880	4.732 PPM NITROGEN DIOXIDE/NITROGEN	2.1%	May 02, 2022
NTRM	08012251	KAL004695	2466 PPM CARBON MONOXIDE/NITROGEN	0.5%	May 09, 2024


The SRM, PRM or RGM noted above is only in reference to the GMIS used in the assay and not part of the analysis.

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Nicolet 6700 AHR0801550 CO HCO	FTIR	Dec 23, 2020
Nicolet 6700 AHR0801550 NO MNO	FTIR	Dec 29, 2020
Nicolet 6700 AHR0801550 NO2 impurity	FTIR NO2 impurity	Dec 30, 2020

Triad Data Available Upon Request




 Approved for Release

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number: E02NI79E15AC046
Cylinder Number: CC194934
Laboratory: 124 - Tooele (SAP) - UT
PGVP Number: B72021

Reference Number: 153-402226907-1
Cylinder Volume: 146.2 CF
Cylinder Pressure: 2015 PSIG
Valve Outlet: 590
Certification Date: Sep 20, 2021

CT2
CV2

Expiration Date: Sep 20, 2029

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
OXYGEN	21.00 %	20.99 %	G1	+/- 0.4% NIST Traceable	09/20/2021
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	12062008	CC367433	22.883 % OXYGEN/NITROGEN	0.2%	May 14, 2024

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Horiba MPA-510 W603MM58 O2	O2 Paramagnetic (Mason)	Sep 09, 2021

Triad Data Available Upon Request

PERMANENT NOTES:-NA-

NOTES:

Nitric Oxide: < 0.01PPM
Carbon Monoxide: < 0.01PPM
Carbon Dioxide: < 0.01PPM



Dan Zg

Approved for Release

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number: E03NI99E15A7635 Reference Number: 153-402066793-1
Cylinder Number: EB0064623 Cylinder Volume: 144.3 CF
Laboratory: 124 - Tooele (SAP) - UT Cylinder Pressure: 2015 PSIG
PGVP Number: B72021 Valve Outlet: 660
Gas Code: CO,NO,NOX,BALN Certification Date: Apr 06, 2021

CT2
CV3

Expiration Date: Apr 06, 2024

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	9.000 PPM	8.960 PPM	G1	+/- 1.4% NIST Traceable	03/29/2021, 04/06/2021
NITRIC OXIDE	9.000 PPM	8.829 PPM	G1	+/- 1.2% NIST Traceable	03/29/2021, 04/06/2021
CARBON MONOXIDE	11.00 PPM	10.94 PPM	G1	+/- 0.7% NIST Traceable	03/29/2021
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder N	Concentration	Uncertainty	Expiration Date
NTRM	120102	AAL07342	10.04 PPM NITRIC OXIDE/NITROGEN	1.0%	Oct 16, 2022
NTRM	120102	AAL073425-NOX	10.04 PPM NOx/NITROGEN	1.0%	Oct 16, 2022
NTRM	08011130	KAL004049	9.855 PPM CARBON MONOXIDE/NITROGEN	0.5%	Jun 05, 2024

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Thermo 48i-TLE 1163640031 CO	CO NDIR (Mason)	Mar 01, 2021
Thermo 42i-LS 1123749327 NO	Chemiluminescence (Mason)	Mar 22, 2021
Thermo 42i-LS 1123749327 NOx	Chemiluminescence (Mason)	Mar 22, 2021

Triad Data Available Upon Request



[Signature]
Approved for Release

CT2 - CV4

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E02NI99E15A0093	Reference Number:	153-400996726-1
Cylinder Number:	CC205834	Cylinder Volume:	144.3 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72017	Valve Outlet:	660
Gas Code:	NO,NOX,BALN	Certification Date:	Sep 19, 2017

Expiration Date: Sep 19, 2025

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	110.0 PPM	110.4 PPM	G1	+/- 1.0% NIST Traceable	09/12/2017, 09/19/2017
NITRIC OXIDE	110.0 PPM	110.2 PPM	G1	+/- 1.0% NIST Traceable	09/12/2017, 09/19/2017
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	13010428	KAL004053	97.6 PPM NITRIC OXIDE/NITROGEN	0.8	May 09, 2019
PRM	12367	APEX1099237	10.00 PPM NITROGEN DIOXIDE/NITROGEN	1.6%	May 29, 2016
GMIS	1114201604	CC507567	4.955 PPM NITROGEN DIOXIDE/NITROGEN	2.0%	Nov 14, 2019

The SRM, PRM or RGM noted above is only in reference to the GMIS used in the assay and not part of the analysis.

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Nicolet 6700 AHR0801550 NO LNO	FTIR	Sep 07, 2017
Nicolet 6700 AHR0801550 NO2 impurity	FTIR NO2 impurity	Sep 07, 2017

Triad Data Available Upon Request



CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

CTZ
CV5

Part Number: E02NI99E15A0147 Reference Number: 153-401144292-1
Cylinder Number: CC215825 Cylinder Volume: 144.3 CF
Laboratory: 124 - Tooele (SAP) - UT Cylinder Pressure: 2015 PSIG
PGVP Number: B72018 Valve Outlet: 660
Gas Code: NO,NOX,BALN Certification Date: Mar 13, 2018

Expiration Date: Mar 13, 2026

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	50.00 PPM	50.34 PPM	G1	+/- 1.4% NIST Traceable	03/06/2018, 03/13/2018
NITRIC OXIDE	50.00 PPM	50.31 PPM	G1	+/- 1.4% NIST Traceable	03/06/2018, 03/13/2018
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	16060619	CC442576	50.42 PPM NITRIC OXIDE/NITROGEN	0.8%	Jun 27, 2020
PRM	12367	APEX1099237	9.82 PPM NITROGEN DIOXIDE/NITROGEN	1.6%	May 29, 2016
GMIS	1114201604	CC507567	4.955 PPM NITROGEN DIOXIDE/NITROGEN	2.0%	Nov 14, 2019

The SRM, PRM or RGM noted above is only in reference to the GMIS used in the assay and not part of the analysis.

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Nicolet 6700 AHR0801550 NO LNO	FTIR	Mar 07, 2018
Nicolet 6700 AHR0801550 NO2 impurity	FTIR NO2 impurity	Mar 07, 2018

Triad Data Available Upon Request



[Signature]

Approved for Release

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number: E03NI99E15A42C9
Cylinder Number: EB0102482
Laboratory: 124 - Los Angeles (SAP) - CA
PGVP Number: B32020
Gas Code: CO,NO,NOX,BALN

Reference Number: 48-401707982-1
Cylinder Volume: 144.3 CF
Cylinder Pressure: 2015 PSIG
Valve Outlet: 660
Certification Date: Feb 12, 2020

CTZ
CV₆

Expiration Date: Feb 12, 2023

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	5,500 PPM	5,476 PPM	G1	+/- 1.2% NIST Traceable	02/03/2020, 02/12/2020
NITRIC OXIDE	5,500 PPM	5,410 PPM	G1	+/- 1.1% NIST Traceable	02/03/2020, 02/12/2020
CARBON MONOXIDE	500.0 PPM	511.1 PPM	G1	+/- 0.6% NIST Traceable	02/04/2020
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	08012106A	KAL004222	5.08 PPM NITRIC OXIDE/NITROGEN	+/- 1.0%	Jul 05, 2021
NTRM	08012106A	KAL004222-NOx	5.08 PPM NOx/NITROGEN	+/- 1.0%	Jul 05, 2021
NTRM	15060524	CC450548	491.9 PPM CARBON MONOXIDE/NITROGEN	+/- 0.6%	Jan 08, 2021

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
SIEMENS 6E CO HIGH	NDIR	Jan 15, 2020
Thermo 42-ILS 1115848421 NO	Chemiluminescence	Feb 02, 2020
Thermo 42-ILS 1115848421 NOx	Chemiluminescence	Feb 02, 2020

Triad Data Available Upon Request



Approved for Release

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

CT 2
CV 7

Part Number: E03NI99E15A73F4 Reference Number: 153-401707981-1
Cylinder Number: CC472917 Cylinder Volume: 144.3 CF
Laboratory: 124 - Tooele (SAP) - UT Cylinder Pressure: 2015 PSIG
PGVP Number: B72020 Valve Outlet: 660
Gas Code: CO,NO,NOX,BALN Certification Date: Jan 28, 2020

Expiration Date: Jan 28, 2023

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	2.500 PPM	2.507 PPM	G1	+/- 1.3% NIST Traceable	01/21/2020, 01/28/2020
NITRIC OXIDE	2.500 PPM	2.502 PPM	G1	+/- 1.4% NIST Traceable	01/21/2020, 01/28/2020
CARBON MONOXIDE	4.750 PPM	4.637 PPM	G1	+/- 0.6% NIST Traceable	01/21/2020
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	08012121A	KAL004278	5.08 PPM NITRIC OXIDE/NITROGEN	1.0%	Jun 05, 2021
NTRM	08012126	KAL004291	5.08 PPM NITRIC OXIDE/NITROGEN	1.0%	Jul 05, 2021
NTRM	08012121A	KAL004278-NOX	5.08 PPM NOx/NITROGEN	1.0%	Jun 05, 2021
NTRM	08012126	KAL004291-NOX	5.08 PPM NOx/NITROGEN	1.0%	Jul 05, 2021
NTRM	08011130	KAL004049	9.855 PPM CARBON MONOXIDE/NITROGEN	0.5%	Jun 05, 2024

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Thermo 48i-TLE 1163640031 CO	CO NDIR (Mason)	Jan 06, 2020
Thermo 42i-LS 1123749327 NO	Chemiluminescence (Mason)	Jan 16, 2020
Thermo 42i-LS 1123749327 NOx	Chemiluminescence (Mason)	Jan 16, 2020

Triad Data Available Upon Request



Carlye Wright
Approved for Release

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

CTZ
CV8

Part Number:	E02NI87E15A0080	Reference Number:	153-402028995-1
Cylinder Number:	CC203622	Cylinder Volume:	145.5 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72021	Valve Outlet:	590
Gas Code:	O2,BALN	Certification Date:	Feb 15, 2021

Expiration Date: Feb 15, 2029

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
OXYGEN	13.00 %	13.02 %	G1	+/- 0.7% NIST Traceable	02/15/2021
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	98051010	SG9161286BAL	12.05 % OXYGEN/NITROGEN	0.7%	Dec 14, 2023

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Horiba MPA-510 W603MM58 O2	O2 Paramagnetic (Mason)	Feb 01, 2021

Triad Data Available Upon Request



Dan J. J.
Approved for Release

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number: E02NI94E15AC040
Cylinder Number: CC415540
Laboratory: 124 - Tooele (SAP) - UT
PGVP Number: B72020
Gas Code: O2,BALN

Reference Number: 153-401825995-1
Cylinder Volume: 144.8 CF
Cylinder Pressure: 2015 PSIG
Valve Outlet: 590
Certification Date: Jun 02, 2020

CTZ
CVg

Expiration Date: Jun 02, 2028

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
OXYGEN	5.500 %	5.495 %	G1	+/- 0.5% NIST Traceable	06/02/2020
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	11060717	CC338451	4.861 % OXYGEN/NITROGEN	0.4%	Dec 13, 2022

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Horiba MPA-510 W603MM58 O2	O2 Paramagnetic (Mason)	May 21, 2020

Triad Data Available Upon Request

PERMANENT NOTES:-NA-

NOTES:

NO: 0.01 ppm
CO: 0.02 ppm
CO2: 0.00 ppm



Conner Wright

Approved for Release

ATTACHMENT 12
Startup/Shutdown Emissions

Title V: #13

100scf Per Event Report

CT1 - GasFlowTotal 100scf



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION

Generated: 04/11/2022 06:47 Location: Maxwell, CA

Tag Name: CT1_GasFlowTot_Event_100scf_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 937.60 Hours

Non-Operating Time: 1,222.40 Hours Report Time: 2,160.00 Hours

Unit Operation and Excess Events

Event Period			Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Code - Description	Code - Description
01/07/2022 22:24 01/07/2022 22:29 Shut Down - Gas	6	0.6		
01/08/2022 10:30 01/08/2022 12:49 Warm Start - Gas	140	181.2		
01/13/2022 23:23 01/13/2022 23:28 Shut Down - Gas	6	0.6		
01/14/2022 04:42 01/14/2022 05:54 Hot Start - Gas	73	119.2		
01/14/2022 23:23 01/14/2022 23:28 Shut Down - Gas	6	0.8		
01/15/2022 04:46 01/15/2022 05:55 Hot Start - Gas	70	116.2		
01/15/2022 23:39 01/15/2022 23:43 Shut Down - Gas	5	0.4		
01/16/2022 11:01 01/16/2022 12:59 Warm Start - Gas	119	165.4		
01/20/2022 23:43 01/20/2022 23:48 Shut Down - Gas	6	0.6		
01/23/2022 11:15 01/23/2022 13:55 Warm Start - Gas	161	215.2		
01/23/2022 23:23 01/23/2022 23:28 Shut Down - Gas	6	0.6		
01/24/2022 03:49 01/24/2022 04:50 Hot Start - Gas	62	107.3		
01/25/2022 08:40 01/25/2022 08:44 Shut Down - Gas	5	0.3		

100scf Per Event Report

CT1 - GasFlowTotal 100scf



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION

Generated: 04/11/2022 06:47

Location: Maxwell, CA

Tag Name: CT1_GasFlowTot_Event_100scf_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 937.60 Hours

Non-Operating Time: 1,222.40 Hours

Report Time: 2,160.00 Hours

Event Period			Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Code - Description	Code - Description
01/25/2022 15:32 01/25/2022 16:43 Hot Start - Gas	72	107.7		
01/26/2022 08:38 01/26/2022 08:43 Shut Down - Gas	6	0.7		
01/26/2022 15:32 01/26/2022 16:42 Hot Start - Gas	71	105.6		
01/27/2022 10:20 01/27/2022 10:25 Shut Down - Gas	6	0.6		
01/27/2022 15:32 01/27/2022 16:43 Hot Start - Gas	72	108.9		
01/30/2022 07:40 01/30/2022 07:45 Shut Down - Gas	6	0.5		
01/31/2022 02:17 01/31/2022 03:49 Warm Start - Gas	93	139.4		
01/31/2022 23:23 01/31/2022 23:28 Shut Down - Gas	6	0.8		
02/01/2022 05:07 02/01/2022 06:28 Hot Start - Gas	82	136.7		
02/02/2022 10:19 02/02/2022 10:24 Shut Down - Gas	6	0.8		
02/02/2022 15:46 02/02/2022 17:03 Hot Start - Gas	78	135.7		
02/04/2022 08:23 02/04/2022 08:28 Shut Down - Gas	6	0.5		
02/04/2022 16:01 02/04/2022 17:11 Hot Start - Gas	71	136.1		
02/05/2022 08:24 02/05/2022 08:29 Shut Down - Gas	6	0.9		

100scf Per Event Report

CT1 - GasFlowTotal 100scf



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION

Generated: 04/11/2022 06:47

Location: Maxwell, CA

Tag Name: CT1_GasFlowTot_Event_100scf_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 937.60 Hours

Non-Operating Time: 1,222.40 Hours

Report Time: 2,160.00 Hours

Event Period			Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Code - Description	Code - Description
02/05/2022 13:37 02/05/2022 14:49 Hot Start - Gas	73	118.4		
02/06/2022 08:06 02/06/2022 08:10 Shut Down - Gas	5	0.4		
02/06/2022 14:33 02/06/2022 15:49 Hot Start - Gas	77	121.1		
02/06/2022 23:05 02/06/2022 23:10 Shut Down - Gas	6	1.0		
02/07/2022 11:18 02/07/2022 13:51 Warm Start - Gas	154	183.5		
02/07/2022 23:23 02/07/2022 23:28 Shut Down - Gas	6	0.7		
02/08/2022 03:18 02/08/2022 04:24 Hot Start - Gas	67	101.1		
02/10/2022 08:08 02/10/2022 08:13 Shut Down - Gas	6	1.0		
02/10/2022 11:50 02/10/2022 12:54 Hot Start - Gas	65	113.7		
02/11/2022 01:04 02/11/2022 01:09 Shut Down - Gas	6	1.0		
02/18/2022 08:50 02/18/2022 12:43 Cold Start - Gas	234	334.5		
02/19/2022 00:24 02/19/2022 00:28 Shut Down - Gas	5	0.2		
02/21/2022 23:18 02/22/2022 01:58 Warm Start - Gas	161	204.3		
02/26/2022 07:23 02/26/2022 07:28 Shut Down - Gas	6	0.8		

100scf Per Event Report

CT1 - GasFlowTotal 100scf



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION

Generated: 04/11/2022 06:47 Location: Maxwell, CA

Tag Name: CT1_GasFlowTot_Event_100scf_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 937.60 Hours

Non-Operating Time: 1,222.40 Hours Report Time: 2,160.00 Hours

Event Period			Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Code - Description	Code - Description
02/26/2022 15:37 02/26/2022 16:51 Warm Start - Gas	75	118.2		
02/26/2022 23:24 02/26/2022 23:28 Shut Down - Gas	5	0.5		
02/28/2022 13:13 02/28/2022 15:49 Warm Start - Gas	157	197.8		
02/28/2022 22:08 02/28/2022 22:13 Shut Down - Gas	6	0.9		

No excess emissions were found in the reporting period.

100scf Per Event Report

CT1 - GasFlowTotal 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 06:47 **Location:** Maxwell, CA
Tag Name: CT1_GasFlowTot_Event_100scf_1M SI = SampleInvalid, * = Excess Emission
Total Operating Time: 937.60 Hours
Non-Operating Time: 1,222.40 Hours Report Time: 2,160.00 Hours

Event Invalid Information

No invalid events were found in the reporting period.

100scf Per Event Report

CT1 - GasFlowTotal 100scf



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION

Generated: 04/11/2022 06:47 Location: Maxwell, CA

Tag Name: CT1_GasFlowTot_Event_100scf_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 937.60 Hours

Non-Operating Time: 1,222.40 Hours Report Time: 2,160.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary

1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary

1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime in Minute(s)	0
3. Total Downtime as a percentage of operating time	0.00
4. Total Availability as a percentage of operating time	100.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/01/2022 00:00	0.0	0	0	0	0	1
01/01/2022 01:00	0.0	0	0	0	0	1
01/01/2022 02:00	0.0	0	0	0	0	1
01/01/2022 03:00	0.0	0	0	0	0	1
01/01/2022 04:00	0.0	0	0	0	0	1
01/01/2022 05:00	0.0	0	0	0	0	1
01/01/2022 06:00	0.0	0	0	0	0	1
01/01/2022 07:00	0.0	0	0	0	0	1
01/01/2022 08:00	0.0	0	0	0	0	1
01/01/2022 09:00	0.0	0	0	0	0	1
01/01/2022 10:00	0.0	0	0	0	0	1
01/01/2022 11:00	0.0	0	0	0	0	1
01/01/2022 12:00	0.0	0	0	0	0	1
01/01/2022 13:00	0.0	0	0	0	0	1
01/01/2022 14:00	0.0	0	0	0	0	1
01/01/2022 15:00	0.0	0	0	0	0	1
01/01/2022 16:00	0.0	0	0	0	0	1
01/01/2022 17:00	0.0	0	0	0	0	1
01/01/2022 18:00	0.0	0	0	0	0	1
01/01/2022 19:00	0.0	0	0	0	0	1
01/01/2022 20:00	0.0	0	0	0	0	1
01/01/2022 21:00	0.0	0	0	0	0	1
01/01/2022 22:00	0.0	0	0	0	0	1
01/01/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/02/2022 00:00	0.0	0	0	0	0	1
01/02/2022 01:00	0.0	0	0	0	0	1
01/02/2022 02:00	0.0	0	0	0	0	1
01/02/2022 03:00	0.0	0	0	0	0	1
01/02/2022 04:00	0.0	0	0	0	0	1
01/02/2022 05:00	0.0	0	0	0	0	1
01/02/2022 06:00	0.0	0	0	0	0	1
01/02/2022 07:00	0.0	0	0	0	0	1
01/02/2022 08:00	0.0	0	0	0	0	1
01/02/2022 09:00	0.0	0	0	0	0	1
01/02/2022 10:00	0.0	0	0	0	0	1
01/02/2022 11:00	0.0	0	0	0	0	1
01/02/2022 12:00	0.0	0	0	0	0	1
01/02/2022 13:00	0.0	0	0	0	0	1
01/02/2022 14:00	0.0	0	0	0	0	1
01/02/2022 15:00	0.0	0	0	0	0	1
01/02/2022 16:00	0.0	0	0	0	0	1
01/02/2022 17:00	0.0	0	0	0	0	1
01/02/2022 18:00	0.0	0	0	0	0	1
01/02/2022 19:00	0.0	0	0	0	0	1
01/02/2022 20:00	0.0	0	0	0	0	1
01/02/2022 21:00	0.0	0	0	0	0	1
01/02/2022 22:00	0.0	0	0	0	0	1
01/02/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/03/2022 00:00	0.0	0	0	0	0	1
01/03/2022 01:00	0.0	0	0	0	0	1
01/03/2022 02:00	0.0	0	0	0	0	1
01/03/2022 03:00	0.0	0	0	0	0	1
01/03/2022 04:00	0.0	0	0	0	0	1
01/03/2022 05:00	0.0	0	0	0	0	1
01/03/2022 06:00	0.0	0	0	0	0	1
01/03/2022 07:00	0.0	0	0	0	0	1
01/03/2022 08:00	0.0	0	0	0	0	1
01/03/2022 09:00	0.0	0	0	0	0	1
01/03/2022 10:00	0.0	0	0	0	0	1
01/03/2022 11:00	0.0	0	0	0	0	1
01/03/2022 12:00	0.0	0	0	0	0	1
01/03/2022 13:00	0.0	0	0	0	0	1
01/03/2022 14:00	0.0	0	0	0	0	1
01/03/2022 15:00	0.0	0	0	0	0	1
01/03/2022 16:00	0.0	0	0	0	0	1
01/03/2022 17:00	0.0	0	0	0	0	1
01/03/2022 18:00	0.0	0	0	0	0	1
01/03/2022 19:00	0.0	0	0	0	0	1
01/03/2022 20:00	0.0	0	0	0	0	1
01/03/2022 21:00	0.0	0	0	0	0	1
01/03/2022 22:00	0.0	0	0	0	0	1
01/03/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/04/2022 00:00	0.0	0	0	0	0	1
01/04/2022 01:00	0.0	0	0	0	0	1
01/04/2022 02:00	0.0	0	0	0	0	1
01/04/2022 03:00	0.0	0	0	0	0	1
01/04/2022 04:00	0.0	0	0	0	0	1
01/04/2022 05:00	0.0	0	0	0	0	1
01/04/2022 06:00	0.0	0	0	0	0	1
01/04/2022 07:00	0.0	0	0	0	0	1
01/04/2022 08:00	0.0	0	0	0	0	1
01/04/2022 09:00	0.0	0	0	0	0	1
01/04/2022 10:00	0.0	0	0	0	0	1
01/04/2022 11:00	0.0	0	0	0	0	1
01/04/2022 12:00	0.0	0	0	0	0	1
01/04/2022 13:00	0.0	0	0	0	0	1
01/04/2022 14:00	0.0	0	0	0	0	1
01/04/2022 15:00	0.0	0	0	0	0	1
01/04/2022 16:00	0.0	0	0	0	0	1
01/04/2022 17:00	0.0	0	0	0	0	1
01/04/2022 18:00	0.0	0	0	0	0	1
01/04/2022 19:00	0.0	0	0	0	0	1
01/04/2022 20:00	0.0	0	0	0	0	1
01/04/2022 21:00	0.0	0	0	0	0	1
01/04/2022 22:00	0.0	0	0	0	0	1
01/04/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/05/2022 00:00	0.0	0	0	0	0	1
01/05/2022 01:00	0.0	0	0	0	0	1
01/05/2022 02:00	0.0	0	0	0	0	1
01/05/2022 03:00	0.0	0	0	0	0	1
01/05/2022 04:00	0.0	0	0	0	0	1
01/05/2022 05:00	0.0	0	0	0	0	1
01/05/2022 06:00	0.0	0	0	0	0	1
01/05/2022 07:00	0.0	0	0	0	0	1
01/05/2022 08:00	0.0	0	0	0	0	1
01/05/2022 09:00	0.0	0	0	0	0	1
01/05/2022 10:00	0.0	0	0	0	0	1
01/05/2022 11:00	0.0	0	0	0	0	1
01/05/2022 12:00	0.0	0	0	0	0	1
01/05/2022 13:00	0.0	0	0	0	0	1
01/05/2022 14:00	0.0	0	0	0	0	1
01/05/2022 15:00	0.0	0	0	0	0	1
01/05/2022 16:00	0.0	0	0	0	0	1
01/05/2022 17:00	0.0	0	0	0	0	1
01/05/2022 18:00	0.0	0	0	0	0	1
01/05/2022 19:00	0.0	0	0	0	0	1
01/05/2022 20:00	0.0	0	0	0	0	1
01/05/2022 21:00	0.0	0	0	0	0	1
01/05/2022 22:00	0.0	0	0	0	0	1
01/05/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/06/2022 00:00	0.0	0	0	0	0	1
01/06/2022 01:00	0.0	0	0	0	0	1
01/06/2022 02:00	0.0	0	0	0	0	1
01/06/2022 03:00	0.0	0	0	0	0	1
01/06/2022 04:00	0.0	0	0	0	0	1
01/06/2022 05:00	0.0	0	0	0	0	1
01/06/2022 06:00	0.0	0	0	0	0	1
01/06/2022 07:00	0.0	0	0	0	0	1
01/06/2022 08:00	0.0	0	0	0	0	1
01/06/2022 09:00	0.0	0	0	0	0	1
01/06/2022 10:00	0.0	0	0	0	0	1
01/06/2022 11:00	0.0	0	0	0	0	1
01/06/2022 12:00	0.0	0	0	0	0	1
01/06/2022 13:00	0.0	0	0	0	0	1
01/06/2022 14:00	0.0	0	0	0	0	1
01/06/2022 15:00	0.0	0	0	0	0	1
01/06/2022 16:00	0.0	0	0	0	0	1
01/06/2022 17:00	0.0	0	0	0	0	1
01/06/2022 18:00	0.0	0	0	0	0	1
01/06/2022 19:00	0.0	0	0	0	0	1
01/06/2022 20:00	0.0	0	0	0	0	1
01/06/2022 21:00	0.0	0	0	0	0	1
01/06/2022 22:00	0.0	0	0	0	0	1
01/06/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/07/2022 00:00	0.0	0	0	0	0	1
01/07/2022 01:00	0.0	0	0	0	0	1
01/07/2022 02:00	0.0	0	0	0	0	1
01/07/2022 03:00	0.0	0	0	0	0	1
01/07/2022 04:00	0.0	0	0	0	0	1
01/07/2022 05:00	0.0	0	0	0	0	1
01/07/2022 06:00	0.0	0	0	0	0	1
01/07/2022 07:00	0.0	0	0	0	0	1
01/07/2022 08:00	0.0	0	0	0	0	1
01/07/2022 09:00	0.0	0	0	0	0	1
01/07/2022 10:00	0.0	0	0	0	0	1
01/07/2022 11:00	0.0	0	0	0	0	1
01/07/2022 12:00	0.0	0	0	0	0	1
01/07/2022 13:00	0.0	0	0	0	0	1
01/07/2022 14:00	0.0	0	0	0	0	1
01/07/2022 15:00	0.0	0	0	0	0	1
01/07/2022 16:00	0.0	0	0	0	0	1
01/07/2022 17:00	0.0	0	0	0	0	1
01/07/2022 18:00	0.0	0	0	0	0	1
01/07/2022 19:00	0.0	0	0	0	0	1
01/07/2022 20:00	0.0	0	0	0	0	1
01/07/2022 21:00	0.0	0	0	0	0	1
01/07/2022 22:00	2.7	0	0	0	1	0
01/07/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	2.7 #	0 #	0 #	0 #	1 #	22 #
Minimum:	0.0	0	0	0	0	0
Maximum:	2.7	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/08/2022 00:00	0.0	0	0	0	0	0
01/08/2022 01:00	0.0	0	0	0	0	0
01/08/2022 02:00	0.0	0	0	0	0	0
01/08/2022 03:00	0.0	0	0	0	0	0
01/08/2022 04:00	0.0	0	0	0	0	0
01/08/2022 05:00	0.0	0	0	0	0	0
01/08/2022 06:00	0.0	0	0	0	0	0
01/08/2022 07:00	0.0	0	0	0	0	0
01/08/2022 08:00	0.0	0	0	0	0	0
01/08/2022 09:00	0.0	0	0	0	0	0
01/08/2022 10:00	40.4	0	1	0	0	0
01/08/2022 11:00	29.9	0	1	0	0	0
01/08/2022 12:00	54.0	0	1	0	0	0
01/08/2022 13:00	0.0	0	0	0	0	1
01/08/2022 14:00	0.0	0	0	0	0	1
01/08/2022 15:00	0.0	0	0	0	0	1
01/08/2022 16:00	0.0	0	0	0	0	1
01/08/2022 17:00	0.0	0	0	0	0	1
01/08/2022 18:00	0.0	0	0	0	0	1
01/08/2022 19:00	0.0	0	0	0	0	1
01/08/2022 20:00	0.0	0	0	0	0	1
01/08/2022 21:00	0.0	0	0	0	0	1
01/08/2022 22:00	0.0	0	0	0	0	1
01/08/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	124.3 #	0 #	3 #	0 #	0 #	11 #
Minimum:	0.0	0	0	0	0	0
Maximum:	54.0	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/09/2022 00:00	0.0	0	0	0	0	1
01/09/2022 01:00	0.0	0	0	0	0	1
01/09/2022 02:00	0.0	0	0	0	0	1
01/09/2022 03:00	0.0	0	0	0	0	1
01/09/2022 04:00	0.0	0	0	0	0	1
01/09/2022 05:00	0.0	0	0	0	0	1
01/09/2022 06:00	0.0	0	0	0	0	1
01/09/2022 07:00	0.0	0	0	0	0	1
01/09/2022 08:00	0.0	0	0	0	0	1
01/09/2022 09:00	0.0	0	0	0	0	1
01/09/2022 10:00	0.0	0	0	0	0	1
01/09/2022 11:00	0.0	0	0	0	0	1
01/09/2022 12:00	0.0	0	0	0	0	1
01/09/2022 13:00	0.0	0	0	0	0	1
01/09/2022 14:00	0.0	0	0	0	0	1
01/09/2022 15:00	0.0	0	0	0	0	1
01/09/2022 16:00	0.0	0	0	0	0	1
01/09/2022 17:00	0.0	0	0	0	0	1
01/09/2022 18:00	0.0	0	0	0	0	1
01/09/2022 19:00	0.0	0	0	0	0	1
01/09/2022 20:00	0.0	0	0	0	0	1
01/09/2022 21:00	0.0	0	0	0	0	1
01/09/2022 22:00	0.0	0	0	0	0	1
01/09/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/10/2022 00:00	0.0	0	0	0	0	1
01/10/2022 01:00	0.0	0	0	0	0	1
01/10/2022 02:00	0.0	0	0	0	0	1
01/10/2022 03:00	0.0	0	0	0	0	1
01/10/2022 04:00	0.0	0	0	0	0	1
01/10/2022 05:00	0.0	0	0	0	0	1
01/10/2022 06:00	0.0	0	0	0	0	1
01/10/2022 07:00	0.0	0	0	0	0	1
01/10/2022 08:00	0.0	0	0	0	0	1
01/10/2022 09:00	0.0	0	0	0	0	1
01/10/2022 10:00	0.0	0	0	0	0	1
01/10/2022 11:00	0.0	0	0	0	0	1
01/10/2022 12:00	0.0	0	0	0	0	1
01/10/2022 13:00	0.0	0	0	0	0	1
01/10/2022 14:00	0.0	0	0	0	0	1
01/10/2022 15:00	0.0	0	0	0	0	1
01/10/2022 16:00	0.0	0	0	0	0	1
01/10/2022 17:00	0.0	0	0	0	0	1
01/10/2022 18:00	0.0	0	0	0	0	1
01/10/2022 19:00	0.0	0	0	0	0	1
01/10/2022 20:00	0.0	0	0	0	0	1
01/10/2022 21:00	0.0	0	0	0	0	1
01/10/2022 22:00	0.0	0	0	0	0	1
01/10/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/11/2022 00:00	0.0	0	0	0	0	1
01/11/2022 01:00	0.0	0	0	0	0	1
01/11/2022 02:00	0.0	0	0	0	0	1
01/11/2022 03:00	0.0	0	0	0	0	1
01/11/2022 04:00	0.0	0	0	0	0	1
01/11/2022 05:00	0.0	0	0	0	0	1
01/11/2022 06:00	0.0	0	0	0	0	1
01/11/2022 07:00	0.0	0	0	0	0	1
01/11/2022 08:00	0.0	0	0	0	0	1
01/11/2022 09:00	0.0	0	0	0	0	1
01/11/2022 10:00	0.0	0	0	0	0	1
01/11/2022 11:00	0.0	0	0	0	0	1
01/11/2022 12:00	0.0	0	0	0	0	1
01/11/2022 13:00	0.0	0	0	0	0	1
01/11/2022 14:00	0.0	0	0	0	0	1
01/11/2022 15:00	0.0	0	0	0	0	1
01/11/2022 16:00	0.0	0	0	0	0	1
01/11/2022 17:00	0.0	0	0	0	0	1
01/11/2022 18:00	0.0	0	0	0	0	1
01/11/2022 19:00	0.0	0	0	0	0	1
01/11/2022 20:00	0.0	0	0	0	0	1
01/11/2022 21:00	0.0	0	0	0	0	1
01/11/2022 22:00	0.0	0	0	0	0	1
01/11/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/12/2022 00:00	0.0	0	0	0	0	1
01/12/2022 01:00	0.0	0	0	0	0	1
01/12/2022 02:00	0.0	0	0	0	0	1
01/12/2022 03:00	0.0	0	0	0	0	1
01/12/2022 04:00	0.0	0	0	0	0	1
01/12/2022 05:00	0.0	0	0	0	0	1
01/12/2022 06:00	0.0	0	0	0	0	1
01/12/2022 07:00	0.0	0	0	0	0	1
01/12/2022 08:00	0.0	0	0	0	0	1
01/12/2022 09:00	0.0	0	0	0	0	1
01/12/2022 10:00	0.0	0	0	0	0	1
01/12/2022 11:00	0.0	0	0	0	0	1
01/12/2022 12:00	0.0	0	0	0	0	1
01/12/2022 13:00	0.0	0	0	0	0	1
01/12/2022 14:00	0.0	0	0	0	0	1
01/12/2022 15:00	0.0	0	0	0	0	1
01/12/2022 16:00	0.0	0	0	0	0	1
01/12/2022 17:00	0.0	0	0	0	0	1
01/12/2022 18:00	0.0	0	0	0	0	1
01/12/2022 19:00	0.0	0	0	0	0	1
01/12/2022 20:00	0.0	0	0	0	0	1
01/12/2022 21:00	0.0	0	0	0	0	1
01/12/2022 22:00	0.0	0	0	0	0	1
01/12/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/13/2022 00:00	0.0	0	0	0	0	1
01/13/2022 01:00	0.0	0	0	0	0	1
01/13/2022 02:00	0.0	0	0	0	0	1
01/13/2022 03:00	0.0	0	0	0	0	1
01/13/2022 04:00	0.0	0	0	0	0	1
01/13/2022 05:00	0.0	0	0	0	0	1
01/13/2022 06:00	0.0	0	0	0	0	1
01/13/2022 07:00	0.0	0	0	0	0	1
01/13/2022 08:00	0.0	0	0	0	0	1
01/13/2022 09:00	0.0	0	0	0	0	1
01/13/2022 10:00	0.0	0	0	0	0	1
01/13/2022 11:00	0.0	0	0	0	0	1
01/13/2022 12:00	0.0	0	0	0	0	1
01/13/2022 13:00	0.0	0	0	0	0	1
01/13/2022 14:00	0.0	0	0	0	0	1
01/13/2022 15:00	0.0	0	0	0	0	1
01/13/2022 16:00	0.0	0	0	0	0	1
01/13/2022 17:00	0.0	0	0	0	0	1
01/13/2022 18:00	0.0	0	0	0	0	1
01/13/2022 19:00	0.0	0	0	0	0	1
01/13/2022 20:00	0.0	0	0	0	0	1
01/13/2022 21:00	0.0	0	0	0	0	1
01/13/2022 22:00	0.0	0	0	0	0	1
01/13/2022 23:00	2.6	0	0	0	1	0
Average/Sum#:	2.6 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	2.6	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/14/2022 00:00	0.0	0	0	0	0	0
01/14/2022 01:00	0.0	0	0	0	0	0
01/14/2022 02:00	0.0	0	0	0	0	0
01/14/2022 03:00	0.0	0	0	0	0	0
01/14/2022 04:00	6.8	0	0	1	0	0
01/14/2022 05:00	78.8	0	0	1	0	0
01/14/2022 06:00	0.0	0	0	0	0	1
01/14/2022 07:00	0.0	0	0	0	0	1
01/14/2022 08:00	0.0	0	0	0	0	1
01/14/2022 09:00	0.0	0	0	0	0	1
01/14/2022 10:00	0.0	0	0	0	0	1
01/14/2022 11:00	0.0	0	0	0	0	1
01/14/2022 12:00	0.0	0	0	0	0	1
01/14/2022 13:00	0.0	0	0	0	0	1
01/14/2022 14:00	0.0	0	0	0	0	1
01/14/2022 15:00	0.0	0	0	0	0	1
01/14/2022 16:00	0.0	0	0	0	0	1
01/14/2022 17:00	0.0	0	0	0	0	1
01/14/2022 18:00	0.0	0	0	0	0	1
01/14/2022 19:00	0.0	0	0	0	0	1
01/14/2022 20:00	0.0	0	0	0	0	1
01/14/2022 21:00	0.0	0	0	0	0	1
01/14/2022 22:00	0.0	0	0	0	0	1
01/14/2022 23:00	3.0	0	0	0	1	0
Average/Sum#:	88.6 #	0 #	0 #	2 #	1 #	17 #
Minimum:	0.0	0	0	0	0	0
Maximum:	78.8	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/15/2022 00:00	0.0	0	0	0	0	0
01/15/2022 01:00	0.0	0	0	0	0	0
01/15/2022 02:00	0.0	0	0	0	0	0
01/15/2022 03:00	0.0	0	0	0	0	0
01/15/2022 04:00	4.9	0	0	1	0	0
01/15/2022 05:00	87.4	0	0	1	0	0
01/15/2022 06:00	0.0	0	0	0	0	1
01/15/2022 07:00	0.0	0	0	0	0	1
01/15/2022 08:00	0.0	0	0	0	0	1
01/15/2022 09:00	0.0	0	0	0	0	1
01/15/2022 10:00	0.0	0	0	0	0	1
01/15/2022 11:00	0.0	0	0	0	0	1
01/15/2022 12:00	0.0	0	0	0	0	1
01/15/2022 13:00	0.0	0	0	0	0	1
01/15/2022 14:00	0.0	0	0	0	0	1
01/15/2022 15:00	0.0	0	0	0	0	1
01/15/2022 16:00	0.0	0	0	0	0	1
01/15/2022 17:00	0.0	0	0	0	0	1
01/15/2022 18:00	0.0	0	0	0	0	1
01/15/2022 19:00	0.0	0	0	0	0	1
01/15/2022 20:00	0.0	0	0	0	0	1
01/15/2022 21:00	0.0	0	0	0	0	1
01/15/2022 22:00	0.0	0	0	0	0	1
01/15/2022 23:00	1.9	0	0	0	1	0
Average/Sum#:	94.2 #	0 #	0 #	2 #	1 #	17 #
Minimum:	0.0	0	0	0	0	0
Maximum:	87.4	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/16/2022 00:00	0.0	0	0	0	0	0
01/16/2022 01:00	0.0	0	0	0	0	0
01/16/2022 02:00	0.0	0	0	0	0	0
01/16/2022 03:00	0.0	0	0	0	0	0
01/16/2022 04:00	0.0	0	0	0	0	0
01/16/2022 05:00	0.0	0	0	0	0	0
01/16/2022 06:00	0.0	0	0	0	0	0
01/16/2022 07:00	0.0	0	0	0	0	0
01/16/2022 08:00	0.0	0	0	0	0	0
01/16/2022 09:00	0.0	0	0	0	0	0
01/16/2022 10:00	0.0	0	0	0	0	0
01/16/2022 11:00	51.0	0	1	0	0	0
01/16/2022 12:00	83.4	0	1	0	0	0
01/16/2022 13:00	0.0	0	0	0	0	1
01/16/2022 14:00	0.0	0	0	0	0	1
01/16/2022 15:00	0.0	0	0	0	0	1
01/16/2022 16:00	0.0	0	0	0	0	1
01/16/2022 17:00	0.0	0	0	0	0	1
01/16/2022 18:00	0.0	0	0	0	0	1
01/16/2022 19:00	0.0	0	0	0	0	1
01/16/2022 20:00	0.0	0	0	0	0	1
01/16/2022 21:00	0.0	0	0	0	0	1
01/16/2022 22:00	0.0	0	0	0	0	1
01/16/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	134.4 #	0 #	2 #	0 #	0 #	11 #
Minimum:	0.0	0	0	0	0	0
Maximum:	83.4	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/17/2022 00:00	0.0	0	0	0	0	1
01/17/2022 01:00	0.0	0	0	0	0	1
01/17/2022 02:00	0.0	0	0	0	0	1
01/17/2022 03:00	0.0	0	0	0	0	1
01/17/2022 04:00	0.0	0	0	0	0	1
01/17/2022 05:00	0.0	0	0	0	0	1
01/17/2022 06:00	0.0	0	0	0	0	1
01/17/2022 07:00	0.0	0	0	0	0	1
01/17/2022 08:00	0.0	0	0	0	0	1
01/17/2022 09:00	0.0	0	0	0	0	1
01/17/2022 10:00	0.0	0	0	0	0	1
01/17/2022 11:00	0.0	0	0	0	0	1
01/17/2022 12:00	0.0	0	0	0	0	1
01/17/2022 13:00	0.0	0	0	0	0	1
01/17/2022 14:00	0.0	0	0	0	0	1
01/17/2022 15:00	0.0	0	0	0	0	1
01/17/2022 16:00	0.0	0	0	0	0	1
01/17/2022 17:00	0.0	0	0	0	0	1
01/17/2022 18:00	0.0	0	0	0	0	1
01/17/2022 19:00	0.0	0	0	0	0	1
01/17/2022 20:00	0.0	0	0	0	0	1
01/17/2022 21:00	0.0	0	0	0	0	1
01/17/2022 22:00	0.0	0	0	0	0	1
01/17/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/18/2022 00:00	0.0	0	0	0	0	1
01/18/2022 01:00	0.0	0	0	0	0	1
01/18/2022 02:00	0.0	0	0	0	0	1
01/18/2022 03:00	0.0	0	0	0	0	1
01/18/2022 04:00	0.0	0	0	0	0	1
01/18/2022 05:00	0.0	0	0	0	0	1
01/18/2022 06:00	0.0	0	0	0	0	1
01/18/2022 07:00	0.0	0	0	0	0	1
01/18/2022 08:00	0.0	0	0	0	0	1
01/18/2022 09:00	0.0	0	0	0	0	1
01/18/2022 10:00	0.0	0	0	0	0	1
01/18/2022 11:00	0.0	0	0	0	0	1
01/18/2022 12:00	0.0	0	0	0	0	1
01/18/2022 13:00	0.0	0	0	0	0	1
01/18/2022 14:00	0.0	0	0	0	0	1
01/18/2022 15:00	0.0	0	0	0	0	1
01/18/2022 16:00	0.0	0	0	0	0	1
01/18/2022 17:00	0.0	0	0	0	0	1
01/18/2022 18:00	0.0	0	0	0	0	1
01/18/2022 19:00	0.0	0	0	0	0	1
01/18/2022 20:00	0.0	0	0	0	0	1
01/18/2022 21:00	0.0	0	0	0	0	1
01/18/2022 22:00	0.0	0	0	0	0	1
01/18/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/19/2022 00:00	0.0	0	0	0	0	1
01/19/2022 01:00	0.0	0	0	0	0	1
01/19/2022 02:00	0.0	0	0	0	0	1
01/19/2022 03:00	0.0	0	0	0	0	1
01/19/2022 04:00	0.0	0	0	0	0	1
01/19/2022 05:00	0.0	0	0	0	0	1
01/19/2022 06:00	0.0	0	0	0	0	1
01/19/2022 07:00	0.0	0	0	0	0	1
01/19/2022 08:00	0.0	0	0	0	0	1
01/19/2022 09:00	0.0	0	0	0	0	1
01/19/2022 10:00	0.0	0	0	0	0	1
01/19/2022 11:00	0.0	0	0	0	0	1
01/19/2022 12:00	0.0	0	0	0	0	1
01/19/2022 13:00	0.0	0	0	0	0	1
01/19/2022 14:00	0.0	0	0	0	0	1
01/19/2022 15:00	0.0	0	0	0	0	1
01/19/2022 16:00	0.0	0	0	0	0	1
01/19/2022 17:00	0.0	0	0	0	0	1
01/19/2022 18:00	0.0	0	0	0	0	1
01/19/2022 19:00	0.0	0	0	0	0	1
01/19/2022 20:00	0.0	0	0	0	0	1
01/19/2022 21:00	0.0	0	0	0	0	1
01/19/2022 22:00	0.0	0	0	0	0	1
01/19/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/20/2022 00:00	0.0	0	0	0	0	1
01/20/2022 01:00	0.0	0	0	0	0	1
01/20/2022 02:00	0.0	0	0	0	0	1
01/20/2022 03:00	0.0	0	0	0	0	1
01/20/2022 04:00	0.0	0	0	0	0	1
01/20/2022 05:00	0.0	0	0	0	0	1
01/20/2022 06:00	0.0	0	0	0	0	1
01/20/2022 07:00	0.0	0	0	0	0	1
01/20/2022 08:00	0.0	0	0	0	0	1
01/20/2022 09:00	0.0	0	0	0	0	1
01/20/2022 10:00	0.0	0	0	0	0	1
01/20/2022 11:00	0.0	0	0	0	0	1
01/20/2022 12:00	0.0	0	0	0	0	1
01/20/2022 13:00	0.0	0	0	0	0	1
01/20/2022 14:00	0.0	0	0	0	0	1
01/20/2022 15:00	0.0	0	0	0	0	1
01/20/2022 16:00	0.0	0	0	0	0	1
01/20/2022 17:00	0.0	0	0	0	0	1
01/20/2022 18:00	0.0	0	0	0	0	1
01/20/2022 19:00	0.0	0	0	0	0	1
01/20/2022 20:00	0.0	0	0	0	0	1
01/20/2022 21:00	0.0	0	0	0	0	1
01/20/2022 22:00	0.0	0	0	0	0	1
01/20/2022 23:00	1.5	0	0	0	1	0
Average/Sum#:	1.5 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.5	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/21/2022 00:00	0.0	0	0	0	0	0
01/21/2022 01:00	0.0	0	0	0	0	0
01/21/2022 02:00	0.0	0	0	0	0	0
01/21/2022 03:00	0.0	0	0	0	0	0
01/21/2022 04:00	0.0	0	0	0	0	0
01/21/2022 05:00	0.0	0	0	0	0	0
01/21/2022 06:00	0.0	0	0	0	0	0
01/21/2022 07:00	0.0	0	0	0	0	0
01/21/2022 08:00	0.0	0	0	0	0	0
01/21/2022 09:00	0.0	0	0	0	0	0
01/21/2022 10:00	0.0	0	0	0	0	0
01/21/2022 11:00	0.0	0	0	0	0	0
01/21/2022 12:00	0.0	0	0	0	0	0
01/21/2022 13:00	0.0	0	0	0	0	0
01/21/2022 14:00	0.0	0	0	0	0	0
01/21/2022 15:00	0.0	0	0	0	0	0
01/21/2022 16:00	0.0	0	0	0	0	0
01/21/2022 17:00	0.0	0	0	0	0	0
01/21/2022 18:00	0.0	0	0	0	0	0
01/21/2022 19:00	0.0	0	0	0	0	0
01/21/2022 20:00	0.0	0	0	0	0	0
01/21/2022 21:00	0.0	0	0	0	0	0
01/21/2022 22:00	0.0	0	0	0	0	0
01/21/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/22/2022 00:00	0.0	0	0	0	0	0
01/22/2022 01:00	0.0	0	0	0	0	0
01/22/2022 02:00	0.0	0	0	0	0	0
01/22/2022 03:00	0.0	0	0	0	0	0
01/22/2022 04:00	0.0	0	0	0	0	0
01/22/2022 05:00	0.0	0	0	0	0	0
01/22/2022 06:00	0.0	0	0	0	0	0
01/22/2022 07:00	0.0	0	0	0	0	0
01/22/2022 08:00	0.0	0	0	0	0	0
01/22/2022 09:00	0.0	0	0	0	0	0
01/22/2022 10:00	0.0	0	0	0	0	0
01/22/2022 11:00	0.0	0	0	0	0	0
01/22/2022 12:00	0.0	0	0	0	0	0
01/22/2022 13:00	0.0	0	0	0	0	0
01/22/2022 14:00	0.0	0	0	0	0	0
01/22/2022 15:00	0.0	0	0	0	0	0
01/22/2022 16:00	0.0	0	0	0	0	0
01/22/2022 17:00	0.0	0	0	0	0	0
01/22/2022 18:00	0.0	0	0	0	0	0
01/22/2022 19:00	0.0	0	0	0	0	0
01/22/2022 20:00	0.0	0	0	0	0	0
01/22/2022 21:00	0.0	0	0	0	0	0
01/22/2022 22:00	0.0	0	0	0	0	0
01/22/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/23/2022 00:00	0.0	0	0	0	0	0
01/23/2022 01:00	0.0	0	0	0	0	0
01/23/2022 02:00	0.0	0	0	0	0	0
01/23/2022 03:00	0.0	0	0	0	0	0
01/23/2022 04:00	0.0	0	0	0	0	0
01/23/2022 05:00	0.0	0	0	0	0	0
01/23/2022 06:00	0.0	0	0	0	0	0
01/23/2022 07:00	0.0	0	0	0	0	0
01/23/2022 08:00	0.0	0	0	0	0	0
01/23/2022 09:00	0.0	0	0	0	0	0
01/23/2022 10:00	0.0	0	0	0	0	0
01/23/2022 11:00	61.7	0	1	0	0	0
01/23/2022 12:00	24.1	0	1	0	0	0
01/23/2022 13:00	71.0	0	1	0	0	0
01/23/2022 14:00	0.0	0	0	0	0	1
01/23/2022 15:00	0.0	0	0	0	0	1
01/23/2022 16:00	0.0	0	0	0	0	1
01/23/2022 17:00	0.0	0	0	0	0	1
01/23/2022 18:00	0.0	0	0	0	0	1
01/23/2022 19:00	0.0	0	0	0	0	1
01/23/2022 20:00	0.0	0	0	0	0	1
01/23/2022 21:00	0.0	0	0	0	0	1
01/23/2022 22:00	0.0	0	0	0	0	1
01/23/2022 23:00	2.7	0	0	0	1	0
Average/Sum#:	159.5 #	0 #	3 #	0 #	1 #	9 #
Minimum:	0.0	0	0	0	0	0
Maximum:	71.0	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/24/2022 00:00	0.0	0	0	0	0	0
01/24/2022 01:00	0.0	0	0	0	0	0
01/24/2022 02:00	0.0	0	0	0	0	0
01/24/2022 03:00	2.6	0	0	1	0	0
01/24/2022 04:00	92.9	0	0	1	0	0
01/24/2022 05:00	0.0	0	0	0	0	1
01/24/2022 06:00	0.0	0	0	0	0	1
01/24/2022 07:00	0.0	0	0	0	0	1
01/24/2022 08:00	0.0	0	0	0	0	1
01/24/2022 09:00	0.0	0	0	0	0	1
01/24/2022 10:00	0.0	0	0	0	0	1
01/24/2022 11:00	0.0	0	0	0	0	1
01/24/2022 12:00	0.0	0	0	0	0	1
01/24/2022 13:00	0.0	0	0	0	0	1
01/24/2022 14:00	0.0	0	0	0	0	1
01/24/2022 15:00	0.0	0	0	0	0	1
01/24/2022 16:00	0.0	0	0	0	0	1
01/24/2022 17:00	0.0	0	0	0	0	1
01/24/2022 18:00	0.0	0	0	0	0	1
01/24/2022 19:00	0.0	0	0	0	0	1
01/24/2022 20:00	0.0	0	0	0	0	1
01/24/2022 21:00	0.0	0	0	0	0	1
01/24/2022 22:00	0.0	0	0	0	0	1
01/24/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	95.5 #	0 #	0 #	2 #	0 #	19 #
Minimum:	0.0	0	0	0	0	0
Maximum:	92.9	0	0	1	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/25/2022 00:00	0.0	0	0	0	0	1
01/25/2022 01:00	0.0	0	0	0	0	1
01/25/2022 02:00	0.0	0	0	0	0	1
01/25/2022 03:00	0.0	0	0	0	0	1
01/25/2022 04:00	0.0	0	0	0	0	1
01/25/2022 05:00	0.0	0	0	0	0	1
01/25/2022 06:00	0.0	0	0	0	0	1
01/25/2022 07:00	0.0	0	0	0	0	1
01/25/2022 08:00	1.5	0	0	0	1	0
01/25/2022 09:00	0.0	0	0	0	0	0
01/25/2022 10:00	0.0	0	0	0	0	0
01/25/2022 11:00	0.0	0	0	0	0	0
01/25/2022 12:00	0.0	0	0	0	0	0
01/25/2022 13:00	0.0	0	0	0	0	0
01/25/2022 14:00	0.0	0	0	0	0	0
01/25/2022 15:00	15.4	0	0	1	0	0
01/25/2022 16:00	42.0	0	0	1	0	0
01/25/2022 17:00	0.0	0	0	0	0	1
01/25/2022 18:00	0.0	0	0	0	0	1
01/25/2022 19:00	0.0	0	0	0	0	1
01/25/2022 20:00	0.0	0	0	0	0	1
01/25/2022 21:00	0.0	0	0	0	0	1
01/25/2022 22:00	0.0	0	0	0	0	1
01/25/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	58.9 #	0 #	0 #	2 #	1 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	42.0	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/26/2022 00:00	0.0	0	0	0	0	1
01/26/2022 01:00	0.0	0	0	0	0	1
01/26/2022 02:00	0.0	0	0	0	0	1
01/26/2022 03:00	0.0	0	0	0	0	1
01/26/2022 04:00	0.0	0	0	0	0	1
01/26/2022 05:00	0.0	0	0	0	0	1
01/26/2022 06:00	0.0	0	0	0	0	1
01/26/2022 07:00	0.0	0	0	0	0	1
01/26/2022 08:00	2.4	0	0	0	1	0
01/26/2022 09:00	0.0	0	0	0	0	0
01/26/2022 10:00	0.0	0	0	0	0	0
01/26/2022 11:00	0.0	0	0	0	0	0
01/26/2022 12:00	0.0	0	0	0	0	0
01/26/2022 13:00	0.0	0	0	0	0	0
01/26/2022 14:00	0.0	0	0	0	0	0
01/26/2022 15:00	15.6	0	0	1	0	0
01/26/2022 16:00	44.5	0	0	1	0	0
01/26/2022 17:00	0.0	0	0	0	0	1
01/26/2022 18:00	0.0	0	0	0	0	1
01/26/2022 19:00	0.0	0	0	0	0	1
01/26/2022 20:00	0.0	0	0	0	0	1
01/26/2022 21:00	0.0	0	0	0	0	1
01/26/2022 22:00	0.0	0	0	0	0	1
01/26/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	62.5 #	0 #	0 #	2 #	1 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	44.5	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/27/2022 00:00	0.0	0	0	0	0	1
01/27/2022 01:00	0.0	0	0	0	0	1
01/27/2022 02:00	0.0	0	0	0	0	1
01/27/2022 03:00	0.0	0	0	0	0	1
01/27/2022 04:00	0.0	0	0	0	0	1
01/27/2022 05:00	0.0	0	0	0	0	1
01/27/2022 06:00	0.0	0	0	0	0	1
01/27/2022 07:00	0.0	0	0	0	0	1
01/27/2022 08:00	0.0	0	0	0	0	1
01/27/2022 09:00	0.0	0	0	0	0	1
01/27/2022 10:00	2.9	0	0	0	1	0
01/27/2022 11:00	0.0	0	0	0	0	0
01/27/2022 12:00	0.0	0	0	0	0	0
01/27/2022 13:00	0.0	0	0	0	0	0
01/27/2022 14:00	0.0	0	0	0	0	0
01/27/2022 15:00	13.8	0	0	1	0	0
01/27/2022 16:00	42.6	0	0	1	0	0
01/27/2022 17:00	0.0	0	0	0	0	1
01/27/2022 18:00	0.0	0	0	0	0	1
01/27/2022 19:00	0.0	0	0	0	0	1
01/27/2022 20:00	0.0	0	0	0	0	1
01/27/2022 21:00	0.0	0	0	0	0	1
01/27/2022 22:00	0.0	0	0	0	0	1
01/27/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	59.3 #	0 #	0 #	2 #	1 #	17 #
Minimum:	0.0	0	0	0	0	0
Maximum:	42.6	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/28/2022 00:00	0.0	0	0	0	0	1
01/28/2022 01:00	0.0	0	0	0	0	1
01/28/2022 02:00	0.0	0	0	0	0	1
01/28/2022 03:00	0.0	0	0	0	0	1
01/28/2022 04:00	0.0	0	0	0	0	1
01/28/2022 05:00	0.0	0	0	0	0	1
01/28/2022 06:00	0.0	0	0	0	0	1
01/28/2022 07:00	0.0	0	0	0	0	1
01/28/2022 08:00	0.0	0	0	0	0	1
01/28/2022 09:00	0.0	0	0	0	0	1
01/28/2022 10:00	0.0	0	0	0	0	1
01/28/2022 11:00	0.0	0	0	0	0	1
01/28/2022 12:00	0.0	0	0	0	0	1
01/28/2022 13:00	0.0	0	0	0	0	1
01/28/2022 14:00	0.0	0	0	0	0	1
01/28/2022 15:00	0.0	0	0	0	0	1
01/28/2022 16:00	0.0	0	0	0	0	1
01/28/2022 17:00	0.0	0	0	0	0	1
01/28/2022 18:00	0.0	0	0	0	0	1
01/28/2022 19:00	0.0	0	0	0	0	1
01/28/2022 20:00	0.0	0	0	0	0	1
01/28/2022 21:00	0.0	0	0	0	0	1
01/28/2022 22:00	0.0	0	0	0	0	1
01/28/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/29/2022 00:00	0.0	0	0	0	0	1
01/29/2022 01:00	0.0	0	0	0	0	1
01/29/2022 02:00	0.0	0	0	0	0	1
01/29/2022 03:00	0.0	0	0	0	0	1
01/29/2022 04:00	0.0	0	0	0	0	1
01/29/2022 05:00	0.0	0	0	0	0	1
01/29/2022 06:00	0.0	0	0	0	0	1
01/29/2022 07:00	0.0	0	0	0	0	1
01/29/2022 08:00	0.0	0	0	0	0	1
01/29/2022 09:00	0.0	0	0	0	0	1
01/29/2022 10:00	0.0	0	0	0	0	1
01/29/2022 11:00	0.0	0	0	0	0	1
01/29/2022 12:00	0.0	0	0	0	0	1
01/29/2022 13:00	0.0	0	0	0	0	1
01/29/2022 14:00	0.0	0	0	0	0	1
01/29/2022 15:00	0.0	0	0	0	0	1
01/29/2022 16:00	0.0	0	0	0	0	1
01/29/2022 17:00	0.0	0	0	0	0	1
01/29/2022 18:00	0.0	0	0	0	0	1
01/29/2022 19:00	0.0	0	0	0	0	1
01/29/2022 20:00	0.0	0	0	0	0	1
01/29/2022 21:00	0.0	0	0	0	0	1
01/29/2022 22:00	0.0	0	0	0	0	1
01/29/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/30/2022 00:00	0.0	0	0	0	0	1
01/30/2022 01:00	0.0	0	0	0	0	1
01/30/2022 02:00	0.0	0	0	0	0	1
01/30/2022 03:00	0.0	0	0	0	0	1
01/30/2022 04:00	0.0	0	0	0	0	1
01/30/2022 05:00	0.0	0	0	0	0	1
01/30/2022 06:00	0.0	0	0	0	0	1
01/30/2022 07:00	2.2	0	0	0	1	0
01/30/2022 08:00	0.0	0	0	0	0	0
01/30/2022 09:00	0.0	0	0	0	0	0
01/30/2022 10:00	0.0	0	0	0	0	0
01/30/2022 11:00	0.0	0	0	0	0	0
01/30/2022 12:00	0.0	0	0	0	0	0
01/30/2022 13:00	0.0	0	0	0	0	0
01/30/2022 14:00	0.0	0	0	0	0	0
01/30/2022 15:00	0.0	0	0	0	0	0
01/30/2022 16:00	0.0	0	0	0	0	0
01/30/2022 17:00	0.0	0	0	0	0	0
01/30/2022 18:00	0.0	0	0	0	0	0
01/30/2022 19:00	0.0	0	0	0	0	0
01/30/2022 20:00	0.0	0	0	0	0	0
01/30/2022 21:00	0.0	0	0	0	0	0
01/30/2022 22:00	0.0	0	0	0	0	0
01/30/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	2.2 #	0 #	0 #	0 #	1 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	2.2	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/31/2022 00:00	0.0	0	0	0	0	0
01/31/2022 01:00	0.0	0	0	0	0	0
01/31/2022 02:00	60.8	0	1	0	0	0
01/31/2022 03:00	75.0	0	1	0	0	0
01/31/2022 04:00	0.0	0	0	0	0	1
01/31/2022 05:00	0.0	0	0	0	0	1
01/31/2022 06:00	0.0	0	0	0	0	1
01/31/2022 07:00	0.0	0	0	0	0	1
01/31/2022 08:00	0.0	0	0	0	0	1
01/31/2022 09:00	0.0	0	0	0	0	1
01/31/2022 10:00	0.0	0	0	0	0	1
01/31/2022 11:00	0.0	0	0	0	0	1
01/31/2022 12:00	0.0	0	0	0	0	1
01/31/2022 13:00	0.0	0	0	0	0	1
01/31/2022 14:00	0.0	0	0	0	0	1
01/31/2022 15:00	0.0	0	0	0	0	1
01/31/2022 16:00	0.0	0	0	0	0	1
01/31/2022 17:00	0.0	0	0	0	0	1
01/31/2022 18:00	0.0	0	0	0	0	1
01/31/2022 19:00	0.0	0	0	0	0	1
01/31/2022 20:00	0.0	0	0	0	0	1
01/31/2022 21:00	0.0	0	0	0	0	1
01/31/2022 22:00	0.0	0	0	0	0	1
01/31/2022 23:00	2.5	0	0	0	1	0
Average/Sum#:	138.3 #	0 #	2 #	0 #	1 #	19 #
Minimum:	0.0	0	0	0	0	0
Maximum:	75.0	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/01/2022 00:00	0.0	0	0	0	0	0
02/01/2022 01:00	0.0	0	0	0	0	0
02/01/2022 02:00	0.0	0	0	0	0	0
02/01/2022 03:00	0.0	0	0	0	0	0
02/01/2022 04:00	0.0	0	0	0	0	0
02/01/2022 05:00	65.6	0	0	1	0	0
02/01/2022 06:00	40.1	0	0	1	0	0
02/01/2022 07:00	0.0	0	0	0	0	1
02/01/2022 08:00	0.0	0	0	0	0	1
02/01/2022 09:00	0.0	0	0	0	0	1
02/01/2022 10:00	0.0	0	0	0	0	1
02/01/2022 11:00	0.0	0	0	0	0	1
02/01/2022 12:00	0.0	0	0	0	0	1
02/01/2022 13:00	0.0	0	0	0	0	1
02/01/2022 14:00	0.0	0	0	0	0	1
02/01/2022 15:00	0.0	0	0	0	0	1
02/01/2022 16:00	0.0	0	0	0	0	1
02/01/2022 17:00	0.0	0	0	0	0	1
02/01/2022 18:00	0.0	0	0	0	0	1
02/01/2022 19:00	0.0	0	0	0	0	1
02/01/2022 20:00	0.0	0	0	0	0	1
02/01/2022 21:00	0.0	0	0	0	0	1
02/01/2022 22:00	0.0	0	0	0	0	1
02/01/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	105.7 #	0 #	0 #	2 #	0 #	17 #
Minimum:	0.0	0	0	0	0	0
Maximum:	65.6	0	0	1	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/02/2022 00:00	0.0	0	0	0	0	1
02/02/2022 01:00	0.0	0	0	0	0	1
02/02/2022 02:00	0.0	0	0	0	0	1
02/02/2022 03:00	0.0	0	0	0	0	1
02/02/2022 04:00	0.0	0	0	0	0	1
02/02/2022 05:00	0.0	0	0	0	0	1
02/02/2022 06:00	0.0	0	0	0	0	1
02/02/2022 07:00	0.0	0	0	0	0	1
02/02/2022 08:00	0.0	0	0	0	0	1
02/02/2022 09:00	0.0	0	0	0	0	1
02/02/2022 10:00	2.8	0	0	0	1	0
02/02/2022 11:00	0.0	0	0	0	0	0
02/02/2022 12:00	0.0	0	0	0	0	0
02/02/2022 13:00	0.0	0	0	0	0	0
02/02/2022 14:00	0.0	0	0	0	0	0
02/02/2022 15:00	4.3	0	0	1	0	0
02/02/2022 16:00	144.1	0	0	1	0	0
02/02/2022 17:00	0.2	0	0	1	0	0
02/02/2022 18:00	0.0	0	0	0	0	1
02/02/2022 19:00	0.0	0	0	0	0	1
02/02/2022 20:00	0.0	0	0	0	0	1
02/02/2022 21:00	0.0	0	0	0	0	1
02/02/2022 22:00	0.0	0	0	0	0	1
02/02/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	151.4 #	0 #	0 #	3 #	1 #	16 #
Minimum:	0.0	0	0	0	0	0
Maximum:	144.1	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/03/2022 00:00	0.0	0	0	0	0	1
02/03/2022 01:00	0.0	0	0	0	0	1
02/03/2022 02:00	0.0	0	0	0	0	1
02/03/2022 03:00	0.0	0	0	0	0	1
02/03/2022 04:00	0.0	0	0	0	0	1
02/03/2022 05:00	0.0	0	0	0	0	1
02/03/2022 06:00	0.0	0	0	0	0	1
02/03/2022 07:00	0.0	0	0	0	0	1
02/03/2022 08:00	0.0	0	0	0	0	1
02/03/2022 09:00	0.0	0	0	0	0	1
02/03/2022 10:00	0.0	0	0	0	0	1
02/03/2022 11:00	0.0	0	0	0	0	1
02/03/2022 12:00	0.0	0	0	0	0	1
02/03/2022 13:00	0.0	0	0	0	0	1
02/03/2022 14:00	0.0	0	0	0	0	1
02/03/2022 15:00	0.0	0	0	0	0	1
02/03/2022 16:00	0.0	0	0	0	0	1
02/03/2022 17:00	0.0	0	0	0	0	1
02/03/2022 18:00	0.0	0	0	0	0	1
02/03/2022 19:00	0.0	0	0	0	0	1
02/03/2022 20:00	0.0	0	0	0	0	1
02/03/2022 21:00	0.0	0	0	0	0	1
02/03/2022 22:00	0.0	0	0	0	0	1
02/03/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/04/2022 00:00	0.0	0	0	0	0	1
02/04/2022 01:00	0.0	0	0	0	0	1
02/04/2022 02:00	0.0	0	0	0	0	1
02/04/2022 03:00	0.0	0	0	0	0	1
02/04/2022 04:00	0.0	0	0	0	0	1
02/04/2022 05:00	0.0	0	0	0	0	1
02/04/2022 06:00	0.0	0	0	0	0	1
02/04/2022 07:00	0.0	0	0	0	0	1
02/04/2022 08:00	2.6	0	0	0	1	0
02/04/2022 09:00	0.0	0	0	0	0	0
02/04/2022 10:00	0.0	0	0	0	0	0
02/04/2022 11:00	0.0	0	0	0	0	0
02/04/2022 12:00	0.0	0	0	0	0	0
02/04/2022 13:00	0.0	0	0	0	0	0
02/04/2022 14:00	0.0	0	0	0	0	0
02/04/2022 15:00	0.0	0	0	0	0	0
02/04/2022 16:00	186.9	0	0	1	0	0
02/04/2022 17:00	5.0	0	0	1	0	0
02/04/2022 18:00	0.0	0	0	0	0	1
02/04/2022 19:00	0.0	0	0	0	0	1
02/04/2022 20:00	0.0	0	0	0	0	1
02/04/2022 21:00	0.0	0	0	0	0	1
02/04/2022 22:00	0.0	0	0	0	0	1
02/04/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	194.5 #	0 #	0 #	2 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	186.9	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/05/2022 00:00	0.0	0	0	0	0	1
02/05/2022 01:00	0.0	0	0	0	0	1
02/05/2022 02:00	0.0	0	0	0	0	1
02/05/2022 03:00	0.0	0	0	0	0	1
02/05/2022 04:00	0.0	0	0	0	0	1
02/05/2022 05:00	0.0	0	0	0	0	1
02/05/2022 06:00	0.0	0	0	0	0	1
02/05/2022 07:00	0.0	0	0	0	0	1
02/05/2022 08:00	2.7	0	0	0	1	0
02/05/2022 09:00	0.0	0	0	0	0	0
02/05/2022 10:00	0.0	0	0	0	0	0
02/05/2022 11:00	0.0	0	0	0	0	0
02/05/2022 12:00	0.0	0	0	0	0	0
02/05/2022 13:00	8.7	0	0	1	0	0
02/05/2022 14:00	64.5	0	0	1	0	0
02/05/2022 15:00	0.0	0	0	0	0	1
02/05/2022 16:00	0.0	0	0	0	0	1
02/05/2022 17:00	0.0	0	0	0	0	1
02/05/2022 18:00	0.0	0	0	0	0	1
02/05/2022 19:00	0.0	0	0	0	0	1
02/05/2022 20:00	0.0	0	0	0	0	1
02/05/2022 21:00	0.0	0	0	0	0	1
02/05/2022 22:00	0.0	0	0	0	0	1
02/05/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	75.9 #	0 #	0 #	2 #	1 #	17 #
Minimum:	0.0	0	0	0	0	0
Maximum:	64.5	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/06/2022 00:00	0.0	0	0	0	0	1
02/06/2022 01:00	0.0	0	0	0	0	1
02/06/2022 02:00	0.0	0	0	0	0	1
02/06/2022 03:00	0.0	0	0	0	0	1
02/06/2022 04:00	0.0	0	0	0	0	1
02/06/2022 05:00	0.0	0	0	0	0	1
02/06/2022 06:00	0.0	0	0	0	0	1
02/06/2022 07:00	0.0	0	0	0	0	1
02/06/2022 08:00	2.6	0	0	0	1	0
02/06/2022 09:00	0.0	0	0	0	0	0
02/06/2022 10:00	0.0	0	0	0	0	0
02/06/2022 11:00	0.0	0	0	0	0	0
02/06/2022 12:00	0.0	0	0	0	0	0
02/06/2022 13:00	0.0	0	0	0	0	0
02/06/2022 14:00	13.0	0	0	1	0	0
02/06/2022 15:00	62.7	0	0	1	0	0
02/06/2022 16:00	0.0	0	0	0	0	1
02/06/2022 17:00	0.0	0	0	0	0	1
02/06/2022 18:00	0.0	0	0	0	0	1
02/06/2022 19:00	0.0	0	0	0	0	1
02/06/2022 20:00	0.0	0	0	0	0	1
02/06/2022 21:00	0.0	0	0	0	0	1
02/06/2022 22:00	0.0	0	0	0	0	1
02/06/2022 23:00	4.5	0	0	0	1	0
Average/Sum#:	82.8 #	0 #	0 #	2 #	2 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	62.7	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/07/2022 00:00	0.0	0	0	0	0	0
02/07/2022 01:00	0.0	0	0	0	0	0
02/07/2022 02:00	0.0	0	0	0	0	0
02/07/2022 03:00	0.0	0	0	0	0	0
02/07/2022 04:00	0.0	0	0	0	0	0
02/07/2022 05:00	0.0	0	0	0	0	0
02/07/2022 06:00	0.0	0	0	0	0	0
02/07/2022 07:00	0.0	0	0	0	0	0
02/07/2022 08:00	0.0	0	0	0	0	0
02/07/2022 09:00	0.0	0	0	0	0	0
02/07/2022 10:00	0.0	0	0	0	0	0
02/07/2022 11:00	44.5	0	1	0	0	0
02/07/2022 12:00	33.9	0	1	0	0	0
02/07/2022 13:00	90.3	0	1	0	0	0
02/07/2022 14:00	0.0	0	0	0	0	1
02/07/2022 15:00	0.0	0	0	0	0	1
02/07/2022 16:00	0.0	0	0	0	0	1
02/07/2022 17:00	0.0	0	0	0	0	1
02/07/2022 18:00	0.0	0	0	0	0	1
02/07/2022 19:00	0.0	0	0	0	0	1
02/07/2022 20:00	0.0	0	0	0	0	1
02/07/2022 21:00	0.0	0	0	0	0	1
02/07/2022 22:00	0.0	0	0	0	0	1
02/07/2022 23:00	2.8	0	0	0	1	0
Average/Sum#:	171.5 #	0 #	3 #	0 #	1 #	9 #
Minimum:	0.0	0	0	0	0	0
Maximum:	90.3	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/08/2022 00:00	0.0	0	0	0	0	0
02/08/2022 01:00	0.0	0	0	0	0	0
02/08/2022 02:00	0.0	0	0	0	0	0
02/08/2022 03:00	18.9	0	0	1	0	0
02/08/2022 04:00	23.4	0	0	1	0	0
02/08/2022 05:00	0.0	0	0	0	0	1
02/08/2022 06:00	0.0	0	0	0	0	1
02/08/2022 07:00	0.0	0	0	0	0	1
02/08/2022 08:00	0.0	0	0	0	0	1
02/08/2022 09:00	0.0	0	0	0	0	1
02/08/2022 10:00	0.0	0	0	0	0	1
02/08/2022 11:00	0.0	0	0	0	0	1
02/08/2022 12:00	0.0	0	0	0	0	1
02/08/2022 13:00	0.0	0	0	0	0	1
02/08/2022 14:00	0.0	0	0	0	0	1
02/08/2022 15:00	0.0	0	0	0	0	1
02/08/2022 16:00	0.0	0	0	0	0	1
02/08/2022 17:00	0.0	0	0	0	0	1
02/08/2022 18:00	0.0	0	0	0	0	1
02/08/2022 19:00	0.0	0	0	0	0	1
02/08/2022 20:00	0.0	0	0	0	0	1
02/08/2022 21:00	0.0	0	0	0	0	1
02/08/2022 22:00	0.0	0	0	0	0	1
02/08/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	42.3 #	0 #	0 #	2 #	0 #	19 #
Minimum:	0.0	0	0	0	0	0
Maximum:	23.4	0	0	1	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/09/2022 00:00	0.0	0	0	0	0	1
02/09/2022 01:00	0.0	0	0	0	0	1
02/09/2022 02:00	0.0	0	0	0	0	1
02/09/2022 03:00	0.0	0	0	0	0	1
02/09/2022 04:00	0.0	0	0	0	0	1
02/09/2022 05:00	0.0	0	0	0	0	1
02/09/2022 06:00	0.0	0	0	0	0	1
02/09/2022 07:00	0.0	0	0	0	0	1
02/09/2022 08:00	0.0	0	0	0	0	1
02/09/2022 09:00	0.0	0	0	0	0	1
02/09/2022 10:00	0.0	0	0	0	0	1
02/09/2022 11:00	0.0	0	0	0	0	1
02/09/2022 12:00	0.0	0	0	0	0	1
02/09/2022 13:00	0.0	0	0	0	0	1
02/09/2022 14:00	0.0	0	0	0	0	1
02/09/2022 15:00	0.0	0	0	0	0	1
02/09/2022 16:00	0.0	0	0	0	0	1
02/09/2022 17:00	0.0	0	0	0	0	1
02/09/2022 18:00	0.0	0	0	0	0	1
02/09/2022 19:00	0.0	0	0	0	0	1
02/09/2022 20:00	0.0	0	0	0	0	1
02/09/2022 21:00	0.0	0	0	0	0	1
02/09/2022 22:00	0.0	0	0	0	0	1
02/09/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/10/2022 00:00	0.0	0	0	0	0	1
02/10/2022 01:00	0.0	0	0	0	0	1
02/10/2022 02:00	0.0	0	0	0	0	1
02/10/2022 03:00	0.0	0	0	0	0	1
02/10/2022 04:00	0.0	0	0	0	0	1
02/10/2022 05:00	0.0	0	0	0	0	1
02/10/2022 06:00	0.0	0	0	0	0	1
02/10/2022 07:00	0.0	0	0	0	0	1
02/10/2022 08:00	3.5	0	0	0	1	0
02/10/2022 09:00	0.0	0	0	0	0	0
02/10/2022 10:00	0.0	0	0	0	0	0
02/10/2022 11:00	1.1	0	0	1	0	0
02/10/2022 12:00	76.2	0	0	1	0	0
02/10/2022 13:00	0.0	0	0	0	0	1
02/10/2022 14:00	0.0	0	0	0	0	1
02/10/2022 15:00	0.0	0	0	0	0	1
02/10/2022 16:00	0.0	0	0	0	0	1
02/10/2022 17:00	0.0	0	0	0	0	1
02/10/2022 18:00	0.0	0	0	0	0	1
02/10/2022 19:00	0.0	0	0	0	0	1
02/10/2022 20:00	0.0	0	0	0	0	1
02/10/2022 21:00	0.0	0	0	0	0	1
02/10/2022 22:00	0.0	0	0	0	0	1
02/10/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	80.8 #	0 #	0 #	2 #	1 #	19 #
Minimum:	0.0	0	0	0	0	0
Maximum:	76.2	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/11/2022 00:00	0.0	0	0	0	0	1
02/11/2022 01:00	3.0	0	0	0	1	0
02/11/2022 02:00	0.0	0	0	0	0	0
02/11/2022 03:00	0.0	0	0	0	0	0
02/11/2022 04:00	0.0	0	0	0	0	0
02/11/2022 05:00	0.0	0	0	0	0	0
02/11/2022 06:00	0.0	0	0	0	0	0
02/11/2022 07:00	0.0	0	0	0	0	0
02/11/2022 08:00	0.0	0	0	0	0	0
02/11/2022 09:00	0.0	0	0	0	0	0
02/11/2022 10:00	0.0	0	0	0	0	0
02/11/2022 11:00	0.0	0	0	0	0	0
02/11/2022 12:00	0.0	0	0	0	0	0
02/11/2022 13:00	0.0	0	0	0	0	0
02/11/2022 14:00	0.0	0	0	0	0	0
02/11/2022 15:00	0.0	0	0	0	0	0
02/11/2022 16:00	0.0	0	0	0	0	0
02/11/2022 17:00	0.0	0	0	0	0	0
02/11/2022 18:00	0.0	0	0	0	0	0
02/11/2022 19:00	0.0	0	0	0	0	0
02/11/2022 20:00	0.0	0	0	0	0	0
02/11/2022 21:00	0.0	0	0	0	0	0
02/11/2022 22:00	0.0	0	0	0	0	0
02/11/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	3.0 #	0 #	0 #	0 #	1 #	1 #
Minimum:	0.0	0	0	0	0	0
Maximum:	3.0	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/12/2022 00:00	0.0	0	0	0	0	0
02/12/2022 01:00	0.0	0	0	0	0	0
02/12/2022 02:00	0.0	0	0	0	0	0
02/12/2022 03:00	0.0	0	0	0	0	0
02/12/2022 04:00	0.0	0	0	0	0	0
02/12/2022 05:00	0.0	0	0	0	0	0
02/12/2022 06:00	0.0	0	0	0	0	0
02/12/2022 07:00	0.0	0	0	0	0	0
02/12/2022 08:00	0.0	0	0	0	0	0
02/12/2022 09:00	0.0	0	0	0	0	0
02/12/2022 10:00	0.0	0	0	0	0	0
02/12/2022 11:00	0.0	0	0	0	0	0
02/12/2022 12:00	0.0	0	0	0	0	0
02/12/2022 13:00	0.0	0	0	0	0	0
02/12/2022 14:00	0.0	0	0	0	0	0
02/12/2022 15:00	0.0	0	0	0	0	0
02/12/2022 16:00	0.0	0	0	0	0	0
02/12/2022 17:00	0.0	0	0	0	0	0
02/12/2022 18:00	0.0	0	0	0	0	0
02/12/2022 19:00	0.0	0	0	0	0	0
02/12/2022 20:00	0.0	0	0	0	0	0
02/12/2022 21:00	0.0	0	0	0	0	0
02/12/2022 22:00	0.0	0	0	0	0	0
02/12/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/13/2022 00:00	0.0	0	0	0	0	0
02/13/2022 01:00	0.0	0	0	0	0	0
02/13/2022 02:00	0.0	0	0	0	0	0
02/13/2022 03:00	0.0	0	0	0	0	0
02/13/2022 04:00	0.0	0	0	0	0	0
02/13/2022 05:00	0.0	0	0	0	0	0
02/13/2022 06:00	0.0	0	0	0	0	0
02/13/2022 07:00	0.0	0	0	0	0	0
02/13/2022 08:00	0.0	0	0	0	0	0
02/13/2022 09:00	0.0	0	0	0	0	0
02/13/2022 10:00	0.0	0	0	0	0	0
02/13/2022 11:00	0.0	0	0	0	0	0
02/13/2022 12:00	0.0	0	0	0	0	0
02/13/2022 13:00	0.0	0	0	0	0	0
02/13/2022 14:00	0.0	0	0	0	0	0
02/13/2022 15:00	0.0	0	0	0	0	0
02/13/2022 16:00	0.0	0	0	0	0	0
02/13/2022 17:00	0.0	0	0	0	0	0
02/13/2022 18:00	0.0	0	0	0	0	0
02/13/2022 19:00	0.0	0	0	0	0	0
02/13/2022 20:00	0.0	0	0	0	0	0
02/13/2022 21:00	0.0	0	0	0	0	0
02/13/2022 22:00	0.0	0	0	0	0	0
02/13/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/14/2022 00:00	0.0	0	0	0	0	0
02/14/2022 01:00	0.0	0	0	0	0	0
02/14/2022 02:00	0.0	0	0	0	0	0
02/14/2022 03:00	0.0	0	0	0	0	0
02/14/2022 04:00	0.0	0	0	0	0	0
02/14/2022 05:00	0.0	0	0	0	0	0
02/14/2022 06:00	0.0	0	0	0	0	0
02/14/2022 07:00	0.0	0	0	0	0	0
02/14/2022 08:00	0.0	0	0	0	0	0
02/14/2022 09:00	0.0	0	0	0	0	0
02/14/2022 10:00	0.0	0	0	0	0	0
02/14/2022 11:00	0.0	0	0	0	0	0
02/14/2022 12:00	0.0	0	0	0	0	0
02/14/2022 13:00	0.0	0	0	0	0	0
02/14/2022 14:00	0.0	0	0	0	0	0
02/14/2022 15:00	0.0	0	0	0	0	0
02/14/2022 16:00	0.0	0	0	0	0	0
02/14/2022 17:00	0.0	0	0	0	0	0
02/14/2022 18:00	0.0	0	0	0	0	0
02/14/2022 19:00	0.0	0	0	0	0	0
02/14/2022 20:00	0.0	0	0	0	0	0
02/14/2022 21:00	0.0	0	0	0	0	0
02/14/2022 22:00	0.0	0	0	0	0	0
02/14/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/15/2022 00:00	0.0	0	0	0	0	0
02/15/2022 01:00	0.0	0	0	0	0	0
02/15/2022 02:00	0.0	0	0	0	0	0
02/15/2022 03:00	0.0	0	0	0	0	0
02/15/2022 04:00	0.0	0	0	0	0	0
02/15/2022 05:00	0.0	0	0	0	0	0
02/15/2022 06:00	0.0	0	0	0	0	0
02/15/2022 07:00	0.0	0	0	0	0	0
02/15/2022 08:00	0.0	0	0	0	0	0
02/15/2022 09:00	0.0	0	0	0	0	0
02/15/2022 10:00	0.0	0	0	0	0	0
02/15/2022 11:00	0.0	0	0	0	0	0
02/15/2022 12:00	0.0	0	0	0	0	0
02/15/2022 13:00	0.0	0	0	0	0	0
02/15/2022 14:00	0.0	0	0	0	0	0
02/15/2022 15:00	0.0	0	0	0	0	0
02/15/2022 16:00	0.0	0	0	0	0	0
02/15/2022 17:00	0.0	0	0	0	0	0
02/15/2022 18:00	0.0	0	0	0	0	0
02/15/2022 19:00	0.0	0	0	0	0	0
02/15/2022 20:00	0.0	0	0	0	0	0
02/15/2022 21:00	0.0	0	0	0	0	0
02/15/2022 22:00	0.0	0	0	0	0	0
02/15/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/16/2022 00:00	0.0	0	0	0	0	0
02/16/2022 01:00	0.0	0	0	0	0	0
02/16/2022 02:00	0.0	0	0	0	0	0
02/16/2022 03:00	0.0	0	0	0	0	0
02/16/2022 04:00	0.0	0	0	0	0	0
02/16/2022 05:00	0.0	0	0	0	0	0
02/16/2022 06:00	0.0	0	0	0	0	0
02/16/2022 07:00	0.0	0	0	0	0	0
02/16/2022 08:00	0.0	0	0	0	0	0
02/16/2022 09:00	0.0	0	0	0	0	0
02/16/2022 10:00	0.0	0	0	0	0	0
02/16/2022 11:00	0.0	0	0	0	0	0
02/16/2022 12:00	0.0	0	0	0	0	0
02/16/2022 13:00	0.0	0	0	0	0	0
02/16/2022 14:00	0.0	0	0	0	0	0
02/16/2022 15:00	0.0	0	0	0	0	0
02/16/2022 16:00	0.0	0	0	0	0	0
02/16/2022 17:00	0.0	0	0	0	0	0
02/16/2022 18:00	0.0	0	0	0	0	0
02/16/2022 19:00	0.0	0	0	0	0	0
02/16/2022 20:00	0.0	0	0	0	0	0
02/16/2022 21:00	0.0	0	0	0	0	0
02/16/2022 22:00	0.0	0	0	0	0	0
02/16/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/17/2022 00:00	0.0	0	0	0	0	0
02/17/2022 01:00	0.0	0	0	0	0	0
02/17/2022 02:00	0.0	0	0	0	0	0
02/17/2022 03:00	0.0	0	0	0	0	0
02/17/2022 04:00	0.0	0	0	0	0	0
02/17/2022 05:00	0.0	0	0	0	0	0
02/17/2022 06:00	0.0	0	0	0	0	0
02/17/2022 07:00	0.0	0	0	0	0	0
02/17/2022 08:00	0.0	0	0	0	0	0
02/17/2022 09:00	0.0	0	0	0	0	0
02/17/2022 10:00	0.0	0	0	0	0	0
02/17/2022 11:00	0.0	0	0	0	0	0
02/17/2022 12:00	0.0	0	0	0	0	0
02/17/2022 13:00	0.0	0	0	0	0	0
02/17/2022 14:00	0.0	0	0	0	0	0
02/17/2022 15:00	0.0	0	0	0	0	0
02/17/2022 16:00	0.0	0	0	0	0	0
02/17/2022 17:00	0.0	0	0	0	0	0
02/17/2022 18:00	0.0	0	0	0	0	0
02/17/2022 19:00	0.0	0	0	0	0	0
02/17/2022 20:00	0.0	0	0	0	0	0
02/17/2022 21:00	0.0	0	0	0	0	0
02/17/2022 22:00	0.0	0	0	0	0	0
02/17/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/18/2022 00:00	0.0	0	0	0	0	0
02/18/2022 01:00	0.0	0	0	0	0	0
02/18/2022 02:00	0.0	0	0	0	0	0
02/18/2022 03:00	0.0	0	0	0	0	0
02/18/2022 04:00	0.0	0	0	0	0	0
02/18/2022 05:00	0.0	0	0	0	0	0
02/18/2022 06:00	0.0	0	0	0	0	0
02/18/2022 07:00	0.0	0	0	0	0	0
02/18/2022 08:00	18.5	1	0	0	0	0
02/18/2022 09:00	61.4	1	0	0	0	0
02/18/2022 10:00	25.8	1	0	0	0	0
02/18/2022 11:00	140.3	1	0	0	0	0
02/18/2022 12:00	72.1	1	0	0	0	0
02/18/2022 13:00	0.0	0	0	0	0	1
02/18/2022 14:00	0.0	0	0	0	0	1
02/18/2022 15:00	0.0	0	0	0	0	1
02/18/2022 16:00	0.0	0	0	0	0	1
02/18/2022 17:00	0.0	0	0	0	0	1
02/18/2022 18:00	0.0	0	0	0	0	1
02/18/2022 19:00	0.0	0	0	0	0	1
02/18/2022 20:00	0.0	0	0	0	0	1
02/18/2022 21:00	0.0	0	0	0	0	1
02/18/2022 22:00	0.0	0	0	0	0	1
02/18/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	318.1 #	5 #	0 #	0 #	0 #	11 #
Minimum:	0.0	0	0	0	0	0
Maximum:	140.3	1	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/19/2022 00:00	2.3	0	0	0	1	0
02/19/2022 01:00	0.0	0	0	0	0	0
02/19/2022 02:00	0.0	0	0	0	0	0
02/19/2022 03:00	0.0	0	0	0	0	0
02/19/2022 04:00	0.0	0	0	0	0	0
02/19/2022 05:00	0.0	0	0	0	0	0
02/19/2022 06:00	0.0	0	0	0	0	0
02/19/2022 07:00	0.0	0	0	0	0	0
02/19/2022 08:00	0.0	0	0	0	0	0
02/19/2022 09:00	0.0	0	0	0	0	0
02/19/2022 10:00	0.0	0	0	0	0	0
02/19/2022 11:00	0.0	0	0	0	0	0
02/19/2022 12:00	0.0	0	0	0	0	0
02/19/2022 13:00	0.0	0	0	0	0	0
02/19/2022 14:00	0.0	0	0	0	0	0
02/19/2022 15:00	0.0	0	0	0	0	0
02/19/2022 16:00	0.0	0	0	0	0	0
02/19/2022 17:00	0.0	0	0	0	0	0
02/19/2022 18:00	0.0	0	0	0	0	0
02/19/2022 19:00	0.0	0	0	0	0	0
02/19/2022 20:00	0.0	0	0	0	0	0
02/19/2022 21:00	0.0	0	0	0	0	0
02/19/2022 22:00	0.0	0	0	0	0	0
02/19/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	2.3 #	0 #	0 #	0 #	1 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	2.3	0	0	0	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/20/2022 00:00	0.0	0	0	0	0	0
02/20/2022 01:00	0.0	0	0	0	0	0
02/20/2022 02:00	0.0	0	0	0	0	0
02/20/2022 03:00	0.0	0	0	0	0	0
02/20/2022 04:00	0.0	0	0	0	0	0
02/20/2022 05:00	0.0	0	0	0	0	0
02/20/2022 06:00	0.0	0	0	0	0	0
02/20/2022 07:00	0.0	0	0	0	0	0
02/20/2022 08:00	0.0	0	0	0	0	0
02/20/2022 09:00	0.0	0	0	0	0	0
02/20/2022 10:00	0.0	0	0	0	0	0
02/20/2022 11:00	0.0	0	0	0	0	0
02/20/2022 12:00	0.0	0	0	0	0	0
02/20/2022 13:00	0.0	0	0	0	0	0
02/20/2022 14:00	0.0	0	0	0	0	0
02/20/2022 15:00	0.0	0	0	0	0	0
02/20/2022 16:00	0.0	0	0	0	0	0
02/20/2022 17:00	0.0	0	0	0	0	0
02/20/2022 18:00	0.0	0	0	0	0	0
02/20/2022 19:00	0.0	0	0	0	0	0
02/20/2022 20:00	0.0	0	0	0	0	0
02/20/2022 21:00	0.0	0	0	0	0	0
02/20/2022 22:00	0.0	0	0	0	0	0
02/20/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/21/2022 00:00	0.0	0	0	0	0	0
02/21/2022 01:00	0.0	0	0	0	0	0
02/21/2022 02:00	0.0	0	0	0	0	0
02/21/2022 03:00	0.0	0	0	0	0	0
02/21/2022 04:00	0.0	0	0	0	0	0
02/21/2022 05:00	0.0	0	0	0	0	0
02/21/2022 06:00	0.0	0	0	0	0	0
02/21/2022 07:00	0.0	0	0	0	0	0
02/21/2022 08:00	0.0	0	0	0	0	0
02/21/2022 09:00	0.0	0	0	0	0	0
02/21/2022 10:00	0.0	0	0	0	0	0
02/21/2022 11:00	0.0	0	0	0	0	0
02/21/2022 12:00	0.0	0	0	0	0	0
02/21/2022 13:00	0.0	0	0	0	0	0
02/21/2022 14:00	0.0	0	0	0	0	0
02/21/2022 15:00	0.0	0	0	0	0	0
02/21/2022 16:00	0.0	0	0	0	0	0
02/21/2022 17:00	0.0	0	0	0	0	0
02/21/2022 18:00	0.0	0	0	0	0	0
02/21/2022 19:00	0.0	0	0	0	0	0
02/21/2022 20:00	0.0	0	0	0	0	0
02/21/2022 21:00	0.0	0	0	0	0	0
02/21/2022 22:00	0.0	0	0	0	0	0
02/21/2022 23:00	68.3	0	1	0	0	0
Average/Sum#:	68.3 #	0 #	1 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	68.3	0	1	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/22/2022 00:00	30.9	0	1	0	0	0
02/22/2022 01:00	84.0	0	1	0	0	0
02/22/2022 02:00	0.0	0	0	0	0	1
02/22/2022 03:00	0.0	0	0	0	0	1
02/22/2022 04:00	0.0	0	0	0	0	1
02/22/2022 05:00	0.0	0	0	0	0	1
02/22/2022 06:00	0.0	0	0	0	0	1
02/22/2022 07:00	0.0	0	0	0	0	1
02/22/2022 08:00	0.0	0	0	0	0	1
02/22/2022 09:00	0.0	0	0	0	0	1
02/22/2022 10:00	0.0	0	0	0	0	1
02/22/2022 11:00	0.0	0	0	0	0	1
02/22/2022 12:00	0.0	0	0	0	0	1
02/22/2022 13:00	0.0	0	0	0	0	1
02/22/2022 14:00	0.0	0	0	0	0	1
02/22/2022 15:00	0.0	0	0	0	0	1
02/22/2022 16:00	0.0	0	0	0	0	1
02/22/2022 17:00	0.0	0	0	0	0	1
02/22/2022 18:00	0.0	0	0	0	0	1
02/22/2022 19:00	0.0	0	0	0	0	1
02/22/2022 20:00	0.0	0	0	0	0	1
02/22/2022 21:00	0.0	0	0	0	0	1
02/22/2022 22:00	0.0	0	0	0	0	1
02/22/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	114.9 #	0 #	2 #	0 #	0 #	22 #
Minimum:	0.0	0	0	0	0	0
Maximum:	84.0	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/23/2022 00:00	0.0	0	0	0	0	1
02/23/2022 01:00	0.0	0	0	0	0	1
02/23/2022 02:00	0.0	0	0	0	0	1
02/23/2022 03:00	0.0	0	0	0	0	1
02/23/2022 04:00	0.0	0	0	0	0	1
02/23/2022 05:00	0.0	0	0	0	0	1
02/23/2022 06:00	0.0	0	0	0	0	1
02/23/2022 07:00	0.0	0	0	0	0	1
02/23/2022 08:00	0.0	0	0	0	0	1
02/23/2022 09:00	0.0	0	0	0	0	1
02/23/2022 10:00	0.0	0	0	0	0	1
02/23/2022 11:00	0.0	0	0	0	0	1
02/23/2022 12:00	0.0	0	0	0	0	1
02/23/2022 13:00	0.0	0	0	0	0	1
02/23/2022 14:00	0.0	0	0	0	0	1
02/23/2022 15:00	0.0	0	0	0	0	1
02/23/2022 16:00	0.0	0	0	0	0	1
02/23/2022 17:00	0.0	0	0	0	0	1
02/23/2022 18:00	0.0	0	0	0	0	1
02/23/2022 19:00	0.0	0	0	0	0	1
02/23/2022 20:00	0.0	0	0	0	0	1
02/23/2022 21:00	0.0	0	0	0	0	1
02/23/2022 22:00	0.0	0	0	0	0	1
02/23/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/24/2022 00:00	0.0	0	0	0	0	1
02/24/2022 01:00	0.0	0	0	0	0	1
02/24/2022 02:00	0.0	0	0	0	0	1
02/24/2022 03:00	0.0	0	0	0	0	1
02/24/2022 04:00	0.0	0	0	0	0	1
02/24/2022 05:00	0.0	0	0	0	0	1
02/24/2022 06:00	0.0	0	0	0	0	1
02/24/2022 07:00	0.0	0	0	0	0	1
02/24/2022 08:00	0.0	0	0	0	0	1
02/24/2022 09:00	0.0	0	0	0	0	1
02/24/2022 10:00	0.0	0	0	0	0	1
02/24/2022 11:00	0.0	0	0	0	0	1
02/24/2022 12:00	0.0	0	0	0	0	1
02/24/2022 13:00	0.0	0	0	0	0	1
02/24/2022 14:00	0.0	0	0	0	0	1
02/24/2022 15:00	0.0	0	0	0	0	1
02/24/2022 16:00	0.0	0	0	0	0	1
02/24/2022 17:00	0.0	0	0	0	0	1
02/24/2022 18:00	0.0	0	0	0	0	1
02/24/2022 19:00	0.0	0	0	0	0	1
02/24/2022 20:00	0.0	0	0	0	0	1
02/24/2022 21:00	0.0	0	0	0	0	1
02/24/2022 22:00	0.0	0	0	0	0	1
02/24/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/25/2022 00:00	0.0	0	0	0	0	1
02/25/2022 01:00	0.0	0	0	0	0	1
02/25/2022 02:00	0.0	0	0	0	0	1
02/25/2022 03:00	0.0	0	0	0	0	1
02/25/2022 04:00	0.0	0	0	0	0	1
02/25/2022 05:00	0.0	0	0	0	0	1
02/25/2022 06:00	0.0	0	0	0	0	1
02/25/2022 07:00	0.0	0	0	0	0	1
02/25/2022 08:00	0.0	0	0	0	0	1
02/25/2022 09:00	0.0	0	0	0	0	1
02/25/2022 10:00	0.0	0	0	0	0	1
02/25/2022 11:00	0.0	0	0	0	0	1
02/25/2022 12:00	0.0	0	0	0	0	1
02/25/2022 13:00	0.0	0	0	0	0	1
02/25/2022 14:00	0.0	0	0	0	0	1
02/25/2022 15:00	0.0	0	0	0	0	1
02/25/2022 16:00	0.0	0	0	0	0	1
02/25/2022 17:00	0.0	0	0	0	0	1
02/25/2022 18:00	0.0	0	0	0	0	1
02/25/2022 19:00	0.0	0	0	0	0	1
02/25/2022 20:00	0.0	0	0	0	0	1
02/25/2022 21:00	0.0	0	0	0	0	1
02/25/2022 22:00	0.0	0	0	0	0	1
02/25/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/26/2022 00:00	0.0	0	0	0	0	1
02/26/2022 01:00	0.0	0	0	0	0	1
02/26/2022 02:00	0.0	0	0	0	0	1
02/26/2022 03:00	0.0	0	0	0	0	1
02/26/2022 04:00	0.0	0	0	0	0	1
02/26/2022 05:00	0.0	0	0	0	0	1
02/26/2022 06:00	0.0	0	0	0	0	1
02/26/2022 07:00	2.7	0	0	0	1	0
02/26/2022 08:00	0.0	0	0	0	0	0
02/26/2022 09:00	0.0	0	0	0	0	0
02/26/2022 10:00	0.0	0	0	0	0	0
02/26/2022 11:00	0.0	0	0	0	0	0
02/26/2022 12:00	0.0	0	0	0	0	0
02/26/2022 13:00	0.0	0	0	0	0	0
02/26/2022 14:00	0.0	0	0	0	0	0
02/26/2022 15:00	15.9	0	1	0	0	0
02/26/2022 16:00	93.1	0	1	0	0	0
02/26/2022 17:00	0.0	0	0	0	0	1
02/26/2022 18:00	0.0	0	0	0	0	1
02/26/2022 19:00	0.0	0	0	0	0	1
02/26/2022 20:00	0.0	0	0	0	0	1
02/26/2022 21:00	0.0	0	0	0	0	1
02/26/2022 22:00	0.0	0	0	0	0	1
02/26/2022 23:00	2.7	0	0	0	1	0
Average/Sum#:	114.4 #	0 #	2 #	0 #	2 #	13 #
Minimum:	0.0	0	0	0	0	0
Maximum:	93.1	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/27/2022 00:00	0.0	0	0	0	0	0
02/27/2022 01:00	0.0	0	0	0	0	0
02/27/2022 02:00	0.0	0	0	0	0	0
02/27/2022 03:00	0.0	0	0	0	0	0
02/27/2022 04:00	0.0	0	0	0	0	0
02/27/2022 05:00	0.0	0	0	0	0	0
02/27/2022 06:00	0.0	0	0	0	0	0
02/27/2022 07:00	0.0	0	0	0	0	0
02/27/2022 08:00	0.0	0	0	0	0	0
02/27/2022 09:00	0.0	0	0	0	0	0
02/27/2022 10:00	0.0	0	0	0	0	0
02/27/2022 11:00	0.0	0	0	0	0	0
02/27/2022 12:00	0.0	0	0	0	0	0
02/27/2022 13:00	0.0	0	0	0	0	0
02/27/2022 14:00	0.0	0	0	0	0	0
02/27/2022 15:00	0.0	0	0	0	0	0
02/27/2022 16:00	0.0	0	0	0	0	0
02/27/2022 17:00	0.0	0	0	0	0	0
02/27/2022 18:00	0.0	0	0	0	0	0
02/27/2022 19:00	0.0	0	0	0	0	0
02/27/2022 20:00	0.0	0	0	0	0	0
02/27/2022 21:00	0.0	0	0	0	0	0
02/27/2022 22:00	0.0	0	0	0	0	0
02/27/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/28/2022 00:00	0.0	0	0	0	0	0
02/28/2022 01:00	0.0	0	0	0	0	0
02/28/2022 02:00	0.0	0	0	0	0	0
02/28/2022 03:00	0.0	0	0	0	0	0
02/28/2022 04:00	0.0	0	0	0	0	0
02/28/2022 05:00	0.0	0	0	0	0	0
02/28/2022 06:00	0.0	0	0	0	0	0
02/28/2022 07:00	0.0	0	0	0	0	0
02/28/2022 08:00	0.0	0	0	0	0	0
02/28/2022 09:00	0.0	0	0	0	0	0
02/28/2022 10:00	0.0	0	0	0	0	0
02/28/2022 11:00	0.0	0	0	0	0	0
02/28/2022 12:00	0.0	0	0	0	0	0
02/28/2022 13:00	63.8	0	1	0	0	0
02/28/2022 14:00	27.2	0	1	0	0	0
02/28/2022 15:00	56.9	0	1	0	0	0
02/28/2022 16:00	0.0	0	0	0	0	1
02/28/2022 17:00	0.0	0	0	0	0	1
02/28/2022 18:00	0.0	0	0	0	0	1
02/28/2022 19:00	0.0	0	0	0	0	1
02/28/2022 20:00	0.0	0	0	0	0	1
02/28/2022 21:00	0.0	0	0	0	0	1
02/28/2022 22:00	4.2	0	0	0	1	0
02/28/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	152.1 #	0 #	3 #	0 #	1 #	6 #
Minimum:	0.0	0	0	0	0	0
Maximum:	63.8	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/01/2022 00:00	0.0	0	0	0	0	0
03/01/2022 01:00	0.0	0	0	0	0	0
03/01/2022 02:00	0.0	0	0	0	0	0
03/01/2022 03:00	0.0	0	0	0	0	0
03/01/2022 04:00	0.0	0	0	0	0	0
03/01/2022 05:00	0.0	0	0	0	0	0
03/01/2022 06:00	0.0	0	0	0	0	0
03/01/2022 07:00	0.0	0	0	0	0	0
03/01/2022 08:00	0.0	0	0	0	0	0
03/01/2022 09:00	0.0	0	0	0	0	0
03/01/2022 10:00	0.0	0	0	0	0	0
03/01/2022 11:00	0.0	0	0	0	0	0
03/01/2022 12:00	0.0	0	0	0	0	0
03/01/2022 13:00	0.0	0	0	0	0	0
03/01/2022 14:00	0.0	0	0	0	0	0
03/01/2022 15:00	0.0	0	0	0	0	0
03/01/2022 16:00	0.0	0	0	0	0	0
03/01/2022 17:00	0.0	0	0	0	0	0
03/01/2022 18:00	0.0	0	0	0	0	0
03/01/2022 19:00	0.0	0	0	0	0	0
03/01/2022 20:00	0.0	0	0	0	0	0
03/01/2022 21:00	0.0	0	0	0	0	0
03/01/2022 22:00	0.0	0	0	0	0	0
03/01/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/02/2022 00:00	0.0	0	0	0	0	0
03/02/2022 01:00	0.0	0	0	0	0	0
03/02/2022 02:00	0.0	0	0	0	0	0
03/02/2022 03:00	0.0	0	0	0	0	0
03/02/2022 04:00	0.0	0	0	0	0	0
03/02/2022 05:00	0.0	0	0	0	0	0
03/02/2022 06:00	0.0	0	0	0	0	0
03/02/2022 07:00	0.0	0	0	0	0	0
03/02/2022 08:00	0.0	0	0	0	0	0
03/02/2022 09:00	0.0	0	0	0	0	0
03/02/2022 10:00	0.0	0	0	0	0	0
03/02/2022 11:00	0.0	0	0	0	0	0
03/02/2022 12:00	0.0	0	0	0	0	0
03/02/2022 13:00	0.0	0	0	0	0	0
03/02/2022 14:00	0.0	0	0	0	0	0
03/02/2022 15:00	0.0	0	0	0	0	0
03/02/2022 16:00	0.0	0	0	0	0	0
03/02/2022 17:00	0.0	0	0	0	0	0
03/02/2022 18:00	0.0	0	0	0	0	0
03/02/2022 19:00	0.0	0	0	0	0	0
03/02/2022 20:00	0.0	0	0	0	0	0
03/02/2022 21:00	0.0	0	0	0	0	0
03/02/2022 22:00	0.0	0	0	0	0	0
03/02/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/03/2022 00:00	0.0	0	0	0	0	0
03/03/2022 01:00	0.0	0	0	0	0	0
03/03/2022 02:00	0.0	0	0	0	0	0
03/03/2022 03:00	0.0	0	0	0	0	0
03/03/2022 04:00	0.0	0	0	0	0	0
03/03/2022 05:00	0.0	0	0	0	0	0
03/03/2022 06:00	0.0	0	0	0	0	0
03/03/2022 07:00	0.0	0	0	0	0	0
03/03/2022 08:00	0.0	0	0	0	0	0
03/03/2022 09:00	0.0	0	0	0	0	0
03/03/2022 10:00	0.0	0	0	0	0	0
03/03/2022 11:00	0.0	0	0	0	0	0
03/03/2022 12:00	0.0	0	0	0	0	0
03/03/2022 13:00	0.0	0	0	0	0	0
03/03/2022 14:00	0.0	0	0	0	0	0
03/03/2022 15:00	0.0	0	0	0	0	0
03/03/2022 16:00	0.0	0	0	0	0	0
03/03/2022 17:00	0.0	0	0	0	0	0
03/03/2022 18:00	0.0	0	0	0	0	0
03/03/2022 19:00	0.0	0	0	0	0	0
03/03/2022 20:00	0.0	0	0	0	0	0
03/03/2022 21:00	0.0	0	0	0	0	0
03/03/2022 22:00	0.0	0	0	0	0	0
03/03/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/04/2022 00:00	0.0	0	0	0	0	0
03/04/2022 01:00	0.0	0	0	0	0	0
03/04/2022 02:00	0.0	0	0	0	0	0
03/04/2022 03:00	0.0	0	0	0	0	0
03/04/2022 04:00	0.0	0	0	0	0	0
03/04/2022 05:00	0.0	0	0	0	0	0
03/04/2022 06:00	0.0	0	0	0	0	0
03/04/2022 07:00	0.0	0	0	0	0	0
03/04/2022 08:00	0.0	0	0	0	0	0
03/04/2022 09:00	0.0	0	0	0	0	0
03/04/2022 10:00	0.0	0	0	0	0	0
03/04/2022 11:00	0.0	0	0	0	0	0
03/04/2022 12:00	0.0	0	0	0	0	0
03/04/2022 13:00	0.0	0	0	0	0	0
03/04/2022 14:00	0.0	0	0	0	0	0
03/04/2022 15:00	0.0	0	0	0	0	0
03/04/2022 16:00	0.0	0	0	0	0	0
03/04/2022 17:00	0.0	0	0	0	0	0
03/04/2022 18:00	0.0	0	0	0	0	0
03/04/2022 19:00	0.0	0	0	0	0	0
03/04/2022 20:00	0.0	0	0	0	0	0
03/04/2022 21:00	0.0	0	0	0	0	0
03/04/2022 22:00	0.0	0	0	0	0	0
03/04/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/05/2022 00:00	0.0	0	0	0	0	0
03/05/2022 01:00	0.0	0	0	0	0	0
03/05/2022 02:00	0.0	0	0	0	0	0
03/05/2022 03:00	0.0	0	0	0	0	0
03/05/2022 04:00	0.0	0	0	0	0	0
03/05/2022 05:00	0.0	0	0	0	0	0
03/05/2022 06:00	0.0	0	0	0	0	0
03/05/2022 07:00	0.0	0	0	0	0	0
03/05/2022 08:00	0.0	0	0	0	0	0
03/05/2022 09:00	0.0	0	0	0	0	0
03/05/2022 10:00	0.0	0	0	0	0	0
03/05/2022 11:00	0.0	0	0	0	0	0
03/05/2022 12:00	0.0	0	0	0	0	0
03/05/2022 13:00	0.0	0	0	0	0	0
03/05/2022 14:00	0.0	0	0	0	0	0
03/05/2022 15:00	0.0	0	0	0	0	0
03/05/2022 16:00	0.0	0	0	0	0	0
03/05/2022 17:00	0.0	0	0	0	0	0
03/05/2022 18:00	0.0	0	0	0	0	0
03/05/2022 19:00	0.0	0	0	0	0	0
03/05/2022 20:00	0.0	0	0	0	0	0
03/05/2022 21:00	0.0	0	0	0	0	0
03/05/2022 22:00	0.0	0	0	0	0	0
03/05/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/06/2022 00:00	0.0	0	0	0	0	0
03/06/2022 01:00	0.0	0	0	0	0	0
03/06/2022 02:00	0.0	0	0	0	0	0
03/06/2022 03:00	0.0	0	0	0	0	0
03/06/2022 04:00	0.0	0	0	0	0	0
03/06/2022 05:00	0.0	0	0	0	0	0
03/06/2022 06:00	0.0	0	0	0	0	0
03/06/2022 07:00	0.0	0	0	0	0	0
03/06/2022 08:00	0.0	0	0	0	0	0
03/06/2022 09:00	0.0	0	0	0	0	0
03/06/2022 10:00	0.0	0	0	0	0	0
03/06/2022 11:00	0.0	0	0	0	0	0
03/06/2022 12:00	0.0	0	0	0	0	0
03/06/2022 13:00	0.0	0	0	0	0	0
03/06/2022 14:00	0.0	0	0	0	0	0
03/06/2022 15:00	0.0	0	0	0	0	0
03/06/2022 16:00	0.0	0	0	0	0	0
03/06/2022 17:00	0.0	0	0	0	0	0
03/06/2022 18:00	0.0	0	0	0	0	0
03/06/2022 19:00	0.0	0	0	0	0	0
03/06/2022 20:00	0.0	0	0	0	0	0
03/06/2022 21:00	0.0	0	0	0	0	0
03/06/2022 22:00	0.0	0	0	0	0	0
03/06/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/07/2022 00:00	0.0	0	0	0	0	0
03/07/2022 01:00	0.0	0	0	0	0	0
03/07/2022 02:00	0.0	0	0	0	0	0
03/07/2022 03:00	0.0	0	0	0	0	0
03/07/2022 04:00	0.0	0	0	0	0	0
03/07/2022 05:00	0.0	0	0	0	0	0
03/07/2022 06:00	0.0	0	0	0	0	0
03/07/2022 07:00	0.0	0	0	0	0	0
03/07/2022 08:00	0.0	0	0	0	0	0
03/07/2022 09:00	0.0	0	0	0	0	0
03/07/2022 10:00	0.0	0	0	0	0	0
03/07/2022 11:00	0.0	0	0	0	0	0
03/07/2022 12:00	0.0	0	0	0	0	0
03/07/2022 13:00	0.0	0	0	0	0	0
03/07/2022 14:00	0.0	0	0	0	0	0
03/07/2022 15:00	0.0	0	0	0	0	0
03/07/2022 16:00	0.0	0	0	0	0	0
03/07/2022 17:00	0.0	0	0	0	0	0
03/07/2022 18:00	0.0	0	0	0	0	0
03/07/2022 19:00	0.0	0	0	0	0	0
03/07/2022 20:00	0.0	0	0	0	0	0
03/07/2022 21:00	0.0	0	0	0	0	0
03/07/2022 22:00	0.0	0	0	0	0	0
03/07/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/08/2022 00:00	0.0	0	0	0	0	0
03/08/2022 01:00	0.0	0	0	0	0	0
03/08/2022 02:00	0.0	0	0	0	0	0
03/08/2022 03:00	0.0	0	0	0	0	0
03/08/2022 04:00	0.0	0	0	0	0	0
03/08/2022 05:00	0.0	0	0	0	0	0
03/08/2022 06:00	0.0	0	0	0	0	0
03/08/2022 07:00	0.0	0	0	0	0	0
03/08/2022 08:00	0.0	0	0	0	0	0
03/08/2022 09:00	0.0	0	0	0	0	0
03/08/2022 10:00	0.0	0	0	0	0	0
03/08/2022 11:00	0.0	0	0	0	0	0
03/08/2022 12:00	0.0	0	0	0	0	0
03/08/2022 13:00	0.0	0	0	0	0	0
03/08/2022 14:00	0.0	0	0	0	0	0
03/08/2022 15:00	0.0	0	0	0	0	0
03/08/2022 16:00	0.0	0	0	0	0	0
03/08/2022 17:00	0.0	0	0	0	0	0
03/08/2022 18:00	0.0	0	0	0	0	0
03/08/2022 19:00	0.0	0	0	0	0	0
03/08/2022 20:00	0.0	0	0	0	0	0
03/08/2022 21:00	0.0	0	0	0	0	0
03/08/2022 22:00	0.0	0	0	0	0	0
03/08/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/09/2022 00:00	0.0	0	0	0	0	0
03/09/2022 01:00	0.0	0	0	0	0	0
03/09/2022 02:00	0.0	0	0	0	0	0
03/09/2022 03:00	0.0	0	0	0	0	0
03/09/2022 04:00	0.0	0	0	0	0	0
03/09/2022 05:00	0.0	0	0	0	0	0
03/09/2022 06:00	0.0	0	0	0	0	0
03/09/2022 07:00	0.0	0	0	0	0	0
03/09/2022 08:00	0.0	0	0	0	0	0
03/09/2022 09:00	0.0	0	0	0	0	0
03/09/2022 10:00	0.0	0	0	0	0	0
03/09/2022 11:00	0.0	0	0	0	0	0
03/09/2022 12:00	0.0	0	0	0	0	0
03/09/2022 13:00	0.0	0	0	0	0	0
03/09/2022 14:00	0.0	0	0	0	0	0
03/09/2022 15:00	0.0	0	0	0	0	0
03/09/2022 16:00	0.0	0	0	0	0	0
03/09/2022 17:00	0.0	0	0	0	0	0
03/09/2022 18:00	0.0	0	0	0	0	0
03/09/2022 19:00	0.0	0	0	0	0	0
03/09/2022 20:00	0.0	0	0	0	0	0
03/09/2022 21:00	0.0	0	0	0	0	0
03/09/2022 22:00	0.0	0	0	0	0	0
03/09/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/10/2022 00:00	0.0	0	0	0	0	0
03/10/2022 01:00	0.0	0	0	0	0	0
03/10/2022 02:00	0.0	0	0	0	0	0
03/10/2022 03:00	0.0	0	0	0	0	0
03/10/2022 04:00	0.0	0	0	0	0	0
03/10/2022 05:00	0.0	0	0	0	0	0
03/10/2022 06:00	0.0	0	0	0	0	0
03/10/2022 07:00	0.0	0	0	0	0	0
03/10/2022 08:00	0.0	0	0	0	0	0
03/10/2022 09:00	0.0	0	0	0	0	0
03/10/2022 10:00	0.0	0	0	0	0	0
03/10/2022 11:00	0.0	0	0	0	0	0
03/10/2022 12:00	0.0	0	0	0	0	0
03/10/2022 13:00	0.0	0	0	0	0	0
03/10/2022 14:00	0.0	0	0	0	0	0
03/10/2022 15:00	0.0	0	0	0	0	0
03/10/2022 16:00	0.0	0	0	0	0	0
03/10/2022 17:00	0.0	0	0	0	0	0
03/10/2022 18:00	0.0	0	0	0	0	0
03/10/2022 19:00	0.0	0	0	0	0	0
03/10/2022 20:00	0.0	0	0	0	0	0
03/10/2022 21:00	0.0	0	0	0	0	0
03/10/2022 22:00	0.0	0	0	0	0	0
03/10/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/11/2022 00:00	0.0	0	0	0	0	0
03/11/2022 01:00	0.0	0	0	0	0	0
03/11/2022 02:00	0.0	0	0	0	0	0
03/11/2022 03:00	0.0	0	0	0	0	0
03/11/2022 04:00	0.0	0	0	0	0	0
03/11/2022 05:00	0.0	0	0	0	0	0
03/11/2022 06:00	0.0	0	0	0	0	0
03/11/2022 07:00	0.0	0	0	0	0	0
03/11/2022 08:00	0.0	0	0	0	0	0
03/11/2022 09:00	0.0	0	0	0	0	0
03/11/2022 10:00	0.0	0	0	0	0	0
03/11/2022 11:00	0.0	0	0	0	0	0
03/11/2022 12:00	0.0	0	0	0	0	0
03/11/2022 13:00	0.0	0	0	0	0	0
03/11/2022 14:00	0.0	0	0	0	0	0
03/11/2022 15:00	0.0	0	0	0	0	0
03/11/2022 16:00	0.0	0	0	0	0	0
03/11/2022 17:00	0.0	0	0	0	0	0
03/11/2022 18:00	0.0	0	0	0	0	0
03/11/2022 19:00	0.0	0	0	0	0	0
03/11/2022 20:00	0.0	0	0	0	0	0
03/11/2022 21:00	0.0	0	0	0	0	0
03/11/2022 22:00	0.0	0	0	0	0	0
03/11/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/12/2022 00:00	0.0	0	0	0	0	0
03/12/2022 01:00	0.0	0	0	0	0	0
03/12/2022 02:00	0.0	0	0	0	0	0
03/12/2022 03:00	0.0	0	0	0	0	0
03/12/2022 04:00	0.0	0	0	0	0	0
03/12/2022 05:00	0.0	0	0	0	0	0
03/12/2022 06:00	0.0	0	0	0	0	0
03/12/2022 07:00	0.0	0	0	0	0	0
03/12/2022 08:00	0.0	0	0	0	0	0
03/12/2022 09:00	0.0	0	0	0	0	0
03/12/2022 10:00	0.0	0	0	0	0	0
03/12/2022 11:00	0.0	0	0	0	0	0
03/12/2022 12:00	0.0	0	0	0	0	0
03/12/2022 13:00	0.0	0	0	0	0	0
03/12/2022 14:00	0.0	0	0	0	0	0
03/12/2022 15:00	0.0	0	0	0	0	0
03/12/2022 16:00	0.0	0	0	0	0	0
03/12/2022 17:00	0.0	0	0	0	0	0
03/12/2022 18:00	0.0	0	0	0	0	0
03/12/2022 19:00	0.0	0	0	0	0	0
03/12/2022 20:00	0.0	0	0	0	0	0
03/12/2022 21:00	0.0	0	0	0	0	0
03/12/2022 22:00	0.0	0	0	0	0	0
03/12/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/13/2022 00:00	0.0	0	0	0	0	0
03/13/2022 01:00	0.0	0	0	0	0	0
03/13/2022 02:00	0.0	0	0	0	0	0
03/13/2022 03:00	0.0	0	0	0	0	0
03/13/2022 04:00	0.0	0	0	0	0	0
03/13/2022 05:00	0.0	0	0	0	0	0
03/13/2022 06:00	0.0	0	0	0	0	0
03/13/2022 07:00	0.0	0	0	0	0	0
03/13/2022 08:00	0.0	0	0	0	0	0
03/13/2022 09:00	0.0	0	0	0	0	0
03/13/2022 10:00	0.0	0	0	0	0	0
03/13/2022 11:00	0.0	0	0	0	0	0
03/13/2022 12:00	0.0	0	0	0	0	0
03/13/2022 13:00	0.0	0	0	0	0	0
03/13/2022 14:00	0.0	0	0	0	0	0
03/13/2022 15:00	0.0	0	0	0	0	0
03/13/2022 16:00	0.0	0	0	0	0	0
03/13/2022 17:00	0.0	0	0	0	0	0
03/13/2022 18:00	0.0	0	0	0	0	0
03/13/2022 19:00	0.0	0	0	0	0	0
03/13/2022 20:00	0.0	0	0	0	0	0
03/13/2022 21:00	0.0	0	0	0	0	0
03/13/2022 22:00	0.0	0	0	0	0	0
03/13/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/14/2022 00:00	0.0	0	0	0	0	0
03/14/2022 01:00	0.0	0	0	0	0	0
03/14/2022 02:00	0.0	0	0	0	0	0
03/14/2022 03:00	0.0	0	0	0	0	0
03/14/2022 04:00	0.0	0	0	0	0	0
03/14/2022 05:00	0.0	0	0	0	0	0
03/14/2022 06:00	0.0	0	0	0	0	0
03/14/2022 07:00	0.0	0	0	0	0	0
03/14/2022 08:00	0.0	0	0	0	0	0
03/14/2022 09:00	0.0	0	0	0	0	0
03/14/2022 10:00	0.0	0	0	0	0	0
03/14/2022 11:00	0.0	0	0	0	0	0
03/14/2022 12:00	0.0	0	0	0	0	0
03/14/2022 13:00	0.0	0	0	0	0	0
03/14/2022 14:00	0.0	0	0	0	0	0
03/14/2022 15:00	0.0	0	0	0	0	0
03/14/2022 16:00	0.0	0	0	0	0	0
03/14/2022 17:00	0.0	0	0	0	0	0
03/14/2022 18:00	0.0	0	0	0	0	0
03/14/2022 19:00	0.0	0	0	0	0	0
03/14/2022 20:00	0.0	0	0	0	0	0
03/14/2022 21:00	0.0	0	0	0	0	0
03/14/2022 22:00	0.0	0	0	0	0	0
03/14/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/15/2022 00:00	0.0	0	0	0	0	0
03/15/2022 01:00	0.0	0	0	0	0	0
03/15/2022 02:00	0.0	0	0	0	0	0
03/15/2022 03:00	0.0	0	0	0	0	0
03/15/2022 04:00	0.0	0	0	0	0	0
03/15/2022 05:00	0.0	0	0	0	0	0
03/15/2022 06:00	0.0	0	0	0	0	0
03/15/2022 07:00	0.0	0	0	0	0	0
03/15/2022 08:00	0.0	0	0	0	0	0
03/15/2022 09:00	0.0	0	0	0	0	0
03/15/2022 10:00	0.0	0	0	0	0	0
03/15/2022 11:00	0.0	0	0	0	0	0
03/15/2022 12:00	0.0	0	0	0	0	0
03/15/2022 13:00	0.0	0	0	0	0	0
03/15/2022 14:00	0.0	0	0	0	0	0
03/15/2022 15:00	0.0	0	0	0	0	0
03/15/2022 16:00	0.0	0	0	0	0	0
03/15/2022 17:00	0.0	0	0	0	0	0
03/15/2022 18:00	0.0	0	0	0	0	0
03/15/2022 19:00	0.0	0	0	0	0	0
03/15/2022 20:00	0.0	0	0	0	0	0
03/15/2022 21:00	0.0	0	0	0	0	0
03/15/2022 22:00	0.0	0	0	0	0	0
03/15/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/16/2022 00:00	0.0	0	0	0	0	0
03/16/2022 01:00	0.0	0	0	0	0	0
03/16/2022 02:00	0.0	0	0	0	0	0
03/16/2022 03:00	0.0	0	0	0	0	0
03/16/2022 04:00	0.0	0	0	0	0	0
03/16/2022 05:00	0.0	0	0	0	0	0
03/16/2022 06:00	0.0	0	0	0	0	0
03/16/2022 07:00	0.0	0	0	0	0	0
03/16/2022 08:00	0.0	0	0	0	0	0
03/16/2022 09:00	0.0	0	0	0	0	0
03/16/2022 10:00	0.0	0	0	0	0	0
03/16/2022 11:00	0.0	0	0	0	0	0
03/16/2022 12:00	0.0	0	0	0	0	0
03/16/2022 13:00	0.0	0	0	0	0	0
03/16/2022 14:00	0.0	0	0	0	0	0
03/16/2022 15:00	0.0	0	0	0	0	0
03/16/2022 16:00	0.0	0	0	0	0	0
03/16/2022 17:00	0.0	0	0	0	0	0
03/16/2022 18:00	0.0	0	0	0	0	0
03/16/2022 19:00	0.0	0	0	0	0	0
03/16/2022 20:00	0.0	0	0	0	0	0
03/16/2022 21:00	0.0	0	0	0	0	0
03/16/2022 22:00	0.0	0	0	0	0	0
03/16/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/17/2022 00:00	0.0	0	0	0	0	0
03/17/2022 01:00	0.0	0	0	0	0	0
03/17/2022 02:00	0.0	0	0	0	0	0
03/17/2022 03:00	0.0	0	0	0	0	0
03/17/2022 04:00	0.0	0	0	0	0	0
03/17/2022 05:00	0.0	0	0	0	0	0
03/17/2022 06:00	0.0	0	0	0	0	0
03/17/2022 07:00	0.0	0	0	0	0	0
03/17/2022 08:00	0.0	0	0	0	0	0
03/17/2022 09:00	0.0	0	0	0	0	0
03/17/2022 10:00	0.0	0	0	0	0	0
03/17/2022 11:00	0.0	0	0	0	0	0
03/17/2022 12:00	0.0	0	0	0	0	0
03/17/2022 13:00	0.0	0	0	0	0	0
03/17/2022 14:00	0.0	0	0	0	0	0
03/17/2022 15:00	0.0	0	0	0	0	0
03/17/2022 16:00	0.0	0	0	0	0	0
03/17/2022 17:00	0.0	0	0	0	0	0
03/17/2022 18:00	0.0	0	0	0	0	0
03/17/2022 19:00	0.0	0	0	0	0	0
03/17/2022 20:00	0.0	0	0	0	0	0
03/17/2022 21:00	0.0	0	0	0	0	0
03/17/2022 22:00	0.0	0	0	0	0	0
03/17/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/18/2022 00:00	0.0	0	0	0	0	0
03/18/2022 01:00	0.0	0	0	0	0	0
03/18/2022 02:00	0.0	0	0	0	0	0
03/18/2022 03:00	0.0	0	0	0	0	0
03/18/2022 04:00	0.0	0	0	0	0	0
03/18/2022 05:00	0.0	0	0	0	0	0
03/18/2022 06:00	0.0	0	0	0	0	0
03/18/2022 07:00	0.0	0	0	0	0	0
03/18/2022 08:00	0.0	0	0	0	0	0
03/18/2022 09:00	0.0	0	0	0	0	0
03/18/2022 10:00	0.0	0	0	0	0	0
03/18/2022 11:00	0.0	0	0	0	0	0
03/18/2022 12:00	0.0	0	0	0	0	0
03/18/2022 13:00	0.0	0	0	0	0	0
03/18/2022 14:00	0.0	0	0	0	0	0
03/18/2022 15:00	0.0	0	0	0	0	0
03/18/2022 16:00	0.0	0	0	0	0	0
03/18/2022 17:00	0.0	0	0	0	0	0
03/18/2022 18:00	0.0	0	0	0	0	0
03/18/2022 19:00	0.0	0	0	0	0	0
03/18/2022 20:00	0.0	0	0	0	0	0
03/18/2022 21:00	0.0	0	0	0	0	0
03/18/2022 22:00	0.0	0	0	0	0	0
03/18/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/19/2022 00:00	0.0	0	0	0	0	0
03/19/2022 01:00	0.0	0	0	0	0	0
03/19/2022 02:00	0.0	0	0	0	0	0
03/19/2022 03:00	0.0	0	0	0	0	0
03/19/2022 04:00	0.0	0	0	0	0	0
03/19/2022 05:00	0.0	0	0	0	0	0
03/19/2022 06:00	0.0	0	0	0	0	0
03/19/2022 07:00	0.0	0	0	0	0	0
03/19/2022 08:00	0.0	0	0	0	0	0
03/19/2022 09:00	0.0	0	0	0	0	0
03/19/2022 10:00	0.0	0	0	0	0	0
03/19/2022 11:00	0.0	0	0	0	0	0
03/19/2022 12:00	0.0	0	0	0	0	0
03/19/2022 13:00	0.0	0	0	0	0	0
03/19/2022 14:00	0.0	0	0	0	0	0
03/19/2022 15:00	0.0	0	0	0	0	0
03/19/2022 16:00	0.0	0	0	0	0	0
03/19/2022 17:00	0.0	0	0	0	0	0
03/19/2022 18:00	0.0	0	0	0	0	0
03/19/2022 19:00	0.0	0	0	0	0	0
03/19/2022 20:00	0.0	0	0	0	0	0
03/19/2022 21:00	0.0	0	0	0	0	0
03/19/2022 22:00	0.0	0	0	0	0	0
03/19/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/20/2022 00:00	0.0	0	0	0	0	0
03/20/2022 01:00	0.0	0	0	0	0	0
03/20/2022 02:00	0.0	0	0	0	0	0
03/20/2022 03:00	0.0	0	0	0	0	0
03/20/2022 04:00	0.0	0	0	0	0	0
03/20/2022 05:00	0.0	0	0	0	0	0
03/20/2022 06:00	0.0	0	0	0	0	0
03/20/2022 07:00	0.0	0	0	0	0	0
03/20/2022 08:00	0.0	0	0	0	0	0
03/20/2022 09:00	0.0	0	0	0	0	0
03/20/2022 10:00	0.0	0	0	0	0	0
03/20/2022 11:00	0.0	0	0	0	0	0
03/20/2022 12:00	0.0	0	0	0	0	0
03/20/2022 13:00	0.0	0	0	0	0	0
03/20/2022 14:00	0.0	0	0	0	0	0
03/20/2022 15:00	0.0	0	0	0	0	0
03/20/2022 16:00	0.0	0	0	0	0	0
03/20/2022 17:00	0.0	0	0	0	0	0
03/20/2022 18:00	0.0	0	0	0	0	0
03/20/2022 19:00	0.0	0	0	0	0	0
03/20/2022 20:00	0.0	0	0	0	0	0
03/20/2022 21:00	0.0	0	0	0	0	0
03/20/2022 22:00	0.0	0	0	0	0	0
03/20/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/21/2022 00:00	0.0	0	0	0	0	0
03/21/2022 01:00	0.0	0	0	0	0	0
03/21/2022 02:00	0.0	0	0	0	0	0
03/21/2022 03:00	0.0	0	0	0	0	0
03/21/2022 04:00	0.0	0	0	0	0	0
03/21/2022 05:00	0.0	0	0	0	0	0
03/21/2022 06:00	0.0	0	0	0	0	0
03/21/2022 07:00	0.0	0	0	0	0	0
03/21/2022 08:00	0.0	0	0	0	0	0
03/21/2022 09:00	0.0	0	0	0	0	0
03/21/2022 10:00	0.0	0	0	0	0	0
03/21/2022 11:00	0.0	0	0	0	0	0
03/21/2022 12:00	0.0	0	0	0	0	0
03/21/2022 13:00	0.0	0	0	0	0	0
03/21/2022 14:00	0.0	0	0	0	0	0
03/21/2022 15:00	0.0	0	0	0	0	0
03/21/2022 16:00	0.0	0	0	0	0	0
03/21/2022 17:00	0.0	0	0	0	0	0
03/21/2022 18:00	0.0	0	0	0	0	0
03/21/2022 19:00	0.0	0	0	0	0	0
03/21/2022 20:00	0.0	0	0	0	0	0
03/21/2022 21:00	0.0	0	0	0	0	0
03/21/2022 22:00	0.0	0	0	0	0	0
03/21/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/22/2022 00:00	0.0	0	0	0	0	0
03/22/2022 01:00	0.0	0	0	0	0	0
03/22/2022 02:00	0.0	0	0	0	0	0
03/22/2022 03:00	0.0	0	0	0	0	0
03/22/2022 04:00	0.0	0	0	0	0	0
03/22/2022 05:00	0.0	0	0	0	0	0
03/22/2022 06:00	0.0	0	0	0	0	0
03/22/2022 07:00	0.0	0	0	0	0	0
03/22/2022 08:00	0.0	0	0	0	0	0
03/22/2022 09:00	0.0	0	0	0	0	0
03/22/2022 10:00	0.0	0	0	0	0	0
03/22/2022 11:00	0.0	0	0	0	0	0
03/22/2022 12:00	0.0	0	0	0	0	0
03/22/2022 13:00	0.0	0	0	0	0	0
03/22/2022 14:00	0.0	0	0	0	0	0
03/22/2022 15:00	0.0	0	0	0	0	0
03/22/2022 16:00	0.0	0	0	0	0	0
03/22/2022 17:00	0.0	0	0	0	0	0
03/22/2022 18:00	0.0	0	0	0	0	0
03/22/2022 19:00	0.0	0	0	0	0	0
03/22/2022 20:00	0.0	0	0	0	0	0
03/22/2022 21:00	0.0	0	0	0	0	0
03/22/2022 22:00	0.0	0	0	0	0	0
03/22/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/23/2022 00:00	0.0	0	0	0	0	0
03/23/2022 01:00	0.0	0	0	0	0	0
03/23/2022 02:00	0.0	0	0	0	0	0
03/23/2022 03:00	0.0	0	0	0	0	0
03/23/2022 04:00	0.0	0	0	0	0	0
03/23/2022 05:00	0.0	0	0	0	0	0
03/23/2022 06:00	0.0	0	0	0	0	0
03/23/2022 07:00	0.0	0	0	0	0	0
03/23/2022 08:00	0.0	0	0	0	0	0
03/23/2022 09:00	0.0	0	0	0	0	0
03/23/2022 10:00	0.0	0	0	0	0	0
03/23/2022 11:00	0.0	0	0	0	0	0
03/23/2022 12:00	0.0	0	0	0	0	0
03/23/2022 13:00	0.0	0	0	0	0	0
03/23/2022 14:00	0.0	0	0	0	0	0
03/23/2022 15:00	0.0	0	0	0	0	0
03/23/2022 16:00	0.0	0	0	0	0	0
03/23/2022 17:00	0.0	0	0	0	0	0
03/23/2022 18:00	0.0	0	0	0	0	0
03/23/2022 19:00	0.0	0	0	0	0	0
03/23/2022 20:00	0.0	0	0	0	0	0
03/23/2022 21:00	0.0	0	0	0	0	0
03/23/2022 22:00	0.0	0	0	0	0	0
03/23/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/24/2022 00:00	0.0	0	0	0	0	0
03/24/2022 01:00	0.0	0	0	0	0	0
03/24/2022 02:00	0.0	0	0	0	0	0
03/24/2022 03:00	0.0	0	0	0	0	0
03/24/2022 04:00	0.0	0	0	0	0	0
03/24/2022 05:00	0.0	0	0	0	0	0
03/24/2022 06:00	0.0	0	0	0	0	0
03/24/2022 07:00	0.0	0	0	0	0	0
03/24/2022 08:00	0.0	0	0	0	0	0
03/24/2022 09:00	0.0	0	0	0	0	0
03/24/2022 10:00	0.0	0	0	0	0	0
03/24/2022 11:00	0.0	0	0	0	0	0
03/24/2022 12:00	0.0	0	0	0	0	0
03/24/2022 13:00	0.0	0	0	0	0	0
03/24/2022 14:00	0.0	0	0	0	0	0
03/24/2022 15:00	0.0	0	0	0	0	0
03/24/2022 16:00	0.0	0	0	0	0	0
03/24/2022 17:00	0.0	0	0	0	0	0
03/24/2022 18:00	0.0	0	0	0	0	0
03/24/2022 19:00	0.0	0	0	0	0	0
03/24/2022 20:00	0.0	0	0	0	0	0
03/24/2022 21:00	0.0	0	0	0	0	0
03/24/2022 22:00	0.0	0	0	0	0	0
03/24/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/25/2022 00:00	0.0	0	0	0	0	0
03/25/2022 01:00	0.0	0	0	0	0	0
03/25/2022 02:00	0.0	0	0	0	0	0
03/25/2022 03:00	0.0	0	0	0	0	0
03/25/2022 04:00	0.0	0	0	0	0	0
03/25/2022 05:00	0.0	0	0	0	0	0
03/25/2022 06:00	0.0	0	0	0	0	0
03/25/2022 07:00	0.0	0	0	0	0	0
03/25/2022 08:00	0.0	0	0	0	0	0
03/25/2022 09:00	0.0	0	0	0	0	0
03/25/2022 10:00	0.0	0	0	0	0	0
03/25/2022 11:00	0.0	0	0	0	0	0
03/25/2022 12:00	0.0	0	0	0	0	0
03/25/2022 13:00	0.0	0	0	0	0	0
03/25/2022 14:00	0.0	0	0	0	0	0
03/25/2022 15:00	0.0	0	0	0	0	0
03/25/2022 16:00	0.0	0	0	0	0	0
03/25/2022 17:00	0.0	0	0	0	0	0
03/25/2022 18:00	0.0	0	0	0	0	0
03/25/2022 19:00	0.0	0	0	0	0	0
03/25/2022 20:00	0.0	0	0	0	0	0
03/25/2022 21:00	0.0	0	0	0	0	0
03/25/2022 22:00	0.0	0	0	0	0	0
03/25/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwelll, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/26/2022 00:00	0.0	0	0	0	0	0
03/26/2022 01:00	0.0	0	0	0	0	0
03/26/2022 02:00	0.0	0	0	0	0	0
03/26/2022 03:00	0.0	0	0	0	0	0
03/26/2022 04:00	0.0	0	0	0	0	0
03/26/2022 05:00	0.0	0	0	0	0	0
03/26/2022 06:00	0.0	0	0	0	0	0
03/26/2022 07:00	0.0	0	0	0	0	0
03/26/2022 08:00	0.0	0	0	0	0	0
03/26/2022 09:00	0.0	0	0	0	0	0
03/26/2022 10:00	0.0	0	0	0	0	0
03/26/2022 11:00	0.0	0	0	0	0	0
03/26/2022 12:00	0.0	0	0	0	0	0
03/26/2022 13:00	0.0	0	0	0	0	0
03/26/2022 14:00	0.0	0	0	0	0	0
03/26/2022 15:00	0.0	0	0	0	0	0
03/26/2022 16:00	0.0	0	0	0	0	0
03/26/2022 17:00	0.0	0	0	0	0	0
03/26/2022 18:00	0.0	0	0	0	0	0
03/26/2022 19:00	0.0	0	0	0	0	0
03/26/2022 20:00	0.0	0	0	0	0	0
03/26/2022 21:00	0.0	0	0	0	0	0
03/26/2022 22:00	0.0	0	0	0	0	0
03/26/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/27/2022 00:00	0.0	0	0	0	0	0
03/27/2022 01:00	0.0	0	0	0	0	0
03/27/2022 02:00	0.0	0	0	0	0	0
03/27/2022 03:00	0.0	0	0	0	0	0
03/27/2022 04:00	0.0	0	0	0	0	0
03/27/2022 05:00	0.0	0	0	0	0	0
03/27/2022 06:00	0.0	0	0	0	0	0
03/27/2022 07:00	0.0	0	0	0	0	0
03/27/2022 08:00	0.0	0	0	0	0	0
03/27/2022 09:00	0.0	0	0	0	0	0
03/27/2022 10:00	0.0	0	0	0	0	0
03/27/2022 11:00	0.0	0	0	0	0	0
03/27/2022 12:00	0.0	0	0	0	0	0
03/27/2022 13:00	0.0	0	0	0	0	0
03/27/2022 14:00	0.0	0	0	0	0	0
03/27/2022 15:00	0.0	0	0	0	0	0
03/27/2022 16:00	0.0	0	0	0	0	0
03/27/2022 17:00	0.0	0	0	0	0	0
03/27/2022 18:00	0.0	0	0	0	0	0
03/27/2022 19:00	0.0	0	0	0	0	0
03/27/2022 20:00	0.0	0	0	0	0	0
03/27/2022 21:00	0.0	0	0	0	0	0
03/27/2022 22:00	0.0	0	0	0	0	0
03/27/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/28/2022 00:00	0.0	0	0	0	0	0
03/28/2022 01:00	0.0	0	0	0	0	0
03/28/2022 02:00	0.0	0	0	0	0	0
03/28/2022 03:00	0.0	0	0	0	0	0
03/28/2022 04:00	0.0	0	0	0	0	0
03/28/2022 05:00	0.0	0	0	0	0	0
03/28/2022 06:00	0.0	0	0	0	0	0
03/28/2022 07:00	0.0	0	0	0	0	0
03/28/2022 08:00	0.0	0	0	0	0	0
03/28/2022 09:00	0.0	0	0	0	0	0
03/28/2022 10:00	0.0	0	0	0	0	0
03/28/2022 11:00	0.0	0	0	0	0	0
03/28/2022 12:00	0.0	0	0	0	0	0
03/28/2022 13:00	0.0	0	0	0	0	0
03/28/2022 14:00	0.0	0	0	0	0	0
03/28/2022 15:00	0.0	0	0	0	0	0
03/28/2022 16:00	0.0	0	0	0	0	0
03/28/2022 17:00	0.0	0	0	0	0	0
03/28/2022 18:00	0.0	0	0	0	0	0
03/28/2022 19:00	0.0	0	0	0	0	0
03/28/2022 20:00	0.0	0	0	0	0	0
03/28/2022 21:00	0.0	0	0	0	0	0
03/28/2022 22:00	0.0	0	0	0	0	0
03/28/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/29/2022 00:00	0.0	0	0	0	0	0
03/29/2022 01:00	0.0	0	0	0	0	0
03/29/2022 02:00	0.0	0	0	0	0	0
03/29/2022 03:00	0.0	0	0	0	0	0
03/29/2022 04:00	0.0	0	0	0	0	0
03/29/2022 05:00	0.0	0	0	0	0	0
03/29/2022 06:00	0.0	0	0	0	0	0
03/29/2022 07:00	0.0	0	0	0	0	0
03/29/2022 08:00	0.0	0	0	0	0	0
03/29/2022 09:00	0.0	0	0	0	0	0
03/29/2022 10:00	0.0	0	0	0	0	0
03/29/2022 11:00	0.0	0	0	0	0	0
03/29/2022 12:00	0.0	0	0	0	0	0
03/29/2022 13:00	0.0	0	0	0	0	0
03/29/2022 14:00	0.0	0	0	0	0	0
03/29/2022 15:00	0.0	0	0	0	0	0
03/29/2022 16:00	0.0	0	0	0	0	0
03/29/2022 17:00	0.0	0	0	0	0	0
03/29/2022 18:00	0.0	0	0	0	0	0
03/29/2022 19:00	0.0	0	0	0	0	0
03/29/2022 20:00	0.0	0	0	0	0	0
03/29/2022 21:00	0.0	0	0	0	0	0
03/29/2022 22:00	0.0	0	0	0	0	0
03/29/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/30/2022 00:00	0.0	0	0	0	0	0
03/30/2022 01:00	0.0	0	0	0	0	0
03/30/2022 02:00	0.0	0	0	0	0	0
03/30/2022 03:00	0.0	0	0	0	0	0
03/30/2022 04:00	0.0	0	0	0	0	0
03/30/2022 05:00	0.0	0	0	0	0	0
03/30/2022 06:00	0.0	0	0	0	0	0
03/30/2022 07:00	0.0	0	0	0	0	0
03/30/2022 08:00	0.0	0	0	0	0	0
03/30/2022 09:00	0.0	0	0	0	0	0
03/30/2022 10:00	0.0	0	0	0	0	0
03/30/2022 11:00	0.0	0	0	0	0	0
03/30/2022 12:00	0.0	0	0	0	0	0
03/30/2022 13:00	0.0	0	0	0	0	0
03/30/2022 14:00	0.0	0	0	0	0	0
03/30/2022 15:00	0.0	0	0	0	0	0
03/30/2022 16:00	0.0	0	0	0	0	0
03/30/2022 17:00	0.0	0	0	0	0	0
03/30/2022 18:00	0.0	0	0	0	0	0
03/30/2022 19:00	0.0	0	0	0	0	0
03/30/2022 20:00	0.0	0	0	0	0	0
03/30/2022 21:00	0.0	0	0	0	0	0
03/30/2022 22:00	0.0	0	0	0	0	0
03/30/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/31/2022 00:00	0.0	0	0	0	0	0
03/31/2022 01:00	0.0	0	0	0	0	0
03/31/2022 02:00	0.0	0	0	0	0	0
03/31/2022 03:00	0.0	0	0	0	0	0
03/31/2022 04:00	0.0	0	0	0	0	0
03/31/2022 05:00	0.0	0	0	0	0	0
03/31/2022 06:00	0.0	0	0	0	0	0
03/31/2022 07:00	0.0	0	0	0	0	0
03/31/2022 08:00	0.0	0	0	0	0	0
03/31/2022 09:00	0.0	0	0	0	0	0
03/31/2022 10:00	0.0	0	0	0	0	0
03/31/2022 11:00	0.0	0	0	0	0	0
03/31/2022 12:00	0.0	0	0	0	0	0
03/31/2022 13:00	0.0	0	0	0	0	0
03/31/2022 14:00	0.0	0	0	0	0	0
03/31/2022 15:00	0.0	0	0	0	0	0
03/31/2022 16:00	0.0	0	0	0	0	0
03/31/2022 17:00	0.0	0	0	0	0	0
03/31/2022 18:00	0.0	0	0	0	0	0
03/31/2022 19:00	0.0	0	0	0	0	0
03/31/2022 20:00	0.0	0	0	0	0	0
03/31/2022 21:00	0.0	0	0	0	0	0
03/31/2022 22:00	0.0	0	0	0	0	0
03/31/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/01/2022 00:00	0.0	0	0	0	0	1
01/01/2022 01:00	0.0	0	0	0	0	1
01/01/2022 02:00	0.0	0	0	0	0	1
01/01/2022 03:00	0.0	0	0	0	0	1
01/01/2022 04:00	0.0	0	0	0	0	1
01/01/2022 05:00	0.0	0	0	0	0	1
01/01/2022 06:00	0.0	0	0	0	0	1
01/01/2022 07:00	0.0	0	0	0	0	1
01/01/2022 08:00	0.0	0	0	0	0	1
01/01/2022 09:00	0.0	0	0	0	0	1
01/01/2022 10:00	0.0	0	0	0	0	1
01/01/2022 11:00	0.0	0	0	0	0	1
01/01/2022 12:00	0.0	0	0	0	0	1
01/01/2022 13:00	0.0	0	0	0	0	1
01/01/2022 14:00	0.0	0	0	0	0	1
01/01/2022 15:00	0.0	0	0	0	0	1
01/01/2022 16:00	0.0	0	0	0	0	1
01/01/2022 17:00	0.0	0	0	0	0	1
01/01/2022 18:00	0.0	0	0	0	0	1
01/01/2022 19:00	0.0	0	0	0	0	1
01/01/2022 20:00	0.0	0	0	0	0	1
01/01/2022 21:00	0.0	0	0	0	0	1
01/01/2022 22:00	0.0	0	0	0	0	1
01/01/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/02/2022 00:00	0.0	0	0	0	0	1
01/02/2022 01:00	0.0	0	0	0	0	1
01/02/2022 02:00	0.0	0	0	0	0	1
01/02/2022 03:00	0.0	0	0	0	0	1
01/02/2022 04:00	0.0	0	0	0	0	1
01/02/2022 05:00	0.0	0	0	0	0	1
01/02/2022 06:00	0.0	0	0	0	0	1
01/02/2022 07:00	0.0	0	0	0	0	1
01/02/2022 08:00	0.0	0	0	0	0	1
01/02/2022 09:00	0.0	0	0	0	0	1
01/02/2022 10:00	0.0	0	0	0	0	1
01/02/2022 11:00	0.0	0	0	0	0	1
01/02/2022 12:00	0.0	0	0	0	0	1
01/02/2022 13:00	0.0	0	0	0	0	1
01/02/2022 14:00	0.0	0	0	0	0	1
01/02/2022 15:00	0.0	0	0	0	0	1
01/02/2022 16:00	0.0	0	0	0	0	1
01/02/2022 17:00	0.0	0	0	0	0	1
01/02/2022 18:00	0.0	0	0	0	0	1
01/02/2022 19:00	0.0	0	0	0	0	1
01/02/2022 20:00	0.0	0	0	0	0	1
01/02/2022 21:00	0.0	0	0	0	0	1
01/02/2022 22:00	0.0	0	0	0	0	1
01/02/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/03/2022 00:00	0.0	0	0	0	0	1
01/03/2022 01:00	0.0	0	0	0	0	1
01/03/2022 02:00	0.0	0	0	0	0	1
01/03/2022 03:00	0.0	0	0	0	0	1
01/03/2022 04:00	0.0	0	0	0	0	1
01/03/2022 05:00	0.0	0	0	0	0	1
01/03/2022 06:00	0.0	0	0	0	0	1
01/03/2022 07:00	0.0	0	0	0	0	1
01/03/2022 08:00	0.0	0	0	0	0	1
01/03/2022 09:00	0.0	0	0	0	0	1
01/03/2022 10:00	0.0	0	0	0	0	1
01/03/2022 11:00	0.0	0	0	0	0	1
01/03/2022 12:00	0.0	0	0	0	0	1
01/03/2022 13:00	0.0	0	0	0	0	1
01/03/2022 14:00	0.0	0	0	0	0	1
01/03/2022 15:00	0.0	0	0	0	0	1
01/03/2022 16:00	0.0	0	0	0	0	1
01/03/2022 17:00	0.0	0	0	0	0	1
01/03/2022 18:00	0.0	0	0	0	0	1
01/03/2022 19:00	0.0	0	0	0	0	1
01/03/2022 20:00	0.0	0	0	0	0	1
01/03/2022 21:00	0.0	0	0	0	0	1
01/03/2022 22:00	0.0	0	0	0	0	1
01/03/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/04/2022 00:00	0.0	0	0	0	0	1
01/04/2022 01:00	0.0	0	0	0	0	1
01/04/2022 02:00	0.0	0	0	0	0	1
01/04/2022 03:00	0.0	0	0	0	0	1
01/04/2022 04:00	0.0	0	0	0	0	1
01/04/2022 05:00	0.0	0	0	0	0	1
01/04/2022 06:00	0.0	0	0	0	0	1
01/04/2022 07:00	0.0	0	0	0	0	1
01/04/2022 08:00	0.0	0	0	0	0	1
01/04/2022 09:00	0.0	0	0	0	0	1
01/04/2022 10:00	0.0	0	0	0	0	1
01/04/2022 11:00	0.0	0	0	0	0	1
01/04/2022 12:00	0.0	0	0	0	0	1
01/04/2022 13:00	0.0	0	0	0	0	1
01/04/2022 14:00	0.0	0	0	0	0	1
01/04/2022 15:00	0.0	0	0	0	0	1
01/04/2022 16:00	0.0	0	0	0	0	1
01/04/2022 17:00	0.0	0	0	0	0	1
01/04/2022 18:00	0.0	0	0	0	0	1
01/04/2022 19:00	0.0	0	0	0	0	1
01/04/2022 20:00	0.0	0	0	0	0	1
01/04/2022 21:00	0.0	0	0	0	0	1
01/04/2022 22:00	0.0	0	0	0	0	1
01/04/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/05/2022 00:00	0.0	0	0	0	0	1
01/05/2022 01:00	0.0	0	0	0	0	1
01/05/2022 02:00	0.0	0	0	0	0	1
01/05/2022 03:00	0.0	0	0	0	0	1
01/05/2022 04:00	0.0	0	0	0	0	1
01/05/2022 05:00	0.0	0	0	0	0	1
01/05/2022 06:00	0.0	0	0	0	0	1
01/05/2022 07:00	0.0	0	0	0	0	1
01/05/2022 08:00	0.0	0	0	0	0	1
01/05/2022 09:00	0.0	0	0	0	0	1
01/05/2022 10:00	0.0	0	0	0	0	1
01/05/2022 11:00	0.0	0	0	0	0	1
01/05/2022 12:00	0.0	0	0	0	0	1
01/05/2022 13:00	0.0	0	0	0	0	1
01/05/2022 14:00	0.0	0	0	0	0	1
01/05/2022 15:00	0.0	0	0	0	0	1
01/05/2022 16:00	0.0	0	0	0	0	1
01/05/2022 17:00	0.0	0	0	0	0	1
01/05/2022 18:00	0.0	0	0	0	0	1
01/05/2022 19:00	0.0	0	0	0	0	1
01/05/2022 20:00	0.0	0	0	0	0	1
01/05/2022 21:00	0.0	0	0	0	0	1
01/05/2022 22:00	0.0	0	0	0	0	1
01/05/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/06/2022 00:00	0.0	0	0	0	0	1
01/06/2022 01:00	0.0	0	0	0	0	1
01/06/2022 02:00	0.0	0	0	0	0	1
01/06/2022 03:00	0.0	0	0	0	0	1
01/06/2022 04:00	0.0	0	0	0	0	1
01/06/2022 05:00	0.0	0	0	0	0	1
01/06/2022 06:00	0.0	0	0	0	0	1
01/06/2022 07:00	0.0	0	0	0	0	1
01/06/2022 08:00	0.0	0	0	0	0	1
01/06/2022 09:00	0.0	0	0	0	0	1
01/06/2022 10:00	0.0	0	0	0	0	1
01/06/2022 11:00	0.0	0	0	0	0	1
01/06/2022 12:00	0.0	0	0	0	0	1
01/06/2022 13:00	0.0	0	0	0	0	1
01/06/2022 14:00	0.0	0	0	0	0	1
01/06/2022 15:00	0.0	0	0	0	0	1
01/06/2022 16:00	0.0	0	0	0	0	1
01/06/2022 17:00	0.0	0	0	0	0	1
01/06/2022 18:00	0.0	0	0	0	0	1
01/06/2022 19:00	0.0	0	0	0	0	1
01/06/2022 20:00	0.0	0	0	0	0	1
01/06/2022 21:00	0.0	0	0	0	0	1
01/06/2022 22:00	0.0	0	0	0	0	1
01/06/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/07/2022 00:00	0.0	0	0	0	0	1
01/07/2022 01:00	0.0	0	0	0	0	1
01/07/2022 02:00	0.0	0	0	0	0	1
01/07/2022 03:00	0.0	0	0	0	0	1
01/07/2022 04:00	0.0	0	0	0	0	1
01/07/2022 05:00	0.0	0	0	0	0	1
01/07/2022 06:00	0.0	0	0	0	0	1
01/07/2022 07:00	0.0	0	0	0	0	1
01/07/2022 08:00	0.0	0	0	0	0	1
01/07/2022 09:00	0.0	0	0	0	0	1
01/07/2022 10:00	0.0	0	0	0	0	1
01/07/2022 11:00	0.0	0	0	0	0	1
01/07/2022 12:00	0.0	0	0	0	0	1
01/07/2022 13:00	0.0	0	0	0	0	1
01/07/2022 14:00	0.0	0	0	0	0	1
01/07/2022 15:00	0.0	0	0	0	0	1
01/07/2022 16:00	0.0	0	0	0	0	1
01/07/2022 17:00	0.0	0	0	0	0	1
01/07/2022 18:00	0.0	0	0	0	0	1
01/07/2022 19:00	0.0	0	0	0	0	1
01/07/2022 20:00	0.0	0	0	0	0	1
01/07/2022 21:00	0.0	0	0	0	0	1
01/07/2022 22:00	33.5	0	0	0	1	0
01/07/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	33.5 #	0 #	0 #	0 #	1 #	22 #
Minimum:	0.0	0	0	0	0	0
Maximum:	33.5	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/08/2022 00:00	0.0	0	0	0	0	0
01/08/2022 01:00	0.0	0	0	0	0	0
01/08/2022 02:00	0.0	0	0	0	0	0
01/08/2022 03:00	0.0	0	0	0	0	0
01/08/2022 04:00	0.0	0	0	0	0	0
01/08/2022 05:00	0.0	0	0	0	0	0
01/08/2022 06:00	0.0	0	0	0	0	0
01/08/2022 07:00	0.0	0	0	0	0	0
01/08/2022 08:00	0.0	0	0	0	0	0
01/08/2022 09:00	0.0	0	0	0	0	0
01/08/2022 10:00	1,544.7	0	1	0	0	0
01/08/2022 11:00	3,731.4	0	1	0	0	0
01/08/2022 12:00	5,596.8	0	1	0	0	0
01/08/2022 13:00	0.0	0	0	0	0	1
01/08/2022 14:00	0.0	0	0	0	0	1
01/08/2022 15:00	0.0	0	0	0	0	1
01/08/2022 16:00	0.0	0	0	0	0	1
01/08/2022 17:00	0.0	0	0	0	0	1
01/08/2022 18:00	0.0	0	0	0	0	1
01/08/2022 19:00	0.0	0	0	0	0	1
01/08/2022 20:00	0.0	0	0	0	0	1
01/08/2022 21:00	0.0	0	0	0	0	1
01/08/2022 22:00	0.0	0	0	0	0	1
01/08/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	10,872.9 #	0 #	3 #	0 #	0 #	11 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,596.8	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/09/2022 00:00	0.0	0	0	0	0	1
01/09/2022 01:00	0.0	0	0	0	0	1
01/09/2022 02:00	0.0	0	0	0	0	1
01/09/2022 03:00	0.0	0	0	0	0	1
01/09/2022 04:00	0.0	0	0	0	0	1
01/09/2022 05:00	0.0	0	0	0	0	1
01/09/2022 06:00	0.0	0	0	0	0	1
01/09/2022 07:00	0.0	0	0	0	0	1
01/09/2022 08:00	0.0	0	0	0	0	1
01/09/2022 09:00	0.0	0	0	0	0	1
01/09/2022 10:00	0.0	0	0	0	0	1
01/09/2022 11:00	0.0	0	0	0	0	1
01/09/2022 12:00	0.0	0	0	0	0	1
01/09/2022 13:00	0.0	0	0	0	0	1
01/09/2022 14:00	0.0	0	0	0	0	1
01/09/2022 15:00	0.0	0	0	0	0	1
01/09/2022 16:00	0.0	0	0	0	0	1
01/09/2022 17:00	0.0	0	0	0	0	1
01/09/2022 18:00	0.0	0	0	0	0	1
01/09/2022 19:00	0.0	0	0	0	0	1
01/09/2022 20:00	0.0	0	0	0	0	1
01/09/2022 21:00	0.0	0	0	0	0	1
01/09/2022 22:00	0.0	0	0	0	0	1
01/09/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/10/2022 00:00	0.0	0	0	0	0	1
01/10/2022 01:00	0.0	0	0	0	0	1
01/10/2022 02:00	0.0	0	0	0	0	1
01/10/2022 03:00	0.0	0	0	0	0	1
01/10/2022 04:00	0.0	0	0	0	0	1
01/10/2022 05:00	0.0	0	0	0	0	1
01/10/2022 06:00	0.0	0	0	0	0	1
01/10/2022 07:00	0.0	0	0	0	0	1
01/10/2022 08:00	0.0	0	0	0	0	1
01/10/2022 09:00	0.0	0	0	0	0	1
01/10/2022 10:00	0.0	0	0	0	0	1
01/10/2022 11:00	0.0	0	0	0	0	1
01/10/2022 12:00	0.0	0	0	0	0	1
01/10/2022 13:00	0.0	0	0	0	0	1
01/10/2022 14:00	0.0	0	0	0	0	1
01/10/2022 15:00	0.0	0	0	0	0	1
01/10/2022 16:00	0.0	0	0	0	0	1
01/10/2022 17:00	0.0	0	0	0	0	1
01/10/2022 18:00	0.0	0	0	0	0	1
01/10/2022 19:00	0.0	0	0	0	0	1
01/10/2022 20:00	0.0	0	0	0	0	1
01/10/2022 21:00	0.0	0	0	0	0	1
01/10/2022 22:00	0.0	0	0	0	0	1
01/10/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/11/2022 00:00	0.0	0	0	0	0	1
01/11/2022 01:00	0.0	0	0	0	0	1
01/11/2022 02:00	0.0	0	0	0	0	1
01/11/2022 03:00	0.0	0	0	0	0	1
01/11/2022 04:00	0.0	0	0	0	0	1
01/11/2022 05:00	0.0	0	0	0	0	1
01/11/2022 06:00	0.0	0	0	0	0	1
01/11/2022 07:00	0.0	0	0	0	0	1
01/11/2022 08:00	0.0	0	0	0	0	1
01/11/2022 09:00	0.0	0	0	0	0	1
01/11/2022 10:00	0.0	0	0	0	0	1
01/11/2022 11:00	0.0	0	0	0	0	1
01/11/2022 12:00	0.0	0	0	0	0	1
01/11/2022 13:00	0.0	0	0	0	0	1
01/11/2022 14:00	0.0	0	0	0	0	1
01/11/2022 15:00	0.0	0	0	0	0	1
01/11/2022 16:00	0.0	0	0	0	0	1
01/11/2022 17:00	0.0	0	0	0	0	1
01/11/2022 18:00	0.0	0	0	0	0	1
01/11/2022 19:00	0.0	0	0	0	0	1
01/11/2022 20:00	0.0	0	0	0	0	1
01/11/2022 21:00	0.0	0	0	0	0	1
01/11/2022 22:00	0.0	0	0	0	0	1
01/11/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/12/2022 00:00	0.0	0	0	0	0	1
01/12/2022 01:00	0.0	0	0	0	0	1
01/12/2022 02:00	0.0	0	0	0	0	1
01/12/2022 03:00	0.0	0	0	0	0	1
01/12/2022 04:00	0.0	0	0	0	0	1
01/12/2022 05:00	0.0	0	0	0	0	1
01/12/2022 06:00	0.0	0	0	0	0	1
01/12/2022 07:00	0.0	0	0	0	0	1
01/12/2022 08:00	0.0	0	0	0	0	1
01/12/2022 09:00	0.0	0	0	0	0	1
01/12/2022 10:00	0.0	0	0	0	0	1
01/12/2022 11:00	0.0	0	0	0	0	1
01/12/2022 12:00	0.0	0	0	0	0	1
01/12/2022 13:00	0.0	0	0	0	0	1
01/12/2022 14:00	0.0	0	0	0	0	1
01/12/2022 15:00	0.0	0	0	0	0	1
01/12/2022 16:00	0.0	0	0	0	0	1
01/12/2022 17:00	0.0	0	0	0	0	1
01/12/2022 18:00	0.0	0	0	0	0	1
01/12/2022 19:00	0.0	0	0	0	0	1
01/12/2022 20:00	0.0	0	0	0	0	1
01/12/2022 21:00	0.0	0	0	0	0	1
01/12/2022 22:00	0.0	0	0	0	0	1
01/12/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/13/2022 00:00	0.0	0	0	0	0	1
01/13/2022 01:00	0.0	0	0	0	0	1
01/13/2022 02:00	0.0	0	0	0	0	1
01/13/2022 03:00	0.0	0	0	0	0	1
01/13/2022 04:00	0.0	0	0	0	0	1
01/13/2022 05:00	0.0	0	0	0	0	1
01/13/2022 06:00	0.0	0	0	0	0	1
01/13/2022 07:00	0.0	0	0	0	0	1
01/13/2022 08:00	0.0	0	0	0	0	1
01/13/2022 09:00	0.0	0	0	0	0	1
01/13/2022 10:00	0.0	0	0	0	0	1
01/13/2022 11:00	0.0	0	0	0	0	1
01/13/2022 12:00	0.0	0	0	0	0	1
01/13/2022 13:00	0.0	0	0	0	0	1
01/13/2022 14:00	0.0	0	0	0	0	1
01/13/2022 15:00	0.0	0	0	0	0	1
01/13/2022 16:00	0.0	0	0	0	0	1
01/13/2022 17:00	0.0	0	0	0	0	1
01/13/2022 18:00	0.0	0	0	0	0	1
01/13/2022 19:00	0.0	0	0	0	0	1
01/13/2022 20:00	0.0	0	0	0	0	1
01/13/2022 21:00	0.0	0	0	0	0	1
01/13/2022 22:00	0.0	0	0	0	0	1
01/13/2022 23:00	33.8	0	0	0	1	0
Average/Sum#:	33.8 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	33.8	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/14/2022 00:00	0.0	0	0	0	0	0
01/14/2022 01:00	0.0	0	0	0	0	0
01/14/2022 02:00	0.0	0	0	0	0	0
01/14/2022 03:00	0.0	0	0	0	0	0
01/14/2022 04:00	814.6	0	0	1	0	0
01/14/2022 05:00	6,335.5	0	0	1	0	0
01/14/2022 06:00	0.0	0	0	0	0	1
01/14/2022 07:00	0.0	0	0	0	0	1
01/14/2022 08:00	0.0	0	0	0	0	1
01/14/2022 09:00	0.0	0	0	0	0	1
01/14/2022 10:00	0.0	0	0	0	0	1
01/14/2022 11:00	0.0	0	0	0	0	1
01/14/2022 12:00	0.0	0	0	0	0	1
01/14/2022 13:00	0.0	0	0	0	0	1
01/14/2022 14:00	0.0	0	0	0	0	1
01/14/2022 15:00	0.0	0	0	0	0	1
01/14/2022 16:00	0.0	0	0	0	0	1
01/14/2022 17:00	0.0	0	0	0	0	1
01/14/2022 18:00	0.0	0	0	0	0	1
01/14/2022 19:00	0.0	0	0	0	0	1
01/14/2022 20:00	0.0	0	0	0	0	1
01/14/2022 21:00	0.0	0	0	0	0	1
01/14/2022 22:00	0.0	0	0	0	0	1
01/14/2022 23:00	46.4	0	0	0	1	0
Average/Sum#:	7,196.5 #	0 #	0 #	2 #	1 #	17 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,335.5	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/15/2022 00:00	0.0	0	0	0	0	0
01/15/2022 01:00	0.0	0	0	0	0	0
01/15/2022 02:00	0.0	0	0	0	0	0
01/15/2022 03:00	0.0	0	0	0	0	0
01/15/2022 04:00	569.3	0	0	1	0	0
01/15/2022 05:00	6,405.3	0	0	1	0	0
01/15/2022 06:00	0.0	0	0	0	0	1
01/15/2022 07:00	0.0	0	0	0	0	1
01/15/2022 08:00	0.0	0	0	0	0	1
01/15/2022 09:00	0.0	0	0	0	0	1
01/15/2022 10:00	0.0	0	0	0	0	1
01/15/2022 11:00	0.0	0	0	0	0	1
01/15/2022 12:00	0.0	0	0	0	0	1
01/15/2022 13:00	0.0	0	0	0	0	1
01/15/2022 14:00	0.0	0	0	0	0	1
01/15/2022 15:00	0.0	0	0	0	0	1
01/15/2022 16:00	0.0	0	0	0	0	1
01/15/2022 17:00	0.0	0	0	0	0	1
01/15/2022 18:00	0.0	0	0	0	0	1
01/15/2022 19:00	0.0	0	0	0	0	1
01/15/2022 20:00	0.0	0	0	0	0	1
01/15/2022 21:00	0.0	0	0	0	0	1
01/15/2022 22:00	0.0	0	0	0	0	1
01/15/2022 23:00	26.1	0	0	0	1	0
Average/Sum#:	7,000.7 #	0 #	0 #	2 #	1 #	17 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,405.3	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/16/2022 00:00	0.0	0	0	0	0	0
01/16/2022 01:00	0.0	0	0	0	0	0
01/16/2022 02:00	0.0	0	0	0	0	0
01/16/2022 03:00	0.0	0	0	0	0	0
01/16/2022 04:00	0.0	0	0	0	0	0
01/16/2022 05:00	0.0	0	0	0	0	0
01/16/2022 06:00	0.0	0	0	0	0	0
01/16/2022 07:00	0.0	0	0	0	0	0
01/16/2022 08:00	0.0	0	0	0	0	0
01/16/2022 09:00	0.0	0	0	0	0	0
01/16/2022 10:00	0.0	0	0	0	0	0
01/16/2022 11:00	3,362.3	0	1	0	0	0
01/16/2022 12:00	6,559.6	0	1	0	0	0
01/16/2022 13:00	0.0	0	0	0	0	1
01/16/2022 14:00	0.0	0	0	0	0	1
01/16/2022 15:00	0.0	0	0	0	0	1
01/16/2022 16:00	0.0	0	0	0	0	1
01/16/2022 17:00	0.0	0	0	0	0	1
01/16/2022 18:00	0.0	0	0	0	0	1
01/16/2022 19:00	0.0	0	0	0	0	1
01/16/2022 20:00	0.0	0	0	0	0	1
01/16/2022 21:00	0.0	0	0	0	0	1
01/16/2022 22:00	0.0	0	0	0	0	1
01/16/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	9,921.9 #	0 #	2 #	0 #	0 #	11 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,559.6	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/17/2022 00:00	0.0	0	0	0	0	1
01/17/2022 01:00	0.0	0	0	0	0	1
01/17/2022 02:00	0.0	0	0	0	0	1
01/17/2022 03:00	0.0	0	0	0	0	1
01/17/2022 04:00	0.0	0	0	0	0	1
01/17/2022 05:00	0.0	0	0	0	0	1
01/17/2022 06:00	0.0	0	0	0	0	1
01/17/2022 07:00	0.0	0	0	0	0	1
01/17/2022 08:00	0.0	0	0	0	0	1
01/17/2022 09:00	0.0	0	0	0	0	1
01/17/2022 10:00	0.0	0	0	0	0	1
01/17/2022 11:00	0.0	0	0	0	0	1
01/17/2022 12:00	0.0	0	0	0	0	1
01/17/2022 13:00	0.0	0	0	0	0	1
01/17/2022 14:00	0.0	0	0	0	0	1
01/17/2022 15:00	0.0	0	0	0	0	1
01/17/2022 16:00	0.0	0	0	0	0	1
01/17/2022 17:00	0.0	0	0	0	0	1
01/17/2022 18:00	0.0	0	0	0	0	1
01/17/2022 19:00	0.0	0	0	0	0	1
01/17/2022 20:00	0.0	0	0	0	0	1
01/17/2022 21:00	0.0	0	0	0	0	1
01/17/2022 22:00	0.0	0	0	0	0	1
01/17/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/18/2022 00:00	0.0	0	0	0	0	1
01/18/2022 01:00	0.0	0	0	0	0	1
01/18/2022 02:00	0.0	0	0	0	0	1
01/18/2022 03:00	0.0	0	0	0	0	1
01/18/2022 04:00	0.0	0	0	0	0	1
01/18/2022 05:00	0.0	0	0	0	0	1
01/18/2022 06:00	0.0	0	0	0	0	1
01/18/2022 07:00	0.0	0	0	0	0	1
01/18/2022 08:00	0.0	0	0	0	0	1
01/18/2022 09:00	0.0	0	0	0	0	1
01/18/2022 10:00	0.0	0	0	0	0	1
01/18/2022 11:00	0.0	0	0	0	0	1
01/18/2022 12:00	0.0	0	0	0	0	1
01/18/2022 13:00	0.0	0	0	0	0	1
01/18/2022 14:00	0.0	0	0	0	0	1
01/18/2022 15:00	0.0	0	0	0	0	1
01/18/2022 16:00	0.0	0	0	0	0	1
01/18/2022 17:00	0.0	0	0	0	0	1
01/18/2022 18:00	0.0	0	0	0	0	1
01/18/2022 19:00	0.0	0	0	0	0	1
01/18/2022 20:00	0.0	0	0	0	0	1
01/18/2022 21:00	0.0	0	0	0	0	1
01/18/2022 22:00	0.0	0	0	0	0	1
01/18/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/19/2022 00:00	0.0	0	0	0	0	1
01/19/2022 01:00	0.0	0	0	0	0	1
01/19/2022 02:00	0.0	0	0	0	0	1
01/19/2022 03:00	0.0	0	0	0	0	1
01/19/2022 04:00	0.0	0	0	0	0	1
01/19/2022 05:00	0.0	0	0	0	0	1
01/19/2022 06:00	0.0	0	0	0	0	1
01/19/2022 07:00	0.0	0	0	0	0	1
01/19/2022 08:00	0.0	0	0	0	0	1
01/19/2022 09:00	0.0	0	0	0	0	1
01/19/2022 10:00	0.0	0	0	0	0	1
01/19/2022 11:00	0.0	0	0	0	0	1
01/19/2022 12:00	0.0	0	0	0	0	1
01/19/2022 13:00	0.0	0	0	0	0	1
01/19/2022 14:00	0.0	0	0	0	0	1
01/19/2022 15:00	0.0	0	0	0	0	1
01/19/2022 16:00	0.0	0	0	0	0	1
01/19/2022 17:00	0.0	0	0	0	0	1
01/19/2022 18:00	0.0	0	0	0	0	1
01/19/2022 19:00	0.0	0	0	0	0	1
01/19/2022 20:00	0.0	0	0	0	0	1
01/19/2022 21:00	0.0	0	0	0	0	1
01/19/2022 22:00	0.0	0	0	0	0	1
01/19/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/20/2022 00:00	0.0	0	0	0	0	1
01/20/2022 01:00	0.0	0	0	0	0	1
01/20/2022 02:00	0.0	0	0	0	0	1
01/20/2022 03:00	0.0	0	0	0	0	1
01/20/2022 04:00	0.0	0	0	0	0	1
01/20/2022 05:00	0.0	0	0	0	0	1
01/20/2022 06:00	0.0	0	0	0	0	1
01/20/2022 07:00	0.0	0	0	0	0	1
01/20/2022 08:00	0.0	0	0	0	0	1
01/20/2022 09:00	0.0	0	0	0	0	1
01/20/2022 10:00	0.0	0	0	0	0	1
01/20/2022 11:00	0.0	0	0	0	0	1
01/20/2022 12:00	0.0	0	0	0	0	1
01/20/2022 13:00	0.0	0	0	0	0	1
01/20/2022 14:00	0.0	0	0	0	0	1
01/20/2022 15:00	0.0	0	0	0	0	1
01/20/2022 16:00	0.0	0	0	0	0	1
01/20/2022 17:00	0.0	0	0	0	0	1
01/20/2022 18:00	0.0	0	0	0	0	1
01/20/2022 19:00	0.0	0	0	0	0	1
01/20/2022 20:00	0.0	0	0	0	0	1
01/20/2022 21:00	0.0	0	0	0	0	1
01/20/2022 22:00	0.0	0	0	0	0	1
01/20/2022 23:00	34.5	0	0	0	1	0
Average/Sum#:	34.5 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	34.5	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/21/2022 00:00	0.0	0	0	0	0	0
01/21/2022 01:00	0.0	0	0	0	0	0
01/21/2022 02:00	0.0	0	0	0	0	0
01/21/2022 03:00	0.0	0	0	0	0	0
01/21/2022 04:00	0.0	0	0	0	0	0
01/21/2022 05:00	0.0	0	0	0	0	0
01/21/2022 06:00	0.0	0	0	0	0	0
01/21/2022 07:00	0.0	0	0	0	0	0
01/21/2022 08:00	0.0	0	0	0	0	0
01/21/2022 09:00	0.0	0	0	0	0	0
01/21/2022 10:00	0.0	0	0	0	0	0
01/21/2022 11:00	0.0	0	0	0	0	0
01/21/2022 12:00	0.0	0	0	0	0	0
01/21/2022 13:00	0.0	0	0	0	0	0
01/21/2022 14:00	0.0	0	0	0	0	0
01/21/2022 15:00	0.0	0	0	0	0	0
01/21/2022 16:00	0.0	0	0	0	0	0
01/21/2022 17:00	0.0	0	0	0	0	0
01/21/2022 18:00	0.0	0	0	0	0	0
01/21/2022 19:00	0.0	0	0	0	0	0
01/21/2022 20:00	0.0	0	0	0	0	0
01/21/2022 21:00	0.0	0	0	0	0	0
01/21/2022 22:00	0.0	0	0	0	0	0
01/21/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/22/2022 00:00	0.0	0	0	0	0	0
01/22/2022 01:00	0.0	0	0	0	0	0
01/22/2022 02:00	0.0	0	0	0	0	0
01/22/2022 03:00	0.0	0	0	0	0	0
01/22/2022 04:00	0.0	0	0	0	0	0
01/22/2022 05:00	0.0	0	0	0	0	0
01/22/2022 06:00	0.0	0	0	0	0	0
01/22/2022 07:00	0.0	0	0	0	0	0
01/22/2022 08:00	0.0	0	0	0	0	0
01/22/2022 09:00	0.0	0	0	0	0	0
01/22/2022 10:00	0.0	0	0	0	0	0
01/22/2022 11:00	0.0	0	0	0	0	0
01/22/2022 12:00	0.0	0	0	0	0	0
01/22/2022 13:00	0.0	0	0	0	0	0
01/22/2022 14:00	0.0	0	0	0	0	0
01/22/2022 15:00	0.0	0	0	0	0	0
01/22/2022 16:00	0.0	0	0	0	0	0
01/22/2022 17:00	0.0	0	0	0	0	0
01/22/2022 18:00	0.0	0	0	0	0	0
01/22/2022 19:00	0.0	0	0	0	0	0
01/22/2022 20:00	0.0	0	0	0	0	0
01/22/2022 21:00	0.0	0	0	0	0	0
01/22/2022 22:00	0.0	0	0	0	0	0
01/22/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/23/2022 00:00	0.0	0	0	0	0	0
01/23/2022 01:00	0.0	0	0	0	0	0
01/23/2022 02:00	0.0	0	0	0	0	0
01/23/2022 03:00	0.0	0	0	0	0	0
01/23/2022 04:00	0.0	0	0	0	0	0
01/23/2022 05:00	0.0	0	0	0	0	0
01/23/2022 06:00	0.0	0	0	0	0	0
01/23/2022 07:00	0.0	0	0	0	0	0
01/23/2022 08:00	0.0	0	0	0	0	0
01/23/2022 09:00	0.0	0	0	0	0	0
01/23/2022 10:00	0.0	0	0	0	0	0
01/23/2022 11:00	2,330.2	0	1	0	0	0
01/23/2022 12:00	3,685.2	0	1	0	0	0
01/23/2022 13:00	6,898.8	0	1	0	0	0
01/23/2022 14:00	0.0	0	0	0	0	1
01/23/2022 15:00	0.0	0	0	0	0	1
01/23/2022 16:00	0.0	0	0	0	0	1
01/23/2022 17:00	0.0	0	0	0	0	1
01/23/2022 18:00	0.0	0	0	0	0	1
01/23/2022 19:00	0.0	0	0	0	0	1
01/23/2022 20:00	0.0	0	0	0	0	1
01/23/2022 21:00	0.0	0	0	0	0	1
01/23/2022 22:00	0.0	0	0	0	0	1
01/23/2022 23:00	35.9	0	0	0	1	0
Average/Sum#:	12,950.1 #	0 #	3 #	0 #	1 #	9 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,898.8	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/24/2022 00:00	0.0	0	0	0	0	0
01/24/2022 01:00	0.0	0	0	0	0	0
01/24/2022 02:00	0.0	0	0	0	0	0
01/24/2022 03:00	378.7	0	0	1	0	0
01/24/2022 04:00	6,057.6	0	0	1	0	0
01/24/2022 05:00	0.0	0	0	0	0	1
01/24/2022 06:00	0.0	0	0	0	0	1
01/24/2022 07:00	0.0	0	0	0	0	1
01/24/2022 08:00	0.0	0	0	0	0	1
01/24/2022 09:00	0.0	0	0	0	0	1
01/24/2022 10:00	0.0	0	0	0	0	1
01/24/2022 11:00	0.0	0	0	0	0	1
01/24/2022 12:00	0.0	0	0	0	0	1
01/24/2022 13:00	0.0	0	0	0	0	1
01/24/2022 14:00	0.0	0	0	0	0	1
01/24/2022 15:00	0.0	0	0	0	0	1
01/24/2022 16:00	0.0	0	0	0	0	1
01/24/2022 17:00	0.0	0	0	0	0	1
01/24/2022 18:00	0.0	0	0	0	0	1
01/24/2022 19:00	0.0	0	0	0	0	1
01/24/2022 20:00	0.0	0	0	0	0	1
01/24/2022 21:00	0.0	0	0	0	0	1
01/24/2022 22:00	0.0	0	0	0	0	1
01/24/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	6,436.3 #	0 #	0 #	2 #	0 #	19 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,057.6	0	0	1	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/25/2022 00:00	0.0	0	0	0	0	1
01/25/2022 01:00	0.0	0	0	0	0	1
01/25/2022 02:00	0.0	0	0	0	0	1
01/25/2022 03:00	0.0	0	0	0	0	1
01/25/2022 04:00	0.0	0	0	0	0	1
01/25/2022 05:00	0.0	0	0	0	0	1
01/25/2022 06:00	0.0	0	0	0	0	1
01/25/2022 07:00	0.0	0	0	0	0	1
01/25/2022 08:00	19.8	0	0	0	1	0
01/25/2022 09:00	0.0	0	0	0	0	0
01/25/2022 10:00	0.0	0	0	0	0	0
01/25/2022 11:00	0.0	0	0	0	0	0
01/25/2022 12:00	0.0	0	0	0	0	0
01/25/2022 13:00	0.0	0	0	0	0	0
01/25/2022 14:00	0.0	0	0	0	0	0
01/25/2022 15:00	1,397.5	0	0	1	0	0
01/25/2022 16:00	5,065.1	0	0	1	0	0
01/25/2022 17:00	0.0	0	0	0	0	1
01/25/2022 18:00	0.0	0	0	0	0	1
01/25/2022 19:00	0.0	0	0	0	0	1
01/25/2022 20:00	0.0	0	0	0	0	1
01/25/2022 21:00	0.0	0	0	0	0	1
01/25/2022 22:00	0.0	0	0	0	0	1
01/25/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	6,482.4 #	0 #	0 #	2 #	1 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,065.1	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/26/2022 00:00	0.0	0	0	0	0	1
01/26/2022 01:00	0.0	0	0	0	0	1
01/26/2022 02:00	0.0	0	0	0	0	1
01/26/2022 03:00	0.0	0	0	0	0	1
01/26/2022 04:00	0.0	0	0	0	0	1
01/26/2022 05:00	0.0	0	0	0	0	1
01/26/2022 06:00	0.0	0	0	0	0	1
01/26/2022 07:00	0.0	0	0	0	0	1
01/26/2022 08:00	43.2	0	0	0	1	0
01/26/2022 09:00	0.0	0	0	0	0	0
01/26/2022 10:00	0.0	0	0	0	0	0
01/26/2022 11:00	0.0	0	0	0	0	0
01/26/2022 12:00	0.0	0	0	0	0	0
01/26/2022 13:00	0.0	0	0	0	0	0
01/26/2022 14:00	0.0	0	0	0	0	0
01/26/2022 15:00	1,446.5	0	0	1	0	0
01/26/2022 16:00	4,889.2	0	0	1	0	0
01/26/2022 17:00	0.0	0	0	0	0	1
01/26/2022 18:00	0.0	0	0	0	0	1
01/26/2022 19:00	0.0	0	0	0	0	1
01/26/2022 20:00	0.0	0	0	0	0	1
01/26/2022 21:00	0.0	0	0	0	0	1
01/26/2022 22:00	0.0	0	0	0	0	1
01/26/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	6,378.9 #	0 #	0 #	2 #	1 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	4,889.2	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/27/2022 00:00	0.0	0	0	0	0	1
01/27/2022 01:00	0.0	0	0	0	0	1
01/27/2022 02:00	0.0	0	0	0	0	1
01/27/2022 03:00	0.0	0	0	0	0	1
01/27/2022 04:00	0.0	0	0	0	0	1
01/27/2022 05:00	0.0	0	0	0	0	1
01/27/2022 06:00	0.0	0	0	0	0	1
01/27/2022 07:00	0.0	0	0	0	0	1
01/27/2022 08:00	0.0	0	0	0	0	1
01/27/2022 09:00	0.0	0	0	0	0	1
01/27/2022 10:00	35.3	0	0	0	1	0
01/27/2022 11:00	0.0	0	0	0	0	0
01/27/2022 12:00	0.0	0	0	0	0	0
01/27/2022 13:00	0.0	0	0	0	0	0
01/27/2022 14:00	0.0	0	0	0	0	0
01/27/2022 15:00	1,435.8	0	0	1	0	0
01/27/2022 16:00	5,097.3	0	0	1	0	0
01/27/2022 17:00	0.0	0	0	0	0	1
01/27/2022 18:00	0.0	0	0	0	0	1
01/27/2022 19:00	0.0	0	0	0	0	1
01/27/2022 20:00	0.0	0	0	0	0	1
01/27/2022 21:00	0.0	0	0	0	0	1
01/27/2022 22:00	0.0	0	0	0	0	1
01/27/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	6,568.4 #	0 #	0 #	2 #	1 #	17 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,097.3	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/28/2022 00:00	0.0	0	0	0	0	1
01/28/2022 01:00	0.0	0	0	0	0	1
01/28/2022 02:00	0.0	0	0	0	0	1
01/28/2022 03:00	0.0	0	0	0	0	1
01/28/2022 04:00	0.0	0	0	0	0	1
01/28/2022 05:00	0.0	0	0	0	0	1
01/28/2022 06:00	0.0	0	0	0	0	1
01/28/2022 07:00	0.0	0	0	0	0	1
01/28/2022 08:00	0.0	0	0	0	0	1
01/28/2022 09:00	0.0	0	0	0	0	1
01/28/2022 10:00	0.0	0	0	0	0	1
01/28/2022 11:00	0.0	0	0	0	0	1
01/28/2022 12:00	0.0	0	0	0	0	1
01/28/2022 13:00	0.0	0	0	0	0	1
01/28/2022 14:00	0.0	0	0	0	0	1
01/28/2022 15:00	0.0	0	0	0	0	1
01/28/2022 16:00	0.0	0	0	0	0	1
01/28/2022 17:00	0.0	0	0	0	0	1
01/28/2022 18:00	0.0	0	0	0	0	1
01/28/2022 19:00	0.0	0	0	0	0	1
01/28/2022 20:00	0.0	0	0	0	0	1
01/28/2022 21:00	0.0	0	0	0	0	1
01/28/2022 22:00	0.0	0	0	0	0	1
01/28/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/29/2022 00:00	0.0	0	0	0	0	1
01/29/2022 01:00	0.0	0	0	0	0	1
01/29/2022 02:00	0.0	0	0	0	0	1
01/29/2022 03:00	0.0	0	0	0	0	1
01/29/2022 04:00	0.0	0	0	0	0	1
01/29/2022 05:00	0.0	0	0	0	0	1
01/29/2022 06:00	0.0	0	0	0	0	1
01/29/2022 07:00	0.0	0	0	0	0	1
01/29/2022 08:00	0.0	0	0	0	0	1
01/29/2022 09:00	0.0	0	0	0	0	1
01/29/2022 10:00	0.0	0	0	0	0	1
01/29/2022 11:00	0.0	0	0	0	0	1
01/29/2022 12:00	0.0	0	0	0	0	1
01/29/2022 13:00	0.0	0	0	0	0	1
01/29/2022 14:00	0.0	0	0	0	0	1
01/29/2022 15:00	0.0	0	0	0	0	1
01/29/2022 16:00	0.0	0	0	0	0	1
01/29/2022 17:00	0.0	0	0	0	0	1
01/29/2022 18:00	0.0	0	0	0	0	1
01/29/2022 19:00	0.0	0	0	0	0	1
01/29/2022 20:00	0.0	0	0	0	0	1
01/29/2022 21:00	0.0	0	0	0	0	1
01/29/2022 22:00	0.0	0	0	0	0	1
01/29/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/30/2022 00:00	0.0	0	0	0	0	1
01/30/2022 01:00	0.0	0	0	0	0	1
01/30/2022 02:00	0.0	0	0	0	0	1
01/30/2022 03:00	0.0	0	0	0	0	1
01/30/2022 04:00	0.0	0	0	0	0	1
01/30/2022 05:00	0.0	0	0	0	0	1
01/30/2022 06:00	0.0	0	0	0	0	1
01/30/2022 07:00	28.8	0	0	0	1	0
01/30/2022 08:00	0.0	0	0	0	0	0
01/30/2022 09:00	0.0	0	0	0	0	0
01/30/2022 10:00	0.0	0	0	0	0	0
01/30/2022 11:00	0.0	0	0	0	0	0
01/30/2022 12:00	0.0	0	0	0	0	0
01/30/2022 13:00	0.0	0	0	0	0	0
01/30/2022 14:00	0.0	0	0	0	0	0
01/30/2022 15:00	0.0	0	0	0	0	0
01/30/2022 16:00	0.0	0	0	0	0	0
01/30/2022 17:00	0.0	0	0	0	0	0
01/30/2022 18:00	0.0	0	0	0	0	0
01/30/2022 19:00	0.0	0	0	0	0	0
01/30/2022 20:00	0.0	0	0	0	0	0
01/30/2022 21:00	0.0	0	0	0	0	0
01/30/2022 22:00	0.0	0	0	0	0	0
01/30/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	28.8 #	0 #	0 #	0 #	1 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	28.8	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/31/2022 00:00	0.0	0	0	0	0	0
01/31/2022 01:00	0.0	0	0	0	0	0
01/31/2022 02:00	2,360.0	0	1	0	0	0
01/31/2022 03:00	6,001.9	0	1	0	0	0
01/31/2022 04:00	0.0	0	0	0	0	1
01/31/2022 05:00	0.0	0	0	0	0	1
01/31/2022 06:00	0.0	0	0	0	0	1
01/31/2022 07:00	0.0	0	0	0	0	1
01/31/2022 08:00	0.0	0	0	0	0	1
01/31/2022 09:00	0.0	0	0	0	0	1
01/31/2022 10:00	0.0	0	0	0	0	1
01/31/2022 11:00	0.0	0	0	0	0	1
01/31/2022 12:00	0.0	0	0	0	0	1
01/31/2022 13:00	0.0	0	0	0	0	1
01/31/2022 14:00	0.0	0	0	0	0	1
01/31/2022 15:00	0.0	0	0	0	0	1
01/31/2022 16:00	0.0	0	0	0	0	1
01/31/2022 17:00	0.0	0	0	0	0	1
01/31/2022 18:00	0.0	0	0	0	0	1
01/31/2022 19:00	0.0	0	0	0	0	1
01/31/2022 20:00	0.0	0	0	0	0	1
01/31/2022 21:00	0.0	0	0	0	0	1
01/31/2022 22:00	0.0	0	0	0	0	1
01/31/2022 23:00	46.0	0	0	0	1	0
Average/Sum#:	8,407.9 #	0 #	2 #	0 #	1 #	19 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,001.9	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/01/2022 00:00	0.0	0	0	0	0	0
02/01/2022 01:00	0.0	0	0	0	0	0
02/01/2022 02:00	0.0	0	0	0	0	0
02/01/2022 03:00	0.0	0	0	0	0	0
02/01/2022 04:00	0.0	0	0	0	0	0
02/01/2022 05:00	3,950.7	0	0	1	0	0
02/01/2022 06:00	4,253.3	0	0	1	0	0
02/01/2022 07:00	0.0	0	0	0	0	1
02/01/2022 08:00	0.0	0	0	0	0	1
02/01/2022 09:00	0.0	0	0	0	0	1
02/01/2022 10:00	0.0	0	0	0	0	1
02/01/2022 11:00	0.0	0	0	0	0	1
02/01/2022 12:00	0.0	0	0	0	0	1
02/01/2022 13:00	0.0	0	0	0	0	1
02/01/2022 14:00	0.0	0	0	0	0	1
02/01/2022 15:00	0.0	0	0	0	0	1
02/01/2022 16:00	0.0	0	0	0	0	1
02/01/2022 17:00	0.0	0	0	0	0	1
02/01/2022 18:00	0.0	0	0	0	0	1
02/01/2022 19:00	0.0	0	0	0	0	1
02/01/2022 20:00	0.0	0	0	0	0	1
02/01/2022 21:00	0.0	0	0	0	0	1
02/01/2022 22:00	0.0	0	0	0	0	1
02/01/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	8,204.0 #	0 #	0 #	2 #	0 #	17 #
Minimum:	0.0	0	0	0	0	0
Maximum:	4,253.3	0	0	1	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/02/2022 00:00	0.0	0	0	0	0	1
02/02/2022 01:00	0.0	0	0	0	0	1
02/02/2022 02:00	0.0	0	0	0	0	1
02/02/2022 03:00	0.0	0	0	0	0	1
02/02/2022 04:00	0.0	0	0	0	0	1
02/02/2022 05:00	0.0	0	0	0	0	1
02/02/2022 06:00	0.0	0	0	0	0	1
02/02/2022 07:00	0.0	0	0	0	0	1
02/02/2022 08:00	0.0	0	0	0	0	1
02/02/2022 09:00	0.0	0	0	0	0	1
02/02/2022 10:00	50.7	0	0	0	1	0
02/02/2022 11:00	0.0	0	0	0	0	0
02/02/2022 12:00	0.0	0	0	0	0	0
02/02/2022 13:00	0.0	0	0	0	0	0
02/02/2022 14:00	0.0	0	0	0	0	0
02/02/2022 15:00	478.6	0	0	1	0	0
02/02/2022 16:00	6,798.6	0	0	1	0	0
02/02/2022 17:00	867.6	0	0	1	0	0
02/02/2022 18:00	0.0	0	0	0	0	1
02/02/2022 19:00	0.0	0	0	0	0	1
02/02/2022 20:00	0.0	0	0	0	0	1
02/02/2022 21:00	0.0	0	0	0	0	1
02/02/2022 22:00	0.0	0	0	0	0	1
02/02/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	8,195.5 #	0 #	0 #	3 #	1 #	16 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,798.6	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/03/2022 00:00	0.0	0	0	0	0	1
02/03/2022 01:00	0.0	0	0	0	0	1
02/03/2022 02:00	0.0	0	0	0	0	1
02/03/2022 03:00	0.0	0	0	0	0	1
02/03/2022 04:00	0.0	0	0	0	0	1
02/03/2022 05:00	0.0	0	0	0	0	1
02/03/2022 06:00	0.0	0	0	0	0	1
02/03/2022 07:00	0.0	0	0	0	0	1
02/03/2022 08:00	0.0	0	0	0	0	1
02/03/2022 09:00	0.0	0	0	0	0	1
02/03/2022 10:00	0.0	0	0	0	0	1
02/03/2022 11:00	0.0	0	0	0	0	1
02/03/2022 12:00	0.0	0	0	0	0	1
02/03/2022 13:00	0.0	0	0	0	0	1
02/03/2022 14:00	0.0	0	0	0	0	1
02/03/2022 15:00	0.0	0	0	0	0	1
02/03/2022 16:00	0.0	0	0	0	0	1
02/03/2022 17:00	0.0	0	0	0	0	1
02/03/2022 18:00	0.0	0	0	0	0	1
02/03/2022 19:00	0.0	0	0	0	0	1
02/03/2022 20:00	0.0	0	0	0	0	1
02/03/2022 21:00	0.0	0	0	0	0	1
02/03/2022 22:00	0.0	0	0	0	0	1
02/03/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/04/2022 00:00	0.0	0	0	0	0	1
02/04/2022 01:00	0.0	0	0	0	0	1
02/04/2022 02:00	0.0	0	0	0	0	1
02/04/2022 03:00	0.0	0	0	0	0	1
02/04/2022 04:00	0.0	0	0	0	0	1
02/04/2022 05:00	0.0	0	0	0	0	1
02/04/2022 06:00	0.0	0	0	0	0	1
02/04/2022 07:00	0.0	0	0	0	0	1
02/04/2022 08:00	32.2	0	0	0	1	0
02/04/2022 09:00	0.0	0	0	0	0	0
02/04/2022 10:00	0.0	0	0	0	0	0
02/04/2022 11:00	0.0	0	0	0	0	0
02/04/2022 12:00	0.0	0	0	0	0	0
02/04/2022 13:00	0.0	0	0	0	0	0
02/04/2022 14:00	0.0	0	0	0	0	0
02/04/2022 15:00	0.0	0	0	0	0	0
02/04/2022 16:00	5,922.5	0	0	1	0	0
02/04/2022 17:00	2,242.9	0	0	1	0	0
02/04/2022 18:00	0.0	0	0	0	0	1
02/04/2022 19:00	0.0	0	0	0	0	1
02/04/2022 20:00	0.0	0	0	0	0	1
02/04/2022 21:00	0.0	0	0	0	0	1
02/04/2022 22:00	0.0	0	0	0	0	1
02/04/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	8,197.6 #	0 #	0 #	2 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,922.5	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/05/2022 00:00	0.0	0	0	0	0	1
02/05/2022 01:00	0.0	0	0	0	0	1
02/05/2022 02:00	0.0	0	0	0	0	1
02/05/2022 03:00	0.0	0	0	0	0	1
02/05/2022 04:00	0.0	0	0	0	0	1
02/05/2022 05:00	0.0	0	0	0	0	1
02/05/2022 06:00	0.0	0	0	0	0	1
02/05/2022 07:00	0.0	0	0	0	0	1
02/05/2022 08:00	55.6	0	0	0	1	0
02/05/2022 09:00	0.0	0	0	0	0	0
02/05/2022 10:00	0.0	0	0	0	0	0
02/05/2022 11:00	0.0	0	0	0	0	0
02/05/2022 12:00	0.0	0	0	0	0	0
02/05/2022 13:00	1,086.1	0	0	1	0	0
02/05/2022 14:00	6,019.0	0	0	1	0	0
02/05/2022 15:00	0.0	0	0	0	0	1
02/05/2022 16:00	0.0	0	0	0	0	1
02/05/2022 17:00	0.0	0	0	0	0	1
02/05/2022 18:00	0.0	0	0	0	0	1
02/05/2022 19:00	0.0	0	0	0	0	1
02/05/2022 20:00	0.0	0	0	0	0	1
02/05/2022 21:00	0.0	0	0	0	0	1
02/05/2022 22:00	0.0	0	0	0	0	1
02/05/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	7,160.7 #	0 #	0 #	2 #	1 #	17 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,019.0	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/06/2022 00:00	0.0	0	0	0	0	1
02/06/2022 01:00	0.0	0	0	0	0	1
02/06/2022 02:00	0.0	0	0	0	0	1
02/06/2022 03:00	0.0	0	0	0	0	1
02/06/2022 04:00	0.0	0	0	0	0	1
02/06/2022 05:00	0.0	0	0	0	0	1
02/06/2022 06:00	0.0	0	0	0	0	1
02/06/2022 07:00	0.0	0	0	0	0	1
02/06/2022 08:00	26.4	0	0	0	1	0
02/06/2022 09:00	0.0	0	0	0	0	0
02/06/2022 10:00	0.0	0	0	0	0	0
02/06/2022 11:00	0.0	0	0	0	0	0
02/06/2022 12:00	0.0	0	0	0	0	0
02/06/2022 13:00	0.0	0	0	0	0	0
02/06/2022 14:00	1,360.6	0	0	1	0	0
02/06/2022 15:00	5,906.4	0	0	1	0	0
02/06/2022 16:00	0.0	0	0	0	0	1
02/06/2022 17:00	0.0	0	0	0	0	1
02/06/2022 18:00	0.0	0	0	0	0	1
02/06/2022 19:00	0.0	0	0	0	0	1
02/06/2022 20:00	0.0	0	0	0	0	1
02/06/2022 21:00	0.0	0	0	0	0	1
02/06/2022 22:00	0.0	0	0	0	0	1
02/06/2022 23:00	57.9	0	0	0	1	0
Average/Sum#:	7,351.3 #	0 #	0 #	2 #	2 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,906.4	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/07/2022 00:00	0.0	0	0	0	0	0
02/07/2022 01:00	0.0	0	0	0	0	0
02/07/2022 02:00	0.0	0	0	0	0	0
02/07/2022 03:00	0.0	0	0	0	0	0
02/07/2022 04:00	0.0	0	0	0	0	0
02/07/2022 05:00	0.0	0	0	0	0	0
02/07/2022 06:00	0.0	0	0	0	0	0
02/07/2022 07:00	0.0	0	0	0	0	0
02/07/2022 08:00	0.0	0	0	0	0	0
02/07/2022 09:00	0.0	0	0	0	0	0
02/07/2022 10:00	0.0	0	0	0	0	0
02/07/2022 11:00	1,962.4	0	1	0	0	0
02/07/2022 12:00	3,196.6	0	1	0	0	0
02/07/2022 13:00	5,853.5	0	1	0	0	0
02/07/2022 14:00	0.0	0	0	0	0	1
02/07/2022 15:00	0.0	0	0	0	0	1
02/07/2022 16:00	0.0	0	0	0	0	1
02/07/2022 17:00	0.0	0	0	0	0	1
02/07/2022 18:00	0.0	0	0	0	0	1
02/07/2022 19:00	0.0	0	0	0	0	1
02/07/2022 20:00	0.0	0	0	0	0	1
02/07/2022 21:00	0.0	0	0	0	0	1
02/07/2022 22:00	0.0	0	0	0	0	1
02/07/2022 23:00	42.2	0	0	0	1	0
Average/Sum#:	11,054.7 #	0 #	3 #	0 #	1 #	9 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,853.5	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/08/2022 00:00	0.0	0	0	0	0	0
02/08/2022 01:00	0.0	0	0	0	0	0
02/08/2022 02:00	0.0	0	0	0	0	0
02/08/2022 03:00	2,394.2	0	0	1	0	0
02/08/2022 04:00	3,669.9	0	0	1	0	0
02/08/2022 05:00	0.0	0	0	0	0	1
02/08/2022 06:00	0.0	0	0	0	0	1
02/08/2022 07:00	0.0	0	0	0	0	1
02/08/2022 08:00	0.0	0	0	0	0	1
02/08/2022 09:00	0.0	0	0	0	0	1
02/08/2022 10:00	0.0	0	0	0	0	1
02/08/2022 11:00	0.0	0	0	0	0	1
02/08/2022 12:00	0.0	0	0	0	0	1
02/08/2022 13:00	0.0	0	0	0	0	1
02/08/2022 14:00	0.0	0	0	0	0	1
02/08/2022 15:00	0.0	0	0	0	0	1
02/08/2022 16:00	0.0	0	0	0	0	1
02/08/2022 17:00	0.0	0	0	0	0	1
02/08/2022 18:00	0.0	0	0	0	0	1
02/08/2022 19:00	0.0	0	0	0	0	1
02/08/2022 20:00	0.0	0	0	0	0	1
02/08/2022 21:00	0.0	0	0	0	0	1
02/08/2022 22:00	0.0	0	0	0	0	1
02/08/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	6,064.1 #	0 #	0 #	2 #	0 #	19 #
Minimum:	0.0	0	0	0	0	0
Maximum:	3,669.9	0	0	1	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/09/2022 00:00	0.0	0	0	0	0	1
02/09/2022 01:00	0.0	0	0	0	0	1
02/09/2022 02:00	0.0	0	0	0	0	1
02/09/2022 03:00	0.0	0	0	0	0	1
02/09/2022 04:00	0.0	0	0	0	0	1
02/09/2022 05:00	0.0	0	0	0	0	1
02/09/2022 06:00	0.0	0	0	0	0	1
02/09/2022 07:00	0.0	0	0	0	0	1
02/09/2022 08:00	0.0	0	0	0	0	1
02/09/2022 09:00	0.0	0	0	0	0	1
02/09/2022 10:00	0.0	0	0	0	0	1
02/09/2022 11:00	0.0	0	0	0	0	1
02/09/2022 12:00	0.0	0	0	0	0	1
02/09/2022 13:00	0.0	0	0	0	0	1
02/09/2022 14:00	0.0	0	0	0	0	1
02/09/2022 15:00	0.0	0	0	0	0	1
02/09/2022 16:00	0.0	0	0	0	0	1
02/09/2022 17:00	0.0	0	0	0	0	1
02/09/2022 18:00	0.0	0	0	0	0	1
02/09/2022 19:00	0.0	0	0	0	0	1
02/09/2022 20:00	0.0	0	0	0	0	1
02/09/2022 21:00	0.0	0	0	0	0	1
02/09/2022 22:00	0.0	0	0	0	0	1
02/09/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/10/2022 00:00	0.0	0	0	0	0	1
02/10/2022 01:00	0.0	0	0	0	0	1
02/10/2022 02:00	0.0	0	0	0	0	1
02/10/2022 03:00	0.0	0	0	0	0	1
02/10/2022 04:00	0.0	0	0	0	0	1
02/10/2022 05:00	0.0	0	0	0	0	1
02/10/2022 06:00	0.0	0	0	0	0	1
02/10/2022 07:00	0.0	0	0	0	0	1
02/10/2022 08:00	60.4	0	0	0	1	0
02/10/2022 09:00	0.0	0	0	0	0	0
02/10/2022 10:00	0.0	0	0	0	0	0
02/10/2022 11:00	231.4	0	0	1	0	0
02/10/2022 12:00	6,589.9	0	0	1	0	0
02/10/2022 13:00	0.0	0	0	0	0	1
02/10/2022 14:00	0.0	0	0	0	0	1
02/10/2022 15:00	0.0	0	0	0	0	1
02/10/2022 16:00	0.0	0	0	0	0	1
02/10/2022 17:00	0.0	0	0	0	0	1
02/10/2022 18:00	0.0	0	0	0	0	1
02/10/2022 19:00	0.0	0	0	0	0	1
02/10/2022 20:00	0.0	0	0	0	0	1
02/10/2022 21:00	0.0	0	0	0	0	1
02/10/2022 22:00	0.0	0	0	0	0	1
02/10/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	6,881.7 #	0 #	0 #	2 #	1 #	19 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,589.9	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/11/2022 00:00	0.0	0	0	0	0	1
02/11/2022 01:00	57.5	0	0	0	1	0
02/11/2022 02:00	0.0	0	0	0	0	0
02/11/2022 03:00	0.0	0	0	0	0	0
02/11/2022 04:00	0.0	0	0	0	0	0
02/11/2022 05:00	0.0	0	0	0	0	0
02/11/2022 06:00	0.0	0	0	0	0	0
02/11/2022 07:00	0.0	0	0	0	0	0
02/11/2022 08:00	0.0	0	0	0	0	0
02/11/2022 09:00	0.0	0	0	0	0	0
02/11/2022 10:00	0.0	0	0	0	0	0
02/11/2022 11:00	0.0	0	0	0	0	0
02/11/2022 12:00	0.0	0	0	0	0	0
02/11/2022 13:00	0.0	0	0	0	0	0
02/11/2022 14:00	0.0	0	0	0	0	0
02/11/2022 15:00	0.0	0	0	0	0	0
02/11/2022 16:00	0.0	0	0	0	0	0
02/11/2022 17:00	0.0	0	0	0	0	0
02/11/2022 18:00	0.0	0	0	0	0	0
02/11/2022 19:00	0.0	0	0	0	0	0
02/11/2022 20:00	0.0	0	0	0	0	0
02/11/2022 21:00	0.0	0	0	0	0	0
02/11/2022 22:00	0.0	0	0	0	0	0
02/11/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	57.5 #	0 #	0 #	0 #	1 #	1 #
Minimum:	0.0	0	0	0	0	0
Maximum:	57.5	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/12/2022 00:00	0.0	0	0	0	0	0
02/12/2022 01:00	0.0	0	0	0	0	0
02/12/2022 02:00	0.0	0	0	0	0	0
02/12/2022 03:00	0.0	0	0	0	0	0
02/12/2022 04:00	0.0	0	0	0	0	0
02/12/2022 05:00	0.0	0	0	0	0	0
02/12/2022 06:00	0.0	0	0	0	0	0
02/12/2022 07:00	0.0	0	0	0	0	0
02/12/2022 08:00	0.0	0	0	0	0	0
02/12/2022 09:00	0.0	0	0	0	0	0
02/12/2022 10:00	0.0	0	0	0	0	0
02/12/2022 11:00	0.0	0	0	0	0	0
02/12/2022 12:00	0.0	0	0	0	0	0
02/12/2022 13:00	0.0	0	0	0	0	0
02/12/2022 14:00	0.0	0	0	0	0	0
02/12/2022 15:00	0.0	0	0	0	0	0
02/12/2022 16:00	0.0	0	0	0	0	0
02/12/2022 17:00	0.0	0	0	0	0	0
02/12/2022 18:00	0.0	0	0	0	0	0
02/12/2022 19:00	0.0	0	0	0	0	0
02/12/2022 20:00	0.0	0	0	0	0	0
02/12/2022 21:00	0.0	0	0	0	0	0
02/12/2022 22:00	0.0	0	0	0	0	0
02/12/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/13/2022 00:00	0.0	0	0	0	0	0
02/13/2022 01:00	0.0	0	0	0	0	0
02/13/2022 02:00	0.0	0	0	0	0	0
02/13/2022 03:00	0.0	0	0	0	0	0
02/13/2022 04:00	0.0	0	0	0	0	0
02/13/2022 05:00	0.0	0	0	0	0	0
02/13/2022 06:00	0.0	0	0	0	0	0
02/13/2022 07:00	0.0	0	0	0	0	0
02/13/2022 08:00	0.0	0	0	0	0	0
02/13/2022 09:00	0.0	0	0	0	0	0
02/13/2022 10:00	0.0	0	0	0	0	0
02/13/2022 11:00	0.0	0	0	0	0	0
02/13/2022 12:00	0.0	0	0	0	0	0
02/13/2022 13:00	0.0	0	0	0	0	0
02/13/2022 14:00	0.0	0	0	0	0	0
02/13/2022 15:00	0.0	0	0	0	0	0
02/13/2022 16:00	0.0	0	0	0	0	0
02/13/2022 17:00	0.0	0	0	0	0	0
02/13/2022 18:00	0.0	0	0	0	0	0
02/13/2022 19:00	0.0	0	0	0	0	0
02/13/2022 20:00	0.0	0	0	0	0	0
02/13/2022 21:00	0.0	0	0	0	0	0
02/13/2022 22:00	0.0	0	0	0	0	0
02/13/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/14/2022 00:00	0.0	0	0	0	0	0
02/14/2022 01:00	0.0	0	0	0	0	0
02/14/2022 02:00	0.0	0	0	0	0	0
02/14/2022 03:00	0.0	0	0	0	0	0
02/14/2022 04:00	0.0	0	0	0	0	0
02/14/2022 05:00	0.0	0	0	0	0	0
02/14/2022 06:00	0.0	0	0	0	0	0
02/14/2022 07:00	0.0	0	0	0	0	0
02/14/2022 08:00	0.0	0	0	0	0	0
02/14/2022 09:00	0.0	0	0	0	0	0
02/14/2022 10:00	0.0	0	0	0	0	0
02/14/2022 11:00	0.0	0	0	0	0	0
02/14/2022 12:00	0.0	0	0	0	0	0
02/14/2022 13:00	0.0	0	0	0	0	0
02/14/2022 14:00	0.0	0	0	0	0	0
02/14/2022 15:00	0.0	0	0	0	0	0
02/14/2022 16:00	0.0	0	0	0	0	0
02/14/2022 17:00	0.0	0	0	0	0	0
02/14/2022 18:00	0.0	0	0	0	0	0
02/14/2022 19:00	0.0	0	0	0	0	0
02/14/2022 20:00	0.0	0	0	0	0	0
02/14/2022 21:00	0.0	0	0	0	0	0
02/14/2022 22:00	0.0	0	0	0	0	0
02/14/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/15/2022 00:00	0.0	0	0	0	0	0
02/15/2022 01:00	0.0	0	0	0	0	0
02/15/2022 02:00	0.0	0	0	0	0	0
02/15/2022 03:00	0.0	0	0	0	0	0
02/15/2022 04:00	0.0	0	0	0	0	0
02/15/2022 05:00	0.0	0	0	0	0	0
02/15/2022 06:00	0.0	0	0	0	0	0
02/15/2022 07:00	0.0	0	0	0	0	0
02/15/2022 08:00	0.0	0	0	0	0	0
02/15/2022 09:00	0.0	0	0	0	0	0
02/15/2022 10:00	0.0	0	0	0	0	0
02/15/2022 11:00	0.0	0	0	0	0	0
02/15/2022 12:00	0.0	0	0	0	0	0
02/15/2022 13:00	0.0	0	0	0	0	0
02/15/2022 14:00	0.0	0	0	0	0	0
02/15/2022 15:00	0.0	0	0	0	0	0
02/15/2022 16:00	0.0	0	0	0	0	0
02/15/2022 17:00	0.0	0	0	0	0	0
02/15/2022 18:00	0.0	0	0	0	0	0
02/15/2022 19:00	0.0	0	0	0	0	0
02/15/2022 20:00	0.0	0	0	0	0	0
02/15/2022 21:00	0.0	0	0	0	0	0
02/15/2022 22:00	0.0	0	0	0	0	0
02/15/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/16/2022 00:00	0.0	0	0	0	0	0
02/16/2022 01:00	0.0	0	0	0	0	0
02/16/2022 02:00	0.0	0	0	0	0	0
02/16/2022 03:00	0.0	0	0	0	0	0
02/16/2022 04:00	0.0	0	0	0	0	0
02/16/2022 05:00	0.0	0	0	0	0	0
02/16/2022 06:00	0.0	0	0	0	0	0
02/16/2022 07:00	0.0	0	0	0	0	0
02/16/2022 08:00	0.0	0	0	0	0	0
02/16/2022 09:00	0.0	0	0	0	0	0
02/16/2022 10:00	0.0	0	0	0	0	0
02/16/2022 11:00	0.0	0	0	0	0	0
02/16/2022 12:00	0.0	0	0	0	0	0
02/16/2022 13:00	0.0	0	0	0	0	0
02/16/2022 14:00	0.0	0	0	0	0	0
02/16/2022 15:00	0.0	0	0	0	0	0
02/16/2022 16:00	0.0	0	0	0	0	0
02/16/2022 17:00	0.0	0	0	0	0	0
02/16/2022 18:00	0.0	0	0	0	0	0
02/16/2022 19:00	0.0	0	0	0	0	0
02/16/2022 20:00	0.0	0	0	0	0	0
02/16/2022 21:00	0.0	0	0	0	0	0
02/16/2022 22:00	0.0	0	0	0	0	0
02/16/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/17/2022 00:00	0.0	0	0	0	0	0
02/17/2022 01:00	0.0	0	0	0	0	0
02/17/2022 02:00	0.0	0	0	0	0	0
02/17/2022 03:00	0.0	0	0	0	0	0
02/17/2022 04:00	0.0	0	0	0	0	0
02/17/2022 05:00	0.0	0	0	0	0	0
02/17/2022 06:00	0.0	0	0	0	0	0
02/17/2022 07:00	0.0	0	0	0	0	0
02/17/2022 08:00	0.0	0	0	0	0	0
02/17/2022 09:00	0.0	0	0	0	0	0
02/17/2022 10:00	0.0	0	0	0	0	0
02/17/2022 11:00	0.0	0	0	0	0	0
02/17/2022 12:00	0.0	0	0	0	0	0
02/17/2022 13:00	0.0	0	0	0	0	0
02/17/2022 14:00	0.0	0	0	0	0	0
02/17/2022 15:00	0.0	0	0	0	0	0
02/17/2022 16:00	0.0	0	0	0	0	0
02/17/2022 17:00	0.0	0	0	0	0	0
02/17/2022 18:00	0.0	0	0	0	0	0
02/17/2022 19:00	0.0	0	0	0	0	0
02/17/2022 20:00	0.0	0	0	0	0	0
02/17/2022 21:00	0.0	0	0	0	0	0
02/17/2022 22:00	0.0	0	0	0	0	0
02/17/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/18/2022 00:00	0.0	0	0	0	0	0
02/18/2022 01:00	0.0	0	0	0	0	0
02/18/2022 02:00	0.0	0	0	0	0	0
02/18/2022 03:00	0.0	0	0	0	0	0
02/18/2022 04:00	0.0	0	0	0	0	0
02/18/2022 05:00	0.0	0	0	0	0	0
02/18/2022 06:00	0.0	0	0	0	0	0
02/18/2022 07:00	0.0	0	0	0	0	0
02/18/2022 08:00	185.4	1	0	0	0	0
02/18/2022 09:00	3,611.7	1	0	0	0	0
02/18/2022 10:00	3,741.7	1	0	0	0	0
02/18/2022 11:00	6,508.4	1	0	0	0	0
02/18/2022 12:00	6,024.6	1	0	0	0	0
02/18/2022 13:00	0.0	0	0	0	0	1
02/18/2022 14:00	0.0	0	0	0	0	1
02/18/2022 15:00	0.0	0	0	0	0	1
02/18/2022 16:00	0.0	0	0	0	0	1
02/18/2022 17:00	0.0	0	0	0	0	1
02/18/2022 18:00	0.0	0	0	0	0	1
02/18/2022 19:00	0.0	0	0	0	0	1
02/18/2022 20:00	0.0	0	0	0	0	1
02/18/2022 21:00	0.0	0	0	0	0	1
02/18/2022 22:00	0.0	0	0	0	0	1
02/18/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	20,071.8 #	5 #	0 #	0 #	0 #	11 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,508.4	1	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/19/2022 00:00	14.7	0	0	0	1	0
02/19/2022 01:00	0.0	0	0	0	0	0
02/19/2022 02:00	0.0	0	0	0	0	0
02/19/2022 03:00	0.0	0	0	0	0	0
02/19/2022 04:00	0.0	0	0	0	0	0
02/19/2022 05:00	0.0	0	0	0	0	0
02/19/2022 06:00	0.0	0	0	0	0	0
02/19/2022 07:00	0.0	0	0	0	0	0
02/19/2022 08:00	0.0	0	0	0	0	0
02/19/2022 09:00	0.0	0	0	0	0	0
02/19/2022 10:00	0.0	0	0	0	0	0
02/19/2022 11:00	0.0	0	0	0	0	0
02/19/2022 12:00	0.0	0	0	0	0	0
02/19/2022 13:00	0.0	0	0	0	0	0
02/19/2022 14:00	0.0	0	0	0	0	0
02/19/2022 15:00	0.0	0	0	0	0	0
02/19/2022 16:00	0.0	0	0	0	0	0
02/19/2022 17:00	0.0	0	0	0	0	0
02/19/2022 18:00	0.0	0	0	0	0	0
02/19/2022 19:00	0.0	0	0	0	0	0
02/19/2022 20:00	0.0	0	0	0	0	0
02/19/2022 21:00	0.0	0	0	0	0	0
02/19/2022 22:00	0.0	0	0	0	0	0
02/19/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	14.7 #	0 #	0 #	0 #	1 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	14.7	0	0	0	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/20/2022 00:00	0.0	0	0	0	0	0
02/20/2022 01:00	0.0	0	0	0	0	0
02/20/2022 02:00	0.0	0	0	0	0	0
02/20/2022 03:00	0.0	0	0	0	0	0
02/20/2022 04:00	0.0	0	0	0	0	0
02/20/2022 05:00	0.0	0	0	0	0	0
02/20/2022 06:00	0.0	0	0	0	0	0
02/20/2022 07:00	0.0	0	0	0	0	0
02/20/2022 08:00	0.0	0	0	0	0	0
02/20/2022 09:00	0.0	0	0	0	0	0
02/20/2022 10:00	0.0	0	0	0	0	0
02/20/2022 11:00	0.0	0	0	0	0	0
02/20/2022 12:00	0.0	0	0	0	0	0
02/20/2022 13:00	0.0	0	0	0	0	0
02/20/2022 14:00	0.0	0	0	0	0	0
02/20/2022 15:00	0.0	0	0	0	0	0
02/20/2022 16:00	0.0	0	0	0	0	0
02/20/2022 17:00	0.0	0	0	0	0	0
02/20/2022 18:00	0.0	0	0	0	0	0
02/20/2022 19:00	0.0	0	0	0	0	0
02/20/2022 20:00	0.0	0	0	0	0	0
02/20/2022 21:00	0.0	0	0	0	0	0
02/20/2022 22:00	0.0	0	0	0	0	0
02/20/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/21/2022 00:00	0.0	0	0	0	0	0
02/21/2022 01:00	0.0	0	0	0	0	0
02/21/2022 02:00	0.0	0	0	0	0	0
02/21/2022 03:00	0.0	0	0	0	0	0
02/21/2022 04:00	0.0	0	0	0	0	0
02/21/2022 05:00	0.0	0	0	0	0	0
02/21/2022 06:00	0.0	0	0	0	0	0
02/21/2022 07:00	0.0	0	0	0	0	0
02/21/2022 08:00	0.0	0	0	0	0	0
02/21/2022 09:00	0.0	0	0	0	0	0
02/21/2022 10:00	0.0	0	0	0	0	0
02/21/2022 11:00	0.0	0	0	0	0	0
02/21/2022 12:00	0.0	0	0	0	0	0
02/21/2022 13:00	0.0	0	0	0	0	0
02/21/2022 14:00	0.0	0	0	0	0	0
02/21/2022 15:00	0.0	0	0	0	0	0
02/21/2022 16:00	0.0	0	0	0	0	0
02/21/2022 17:00	0.0	0	0	0	0	0
02/21/2022 18:00	0.0	0	0	0	0	0
02/21/2022 19:00	0.0	0	0	0	0	0
02/21/2022 20:00	0.0	0	0	0	0	0
02/21/2022 21:00	0.0	0	0	0	0	0
02/21/2022 22:00	0.0	0	0	0	0	0
02/21/2022 23:00	2,162.0	0	1	0	0	0
Average/Sum#:	2,162.0 #	0 #	1 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	2,162.0	0	1	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/22/2022 00:00	3,627.9	0	1	0	0	0
02/22/2022 01:00	6,468.1	0	1	0	0	0
02/22/2022 02:00	0.0	0	0	0	0	1
02/22/2022 03:00	0.0	0	0	0	0	1
02/22/2022 04:00	0.0	0	0	0	0	1
02/22/2022 05:00	0.0	0	0	0	0	1
02/22/2022 06:00	0.0	0	0	0	0	1
02/22/2022 07:00	0.0	0	0	0	0	1
02/22/2022 08:00	0.0	0	0	0	0	1
02/22/2022 09:00	0.0	0	0	0	0	1
02/22/2022 10:00	0.0	0	0	0	0	1
02/22/2022 11:00	0.0	0	0	0	0	1
02/22/2022 12:00	0.0	0	0	0	0	1
02/22/2022 13:00	0.0	0	0	0	0	1
02/22/2022 14:00	0.0	0	0	0	0	1
02/22/2022 15:00	0.0	0	0	0	0	1
02/22/2022 16:00	0.0	0	0	0	0	1
02/22/2022 17:00	0.0	0	0	0	0	1
02/22/2022 18:00	0.0	0	0	0	0	1
02/22/2022 19:00	0.0	0	0	0	0	1
02/22/2022 20:00	0.0	0	0	0	0	1
02/22/2022 21:00	0.0	0	0	0	0	1
02/22/2022 22:00	0.0	0	0	0	0	1
02/22/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	10,096.0 #	0 #	2 #	0 #	0 #	22 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,468.1	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/23/2022 00:00	0.0	0	0	0	0	1
02/23/2022 01:00	0.0	0	0	0	0	1
02/23/2022 02:00	0.0	0	0	0	0	1
02/23/2022 03:00	0.0	0	0	0	0	1
02/23/2022 04:00	0.0	0	0	0	0	1
02/23/2022 05:00	0.0	0	0	0	0	1
02/23/2022 06:00	0.0	0	0	0	0	1
02/23/2022 07:00	0.0	0	0	0	0	1
02/23/2022 08:00	0.0	0	0	0	0	1
02/23/2022 09:00	0.0	0	0	0	0	1
02/23/2022 10:00	0.0	0	0	0	0	1
02/23/2022 11:00	0.0	0	0	0	0	1
02/23/2022 12:00	0.0	0	0	0	0	1
02/23/2022 13:00	0.0	0	0	0	0	1
02/23/2022 14:00	0.0	0	0	0	0	1
02/23/2022 15:00	0.0	0	0	0	0	1
02/23/2022 16:00	0.0	0	0	0	0	1
02/23/2022 17:00	0.0	0	0	0	0	1
02/23/2022 18:00	0.0	0	0	0	0	1
02/23/2022 19:00	0.0	0	0	0	0	1
02/23/2022 20:00	0.0	0	0	0	0	1
02/23/2022 21:00	0.0	0	0	0	0	1
02/23/2022 22:00	0.0	0	0	0	0	1
02/23/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/24/2022 00:00	0.0	0	0	0	0	1
02/24/2022 01:00	0.0	0	0	0	0	1
02/24/2022 02:00	0.0	0	0	0	0	1
02/24/2022 03:00	0.0	0	0	0	0	1
02/24/2022 04:00	0.0	0	0	0	0	1
02/24/2022 05:00	0.0	0	0	0	0	1
02/24/2022 06:00	0.0	0	0	0	0	1
02/24/2022 07:00	0.0	0	0	0	0	1
02/24/2022 08:00	0.0	0	0	0	0	1
02/24/2022 09:00	0.0	0	0	0	0	1
02/24/2022 10:00	0.0	0	0	0	0	1
02/24/2022 11:00	0.0	0	0	0	0	1
02/24/2022 12:00	0.0	0	0	0	0	1
02/24/2022 13:00	0.0	0	0	0	0	1
02/24/2022 14:00	0.0	0	0	0	0	1
02/24/2022 15:00	0.0	0	0	0	0	1
02/24/2022 16:00	0.0	0	0	0	0	1
02/24/2022 17:00	0.0	0	0	0	0	1
02/24/2022 18:00	0.0	0	0	0	0	1
02/24/2022 19:00	0.0	0	0	0	0	1
02/24/2022 20:00	0.0	0	0	0	0	1
02/24/2022 21:00	0.0	0	0	0	0	1
02/24/2022 22:00	0.0	0	0	0	0	1
02/24/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/25/2022 00:00	0.0	0	0	0	0	1
02/25/2022 01:00	0.0	0	0	0	0	1
02/25/2022 02:00	0.0	0	0	0	0	1
02/25/2022 03:00	0.0	0	0	0	0	1
02/25/2022 04:00	0.0	0	0	0	0	1
02/25/2022 05:00	0.0	0	0	0	0	1
02/25/2022 06:00	0.0	0	0	0	0	1
02/25/2022 07:00	0.0	0	0	0	0	1
02/25/2022 08:00	0.0	0	0	0	0	1
02/25/2022 09:00	0.0	0	0	0	0	1
02/25/2022 10:00	0.0	0	0	0	0	1
02/25/2022 11:00	0.0	0	0	0	0	1
02/25/2022 12:00	0.0	0	0	0	0	1
02/25/2022 13:00	0.0	0	0	0	0	1
02/25/2022 14:00	0.0	0	0	0	0	1
02/25/2022 15:00	0.0	0	0	0	0	1
02/25/2022 16:00	0.0	0	0	0	0	1
02/25/2022 17:00	0.0	0	0	0	0	1
02/25/2022 18:00	0.0	0	0	0	0	1
02/25/2022 19:00	0.0	0	0	0	0	1
02/25/2022 20:00	0.0	0	0	0	0	1
02/25/2022 21:00	0.0	0	0	0	0	1
02/25/2022 22:00	0.0	0	0	0	0	1
02/25/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/26/2022 00:00	0.0	0	0	0	0	1
02/26/2022 01:00	0.0	0	0	0	0	1
02/26/2022 02:00	0.0	0	0	0	0	1
02/26/2022 03:00	0.0	0	0	0	0	1
02/26/2022 04:00	0.0	0	0	0	0	1
02/26/2022 05:00	0.0	0	0	0	0	1
02/26/2022 06:00	0.0	0	0	0	0	1
02/26/2022 07:00	46.8	0	0	0	1	0
02/26/2022 08:00	0.0	0	0	0	0	0
02/26/2022 09:00	0.0	0	0	0	0	0
02/26/2022 10:00	0.0	0	0	0	0	0
02/26/2022 11:00	0.0	0	0	0	0	0
02/26/2022 12:00	0.0	0	0	0	0	0
02/26/2022 13:00	0.0	0	0	0	0	0
02/26/2022 14:00	0.0	0	0	0	0	0
02/26/2022 15:00	1,106.4	0	1	0	0	0
02/26/2022 16:00	5,984.2	0	1	0	0	0
02/26/2022 17:00	0.0	0	0	0	0	1
02/26/2022 18:00	0.0	0	0	0	0	1
02/26/2022 19:00	0.0	0	0	0	0	1
02/26/2022 20:00	0.0	0	0	0	0	1
02/26/2022 21:00	0.0	0	0	0	0	1
02/26/2022 22:00	0.0	0	0	0	0	1
02/26/2022 23:00	30.2	0	0	0	1	0
Average/Sum#:	7,167.6 #	0 #	2 #	0 #	2 #	13 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,984.2	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/27/2022 00:00	0.0	0	0	0	0	0
02/27/2022 01:00	0.0	0	0	0	0	0
02/27/2022 02:00	0.0	0	0	0	0	0
02/27/2022 03:00	0.0	0	0	0	0	0
02/27/2022 04:00	0.0	0	0	0	0	0
02/27/2022 05:00	0.0	0	0	0	0	0
02/27/2022 06:00	0.0	0	0	0	0	0
02/27/2022 07:00	0.0	0	0	0	0	0
02/27/2022 08:00	0.0	0	0	0	0	0
02/27/2022 09:00	0.0	0	0	0	0	0
02/27/2022 10:00	0.0	0	0	0	0	0
02/27/2022 11:00	0.0	0	0	0	0	0
02/27/2022 12:00	0.0	0	0	0	0	0
02/27/2022 13:00	0.0	0	0	0	0	0
02/27/2022 14:00	0.0	0	0	0	0	0
02/27/2022 15:00	0.0	0	0	0	0	0
02/27/2022 16:00	0.0	0	0	0	0	0
02/27/2022 17:00	0.0	0	0	0	0	0
02/27/2022 18:00	0.0	0	0	0	0	0
02/27/2022 19:00	0.0	0	0	0	0	0
02/27/2022 20:00	0.0	0	0	0	0	0
02/27/2022 21:00	0.0	0	0	0	0	0
02/27/2022 22:00	0.0	0	0	0	0	0
02/27/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/28/2022 00:00	0.0	0	0	0	0	0
02/28/2022 01:00	0.0	0	0	0	0	0
02/28/2022 02:00	0.0	0	0	0	0	0
02/28/2022 03:00	0.0	0	0	0	0	0
02/28/2022 04:00	0.0	0	0	0	0	0
02/28/2022 05:00	0.0	0	0	0	0	0
02/28/2022 06:00	0.0	0	0	0	0	0
02/28/2022 07:00	0.0	0	0	0	0	0
02/28/2022 08:00	0.0	0	0	0	0	0
02/28/2022 09:00	0.0	0	0	0	0	0
02/28/2022 10:00	0.0	0	0	0	0	0
02/28/2022 11:00	0.0	0	0	0	0	0
02/28/2022 12:00	0.0	0	0	0	0	0
02/28/2022 13:00	2,477.5	0	1	0	0	0
02/28/2022 14:00	3,738.3	0	1	0	0	0
02/28/2022 15:00	5,652.1	0	1	0	0	0
02/28/2022 16:00	0.0	0	0	0	0	1
02/28/2022 17:00	0.0	0	0	0	0	1
02/28/2022 18:00	0.0	0	0	0	0	1
02/28/2022 19:00	0.0	0	0	0	0	1
02/28/2022 20:00	0.0	0	0	0	0	1
02/28/2022 21:00	0.0	0	0	0	0	1
02/28/2022 22:00	51.2	0	0	0	1	0
02/28/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	11,919.1 #	0 #	3 #	0 #	1 #	6 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,652.1	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/01/2022 00:00	0.0	0	0	0	0	0
03/01/2022 01:00	0.0	0	0	0	0	0
03/01/2022 02:00	0.0	0	0	0	0	0
03/01/2022 03:00	0.0	0	0	0	0	0
03/01/2022 04:00	0.0	0	0	0	0	0
03/01/2022 05:00	0.0	0	0	0	0	0
03/01/2022 06:00	0.0	0	0	0	0	0
03/01/2022 07:00	0.0	0	0	0	0	0
03/01/2022 08:00	0.0	0	0	0	0	0
03/01/2022 09:00	0.0	0	0	0	0	0
03/01/2022 10:00	0.0	0	0	0	0	0
03/01/2022 11:00	0.0	0	0	0	0	0
03/01/2022 12:00	0.0	0	0	0	0	0
03/01/2022 13:00	0.0	0	0	0	0	0
03/01/2022 14:00	0.0	0	0	0	0	0
03/01/2022 15:00	0.0	0	0	0	0	0
03/01/2022 16:00	0.0	0	0	0	0	0
03/01/2022 17:00	0.0	0	0	0	0	0
03/01/2022 18:00	0.0	0	0	0	0	0
03/01/2022 19:00	0.0	0	0	0	0	0
03/01/2022 20:00	0.0	0	0	0	0	0
03/01/2022 21:00	0.0	0	0	0	0	0
03/01/2022 22:00	0.0	0	0	0	0	0
03/01/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/02/2022 00:00	0.0	0	0	0	0	0
03/02/2022 01:00	0.0	0	0	0	0	0
03/02/2022 02:00	0.0	0	0	0	0	0
03/02/2022 03:00	0.0	0	0	0	0	0
03/02/2022 04:00	0.0	0	0	0	0	0
03/02/2022 05:00	0.0	0	0	0	0	0
03/02/2022 06:00	0.0	0	0	0	0	0
03/02/2022 07:00	0.0	0	0	0	0	0
03/02/2022 08:00	0.0	0	0	0	0	0
03/02/2022 09:00	0.0	0	0	0	0	0
03/02/2022 10:00	0.0	0	0	0	0	0
03/02/2022 11:00	0.0	0	0	0	0	0
03/02/2022 12:00	0.0	0	0	0	0	0
03/02/2022 13:00	0.0	0	0	0	0	0
03/02/2022 14:00	0.0	0	0	0	0	0
03/02/2022 15:00	0.0	0	0	0	0	0
03/02/2022 16:00	0.0	0	0	0	0	0
03/02/2022 17:00	0.0	0	0	0	0	0
03/02/2022 18:00	0.0	0	0	0	0	0
03/02/2022 19:00	0.0	0	0	0	0	0
03/02/2022 20:00	0.0	0	0	0	0	0
03/02/2022 21:00	0.0	0	0	0	0	0
03/02/2022 22:00	0.0	0	0	0	0	0
03/02/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/03/2022 00:00	0.0	0	0	0	0	0
03/03/2022 01:00	0.0	0	0	0	0	0
03/03/2022 02:00	0.0	0	0	0	0	0
03/03/2022 03:00	0.0	0	0	0	0	0
03/03/2022 04:00	0.0	0	0	0	0	0
03/03/2022 05:00	0.0	0	0	0	0	0
03/03/2022 06:00	0.0	0	0	0	0	0
03/03/2022 07:00	0.0	0	0	0	0	0
03/03/2022 08:00	0.0	0	0	0	0	0
03/03/2022 09:00	0.0	0	0	0	0	0
03/03/2022 10:00	0.0	0	0	0	0	0
03/03/2022 11:00	0.0	0	0	0	0	0
03/03/2022 12:00	0.0	0	0	0	0	0
03/03/2022 13:00	0.0	0	0	0	0	0
03/03/2022 14:00	0.0	0	0	0	0	0
03/03/2022 15:00	0.0	0	0	0	0	0
03/03/2022 16:00	0.0	0	0	0	0	0
03/03/2022 17:00	0.0	0	0	0	0	0
03/03/2022 18:00	0.0	0	0	0	0	0
03/03/2022 19:00	0.0	0	0	0	0	0
03/03/2022 20:00	0.0	0	0	0	0	0
03/03/2022 21:00	0.0	0	0	0	0	0
03/03/2022 22:00	0.0	0	0	0	0	0
03/03/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/04/2022 00:00	0.0	0	0	0	0	0
03/04/2022 01:00	0.0	0	0	0	0	0
03/04/2022 02:00	0.0	0	0	0	0	0
03/04/2022 03:00	0.0	0	0	0	0	0
03/04/2022 04:00	0.0	0	0	0	0	0
03/04/2022 05:00	0.0	0	0	0	0	0
03/04/2022 06:00	0.0	0	0	0	0	0
03/04/2022 07:00	0.0	0	0	0	0	0
03/04/2022 08:00	0.0	0	0	0	0	0
03/04/2022 09:00	0.0	0	0	0	0	0
03/04/2022 10:00	0.0	0	0	0	0	0
03/04/2022 11:00	0.0	0	0	0	0	0
03/04/2022 12:00	0.0	0	0	0	0	0
03/04/2022 13:00	0.0	0	0	0	0	0
03/04/2022 14:00	0.0	0	0	0	0	0
03/04/2022 15:00	0.0	0	0	0	0	0
03/04/2022 16:00	0.0	0	0	0	0	0
03/04/2022 17:00	0.0	0	0	0	0	0
03/04/2022 18:00	0.0	0	0	0	0	0
03/04/2022 19:00	0.0	0	0	0	0	0
03/04/2022 20:00	0.0	0	0	0	0	0
03/04/2022 21:00	0.0	0	0	0	0	0
03/04/2022 22:00	0.0	0	0	0	0	0
03/04/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/05/2022 00:00	0.0	0	0	0	0	0
03/05/2022 01:00	0.0	0	0	0	0	0
03/05/2022 02:00	0.0	0	0	0	0	0
03/05/2022 03:00	0.0	0	0	0	0	0
03/05/2022 04:00	0.0	0	0	0	0	0
03/05/2022 05:00	0.0	0	0	0	0	0
03/05/2022 06:00	0.0	0	0	0	0	0
03/05/2022 07:00	0.0	0	0	0	0	0
03/05/2022 08:00	0.0	0	0	0	0	0
03/05/2022 09:00	0.0	0	0	0	0	0
03/05/2022 10:00	0.0	0	0	0	0	0
03/05/2022 11:00	0.0	0	0	0	0	0
03/05/2022 12:00	0.0	0	0	0	0	0
03/05/2022 13:00	0.0	0	0	0	0	0
03/05/2022 14:00	0.0	0	0	0	0	0
03/05/2022 15:00	0.0	0	0	0	0	0
03/05/2022 16:00	0.0	0	0	0	0	0
03/05/2022 17:00	0.0	0	0	0	0	0
03/05/2022 18:00	0.0	0	0	0	0	0
03/05/2022 19:00	0.0	0	0	0	0	0
03/05/2022 20:00	0.0	0	0	0	0	0
03/05/2022 21:00	0.0	0	0	0	0	0
03/05/2022 22:00	0.0	0	0	0	0	0
03/05/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/06/2022 00:00	0.0	0	0	0	0	0
03/06/2022 01:00	0.0	0	0	0	0	0
03/06/2022 02:00	0.0	0	0	0	0	0
03/06/2022 03:00	0.0	0	0	0	0	0
03/06/2022 04:00	0.0	0	0	0	0	0
03/06/2022 05:00	0.0	0	0	0	0	0
03/06/2022 06:00	0.0	0	0	0	0	0
03/06/2022 07:00	0.0	0	0	0	0	0
03/06/2022 08:00	0.0	0	0	0	0	0
03/06/2022 09:00	0.0	0	0	0	0	0
03/06/2022 10:00	0.0	0	0	0	0	0
03/06/2022 11:00	0.0	0	0	0	0	0
03/06/2022 12:00	0.0	0	0	0	0	0
03/06/2022 13:00	0.0	0	0	0	0	0
03/06/2022 14:00	0.0	0	0	0	0	0
03/06/2022 15:00	0.0	0	0	0	0	0
03/06/2022 16:00	0.0	0	0	0	0	0
03/06/2022 17:00	0.0	0	0	0	0	0
03/06/2022 18:00	0.0	0	0	0	0	0
03/06/2022 19:00	0.0	0	0	0	0	0
03/06/2022 20:00	0.0	0	0	0	0	0
03/06/2022 21:00	0.0	0	0	0	0	0
03/06/2022 22:00	0.0	0	0	0	0	0
03/06/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/07/2022 00:00	0.0	0	0	0	0	0
03/07/2022 01:00	0.0	0	0	0	0	0
03/07/2022 02:00	0.0	0	0	0	0	0
03/07/2022 03:00	0.0	0	0	0	0	0
03/07/2022 04:00	0.0	0	0	0	0	0
03/07/2022 05:00	0.0	0	0	0	0	0
03/07/2022 06:00	0.0	0	0	0	0	0
03/07/2022 07:00	0.0	0	0	0	0	0
03/07/2022 08:00	0.0	0	0	0	0	0
03/07/2022 09:00	0.0	0	0	0	0	0
03/07/2022 10:00	0.0	0	0	0	0	0
03/07/2022 11:00	0.0	0	0	0	0	0
03/07/2022 12:00	0.0	0	0	0	0	0
03/07/2022 13:00	0.0	0	0	0	0	0
03/07/2022 14:00	0.0	0	0	0	0	0
03/07/2022 15:00	0.0	0	0	0	0	0
03/07/2022 16:00	0.0	0	0	0	0	0
03/07/2022 17:00	0.0	0	0	0	0	0
03/07/2022 18:00	0.0	0	0	0	0	0
03/07/2022 19:00	0.0	0	0	0	0	0
03/07/2022 20:00	0.0	0	0	0	0	0
03/07/2022 21:00	0.0	0	0	0	0	0
03/07/2022 22:00	0.0	0	0	0	0	0
03/07/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/08/2022 00:00	0.0	0	0	0	0	0
03/08/2022 01:00	0.0	0	0	0	0	0
03/08/2022 02:00	0.0	0	0	0	0	0
03/08/2022 03:00	0.0	0	0	0	0	0
03/08/2022 04:00	0.0	0	0	0	0	0
03/08/2022 05:00	0.0	0	0	0	0	0
03/08/2022 06:00	0.0	0	0	0	0	0
03/08/2022 07:00	0.0	0	0	0	0	0
03/08/2022 08:00	0.0	0	0	0	0	0
03/08/2022 09:00	0.0	0	0	0	0	0
03/08/2022 10:00	0.0	0	0	0	0	0
03/08/2022 11:00	0.0	0	0	0	0	0
03/08/2022 12:00	0.0	0	0	0	0	0
03/08/2022 13:00	0.0	0	0	0	0	0
03/08/2022 14:00	0.0	0	0	0	0	0
03/08/2022 15:00	0.0	0	0	0	0	0
03/08/2022 16:00	0.0	0	0	0	0	0
03/08/2022 17:00	0.0	0	0	0	0	0
03/08/2022 18:00	0.0	0	0	0	0	0
03/08/2022 19:00	0.0	0	0	0	0	0
03/08/2022 20:00	0.0	0	0	0	0	0
03/08/2022 21:00	0.0	0	0	0	0	0
03/08/2022 22:00	0.0	0	0	0	0	0
03/08/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/09/2022 00:00	0.0	0	0	0	0	0
03/09/2022 01:00	0.0	0	0	0	0	0
03/09/2022 02:00	0.0	0	0	0	0	0
03/09/2022 03:00	0.0	0	0	0	0	0
03/09/2022 04:00	0.0	0	0	0	0	0
03/09/2022 05:00	0.0	0	0	0	0	0
03/09/2022 06:00	0.0	0	0	0	0	0
03/09/2022 07:00	0.0	0	0	0	0	0
03/09/2022 08:00	0.0	0	0	0	0	0
03/09/2022 09:00	0.0	0	0	0	0	0
03/09/2022 10:00	0.0	0	0	0	0	0
03/09/2022 11:00	0.0	0	0	0	0	0
03/09/2022 12:00	0.0	0	0	0	0	0
03/09/2022 13:00	0.0	0	0	0	0	0
03/09/2022 14:00	0.0	0	0	0	0	0
03/09/2022 15:00	0.0	0	0	0	0	0
03/09/2022 16:00	0.0	0	0	0	0	0
03/09/2022 17:00	0.0	0	0	0	0	0
03/09/2022 18:00	0.0	0	0	0	0	0
03/09/2022 19:00	0.0	0	0	0	0	0
03/09/2022 20:00	0.0	0	0	0	0	0
03/09/2022 21:00	0.0	0	0	0	0	0
03/09/2022 22:00	0.0	0	0	0	0	0
03/09/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/10/2022 00:00	0.0	0	0	0	0	0
03/10/2022 01:00	0.0	0	0	0	0	0
03/10/2022 02:00	0.0	0	0	0	0	0
03/10/2022 03:00	0.0	0	0	0	0	0
03/10/2022 04:00	0.0	0	0	0	0	0
03/10/2022 05:00	0.0	0	0	0	0	0
03/10/2022 06:00	0.0	0	0	0	0	0
03/10/2022 07:00	0.0	0	0	0	0	0
03/10/2022 08:00	0.0	0	0	0	0	0
03/10/2022 09:00	0.0	0	0	0	0	0
03/10/2022 10:00	0.0	0	0	0	0	0
03/10/2022 11:00	0.0	0	0	0	0	0
03/10/2022 12:00	0.0	0	0	0	0	0
03/10/2022 13:00	0.0	0	0	0	0	0
03/10/2022 14:00	0.0	0	0	0	0	0
03/10/2022 15:00	0.0	0	0	0	0	0
03/10/2022 16:00	0.0	0	0	0	0	0
03/10/2022 17:00	0.0	0	0	0	0	0
03/10/2022 18:00	0.0	0	0	0	0	0
03/10/2022 19:00	0.0	0	0	0	0	0
03/10/2022 20:00	0.0	0	0	0	0	0
03/10/2022 21:00	0.0	0	0	0	0	0
03/10/2022 22:00	0.0	0	0	0	0	0
03/10/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/11/2022 00:00	0.0	0	0	0	0	0
03/11/2022 01:00	0.0	0	0	0	0	0
03/11/2022 02:00	0.0	0	0	0	0	0
03/11/2022 03:00	0.0	0	0	0	0	0
03/11/2022 04:00	0.0	0	0	0	0	0
03/11/2022 05:00	0.0	0	0	0	0	0
03/11/2022 06:00	0.0	0	0	0	0	0
03/11/2022 07:00	0.0	0	0	0	0	0
03/11/2022 08:00	0.0	0	0	0	0	0
03/11/2022 09:00	0.0	0	0	0	0	0
03/11/2022 10:00	0.0	0	0	0	0	0
03/11/2022 11:00	0.0	0	0	0	0	0
03/11/2022 12:00	0.0	0	0	0	0	0
03/11/2022 13:00	0.0	0	0	0	0	0
03/11/2022 14:00	0.0	0	0	0	0	0
03/11/2022 15:00	0.0	0	0	0	0	0
03/11/2022 16:00	0.0	0	0	0	0	0
03/11/2022 17:00	0.0	0	0	0	0	0
03/11/2022 18:00	0.0	0	0	0	0	0
03/11/2022 19:00	0.0	0	0	0	0	0
03/11/2022 20:00	0.0	0	0	0	0	0
03/11/2022 21:00	0.0	0	0	0	0	0
03/11/2022 22:00	0.0	0	0	0	0	0
03/11/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/12/2022 00:00	0.0	0	0	0	0	0
03/12/2022 01:00	0.0	0	0	0	0	0
03/12/2022 02:00	0.0	0	0	0	0	0
03/12/2022 03:00	0.0	0	0	0	0	0
03/12/2022 04:00	0.0	0	0	0	0	0
03/12/2022 05:00	0.0	0	0	0	0	0
03/12/2022 06:00	0.0	0	0	0	0	0
03/12/2022 07:00	0.0	0	0	0	0	0
03/12/2022 08:00	0.0	0	0	0	0	0
03/12/2022 09:00	0.0	0	0	0	0	0
03/12/2022 10:00	0.0	0	0	0	0	0
03/12/2022 11:00	0.0	0	0	0	0	0
03/12/2022 12:00	0.0	0	0	0	0	0
03/12/2022 13:00	0.0	0	0	0	0	0
03/12/2022 14:00	0.0	0	0	0	0	0
03/12/2022 15:00	0.0	0	0	0	0	0
03/12/2022 16:00	0.0	0	0	0	0	0
03/12/2022 17:00	0.0	0	0	0	0	0
03/12/2022 18:00	0.0	0	0	0	0	0
03/12/2022 19:00	0.0	0	0	0	0	0
03/12/2022 20:00	0.0	0	0	0	0	0
03/12/2022 21:00	0.0	0	0	0	0	0
03/12/2022 22:00	0.0	0	0	0	0	0
03/12/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/13/2022 00:00	0.0	0	0	0	0	0
03/13/2022 01:00	0.0	0	0	0	0	0
03/13/2022 02:00	0.0	0	0	0	0	0
03/13/2022 03:00	0.0	0	0	0	0	0
03/13/2022 04:00	0.0	0	0	0	0	0
03/13/2022 05:00	0.0	0	0	0	0	0
03/13/2022 06:00	0.0	0	0	0	0	0
03/13/2022 07:00	0.0	0	0	0	0	0
03/13/2022 08:00	0.0	0	0	0	0	0
03/13/2022 09:00	0.0	0	0	0	0	0
03/13/2022 10:00	0.0	0	0	0	0	0
03/13/2022 11:00	0.0	0	0	0	0	0
03/13/2022 12:00	0.0	0	0	0	0	0
03/13/2022 13:00	0.0	0	0	0	0	0
03/13/2022 14:00	0.0	0	0	0	0	0
03/13/2022 15:00	0.0	0	0	0	0	0
03/13/2022 16:00	0.0	0	0	0	0	0
03/13/2022 17:00	0.0	0	0	0	0	0
03/13/2022 18:00	0.0	0	0	0	0	0
03/13/2022 19:00	0.0	0	0	0	0	0
03/13/2022 20:00	0.0	0	0	0	0	0
03/13/2022 21:00	0.0	0	0	0	0	0
03/13/2022 22:00	0.0	0	0	0	0	0
03/13/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/14/2022 00:00	0.0	0	0	0	0	0
03/14/2022 01:00	0.0	0	0	0	0	0
03/14/2022 02:00	0.0	0	0	0	0	0
03/14/2022 03:00	0.0	0	0	0	0	0
03/14/2022 04:00	0.0	0	0	0	0	0
03/14/2022 05:00	0.0	0	0	0	0	0
03/14/2022 06:00	0.0	0	0	0	0	0
03/14/2022 07:00	0.0	0	0	0	0	0
03/14/2022 08:00	0.0	0	0	0	0	0
03/14/2022 09:00	0.0	0	0	0	0	0
03/14/2022 10:00	0.0	0	0	0	0	0
03/14/2022 11:00	0.0	0	0	0	0	0
03/14/2022 12:00	0.0	0	0	0	0	0
03/14/2022 13:00	0.0	0	0	0	0	0
03/14/2022 14:00	0.0	0	0	0	0	0
03/14/2022 15:00	0.0	0	0	0	0	0
03/14/2022 16:00	0.0	0	0	0	0	0
03/14/2022 17:00	0.0	0	0	0	0	0
03/14/2022 18:00	0.0	0	0	0	0	0
03/14/2022 19:00	0.0	0	0	0	0	0
03/14/2022 20:00	0.0	0	0	0	0	0
03/14/2022 21:00	0.0	0	0	0	0	0
03/14/2022 22:00	0.0	0	0	0	0	0
03/14/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/15/2022 00:00	0.0	0	0	0	0	0
03/15/2022 01:00	0.0	0	0	0	0	0
03/15/2022 02:00	0.0	0	0	0	0	0
03/15/2022 03:00	0.0	0	0	0	0	0
03/15/2022 04:00	0.0	0	0	0	0	0
03/15/2022 05:00	0.0	0	0	0	0	0
03/15/2022 06:00	0.0	0	0	0	0	0
03/15/2022 07:00	0.0	0	0	0	0	0
03/15/2022 08:00	0.0	0	0	0	0	0
03/15/2022 09:00	0.0	0	0	0	0	0
03/15/2022 10:00	0.0	0	0	0	0	0
03/15/2022 11:00	0.0	0	0	0	0	0
03/15/2022 12:00	0.0	0	0	0	0	0
03/15/2022 13:00	0.0	0	0	0	0	0
03/15/2022 14:00	0.0	0	0	0	0	0
03/15/2022 15:00	0.0	0	0	0	0	0
03/15/2022 16:00	0.0	0	0	0	0	0
03/15/2022 17:00	0.0	0	0	0	0	0
03/15/2022 18:00	0.0	0	0	0	0	0
03/15/2022 19:00	0.0	0	0	0	0	0
03/15/2022 20:00	0.0	0	0	0	0	0
03/15/2022 21:00	0.0	0	0	0	0	0
03/15/2022 22:00	0.0	0	0	0	0	0
03/15/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/16/2022 00:00	0.0	0	0	0	0	0
03/16/2022 01:00	0.0	0	0	0	0	0
03/16/2022 02:00	0.0	0	0	0	0	0
03/16/2022 03:00	0.0	0	0	0	0	0
03/16/2022 04:00	0.0	0	0	0	0	0
03/16/2022 05:00	0.0	0	0	0	0	0
03/16/2022 06:00	0.0	0	0	0	0	0
03/16/2022 07:00	0.0	0	0	0	0	0
03/16/2022 08:00	0.0	0	0	0	0	0
03/16/2022 09:00	0.0	0	0	0	0	0
03/16/2022 10:00	0.0	0	0	0	0	0
03/16/2022 11:00	0.0	0	0	0	0	0
03/16/2022 12:00	0.0	0	0	0	0	0
03/16/2022 13:00	0.0	0	0	0	0	0
03/16/2022 14:00	0.0	0	0	0	0	0
03/16/2022 15:00	0.0	0	0	0	0	0
03/16/2022 16:00	0.0	0	0	0	0	0
03/16/2022 17:00	0.0	0	0	0	0	0
03/16/2022 18:00	0.0	0	0	0	0	0
03/16/2022 19:00	0.0	0	0	0	0	0
03/16/2022 20:00	0.0	0	0	0	0	0
03/16/2022 21:00	0.0	0	0	0	0	0
03/16/2022 22:00	0.0	0	0	0	0	0
03/16/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/17/2022 00:00	0.0	0	0	0	0	0
03/17/2022 01:00	0.0	0	0	0	0	0
03/17/2022 02:00	0.0	0	0	0	0	0
03/17/2022 03:00	0.0	0	0	0	0	0
03/17/2022 04:00	0.0	0	0	0	0	0
03/17/2022 05:00	0.0	0	0	0	0	0
03/17/2022 06:00	0.0	0	0	0	0	0
03/17/2022 07:00	0.0	0	0	0	0	0
03/17/2022 08:00	0.0	0	0	0	0	0
03/17/2022 09:00	0.0	0	0	0	0	0
03/17/2022 10:00	0.0	0	0	0	0	0
03/17/2022 11:00	0.0	0	0	0	0	0
03/17/2022 12:00	0.0	0	0	0	0	0
03/17/2022 13:00	0.0	0	0	0	0	0
03/17/2022 14:00	0.0	0	0	0	0	0
03/17/2022 15:00	0.0	0	0	0	0	0
03/17/2022 16:00	0.0	0	0	0	0	0
03/17/2022 17:00	0.0	0	0	0	0	0
03/17/2022 18:00	0.0	0	0	0	0	0
03/17/2022 19:00	0.0	0	0	0	0	0
03/17/2022 20:00	0.0	0	0	0	0	0
03/17/2022 21:00	0.0	0	0	0	0	0
03/17/2022 22:00	0.0	0	0	0	0	0
03/17/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/18/2022 00:00	0.0	0	0	0	0	0
03/18/2022 01:00	0.0	0	0	0	0	0
03/18/2022 02:00	0.0	0	0	0	0	0
03/18/2022 03:00	0.0	0	0	0	0	0
03/18/2022 04:00	0.0	0	0	0	0	0
03/18/2022 05:00	0.0	0	0	0	0	0
03/18/2022 06:00	0.0	0	0	0	0	0
03/18/2022 07:00	0.0	0	0	0	0	0
03/18/2022 08:00	0.0	0	0	0	0	0
03/18/2022 09:00	0.0	0	0	0	0	0
03/18/2022 10:00	0.0	0	0	0	0	0
03/18/2022 11:00	0.0	0	0	0	0	0
03/18/2022 12:00	0.0	0	0	0	0	0
03/18/2022 13:00	0.0	0	0	0	0	0
03/18/2022 14:00	0.0	0	0	0	0	0
03/18/2022 15:00	0.0	0	0	0	0	0
03/18/2022 16:00	0.0	0	0	0	0	0
03/18/2022 17:00	0.0	0	0	0	0	0
03/18/2022 18:00	0.0	0	0	0	0	0
03/18/2022 19:00	0.0	0	0	0	0	0
03/18/2022 20:00	0.0	0	0	0	0	0
03/18/2022 21:00	0.0	0	0	0	0	0
03/18/2022 22:00	0.0	0	0	0	0	0
03/18/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/19/2022 00:00	0.0	0	0	0	0	0
03/19/2022 01:00	0.0	0	0	0	0	0
03/19/2022 02:00	0.0	0	0	0	0	0
03/19/2022 03:00	0.0	0	0	0	0	0
03/19/2022 04:00	0.0	0	0	0	0	0
03/19/2022 05:00	0.0	0	0	0	0	0
03/19/2022 06:00	0.0	0	0	0	0	0
03/19/2022 07:00	0.0	0	0	0	0	0
03/19/2022 08:00	0.0	0	0	0	0	0
03/19/2022 09:00	0.0	0	0	0	0	0
03/19/2022 10:00	0.0	0	0	0	0	0
03/19/2022 11:00	0.0	0	0	0	0	0
03/19/2022 12:00	0.0	0	0	0	0	0
03/19/2022 13:00	0.0	0	0	0	0	0
03/19/2022 14:00	0.0	0	0	0	0	0
03/19/2022 15:00	0.0	0	0	0	0	0
03/19/2022 16:00	0.0	0	0	0	0	0
03/19/2022 17:00	0.0	0	0	0	0	0
03/19/2022 18:00	0.0	0	0	0	0	0
03/19/2022 19:00	0.0	0	0	0	0	0
03/19/2022 20:00	0.0	0	0	0	0	0
03/19/2022 21:00	0.0	0	0	0	0	0
03/19/2022 22:00	0.0	0	0	0	0	0
03/19/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/20/2022 00:00	0.0	0	0	0	0	0
03/20/2022 01:00	0.0	0	0	0	0	0
03/20/2022 02:00	0.0	0	0	0	0	0
03/20/2022 03:00	0.0	0	0	0	0	0
03/20/2022 04:00	0.0	0	0	0	0	0
03/20/2022 05:00	0.0	0	0	0	0	0
03/20/2022 06:00	0.0	0	0	0	0	0
03/20/2022 07:00	0.0	0	0	0	0	0
03/20/2022 08:00	0.0	0	0	0	0	0
03/20/2022 09:00	0.0	0	0	0	0	0
03/20/2022 10:00	0.0	0	0	0	0	0
03/20/2022 11:00	0.0	0	0	0	0	0
03/20/2022 12:00	0.0	0	0	0	0	0
03/20/2022 13:00	0.0	0	0	0	0	0
03/20/2022 14:00	0.0	0	0	0	0	0
03/20/2022 15:00	0.0	0	0	0	0	0
03/20/2022 16:00	0.0	0	0	0	0	0
03/20/2022 17:00	0.0	0	0	0	0	0
03/20/2022 18:00	0.0	0	0	0	0	0
03/20/2022 19:00	0.0	0	0	0	0	0
03/20/2022 20:00	0.0	0	0	0	0	0
03/20/2022 21:00	0.0	0	0	0	0	0
03/20/2022 22:00	0.0	0	0	0	0	0
03/20/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/21/2022 00:00	0.0	0	0	0	0	0
03/21/2022 01:00	0.0	0	0	0	0	0
03/21/2022 02:00	0.0	0	0	0	0	0
03/21/2022 03:00	0.0	0	0	0	0	0
03/21/2022 04:00	0.0	0	0	0	0	0
03/21/2022 05:00	0.0	0	0	0	0	0
03/21/2022 06:00	0.0	0	0	0	0	0
03/21/2022 07:00	0.0	0	0	0	0	0
03/21/2022 08:00	0.0	0	0	0	0	0
03/21/2022 09:00	0.0	0	0	0	0	0
03/21/2022 10:00	0.0	0	0	0	0	0
03/21/2022 11:00	0.0	0	0	0	0	0
03/21/2022 12:00	0.0	0	0	0	0	0
03/21/2022 13:00	0.0	0	0	0	0	0
03/21/2022 14:00	0.0	0	0	0	0	0
03/21/2022 15:00	0.0	0	0	0	0	0
03/21/2022 16:00	0.0	0	0	0	0	0
03/21/2022 17:00	0.0	0	0	0	0	0
03/21/2022 18:00	0.0	0	0	0	0	0
03/21/2022 19:00	0.0	0	0	0	0	0
03/21/2022 20:00	0.0	0	0	0	0	0
03/21/2022 21:00	0.0	0	0	0	0	0
03/21/2022 22:00	0.0	0	0	0	0	0
03/21/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/22/2022 00:00	0.0	0	0	0	0	0
03/22/2022 01:00	0.0	0	0	0	0	0
03/22/2022 02:00	0.0	0	0	0	0	0
03/22/2022 03:00	0.0	0	0	0	0	0
03/22/2022 04:00	0.0	0	0	0	0	0
03/22/2022 05:00	0.0	0	0	0	0	0
03/22/2022 06:00	0.0	0	0	0	0	0
03/22/2022 07:00	0.0	0	0	0	0	0
03/22/2022 08:00	0.0	0	0	0	0	0
03/22/2022 09:00	0.0	0	0	0	0	0
03/22/2022 10:00	0.0	0	0	0	0	0
03/22/2022 11:00	0.0	0	0	0	0	0
03/22/2022 12:00	0.0	0	0	0	0	0
03/22/2022 13:00	0.0	0	0	0	0	0
03/22/2022 14:00	0.0	0	0	0	0	0
03/22/2022 15:00	0.0	0	0	0	0	0
03/22/2022 16:00	0.0	0	0	0	0	0
03/22/2022 17:00	0.0	0	0	0	0	0
03/22/2022 18:00	0.0	0	0	0	0	0
03/22/2022 19:00	0.0	0	0	0	0	0
03/22/2022 20:00	0.0	0	0	0	0	0
03/22/2022 21:00	0.0	0	0	0	0	0
03/22/2022 22:00	0.0	0	0	0	0	0
03/22/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/23/2022 00:00	0.0	0	0	0	0	0
03/23/2022 01:00	0.0	0	0	0	0	0
03/23/2022 02:00	0.0	0	0	0	0	0
03/23/2022 03:00	0.0	0	0	0	0	0
03/23/2022 04:00	0.0	0	0	0	0	0
03/23/2022 05:00	0.0	0	0	0	0	0
03/23/2022 06:00	0.0	0	0	0	0	0
03/23/2022 07:00	0.0	0	0	0	0	0
03/23/2022 08:00	0.0	0	0	0	0	0
03/23/2022 09:00	0.0	0	0	0	0	0
03/23/2022 10:00	0.0	0	0	0	0	0
03/23/2022 11:00	0.0	0	0	0	0	0
03/23/2022 12:00	0.0	0	0	0	0	0
03/23/2022 13:00	0.0	0	0	0	0	0
03/23/2022 14:00	0.0	0	0	0	0	0
03/23/2022 15:00	0.0	0	0	0	0	0
03/23/2022 16:00	0.0	0	0	0	0	0
03/23/2022 17:00	0.0	0	0	0	0	0
03/23/2022 18:00	0.0	0	0	0	0	0
03/23/2022 19:00	0.0	0	0	0	0	0
03/23/2022 20:00	0.0	0	0	0	0	0
03/23/2022 21:00	0.0	0	0	0	0	0
03/23/2022 22:00	0.0	0	0	0	0	0
03/23/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/24/2022 00:00	0.0	0	0	0	0	0
03/24/2022 01:00	0.0	0	0	0	0	0
03/24/2022 02:00	0.0	0	0	0	0	0
03/24/2022 03:00	0.0	0	0	0	0	0
03/24/2022 04:00	0.0	0	0	0	0	0
03/24/2022 05:00	0.0	0	0	0	0	0
03/24/2022 06:00	0.0	0	0	0	0	0
03/24/2022 07:00	0.0	0	0	0	0	0
03/24/2022 08:00	0.0	0	0	0	0	0
03/24/2022 09:00	0.0	0	0	0	0	0
03/24/2022 10:00	0.0	0	0	0	0	0
03/24/2022 11:00	0.0	0	0	0	0	0
03/24/2022 12:00	0.0	0	0	0	0	0
03/24/2022 13:00	0.0	0	0	0	0	0
03/24/2022 14:00	0.0	0	0	0	0	0
03/24/2022 15:00	0.0	0	0	0	0	0
03/24/2022 16:00	0.0	0	0	0	0	0
03/24/2022 17:00	0.0	0	0	0	0	0
03/24/2022 18:00	0.0	0	0	0	0	0
03/24/2022 19:00	0.0	0	0	0	0	0
03/24/2022 20:00	0.0	0	0	0	0	0
03/24/2022 21:00	0.0	0	0	0	0	0
03/24/2022 22:00	0.0	0	0	0	0	0
03/24/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/25/2022 00:00	0.0	0	0	0	0	0
03/25/2022 01:00	0.0	0	0	0	0	0
03/25/2022 02:00	0.0	0	0	0	0	0
03/25/2022 03:00	0.0	0	0	0	0	0
03/25/2022 04:00	0.0	0	0	0	0	0
03/25/2022 05:00	0.0	0	0	0	0	0
03/25/2022 06:00	0.0	0	0	0	0	0
03/25/2022 07:00	0.0	0	0	0	0	0
03/25/2022 08:00	0.0	0	0	0	0	0
03/25/2022 09:00	0.0	0	0	0	0	0
03/25/2022 10:00	0.0	0	0	0	0	0
03/25/2022 11:00	0.0	0	0	0	0	0
03/25/2022 12:00	0.0	0	0	0	0	0
03/25/2022 13:00	0.0	0	0	0	0	0
03/25/2022 14:00	0.0	0	0	0	0	0
03/25/2022 15:00	0.0	0	0	0	0	0
03/25/2022 16:00	0.0	0	0	0	0	0
03/25/2022 17:00	0.0	0	0	0	0	0
03/25/2022 18:00	0.0	0	0	0	0	0
03/25/2022 19:00	0.0	0	0	0	0	0
03/25/2022 20:00	0.0	0	0	0	0	0
03/25/2022 21:00	0.0	0	0	0	0	0
03/25/2022 22:00	0.0	0	0	0	0	0
03/25/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/26/2022 00:00	0.0	0	0	0	0	0
03/26/2022 01:00	0.0	0	0	0	0	0
03/26/2022 02:00	0.0	0	0	0	0	0
03/26/2022 03:00	0.0	0	0	0	0	0
03/26/2022 04:00	0.0	0	0	0	0	0
03/26/2022 05:00	0.0	0	0	0	0	0
03/26/2022 06:00	0.0	0	0	0	0	0
03/26/2022 07:00	0.0	0	0	0	0	0
03/26/2022 08:00	0.0	0	0	0	0	0
03/26/2022 09:00	0.0	0	0	0	0	0
03/26/2022 10:00	0.0	0	0	0	0	0
03/26/2022 11:00	0.0	0	0	0	0	0
03/26/2022 12:00	0.0	0	0	0	0	0
03/26/2022 13:00	0.0	0	0	0	0	0
03/26/2022 14:00	0.0	0	0	0	0	0
03/26/2022 15:00	0.0	0	0	0	0	0
03/26/2022 16:00	0.0	0	0	0	0	0
03/26/2022 17:00	0.0	0	0	0	0	0
03/26/2022 18:00	0.0	0	0	0	0	0
03/26/2022 19:00	0.0	0	0	0	0	0
03/26/2022 20:00	0.0	0	0	0	0	0
03/26/2022 21:00	0.0	0	0	0	0	0
03/26/2022 22:00	0.0	0	0	0	0	0
03/26/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/27/2022 00:00	0.0	0	0	0	0	0
03/27/2022 01:00	0.0	0	0	0	0	0
03/27/2022 02:00	0.0	0	0	0	0	0
03/27/2022 03:00	0.0	0	0	0	0	0
03/27/2022 04:00	0.0	0	0	0	0	0
03/27/2022 05:00	0.0	0	0	0	0	0
03/27/2022 06:00	0.0	0	0	0	0	0
03/27/2022 07:00	0.0	0	0	0	0	0
03/27/2022 08:00	0.0	0	0	0	0	0
03/27/2022 09:00	0.0	0	0	0	0	0
03/27/2022 10:00	0.0	0	0	0	0	0
03/27/2022 11:00	0.0	0	0	0	0	0
03/27/2022 12:00	0.0	0	0	0	0	0
03/27/2022 13:00	0.0	0	0	0	0	0
03/27/2022 14:00	0.0	0	0	0	0	0
03/27/2022 15:00	0.0	0	0	0	0	0
03/27/2022 16:00	0.0	0	0	0	0	0
03/27/2022 17:00	0.0	0	0	0	0	0
03/27/2022 18:00	0.0	0	0	0	0	0
03/27/2022 19:00	0.0	0	0	0	0	0
03/27/2022 20:00	0.0	0	0	0	0	0
03/27/2022 21:00	0.0	0	0	0	0	0
03/27/2022 22:00	0.0	0	0	0	0	0
03/27/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/28/2022 00:00	0.0	0	0	0	0	0
03/28/2022 01:00	0.0	0	0	0	0	0
03/28/2022 02:00	0.0	0	0	0	0	0
03/28/2022 03:00	0.0	0	0	0	0	0
03/28/2022 04:00	0.0	0	0	0	0	0
03/28/2022 05:00	0.0	0	0	0	0	0
03/28/2022 06:00	0.0	0	0	0	0	0
03/28/2022 07:00	0.0	0	0	0	0	0
03/28/2022 08:00	0.0	0	0	0	0	0
03/28/2022 09:00	0.0	0	0	0	0	0
03/28/2022 10:00	0.0	0	0	0	0	0
03/28/2022 11:00	0.0	0	0	0	0	0
03/28/2022 12:00	0.0	0	0	0	0	0
03/28/2022 13:00	0.0	0	0	0	0	0
03/28/2022 14:00	0.0	0	0	0	0	0
03/28/2022 15:00	0.0	0	0	0	0	0
03/28/2022 16:00	0.0	0	0	0	0	0
03/28/2022 17:00	0.0	0	0	0	0	0
03/28/2022 18:00	0.0	0	0	0	0	0
03/28/2022 19:00	0.0	0	0	0	0	0
03/28/2022 20:00	0.0	0	0	0	0	0
03/28/2022 21:00	0.0	0	0	0	0	0
03/28/2022 22:00	0.0	0	0	0	0	0
03/28/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/29/2022 00:00	0.0	0	0	0	0	0
03/29/2022 01:00	0.0	0	0	0	0	0
03/29/2022 02:00	0.0	0	0	0	0	0
03/29/2022 03:00	0.0	0	0	0	0	0
03/29/2022 04:00	0.0	0	0	0	0	0
03/29/2022 05:00	0.0	0	0	0	0	0
03/29/2022 06:00	0.0	0	0	0	0	0
03/29/2022 07:00	0.0	0	0	0	0	0
03/29/2022 08:00	0.0	0	0	0	0	0
03/29/2022 09:00	0.0	0	0	0	0	0
03/29/2022 10:00	0.0	0	0	0	0	0
03/29/2022 11:00	0.0	0	0	0	0	0
03/29/2022 12:00	0.0	0	0	0	0	0
03/29/2022 13:00	0.0	0	0	0	0	0
03/29/2022 14:00	0.0	0	0	0	0	0
03/29/2022 15:00	0.0	0	0	0	0	0
03/29/2022 16:00	0.0	0	0	0	0	0
03/29/2022 17:00	0.0	0	0	0	0	0
03/29/2022 18:00	0.0	0	0	0	0	0
03/29/2022 19:00	0.0	0	0	0	0	0
03/29/2022 20:00	0.0	0	0	0	0	0
03/29/2022 21:00	0.0	0	0	0	0	0
03/29/2022 22:00	0.0	0	0	0	0	0
03/29/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/30/2022 00:00	0.0	0	0	0	0	0
03/30/2022 01:00	0.0	0	0	0	0	0
03/30/2022 02:00	0.0	0	0	0	0	0
03/30/2022 03:00	0.0	0	0	0	0	0
03/30/2022 04:00	0.0	0	0	0	0	0
03/30/2022 05:00	0.0	0	0	0	0	0
03/30/2022 06:00	0.0	0	0	0	0	0
03/30/2022 07:00	0.0	0	0	0	0	0
03/30/2022 08:00	0.0	0	0	0	0	0
03/30/2022 09:00	0.0	0	0	0	0	0
03/30/2022 10:00	0.0	0	0	0	0	0
03/30/2022 11:00	0.0	0	0	0	0	0
03/30/2022 12:00	0.0	0	0	0	0	0
03/30/2022 13:00	0.0	0	0	0	0	0
03/30/2022 14:00	0.0	0	0	0	0	0
03/30/2022 15:00	0.0	0	0	0	0	0
03/30/2022 16:00	0.0	0	0	0	0	0
03/30/2022 17:00	0.0	0	0	0	0	0
03/30/2022 18:00	0.0	0	0	0	0	0
03/30/2022 19:00	0.0	0	0	0	0	0
03/30/2022 20:00	0.0	0	0	0	0	0
03/30/2022 21:00	0.0	0	0	0	0	0
03/30/2022 22:00	0.0	0	0	0	0	0
03/30/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:46 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/31/2022 00:00	0.0	0	0	0	0	0
03/31/2022 01:00	0.0	0	0	0	0	0
03/31/2022 02:00	0.0	0	0	0	0	0
03/31/2022 03:00	0.0	0	0	0	0	0
03/31/2022 04:00	0.0	0	0	0	0	0
03/31/2022 05:00	0.0	0	0	0	0	0
03/31/2022 06:00	0.0	0	0	0	0	0
03/31/2022 07:00	0.0	0	0	0	0	0
03/31/2022 08:00	0.0	0	0	0	0	0
03/31/2022 09:00	0.0	0	0	0	0	0
03/31/2022 10:00	0.0	0	0	0	0	0
03/31/2022 11:00	0.0	0	0	0	0	0
03/31/2022 12:00	0.0	0	0	0	0	0
03/31/2022 13:00	0.0	0	0	0	0	0
03/31/2022 14:00	0.0	0	0	0	0	0
03/31/2022 15:00	0.0	0	0	0	0	0
03/31/2022 16:00	0.0	0	0	0	0	0
03/31/2022 17:00	0.0	0	0	0	0	0
03/31/2022 18:00	0.0	0	0	0	0	0
03/31/2022 19:00	0.0	0	0	0	0	0
03/31/2022 20:00	0.0	0	0	0	0	0
03/31/2022 21:00	0.0	0	0	0	0	0
03/31/2022 22:00	0.0	0	0	0	0	0
03/31/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/01/2022 00:00	0.0	0	0	0	0	1
01/01/2022 01:00	0.0	0	0	0	0	1
01/01/2022 02:00	0.0	0	0	0	0	1
01/01/2022 03:00	0.0	0	0	0	0	1
01/01/2022 04:00	0.0	0	0	0	0	1
01/01/2022 05:00	0.0	0	0	0	0	1
01/01/2022 06:00	0.0	0	0	0	0	1
01/01/2022 07:00	0.0	0	0	0	0	1
01/01/2022 08:00	0.0	0	0	0	0	1
01/01/2022 09:00	0.0	0	0	0	0	1
01/01/2022 10:00	0.0	0	0	0	0	1
01/01/2022 11:00	0.0	0	0	0	0	1
01/01/2022 12:00	0.0	0	0	0	0	1
01/01/2022 13:00	0.0	0	0	0	0	1
01/01/2022 14:00	0.0	0	0	0	0	1
01/01/2022 15:00	0.0	0	0	0	0	1
01/01/2022 16:00	0.0	0	0	0	0	1
01/01/2022 17:00	0.0	0	0	0	0	1
01/01/2022 18:00	0.0	0	0	0	0	1
01/01/2022 19:00	0.0	0	0	0	0	1
01/01/2022 20:00	0.0	0	0	0	0	1
01/01/2022 21:00	0.0	0	0	0	0	1
01/01/2022 22:00	0.0	0	0	0	0	1
01/01/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/02/2022 00:00	0.0	0	0	0	0	1
01/02/2022 01:00	0.0	0	0	0	0	1
01/02/2022 02:00	0.0	0	0	0	0	1
01/02/2022 03:00	0.0	0	0	0	0	1
01/02/2022 04:00	0.0	0	0	0	0	1
01/02/2022 05:00	0.0	0	0	0	0	1
01/02/2022 06:00	0.0	0	0	0	0	1
01/02/2022 07:00	0.0	0	0	0	0	1
01/02/2022 08:00	0.0	0	0	0	0	1
01/02/2022 09:00	0.0	0	0	0	0	1
01/02/2022 10:00	0.0	0	0	0	0	1
01/02/2022 11:00	0.0	0	0	0	0	1
01/02/2022 12:00	0.0	0	0	0	0	1
01/02/2022 13:00	0.0	0	0	0	0	1
01/02/2022 14:00	0.0	0	0	0	0	1
01/02/2022 15:00	0.0	0	0	0	0	1
01/02/2022 16:00	0.0	0	0	0	0	1
01/02/2022 17:00	0.0	0	0	0	0	1
01/02/2022 18:00	0.0	0	0	0	0	1
01/02/2022 19:00	0.0	0	0	0	0	1
01/02/2022 20:00	0.0	0	0	0	0	1
01/02/2022 21:00	0.0	0	0	0	0	1
01/02/2022 22:00	0.0	0	0	0	0	1
01/02/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/03/2022 00:00	0.0	0	0	0	0	1
01/03/2022 01:00	0.0	0	0	0	0	1
01/03/2022 02:00	0.0	0	0	0	0	1
01/03/2022 03:00	0.0	0	0	0	0	1
01/03/2022 04:00	0.0	0	0	0	0	1
01/03/2022 05:00	0.0	0	0	0	0	1
01/03/2022 06:00	0.0	0	0	0	0	1
01/03/2022 07:00	0.0	0	0	0	0	1
01/03/2022 08:00	0.0	0	0	0	0	1
01/03/2022 09:00	0.0	0	0	0	0	1
01/03/2022 10:00	0.0	0	0	0	0	1
01/03/2022 11:00	0.0	0	0	0	0	1
01/03/2022 12:00	0.0	0	0	0	0	1
01/03/2022 13:00	0.0	0	0	0	0	1
01/03/2022 14:00	0.0	0	0	0	0	1
01/03/2022 15:00	0.0	0	0	0	0	1
01/03/2022 16:00	0.0	0	0	0	0	1
01/03/2022 17:00	0.0	0	0	0	0	1
01/03/2022 18:00	0.0	0	0	0	0	1
01/03/2022 19:00	0.0	0	0	0	0	1
01/03/2022 20:00	0.0	0	0	0	0	1
01/03/2022 21:00	0.0	0	0	0	0	1
01/03/2022 22:00	0.0	0	0	0	0	1
01/03/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/04/2022 00:00	0.0	0	0	0	0	1
01/04/2022 01:00	0.0	0	0	0	0	1
01/04/2022 02:00	0.0	0	0	0	0	1
01/04/2022 03:00	0.0	0	0	0	0	1
01/04/2022 04:00	0.0	0	0	0	0	1
01/04/2022 05:00	0.0	0	0	0	0	1
01/04/2022 06:00	0.0	0	0	0	0	1
01/04/2022 07:00	0.0	0	0	0	0	1
01/04/2022 08:00	0.0	0	0	0	0	1
01/04/2022 09:00	0.0	0	0	0	0	1
01/04/2022 10:00	0.0	0	0	0	0	1
01/04/2022 11:00	0.0	0	0	0	0	1
01/04/2022 12:00	0.0	0	0	0	0	1
01/04/2022 13:00	0.0	0	0	0	0	1
01/04/2022 14:00	0.0	0	0	0	0	1
01/04/2022 15:00	0.0	0	0	0	0	1
01/04/2022 16:00	0.0	0	0	0	0	1
01/04/2022 17:00	0.0	0	0	0	0	1
01/04/2022 18:00	0.0	0	0	0	0	1
01/04/2022 19:00	0.0	0	0	0	0	1
01/04/2022 20:00	0.0	0	0	0	0	1
01/04/2022 21:00	0.0	0	0	0	0	1
01/04/2022 22:00	0.0	0	0	0	0	1
01/04/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/05/2022 00:00	0.0	0	0	0	0	1
01/05/2022 01:00	0.0	0	0	0	0	1
01/05/2022 02:00	0.0	0	0	0	0	1
01/05/2022 03:00	0.0	0	0	0	0	1
01/05/2022 04:00	0.0	0	0	0	0	1
01/05/2022 05:00	0.0	0	0	0	0	1
01/05/2022 06:00	0.0	0	0	0	0	1
01/05/2022 07:00	0.0	0	0	0	0	1
01/05/2022 08:00	0.0	0	0	0	0	1
01/05/2022 09:00	0.0	0	0	0	0	1
01/05/2022 10:00	0.0	0	0	0	0	1
01/05/2022 11:00	0.0	0	0	0	0	1
01/05/2022 12:00	0.0	0	0	0	0	1
01/05/2022 13:00	0.0	0	0	0	0	1
01/05/2022 14:00	0.0	0	0	0	0	1
01/05/2022 15:00	0.0	0	0	0	0	1
01/05/2022 16:00	0.0	0	0	0	0	1
01/05/2022 17:00	0.0	0	0	0	0	1
01/05/2022 18:00	0.0	0	0	0	0	1
01/05/2022 19:00	0.0	0	0	0	0	1
01/05/2022 20:00	0.0	0	0	0	0	1
01/05/2022 21:00	0.0	0	0	0	0	1
01/05/2022 22:00	0.0	0	0	0	0	1
01/05/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/06/2022 00:00	0.0	0	0	0	0	1
01/06/2022 01:00	0.0	0	0	0	0	1
01/06/2022 02:00	0.0	0	0	0	0	1
01/06/2022 03:00	0.0	0	0	0	0	1
01/06/2022 04:00	0.0	0	0	0	0	1
01/06/2022 05:00	0.0	0	0	0	0	1
01/06/2022 06:00	0.0	0	0	0	0	1
01/06/2022 07:00	0.0	0	0	0	0	1
01/06/2022 08:00	0.0	0	0	0	0	1
01/06/2022 09:00	0.0	0	0	0	0	1
01/06/2022 10:00	0.0	0	0	0	0	1
01/06/2022 11:00	0.0	0	0	0	0	1
01/06/2022 12:00	0.0	0	0	0	0	1
01/06/2022 13:00	0.0	0	0	0	0	1
01/06/2022 14:00	0.0	0	0	0	0	1
01/06/2022 15:00	0.0	0	0	0	0	1
01/06/2022 16:00	0.0	0	0	0	0	1
01/06/2022 17:00	0.0	0	0	0	0	1
01/06/2022 18:00	0.0	0	0	0	0	1
01/06/2022 19:00	0.0	0	0	0	0	1
01/06/2022 20:00	0.0	0	0	0	0	1
01/06/2022 21:00	0.0	0	0	0	0	1
01/06/2022 22:00	0.0	0	0	0	0	1
01/06/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/07/2022 00:00	0.0	0	0	0	0	1
01/07/2022 01:00	0.0	0	0	0	0	1
01/07/2022 02:00	0.0	0	0	0	0	1
01/07/2022 03:00	0.0	0	0	0	0	1
01/07/2022 04:00	0.0	0	0	0	0	1
01/07/2022 05:00	0.0	0	0	0	0	1
01/07/2022 06:00	0.0	0	0	0	0	1
01/07/2022 07:00	0.0	0	0	0	0	1
01/07/2022 08:00	0.0	0	0	0	0	1
01/07/2022 09:00	0.0	0	0	0	0	1
01/07/2022 10:00	0.0	0	0	0	0	1
01/07/2022 11:00	0.0	0	0	0	0	1
01/07/2022 12:00	0.0	0	0	0	0	1
01/07/2022 13:00	0.0	0	0	0	0	1
01/07/2022 14:00	0.0	0	0	0	0	1
01/07/2022 15:00	0.0	0	0	0	0	1
01/07/2022 16:00	0.0	0	0	0	0	1
01/07/2022 17:00	0.0	0	0	0	0	1
01/07/2022 18:00	0.0	0	0	0	0	1
01/07/2022 19:00	0.0	0	0	0	0	1
01/07/2022 20:00	0.0	0	0	0	0	1
01/07/2022 21:00	0.0	0	0	0	0	1
01/07/2022 22:00	0.9	0	0	0	1	0
01/07/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.9 #	0 #	0 #	0 #	1 #	22 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.9	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/08/2022 00:00	0.0	0	0	0	0	0
01/08/2022 01:00	0.0	0	0	0	0	0
01/08/2022 02:00	0.0	0	0	0	0	0
01/08/2022 03:00	0.0	0	0	0	0	0
01/08/2022 04:00	0.0	0	0	0	0	0
01/08/2022 05:00	0.0	0	0	0	0	0
01/08/2022 06:00	0.0	0	0	0	0	0
01/08/2022 07:00	0.0	0	0	0	0	0
01/08/2022 08:00	0.0	0	0	0	0	0
01/08/2022 09:00	0.0	0	0	0	0	0
01/08/2022 10:00	29.9	0	1	0	0	0
01/08/2022 11:00	24.5	0	1	0	0	0
01/08/2022 12:00	21.6	0	1	0	0	0
01/08/2022 13:00	0.0	0	0	0	0	1
01/08/2022 14:00	0.0	0	0	0	0	1
01/08/2022 15:00	0.0	0	0	0	0	1
01/08/2022 16:00	0.0	0	0	0	0	1
01/08/2022 17:00	0.0	0	0	0	0	1
01/08/2022 18:00	0.0	0	0	0	0	1
01/08/2022 19:00	0.0	0	0	0	0	1
01/08/2022 20:00	0.0	0	0	0	0	1
01/08/2022 21:00	0.0	0	0	0	0	1
01/08/2022 22:00	0.0	0	0	0	0	1
01/08/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	76.0 #	0 #	3 #	0 #	0 #	11 #
Minimum:	0.0	0	0	0	0	0
Maximum:	29.9	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/09/2022 00:00	0.0	0	0	0	0	1
01/09/2022 01:00	0.0	0	0	0	0	1
01/09/2022 02:00	0.0	0	0	0	0	1
01/09/2022 03:00	0.0	0	0	0	0	1
01/09/2022 04:00	0.0	0	0	0	0	1
01/09/2022 05:00	0.0	0	0	0	0	1
01/09/2022 06:00	0.0	0	0	0	0	1
01/09/2022 07:00	0.0	0	0	0	0	1
01/09/2022 08:00	0.0	0	0	0	0	1
01/09/2022 09:00	0.0	0	0	0	0	1
01/09/2022 10:00	0.0	0	0	0	0	1
01/09/2022 11:00	0.0	0	0	0	0	1
01/09/2022 12:00	0.0	0	0	0	0	1
01/09/2022 13:00	0.0	0	0	0	0	1
01/09/2022 14:00	0.0	0	0	0	0	1
01/09/2022 15:00	0.0	0	0	0	0	1
01/09/2022 16:00	0.0	0	0	0	0	1
01/09/2022 17:00	0.0	0	0	0	0	1
01/09/2022 18:00	0.0	0	0	0	0	1
01/09/2022 19:00	0.0	0	0	0	0	1
01/09/2022 20:00	0.0	0	0	0	0	1
01/09/2022 21:00	0.0	0	0	0	0	1
01/09/2022 22:00	0.0	0	0	0	0	1
01/09/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/10/2022 00:00	0.0	0	0	0	0	1
01/10/2022 01:00	0.0	0	0	0	0	1
01/10/2022 02:00	0.0	0	0	0	0	1
01/10/2022 03:00	0.0	0	0	0	0	1
01/10/2022 04:00	0.0	0	0	0	0	1
01/10/2022 05:00	0.0	0	0	0	0	1
01/10/2022 06:00	0.0	0	0	0	0	1
01/10/2022 07:00	0.0	0	0	0	0	1
01/10/2022 08:00	0.0	0	0	0	0	1
01/10/2022 09:00	0.0	0	0	0	0	1
01/10/2022 10:00	0.0	0	0	0	0	1
01/10/2022 11:00	0.0	0	0	0	0	1
01/10/2022 12:00	0.0	0	0	0	0	1
01/10/2022 13:00	0.0	0	0	0	0	1
01/10/2022 14:00	0.0	0	0	0	0	1
01/10/2022 15:00	0.0	0	0	0	0	1
01/10/2022 16:00	0.0	0	0	0	0	1
01/10/2022 17:00	0.0	0	0	0	0	1
01/10/2022 18:00	0.0	0	0	0	0	1
01/10/2022 19:00	0.0	0	0	0	0	1
01/10/2022 20:00	0.0	0	0	0	0	1
01/10/2022 21:00	0.0	0	0	0	0	1
01/10/2022 22:00	0.0	0	0	0	0	1
01/10/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/11/2022 00:00	0.0	0	0	0	0	1
01/11/2022 01:00	0.0	0	0	0	0	1
01/11/2022 02:00	0.0	0	0	0	0	1
01/11/2022 03:00	0.0	0	0	0	0	1
01/11/2022 04:00	0.0	0	0	0	0	1
01/11/2022 05:00	0.0	0	0	0	0	1
01/11/2022 06:00	0.0	0	0	0	0	1
01/11/2022 07:00	0.0	0	0	0	0	1
01/11/2022 08:00	0.0	0	0	0	0	1
01/11/2022 09:00	0.0	0	0	0	0	1
01/11/2022 10:00	0.0	0	0	0	0	1
01/11/2022 11:00	0.0	0	0	0	0	1
01/11/2022 12:00	0.0	0	0	0	0	1
01/11/2022 13:00	0.0	0	0	0	0	1
01/11/2022 14:00	0.0	0	0	0	0	1
01/11/2022 15:00	0.0	0	0	0	0	1
01/11/2022 16:00	0.0	0	0	0	0	1
01/11/2022 17:00	0.0	0	0	0	0	1
01/11/2022 18:00	0.0	0	0	0	0	1
01/11/2022 19:00	0.0	0	0	0	0	1
01/11/2022 20:00	0.0	0	0	0	0	1
01/11/2022 21:00	0.0	0	0	0	0	1
01/11/2022 22:00	0.0	0	0	0	0	1
01/11/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/12/2022 00:00	0.0	0	0	0	0	1
01/12/2022 01:00	0.0	0	0	0	0	1
01/12/2022 02:00	0.0	0	0	0	0	1
01/12/2022 03:00	0.0	0	0	0	0	1
01/12/2022 04:00	0.0	0	0	0	0	1
01/12/2022 05:00	0.0	0	0	0	0	1
01/12/2022 06:00	0.0	0	0	0	0	1
01/12/2022 07:00	0.0	0	0	0	0	1
01/12/2022 08:00	0.0	0	0	0	0	1
01/12/2022 09:00	0.0	0	0	0	0	1
01/12/2022 10:00	0.0	0	0	0	0	1
01/12/2022 11:00	0.0	0	0	0	0	1
01/12/2022 12:00	0.0	0	0	0	0	1
01/12/2022 13:00	0.0	0	0	0	0	1
01/12/2022 14:00	0.0	0	0	0	0	1
01/12/2022 15:00	0.0	0	0	0	0	1
01/12/2022 16:00	0.0	0	0	0	0	1
01/12/2022 17:00	0.0	0	0	0	0	1
01/12/2022 18:00	0.0	0	0	0	0	1
01/12/2022 19:00	0.0	0	0	0	0	1
01/12/2022 20:00	0.0	0	0	0	0	1
01/12/2022 21:00	0.0	0	0	0	0	1
01/12/2022 22:00	0.0	0	0	0	0	1
01/12/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/13/2022 00:00	0.0	0	0	0	0	1
01/13/2022 01:00	0.0	0	0	0	0	1
01/13/2022 02:00	0.0	0	0	0	0	1
01/13/2022 03:00	0.0	0	0	0	0	1
01/13/2022 04:00	0.0	0	0	0	0	1
01/13/2022 05:00	0.0	0	0	0	0	1
01/13/2022 06:00	0.0	0	0	0	0	1
01/13/2022 07:00	0.0	0	0	0	0	1
01/13/2022 08:00	0.0	0	0	0	0	1
01/13/2022 09:00	0.0	0	0	0	0	1
01/13/2022 10:00	0.0	0	0	0	0	1
01/13/2022 11:00	0.0	0	0	0	0	1
01/13/2022 12:00	0.0	0	0	0	0	1
01/13/2022 13:00	0.0	0	0	0	0	1
01/13/2022 14:00	0.0	0	0	0	0	1
01/13/2022 15:00	0.0	0	0	0	0	1
01/13/2022 16:00	0.0	0	0	0	0	1
01/13/2022 17:00	0.0	0	0	0	0	1
01/13/2022 18:00	0.0	0	0	0	0	1
01/13/2022 19:00	0.0	0	0	0	0	1
01/13/2022 20:00	0.0	0	0	0	0	1
01/13/2022 21:00	0.0	0	0	0	0	1
01/13/2022 22:00	0.0	0	0	0	0	1
01/13/2022 23:00	1.1	0	0	0	1	0
Average/Sum#:	1.1 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.1	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/14/2022 00:00	0.0	0	0	0	0	0
01/14/2022 01:00	0.0	0	0	0	0	0
01/14/2022 02:00	0.0	0	0	0	0	0
01/14/2022 03:00	0.0	0	0	0	0	0
01/14/2022 04:00	1.3	0	0	1	0	0
01/14/2022 05:00	27.2	0	0	1	0	0
01/14/2022 06:00	0.0	0	0	0	0	1
01/14/2022 07:00	0.0	0	0	0	0	1
01/14/2022 08:00	0.0	0	0	0	0	1
01/14/2022 09:00	0.0	0	0	0	0	1
01/14/2022 10:00	0.0	0	0	0	0	1
01/14/2022 11:00	0.0	0	0	0	0	1
01/14/2022 12:00	0.0	0	0	0	0	1
01/14/2022 13:00	0.0	0	0	0	0	1
01/14/2022 14:00	0.0	0	0	0	0	1
01/14/2022 15:00	0.0	0	0	0	0	1
01/14/2022 16:00	0.0	0	0	0	0	1
01/14/2022 17:00	0.0	0	0	0	0	1
01/14/2022 18:00	0.0	0	0	0	0	1
01/14/2022 19:00	0.0	0	0	0	0	1
01/14/2022 20:00	0.0	0	0	0	0	1
01/14/2022 21:00	0.0	0	0	0	0	1
01/14/2022 22:00	0.0	0	0	0	0	1
01/14/2022 23:00	0.9	0	0	0	1	0
Average/Sum#:	29.4 #	0 #	0 #	2 #	1 #	17 #
Minimum:	0.0	0	0	0	0	0
Maximum:	27.2	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/15/2022 00:00	0.0	0	0	0	0	0
01/15/2022 01:00	0.0	0	0	0	0	0
01/15/2022 02:00	0.0	0	0	0	0	0
01/15/2022 03:00	0.0	0	0	0	0	0
01/15/2022 04:00	0.6	0	0	1	0	0
01/15/2022 05:00	28.3	0	0	1	0	0
01/15/2022 06:00	0.0	0	0	0	0	1
01/15/2022 07:00	0.0	0	0	0	0	1
01/15/2022 08:00	0.0	0	0	0	0	1
01/15/2022 09:00	0.0	0	0	0	0	1
01/15/2022 10:00	0.0	0	0	0	0	1
01/15/2022 11:00	0.0	0	0	0	0	1
01/15/2022 12:00	0.0	0	0	0	0	1
01/15/2022 13:00	0.0	0	0	0	0	1
01/15/2022 14:00	0.0	0	0	0	0	1
01/15/2022 15:00	0.0	0	0	0	0	1
01/15/2022 16:00	0.0	0	0	0	0	1
01/15/2022 17:00	0.0	0	0	0	0	1
01/15/2022 18:00	0.0	0	0	0	0	1
01/15/2022 19:00	0.0	0	0	0	0	1
01/15/2022 20:00	0.0	0	0	0	0	1
01/15/2022 21:00	0.0	0	0	0	0	1
01/15/2022 22:00	0.0	0	0	0	0	1
01/15/2022 23:00	0.6	0	0	0	1	0
Average/Sum#:	29.5 #	0 #	0 #	2 #	1 #	17 #
Minimum:	0.0	0	0	0	0	0
Maximum:	28.3	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/16/2022 00:00	0.0	0	0	0	0	0
01/16/2022 01:00	0.0	0	0	0	0	0
01/16/2022 02:00	0.0	0	0	0	0	0
01/16/2022 03:00	0.0	0	0	0	0	0
01/16/2022 04:00	0.0	0	0	0	0	0
01/16/2022 05:00	0.0	0	0	0	0	0
01/16/2022 06:00	0.0	0	0	0	0	0
01/16/2022 07:00	0.0	0	0	0	0	0
01/16/2022 08:00	0.0	0	0	0	0	0
01/16/2022 09:00	0.0	0	0	0	0	0
01/16/2022 10:00	0.0	0	0	0	0	0
01/16/2022 11:00	48.8	0	1	0	0	0
01/16/2022 12:00	28.0	0	1	0	0	0
01/16/2022 13:00	0.0	0	0	0	0	1
01/16/2022 14:00	0.0	0	0	0	0	1
01/16/2022 15:00	0.0	0	0	0	0	1
01/16/2022 16:00	0.0	0	0	0	0	1
01/16/2022 17:00	0.0	0	0	0	0	1
01/16/2022 18:00	0.0	0	0	0	0	1
01/16/2022 19:00	0.0	0	0	0	0	1
01/16/2022 20:00	0.0	0	0	0	0	1
01/16/2022 21:00	0.0	0	0	0	0	1
01/16/2022 22:00	0.0	0	0	0	0	1
01/16/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	76.8 #	0 #	2 #	0 #	0 #	11 #
Minimum:	0.0	0	0	0	0	0
Maximum:	48.8	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/17/2022 00:00	0.0	0	0	0	0	1
01/17/2022 01:00	0.0	0	0	0	0	1
01/17/2022 02:00	0.0	0	0	0	0	1
01/17/2022 03:00	0.0	0	0	0	0	1
01/17/2022 04:00	0.0	0	0	0	0	1
01/17/2022 05:00	0.0	0	0	0	0	1
01/17/2022 06:00	0.0	0	0	0	0	1
01/17/2022 07:00	0.0	0	0	0	0	1
01/17/2022 08:00	0.0	0	0	0	0	1
01/17/2022 09:00	0.0	0	0	0	0	1
01/17/2022 10:00	0.0	0	0	0	0	1
01/17/2022 11:00	0.0	0	0	0	0	1
01/17/2022 12:00	0.0	0	0	0	0	1
01/17/2022 13:00	0.0	0	0	0	0	1
01/17/2022 14:00	0.0	0	0	0	0	1
01/17/2022 15:00	0.0	0	0	0	0	1
01/17/2022 16:00	0.0	0	0	0	0	1
01/17/2022 17:00	0.0	0	0	0	0	1
01/17/2022 18:00	0.0	0	0	0	0	1
01/17/2022 19:00	0.0	0	0	0	0	1
01/17/2022 20:00	0.0	0	0	0	0	1
01/17/2022 21:00	0.0	0	0	0	0	1
01/17/2022 22:00	0.0	0	0	0	0	1
01/17/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/18/2022 00:00	0.0	0	0	0	0	1
01/18/2022 01:00	0.0	0	0	0	0	1
01/18/2022 02:00	0.0	0	0	0	0	1
01/18/2022 03:00	0.0	0	0	0	0	1
01/18/2022 04:00	0.0	0	0	0	0	1
01/18/2022 05:00	0.0	0	0	0	0	1
01/18/2022 06:00	0.0	0	0	0	0	1
01/18/2022 07:00	0.0	0	0	0	0	1
01/18/2022 08:00	0.0	0	0	0	0	1
01/18/2022 09:00	0.0	0	0	0	0	1
01/18/2022 10:00	0.0	0	0	0	0	1
01/18/2022 11:00	0.0	0	0	0	0	1
01/18/2022 12:00	0.0	0	0	0	0	1
01/18/2022 13:00	0.0	0	0	0	0	1
01/18/2022 14:00	0.0	0	0	0	0	1
01/18/2022 15:00	0.0	0	0	0	0	1
01/18/2022 16:00	0.0	0	0	0	0	1
01/18/2022 17:00	0.0	0	0	0	0	1
01/18/2022 18:00	0.0	0	0	0	0	1
01/18/2022 19:00	0.0	0	0	0	0	1
01/18/2022 20:00	0.0	0	0	0	0	1
01/18/2022 21:00	0.0	0	0	0	0	1
01/18/2022 22:00	0.0	0	0	0	0	1
01/18/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/19/2022 00:00	0.0	0	0	0	0	1
01/19/2022 01:00	0.0	0	0	0	0	1
01/19/2022 02:00	0.0	0	0	0	0	1
01/19/2022 03:00	0.0	0	0	0	0	1
01/19/2022 04:00	0.0	0	0	0	0	1
01/19/2022 05:00	0.0	0	0	0	0	1
01/19/2022 06:00	0.0	0	0	0	0	1
01/19/2022 07:00	0.0	0	0	0	0	1
01/19/2022 08:00	0.0	0	0	0	0	1
01/19/2022 09:00	0.0	0	0	0	0	1
01/19/2022 10:00	0.0	0	0	0	0	1
01/19/2022 11:00	0.0	0	0	0	0	1
01/19/2022 12:00	0.0	0	0	0	0	1
01/19/2022 13:00	0.0	0	0	0	0	1
01/19/2022 14:00	0.0	0	0	0	0	1
01/19/2022 15:00	0.0	0	0	0	0	1
01/19/2022 16:00	0.0	0	0	0	0	1
01/19/2022 17:00	0.0	0	0	0	0	1
01/19/2022 18:00	0.0	0	0	0	0	1
01/19/2022 19:00	0.0	0	0	0	0	1
01/19/2022 20:00	0.0	0	0	0	0	1
01/19/2022 21:00	0.0	0	0	0	0	1
01/19/2022 22:00	0.0	0	0	0	0	1
01/19/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/20/2022 00:00	0.0	0	0	0	0	1
01/20/2022 01:00	0.0	0	0	0	0	1
01/20/2022 02:00	0.0	0	0	0	0	1
01/20/2022 03:00	0.0	0	0	0	0	1
01/20/2022 04:00	0.0	0	0	0	0	1
01/20/2022 05:00	0.0	0	0	0	0	1
01/20/2022 06:00	0.0	0	0	0	0	1
01/20/2022 07:00	0.0	0	0	0	0	1
01/20/2022 08:00	0.0	0	0	0	0	1
01/20/2022 09:00	0.0	0	0	0	0	1
01/20/2022 10:00	0.0	0	0	0	0	1
01/20/2022 11:00	0.0	0	0	0	0	1
01/20/2022 12:00	0.0	0	0	0	0	1
01/20/2022 13:00	0.0	0	0	0	0	1
01/20/2022 14:00	0.0	0	0	0	0	1
01/20/2022 15:00	0.0	0	0	0	0	1
01/20/2022 16:00	0.0	0	0	0	0	1
01/20/2022 17:00	0.0	0	0	0	0	1
01/20/2022 18:00	0.0	0	0	0	0	1
01/20/2022 19:00	0.0	0	0	0	0	1
01/20/2022 20:00	0.0	0	0	0	0	1
01/20/2022 21:00	0.0	0	0	0	0	1
01/20/2022 22:00	0.0	0	0	0	0	1
01/20/2022 23:00	0.8	0	0	0	1	0
Average/Sum#:	0.8 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.8	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/21/2022 00:00	0.0	0	0	0	0	0
01/21/2022 01:00	0.0	0	0	0	0	0
01/21/2022 02:00	0.0	0	0	0	0	0
01/21/2022 03:00	0.0	0	0	0	0	0
01/21/2022 04:00	0.0	0	0	0	0	0
01/21/2022 05:00	0.0	0	0	0	0	0
01/21/2022 06:00	0.0	0	0	0	0	0
01/21/2022 07:00	0.0	0	0	0	0	0
01/21/2022 08:00	0.0	0	0	0	0	0
01/21/2022 09:00	0.0	0	0	0	0	0
01/21/2022 10:00	0.0	0	0	0	0	0
01/21/2022 11:00	0.0	0	0	0	0	0
01/21/2022 12:00	0.0	0	0	0	0	0
01/21/2022 13:00	0.0	0	0	0	0	0
01/21/2022 14:00	0.0	0	0	0	0	0
01/21/2022 15:00	0.0	0	0	0	0	0
01/21/2022 16:00	0.0	0	0	0	0	0
01/21/2022 17:00	0.0	0	0	0	0	0
01/21/2022 18:00	0.0	0	0	0	0	0
01/21/2022 19:00	0.0	0	0	0	0	0
01/21/2022 20:00	0.0	0	0	0	0	0
01/21/2022 21:00	0.0	0	0	0	0	0
01/21/2022 22:00	0.0	0	0	0	0	0
01/21/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/22/2022 00:00	0.0	0	0	0	0	0
01/22/2022 01:00	0.0	0	0	0	0	0
01/22/2022 02:00	0.0	0	0	0	0	0
01/22/2022 03:00	0.0	0	0	0	0	0
01/22/2022 04:00	0.0	0	0	0	0	0
01/22/2022 05:00	0.0	0	0	0	0	0
01/22/2022 06:00	0.0	0	0	0	0	0
01/22/2022 07:00	0.0	0	0	0	0	0
01/22/2022 08:00	0.0	0	0	0	0	0
01/22/2022 09:00	0.0	0	0	0	0	0
01/22/2022 10:00	0.0	0	0	0	0	0
01/22/2022 11:00	0.0	0	0	0	0	0
01/22/2022 12:00	0.0	0	0	0	0	0
01/22/2022 13:00	0.0	0	0	0	0	0
01/22/2022 14:00	0.0	0	0	0	0	0
01/22/2022 15:00	0.0	0	0	0	0	0
01/22/2022 16:00	0.0	0	0	0	0	0
01/22/2022 17:00	0.0	0	0	0	0	0
01/22/2022 18:00	0.0	0	0	0	0	0
01/22/2022 19:00	0.0	0	0	0	0	0
01/22/2022 20:00	0.0	0	0	0	0	0
01/22/2022 21:00	0.0	0	0	0	0	0
01/22/2022 22:00	0.0	0	0	0	0	0
01/22/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/23/2022 00:00	0.0	0	0	0	0	0
01/23/2022 01:00	0.0	0	0	0	0	0
01/23/2022 02:00	0.0	0	0	0	0	0
01/23/2022 03:00	0.0	0	0	0	0	0
01/23/2022 04:00	0.0	0	0	0	0	0
01/23/2022 05:00	0.0	0	0	0	0	0
01/23/2022 06:00	0.0	0	0	0	0	0
01/23/2022 07:00	0.0	0	0	0	0	0
01/23/2022 08:00	0.0	0	0	0	0	0
01/23/2022 09:00	0.0	0	0	0	0	0
01/23/2022 10:00	0.0	0	0	0	0	0
01/23/2022 11:00	55.3	0	1	0	0	0
01/23/2022 12:00	33.4	0	1	0	0	0
01/23/2022 13:00	50.5	0	1	0	0	0
01/23/2022 14:00	0.0	0	0	0	0	1
01/23/2022 15:00	0.0	0	0	0	0	1
01/23/2022 16:00	0.0	0	0	0	0	1
01/23/2022 17:00	0.0	0	0	0	0	1
01/23/2022 18:00	0.0	0	0	0	0	1
01/23/2022 19:00	0.0	0	0	0	0	1
01/23/2022 20:00	0.0	0	0	0	0	1
01/23/2022 21:00	0.0	0	0	0	0	1
01/23/2022 22:00	0.0	0	0	0	0	1
01/23/2022 23:00	0.9	0	0	0	1	0
Average/Sum#:	140.1 #	0 #	3 #	0 #	1 #	9 #
Minimum:	0.0	0	0	0	0	0
Maximum:	55.3	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/24/2022 00:00	0.0	0	0	0	0	0
01/24/2022 01:00	0.0	0	0	0	0	0
01/24/2022 02:00	0.0	0	0	0	0	0
01/24/2022 03:00	0.2	0	0	1	0	0
01/24/2022 04:00	23.6	0	0	1	0	0
01/24/2022 05:00	0.0	0	0	0	0	1
01/24/2022 06:00	0.0	0	0	0	0	1
01/24/2022 07:00	0.0	0	0	0	0	1
01/24/2022 08:00	0.0	0	0	0	0	1
01/24/2022 09:00	0.0	0	0	0	0	1
01/24/2022 10:00	0.0	0	0	0	0	1
01/24/2022 11:00	0.0	0	0	0	0	1
01/24/2022 12:00	0.0	0	0	0	0	1
01/24/2022 13:00	0.0	0	0	0	0	1
01/24/2022 14:00	0.0	0	0	0	0	1
01/24/2022 15:00	0.0	0	0	0	0	1
01/24/2022 16:00	0.0	0	0	0	0	1
01/24/2022 17:00	0.0	0	0	0	0	1
01/24/2022 18:00	0.0	0	0	0	0	1
01/24/2022 19:00	0.0	0	0	0	0	1
01/24/2022 20:00	0.0	0	0	0	0	1
01/24/2022 21:00	0.0	0	0	0	0	1
01/24/2022 22:00	0.0	0	0	0	0	1
01/24/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	23.8 #	0 #	0 #	2 #	0 #	19 #
Minimum:	0.0	0	0	0	0	0
Maximum:	23.6	0	0	1	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/25/2022 00:00	0.0	0	0	0	0	1
01/25/2022 01:00	0.0	0	0	0	0	1
01/25/2022 02:00	0.0	0	0	0	0	1
01/25/2022 03:00	0.0	0	0	0	0	1
01/25/2022 04:00	0.0	0	0	0	0	1
01/25/2022 05:00	0.0	0	0	0	0	1
01/25/2022 06:00	0.0	0	0	0	0	1
01/25/2022 07:00	0.0	0	0	0	0	1
01/25/2022 08:00	0.9	0	0	0	1	0
01/25/2022 09:00	0.0	0	0	0	0	0
01/25/2022 10:00	0.0	0	0	0	0	0
01/25/2022 11:00	0.0	0	0	0	0	0
01/25/2022 12:00	0.0	0	0	0	0	0
01/25/2022 13:00	0.0	0	0	0	0	0
01/25/2022 14:00	0.0	0	0	0	0	0
01/25/2022 15:00	13.6	0	0	1	0	0
01/25/2022 16:00	27.7	0	0	1	0	0
01/25/2022 17:00	0.0	0	0	0	0	1
01/25/2022 18:00	0.0	0	0	0	0	1
01/25/2022 19:00	0.0	0	0	0	0	1
01/25/2022 20:00	0.0	0	0	0	0	1
01/25/2022 21:00	0.0	0	0	0	0	1
01/25/2022 22:00	0.0	0	0	0	0	1
01/25/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	42.2 #	0 #	0 #	2 #	1 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	27.7	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/26/2022 00:00	0.0	0	0	0	0	1
01/26/2022 01:00	0.0	0	0	0	0	1
01/26/2022 02:00	0.0	0	0	0	0	1
01/26/2022 03:00	0.0	0	0	0	0	1
01/26/2022 04:00	0.0	0	0	0	0	1
01/26/2022 05:00	0.0	0	0	0	0	1
01/26/2022 06:00	0.0	0	0	0	0	1
01/26/2022 07:00	0.0	0	0	0	0	1
01/26/2022 08:00	1.0	0	0	0	1	0
01/26/2022 09:00	0.0	0	0	0	0	0
01/26/2022 10:00	0.0	0	0	0	0	0
01/26/2022 11:00	0.0	0	0	0	0	0
01/26/2022 12:00	0.0	0	0	0	0	0
01/26/2022 13:00	0.0	0	0	0	0	0
01/26/2022 14:00	0.0	0	0	0	0	0
01/26/2022 15:00	8.3	0	0	1	0	0
01/26/2022 16:00	23.8	0	0	1	0	0
01/26/2022 17:00	0.0	0	0	0	0	1
01/26/2022 18:00	0.0	0	0	0	0	1
01/26/2022 19:00	0.0	0	0	0	0	1
01/26/2022 20:00	0.0	0	0	0	0	1
01/26/2022 21:00	0.0	0	0	0	0	1
01/26/2022 22:00	0.0	0	0	0	0	1
01/26/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	33.1 #	0 #	0 #	2 #	1 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	23.8	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/27/2022 00:00	0.0	0	0	0	0	1
01/27/2022 01:00	0.0	0	0	0	0	1
01/27/2022 02:00	0.0	0	0	0	0	1
01/27/2022 03:00	0.0	0	0	0	0	1
01/27/2022 04:00	0.0	0	0	0	0	1
01/27/2022 05:00	0.0	0	0	0	0	1
01/27/2022 06:00	0.0	0	0	0	0	1
01/27/2022 07:00	0.0	0	0	0	0	1
01/27/2022 08:00	0.0	0	0	0	0	1
01/27/2022 09:00	0.0	0	0	0	0	1
01/27/2022 10:00	0.9	0	0	0	1	0
01/27/2022 11:00	0.0	0	0	0	0	0
01/27/2022 12:00	0.0	0	0	0	0	0
01/27/2022 13:00	0.0	0	0	0	0	0
01/27/2022 14:00	0.0	0	0	0	0	0
01/27/2022 15:00	7.1	0	0	1	0	0
01/27/2022 16:00	22.2	0	0	1	0	0
01/27/2022 17:00	0.0	0	0	0	0	1
01/27/2022 18:00	0.0	0	0	0	0	1
01/27/2022 19:00	0.0	0	0	0	0	1
01/27/2022 20:00	0.0	0	0	0	0	1
01/27/2022 21:00	0.0	0	0	0	0	1
01/27/2022 22:00	0.0	0	0	0	0	1
01/27/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	30.2 #	0 #	0 #	2 #	1 #	17 #
Minimum:	0.0	0	0	0	0	0
Maximum:	22.2	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/28/2022 00:00	0.0	0	0	0	0	1
01/28/2022 01:00	0.0	0	0	0	0	1
01/28/2022 02:00	0.0	0	0	0	0	1
01/28/2022 03:00	0.0	0	0	0	0	1
01/28/2022 04:00	0.0	0	0	0	0	1
01/28/2022 05:00	0.0	0	0	0	0	1
01/28/2022 06:00	0.0	0	0	0	0	1
01/28/2022 07:00	0.0	0	0	0	0	1
01/28/2022 08:00	0.0	0	0	0	0	1
01/28/2022 09:00	0.0	0	0	0	0	1
01/28/2022 10:00	0.0	0	0	0	0	1
01/28/2022 11:00	0.0	0	0	0	0	1
01/28/2022 12:00	0.0	0	0	0	0	1
01/28/2022 13:00	0.0	0	0	0	0	1
01/28/2022 14:00	0.0	0	0	0	0	1
01/28/2022 15:00	0.0	0	0	0	0	1
01/28/2022 16:00	0.0	0	0	0	0	1
01/28/2022 17:00	0.0	0	0	0	0	1
01/28/2022 18:00	0.0	0	0	0	0	1
01/28/2022 19:00	0.0	0	0	0	0	1
01/28/2022 20:00	0.0	0	0	0	0	1
01/28/2022 21:00	0.0	0	0	0	0	1
01/28/2022 22:00	0.0	0	0	0	0	1
01/28/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/29/2022 00:00	0.0	0	0	0	0	1
01/29/2022 01:00	0.0	0	0	0	0	1
01/29/2022 02:00	0.0	0	0	0	0	1
01/29/2022 03:00	0.0	0	0	0	0	1
01/29/2022 04:00	0.0	0	0	0	0	1
01/29/2022 05:00	0.0	0	0	0	0	1
01/29/2022 06:00	0.0	0	0	0	0	1
01/29/2022 07:00	0.0	0	0	0	0	1
01/29/2022 08:00	0.0	0	0	0	0	1
01/29/2022 09:00	0.0	0	0	0	0	1
01/29/2022 10:00	0.0	0	0	0	0	1
01/29/2022 11:00	0.0	0	0	0	0	1
01/29/2022 12:00	0.0	0	0	0	0	1
01/29/2022 13:00	0.0	0	0	0	0	1
01/29/2022 14:00	0.0	0	0	0	0	1
01/29/2022 15:00	0.0	0	0	0	0	1
01/29/2022 16:00	0.0	0	0	0	0	1
01/29/2022 17:00	0.0	0	0	0	0	1
01/29/2022 18:00	0.0	0	0	0	0	1
01/29/2022 19:00	0.0	0	0	0	0	1
01/29/2022 20:00	0.0	0	0	0	0	1
01/29/2022 21:00	0.0	0	0	0	0	1
01/29/2022 22:00	0.0	0	0	0	0	1
01/29/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/30/2022 00:00	0.0	0	0	0	0	1
01/30/2022 01:00	0.0	0	0	0	0	1
01/30/2022 02:00	0.0	0	0	0	0	1
01/30/2022 03:00	0.0	0	0	0	0	1
01/30/2022 04:00	0.0	0	0	0	0	1
01/30/2022 05:00	0.0	0	0	0	0	1
01/30/2022 06:00	0.0	0	0	0	0	1
01/30/2022 07:00	0.8	0	0	0	1	0
01/30/2022 08:00	0.0	0	0	0	0	0
01/30/2022 09:00	0.0	0	0	0	0	0
01/30/2022 10:00	0.0	0	0	0	0	0
01/30/2022 11:00	0.0	0	0	0	0	0
01/30/2022 12:00	0.0	0	0	0	0	0
01/30/2022 13:00	0.0	0	0	0	0	0
01/30/2022 14:00	0.0	0	0	0	0	0
01/30/2022 15:00	0.0	0	0	0	0	0
01/30/2022 16:00	0.0	0	0	0	0	0
01/30/2022 17:00	0.0	0	0	0	0	0
01/30/2022 18:00	0.0	0	0	0	0	0
01/30/2022 19:00	0.0	0	0	0	0	0
01/30/2022 20:00	0.0	0	0	0	0	0
01/30/2022 21:00	0.0	0	0	0	0	0
01/30/2022 22:00	0.0	0	0	0	0	0
01/30/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.8 #	0 #	0 #	0 #	1 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.8	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/31/2022 00:00	0.0	0	0	0	0	0
01/31/2022 01:00	0.0	0	0	0	0	0
01/31/2022 02:00	51.6	0	1	0	0	0
01/31/2022 03:00	33.8	0	1	0	0	0
01/31/2022 04:00	0.0	0	0	0	0	1
01/31/2022 05:00	0.0	0	0	0	0	1
01/31/2022 06:00	0.0	0	0	0	0	1
01/31/2022 07:00	0.0	0	0	0	0	1
01/31/2022 08:00	0.0	0	0	0	0	1
01/31/2022 09:00	0.0	0	0	0	0	1
01/31/2022 10:00	0.0	0	0	0	0	1
01/31/2022 11:00	0.0	0	0	0	0	1
01/31/2022 12:00	0.0	0	0	0	0	1
01/31/2022 13:00	0.0	0	0	0	0	1
01/31/2022 14:00	0.0	0	0	0	0	1
01/31/2022 15:00	0.0	0	0	0	0	1
01/31/2022 16:00	0.0	0	0	0	0	1
01/31/2022 17:00	0.0	0	0	0	0	1
01/31/2022 18:00	0.0	0	0	0	0	1
01/31/2022 19:00	0.0	0	0	0	0	1
01/31/2022 20:00	0.0	0	0	0	0	1
01/31/2022 21:00	0.0	0	0	0	0	1
01/31/2022 22:00	0.0	0	0	0	0	1
01/31/2022 23:00	0.9	0	0	0	1	0
Average/Sum#:	86.3 #	0 #	2 #	0 #	1 #	19 #
Minimum:	0.0	0	0	0	0	0
Maximum:	51.6	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/01/2022 00:00	0.0	0	0	0	0	0
02/01/2022 01:00	0.0	0	0	0	0	0
02/01/2022 02:00	0.0	0	0	0	0	0
02/01/2022 03:00	0.0	0	0	0	0	0
02/01/2022 04:00	0.0	0	0	0	0	0
02/01/2022 05:00	28.7	0	0	1	0	0
02/01/2022 06:00	17.4	0	0	1	0	0
02/01/2022 07:00	0.0	0	0	0	0	1
02/01/2022 08:00	0.0	0	0	0	0	1
02/01/2022 09:00	0.0	0	0	0	0	1
02/01/2022 10:00	0.0	0	0	0	0	1
02/01/2022 11:00	0.0	0	0	0	0	1
02/01/2022 12:00	0.0	0	0	0	0	1
02/01/2022 13:00	0.0	0	0	0	0	1
02/01/2022 14:00	0.0	0	0	0	0	1
02/01/2022 15:00	0.0	0	0	0	0	1
02/01/2022 16:00	0.0	0	0	0	0	1
02/01/2022 17:00	0.0	0	0	0	0	1
02/01/2022 18:00	0.0	0	0	0	0	1
02/01/2022 19:00	0.0	0	0	0	0	1
02/01/2022 20:00	0.0	0	0	0	0	1
02/01/2022 21:00	0.0	0	0	0	0	1
02/01/2022 22:00	0.0	0	0	0	0	1
02/01/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	46.1 #	0 #	0 #	2 #	0 #	17 #
Minimum:	0.0	0	0	0	0	0
Maximum:	28.7	0	0	1	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/02/2022 00:00	0.0	0	0	0	0	1
02/02/2022 01:00	0.0	0	0	0	0	1
02/02/2022 02:00	0.0	0	0	0	0	1
02/02/2022 03:00	0.0	0	0	0	0	1
02/02/2022 04:00	0.0	0	0	0	0	1
02/02/2022 05:00	0.0	0	0	0	0	1
02/02/2022 06:00	0.0	0	0	0	0	1
02/02/2022 07:00	0.0	0	0	0	0	1
02/02/2022 08:00	0.0	0	0	0	0	1
02/02/2022 09:00	0.0	0	0	0	0	1
02/02/2022 10:00	0.9	0	0	0	1	0
02/02/2022 11:00	0.0	0	0	0	0	0
02/02/2022 12:00	0.0	0	0	0	0	0
02/02/2022 13:00	0.0	0	0	0	0	0
02/02/2022 14:00	0.0	0	0	0	0	0
02/02/2022 15:00	0.7	0	0	1	0	0
02/02/2022 16:00	48.1	0	0	1	0	0
02/02/2022 17:00	0.4	0	0	1	0	0
02/02/2022 18:00	0.0	0	0	0	0	1
02/02/2022 19:00	0.0	0	0	0	0	1
02/02/2022 20:00	0.0	0	0	0	0	1
02/02/2022 21:00	0.0	0	0	0	0	1
02/02/2022 22:00	0.0	0	0	0	0	1
02/02/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	50.1 #	0 #	0 #	3 #	1 #	16 #
Minimum:	0.0	0	0	0	0	0
Maximum:	48.1	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/03/2022 00:00	0.0	0	0	0	0	1
02/03/2022 01:00	0.0	0	0	0	0	1
02/03/2022 02:00	0.0	0	0	0	0	1
02/03/2022 03:00	0.0	0	0	0	0	1
02/03/2022 04:00	0.0	0	0	0	0	1
02/03/2022 05:00	0.0	0	0	0	0	1
02/03/2022 06:00	0.0	0	0	0	0	1
02/03/2022 07:00	0.0	0	0	0	0	1
02/03/2022 08:00	0.0	0	0	0	0	1
02/03/2022 09:00	0.0	0	0	0	0	1
02/03/2022 10:00	0.0	0	0	0	0	1
02/03/2022 11:00	0.0	0	0	0	0	1
02/03/2022 12:00	0.0	0	0	0	0	1
02/03/2022 13:00	0.0	0	0	0	0	1
02/03/2022 14:00	0.0	0	0	0	0	1
02/03/2022 15:00	0.0	0	0	0	0	1
02/03/2022 16:00	0.0	0	0	0	0	1
02/03/2022 17:00	0.0	0	0	0	0	1
02/03/2022 18:00	0.0	0	0	0	0	1
02/03/2022 19:00	0.0	0	0	0	0	1
02/03/2022 20:00	0.0	0	0	0	0	1
02/03/2022 21:00	0.0	0	0	0	0	1
02/03/2022 22:00	0.0	0	0	0	0	1
02/03/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/04/2022 00:00	0.0	0	0	0	0	1
02/04/2022 01:00	0.0	0	0	0	0	1
02/04/2022 02:00	0.0	0	0	0	0	1
02/04/2022 03:00	0.0	0	0	0	0	1
02/04/2022 04:00	0.0	0	0	0	0	1
02/04/2022 05:00	0.0	0	0	0	0	1
02/04/2022 06:00	0.0	0	0	0	0	1
02/04/2022 07:00	0.0	0	0	0	0	1
02/04/2022 08:00	1.1	0	0	0	1	0
02/04/2022 09:00	0.0	0	0	0	0	0
02/04/2022 10:00	0.0	0	0	0	0	0
02/04/2022 11:00	0.0	0	0	0	0	0
02/04/2022 12:00	0.0	0	0	0	0	0
02/04/2022 13:00	0.0	0	0	0	0	0
02/04/2022 14:00	0.0	0	0	0	0	0
02/04/2022 15:00	0.0	0	0	0	0	0
02/04/2022 16:00	57.7	0	0	1	0	0
02/04/2022 17:00	4.3	0	0	1	0	0
02/04/2022 18:00	0.0	0	0	0	0	1
02/04/2022 19:00	0.0	0	0	0	0	1
02/04/2022 20:00	0.0	0	0	0	0	1
02/04/2022 21:00	0.0	0	0	0	0	1
02/04/2022 22:00	0.0	0	0	0	0	1
02/04/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	63.1 #	0 #	0 #	2 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	57.7	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/05/2022 00:00	0.0	0	0	0	0	1
02/05/2022 01:00	0.0	0	0	0	0	1
02/05/2022 02:00	0.0	0	0	0	0	1
02/05/2022 03:00	0.0	0	0	0	0	1
02/05/2022 04:00	0.0	0	0	0	0	1
02/05/2022 05:00	0.0	0	0	0	0	1
02/05/2022 06:00	0.0	0	0	0	0	1
02/05/2022 07:00	0.0	0	0	0	0	1
02/05/2022 08:00	1.0	0	0	0	1	0
02/05/2022 09:00	0.0	0	0	0	0	0
02/05/2022 10:00	0.0	0	0	0	0	0
02/05/2022 11:00	0.0	0	0	0	0	0
02/05/2022 12:00	0.0	0	0	0	0	0
02/05/2022 13:00	4.1	0	0	1	0	0
02/05/2022 14:00	38.4	0	0	1	0	0
02/05/2022 15:00	0.0	0	0	0	0	1
02/05/2022 16:00	0.0	0	0	0	0	1
02/05/2022 17:00	0.0	0	0	0	0	1
02/05/2022 18:00	0.0	0	0	0	0	1
02/05/2022 19:00	0.0	0	0	0	0	1
02/05/2022 20:00	0.0	0	0	0	0	1
02/05/2022 21:00	0.0	0	0	0	0	1
02/05/2022 22:00	0.0	0	0	0	0	1
02/05/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	43.5 #	0 #	0 #	2 #	1 #	17 #
Minimum:	0.0	0	0	0	0	0
Maximum:	38.4	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/06/2022 00:00	0.0	0	0	0	0	1
02/06/2022 01:00	0.0	0	0	0	0	1
02/06/2022 02:00	0.0	0	0	0	0	1
02/06/2022 03:00	0.0	0	0	0	0	1
02/06/2022 04:00	0.0	0	0	0	0	1
02/06/2022 05:00	0.0	0	0	0	0	1
02/06/2022 06:00	0.0	0	0	0	0	1
02/06/2022 07:00	0.0	0	0	0	0	1
02/06/2022 08:00	0.7	0	0	0	1	0
02/06/2022 09:00	0.0	0	0	0	0	0
02/06/2022 10:00	0.0	0	0	0	0	0
02/06/2022 11:00	0.0	0	0	0	0	0
02/06/2022 12:00	0.0	0	0	0	0	0
02/06/2022 13:00	0.0	0	0	0	0	0
02/06/2022 14:00	6.7	0	0	1	0	0
02/06/2022 15:00	34.5	0	0	1	0	0
02/06/2022 16:00	0.0	0	0	0	0	1
02/06/2022 17:00	0.0	0	0	0	0	1
02/06/2022 18:00	0.0	0	0	0	0	1
02/06/2022 19:00	0.0	0	0	0	0	1
02/06/2022 20:00	0.0	0	0	0	0	1
02/06/2022 21:00	0.0	0	0	0	0	1
02/06/2022 22:00	0.0	0	0	0	0	1
02/06/2022 23:00	0.7	0	0	0	1	0
Average/Sum#:	42.6 #	0 #	0 #	2 #	2 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	34.5	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/07/2022 00:00	0.0	0	0	0	0	0
02/07/2022 01:00	0.0	0	0	0	0	0
02/07/2022 02:00	0.0	0	0	0	0	0
02/07/2022 03:00	0.0	0	0	0	0	0
02/07/2022 04:00	0.0	0	0	0	0	0
02/07/2022 05:00	0.0	0	0	0	0	0
02/07/2022 06:00	0.0	0	0	0	0	0
02/07/2022 07:00	0.0	0	0	0	0	0
02/07/2022 08:00	0.0	0	0	0	0	0
02/07/2022 09:00	0.0	0	0	0	0	0
02/07/2022 10:00	0.0	0	0	0	0	0
02/07/2022 11:00	36.3	0	1	0	0	0
02/07/2022 12:00	14.0	0	1	0	0	0
02/07/2022 13:00	31.1	0	1	0	0	0
02/07/2022 14:00	0.0	0	0	0	0	1
02/07/2022 15:00	0.0	0	0	0	0	1
02/07/2022 16:00	0.0	0	0	0	0	1
02/07/2022 17:00	0.0	0	0	0	0	1
02/07/2022 18:00	0.0	0	0	0	0	1
02/07/2022 19:00	0.0	0	0	0	0	1
02/07/2022 20:00	0.0	0	0	0	0	1
02/07/2022 21:00	0.0	0	0	0	0	1
02/07/2022 22:00	0.0	0	0	0	0	1
02/07/2022 23:00	0.9	0	0	0	1	0
Average/Sum#:	82.3 #	0 #	3 #	0 #	1 #	9 #
Minimum:	0.0	0	0	0	0	0
Maximum:	36.3	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/08/2022 00:00	0.0	0	0	0	0	0
02/08/2022 01:00	0.0	0	0	0	0	0
02/08/2022 02:00	0.0	0	0	0	0	0
02/08/2022 03:00	5.5	0	0	1	0	0
02/08/2022 04:00	10.3	0	0	1	0	0
02/08/2022 05:00	0.0	0	0	0	0	1
02/08/2022 06:00	0.0	0	0	0	0	1
02/08/2022 07:00	0.0	0	0	0	0	1
02/08/2022 08:00	0.0	0	0	0	0	1
02/08/2022 09:00	0.0	0	0	0	0	1
02/08/2022 10:00	0.0	0	0	0	0	1
02/08/2022 11:00	0.0	0	0	0	0	1
02/08/2022 12:00	0.0	0	0	0	0	1
02/08/2022 13:00	0.0	0	0	0	0	1
02/08/2022 14:00	0.0	0	0	0	0	1
02/08/2022 15:00	0.0	0	0	0	0	1
02/08/2022 16:00	0.0	0	0	0	0	1
02/08/2022 17:00	0.0	0	0	0	0	1
02/08/2022 18:00	0.0	0	0	0	0	1
02/08/2022 19:00	0.0	0	0	0	0	1
02/08/2022 20:00	0.0	0	0	0	0	1
02/08/2022 21:00	0.0	0	0	0	0	1
02/08/2022 22:00	0.0	0	0	0	0	1
02/08/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	15.8 #	0 #	0 #	2 #	0 #	19 #
Minimum:	0.0	0	0	0	0	0
Maximum:	10.3	0	0	1	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/09/2022 00:00	0.0	0	0	0	0	1
02/09/2022 01:00	0.0	0	0	0	0	1
02/09/2022 02:00	0.0	0	0	0	0	1
02/09/2022 03:00	0.0	0	0	0	0	1
02/09/2022 04:00	0.0	0	0	0	0	1
02/09/2022 05:00	0.0	0	0	0	0	1
02/09/2022 06:00	0.0	0	0	0	0	1
02/09/2022 07:00	0.0	0	0	0	0	1
02/09/2022 08:00	0.0	0	0	0	0	1
02/09/2022 09:00	0.0	0	0	0	0	1
02/09/2022 10:00	0.0	0	0	0	0	1
02/09/2022 11:00	0.0	0	0	0	0	1
02/09/2022 12:00	0.0	0	0	0	0	1
02/09/2022 13:00	0.0	0	0	0	0	1
02/09/2022 14:00	0.0	0	0	0	0	1
02/09/2022 15:00	0.0	0	0	0	0	1
02/09/2022 16:00	0.0	0	0	0	0	1
02/09/2022 17:00	0.0	0	0	0	0	1
02/09/2022 18:00	0.0	0	0	0	0	1
02/09/2022 19:00	0.0	0	0	0	0	1
02/09/2022 20:00	0.0	0	0	0	0	1
02/09/2022 21:00	0.0	0	0	0	0	1
02/09/2022 22:00	0.0	0	0	0	0	1
02/09/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/10/2022 00:00	0.0	0	0	0	0	1
02/10/2022 01:00	0.0	0	0	0	0	1
02/10/2022 02:00	0.0	0	0	0	0	1
02/10/2022 03:00	0.0	0	0	0	0	1
02/10/2022 04:00	0.0	0	0	0	0	1
02/10/2022 05:00	0.0	0	0	0	0	1
02/10/2022 06:00	0.0	0	0	0	0	1
02/10/2022 07:00	0.0	0	0	0	0	1
02/10/2022 08:00	0.9	0	0	0	1	0
02/10/2022 09:00	0.0	0	0	0	0	0
02/10/2022 10:00	0.0	0	0	0	0	0
02/10/2022 11:00	0.1	0	0	1	0	0
02/10/2022 12:00	29.1	0	0	1	0	0
02/10/2022 13:00	0.0	0	0	0	0	1
02/10/2022 14:00	0.0	0	0	0	0	1
02/10/2022 15:00	0.0	0	0	0	0	1
02/10/2022 16:00	0.0	0	0	0	0	1
02/10/2022 17:00	0.0	0	0	0	0	1
02/10/2022 18:00	0.0	0	0	0	0	1
02/10/2022 19:00	0.0	0	0	0	0	1
02/10/2022 20:00	0.0	0	0	0	0	1
02/10/2022 21:00	0.0	0	0	0	0	1
02/10/2022 22:00	0.0	0	0	0	0	1
02/10/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	30.1 #	0 #	0 #	2 #	1 #	19 #
Minimum:	0.0	0	0	0	0	0
Maximum:	29.1	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/11/2022 00:00	0.0	0	0	0	0	1
02/11/2022 01:00	0.6	0	0	0	1	0
02/11/2022 02:00	0.0	0	0	0	0	0
02/11/2022 03:00	0.0	0	0	0	0	0
02/11/2022 04:00	0.0	0	0	0	0	0
02/11/2022 05:00	0.0	0	0	0	0	0
02/11/2022 06:00	0.0	0	0	0	0	0
02/11/2022 07:00	0.0	0	0	0	0	0
02/11/2022 08:00	0.0	0	0	0	0	0
02/11/2022 09:00	0.0	0	0	0	0	0
02/11/2022 10:00	0.0	0	0	0	0	0
02/11/2022 11:00	0.0	0	0	0	0	0
02/11/2022 12:00	0.0	0	0	0	0	0
02/11/2022 13:00	0.0	0	0	0	0	0
02/11/2022 14:00	0.0	0	0	0	0	0
02/11/2022 15:00	0.0	0	0	0	0	0
02/11/2022 16:00	0.0	0	0	0	0	0
02/11/2022 17:00	0.0	0	0	0	0	0
02/11/2022 18:00	0.0	0	0	0	0	0
02/11/2022 19:00	0.0	0	0	0	0	0
02/11/2022 20:00	0.0	0	0	0	0	0
02/11/2022 21:00	0.0	0	0	0	0	0
02/11/2022 22:00	0.0	0	0	0	0	0
02/11/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.6 #	0 #	0 #	0 #	1 #	1 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.6	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/12/2022 00:00	0.0	0	0	0	0	0
02/12/2022 01:00	0.0	0	0	0	0	0
02/12/2022 02:00	0.0	0	0	0	0	0
02/12/2022 03:00	0.0	0	0	0	0	0
02/12/2022 04:00	0.0	0	0	0	0	0
02/12/2022 05:00	0.0	0	0	0	0	0
02/12/2022 06:00	0.0	0	0	0	0	0
02/12/2022 07:00	0.0	0	0	0	0	0
02/12/2022 08:00	0.0	0	0	0	0	0
02/12/2022 09:00	0.0	0	0	0	0	0
02/12/2022 10:00	0.0	0	0	0	0	0
02/12/2022 11:00	0.0	0	0	0	0	0
02/12/2022 12:00	0.0	0	0	0	0	0
02/12/2022 13:00	0.0	0	0	0	0	0
02/12/2022 14:00	0.0	0	0	0	0	0
02/12/2022 15:00	0.0	0	0	0	0	0
02/12/2022 16:00	0.0	0	0	0	0	0
02/12/2022 17:00	0.0	0	0	0	0	0
02/12/2022 18:00	0.0	0	0	0	0	0
02/12/2022 19:00	0.0	0	0	0	0	0
02/12/2022 20:00	0.0	0	0	0	0	0
02/12/2022 21:00	0.0	0	0	0	0	0
02/12/2022 22:00	0.0	0	0	0	0	0
02/12/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/13/2022 00:00	0.0	0	0	0	0	0
02/13/2022 01:00	0.0	0	0	0	0	0
02/13/2022 02:00	0.0	0	0	0	0	0
02/13/2022 03:00	0.0	0	0	0	0	0
02/13/2022 04:00	0.0	0	0	0	0	0
02/13/2022 05:00	0.0	0	0	0	0	0
02/13/2022 06:00	0.0	0	0	0	0	0
02/13/2022 07:00	0.0	0	0	0	0	0
02/13/2022 08:00	0.0	0	0	0	0	0
02/13/2022 09:00	0.0	0	0	0	0	0
02/13/2022 10:00	0.0	0	0	0	0	0
02/13/2022 11:00	0.0	0	0	0	0	0
02/13/2022 12:00	0.0	0	0	0	0	0
02/13/2022 13:00	0.0	0	0	0	0	0
02/13/2022 14:00	0.0	0	0	0	0	0
02/13/2022 15:00	0.0	0	0	0	0	0
02/13/2022 16:00	0.0	0	0	0	0	0
02/13/2022 17:00	0.0	0	0	0	0	0
02/13/2022 18:00	0.0	0	0	0	0	0
02/13/2022 19:00	0.0	0	0	0	0	0
02/13/2022 20:00	0.0	0	0	0	0	0
02/13/2022 21:00	0.0	0	0	0	0	0
02/13/2022 22:00	0.0	0	0	0	0	0
02/13/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/14/2022 00:00	0.0	0	0	0	0	0
02/14/2022 01:00	0.0	0	0	0	0	0
02/14/2022 02:00	0.0	0	0	0	0	0
02/14/2022 03:00	0.0	0	0	0	0	0
02/14/2022 04:00	0.0	0	0	0	0	0
02/14/2022 05:00	0.0	0	0	0	0	0
02/14/2022 06:00	0.0	0	0	0	0	0
02/14/2022 07:00	0.0	0	0	0	0	0
02/14/2022 08:00	0.0	0	0	0	0	0
02/14/2022 09:00	0.0	0	0	0	0	0
02/14/2022 10:00	0.0	0	0	0	0	0
02/14/2022 11:00	0.0	0	0	0	0	0
02/14/2022 12:00	0.0	0	0	0	0	0
02/14/2022 13:00	0.0	0	0	0	0	0
02/14/2022 14:00	0.0	0	0	0	0	0
02/14/2022 15:00	0.0	0	0	0	0	0
02/14/2022 16:00	0.0	0	0	0	0	0
02/14/2022 17:00	0.0	0	0	0	0	0
02/14/2022 18:00	0.0	0	0	0	0	0
02/14/2022 19:00	0.0	0	0	0	0	0
02/14/2022 20:00	0.0	0	0	0	0	0
02/14/2022 21:00	0.0	0	0	0	0	0
02/14/2022 22:00	0.0	0	0	0	0	0
02/14/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/15/2022 00:00	0.0	0	0	0	0	0
02/15/2022 01:00	0.0	0	0	0	0	0
02/15/2022 02:00	0.0	0	0	0	0	0
02/15/2022 03:00	0.0	0	0	0	0	0
02/15/2022 04:00	0.0	0	0	0	0	0
02/15/2022 05:00	0.0	0	0	0	0	0
02/15/2022 06:00	0.0	0	0	0	0	0
02/15/2022 07:00	0.0	0	0	0	0	0
02/15/2022 08:00	0.0	0	0	0	0	0
02/15/2022 09:00	0.0	0	0	0	0	0
02/15/2022 10:00	0.0	0	0	0	0	0
02/15/2022 11:00	0.0	0	0	0	0	0
02/15/2022 12:00	0.0	0	0	0	0	0
02/15/2022 13:00	0.0	0	0	0	0	0
02/15/2022 14:00	0.0	0	0	0	0	0
02/15/2022 15:00	0.0	0	0	0	0	0
02/15/2022 16:00	0.0	0	0	0	0	0
02/15/2022 17:00	0.0	0	0	0	0	0
02/15/2022 18:00	0.0	0	0	0	0	0
02/15/2022 19:00	0.0	0	0	0	0	0
02/15/2022 20:00	0.0	0	0	0	0	0
02/15/2022 21:00	0.0	0	0	0	0	0
02/15/2022 22:00	0.0	0	0	0	0	0
02/15/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/16/2022 00:00	0.0	0	0	0	0	0
02/16/2022 01:00	0.0	0	0	0	0	0
02/16/2022 02:00	0.0	0	0	0	0	0
02/16/2022 03:00	0.0	0	0	0	0	0
02/16/2022 04:00	0.0	0	0	0	0	0
02/16/2022 05:00	0.0	0	0	0	0	0
02/16/2022 06:00	0.0	0	0	0	0	0
02/16/2022 07:00	0.0	0	0	0	0	0
02/16/2022 08:00	0.0	0	0	0	0	0
02/16/2022 09:00	0.0	0	0	0	0	0
02/16/2022 10:00	0.0	0	0	0	0	0
02/16/2022 11:00	0.0	0	0	0	0	0
02/16/2022 12:00	0.0	0	0	0	0	0
02/16/2022 13:00	0.0	0	0	0	0	0
02/16/2022 14:00	0.0	0	0	0	0	0
02/16/2022 15:00	0.0	0	0	0	0	0
02/16/2022 16:00	0.0	0	0	0	0	0
02/16/2022 17:00	0.0	0	0	0	0	0
02/16/2022 18:00	0.0	0	0	0	0	0
02/16/2022 19:00	0.0	0	0	0	0	0
02/16/2022 20:00	0.0	0	0	0	0	0
02/16/2022 21:00	0.0	0	0	0	0	0
02/16/2022 22:00	0.0	0	0	0	0	0
02/16/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/17/2022 00:00	0.0	0	0	0	0	0
02/17/2022 01:00	0.0	0	0	0	0	0
02/17/2022 02:00	0.0	0	0	0	0	0
02/17/2022 03:00	0.0	0	0	0	0	0
02/17/2022 04:00	0.0	0	0	0	0	0
02/17/2022 05:00	0.0	0	0	0	0	0
02/17/2022 06:00	0.0	0	0	0	0	0
02/17/2022 07:00	0.0	0	0	0	0	0
02/17/2022 08:00	0.0	0	0	0	0	0
02/17/2022 09:00	0.0	0	0	0	0	0
02/17/2022 10:00	0.0	0	0	0	0	0
02/17/2022 11:00	0.0	0	0	0	0	0
02/17/2022 12:00	0.0	0	0	0	0	0
02/17/2022 13:00	0.0	0	0	0	0	0
02/17/2022 14:00	0.0	0	0	0	0	0
02/17/2022 15:00	0.0	0	0	0	0	0
02/17/2022 16:00	0.0	0	0	0	0	0
02/17/2022 17:00	0.0	0	0	0	0	0
02/17/2022 18:00	0.0	0	0	0	0	0
02/17/2022 19:00	0.0	0	0	0	0	0
02/17/2022 20:00	0.0	0	0	0	0	0
02/17/2022 21:00	0.0	0	0	0	0	0
02/17/2022 22:00	0.0	0	0	0	0	0
02/17/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/18/2022 00:00	0.0	0	0	0	0	0
02/18/2022 01:00	0.0	0	0	0	0	0
02/18/2022 02:00	0.0	0	0	0	0	0
02/18/2022 03:00	0.0	0	0	0	0	0
02/18/2022 04:00	0.0	0	0	0	0	0
02/18/2022 05:00	0.0	0	0	0	0	0
02/18/2022 06:00	0.0	0	0	0	0	0
02/18/2022 07:00	0.0	0	0	0	0	0
02/18/2022 08:00	1.6	1	0	0	0	0
02/18/2022 09:00	83.9	1	0	0	0	0
02/18/2022 10:00	20.1	1	0	0	0	0
02/18/2022 11:00	47.9	1	0	0	0	0
02/18/2022 12:00	38.9	1	0	0	0	0
02/18/2022 13:00	0.0	0	0	0	0	1
02/18/2022 14:00	0.0	0	0	0	0	1
02/18/2022 15:00	0.0	0	0	0	0	1
02/18/2022 16:00	0.0	0	0	0	0	1
02/18/2022 17:00	0.0	0	0	0	0	1
02/18/2022 18:00	0.0	0	0	0	0	1
02/18/2022 19:00	0.0	0	0	0	0	1
02/18/2022 20:00	0.0	0	0	0	0	1
02/18/2022 21:00	0.0	0	0	0	0	1
02/18/2022 22:00	0.0	0	0	0	0	1
02/18/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	192.4 #	5 #	0 #	0 #	0 #	11 #
Minimum:	0.0	0	0	0	0	0
Maximum:	83.9	1	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/19/2022 00:00	0.7	0	0	0	1	0
02/19/2022 01:00	0.0	0	0	0	0	0
02/19/2022 02:00	0.0	0	0	0	0	0
02/19/2022 03:00	0.0	0	0	0	0	0
02/19/2022 04:00	0.0	0	0	0	0	0
02/19/2022 05:00	0.0	0	0	0	0	0
02/19/2022 06:00	0.0	0	0	0	0	0
02/19/2022 07:00	0.0	0	0	0	0	0
02/19/2022 08:00	0.0	0	0	0	0	0
02/19/2022 09:00	0.0	0	0	0	0	0
02/19/2022 10:00	0.0	0	0	0	0	0
02/19/2022 11:00	0.0	0	0	0	0	0
02/19/2022 12:00	0.0	0	0	0	0	0
02/19/2022 13:00	0.0	0	0	0	0	0
02/19/2022 14:00	0.0	0	0	0	0	0
02/19/2022 15:00	0.0	0	0	0	0	0
02/19/2022 16:00	0.0	0	0	0	0	0
02/19/2022 17:00	0.0	0	0	0	0	0
02/19/2022 18:00	0.0	0	0	0	0	0
02/19/2022 19:00	0.0	0	0	0	0	0
02/19/2022 20:00	0.0	0	0	0	0	0
02/19/2022 21:00	0.0	0	0	0	0	0
02/19/2022 22:00	0.0	0	0	0	0	0
02/19/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.7 #	0 #	0 #	0 #	1 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.7	0	0	0	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/20/2022 00:00	0.0	0	0	0	0	0
02/20/2022 01:00	0.0	0	0	0	0	0
02/20/2022 02:00	0.0	0	0	0	0	0
02/20/2022 03:00	0.0	0	0	0	0	0
02/20/2022 04:00	0.0	0	0	0	0	0
02/20/2022 05:00	0.0	0	0	0	0	0
02/20/2022 06:00	0.0	0	0	0	0	0
02/20/2022 07:00	0.0	0	0	0	0	0
02/20/2022 08:00	0.0	0	0	0	0	0
02/20/2022 09:00	0.0	0	0	0	0	0
02/20/2022 10:00	0.0	0	0	0	0	0
02/20/2022 11:00	0.0	0	0	0	0	0
02/20/2022 12:00	0.0	0	0	0	0	0
02/20/2022 13:00	0.0	0	0	0	0	0
02/20/2022 14:00	0.0	0	0	0	0	0
02/20/2022 15:00	0.0	0	0	0	0	0
02/20/2022 16:00	0.0	0	0	0	0	0
02/20/2022 17:00	0.0	0	0	0	0	0
02/20/2022 18:00	0.0	0	0	0	0	0
02/20/2022 19:00	0.0	0	0	0	0	0
02/20/2022 20:00	0.0	0	0	0	0	0
02/20/2022 21:00	0.0	0	0	0	0	0
02/20/2022 22:00	0.0	0	0	0	0	0
02/20/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/21/2022 00:00	0.0	0	0	0	0	0
02/21/2022 01:00	0.0	0	0	0	0	0
02/21/2022 02:00	0.0	0	0	0	0	0
02/21/2022 03:00	0.0	0	0	0	0	0
02/21/2022 04:00	0.0	0	0	0	0	0
02/21/2022 05:00	0.0	0	0	0	0	0
02/21/2022 06:00	0.0	0	0	0	0	0
02/21/2022 07:00	0.0	0	0	0	0	0
02/21/2022 08:00	0.0	0	0	0	0	0
02/21/2022 09:00	0.0	0	0	0	0	0
02/21/2022 10:00	0.0	0	0	0	0	0
02/21/2022 11:00	0.0	0	0	0	0	0
02/21/2022 12:00	0.0	0	0	0	0	0
02/21/2022 13:00	0.0	0	0	0	0	0
02/21/2022 14:00	0.0	0	0	0	0	0
02/21/2022 15:00	0.0	0	0	0	0	0
02/21/2022 16:00	0.0	0	0	0	0	0
02/21/2022 17:00	0.0	0	0	0	0	0
02/21/2022 18:00	0.0	0	0	0	0	0
02/21/2022 19:00	0.0	0	0	0	0	0
02/21/2022 20:00	0.0	0	0	0	0	0
02/21/2022 21:00	0.0	0	0	0	0	0
02/21/2022 22:00	0.0	0	0	0	0	0
02/21/2022 23:00	49.8	0	1	0	0	0
Average/Sum#:	49.8 #	0 #	1 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	49.8	0	1	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/22/2022 00:00	41.2	0	1	0	0	0
02/22/2022 01:00	35.3	0	1	0	0	0
02/22/2022 02:00	0.0	0	0	0	0	1
02/22/2022 03:00	0.0	0	0	0	0	1
02/22/2022 04:00	0.0	0	0	0	0	1
02/22/2022 05:00	0.0	0	0	0	0	1
02/22/2022 06:00	0.0	0	0	0	0	1
02/22/2022 07:00	0.0	0	0	0	0	1
02/22/2022 08:00	0.0	0	0	0	0	1
02/22/2022 09:00	0.0	0	0	0	0	1
02/22/2022 10:00	0.0	0	0	0	0	1
02/22/2022 11:00	0.0	0	0	0	0	1
02/22/2022 12:00	0.0	0	0	0	0	1
02/22/2022 13:00	0.0	0	0	0	0	1
02/22/2022 14:00	0.0	0	0	0	0	1
02/22/2022 15:00	0.0	0	0	0	0	1
02/22/2022 16:00	0.0	0	0	0	0	1
02/22/2022 17:00	0.0	0	0	0	0	1
02/22/2022 18:00	0.0	0	0	0	0	1
02/22/2022 19:00	0.0	0	0	0	0	1
02/22/2022 20:00	0.0	0	0	0	0	1
02/22/2022 21:00	0.0	0	0	0	0	1
02/22/2022 22:00	0.0	0	0	0	0	1
02/22/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	76.5 #	0 #	2 #	0 #	0 #	22 #
Minimum:	0.0	0	0	0	0	0
Maximum:	41.2	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/23/2022 00:00	0.0	0	0	0	0	1
02/23/2022 01:00	0.0	0	0	0	0	1
02/23/2022 02:00	0.0	0	0	0	0	1
02/23/2022 03:00	0.0	0	0	0	0	1
02/23/2022 04:00	0.0	0	0	0	0	1
02/23/2022 05:00	0.0	0	0	0	0	1
02/23/2022 06:00	0.0	0	0	0	0	1
02/23/2022 07:00	0.0	0	0	0	0	1
02/23/2022 08:00	0.0	0	0	0	0	1
02/23/2022 09:00	0.0	0	0	0	0	1
02/23/2022 10:00	0.0	0	0	0	0	1
02/23/2022 11:00	0.0	0	0	0	0	1
02/23/2022 12:00	0.0	0	0	0	0	1
02/23/2022 13:00	0.0	0	0	0	0	1
02/23/2022 14:00	0.0	0	0	0	0	1
02/23/2022 15:00	0.0	0	0	0	0	1
02/23/2022 16:00	0.0	0	0	0	0	1
02/23/2022 17:00	0.0	0	0	0	0	1
02/23/2022 18:00	0.0	0	0	0	0	1
02/23/2022 19:00	0.0	0	0	0	0	1
02/23/2022 20:00	0.0	0	0	0	0	1
02/23/2022 21:00	0.0	0	0	0	0	1
02/23/2022 22:00	0.0	0	0	0	0	1
02/23/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/24/2022 00:00	0.0	0	0	0	0	1
02/24/2022 01:00	0.0	0	0	0	0	1
02/24/2022 02:00	0.0	0	0	0	0	1
02/24/2022 03:00	0.0	0	0	0	0	1
02/24/2022 04:00	0.0	0	0	0	0	1
02/24/2022 05:00	0.0	0	0	0	0	1
02/24/2022 06:00	0.0	0	0	0	0	1
02/24/2022 07:00	0.0	0	0	0	0	1
02/24/2022 08:00	0.0	0	0	0	0	1
02/24/2022 09:00	0.0	0	0	0	0	1
02/24/2022 10:00	0.0	0	0	0	0	1
02/24/2022 11:00	0.0	0	0	0	0	1
02/24/2022 12:00	0.0	0	0	0	0	1
02/24/2022 13:00	0.0	0	0	0	0	1
02/24/2022 14:00	0.0	0	0	0	0	1
02/24/2022 15:00	0.0	0	0	0	0	1
02/24/2022 16:00	0.0	0	0	0	0	1
02/24/2022 17:00	0.0	0	0	0	0	1
02/24/2022 18:00	0.0	0	0	0	0	1
02/24/2022 19:00	0.0	0	0	0	0	1
02/24/2022 20:00	0.0	0	0	0	0	1
02/24/2022 21:00	0.0	0	0	0	0	1
02/24/2022 22:00	0.0	0	0	0	0	1
02/24/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/25/2022 00:00	0.0	0	0	0	0	1
02/25/2022 01:00	0.0	0	0	0	0	1
02/25/2022 02:00	0.0	0	0	0	0	1
02/25/2022 03:00	0.0	0	0	0	0	1
02/25/2022 04:00	0.0	0	0	0	0	1
02/25/2022 05:00	0.0	0	0	0	0	1
02/25/2022 06:00	0.0	0	0	0	0	1
02/25/2022 07:00	0.0	0	0	0	0	1
02/25/2022 08:00	0.0	0	0	0	0	1
02/25/2022 09:00	0.0	0	0	0	0	1
02/25/2022 10:00	0.0	0	0	0	0	1
02/25/2022 11:00	0.0	0	0	0	0	1
02/25/2022 12:00	0.0	0	0	0	0	1
02/25/2022 13:00	0.0	0	0	0	0	1
02/25/2022 14:00	0.0	0	0	0	0	1
02/25/2022 15:00	0.0	0	0	0	0	1
02/25/2022 16:00	0.0	0	0	0	0	1
02/25/2022 17:00	0.0	0	0	0	0	1
02/25/2022 18:00	0.0	0	0	0	0	1
02/25/2022 19:00	0.0	0	0	0	0	1
02/25/2022 20:00	0.0	0	0	0	0	1
02/25/2022 21:00	0.0	0	0	0	0	1
02/25/2022 22:00	0.0	0	0	0	0	1
02/25/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/26/2022 00:00	0.0	0	0	0	0	1
02/26/2022 01:00	0.0	0	0	0	0	1
02/26/2022 02:00	0.0	0	0	0	0	1
02/26/2022 03:00	0.0	0	0	0	0	1
02/26/2022 04:00	0.0	0	0	0	0	1
02/26/2022 05:00	0.0	0	0	0	0	1
02/26/2022 06:00	0.0	0	0	0	0	1
02/26/2022 07:00	1.4	0	0	0	1	0
02/26/2022 08:00	0.0	0	0	0	0	0
02/26/2022 09:00	0.0	0	0	0	0	0
02/26/2022 10:00	0.0	0	0	0	0	0
02/26/2022 11:00	0.0	0	0	0	0	0
02/26/2022 12:00	0.0	0	0	0	0	0
02/26/2022 13:00	0.0	0	0	0	0	0
02/26/2022 14:00	0.0	0	0	0	0	0
02/26/2022 15:00	19.0	0	1	0	0	0
02/26/2022 16:00	45.5	0	1	0	0	0
02/26/2022 17:00	0.0	0	0	0	0	1
02/26/2022 18:00	0.0	0	0	0	0	1
02/26/2022 19:00	0.0	0	0	0	0	1
02/26/2022 20:00	0.0	0	0	0	0	1
02/26/2022 21:00	0.0	0	0	0	0	1
02/26/2022 22:00	0.0	0	0	0	0	1
02/26/2022 23:00	1.2	0	0	0	1	0
Average/Sum#:	67.1 #	0 #	2 #	0 #	2 #	13 #
Minimum:	0.0	0	0	0	0	0
Maximum:	45.5	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/27/2022 00:00	0.0	0	0	0	0	0
02/27/2022 01:00	0.0	0	0	0	0	0
02/27/2022 02:00	0.0	0	0	0	0	0
02/27/2022 03:00	0.0	0	0	0	0	0
02/27/2022 04:00	0.0	0	0	0	0	0
02/27/2022 05:00	0.0	0	0	0	0	0
02/27/2022 06:00	0.0	0	0	0	0	0
02/27/2022 07:00	0.0	0	0	0	0	0
02/27/2022 08:00	0.0	0	0	0	0	0
02/27/2022 09:00	0.0	0	0	0	0	0
02/27/2022 10:00	0.0	0	0	0	0	0
02/27/2022 11:00	0.0	0	0	0	0	0
02/27/2022 12:00	0.0	0	0	0	0	0
02/27/2022 13:00	0.0	0	0	0	0	0
02/27/2022 14:00	0.0	0	0	0	0	0
02/27/2022 15:00	0.0	0	0	0	0	0
02/27/2022 16:00	0.0	0	0	0	0	0
02/27/2022 17:00	0.0	0	0	0	0	0
02/27/2022 18:00	0.0	0	0	0	0	0
02/27/2022 19:00	0.0	0	0	0	0	0
02/27/2022 20:00	0.0	0	0	0	0	0
02/27/2022 21:00	0.0	0	0	0	0	0
02/27/2022 22:00	0.0	0	0	0	0	0
02/27/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/28/2022 00:00	0.0	0	0	0	0	0
02/28/2022 01:00	0.0	0	0	0	0	0
02/28/2022 02:00	0.0	0	0	0	0	0
02/28/2022 03:00	0.0	0	0	0	0	0
02/28/2022 04:00	0.0	0	0	0	0	0
02/28/2022 05:00	0.0	0	0	0	0	0
02/28/2022 06:00	0.0	0	0	0	0	0
02/28/2022 07:00	0.0	0	0	0	0	0
02/28/2022 08:00	0.0	0	0	0	0	0
02/28/2022 09:00	0.0	0	0	0	0	0
02/28/2022 10:00	0.0	0	0	0	0	0
02/28/2022 11:00	0.0	0	0	0	0	0
02/28/2022 12:00	0.0	0	0	0	0	0
02/28/2022 13:00	60.4	0	1	0	0	0
02/28/2022 14:00	26.7	0	1	0	0	0
02/28/2022 15:00	34.4	0	1	0	0	0
02/28/2022 16:00	0.0	0	0	0	0	1
02/28/2022 17:00	0.0	0	0	0	0	1
02/28/2022 18:00	0.0	0	0	0	0	1
02/28/2022 19:00	0.0	0	0	0	0	1
02/28/2022 20:00	0.0	0	0	0	0	1
02/28/2022 21:00	0.0	0	0	0	0	1
02/28/2022 22:00	0.6	0	0	0	1	0
02/28/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	122.1 #	0 #	3 #	0 #	1 #	6 #
Minimum:	0.0	0	0	0	0	0
Maximum:	60.4	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/01/2022 00:00	0.0	0	0	0	0	0
03/01/2022 01:00	0.0	0	0	0	0	0
03/01/2022 02:00	0.0	0	0	0	0	0
03/01/2022 03:00	0.0	0	0	0	0	0
03/01/2022 04:00	0.0	0	0	0	0	0
03/01/2022 05:00	0.0	0	0	0	0	0
03/01/2022 06:00	0.0	0	0	0	0	0
03/01/2022 07:00	0.0	0	0	0	0	0
03/01/2022 08:00	0.0	0	0	0	0	0
03/01/2022 09:00	0.0	0	0	0	0	0
03/01/2022 10:00	0.0	0	0	0	0	0
03/01/2022 11:00	0.0	0	0	0	0	0
03/01/2022 12:00	0.0	0	0	0	0	0
03/01/2022 13:00	0.0	0	0	0	0	0
03/01/2022 14:00	0.0	0	0	0	0	0
03/01/2022 15:00	0.0	0	0	0	0	0
03/01/2022 16:00	0.0	0	0	0	0	0
03/01/2022 17:00	0.0	0	0	0	0	0
03/01/2022 18:00	0.0	0	0	0	0	0
03/01/2022 19:00	0.0	0	0	0	0	0
03/01/2022 20:00	0.0	0	0	0	0	0
03/01/2022 21:00	0.0	0	0	0	0	0
03/01/2022 22:00	0.0	0	0	0	0	0
03/01/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/02/2022 00:00	0.0	0	0	0	0	0
03/02/2022 01:00	0.0	0	0	0	0	0
03/02/2022 02:00	0.0	0	0	0	0	0
03/02/2022 03:00	0.0	0	0	0	0	0
03/02/2022 04:00	0.0	0	0	0	0	0
03/02/2022 05:00	0.0	0	0	0	0	0
03/02/2022 06:00	0.0	0	0	0	0	0
03/02/2022 07:00	0.0	0	0	0	0	0
03/02/2022 08:00	0.0	0	0	0	0	0
03/02/2022 09:00	0.0	0	0	0	0	0
03/02/2022 10:00	0.0	0	0	0	0	0
03/02/2022 11:00	0.0	0	0	0	0	0
03/02/2022 12:00	0.0	0	0	0	0	0
03/02/2022 13:00	0.0	0	0	0	0	0
03/02/2022 14:00	0.0	0	0	0	0	0
03/02/2022 15:00	0.0	0	0	0	0	0
03/02/2022 16:00	0.0	0	0	0	0	0
03/02/2022 17:00	0.0	0	0	0	0	0
03/02/2022 18:00	0.0	0	0	0	0	0
03/02/2022 19:00	0.0	0	0	0	0	0
03/02/2022 20:00	0.0	0	0	0	0	0
03/02/2022 21:00	0.0	0	0	0	0	0
03/02/2022 22:00	0.0	0	0	0	0	0
03/02/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/03/2022 00:00	0.0	0	0	0	0	0
03/03/2022 01:00	0.0	0	0	0	0	0
03/03/2022 02:00	0.0	0	0	0	0	0
03/03/2022 03:00	0.0	0	0	0	0	0
03/03/2022 04:00	0.0	0	0	0	0	0
03/03/2022 05:00	0.0	0	0	0	0	0
03/03/2022 06:00	0.0	0	0	0	0	0
03/03/2022 07:00	0.0	0	0	0	0	0
03/03/2022 08:00	0.0	0	0	0	0	0
03/03/2022 09:00	0.0	0	0	0	0	0
03/03/2022 10:00	0.0	0	0	0	0	0
03/03/2022 11:00	0.0	0	0	0	0	0
03/03/2022 12:00	0.0	0	0	0	0	0
03/03/2022 13:00	0.0	0	0	0	0	0
03/03/2022 14:00	0.0	0	0	0	0	0
03/03/2022 15:00	0.0	0	0	0	0	0
03/03/2022 16:00	0.0	0	0	0	0	0
03/03/2022 17:00	0.0	0	0	0	0	0
03/03/2022 18:00	0.0	0	0	0	0	0
03/03/2022 19:00	0.0	0	0	0	0	0
03/03/2022 20:00	0.0	0	0	0	0	0
03/03/2022 21:00	0.0	0	0	0	0	0
03/03/2022 22:00	0.0	0	0	0	0	0
03/03/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/04/2022 00:00	0.0	0	0	0	0	0
03/04/2022 01:00	0.0	0	0	0	0	0
03/04/2022 02:00	0.0	0	0	0	0	0
03/04/2022 03:00	0.0	0	0	0	0	0
03/04/2022 04:00	0.0	0	0	0	0	0
03/04/2022 05:00	0.0	0	0	0	0	0
03/04/2022 06:00	0.0	0	0	0	0	0
03/04/2022 07:00	0.0	0	0	0	0	0
03/04/2022 08:00	0.0	0	0	0	0	0
03/04/2022 09:00	0.0	0	0	0	0	0
03/04/2022 10:00	0.0	0	0	0	0	0
03/04/2022 11:00	0.0	0	0	0	0	0
03/04/2022 12:00	0.0	0	0	0	0	0
03/04/2022 13:00	0.0	0	0	0	0	0
03/04/2022 14:00	0.0	0	0	0	0	0
03/04/2022 15:00	0.0	0	0	0	0	0
03/04/2022 16:00	0.0	0	0	0	0	0
03/04/2022 17:00	0.0	0	0	0	0	0
03/04/2022 18:00	0.0	0	0	0	0	0
03/04/2022 19:00	0.0	0	0	0	0	0
03/04/2022 20:00	0.0	0	0	0	0	0
03/04/2022 21:00	0.0	0	0	0	0	0
03/04/2022 22:00	0.0	0	0	0	0	0
03/04/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/05/2022 00:00	0.0	0	0	0	0	0
03/05/2022 01:00	0.0	0	0	0	0	0
03/05/2022 02:00	0.0	0	0	0	0	0
03/05/2022 03:00	0.0	0	0	0	0	0
03/05/2022 04:00	0.0	0	0	0	0	0
03/05/2022 05:00	0.0	0	0	0	0	0
03/05/2022 06:00	0.0	0	0	0	0	0
03/05/2022 07:00	0.0	0	0	0	0	0
03/05/2022 08:00	0.0	0	0	0	0	0
03/05/2022 09:00	0.0	0	0	0	0	0
03/05/2022 10:00	0.0	0	0	0	0	0
03/05/2022 11:00	0.0	0	0	0	0	0
03/05/2022 12:00	0.0	0	0	0	0	0
03/05/2022 13:00	0.0	0	0	0	0	0
03/05/2022 14:00	0.0	0	0	0	0	0
03/05/2022 15:00	0.0	0	0	0	0	0
03/05/2022 16:00	0.0	0	0	0	0	0
03/05/2022 17:00	0.0	0	0	0	0	0
03/05/2022 18:00	0.0	0	0	0	0	0
03/05/2022 19:00	0.0	0	0	0	0	0
03/05/2022 20:00	0.0	0	0	0	0	0
03/05/2022 21:00	0.0	0	0	0	0	0
03/05/2022 22:00	0.0	0	0	0	0	0
03/05/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/06/2022 00:00	0.0	0	0	0	0	0
03/06/2022 01:00	0.0	0	0	0	0	0
03/06/2022 02:00	0.0	0	0	0	0	0
03/06/2022 03:00	0.0	0	0	0	0	0
03/06/2022 04:00	0.0	0	0	0	0	0
03/06/2022 05:00	0.0	0	0	0	0	0
03/06/2022 06:00	0.0	0	0	0	0	0
03/06/2022 07:00	0.0	0	0	0	0	0
03/06/2022 08:00	0.0	0	0	0	0	0
03/06/2022 09:00	0.0	0	0	0	0	0
03/06/2022 10:00	0.0	0	0	0	0	0
03/06/2022 11:00	0.0	0	0	0	0	0
03/06/2022 12:00	0.0	0	0	0	0	0
03/06/2022 13:00	0.0	0	0	0	0	0
03/06/2022 14:00	0.0	0	0	0	0	0
03/06/2022 15:00	0.0	0	0	0	0	0
03/06/2022 16:00	0.0	0	0	0	0	0
03/06/2022 17:00	0.0	0	0	0	0	0
03/06/2022 18:00	0.0	0	0	0	0	0
03/06/2022 19:00	0.0	0	0	0	0	0
03/06/2022 20:00	0.0	0	0	0	0	0
03/06/2022 21:00	0.0	0	0	0	0	0
03/06/2022 22:00	0.0	0	0	0	0	0
03/06/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/07/2022 00:00	0.0	0	0	0	0	0
03/07/2022 01:00	0.0	0	0	0	0	0
03/07/2022 02:00	0.0	0	0	0	0	0
03/07/2022 03:00	0.0	0	0	0	0	0
03/07/2022 04:00	0.0	0	0	0	0	0
03/07/2022 05:00	0.0	0	0	0	0	0
03/07/2022 06:00	0.0	0	0	0	0	0
03/07/2022 07:00	0.0	0	0	0	0	0
03/07/2022 08:00	0.0	0	0	0	0	0
03/07/2022 09:00	0.0	0	0	0	0	0
03/07/2022 10:00	0.0	0	0	0	0	0
03/07/2022 11:00	0.0	0	0	0	0	0
03/07/2022 12:00	0.0	0	0	0	0	0
03/07/2022 13:00	0.0	0	0	0	0	0
03/07/2022 14:00	0.0	0	0	0	0	0
03/07/2022 15:00	0.0	0	0	0	0	0
03/07/2022 16:00	0.0	0	0	0	0	0
03/07/2022 17:00	0.0	0	0	0	0	0
03/07/2022 18:00	0.0	0	0	0	0	0
03/07/2022 19:00	0.0	0	0	0	0	0
03/07/2022 20:00	0.0	0	0	0	0	0
03/07/2022 21:00	0.0	0	0	0	0	0
03/07/2022 22:00	0.0	0	0	0	0	0
03/07/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/08/2022 00:00	0.0	0	0	0	0	0
03/08/2022 01:00	0.0	0	0	0	0	0
03/08/2022 02:00	0.0	0	0	0	0	0
03/08/2022 03:00	0.0	0	0	0	0	0
03/08/2022 04:00	0.0	0	0	0	0	0
03/08/2022 05:00	0.0	0	0	0	0	0
03/08/2022 06:00	0.0	0	0	0	0	0
03/08/2022 07:00	0.0	0	0	0	0	0
03/08/2022 08:00	0.0	0	0	0	0	0
03/08/2022 09:00	0.0	0	0	0	0	0
03/08/2022 10:00	0.0	0	0	0	0	0
03/08/2022 11:00	0.0	0	0	0	0	0
03/08/2022 12:00	0.0	0	0	0	0	0
03/08/2022 13:00	0.0	0	0	0	0	0
03/08/2022 14:00	0.0	0	0	0	0	0
03/08/2022 15:00	0.0	0	0	0	0	0
03/08/2022 16:00	0.0	0	0	0	0	0
03/08/2022 17:00	0.0	0	0	0	0	0
03/08/2022 18:00	0.0	0	0	0	0	0
03/08/2022 19:00	0.0	0	0	0	0	0
03/08/2022 20:00	0.0	0	0	0	0	0
03/08/2022 21:00	0.0	0	0	0	0	0
03/08/2022 22:00	0.0	0	0	0	0	0
03/08/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/09/2022 00:00	0.0	0	0	0	0	0
03/09/2022 01:00	0.0	0	0	0	0	0
03/09/2022 02:00	0.0	0	0	0	0	0
03/09/2022 03:00	0.0	0	0	0	0	0
03/09/2022 04:00	0.0	0	0	0	0	0
03/09/2022 05:00	0.0	0	0	0	0	0
03/09/2022 06:00	0.0	0	0	0	0	0
03/09/2022 07:00	0.0	0	0	0	0	0
03/09/2022 08:00	0.0	0	0	0	0	0
03/09/2022 09:00	0.0	0	0	0	0	0
03/09/2022 10:00	0.0	0	0	0	0	0
03/09/2022 11:00	0.0	0	0	0	0	0
03/09/2022 12:00	0.0	0	0	0	0	0
03/09/2022 13:00	0.0	0	0	0	0	0
03/09/2022 14:00	0.0	0	0	0	0	0
03/09/2022 15:00	0.0	0	0	0	0	0
03/09/2022 16:00	0.0	0	0	0	0	0
03/09/2022 17:00	0.0	0	0	0	0	0
03/09/2022 18:00	0.0	0	0	0	0	0
03/09/2022 19:00	0.0	0	0	0	0	0
03/09/2022 20:00	0.0	0	0	0	0	0
03/09/2022 21:00	0.0	0	0	0	0	0
03/09/2022 22:00	0.0	0	0	0	0	0
03/09/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/10/2022 00:00	0.0	0	0	0	0	0
03/10/2022 01:00	0.0	0	0	0	0	0
03/10/2022 02:00	0.0	0	0	0	0	0
03/10/2022 03:00	0.0	0	0	0	0	0
03/10/2022 04:00	0.0	0	0	0	0	0
03/10/2022 05:00	0.0	0	0	0	0	0
03/10/2022 06:00	0.0	0	0	0	0	0
03/10/2022 07:00	0.0	0	0	0	0	0
03/10/2022 08:00	0.0	0	0	0	0	0
03/10/2022 09:00	0.0	0	0	0	0	0
03/10/2022 10:00	0.0	0	0	0	0	0
03/10/2022 11:00	0.0	0	0	0	0	0
03/10/2022 12:00	0.0	0	0	0	0	0
03/10/2022 13:00	0.0	0	0	0	0	0
03/10/2022 14:00	0.0	0	0	0	0	0
03/10/2022 15:00	0.0	0	0	0	0	0
03/10/2022 16:00	0.0	0	0	0	0	0
03/10/2022 17:00	0.0	0	0	0	0	0
03/10/2022 18:00	0.0	0	0	0	0	0
03/10/2022 19:00	0.0	0	0	0	0	0
03/10/2022 20:00	0.0	0	0	0	0	0
03/10/2022 21:00	0.0	0	0	0	0	0
03/10/2022 22:00	0.0	0	0	0	0	0
03/10/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/11/2022 00:00	0.0	0	0	0	0	0
03/11/2022 01:00	0.0	0	0	0	0	0
03/11/2022 02:00	0.0	0	0	0	0	0
03/11/2022 03:00	0.0	0	0	0	0	0
03/11/2022 04:00	0.0	0	0	0	0	0
03/11/2022 05:00	0.0	0	0	0	0	0
03/11/2022 06:00	0.0	0	0	0	0	0
03/11/2022 07:00	0.0	0	0	0	0	0
03/11/2022 08:00	0.0	0	0	0	0	0
03/11/2022 09:00	0.0	0	0	0	0	0
03/11/2022 10:00	0.0	0	0	0	0	0
03/11/2022 11:00	0.0	0	0	0	0	0
03/11/2022 12:00	0.0	0	0	0	0	0
03/11/2022 13:00	0.0	0	0	0	0	0
03/11/2022 14:00	0.0	0	0	0	0	0
03/11/2022 15:00	0.0	0	0	0	0	0
03/11/2022 16:00	0.0	0	0	0	0	0
03/11/2022 17:00	0.0	0	0	0	0	0
03/11/2022 18:00	0.0	0	0	0	0	0
03/11/2022 19:00	0.0	0	0	0	0	0
03/11/2022 20:00	0.0	0	0	0	0	0
03/11/2022 21:00	0.0	0	0	0	0	0
03/11/2022 22:00	0.0	0	0	0	0	0
03/11/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/12/2022 00:00	0.0	0	0	0	0	0
03/12/2022 01:00	0.0	0	0	0	0	0
03/12/2022 02:00	0.0	0	0	0	0	0
03/12/2022 03:00	0.0	0	0	0	0	0
03/12/2022 04:00	0.0	0	0	0	0	0
03/12/2022 05:00	0.0	0	0	0	0	0
03/12/2022 06:00	0.0	0	0	0	0	0
03/12/2022 07:00	0.0	0	0	0	0	0
03/12/2022 08:00	0.0	0	0	0	0	0
03/12/2022 09:00	0.0	0	0	0	0	0
03/12/2022 10:00	0.0	0	0	0	0	0
03/12/2022 11:00	0.0	0	0	0	0	0
03/12/2022 12:00	0.0	0	0	0	0	0
03/12/2022 13:00	0.0	0	0	0	0	0
03/12/2022 14:00	0.0	0	0	0	0	0
03/12/2022 15:00	0.0	0	0	0	0	0
03/12/2022 16:00	0.0	0	0	0	0	0
03/12/2022 17:00	0.0	0	0	0	0	0
03/12/2022 18:00	0.0	0	0	0	0	0
03/12/2022 19:00	0.0	0	0	0	0	0
03/12/2022 20:00	0.0	0	0	0	0	0
03/12/2022 21:00	0.0	0	0	0	0	0
03/12/2022 22:00	0.0	0	0	0	0	0
03/12/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/13/2022 00:00	0.0	0	0	0	0	0
03/13/2022 01:00	0.0	0	0	0	0	0
03/13/2022 02:00	0.0	0	0	0	0	0
03/13/2022 03:00	0.0	0	0	0	0	0
03/13/2022 04:00	0.0	0	0	0	0	0
03/13/2022 05:00	0.0	0	0	0	0	0
03/13/2022 06:00	0.0	0	0	0	0	0
03/13/2022 07:00	0.0	0	0	0	0	0
03/13/2022 08:00	0.0	0	0	0	0	0
03/13/2022 09:00	0.0	0	0	0	0	0
03/13/2022 10:00	0.0	0	0	0	0	0
03/13/2022 11:00	0.0	0	0	0	0	0
03/13/2022 12:00	0.0	0	0	0	0	0
03/13/2022 13:00	0.0	0	0	0	0	0
03/13/2022 14:00	0.0	0	0	0	0	0
03/13/2022 15:00	0.0	0	0	0	0	0
03/13/2022 16:00	0.0	0	0	0	0	0
03/13/2022 17:00	0.0	0	0	0	0	0
03/13/2022 18:00	0.0	0	0	0	0	0
03/13/2022 19:00	0.0	0	0	0	0	0
03/13/2022 20:00	0.0	0	0	0	0	0
03/13/2022 21:00	0.0	0	0	0	0	0
03/13/2022 22:00	0.0	0	0	0	0	0
03/13/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/14/2022 00:00	0.0	0	0	0	0	0
03/14/2022 01:00	0.0	0	0	0	0	0
03/14/2022 02:00	0.0	0	0	0	0	0
03/14/2022 03:00	0.0	0	0	0	0	0
03/14/2022 04:00	0.0	0	0	0	0	0
03/14/2022 05:00	0.0	0	0	0	0	0
03/14/2022 06:00	0.0	0	0	0	0	0
03/14/2022 07:00	0.0	0	0	0	0	0
03/14/2022 08:00	0.0	0	0	0	0	0
03/14/2022 09:00	0.0	0	0	0	0	0
03/14/2022 10:00	0.0	0	0	0	0	0
03/14/2022 11:00	0.0	0	0	0	0	0
03/14/2022 12:00	0.0	0	0	0	0	0
03/14/2022 13:00	0.0	0	0	0	0	0
03/14/2022 14:00	0.0	0	0	0	0	0
03/14/2022 15:00	0.0	0	0	0	0	0
03/14/2022 16:00	0.0	0	0	0	0	0
03/14/2022 17:00	0.0	0	0	0	0	0
03/14/2022 18:00	0.0	0	0	0	0	0
03/14/2022 19:00	0.0	0	0	0	0	0
03/14/2022 20:00	0.0	0	0	0	0	0
03/14/2022 21:00	0.0	0	0	0	0	0
03/14/2022 22:00	0.0	0	0	0	0	0
03/14/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/15/2022 00:00	0.0	0	0	0	0	0
03/15/2022 01:00	0.0	0	0	0	0	0
03/15/2022 02:00	0.0	0	0	0	0	0
03/15/2022 03:00	0.0	0	0	0	0	0
03/15/2022 04:00	0.0	0	0	0	0	0
03/15/2022 05:00	0.0	0	0	0	0	0
03/15/2022 06:00	0.0	0	0	0	0	0
03/15/2022 07:00	0.0	0	0	0	0	0
03/15/2022 08:00	0.0	0	0	0	0	0
03/15/2022 09:00	0.0	0	0	0	0	0
03/15/2022 10:00	0.0	0	0	0	0	0
03/15/2022 11:00	0.0	0	0	0	0	0
03/15/2022 12:00	0.0	0	0	0	0	0
03/15/2022 13:00	0.0	0	0	0	0	0
03/15/2022 14:00	0.0	0	0	0	0	0
03/15/2022 15:00	0.0	0	0	0	0	0
03/15/2022 16:00	0.0	0	0	0	0	0
03/15/2022 17:00	0.0	0	0	0	0	0
03/15/2022 18:00	0.0	0	0	0	0	0
03/15/2022 19:00	0.0	0	0	0	0	0
03/15/2022 20:00	0.0	0	0	0	0	0
03/15/2022 21:00	0.0	0	0	0	0	0
03/15/2022 22:00	0.0	0	0	0	0	0
03/15/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/16/2022 00:00	0.0	0	0	0	0	0
03/16/2022 01:00	0.0	0	0	0	0	0
03/16/2022 02:00	0.0	0	0	0	0	0
03/16/2022 03:00	0.0	0	0	0	0	0
03/16/2022 04:00	0.0	0	0	0	0	0
03/16/2022 05:00	0.0	0	0	0	0	0
03/16/2022 06:00	0.0	0	0	0	0	0
03/16/2022 07:00	0.0	0	0	0	0	0
03/16/2022 08:00	0.0	0	0	0	0	0
03/16/2022 09:00	0.0	0	0	0	0	0
03/16/2022 10:00	0.0	0	0	0	0	0
03/16/2022 11:00	0.0	0	0	0	0	0
03/16/2022 12:00	0.0	0	0	0	0	0
03/16/2022 13:00	0.0	0	0	0	0	0
03/16/2022 14:00	0.0	0	0	0	0	0
03/16/2022 15:00	0.0	0	0	0	0	0
03/16/2022 16:00	0.0	0	0	0	0	0
03/16/2022 17:00	0.0	0	0	0	0	0
03/16/2022 18:00	0.0	0	0	0	0	0
03/16/2022 19:00	0.0	0	0	0	0	0
03/16/2022 20:00	0.0	0	0	0	0	0
03/16/2022 21:00	0.0	0	0	0	0	0
03/16/2022 22:00	0.0	0	0	0	0	0
03/16/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/17/2022 00:00	0.0	0	0	0	0	0
03/17/2022 01:00	0.0	0	0	0	0	0
03/17/2022 02:00	0.0	0	0	0	0	0
03/17/2022 03:00	0.0	0	0	0	0	0
03/17/2022 04:00	0.0	0	0	0	0	0
03/17/2022 05:00	0.0	0	0	0	0	0
03/17/2022 06:00	0.0	0	0	0	0	0
03/17/2022 07:00	0.0	0	0	0	0	0
03/17/2022 08:00	0.0	0	0	0	0	0
03/17/2022 09:00	0.0	0	0	0	0	0
03/17/2022 10:00	0.0	0	0	0	0	0
03/17/2022 11:00	0.0	0	0	0	0	0
03/17/2022 12:00	0.0	0	0	0	0	0
03/17/2022 13:00	0.0	0	0	0	0	0
03/17/2022 14:00	0.0	0	0	0	0	0
03/17/2022 15:00	0.0	0	0	0	0	0
03/17/2022 16:00	0.0	0	0	0	0	0
03/17/2022 17:00	0.0	0	0	0	0	0
03/17/2022 18:00	0.0	0	0	0	0	0
03/17/2022 19:00	0.0	0	0	0	0	0
03/17/2022 20:00	0.0	0	0	0	0	0
03/17/2022 21:00	0.0	0	0	0	0	0
03/17/2022 22:00	0.0	0	0	0	0	0
03/17/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/18/2022 00:00	0.0	0	0	0	0	0
03/18/2022 01:00	0.0	0	0	0	0	0
03/18/2022 02:00	0.0	0	0	0	0	0
03/18/2022 03:00	0.0	0	0	0	0	0
03/18/2022 04:00	0.0	0	0	0	0	0
03/18/2022 05:00	0.0	0	0	0	0	0
03/18/2022 06:00	0.0	0	0	0	0	0
03/18/2022 07:00	0.0	0	0	0	0	0
03/18/2022 08:00	0.0	0	0	0	0	0
03/18/2022 09:00	0.0	0	0	0	0	0
03/18/2022 10:00	0.0	0	0	0	0	0
03/18/2022 11:00	0.0	0	0	0	0	0
03/18/2022 12:00	0.0	0	0	0	0	0
03/18/2022 13:00	0.0	0	0	0	0	0
03/18/2022 14:00	0.0	0	0	0	0	0
03/18/2022 15:00	0.0	0	0	0	0	0
03/18/2022 16:00	0.0	0	0	0	0	0
03/18/2022 17:00	0.0	0	0	0	0	0
03/18/2022 18:00	0.0	0	0	0	0	0
03/18/2022 19:00	0.0	0	0	0	0	0
03/18/2022 20:00	0.0	0	0	0	0	0
03/18/2022 21:00	0.0	0	0	0	0	0
03/18/2022 22:00	0.0	0	0	0	0	0
03/18/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/19/2022 00:00	0.0	0	0	0	0	0
03/19/2022 01:00	0.0	0	0	0	0	0
03/19/2022 02:00	0.0	0	0	0	0	0
03/19/2022 03:00	0.0	0	0	0	0	0
03/19/2022 04:00	0.0	0	0	0	0	0
03/19/2022 05:00	0.0	0	0	0	0	0
03/19/2022 06:00	0.0	0	0	0	0	0
03/19/2022 07:00	0.0	0	0	0	0	0
03/19/2022 08:00	0.0	0	0	0	0	0
03/19/2022 09:00	0.0	0	0	0	0	0
03/19/2022 10:00	0.0	0	0	0	0	0
03/19/2022 11:00	0.0	0	0	0	0	0
03/19/2022 12:00	0.0	0	0	0	0	0
03/19/2022 13:00	0.0	0	0	0	0	0
03/19/2022 14:00	0.0	0	0	0	0	0
03/19/2022 15:00	0.0	0	0	0	0	0
03/19/2022 16:00	0.0	0	0	0	0	0
03/19/2022 17:00	0.0	0	0	0	0	0
03/19/2022 18:00	0.0	0	0	0	0	0
03/19/2022 19:00	0.0	0	0	0	0	0
03/19/2022 20:00	0.0	0	0	0	0	0
03/19/2022 21:00	0.0	0	0	0	0	0
03/19/2022 22:00	0.0	0	0	0	0	0
03/19/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/20/2022 00:00	0.0	0	0	0	0	0
03/20/2022 01:00	0.0	0	0	0	0	0
03/20/2022 02:00	0.0	0	0	0	0	0
03/20/2022 03:00	0.0	0	0	0	0	0
03/20/2022 04:00	0.0	0	0	0	0	0
03/20/2022 05:00	0.0	0	0	0	0	0
03/20/2022 06:00	0.0	0	0	0	0	0
03/20/2022 07:00	0.0	0	0	0	0	0
03/20/2022 08:00	0.0	0	0	0	0	0
03/20/2022 09:00	0.0	0	0	0	0	0
03/20/2022 10:00	0.0	0	0	0	0	0
03/20/2022 11:00	0.0	0	0	0	0	0
03/20/2022 12:00	0.0	0	0	0	0	0
03/20/2022 13:00	0.0	0	0	0	0	0
03/20/2022 14:00	0.0	0	0	0	0	0
03/20/2022 15:00	0.0	0	0	0	0	0
03/20/2022 16:00	0.0	0	0	0	0	0
03/20/2022 17:00	0.0	0	0	0	0	0
03/20/2022 18:00	0.0	0	0	0	0	0
03/20/2022 19:00	0.0	0	0	0	0	0
03/20/2022 20:00	0.0	0	0	0	0	0
03/20/2022 21:00	0.0	0	0	0	0	0
03/20/2022 22:00	0.0	0	0	0	0	0
03/20/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/21/2022 00:00	0.0	0	0	0	0	0
03/21/2022 01:00	0.0	0	0	0	0	0
03/21/2022 02:00	0.0	0	0	0	0	0
03/21/2022 03:00	0.0	0	0	0	0	0
03/21/2022 04:00	0.0	0	0	0	0	0
03/21/2022 05:00	0.0	0	0	0	0	0
03/21/2022 06:00	0.0	0	0	0	0	0
03/21/2022 07:00	0.0	0	0	0	0	0
03/21/2022 08:00	0.0	0	0	0	0	0
03/21/2022 09:00	0.0	0	0	0	0	0
03/21/2022 10:00	0.0	0	0	0	0	0
03/21/2022 11:00	0.0	0	0	0	0	0
03/21/2022 12:00	0.0	0	0	0	0	0
03/21/2022 13:00	0.0	0	0	0	0	0
03/21/2022 14:00	0.0	0	0	0	0	0
03/21/2022 15:00	0.0	0	0	0	0	0
03/21/2022 16:00	0.0	0	0	0	0	0
03/21/2022 17:00	0.0	0	0	0	0	0
03/21/2022 18:00	0.0	0	0	0	0	0
03/21/2022 19:00	0.0	0	0	0	0	0
03/21/2022 20:00	0.0	0	0	0	0	0
03/21/2022 21:00	0.0	0	0	0	0	0
03/21/2022 22:00	0.0	0	0	0	0	0
03/21/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/22/2022 00:00	0.0	0	0	0	0	0
03/22/2022 01:00	0.0	0	0	0	0	0
03/22/2022 02:00	0.0	0	0	0	0	0
03/22/2022 03:00	0.0	0	0	0	0	0
03/22/2022 04:00	0.0	0	0	0	0	0
03/22/2022 05:00	0.0	0	0	0	0	0
03/22/2022 06:00	0.0	0	0	0	0	0
03/22/2022 07:00	0.0	0	0	0	0	0
03/22/2022 08:00	0.0	0	0	0	0	0
03/22/2022 09:00	0.0	0	0	0	0	0
03/22/2022 10:00	0.0	0	0	0	0	0
03/22/2022 11:00	0.0	0	0	0	0	0
03/22/2022 12:00	0.0	0	0	0	0	0
03/22/2022 13:00	0.0	0	0	0	0	0
03/22/2022 14:00	0.0	0	0	0	0	0
03/22/2022 15:00	0.0	0	0	0	0	0
03/22/2022 16:00	0.0	0	0	0	0	0
03/22/2022 17:00	0.0	0	0	0	0	0
03/22/2022 18:00	0.0	0	0	0	0	0
03/22/2022 19:00	0.0	0	0	0	0	0
03/22/2022 20:00	0.0	0	0	0	0	0
03/22/2022 21:00	0.0	0	0	0	0	0
03/22/2022 22:00	0.0	0	0	0	0	0
03/22/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/23/2022 00:00	0.0	0	0	0	0	0
03/23/2022 01:00	0.0	0	0	0	0	0
03/23/2022 02:00	0.0	0	0	0	0	0
03/23/2022 03:00	0.0	0	0	0	0	0
03/23/2022 04:00	0.0	0	0	0	0	0
03/23/2022 05:00	0.0	0	0	0	0	0
03/23/2022 06:00	0.0	0	0	0	0	0
03/23/2022 07:00	0.0	0	0	0	0	0
03/23/2022 08:00	0.0	0	0	0	0	0
03/23/2022 09:00	0.0	0	0	0	0	0
03/23/2022 10:00	0.0	0	0	0	0	0
03/23/2022 11:00	0.0	0	0	0	0	0
03/23/2022 12:00	0.0	0	0	0	0	0
03/23/2022 13:00	0.0	0	0	0	0	0
03/23/2022 14:00	0.0	0	0	0	0	0
03/23/2022 15:00	0.0	0	0	0	0	0
03/23/2022 16:00	0.0	0	0	0	0	0
03/23/2022 17:00	0.0	0	0	0	0	0
03/23/2022 18:00	0.0	0	0	0	0	0
03/23/2022 19:00	0.0	0	0	0	0	0
03/23/2022 20:00	0.0	0	0	0	0	0
03/23/2022 21:00	0.0	0	0	0	0	0
03/23/2022 22:00	0.0	0	0	0	0	0
03/23/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/24/2022 00:00	0.0	0	0	0	0	0
03/24/2022 01:00	0.0	0	0	0	0	0
03/24/2022 02:00	0.0	0	0	0	0	0
03/24/2022 03:00	0.0	0	0	0	0	0
03/24/2022 04:00	0.0	0	0	0	0	0
03/24/2022 05:00	0.0	0	0	0	0	0
03/24/2022 06:00	0.0	0	0	0	0	0
03/24/2022 07:00	0.0	0	0	0	0	0
03/24/2022 08:00	0.0	0	0	0	0	0
03/24/2022 09:00	0.0	0	0	0	0	0
03/24/2022 10:00	0.0	0	0	0	0	0
03/24/2022 11:00	0.0	0	0	0	0	0
03/24/2022 12:00	0.0	0	0	0	0	0
03/24/2022 13:00	0.0	0	0	0	0	0
03/24/2022 14:00	0.0	0	0	0	0	0
03/24/2022 15:00	0.0	0	0	0	0	0
03/24/2022 16:00	0.0	0	0	0	0	0
03/24/2022 17:00	0.0	0	0	0	0	0
03/24/2022 18:00	0.0	0	0	0	0	0
03/24/2022 19:00	0.0	0	0	0	0	0
03/24/2022 20:00	0.0	0	0	0	0	0
03/24/2022 21:00	0.0	0	0	0	0	0
03/24/2022 22:00	0.0	0	0	0	0	0
03/24/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/25/2022 00:00	0.0	0	0	0	0	0
03/25/2022 01:00	0.0	0	0	0	0	0
03/25/2022 02:00	0.0	0	0	0	0	0
03/25/2022 03:00	0.0	0	0	0	0	0
03/25/2022 04:00	0.0	0	0	0	0	0
03/25/2022 05:00	0.0	0	0	0	0	0
03/25/2022 06:00	0.0	0	0	0	0	0
03/25/2022 07:00	0.0	0	0	0	0	0
03/25/2022 08:00	0.0	0	0	0	0	0
03/25/2022 09:00	0.0	0	0	0	0	0
03/25/2022 10:00	0.0	0	0	0	0	0
03/25/2022 11:00	0.0	0	0	0	0	0
03/25/2022 12:00	0.0	0	0	0	0	0
03/25/2022 13:00	0.0	0	0	0	0	0
03/25/2022 14:00	0.0	0	0	0	0	0
03/25/2022 15:00	0.0	0	0	0	0	0
03/25/2022 16:00	0.0	0	0	0	0	0
03/25/2022 17:00	0.0	0	0	0	0	0
03/25/2022 18:00	0.0	0	0	0	0	0
03/25/2022 19:00	0.0	0	0	0	0	0
03/25/2022 20:00	0.0	0	0	0	0	0
03/25/2022 21:00	0.0	0	0	0	0	0
03/25/2022 22:00	0.0	0	0	0	0	0
03/25/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/26/2022 00:00	0.0	0	0	0	0	0
03/26/2022 01:00	0.0	0	0	0	0	0
03/26/2022 02:00	0.0	0	0	0	0	0
03/26/2022 03:00	0.0	0	0	0	0	0
03/26/2022 04:00	0.0	0	0	0	0	0
03/26/2022 05:00	0.0	0	0	0	0	0
03/26/2022 06:00	0.0	0	0	0	0	0
03/26/2022 07:00	0.0	0	0	0	0	0
03/26/2022 08:00	0.0	0	0	0	0	0
03/26/2022 09:00	0.0	0	0	0	0	0
03/26/2022 10:00	0.0	0	0	0	0	0
03/26/2022 11:00	0.0	0	0	0	0	0
03/26/2022 12:00	0.0	0	0	0	0	0
03/26/2022 13:00	0.0	0	0	0	0	0
03/26/2022 14:00	0.0	0	0	0	0	0
03/26/2022 15:00	0.0	0	0	0	0	0
03/26/2022 16:00	0.0	0	0	0	0	0
03/26/2022 17:00	0.0	0	0	0	0	0
03/26/2022 18:00	0.0	0	0	0	0	0
03/26/2022 19:00	0.0	0	0	0	0	0
03/26/2022 20:00	0.0	0	0	0	0	0
03/26/2022 21:00	0.0	0	0	0	0	0
03/26/2022 22:00	0.0	0	0	0	0	0
03/26/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/27/2022 00:00	0.0	0	0	0	0	0
03/27/2022 01:00	0.0	0	0	0	0	0
03/27/2022 02:00	0.0	0	0	0	0	0
03/27/2022 03:00	0.0	0	0	0	0	0
03/27/2022 04:00	0.0	0	0	0	0	0
03/27/2022 05:00	0.0	0	0	0	0	0
03/27/2022 06:00	0.0	0	0	0	0	0
03/27/2022 07:00	0.0	0	0	0	0	0
03/27/2022 08:00	0.0	0	0	0	0	0
03/27/2022 09:00	0.0	0	0	0	0	0
03/27/2022 10:00	0.0	0	0	0	0	0
03/27/2022 11:00	0.0	0	0	0	0	0
03/27/2022 12:00	0.0	0	0	0	0	0
03/27/2022 13:00	0.0	0	0	0	0	0
03/27/2022 14:00	0.0	0	0	0	0	0
03/27/2022 15:00	0.0	0	0	0	0	0
03/27/2022 16:00	0.0	0	0	0	0	0
03/27/2022 17:00	0.0	0	0	0	0	0
03/27/2022 18:00	0.0	0	0	0	0	0
03/27/2022 19:00	0.0	0	0	0	0	0
03/27/2022 20:00	0.0	0	0	0	0	0
03/27/2022 21:00	0.0	0	0	0	0	0
03/27/2022 22:00	0.0	0	0	0	0	0
03/27/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/28/2022 00:00	0.0	0	0	0	0	0
03/28/2022 01:00	0.0	0	0	0	0	0
03/28/2022 02:00	0.0	0	0	0	0	0
03/28/2022 03:00	0.0	0	0	0	0	0
03/28/2022 04:00	0.0	0	0	0	0	0
03/28/2022 05:00	0.0	0	0	0	0	0
03/28/2022 06:00	0.0	0	0	0	0	0
03/28/2022 07:00	0.0	0	0	0	0	0
03/28/2022 08:00	0.0	0	0	0	0	0
03/28/2022 09:00	0.0	0	0	0	0	0
03/28/2022 10:00	0.0	0	0	0	0	0
03/28/2022 11:00	0.0	0	0	0	0	0
03/28/2022 12:00	0.0	0	0	0	0	0
03/28/2022 13:00	0.0	0	0	0	0	0
03/28/2022 14:00	0.0	0	0	0	0	0
03/28/2022 15:00	0.0	0	0	0	0	0
03/28/2022 16:00	0.0	0	0	0	0	0
03/28/2022 17:00	0.0	0	0	0	0	0
03/28/2022 18:00	0.0	0	0	0	0	0
03/28/2022 19:00	0.0	0	0	0	0	0
03/28/2022 20:00	0.0	0	0	0	0	0
03/28/2022 21:00	0.0	0	0	0	0	0
03/28/2022 22:00	0.0	0	0	0	0	0
03/28/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/29/2022 00:00	0.0	0	0	0	0	0
03/29/2022 01:00	0.0	0	0	0	0	0
03/29/2022 02:00	0.0	0	0	0	0	0
03/29/2022 03:00	0.0	0	0	0	0	0
03/29/2022 04:00	0.0	0	0	0	0	0
03/29/2022 05:00	0.0	0	0	0	0	0
03/29/2022 06:00	0.0	0	0	0	0	0
03/29/2022 07:00	0.0	0	0	0	0	0
03/29/2022 08:00	0.0	0	0	0	0	0
03/29/2022 09:00	0.0	0	0	0	0	0
03/29/2022 10:00	0.0	0	0	0	0	0
03/29/2022 11:00	0.0	0	0	0	0	0
03/29/2022 12:00	0.0	0	0	0	0	0
03/29/2022 13:00	0.0	0	0	0	0	0
03/29/2022 14:00	0.0	0	0	0	0	0
03/29/2022 15:00	0.0	0	0	0	0	0
03/29/2022 16:00	0.0	0	0	0	0	0
03/29/2022 17:00	0.0	0	0	0	0	0
03/29/2022 18:00	0.0	0	0	0	0	0
03/29/2022 19:00	0.0	0	0	0	0	0
03/29/2022 20:00	0.0	0	0	0	0	0
03/29/2022 21:00	0.0	0	0	0	0	0
03/29/2022 22:00	0.0	0	0	0	0	0
03/29/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/30/2022 00:00	0.0	0	0	0	0	0
03/30/2022 01:00	0.0	0	0	0	0	0
03/30/2022 02:00	0.0	0	0	0	0	0
03/30/2022 03:00	0.0	0	0	0	0	0
03/30/2022 04:00	0.0	0	0	0	0	0
03/30/2022 05:00	0.0	0	0	0	0	0
03/30/2022 06:00	0.0	0	0	0	0	0
03/30/2022 07:00	0.0	0	0	0	0	0
03/30/2022 08:00	0.0	0	0	0	0	0
03/30/2022 09:00	0.0	0	0	0	0	0
03/30/2022 10:00	0.0	0	0	0	0	0
03/30/2022 11:00	0.0	0	0	0	0	0
03/30/2022 12:00	0.0	0	0	0	0	0
03/30/2022 13:00	0.0	0	0	0	0	0
03/30/2022 14:00	0.0	0	0	0	0	0
03/30/2022 15:00	0.0	0	0	0	0	0
03/30/2022 16:00	0.0	0	0	0	0	0
03/30/2022 17:00	0.0	0	0	0	0	0
03/30/2022 18:00	0.0	0	0	0	0	0
03/30/2022 19:00	0.0	0	0	0	0	0
03/30/2022 20:00	0.0	0	0	0	0	0
03/30/2022 21:00	0.0	0	0	0	0	0
03/30/2022 22:00	0.0	0	0	0	0	0
03/30/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:47 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/31/2022 00:00	0.0	0	0	0	0	0
03/31/2022 01:00	0.0	0	0	0	0	0
03/31/2022 02:00	0.0	0	0	0	0	0
03/31/2022 03:00	0.0	0	0	0	0	0
03/31/2022 04:00	0.0	0	0	0	0	0
03/31/2022 05:00	0.0	0	0	0	0	0
03/31/2022 06:00	0.0	0	0	0	0	0
03/31/2022 07:00	0.0	0	0	0	0	0
03/31/2022 08:00	0.0	0	0	0	0	0
03/31/2022 09:00	0.0	0	0	0	0	0
03/31/2022 10:00	0.0	0	0	0	0	0
03/31/2022 11:00	0.0	0	0	0	0	0
03/31/2022 12:00	0.0	0	0	0	0	0
03/31/2022 13:00	0.0	0	0	0	0	0
03/31/2022 14:00	0.0	0	0	0	0	0
03/31/2022 15:00	0.0	0	0	0	0	0
03/31/2022 16:00	0.0	0	0	0	0	0
03/31/2022 17:00	0.0	0	0	0	0	0
03/31/2022 18:00	0.0	0	0	0	0	0
03/31/2022 19:00	0.0	0	0	0	0	0
03/31/2022 20:00	0.0	0	0	0	0	0
03/31/2022 21:00	0.0	0	0	0	0	0
03/31/2022 22:00	0.0	0	0	0	0	0
03/31/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Pound Per Hr Per Event Report

CT1 - CO LbPerHr



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION

Generated: 04/11/2022 09:48

Location: Maxwell, CA

Tag Name: CT1_CO_LbPerHr_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 937.60 Hours

Non-Operating Time: 1,222.40 Hours

Report Time: 2,160.00 Hours

Unit Operation and Excess Events

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description
01/07/2022 22:24 01/07/2022 22:29 Shut Down - Gas	6	0.8	483.5		
01/08/2022 10:30 01/08/2022 12:49 Warm Start - Gas	140	116.0	790.5		
01/13/2022 23:23 01/13/2022 23:28 Shut Down - Gas	6	0.8	483.5		
01/14/2022 04:42 01/14/2022 05:54 Hot Start - Gas	73	80.1	679.6		
01/14/2022 23:23 01/14/2022 23:28 Shut Down - Gas	6	1.2	483.5		
01/15/2022 04:46 01/15/2022 05:55 Hot Start - Gas	70	90.4	679.6		
01/15/2022 23:39 01/15/2022 23:43 Shut Down - Gas	5	0.7	483.5		
01/16/2022 11:01 01/16/2022 12:59 Warm Start - Gas	119	125.6	790.5		
01/20/2022 23:43 01/20/2022 23:48 Shut Down - Gas	6	0.7	483.5		
01/23/2022 11:15 01/23/2022 13:55 Warm Start - Gas	161	142.3	790.5		
01/23/2022 23:23 01/23/2022 23:28 Shut Down - Gas	6	0.9	483.5		
01/24/2022 03:49 01/24/2022 04:50 Hot Start - Gas	62	99.3	679.6		
01/25/2022 08:40 01/25/2022 08:44 Shut Down - Gas	5	0.4	483.5		

Pound Per Hr Per Event Report

CT1 - CO LbPerHr



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION

Generated: 04/11/2022 09:48

Location: Maxwell, CA

Tag Name: CT1_CO_LbPerHr_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 937.60 Hours

Non-Operating Time: 1,222.40 Hours

Report Time: 2,160.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description
01/25/2022 15:32 01/25/2022 16:43 Hot Start - Gas	72	60.8	679.6		
01/26/2022 08:38 01/26/2022 08:43 Shut Down - Gas	6	1.0	483.5		
01/26/2022 15:32 01/26/2022 16:42 Hot Start - Gas	71	64.4	679.6		
01/27/2022 10:20 01/27/2022 10:25 Shut Down - Gas	6	1.1	483.5		
01/27/2022 15:32 01/27/2022 16:43 Hot Start - Gas	72	60.1	679.6		
01/30/2022 07:40 01/30/2022 07:45 Shut Down - Gas	6	0.7	483.5		
01/31/2022 02:17 01/31/2022 03:49 Warm Start - Gas	93	126.3	790.5		
01/31/2022 23:23 01/31/2022 23:28 Shut Down - Gas	6	1.0	483.5		
02/01/2022 05:07 02/01/2022 06:28 Hot Start - Gas	82	126.0	679.6		
02/02/2022 10:19 02/02/2022 10:24 Shut Down - Gas	6	1.4	483.5		
02/02/2022 15:46 02/02/2022 17:03 Hot Start - Gas	78	146.4	679.6		
02/04/2022 08:23 02/04/2022 08:28 Shut Down - Gas	6	0.7	483.5		
02/04/2022 16:01 02/04/2022 17:11 Hot Start - Gas	71	203.5	679.6		
02/05/2022 08:24 02/05/2022 08:29 Shut Down - Gas	6	1.3	483.5		

Pound Per Hr Per Event Report

CT1 - CO LbPerHr



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION

Generated: 04/11/2022 09:48

Location: Maxwell, CA

Tag Name: CT1_CO_LbPerHr_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 937.60 Hours

Non-Operating Time: 1,222.40 Hours

Report Time: 2,160.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description
02/05/2022 13:37 02/05/2022 14:49 Hot Start - Gas	73	76.0	679.6		
02/06/2022 08:06 02/06/2022 08:10 Shut Down - Gas	5	0.6	483.5		
02/06/2022 14:33 02/06/2022 15:49 Hot Start - Gas	77	79.0	679.6		
02/06/2022 23:05 02/06/2022 23:10 Shut Down - Gas	6	2.0	483.5		
02/07/2022 11:18 02/07/2022 13:51 Warm Start - Gas	154	164.0	790.5		
02/07/2022 23:23 02/07/2022 23:28 Shut Down - Gas	6	1.1	483.5		
02/08/2022 03:18 02/08/2022 04:24 Hot Start - Gas	67	62.1	679.6		
02/10/2022 08:08 02/10/2022 08:13 Shut Down - Gas	6	1.4	483.5		
02/10/2022 11:50 02/10/2022 12:54 Hot Start - Gas	65	74.5	679.6		
02/11/2022 01:04 02/11/2022 01:09 Shut Down - Gas	6	1.2	483.5		
02/18/2022 08:50 02/18/2022 12:43 Cold Start - Gas	234	325.6	1,355.6		
02/19/2022 00:24 02/19/2022 00:28 Shut Down - Gas	5	0.3	483.5		
02/21/2022 23:18 02/22/2022 01:58 Warm Start - Gas	161	166.5	790.5		
02/26/2022 07:23 02/26/2022 07:28 Shut Down - Gas	6	1.1	483.5		

Pound Per Hr Per Event Report

CT1 - CO LbPerHr



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION

Generated: 04/11/2022 09:48 Location: Maxwell, CA

Tag Name: CT1_CO_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 937.60 Hours

Non-Operating Time: 1,222.40 Hours Report Time: 2,160.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description
02/26/2022 15:37 02/26/2022 16:51 Warm Start - Gas	75	111.3	790.5		
02/26/2022 23:24 02/26/2022 23:28 Shut Down - Gas	5	0.9	483.5		
02/28/2022 13:13 02/28/2022 15:49 Warm Start - Gas	157	136.8	790.5		
02/28/2022 22:08 02/28/2022 22:13 Shut Down - Gas	6	1.7	483.5		

No excess emissions were found in the reporting period.

Pound Per Hr Per Event Report
CT1 - CO LbPerHr



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 09:48 Location: Maxwell, CA
Tag Name: CT1_CO_LbPerHr_1M SI = SampleInvalid, * = Excess Emission
Total Operating Time: 937.60 Hours
Non-Operating Time: 1,222.40 Hours Report Time: 2,160.00 Hours

Event Invalid Information

No invalid events were found in the reporting period.

Pound Per Hr Per Event Report

CT1 - CO LbPerHr



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION

Generated: 04/11/2022 09:48 Location: Maxwell, CA

Tag Name: CT1_CO_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 937.60 Hours

Non-Operating Time: 1,222.40 Hours Report Time: 2,160.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary

1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary

1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime in Minute(s)	0
3. Total Downtime as a percentage of operating time	0.00
4. Total Availability as a percentage of operating time	100.00

Pound Per Event Report

CT1 - NOx Lbs



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION

Generated: 04/11/2022 09:49 Location: Maxwell, CA

Tag Name: CT1_NOx_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 937.60 Hours
Non-Operating Time: 1,222.40 Hours Report Time: 2,160.00 Hours

Unit Operation and Excess Events

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
01/07/2022 22:24 01/07/2022 22:29 Shut Down - Gas	6	0.10	115.00		
01/08/2022 10:30 01/08/2022 12:49 Warm Start - Gas	140	79.75	456.20		
01/13/2022 23:23 01/13/2022 23:28 Shut Down - Gas	6	0.16	115.00		
01/14/2022 04:42 01/14/2022 05:54 Hot Start - Gas	73	28.35	259.90		
01/14/2022 23:23 01/14/2022 23:28 Shut Down - Gas	6	0.14	115.00		
01/15/2022 04:46 01/15/2022 05:55 Hot Start - Gas	70	29.88	259.90		
01/15/2022 23:39 01/15/2022 23:43 Shut Down - Gas	5	0.07	115.00		
01/16/2022 11:01 01/16/2022 12:59 Warm Start - Gas	119	77.84	456.20		
01/20/2022 23:43 01/20/2022 23:48 Shut Down - Gas	6	0.11	115.00		
01/23/2022 11:15 01/23/2022 13:55 Warm Start - Gas	161	141.91	456.20		
01/23/2022 23:23 01/23/2022 23:28 Shut Down - Gas	6	0.12	115.00		
01/24/2022 03:49 01/24/2022 04:50 Hot Start - Gas	62	26.01	259.90		
01/25/2022 08:40 01/25/2022 08:44 Shut Down - Gas	5	0.09	115.00		

Pound Per Event Report

CT1 - NOx Lbs



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION

Generated: 04/11/2022 09:49 Location: Maxwell, CA

Tag Name: CT1_NOx_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 937.60 Hours
Non-Operating Time: 1,222.40 Hours Report Time: 2,160.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
01/25/2022 15:32 01/25/2022 16:43 Hot Start - Gas	72	44.17	259.90		
01/26/2022 08:38 01/26/2022 08:43 Shut Down - Gas	6	0.16	115.00		
01/26/2022 15:32 01/26/2022 16:42 Hot Start - Gas	71	34.62	259.90		
01/27/2022 10:20 01/27/2022 10:25 Shut Down - Gas	6	0.15	115.00		
01/27/2022 15:32 01/27/2022 16:43 Hot Start - Gas	72	31.74	259.90		
01/30/2022 07:40 01/30/2022 07:45 Shut Down - Gas	6	0.10	115.00		
01/31/2022 02:17 01/31/2022 03:49 Warm Start - Gas	93	87.96	456.20		
01/31/2022 23:23 01/31/2022 23:28 Shut Down - Gas	6	0.14	115.00		
02/01/2022 05:07 02/01/2022 06:28 Hot Start - Gas	82	54.16	259.90		
02/02/2022 10:19 02/02/2022 10:24 Shut Down - Gas	6	0.24	115.00		
02/02/2022 15:46 02/02/2022 17:03 Hot Start - Gas	78	49.29	259.90		
02/04/2022 08:23 02/04/2022 08:28 Shut Down - Gas	6	0.14	115.00		
02/04/2022 16:01 02/04/2022 17:11 Hot Start - Gas	71	72.54	259.90		
02/05/2022 08:24 02/05/2022 08:29 Shut Down - Gas	6	0.22	115.00		

Pound Per Event Report

CT1 - NOx Lbs



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION

Generated: 04/11/2022 09:49 Location: Maxwell, CA

Tag Name: CT1_NOx_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 937.60 Hours
Non-Operating Time: 1,222.40 Hours Report Time: 2,160.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
02/05/2022 13:37 02/05/2022 14:49 Hot Start - Gas	73	45.99	259.90		
02/06/2022 08:06 02/06/2022 08:10 Shut Down - Gas	5	0.08	115.00		
02/06/2022 14:33 02/06/2022 15:49 Hot Start - Gas	77	44.53	259.90		
02/06/2022 23:05 02/06/2022 23:10 Shut Down - Gas	6	0.17	115.00		
02/07/2022 11:18 02/07/2022 13:51 Warm Start - Gas	154	84.79	456.20		
02/07/2022 23:23 02/07/2022 23:28 Shut Down - Gas	6	0.16	115.00		
02/08/2022 03:18 02/08/2022 04:24 Hot Start - Gas	67	24.82	259.90		
02/10/2022 08:08 02/10/2022 08:13 Shut Down - Gas	6	0.23	115.00		
02/10/2022 11:50 02/10/2022 12:54 Hot Start - Gas	65	30.14	259.90		
02/11/2022 01:04 02/11/2022 01:09 Shut Down - Gas	6	0.15	115.00		
02/18/2022 08:50 02/18/2022 12:43 Cold Start - Gas	234	201.41	779.10		
02/19/2022 00:24 02/19/2022 00:28 Shut Down - Gas	5	0.05	115.00		
02/21/2022 23:18 02/22/2022 01:58 Warm Start - Gas	161	126.09	456.20		
02/26/2022 07:23 02/26/2022 07:28 Shut Down - Gas	6	0.27	115.00		

Pound Per Event Report

CT1 - NOx Lbs



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION

Generated: 04/11/2022 09:49 Location: Maxwell, CA

Tag Name: CT1_NOx_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 937.60 Hours

Non-Operating Time: 1,222.40 Hours

Report Time: 2,160.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
02/26/2022 15:37 02/26/2022 16:51 Warm Start - Gas	75	66.10	456.20		
02/26/2022 23:24 02/26/2022 23:28 Shut Down - Gas	5	0.16	115.00		
02/28/2022 13:13 02/28/2022 15:49 Warm Start - Gas	157	125.27	456.20		
02/28/2022 22:08 02/28/2022 22:13 Shut Down - Gas	6	0.14	115.00		

No excess emissions were found in the reporting period.

Pound Per Event Report

CT1 - NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:49 **Location:** Maxwell, CA
Tag Name: CT1_NOx_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission
Total Operating Time: 937.60 Hours
Non-Operating Time: 1,222.40 Hours Report Time: 2,160.00 Hours

Event Invalid Information

No invalid events were found in the reporting period.

Pound Per Event Report

CT1 - NOx Lbs



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION

Generated: 04/11/2022 09:49 Location: Maxwell, CA

Tag Name: CT1_NOx_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 937.60 Hours

Non-Operating Time: 1,222.40 Hours Report Time: 2,160.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary

1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary

1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime in Minute(s)	0
3. Total Downtime as a percentage of operating time	0.00
4. Total Availability as a percentage of operating time	100.00

100scf Per Event Report

CT2 - GasFlowTotal 100scf



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION

Generated: 04/11/2022 09:50 Location: Maxwell, CA

Tag Name: CT2_GasFlowTot_Event_100scf_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 825.67 Hours

Non-Operating Time: 1,334.33 Hours Report Time: 2,160.00 Hours

Unit Operation and Excess Events

Event Period			Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Code - Description	Code - Description
01/01/2022 09:19 01/01/2022 09:24 Shut Down - Gas	6	0.9		
01/01/2022 16:42 01/01/2022 17:52 Hot Start - Gas	71	118.9		
01/02/2022 09:19 01/02/2022 09:24 Shut Down - Gas	6	0.8		
01/02/2022 16:42 01/02/2022 17:50 Hot Start - Gas	69	112.5		
01/07/2022 22:24 01/07/2022 22:29 Shut Down - Gas	6	0.7		
01/08/2022 15:06 01/08/2022 16:36 Warm Start - Gas	91	136.0		
01/10/2022 01:49 01/10/2022 01:54 Shut Down - Gas	6	0.7		
01/10/2022 06:17 01/10/2022 07:29 Hot Start - Gas	73	124.9		
01/12/2022 00:19 01/12/2022 00:23 Shut Down - Gas	5	0.5		
01/12/2022 09:40 01/12/2022 10:58 Warm Start - Gas	79	136.2		
01/13/2022 23:23 01/13/2022 23:28 Shut Down - Gas	6	0.5		
01/14/2022 13:18 01/14/2022 14:40 Warm Start - Gas	83	123.8		
01/14/2022 23:23 01/14/2022 23:28 Shut Down - Gas	6	0.8		

100scf Per Event Report

CT2 - GasFlowTotal 100scf



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION

Generated: 04/11/2022 09:50 Location: Maxwell, CA

Tag Name: CT2_GasFlowTot_Event_100scf_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 825.67 Hours

Non-Operating Time: 1,334.33 Hours Report Time: 2,160.00 Hours

Event Period			Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Code - Description	Code - Description
01/15/2022 14:06 01/15/2022 15:41 Warm Start - Gas	96	145.3		
01/15/2022 23:39 01/15/2022 23:43 Shut Down - Gas	5	0.6		
01/16/2022 15:35 01/16/2022 17:05 Warm Start - Gas	91	141.6		
01/20/2022 09:21 01/20/2022 09:25 Shut Down - Gas	5	0.6		
01/20/2022 16:28 01/20/2022 17:36 Hot Start - Gas	69	115.0		
01/20/2022 23:23 01/20/2022 23:27 Shut Down - Gas	5	0.5		
01/23/2022 16:32 01/23/2022 17:58 Warm Start - Gas	87	140.6		
01/23/2022 23:23 01/23/2022 23:28 Shut Down - Gas	6	0.7		
01/24/2022 14:05 01/24/2022 15:35 Warm Start - Gas	91	138.5		
01/25/2022 08:40 01/25/2022 08:44 Shut Down - Gas	5	0.3		
01/25/2022 11:47 01/25/2022 12:50 Hot Start - Gas	64	98.7		
01/26/2022 08:38 01/26/2022 08:43 Shut Down - Gas	6	0.6		
01/26/2022 11:47 01/26/2022 12:49 Hot Start - Gas	63	99.2		
01/30/2022 07:40 01/30/2022 07:45 Shut Down - Gas	6	0.7		

100scf Per Event Report

CT2 - GasFlowTotal 100scf



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION

Generated: 04/11/2022 09:50

Location: Maxwell, CA

Tag Name: CT2_GasFlowTot_Event_100scf_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 825.67 Hours

Non-Operating Time: 1,334.33 Hours

Report Time: 2,160.00 Hours

Event Period			Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Code - Description	Code - Description
01/30/2022 14:46 01/30/2022 15:54 Hot Start - Gas	69	118.9		
01/31/2022 23:23 01/31/2022 23:28 Shut Down - Gas	6	0.8		
02/01/2022 03:05 02/01/2022 04:17 Hot Start - Gas	73	117.4		
02/04/2022 08:23 02/04/2022 08:28 Shut Down - Gas	6	0.7		
02/04/2022 11:29 02/04/2022 12:49 Hot Start - Gas	81	128.9		
02/05/2022 08:23 02/05/2022 08:28 Shut Down - Gas	6	1.3		
02/05/2022 17:33 02/05/2022 18:56 Warm Start - Gas	84	124.2		
02/06/2022 08:06 02/06/2022 08:10 Shut Down - Gas	5	0.4		
02/07/2022 16:18 02/07/2022 17:50 Warm Start - Gas	93	138.0		
02/07/2022 23:23 02/07/2022 23:28 Shut Down - Gas	6	0.8		
02/08/2022 05:25 02/08/2022 06:44 Hot Start - Gas	80	121.0		
02/08/2022 22:19 02/08/2022 22:24 Shut Down - Gas	6	0.5		
02/09/2022 16:08 02/09/2022 17:05 Warm Start - Gas	58	91.9		
02/10/2022 08:08 02/10/2022 08:13 Shut Down - Gas	6	1.0		

100scf Per Event Report

CT2 - GasFlowTotal 100scf



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION

Generated: 04/11/2022 09:50 Location: Maxwell, CA

Tag Name: CT2_GasFlowTot_Event_100scf_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 825.67 Hours

Non-Operating Time: 1,334.33 Hours Report Time: 2,160.00 Hours

Event Period			Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Code - Description	Code - Description
02/10/2022 15:51 02/10/2022 16:55 Hot Start - Gas	65	114.6		
02/11/2022 01:03 02/11/2022 01:07 Shut Down - Gas	5	0.6		
02/18/2022 15:04 02/18/2022 16:53 Cold Start - Gas	110	170.7		
02/19/2022 00:23 02/19/2022 00:28 Shut Down - Gas	6	0.9		
02/22/2022 04:27 02/22/2022 05:50 Cold Start - Gas	84	126.9		
02/26/2022 07:23 02/26/2022 07:28 Shut Down - Gas	6	0.7		

No excess emissions were found in the reporting period.

100scf Per Event Report

CT2 - GasFlowTotal 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:50 **Location:** Maxwell, CA
Tag Name: CT2_GasFlowTot_Event_100scf_1M SI = SampleInvalid, * = Excess Emission
Total Operating Time: 825.67 Hours
Non-Operating Time: 1,334.33 Hours Report Time: 2,160.00 Hours

Event Invalid Information

No invalid events were found in the reporting period.

100scf Per Event Report

CT2 - GasFlowTotal 100scf



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION

Generated: 04/11/2022 09:50 Location: Maxwell, CA

Tag Name: CT2_GasFlowTot_Event_100scf_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 825.67 Hours

Non-Operating Time: 1,334.33 Hours Report Time: 2,160.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary

1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary

1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime in Minute(s)	0
3. Total Downtime as a percentage of operating time	0.00
4. Total Availability as a percentage of operating time	100.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/01/2022 00:00	0.0	0	0	0	0	1
01/01/2022 01:00	0.0	0	0	0	0	1
01/01/2022 02:00	0.0	0	0	0	0	1
01/01/2022 03:00	0.0	0	0	0	0	1
01/01/2022 04:00	0.0	0	0	0	0	1
01/01/2022 05:00	0.0	0	0	0	0	1
01/01/2022 06:00	0.0	0	0	0	0	1
01/01/2022 07:00	0.0	0	0	0	0	1
01/01/2022 08:00	0.0	0	0	0	0	1
01/01/2022 09:00	0.0	0	0	0	0	1
01/01/2022 10:00	0.0	0	0	0	0	1
01/01/2022 11:00	0.0	0	0	0	0	1
01/01/2022 12:00	0.0	0	0	0	0	1
01/01/2022 13:00	0.0	0	0	0	0	1
01/01/2022 14:00	0.0	0	0	0	0	1
01/01/2022 15:00	0.0	0	0	0	0	1
01/01/2022 16:00	0.0	0	0	0	0	1
01/01/2022 17:00	0.0	0	0	0	0	1
01/01/2022 18:00	0.0	0	0	0	0	1
01/01/2022 19:00	0.0	0	0	0	0	1
01/01/2022 20:00	0.0	0	0	0	0	1
01/01/2022 21:00	0.0	0	0	0	0	1
01/01/2022 22:00	0.0	0	0	0	0	1
01/01/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/02/2022 00:00	0.0	0	0	0	0	1
01/02/2022 01:00	0.0	0	0	0	0	1
01/02/2022 02:00	0.0	0	0	0	0	1
01/02/2022 03:00	0.0	0	0	0	0	1
01/02/2022 04:00	0.0	0	0	0	0	1
01/02/2022 05:00	0.0	0	0	0	0	1
01/02/2022 06:00	0.0	0	0	0	0	1
01/02/2022 07:00	0.0	0	0	0	0	1
01/02/2022 08:00	0.0	0	0	0	0	1
01/02/2022 09:00	0.0	0	0	0	0	1
01/02/2022 10:00	0.0	0	0	0	0	1
01/02/2022 11:00	0.0	0	0	0	0	1
01/02/2022 12:00	0.0	0	0	0	0	1
01/02/2022 13:00	0.0	0	0	0	0	1
01/02/2022 14:00	0.0	0	0	0	0	1
01/02/2022 15:00	0.0	0	0	0	0	1
01/02/2022 16:00	0.0	0	0	0	0	1
01/02/2022 17:00	0.0	0	0	0	0	1
01/02/2022 18:00	0.0	0	0	0	0	1
01/02/2022 19:00	0.0	0	0	0	0	1
01/02/2022 20:00	0.0	0	0	0	0	1
01/02/2022 21:00	0.0	0	0	0	0	1
01/02/2022 22:00	0.0	0	0	0	0	1
01/02/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/03/2022 00:00	0.0	0	0	0	0	1
01/03/2022 01:00	0.0	0	0	0	0	1
01/03/2022 02:00	0.0	0	0	0	0	1
01/03/2022 03:00	0.0	0	0	0	0	1
01/03/2022 04:00	0.0	0	0	0	0	1
01/03/2022 05:00	0.0	0	0	0	0	1
01/03/2022 06:00	0.0	0	0	0	0	1
01/03/2022 07:00	0.0	0	0	0	0	1
01/03/2022 08:00	0.0	0	0	0	0	1
01/03/2022 09:00	0.0	0	0	0	0	1
01/03/2022 10:00	0.0	0	0	0	0	1
01/03/2022 11:00	0.0	0	0	0	0	1
01/03/2022 12:00	0.0	0	0	0	0	1
01/03/2022 13:00	0.0	0	0	0	0	1
01/03/2022 14:00	0.0	0	0	0	0	1
01/03/2022 15:00	0.0	0	0	0	0	1
01/03/2022 16:00	0.0	0	0	0	0	1
01/03/2022 17:00	0.0	0	0	0	0	1
01/03/2022 18:00	0.0	0	0	0	0	1
01/03/2022 19:00	0.0	0	0	0	0	1
01/03/2022 20:00	0.0	0	0	0	0	1
01/03/2022 21:00	0.0	0	0	0	0	1
01/03/2022 22:00	0.0	0	0	0	0	1
01/03/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/04/2022 00:00	0.0	0	0	0	0	1
01/04/2022 01:00	0.0	0	0	0	0	1
01/04/2022 02:00	0.0	0	0	0	0	1
01/04/2022 03:00	0.0	0	0	0	0	1
01/04/2022 04:00	0.0	0	0	0	0	1
01/04/2022 05:00	0.0	0	0	0	0	1
01/04/2022 06:00	0.0	0	0	0	0	1
01/04/2022 07:00	0.0	0	0	0	0	1
01/04/2022 08:00	0.0	0	0	0	0	1
01/04/2022 09:00	0.0	0	0	0	0	1
01/04/2022 10:00	0.0	0	0	0	0	1
01/04/2022 11:00	0.0	0	0	0	0	1
01/04/2022 12:00	0.0	0	0	0	0	1
01/04/2022 13:00	0.0	0	0	0	0	1
01/04/2022 14:00	0.0	0	0	0	0	1
01/04/2022 15:00	0.0	0	0	0	0	1
01/04/2022 16:00	0.0	0	0	0	0	1
01/04/2022 17:00	0.0	0	0	0	0	1
01/04/2022 18:00	0.0	0	0	0	0	1
01/04/2022 19:00	0.0	0	0	0	0	1
01/04/2022 20:00	0.0	0	0	0	0	1
01/04/2022 21:00	0.0	0	0	0	0	1
01/04/2022 22:00	0.0	0	0	0	0	1
01/04/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/05/2022 00:00	0.0	0	0	0	0	1
01/05/2022 01:00	0.0	0	0	0	0	1
01/05/2022 02:00	0.0	0	0	0	0	1
01/05/2022 03:00	0.0	0	0	0	0	1
01/05/2022 04:00	0.0	0	0	0	0	1
01/05/2022 05:00	0.0	0	0	0	0	1
01/05/2022 06:00	0.0	0	0	0	0	1
01/05/2022 07:00	0.0	0	0	0	0	1
01/05/2022 08:00	0.0	0	0	0	0	1
01/05/2022 09:00	0.0	0	0	0	0	1
01/05/2022 10:00	0.0	0	0	0	0	1
01/05/2022 11:00	0.0	0	0	0	0	1
01/05/2022 12:00	0.0	0	0	0	0	1
01/05/2022 13:00	0.0	0	0	0	0	1
01/05/2022 14:00	0.0	0	0	0	0	1
01/05/2022 15:00	0.0	0	0	0	0	1
01/05/2022 16:00	0.0	0	0	0	0	1
01/05/2022 17:00	0.0	0	0	0	0	1
01/05/2022 18:00	0.0	0	0	0	0	1
01/05/2022 19:00	0.0	0	0	0	0	1
01/05/2022 20:00	0.0	0	0	0	0	1
01/05/2022 21:00	0.0	0	0	0	0	1
01/05/2022 22:00	0.0	0	0	0	0	1
01/05/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/06/2022 00:00	0.0	0	0	0	0	1
01/06/2022 01:00	0.0	0	0	0	0	1
01/06/2022 02:00	0.0	0	0	0	0	1
01/06/2022 03:00	0.0	0	0	0	0	1
01/06/2022 04:00	0.0	0	0	0	0	1
01/06/2022 05:00	0.0	0	0	0	0	1
01/06/2022 06:00	0.0	0	0	0	0	1
01/06/2022 07:00	0.0	0	0	0	0	1
01/06/2022 08:00	0.0	0	0	0	0	1
01/06/2022 09:00	0.0	0	0	0	0	1
01/06/2022 10:00	0.0	0	0	0	0	1
01/06/2022 11:00	0.0	0	0	0	0	1
01/06/2022 12:00	0.0	0	0	0	0	1
01/06/2022 13:00	0.0	0	0	0	0	1
01/06/2022 14:00	0.0	0	0	0	0	1
01/06/2022 15:00	0.0	0	0	0	0	1
01/06/2022 16:00	0.0	0	0	0	0	1
01/06/2022 17:00	0.0	0	0	0	0	1
01/06/2022 18:00	0.0	0	0	0	0	1
01/06/2022 19:00	0.0	0	0	0	0	1
01/06/2022 20:00	0.0	0	0	0	0	1
01/06/2022 21:00	0.0	0	0	0	0	1
01/06/2022 22:00	0.0	0	0	0	0	1
01/06/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/07/2022 00:00	0.0	0	0	0	0	1
01/07/2022 01:00	0.0	0	0	0	0	1
01/07/2022 02:00	0.0	0	0	0	0	1
01/07/2022 03:00	0.0	0	0	0	0	1
01/07/2022 04:00	0.0	0	0	0	0	1
01/07/2022 05:00	0.0	0	0	0	0	1
01/07/2022 06:00	0.0	0	0	0	0	1
01/07/2022 07:00	0.0	0	0	0	0	1
01/07/2022 08:00	0.0	0	0	0	0	1
01/07/2022 09:00	0.0	0	0	0	0	1
01/07/2022 10:00	0.0	0	0	0	0	1
01/07/2022 11:00	0.0	0	0	0	0	1
01/07/2022 12:00	0.0	0	0	0	0	1
01/07/2022 13:00	0.0	0	0	0	0	1
01/07/2022 14:00	0.0	0	0	0	0	1
01/07/2022 15:00	0.0	0	0	0	0	1
01/07/2022 16:00	0.0	0	0	0	0	1
01/07/2022 17:00	0.0	0	0	0	0	1
01/07/2022 18:00	0.0	0	0	0	0	1
01/07/2022 19:00	0.0	0	0	0	0	1
01/07/2022 20:00	0.0	0	0	0	0	1
01/07/2022 21:00	0.0	0	0	0	0	1
01/07/2022 22:00	2.7	0	0	0	1	0
01/07/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	2.7 #	0 #	0 #	0 #	1 #	22 #
Minimum:	0.0	0	0	0	0	0
Maximum:	2.7	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/08/2022 00:00	0.0	0	0	0	0	0
01/08/2022 01:00	0.0	0	0	0	0	0
01/08/2022 02:00	0.0	0	0	0	0	0
01/08/2022 03:00	0.0	0	0	0	0	0
01/08/2022 04:00	0.0	0	0	0	0	0
01/08/2022 05:00	0.0	0	0	0	0	0
01/08/2022 06:00	0.0	0	0	0	0	0
01/08/2022 07:00	0.0	0	0	0	0	0
01/08/2022 08:00	0.0	0	0	0	0	0
01/08/2022 09:00	0.0	0	0	0	0	0
01/08/2022 10:00	40.4	0	1	0	0	0
01/08/2022 11:00	29.9	0	1	0	0	0
01/08/2022 12:00	54.0	0	1	0	0	0
01/08/2022 13:00	0.0	0	0	0	0	1
01/08/2022 14:00	0.0	0	0	0	0	1
01/08/2022 15:00	0.0	0	0	0	0	1
01/08/2022 16:00	0.0	0	0	0	0	1
01/08/2022 17:00	0.0	0	0	0	0	1
01/08/2022 18:00	0.0	0	0	0	0	1
01/08/2022 19:00	0.0	0	0	0	0	1
01/08/2022 20:00	0.0	0	0	0	0	1
01/08/2022 21:00	0.0	0	0	0	0	1
01/08/2022 22:00	0.0	0	0	0	0	1
01/08/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	124.3 #	0 #	3 #	0 #	0 #	11 #
Minimum:	0.0	0	0	0	0	0
Maximum:	54.0	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/09/2022 00:00	0.0	0	0	0	0	1
01/09/2022 01:00	0.0	0	0	0	0	1
01/09/2022 02:00	0.0	0	0	0	0	1
01/09/2022 03:00	0.0	0	0	0	0	1
01/09/2022 04:00	0.0	0	0	0	0	1
01/09/2022 05:00	0.0	0	0	0	0	1
01/09/2022 06:00	0.0	0	0	0	0	1
01/09/2022 07:00	0.0	0	0	0	0	1
01/09/2022 08:00	0.0	0	0	0	0	1
01/09/2022 09:00	0.0	0	0	0	0	1
01/09/2022 10:00	0.0	0	0	0	0	1
01/09/2022 11:00	0.0	0	0	0	0	1
01/09/2022 12:00	0.0	0	0	0	0	1
01/09/2022 13:00	0.0	0	0	0	0	1
01/09/2022 14:00	0.0	0	0	0	0	1
01/09/2022 15:00	0.0	0	0	0	0	1
01/09/2022 16:00	0.0	0	0	0	0	1
01/09/2022 17:00	0.0	0	0	0	0	1
01/09/2022 18:00	0.0	0	0	0	0	1
01/09/2022 19:00	0.0	0	0	0	0	1
01/09/2022 20:00	0.0	0	0	0	0	1
01/09/2022 21:00	0.0	0	0	0	0	1
01/09/2022 22:00	0.0	0	0	0	0	1
01/09/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/10/2022 00:00	0.0	0	0	0	0	1
01/10/2022 01:00	0.0	0	0	0	0	1
01/10/2022 02:00	0.0	0	0	0	0	1
01/10/2022 03:00	0.0	0	0	0	0	1
01/10/2022 04:00	0.0	0	0	0	0	1
01/10/2022 05:00	0.0	0	0	0	0	1
01/10/2022 06:00	0.0	0	0	0	0	1
01/10/2022 07:00	0.0	0	0	0	0	1
01/10/2022 08:00	0.0	0	0	0	0	1
01/10/2022 09:00	0.0	0	0	0	0	1
01/10/2022 10:00	0.0	0	0	0	0	1
01/10/2022 11:00	0.0	0	0	0	0	1
01/10/2022 12:00	0.0	0	0	0	0	1
01/10/2022 13:00	0.0	0	0	0	0	1
01/10/2022 14:00	0.0	0	0	0	0	1
01/10/2022 15:00	0.0	0	0	0	0	1
01/10/2022 16:00	0.0	0	0	0	0	1
01/10/2022 17:00	0.0	0	0	0	0	1
01/10/2022 18:00	0.0	0	0	0	0	1
01/10/2022 19:00	0.0	0	0	0	0	1
01/10/2022 20:00	0.0	0	0	0	0	1
01/10/2022 21:00	0.0	0	0	0	0	1
01/10/2022 22:00	0.0	0	0	0	0	1
01/10/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/11/2022 00:00	0.0	0	0	0	0	1
01/11/2022 01:00	0.0	0	0	0	0	1
01/11/2022 02:00	0.0	0	0	0	0	1
01/11/2022 03:00	0.0	0	0	0	0	1
01/11/2022 04:00	0.0	0	0	0	0	1
01/11/2022 05:00	0.0	0	0	0	0	1
01/11/2022 06:00	0.0	0	0	0	0	1
01/11/2022 07:00	0.0	0	0	0	0	1
01/11/2022 08:00	0.0	0	0	0	0	1
01/11/2022 09:00	0.0	0	0	0	0	1
01/11/2022 10:00	0.0	0	0	0	0	1
01/11/2022 11:00	0.0	0	0	0	0	1
01/11/2022 12:00	0.0	0	0	0	0	1
01/11/2022 13:00	0.0	0	0	0	0	1
01/11/2022 14:00	0.0	0	0	0	0	1
01/11/2022 15:00	0.0	0	0	0	0	1
01/11/2022 16:00	0.0	0	0	0	0	1
01/11/2022 17:00	0.0	0	0	0	0	1
01/11/2022 18:00	0.0	0	0	0	0	1
01/11/2022 19:00	0.0	0	0	0	0	1
01/11/2022 20:00	0.0	0	0	0	0	1
01/11/2022 21:00	0.0	0	0	0	0	1
01/11/2022 22:00	0.0	0	0	0	0	1
01/11/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/12/2022 00:00	0.0	0	0	0	0	1
01/12/2022 01:00	0.0	0	0	0	0	1
01/12/2022 02:00	0.0	0	0	0	0	1
01/12/2022 03:00	0.0	0	0	0	0	1
01/12/2022 04:00	0.0	0	0	0	0	1
01/12/2022 05:00	0.0	0	0	0	0	1
01/12/2022 06:00	0.0	0	0	0	0	1
01/12/2022 07:00	0.0	0	0	0	0	1
01/12/2022 08:00	0.0	0	0	0	0	1
01/12/2022 09:00	0.0	0	0	0	0	1
01/12/2022 10:00	0.0	0	0	0	0	1
01/12/2022 11:00	0.0	0	0	0	0	1
01/12/2022 12:00	0.0	0	0	0	0	1
01/12/2022 13:00	0.0	0	0	0	0	1
01/12/2022 14:00	0.0	0	0	0	0	1
01/12/2022 15:00	0.0	0	0	0	0	1
01/12/2022 16:00	0.0	0	0	0	0	1
01/12/2022 17:00	0.0	0	0	0	0	1
01/12/2022 18:00	0.0	0	0	0	0	1
01/12/2022 19:00	0.0	0	0	0	0	1
01/12/2022 20:00	0.0	0	0	0	0	1
01/12/2022 21:00	0.0	0	0	0	0	1
01/12/2022 22:00	0.0	0	0	0	0	1
01/12/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/13/2022 00:00	0.0	0	0	0	0	1
01/13/2022 01:00	0.0	0	0	0	0	1
01/13/2022 02:00	0.0	0	0	0	0	1
01/13/2022 03:00	0.0	0	0	0	0	1
01/13/2022 04:00	0.0	0	0	0	0	1
01/13/2022 05:00	0.0	0	0	0	0	1
01/13/2022 06:00	0.0	0	0	0	0	1
01/13/2022 07:00	0.0	0	0	0	0	1
01/13/2022 08:00	0.0	0	0	0	0	1
01/13/2022 09:00	0.0	0	0	0	0	1
01/13/2022 10:00	0.0	0	0	0	0	1
01/13/2022 11:00	0.0	0	0	0	0	1
01/13/2022 12:00	0.0	0	0	0	0	1
01/13/2022 13:00	0.0	0	0	0	0	1
01/13/2022 14:00	0.0	0	0	0	0	1
01/13/2022 15:00	0.0	0	0	0	0	1
01/13/2022 16:00	0.0	0	0	0	0	1
01/13/2022 17:00	0.0	0	0	0	0	1
01/13/2022 18:00	0.0	0	0	0	0	1
01/13/2022 19:00	0.0	0	0	0	0	1
01/13/2022 20:00	0.0	0	0	0	0	1
01/13/2022 21:00	0.0	0	0	0	0	1
01/13/2022 22:00	0.0	0	0	0	0	1
01/13/2022 23:00	2.6	0	0	0	1	0
Average/Sum#:	2.6 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	2.6	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/14/2022 00:00	0.0	0	0	0	0	0
01/14/2022 01:00	0.0	0	0	0	0	0
01/14/2022 02:00	0.0	0	0	0	0	0
01/14/2022 03:00	0.0	0	0	0	0	0
01/14/2022 04:00	6.8	0	0	1	0	0
01/14/2022 05:00	78.8	0	0	1	0	0
01/14/2022 06:00	0.0	0	0	0	0	1
01/14/2022 07:00	0.0	0	0	0	0	1
01/14/2022 08:00	0.0	0	0	0	0	1
01/14/2022 09:00	0.0	0	0	0	0	1
01/14/2022 10:00	0.0	0	0	0	0	1
01/14/2022 11:00	0.0	0	0	0	0	1
01/14/2022 12:00	0.0	0	0	0	0	1
01/14/2022 13:00	0.0	0	0	0	0	1
01/14/2022 14:00	0.0	0	0	0	0	1
01/14/2022 15:00	0.0	0	0	0	0	1
01/14/2022 16:00	0.0	0	0	0	0	1
01/14/2022 17:00	0.0	0	0	0	0	1
01/14/2022 18:00	0.0	0	0	0	0	1
01/14/2022 19:00	0.0	0	0	0	0	1
01/14/2022 20:00	0.0	0	0	0	0	1
01/14/2022 21:00	0.0	0	0	0	0	1
01/14/2022 22:00	0.0	0	0	0	0	1
01/14/2022 23:00	3.0	0	0	0	1	0
Average/Sum#:	88.6 #	0 #	0 #	2 #	1 #	17 #
Minimum:	0.0	0	0	0	0	0
Maximum:	78.8	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/15/2022 00:00	0.0	0	0	0	0	0
01/15/2022 01:00	0.0	0	0	0	0	0
01/15/2022 02:00	0.0	0	0	0	0	0
01/15/2022 03:00	0.0	0	0	0	0	0
01/15/2022 04:00	4.9	0	0	1	0	0
01/15/2022 05:00	87.4	0	0	1	0	0
01/15/2022 06:00	0.0	0	0	0	0	1
01/15/2022 07:00	0.0	0	0	0	0	1
01/15/2022 08:00	0.0	0	0	0	0	1
01/15/2022 09:00	0.0	0	0	0	0	1
01/15/2022 10:00	0.0	0	0	0	0	1
01/15/2022 11:00	0.0	0	0	0	0	1
01/15/2022 12:00	0.0	0	0	0	0	1
01/15/2022 13:00	0.0	0	0	0	0	1
01/15/2022 14:00	0.0	0	0	0	0	1
01/15/2022 15:00	0.0	0	0	0	0	1
01/15/2022 16:00	0.0	0	0	0	0	1
01/15/2022 17:00	0.0	0	0	0	0	1
01/15/2022 18:00	0.0	0	0	0	0	1
01/15/2022 19:00	0.0	0	0	0	0	1
01/15/2022 20:00	0.0	0	0	0	0	1
01/15/2022 21:00	0.0	0	0	0	0	1
01/15/2022 22:00	0.0	0	0	0	0	1
01/15/2022 23:00	1.9	0	0	0	1	0
Average/Sum#:	94.2 #	0 #	0 #	2 #	1 #	17 #
Minimum:	0.0	0	0	0	0	0
Maximum:	87.4	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/16/2022 00:00	0.0	0	0	0	0	0
01/16/2022 01:00	0.0	0	0	0	0	0
01/16/2022 02:00	0.0	0	0	0	0	0
01/16/2022 03:00	0.0	0	0	0	0	0
01/16/2022 04:00	0.0	0	0	0	0	0
01/16/2022 05:00	0.0	0	0	0	0	0
01/16/2022 06:00	0.0	0	0	0	0	0
01/16/2022 07:00	0.0	0	0	0	0	0
01/16/2022 08:00	0.0	0	0	0	0	0
01/16/2022 09:00	0.0	0	0	0	0	0
01/16/2022 10:00	0.0	0	0	0	0	0
01/16/2022 11:00	51.0	0	1	0	0	0
01/16/2022 12:00	83.4	0	1	0	0	0
01/16/2022 13:00	0.0	0	0	0	0	1
01/16/2022 14:00	0.0	0	0	0	0	1
01/16/2022 15:00	0.0	0	0	0	0	1
01/16/2022 16:00	0.0	0	0	0	0	1
01/16/2022 17:00	0.0	0	0	0	0	1
01/16/2022 18:00	0.0	0	0	0	0	1
01/16/2022 19:00	0.0	0	0	0	0	1
01/16/2022 20:00	0.0	0	0	0	0	1
01/16/2022 21:00	0.0	0	0	0	0	1
01/16/2022 22:00	0.0	0	0	0	0	1
01/16/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	134.4 #	0 #	2 #	0 #	0 #	11 #
Minimum:	0.0	0	0	0	0	0
Maximum:	83.4	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/17/2022 00:00	0.0	0	0	0	0	1
01/17/2022 01:00	0.0	0	0	0	0	1
01/17/2022 02:00	0.0	0	0	0	0	1
01/17/2022 03:00	0.0	0	0	0	0	1
01/17/2022 04:00	0.0	0	0	0	0	1
01/17/2022 05:00	0.0	0	0	0	0	1
01/17/2022 06:00	0.0	0	0	0	0	1
01/17/2022 07:00	0.0	0	0	0	0	1
01/17/2022 08:00	0.0	0	0	0	0	1
01/17/2022 09:00	0.0	0	0	0	0	1
01/17/2022 10:00	0.0	0	0	0	0	1
01/17/2022 11:00	0.0	0	0	0	0	1
01/17/2022 12:00	0.0	0	0	0	0	1
01/17/2022 13:00	0.0	0	0	0	0	1
01/17/2022 14:00	0.0	0	0	0	0	1
01/17/2022 15:00	0.0	0	0	0	0	1
01/17/2022 16:00	0.0	0	0	0	0	1
01/17/2022 17:00	0.0	0	0	0	0	1
01/17/2022 18:00	0.0	0	0	0	0	1
01/17/2022 19:00	0.0	0	0	0	0	1
01/17/2022 20:00	0.0	0	0	0	0	1
01/17/2022 21:00	0.0	0	0	0	0	1
01/17/2022 22:00	0.0	0	0	0	0	1
01/17/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/18/2022 00:00	0.0	0	0	0	0	1
01/18/2022 01:00	0.0	0	0	0	0	1
01/18/2022 02:00	0.0	0	0	0	0	1
01/18/2022 03:00	0.0	0	0	0	0	1
01/18/2022 04:00	0.0	0	0	0	0	1
01/18/2022 05:00	0.0	0	0	0	0	1
01/18/2022 06:00	0.0	0	0	0	0	1
01/18/2022 07:00	0.0	0	0	0	0	1
01/18/2022 08:00	0.0	0	0	0	0	1
01/18/2022 09:00	0.0	0	0	0	0	1
01/18/2022 10:00	0.0	0	0	0	0	1
01/18/2022 11:00	0.0	0	0	0	0	1
01/18/2022 12:00	0.0	0	0	0	0	1
01/18/2022 13:00	0.0	0	0	0	0	1
01/18/2022 14:00	0.0	0	0	0	0	1
01/18/2022 15:00	0.0	0	0	0	0	1
01/18/2022 16:00	0.0	0	0	0	0	1
01/18/2022 17:00	0.0	0	0	0	0	1
01/18/2022 18:00	0.0	0	0	0	0	1
01/18/2022 19:00	0.0	0	0	0	0	1
01/18/2022 20:00	0.0	0	0	0	0	1
01/18/2022 21:00	0.0	0	0	0	0	1
01/18/2022 22:00	0.0	0	0	0	0	1
01/18/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/19/2022 00:00	0.0	0	0	0	0	1
01/19/2022 01:00	0.0	0	0	0	0	1
01/19/2022 02:00	0.0	0	0	0	0	1
01/19/2022 03:00	0.0	0	0	0	0	1
01/19/2022 04:00	0.0	0	0	0	0	1
01/19/2022 05:00	0.0	0	0	0	0	1
01/19/2022 06:00	0.0	0	0	0	0	1
01/19/2022 07:00	0.0	0	0	0	0	1
01/19/2022 08:00	0.0	0	0	0	0	1
01/19/2022 09:00	0.0	0	0	0	0	1
01/19/2022 10:00	0.0	0	0	0	0	1
01/19/2022 11:00	0.0	0	0	0	0	1
01/19/2022 12:00	0.0	0	0	0	0	1
01/19/2022 13:00	0.0	0	0	0	0	1
01/19/2022 14:00	0.0	0	0	0	0	1
01/19/2022 15:00	0.0	0	0	0	0	1
01/19/2022 16:00	0.0	0	0	0	0	1
01/19/2022 17:00	0.0	0	0	0	0	1
01/19/2022 18:00	0.0	0	0	0	0	1
01/19/2022 19:00	0.0	0	0	0	0	1
01/19/2022 20:00	0.0	0	0	0	0	1
01/19/2022 21:00	0.0	0	0	0	0	1
01/19/2022 22:00	0.0	0	0	0	0	1
01/19/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/20/2022 00:00	0.0	0	0	0	0	1
01/20/2022 01:00	0.0	0	0	0	0	1
01/20/2022 02:00	0.0	0	0	0	0	1
01/20/2022 03:00	0.0	0	0	0	0	1
01/20/2022 04:00	0.0	0	0	0	0	1
01/20/2022 05:00	0.0	0	0	0	0	1
01/20/2022 06:00	0.0	0	0	0	0	1
01/20/2022 07:00	0.0	0	0	0	0	1
01/20/2022 08:00	0.0	0	0	0	0	1
01/20/2022 09:00	0.0	0	0	0	0	1
01/20/2022 10:00	0.0	0	0	0	0	1
01/20/2022 11:00	0.0	0	0	0	0	1
01/20/2022 12:00	0.0	0	0	0	0	1
01/20/2022 13:00	0.0	0	0	0	0	1
01/20/2022 14:00	0.0	0	0	0	0	1
01/20/2022 15:00	0.0	0	0	0	0	1
01/20/2022 16:00	0.0	0	0	0	0	1
01/20/2022 17:00	0.0	0	0	0	0	1
01/20/2022 18:00	0.0	0	0	0	0	1
01/20/2022 19:00	0.0	0	0	0	0	1
01/20/2022 20:00	0.0	0	0	0	0	1
01/20/2022 21:00	0.0	0	0	0	0	1
01/20/2022 22:00	0.0	0	0	0	0	1
01/20/2022 23:00	1.5	0	0	0	1	0
Average/Sum#:	1.5 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.5	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/21/2022 00:00	0.0	0	0	0	0	0
01/21/2022 01:00	0.0	0	0	0	0	0
01/21/2022 02:00	0.0	0	0	0	0	0
01/21/2022 03:00	0.0	0	0	0	0	0
01/21/2022 04:00	0.0	0	0	0	0	0
01/21/2022 05:00	0.0	0	0	0	0	0
01/21/2022 06:00	0.0	0	0	0	0	0
01/21/2022 07:00	0.0	0	0	0	0	0
01/21/2022 08:00	0.0	0	0	0	0	0
01/21/2022 09:00	0.0	0	0	0	0	0
01/21/2022 10:00	0.0	0	0	0	0	0
01/21/2022 11:00	0.0	0	0	0	0	0
01/21/2022 12:00	0.0	0	0	0	0	0
01/21/2022 13:00	0.0	0	0	0	0	0
01/21/2022 14:00	0.0	0	0	0	0	0
01/21/2022 15:00	0.0	0	0	0	0	0
01/21/2022 16:00	0.0	0	0	0	0	0
01/21/2022 17:00	0.0	0	0	0	0	0
01/21/2022 18:00	0.0	0	0	0	0	0
01/21/2022 19:00	0.0	0	0	0	0	0
01/21/2022 20:00	0.0	0	0	0	0	0
01/21/2022 21:00	0.0	0	0	0	0	0
01/21/2022 22:00	0.0	0	0	0	0	0
01/21/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/22/2022 00:00	0.0	0	0	0	0	0
01/22/2022 01:00	0.0	0	0	0	0	0
01/22/2022 02:00	0.0	0	0	0	0	0
01/22/2022 03:00	0.0	0	0	0	0	0
01/22/2022 04:00	0.0	0	0	0	0	0
01/22/2022 05:00	0.0	0	0	0	0	0
01/22/2022 06:00	0.0	0	0	0	0	0
01/22/2022 07:00	0.0	0	0	0	0	0
01/22/2022 08:00	0.0	0	0	0	0	0
01/22/2022 09:00	0.0	0	0	0	0	0
01/22/2022 10:00	0.0	0	0	0	0	0
01/22/2022 11:00	0.0	0	0	0	0	0
01/22/2022 12:00	0.0	0	0	0	0	0
01/22/2022 13:00	0.0	0	0	0	0	0
01/22/2022 14:00	0.0	0	0	0	0	0
01/22/2022 15:00	0.0	0	0	0	0	0
01/22/2022 16:00	0.0	0	0	0	0	0
01/22/2022 17:00	0.0	0	0	0	0	0
01/22/2022 18:00	0.0	0	0	0	0	0
01/22/2022 19:00	0.0	0	0	0	0	0
01/22/2022 20:00	0.0	0	0	0	0	0
01/22/2022 21:00	0.0	0	0	0	0	0
01/22/2022 22:00	0.0	0	0	0	0	0
01/22/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/23/2022 00:00	0.0	0	0	0	0	0
01/23/2022 01:00	0.0	0	0	0	0	0
01/23/2022 02:00	0.0	0	0	0	0	0
01/23/2022 03:00	0.0	0	0	0	0	0
01/23/2022 04:00	0.0	0	0	0	0	0
01/23/2022 05:00	0.0	0	0	0	0	0
01/23/2022 06:00	0.0	0	0	0	0	0
01/23/2022 07:00	0.0	0	0	0	0	0
01/23/2022 08:00	0.0	0	0	0	0	0
01/23/2022 09:00	0.0	0	0	0	0	0
01/23/2022 10:00	0.0	0	0	0	0	0
01/23/2022 11:00	61.7	0	1	0	0	0
01/23/2022 12:00	24.1	0	1	0	0	0
01/23/2022 13:00	71.0	0	1	0	0	0
01/23/2022 14:00	0.0	0	0	0	0	1
01/23/2022 15:00	0.0	0	0	0	0	1
01/23/2022 16:00	0.0	0	0	0	0	1
01/23/2022 17:00	0.0	0	0	0	0	1
01/23/2022 18:00	0.0	0	0	0	0	1
01/23/2022 19:00	0.0	0	0	0	0	1
01/23/2022 20:00	0.0	0	0	0	0	1
01/23/2022 21:00	0.0	0	0	0	0	1
01/23/2022 22:00	0.0	0	0	0	0	1
01/23/2022 23:00	2.7	0	0	0	1	0
Average/Sum#:	159.5 #	0 #	3 #	0 #	1 #	9 #
Minimum:	0.0	0	0	0	0	0
Maximum:	71.0	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/24/2022 00:00	0.0	0	0	0	0	0
01/24/2022 01:00	0.0	0	0	0	0	0
01/24/2022 02:00	0.0	0	0	0	0	0
01/24/2022 03:00	2.6	0	0	1	0	0
01/24/2022 04:00	92.9	0	0	1	0	0
01/24/2022 05:00	0.0	0	0	0	0	1
01/24/2022 06:00	0.0	0	0	0	0	1
01/24/2022 07:00	0.0	0	0	0	0	1
01/24/2022 08:00	0.0	0	0	0	0	1
01/24/2022 09:00	0.0	0	0	0	0	1
01/24/2022 10:00	0.0	0	0	0	0	1
01/24/2022 11:00	0.0	0	0	0	0	1
01/24/2022 12:00	0.0	0	0	0	0	1
01/24/2022 13:00	0.0	0	0	0	0	1
01/24/2022 14:00	0.0	0	0	0	0	1
01/24/2022 15:00	0.0	0	0	0	0	1
01/24/2022 16:00	0.0	0	0	0	0	1
01/24/2022 17:00	0.0	0	0	0	0	1
01/24/2022 18:00	0.0	0	0	0	0	1
01/24/2022 19:00	0.0	0	0	0	0	1
01/24/2022 20:00	0.0	0	0	0	0	1
01/24/2022 21:00	0.0	0	0	0	0	1
01/24/2022 22:00	0.0	0	0	0	0	1
01/24/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	95.5 #	0 #	0 #	2 #	0 #	19 #
Minimum:	0.0	0	0	0	0	0
Maximum:	92.9	0	0	1	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/25/2022 00:00	0.0	0	0	0	0	1
01/25/2022 01:00	0.0	0	0	0	0	1
01/25/2022 02:00	0.0	0	0	0	0	1
01/25/2022 03:00	0.0	0	0	0	0	1
01/25/2022 04:00	0.0	0	0	0	0	1
01/25/2022 05:00	0.0	0	0	0	0	1
01/25/2022 06:00	0.0	0	0	0	0	1
01/25/2022 07:00	0.0	0	0	0	0	1
01/25/2022 08:00	1.5	0	0	0	1	0
01/25/2022 09:00	0.0	0	0	0	0	0
01/25/2022 10:00	0.0	0	0	0	0	0
01/25/2022 11:00	0.0	0	0	0	0	0
01/25/2022 12:00	0.0	0	0	0	0	0
01/25/2022 13:00	0.0	0	0	0	0	0
01/25/2022 14:00	0.0	0	0	0	0	0
01/25/2022 15:00	15.4	0	0	1	0	0
01/25/2022 16:00	42.0	0	0	1	0	0
01/25/2022 17:00	0.0	0	0	0	0	1
01/25/2022 18:00	0.0	0	0	0	0	1
01/25/2022 19:00	0.0	0	0	0	0	1
01/25/2022 20:00	0.0	0	0	0	0	1
01/25/2022 21:00	0.0	0	0	0	0	1
01/25/2022 22:00	0.0	0	0	0	0	1
01/25/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	58.9 #	0 #	0 #	2 #	1 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	42.0	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/26/2022 00:00	0.0	0	0	0	0	1
01/26/2022 01:00	0.0	0	0	0	0	1
01/26/2022 02:00	0.0	0	0	0	0	1
01/26/2022 03:00	0.0	0	0	0	0	1
01/26/2022 04:00	0.0	0	0	0	0	1
01/26/2022 05:00	0.0	0	0	0	0	1
01/26/2022 06:00	0.0	0	0	0	0	1
01/26/2022 07:00	0.0	0	0	0	0	1
01/26/2022 08:00	2.4	0	0	0	1	0
01/26/2022 09:00	0.0	0	0	0	0	0
01/26/2022 10:00	0.0	0	0	0	0	0
01/26/2022 11:00	0.0	0	0	0	0	0
01/26/2022 12:00	0.0	0	0	0	0	0
01/26/2022 13:00	0.0	0	0	0	0	0
01/26/2022 14:00	0.0	0	0	0	0	0
01/26/2022 15:00	15.6	0	0	1	0	0
01/26/2022 16:00	44.5	0	0	1	0	0
01/26/2022 17:00	0.0	0	0	0	0	1
01/26/2022 18:00	0.0	0	0	0	0	1
01/26/2022 19:00	0.0	0	0	0	0	1
01/26/2022 20:00	0.0	0	0	0	0	1
01/26/2022 21:00	0.0	0	0	0	0	1
01/26/2022 22:00	0.0	0	0	0	0	1
01/26/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	62.5 #	0 #	0 #	2 #	1 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	44.5	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/27/2022 00:00	0.0	0	0	0	0	1
01/27/2022 01:00	0.0	0	0	0	0	1
01/27/2022 02:00	0.0	0	0	0	0	1
01/27/2022 03:00	0.0	0	0	0	0	1
01/27/2022 04:00	0.0	0	0	0	0	1
01/27/2022 05:00	0.0	0	0	0	0	1
01/27/2022 06:00	0.0	0	0	0	0	1
01/27/2022 07:00	0.0	0	0	0	0	1
01/27/2022 08:00	0.0	0	0	0	0	1
01/27/2022 09:00	0.0	0	0	0	0	1
01/27/2022 10:00	2.9	0	0	0	1	0
01/27/2022 11:00	0.0	0	0	0	0	0
01/27/2022 12:00	0.0	0	0	0	0	0
01/27/2022 13:00	0.0	0	0	0	0	0
01/27/2022 14:00	0.0	0	0	0	0	0
01/27/2022 15:00	13.8	0	0	1	0	0
01/27/2022 16:00	42.6	0	0	1	0	0
01/27/2022 17:00	0.0	0	0	0	0	1
01/27/2022 18:00	0.0	0	0	0	0	1
01/27/2022 19:00	0.0	0	0	0	0	1
01/27/2022 20:00	0.0	0	0	0	0	1
01/27/2022 21:00	0.0	0	0	0	0	1
01/27/2022 22:00	0.0	0	0	0	0	1
01/27/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	59.3 #	0 #	0 #	2 #	1 #	17 #
Minimum:	0.0	0	0	0	0	0
Maximum:	42.6	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/28/2022 00:00	0.0	0	0	0	0	1
01/28/2022 01:00	0.0	0	0	0	0	1
01/28/2022 02:00	0.0	0	0	0	0	1
01/28/2022 03:00	0.0	0	0	0	0	1
01/28/2022 04:00	0.0	0	0	0	0	1
01/28/2022 05:00	0.0	0	0	0	0	1
01/28/2022 06:00	0.0	0	0	0	0	1
01/28/2022 07:00	0.0	0	0	0	0	1
01/28/2022 08:00	0.0	0	0	0	0	1
01/28/2022 09:00	0.0	0	0	0	0	1
01/28/2022 10:00	0.0	0	0	0	0	1
01/28/2022 11:00	0.0	0	0	0	0	1
01/28/2022 12:00	0.0	0	0	0	0	1
01/28/2022 13:00	0.0	0	0	0	0	1
01/28/2022 14:00	0.0	0	0	0	0	1
01/28/2022 15:00	0.0	0	0	0	0	1
01/28/2022 16:00	0.0	0	0	0	0	1
01/28/2022 17:00	0.0	0	0	0	0	1
01/28/2022 18:00	0.0	0	0	0	0	1
01/28/2022 19:00	0.0	0	0	0	0	1
01/28/2022 20:00	0.0	0	0	0	0	1
01/28/2022 21:00	0.0	0	0	0	0	1
01/28/2022 22:00	0.0	0	0	0	0	1
01/28/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/29/2022 00:00	0.0	0	0	0	0	1
01/29/2022 01:00	0.0	0	0	0	0	1
01/29/2022 02:00	0.0	0	0	0	0	1
01/29/2022 03:00	0.0	0	0	0	0	1
01/29/2022 04:00	0.0	0	0	0	0	1
01/29/2022 05:00	0.0	0	0	0	0	1
01/29/2022 06:00	0.0	0	0	0	0	1
01/29/2022 07:00	0.0	0	0	0	0	1
01/29/2022 08:00	0.0	0	0	0	0	1
01/29/2022 09:00	0.0	0	0	0	0	1
01/29/2022 10:00	0.0	0	0	0	0	1
01/29/2022 11:00	0.0	0	0	0	0	1
01/29/2022 12:00	0.0	0	0	0	0	1
01/29/2022 13:00	0.0	0	0	0	0	1
01/29/2022 14:00	0.0	0	0	0	0	1
01/29/2022 15:00	0.0	0	0	0	0	1
01/29/2022 16:00	0.0	0	0	0	0	1
01/29/2022 17:00	0.0	0	0	0	0	1
01/29/2022 18:00	0.0	0	0	0	0	1
01/29/2022 19:00	0.0	0	0	0	0	1
01/29/2022 20:00	0.0	0	0	0	0	1
01/29/2022 21:00	0.0	0	0	0	0	1
01/29/2022 22:00	0.0	0	0	0	0	1
01/29/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/30/2022 00:00	0.0	0	0	0	0	1
01/30/2022 01:00	0.0	0	0	0	0	1
01/30/2022 02:00	0.0	0	0	0	0	1
01/30/2022 03:00	0.0	0	0	0	0	1
01/30/2022 04:00	0.0	0	0	0	0	1
01/30/2022 05:00	0.0	0	0	0	0	1
01/30/2022 06:00	0.0	0	0	0	0	1
01/30/2022 07:00	2.2	0	0	0	1	0
01/30/2022 08:00	0.0	0	0	0	0	0
01/30/2022 09:00	0.0	0	0	0	0	0
01/30/2022 10:00	0.0	0	0	0	0	0
01/30/2022 11:00	0.0	0	0	0	0	0
01/30/2022 12:00	0.0	0	0	0	0	0
01/30/2022 13:00	0.0	0	0	0	0	0
01/30/2022 14:00	0.0	0	0	0	0	0
01/30/2022 15:00	0.0	0	0	0	0	0
01/30/2022 16:00	0.0	0	0	0	0	0
01/30/2022 17:00	0.0	0	0	0	0	0
01/30/2022 18:00	0.0	0	0	0	0	0
01/30/2022 19:00	0.0	0	0	0	0	0
01/30/2022 20:00	0.0	0	0	0	0	0
01/30/2022 21:00	0.0	0	0	0	0	0
01/30/2022 22:00	0.0	0	0	0	0	0
01/30/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	2.2 #	0 #	0 #	0 #	1 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	2.2	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/31/2022 00:00	0.0	0	0	0	0	0
01/31/2022 01:00	0.0	0	0	0	0	0
01/31/2022 02:00	60.8	0	1	0	0	0
01/31/2022 03:00	75.0	0	1	0	0	0
01/31/2022 04:00	0.0	0	0	0	0	1
01/31/2022 05:00	0.0	0	0	0	0	1
01/31/2022 06:00	0.0	0	0	0	0	1
01/31/2022 07:00	0.0	0	0	0	0	1
01/31/2022 08:00	0.0	0	0	0	0	1
01/31/2022 09:00	0.0	0	0	0	0	1
01/31/2022 10:00	0.0	0	0	0	0	1
01/31/2022 11:00	0.0	0	0	0	0	1
01/31/2022 12:00	0.0	0	0	0	0	1
01/31/2022 13:00	0.0	0	0	0	0	1
01/31/2022 14:00	0.0	0	0	0	0	1
01/31/2022 15:00	0.0	0	0	0	0	1
01/31/2022 16:00	0.0	0	0	0	0	1
01/31/2022 17:00	0.0	0	0	0	0	1
01/31/2022 18:00	0.0	0	0	0	0	1
01/31/2022 19:00	0.0	0	0	0	0	1
01/31/2022 20:00	0.0	0	0	0	0	1
01/31/2022 21:00	0.0	0	0	0	0	1
01/31/2022 22:00	0.0	0	0	0	0	1
01/31/2022 23:00	2.5	0	0	0	1	0
Average/Sum#:	138.3 #	0 #	2 #	0 #	1 #	19 #
Minimum:	0.0	0	0	0	0	0
Maximum:	75.0	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/01/2022 00:00	0.0	0	0	0	0	0
02/01/2022 01:00	0.0	0	0	0	0	0
02/01/2022 02:00	0.0	0	0	0	0	0
02/01/2022 03:00	0.0	0	0	0	0	0
02/01/2022 04:00	0.0	0	0	0	0	0
02/01/2022 05:00	65.6	0	0	1	0	0
02/01/2022 06:00	40.1	0	0	1	0	0
02/01/2022 07:00	0.0	0	0	0	0	1
02/01/2022 08:00	0.0	0	0	0	0	1
02/01/2022 09:00	0.0	0	0	0	0	1
02/01/2022 10:00	0.0	0	0	0	0	1
02/01/2022 11:00	0.0	0	0	0	0	1
02/01/2022 12:00	0.0	0	0	0	0	1
02/01/2022 13:00	0.0	0	0	0	0	1
02/01/2022 14:00	0.0	0	0	0	0	1
02/01/2022 15:00	0.0	0	0	0	0	1
02/01/2022 16:00	0.0	0	0	0	0	1
02/01/2022 17:00	0.0	0	0	0	0	1
02/01/2022 18:00	0.0	0	0	0	0	1
02/01/2022 19:00	0.0	0	0	0	0	1
02/01/2022 20:00	0.0	0	0	0	0	1
02/01/2022 21:00	0.0	0	0	0	0	1
02/01/2022 22:00	0.0	0	0	0	0	1
02/01/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	105.7 #	0 #	0 #	2 #	0 #	17 #
Minimum:	0.0	0	0	0	0	0
Maximum:	65.6	0	0	1	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/02/2022 00:00	0.0	0	0	0	0	1
02/02/2022 01:00	0.0	0	0	0	0	1
02/02/2022 02:00	0.0	0	0	0	0	1
02/02/2022 03:00	0.0	0	0	0	0	1
02/02/2022 04:00	0.0	0	0	0	0	1
02/02/2022 05:00	0.0	0	0	0	0	1
02/02/2022 06:00	0.0	0	0	0	0	1
02/02/2022 07:00	0.0	0	0	0	0	1
02/02/2022 08:00	0.0	0	0	0	0	1
02/02/2022 09:00	0.0	0	0	0	0	1
02/02/2022 10:00	2.8	0	0	0	1	0
02/02/2022 11:00	0.0	0	0	0	0	0
02/02/2022 12:00	0.0	0	0	0	0	0
02/02/2022 13:00	0.0	0	0	0	0	0
02/02/2022 14:00	0.0	0	0	0	0	0
02/02/2022 15:00	4.3	0	0	1	0	0
02/02/2022 16:00	144.1	0	0	1	0	0
02/02/2022 17:00	0.2	0	0	1	0	0
02/02/2022 18:00	0.0	0	0	0	0	1
02/02/2022 19:00	0.0	0	0	0	0	1
02/02/2022 20:00	0.0	0	0	0	0	1
02/02/2022 21:00	0.0	0	0	0	0	1
02/02/2022 22:00	0.0	0	0	0	0	1
02/02/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	151.4 #	0 #	0 #	3 #	1 #	16 #
Minimum:	0.0	0	0	0	0	0
Maximum:	144.1	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/03/2022 00:00	0.0	0	0	0	0	1
02/03/2022 01:00	0.0	0	0	0	0	1
02/03/2022 02:00	0.0	0	0	0	0	1
02/03/2022 03:00	0.0	0	0	0	0	1
02/03/2022 04:00	0.0	0	0	0	0	1
02/03/2022 05:00	0.0	0	0	0	0	1
02/03/2022 06:00	0.0	0	0	0	0	1
02/03/2022 07:00	0.0	0	0	0	0	1
02/03/2022 08:00	0.0	0	0	0	0	1
02/03/2022 09:00	0.0	0	0	0	0	1
02/03/2022 10:00	0.0	0	0	0	0	1
02/03/2022 11:00	0.0	0	0	0	0	1
02/03/2022 12:00	0.0	0	0	0	0	1
02/03/2022 13:00	0.0	0	0	0	0	1
02/03/2022 14:00	0.0	0	0	0	0	1
02/03/2022 15:00	0.0	0	0	0	0	1
02/03/2022 16:00	0.0	0	0	0	0	1
02/03/2022 17:00	0.0	0	0	0	0	1
02/03/2022 18:00	0.0	0	0	0	0	1
02/03/2022 19:00	0.0	0	0	0	0	1
02/03/2022 20:00	0.0	0	0	0	0	1
02/03/2022 21:00	0.0	0	0	0	0	1
02/03/2022 22:00	0.0	0	0	0	0	1
02/03/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/04/2022 00:00	0.0	0	0	0	0	1
02/04/2022 01:00	0.0	0	0	0	0	1
02/04/2022 02:00	0.0	0	0	0	0	1
02/04/2022 03:00	0.0	0	0	0	0	1
02/04/2022 04:00	0.0	0	0	0	0	1
02/04/2022 05:00	0.0	0	0	0	0	1
02/04/2022 06:00	0.0	0	0	0	0	1
02/04/2022 07:00	0.0	0	0	0	0	1
02/04/2022 08:00	2.6	0	0	0	1	0
02/04/2022 09:00	0.0	0	0	0	0	0
02/04/2022 10:00	0.0	0	0	0	0	0
02/04/2022 11:00	0.0	0	0	0	0	0
02/04/2022 12:00	0.0	0	0	0	0	0
02/04/2022 13:00	0.0	0	0	0	0	0
02/04/2022 14:00	0.0	0	0	0	0	0
02/04/2022 15:00	0.0	0	0	0	0	0
02/04/2022 16:00	186.9	0	0	1	0	0
02/04/2022 17:00	5.0	0	0	1	0	0
02/04/2022 18:00	0.0	0	0	0	0	1
02/04/2022 19:00	0.0	0	0	0	0	1
02/04/2022 20:00	0.0	0	0	0	0	1
02/04/2022 21:00	0.0	0	0	0	0	1
02/04/2022 22:00	0.0	0	0	0	0	1
02/04/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	194.5 #	0 #	0 #	2 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	186.9	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/05/2022 00:00	0.0	0	0	0	0	1
02/05/2022 01:00	0.0	0	0	0	0	1
02/05/2022 02:00	0.0	0	0	0	0	1
02/05/2022 03:00	0.0	0	0	0	0	1
02/05/2022 04:00	0.0	0	0	0	0	1
02/05/2022 05:00	0.0	0	0	0	0	1
02/05/2022 06:00	0.0	0	0	0	0	1
02/05/2022 07:00	0.0	0	0	0	0	1
02/05/2022 08:00	2.7	0	0	0	1	0
02/05/2022 09:00	0.0	0	0	0	0	0
02/05/2022 10:00	0.0	0	0	0	0	0
02/05/2022 11:00	0.0	0	0	0	0	0
02/05/2022 12:00	0.0	0	0	0	0	0
02/05/2022 13:00	8.7	0	0	1	0	0
02/05/2022 14:00	64.5	0	0	1	0	0
02/05/2022 15:00	0.0	0	0	0	0	1
02/05/2022 16:00	0.0	0	0	0	0	1
02/05/2022 17:00	0.0	0	0	0	0	1
02/05/2022 18:00	0.0	0	0	0	0	1
02/05/2022 19:00	0.0	0	0	0	0	1
02/05/2022 20:00	0.0	0	0	0	0	1
02/05/2022 21:00	0.0	0	0	0	0	1
02/05/2022 22:00	0.0	0	0	0	0	1
02/05/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	75.9 #	0 #	0 #	2 #	1 #	17 #
Minimum:	0.0	0	0	0	0	0
Maximum:	64.5	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/06/2022 00:00	0.0	0	0	0	0	1
02/06/2022 01:00	0.0	0	0	0	0	1
02/06/2022 02:00	0.0	0	0	0	0	1
02/06/2022 03:00	0.0	0	0	0	0	1
02/06/2022 04:00	0.0	0	0	0	0	1
02/06/2022 05:00	0.0	0	0	0	0	1
02/06/2022 06:00	0.0	0	0	0	0	1
02/06/2022 07:00	0.0	0	0	0	0	1
02/06/2022 08:00	2.6	0	0	0	1	0
02/06/2022 09:00	0.0	0	0	0	0	0
02/06/2022 10:00	0.0	0	0	0	0	0
02/06/2022 11:00	0.0	0	0	0	0	0
02/06/2022 12:00	0.0	0	0	0	0	0
02/06/2022 13:00	0.0	0	0	0	0	0
02/06/2022 14:00	13.0	0	0	1	0	0
02/06/2022 15:00	62.7	0	0	1	0	0
02/06/2022 16:00	0.0	0	0	0	0	1
02/06/2022 17:00	0.0	0	0	0	0	1
02/06/2022 18:00	0.0	0	0	0	0	1
02/06/2022 19:00	0.0	0	0	0	0	1
02/06/2022 20:00	0.0	0	0	0	0	1
02/06/2022 21:00	0.0	0	0	0	0	1
02/06/2022 22:00	0.0	0	0	0	0	1
02/06/2022 23:00	4.5	0	0	0	1	0
Average/Sum#:	82.8 #	0 #	0 #	2 #	2 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	62.7	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/07/2022 00:00	0.0	0	0	0	0	0
02/07/2022 01:00	0.0	0	0	0	0	0
02/07/2022 02:00	0.0	0	0	0	0	0
02/07/2022 03:00	0.0	0	0	0	0	0
02/07/2022 04:00	0.0	0	0	0	0	0
02/07/2022 05:00	0.0	0	0	0	0	0
02/07/2022 06:00	0.0	0	0	0	0	0
02/07/2022 07:00	0.0	0	0	0	0	0
02/07/2022 08:00	0.0	0	0	0	0	0
02/07/2022 09:00	0.0	0	0	0	0	0
02/07/2022 10:00	0.0	0	0	0	0	0
02/07/2022 11:00	44.5	0	1	0	0	0
02/07/2022 12:00	33.9	0	1	0	0	0
02/07/2022 13:00	90.3	0	1	0	0	0
02/07/2022 14:00	0.0	0	0	0	0	1
02/07/2022 15:00	0.0	0	0	0	0	1
02/07/2022 16:00	0.0	0	0	0	0	1
02/07/2022 17:00	0.0	0	0	0	0	1
02/07/2022 18:00	0.0	0	0	0	0	1
02/07/2022 19:00	0.0	0	0	0	0	1
02/07/2022 20:00	0.0	0	0	0	0	1
02/07/2022 21:00	0.0	0	0	0	0	1
02/07/2022 22:00	0.0	0	0	0	0	1
02/07/2022 23:00	2.8	0	0	0	1	0
Average/Sum#:	171.5 #	0 #	3 #	0 #	1 #	9 #
Minimum:	0.0	0	0	0	0	0
Maximum:	90.3	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/08/2022 00:00	0.0	0	0	0	0	0
02/08/2022 01:00	0.0	0	0	0	0	0
02/08/2022 02:00	0.0	0	0	0	0	0
02/08/2022 03:00	18.9	0	0	1	0	0
02/08/2022 04:00	23.4	0	0	1	0	0
02/08/2022 05:00	0.0	0	0	0	0	1
02/08/2022 06:00	0.0	0	0	0	0	1
02/08/2022 07:00	0.0	0	0	0	0	1
02/08/2022 08:00	0.0	0	0	0	0	1
02/08/2022 09:00	0.0	0	0	0	0	1
02/08/2022 10:00	0.0	0	0	0	0	1
02/08/2022 11:00	0.0	0	0	0	0	1
02/08/2022 12:00	0.0	0	0	0	0	1
02/08/2022 13:00	0.0	0	0	0	0	1
02/08/2022 14:00	0.0	0	0	0	0	1
02/08/2022 15:00	0.0	0	0	0	0	1
02/08/2022 16:00	0.0	0	0	0	0	1
02/08/2022 17:00	0.0	0	0	0	0	1
02/08/2022 18:00	0.0	0	0	0	0	1
02/08/2022 19:00	0.0	0	0	0	0	1
02/08/2022 20:00	0.0	0	0	0	0	1
02/08/2022 21:00	0.0	0	0	0	0	1
02/08/2022 22:00	0.0	0	0	0	0	1
02/08/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	42.3 #	0 #	0 #	2 #	0 #	19 #
Minimum:	0.0	0	0	0	0	0
Maximum:	23.4	0	0	1	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/09/2022 00:00	0.0	0	0	0	0	1
02/09/2022 01:00	0.0	0	0	0	0	1
02/09/2022 02:00	0.0	0	0	0	0	1
02/09/2022 03:00	0.0	0	0	0	0	1
02/09/2022 04:00	0.0	0	0	0	0	1
02/09/2022 05:00	0.0	0	0	0	0	1
02/09/2022 06:00	0.0	0	0	0	0	1
02/09/2022 07:00	0.0	0	0	0	0	1
02/09/2022 08:00	0.0	0	0	0	0	1
02/09/2022 09:00	0.0	0	0	0	0	1
02/09/2022 10:00	0.0	0	0	0	0	1
02/09/2022 11:00	0.0	0	0	0	0	1
02/09/2022 12:00	0.0	0	0	0	0	1
02/09/2022 13:00	0.0	0	0	0	0	1
02/09/2022 14:00	0.0	0	0	0	0	1
02/09/2022 15:00	0.0	0	0	0	0	1
02/09/2022 16:00	0.0	0	0	0	0	1
02/09/2022 17:00	0.0	0	0	0	0	1
02/09/2022 18:00	0.0	0	0	0	0	1
02/09/2022 19:00	0.0	0	0	0	0	1
02/09/2022 20:00	0.0	0	0	0	0	1
02/09/2022 21:00	0.0	0	0	0	0	1
02/09/2022 22:00	0.0	0	0	0	0	1
02/09/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/10/2022 00:00	0.0	0	0	0	0	1
02/10/2022 01:00	0.0	0	0	0	0	1
02/10/2022 02:00	0.0	0	0	0	0	1
02/10/2022 03:00	0.0	0	0	0	0	1
02/10/2022 04:00	0.0	0	0	0	0	1
02/10/2022 05:00	0.0	0	0	0	0	1
02/10/2022 06:00	0.0	0	0	0	0	1
02/10/2022 07:00	0.0	0	0	0	0	1
02/10/2022 08:00	3.5	0	0	0	1	0
02/10/2022 09:00	0.0	0	0	0	0	0
02/10/2022 10:00	0.0	0	0	0	0	0
02/10/2022 11:00	1.1	0	0	1	0	0
02/10/2022 12:00	76.2	0	0	1	0	0
02/10/2022 13:00	0.0	0	0	0	0	1
02/10/2022 14:00	0.0	0	0	0	0	1
02/10/2022 15:00	0.0	0	0	0	0	1
02/10/2022 16:00	0.0	0	0	0	0	1
02/10/2022 17:00	0.0	0	0	0	0	1
02/10/2022 18:00	0.0	0	0	0	0	1
02/10/2022 19:00	0.0	0	0	0	0	1
02/10/2022 20:00	0.0	0	0	0	0	1
02/10/2022 21:00	0.0	0	0	0	0	1
02/10/2022 22:00	0.0	0	0	0	0	1
02/10/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	80.8 #	0 #	0 #	2 #	1 #	19 #
Minimum:	0.0	0	0	0	0	0
Maximum:	76.2	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/11/2022 00:00	0.0	0	0	0	0	1
02/11/2022 01:00	3.0	0	0	0	1	0
02/11/2022 02:00	0.0	0	0	0	0	0
02/11/2022 03:00	0.0	0	0	0	0	0
02/11/2022 04:00	0.0	0	0	0	0	0
02/11/2022 05:00	0.0	0	0	0	0	0
02/11/2022 06:00	0.0	0	0	0	0	0
02/11/2022 07:00	0.0	0	0	0	0	0
02/11/2022 08:00	0.0	0	0	0	0	0
02/11/2022 09:00	0.0	0	0	0	0	0
02/11/2022 10:00	0.0	0	0	0	0	0
02/11/2022 11:00	0.0	0	0	0	0	0
02/11/2022 12:00	0.0	0	0	0	0	0
02/11/2022 13:00	0.0	0	0	0	0	0
02/11/2022 14:00	0.0	0	0	0	0	0
02/11/2022 15:00	0.0	0	0	0	0	0
02/11/2022 16:00	0.0	0	0	0	0	0
02/11/2022 17:00	0.0	0	0	0	0	0
02/11/2022 18:00	0.0	0	0	0	0	0
02/11/2022 19:00	0.0	0	0	0	0	0
02/11/2022 20:00	0.0	0	0	0	0	0
02/11/2022 21:00	0.0	0	0	0	0	0
02/11/2022 22:00	0.0	0	0	0	0	0
02/11/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	3.0 #	0 #	0 #	0 #	1 #	1 #
Minimum:	0.0	0	0	0	0	0
Maximum:	3.0	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/12/2022 00:00	0.0	0	0	0	0	0
02/12/2022 01:00	0.0	0	0	0	0	0
02/12/2022 02:00	0.0	0	0	0	0	0
02/12/2022 03:00	0.0	0	0	0	0	0
02/12/2022 04:00	0.0	0	0	0	0	0
02/12/2022 05:00	0.0	0	0	0	0	0
02/12/2022 06:00	0.0	0	0	0	0	0
02/12/2022 07:00	0.0	0	0	0	0	0
02/12/2022 08:00	0.0	0	0	0	0	0
02/12/2022 09:00	0.0	0	0	0	0	0
02/12/2022 10:00	0.0	0	0	0	0	0
02/12/2022 11:00	0.0	0	0	0	0	0
02/12/2022 12:00	0.0	0	0	0	0	0
02/12/2022 13:00	0.0	0	0	0	0	0
02/12/2022 14:00	0.0	0	0	0	0	0
02/12/2022 15:00	0.0	0	0	0	0	0
02/12/2022 16:00	0.0	0	0	0	0	0
02/12/2022 17:00	0.0	0	0	0	0	0
02/12/2022 18:00	0.0	0	0	0	0	0
02/12/2022 19:00	0.0	0	0	0	0	0
02/12/2022 20:00	0.0	0	0	0	0	0
02/12/2022 21:00	0.0	0	0	0	0	0
02/12/2022 22:00	0.0	0	0	0	0	0
02/12/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/13/2022 00:00	0.0	0	0	0	0	0
02/13/2022 01:00	0.0	0	0	0	0	0
02/13/2022 02:00	0.0	0	0	0	0	0
02/13/2022 03:00	0.0	0	0	0	0	0
02/13/2022 04:00	0.0	0	0	0	0	0
02/13/2022 05:00	0.0	0	0	0	0	0
02/13/2022 06:00	0.0	0	0	0	0	0
02/13/2022 07:00	0.0	0	0	0	0	0
02/13/2022 08:00	0.0	0	0	0	0	0
02/13/2022 09:00	0.0	0	0	0	0	0
02/13/2022 10:00	0.0	0	0	0	0	0
02/13/2022 11:00	0.0	0	0	0	0	0
02/13/2022 12:00	0.0	0	0	0	0	0
02/13/2022 13:00	0.0	0	0	0	0	0
02/13/2022 14:00	0.0	0	0	0	0	0
02/13/2022 15:00	0.0	0	0	0	0	0
02/13/2022 16:00	0.0	0	0	0	0	0
02/13/2022 17:00	0.0	0	0	0	0	0
02/13/2022 18:00	0.0	0	0	0	0	0
02/13/2022 19:00	0.0	0	0	0	0	0
02/13/2022 20:00	0.0	0	0	0	0	0
02/13/2022 21:00	0.0	0	0	0	0	0
02/13/2022 22:00	0.0	0	0	0	0	0
02/13/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/14/2022 00:00	0.0	0	0	0	0	0
02/14/2022 01:00	0.0	0	0	0	0	0
02/14/2022 02:00	0.0	0	0	0	0	0
02/14/2022 03:00	0.0	0	0	0	0	0
02/14/2022 04:00	0.0	0	0	0	0	0
02/14/2022 05:00	0.0	0	0	0	0	0
02/14/2022 06:00	0.0	0	0	0	0	0
02/14/2022 07:00	0.0	0	0	0	0	0
02/14/2022 08:00	0.0	0	0	0	0	0
02/14/2022 09:00	0.0	0	0	0	0	0
02/14/2022 10:00	0.0	0	0	0	0	0
02/14/2022 11:00	0.0	0	0	0	0	0
02/14/2022 12:00	0.0	0	0	0	0	0
02/14/2022 13:00	0.0	0	0	0	0	0
02/14/2022 14:00	0.0	0	0	0	0	0
02/14/2022 15:00	0.0	0	0	0	0	0
02/14/2022 16:00	0.0	0	0	0	0	0
02/14/2022 17:00	0.0	0	0	0	0	0
02/14/2022 18:00	0.0	0	0	0	0	0
02/14/2022 19:00	0.0	0	0	0	0	0
02/14/2022 20:00	0.0	0	0	0	0	0
02/14/2022 21:00	0.0	0	0	0	0	0
02/14/2022 22:00	0.0	0	0	0	0	0
02/14/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/15/2022 00:00	0.0	0	0	0	0	0
02/15/2022 01:00	0.0	0	0	0	0	0
02/15/2022 02:00	0.0	0	0	0	0	0
02/15/2022 03:00	0.0	0	0	0	0	0
02/15/2022 04:00	0.0	0	0	0	0	0
02/15/2022 05:00	0.0	0	0	0	0	0
02/15/2022 06:00	0.0	0	0	0	0	0
02/15/2022 07:00	0.0	0	0	0	0	0
02/15/2022 08:00	0.0	0	0	0	0	0
02/15/2022 09:00	0.0	0	0	0	0	0
02/15/2022 10:00	0.0	0	0	0	0	0
02/15/2022 11:00	0.0	0	0	0	0	0
02/15/2022 12:00	0.0	0	0	0	0	0
02/15/2022 13:00	0.0	0	0	0	0	0
02/15/2022 14:00	0.0	0	0	0	0	0
02/15/2022 15:00	0.0	0	0	0	0	0
02/15/2022 16:00	0.0	0	0	0	0	0
02/15/2022 17:00	0.0	0	0	0	0	0
02/15/2022 18:00	0.0	0	0	0	0	0
02/15/2022 19:00	0.0	0	0	0	0	0
02/15/2022 20:00	0.0	0	0	0	0	0
02/15/2022 21:00	0.0	0	0	0	0	0
02/15/2022 22:00	0.0	0	0	0	0	0
02/15/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/16/2022 00:00	0.0	0	0	0	0	0
02/16/2022 01:00	0.0	0	0	0	0	0
02/16/2022 02:00	0.0	0	0	0	0	0
02/16/2022 03:00	0.0	0	0	0	0	0
02/16/2022 04:00	0.0	0	0	0	0	0
02/16/2022 05:00	0.0	0	0	0	0	0
02/16/2022 06:00	0.0	0	0	0	0	0
02/16/2022 07:00	0.0	0	0	0	0	0
02/16/2022 08:00	0.0	0	0	0	0	0
02/16/2022 09:00	0.0	0	0	0	0	0
02/16/2022 10:00	0.0	0	0	0	0	0
02/16/2022 11:00	0.0	0	0	0	0	0
02/16/2022 12:00	0.0	0	0	0	0	0
02/16/2022 13:00	0.0	0	0	0	0	0
02/16/2022 14:00	0.0	0	0	0	0	0
02/16/2022 15:00	0.0	0	0	0	0	0
02/16/2022 16:00	0.0	0	0	0	0	0
02/16/2022 17:00	0.0	0	0	0	0	0
02/16/2022 18:00	0.0	0	0	0	0	0
02/16/2022 19:00	0.0	0	0	0	0	0
02/16/2022 20:00	0.0	0	0	0	0	0
02/16/2022 21:00	0.0	0	0	0	0	0
02/16/2022 22:00	0.0	0	0	0	0	0
02/16/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/17/2022 00:00	0.0	0	0	0	0	0
02/17/2022 01:00	0.0	0	0	0	0	0
02/17/2022 02:00	0.0	0	0	0	0	0
02/17/2022 03:00	0.0	0	0	0	0	0
02/17/2022 04:00	0.0	0	0	0	0	0
02/17/2022 05:00	0.0	0	0	0	0	0
02/17/2022 06:00	0.0	0	0	0	0	0
02/17/2022 07:00	0.0	0	0	0	0	0
02/17/2022 08:00	0.0	0	0	0	0	0
02/17/2022 09:00	0.0	0	0	0	0	0
02/17/2022 10:00	0.0	0	0	0	0	0
02/17/2022 11:00	0.0	0	0	0	0	0
02/17/2022 12:00	0.0	0	0	0	0	0
02/17/2022 13:00	0.0	0	0	0	0	0
02/17/2022 14:00	0.0	0	0	0	0	0
02/17/2022 15:00	0.0	0	0	0	0	0
02/17/2022 16:00	0.0	0	0	0	0	0
02/17/2022 17:00	0.0	0	0	0	0	0
02/17/2022 18:00	0.0	0	0	0	0	0
02/17/2022 19:00	0.0	0	0	0	0	0
02/17/2022 20:00	0.0	0	0	0	0	0
02/17/2022 21:00	0.0	0	0	0	0	0
02/17/2022 22:00	0.0	0	0	0	0	0
02/17/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/18/2022 00:00	0.0	0	0	0	0	0
02/18/2022 01:00	0.0	0	0	0	0	0
02/18/2022 02:00	0.0	0	0	0	0	0
02/18/2022 03:00	0.0	0	0	0	0	0
02/18/2022 04:00	0.0	0	0	0	0	0
02/18/2022 05:00	0.0	0	0	0	0	0
02/18/2022 06:00	0.0	0	0	0	0	0
02/18/2022 07:00	0.0	0	0	0	0	0
02/18/2022 08:00	18.5	1	0	0	0	0
02/18/2022 09:00	61.4	1	0	0	0	0
02/18/2022 10:00	25.8	1	0	0	0	0
02/18/2022 11:00	140.3	1	0	0	0	0
02/18/2022 12:00	72.1	1	0	0	0	0
02/18/2022 13:00	0.0	0	0	0	0	1
02/18/2022 14:00	0.0	0	0	0	0	1
02/18/2022 15:00	0.0	0	0	0	0	1
02/18/2022 16:00	0.0	0	0	0	0	1
02/18/2022 17:00	0.0	0	0	0	0	1
02/18/2022 18:00	0.0	0	0	0	0	1
02/18/2022 19:00	0.0	0	0	0	0	1
02/18/2022 20:00	0.0	0	0	0	0	1
02/18/2022 21:00	0.0	0	0	0	0	1
02/18/2022 22:00	0.0	0	0	0	0	1
02/18/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	318.1 #	5 #	0 #	0 #	0 #	11 #
Minimum:	0.0	0	0	0	0	0
Maximum:	140.3	1	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/19/2022 00:00	2.3	0	0	0	1	0
02/19/2022 01:00	0.0	0	0	0	0	0
02/19/2022 02:00	0.0	0	0	0	0	0
02/19/2022 03:00	0.0	0	0	0	0	0
02/19/2022 04:00	0.0	0	0	0	0	0
02/19/2022 05:00	0.0	0	0	0	0	0
02/19/2022 06:00	0.0	0	0	0	0	0
02/19/2022 07:00	0.0	0	0	0	0	0
02/19/2022 08:00	0.0	0	0	0	0	0
02/19/2022 09:00	0.0	0	0	0	0	0
02/19/2022 10:00	0.0	0	0	0	0	0
02/19/2022 11:00	0.0	0	0	0	0	0
02/19/2022 12:00	0.0	0	0	0	0	0
02/19/2022 13:00	0.0	0	0	0	0	0
02/19/2022 14:00	0.0	0	0	0	0	0
02/19/2022 15:00	0.0	0	0	0	0	0
02/19/2022 16:00	0.0	0	0	0	0	0
02/19/2022 17:00	0.0	0	0	0	0	0
02/19/2022 18:00	0.0	0	0	0	0	0
02/19/2022 19:00	0.0	0	0	0	0	0
02/19/2022 20:00	0.0	0	0	0	0	0
02/19/2022 21:00	0.0	0	0	0	0	0
02/19/2022 22:00	0.0	0	0	0	0	0
02/19/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	2.3 #	0 #	0 #	0 #	1 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	2.3	0	0	0	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/20/2022 00:00	0.0	0	0	0	0	0
02/20/2022 01:00	0.0	0	0	0	0	0
02/20/2022 02:00	0.0	0	0	0	0	0
02/20/2022 03:00	0.0	0	0	0	0	0
02/20/2022 04:00	0.0	0	0	0	0	0
02/20/2022 05:00	0.0	0	0	0	0	0
02/20/2022 06:00	0.0	0	0	0	0	0
02/20/2022 07:00	0.0	0	0	0	0	0
02/20/2022 08:00	0.0	0	0	0	0	0
02/20/2022 09:00	0.0	0	0	0	0	0
02/20/2022 10:00	0.0	0	0	0	0	0
02/20/2022 11:00	0.0	0	0	0	0	0
02/20/2022 12:00	0.0	0	0	0	0	0
02/20/2022 13:00	0.0	0	0	0	0	0
02/20/2022 14:00	0.0	0	0	0	0	0
02/20/2022 15:00	0.0	0	0	0	0	0
02/20/2022 16:00	0.0	0	0	0	0	0
02/20/2022 17:00	0.0	0	0	0	0	0
02/20/2022 18:00	0.0	0	0	0	0	0
02/20/2022 19:00	0.0	0	0	0	0	0
02/20/2022 20:00	0.0	0	0	0	0	0
02/20/2022 21:00	0.0	0	0	0	0	0
02/20/2022 22:00	0.0	0	0	0	0	0
02/20/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/21/2022 00:00	0.0	0	0	0	0	0
02/21/2022 01:00	0.0	0	0	0	0	0
02/21/2022 02:00	0.0	0	0	0	0	0
02/21/2022 03:00	0.0	0	0	0	0	0
02/21/2022 04:00	0.0	0	0	0	0	0
02/21/2022 05:00	0.0	0	0	0	0	0
02/21/2022 06:00	0.0	0	0	0	0	0
02/21/2022 07:00	0.0	0	0	0	0	0
02/21/2022 08:00	0.0	0	0	0	0	0
02/21/2022 09:00	0.0	0	0	0	0	0
02/21/2022 10:00	0.0	0	0	0	0	0
02/21/2022 11:00	0.0	0	0	0	0	0
02/21/2022 12:00	0.0	0	0	0	0	0
02/21/2022 13:00	0.0	0	0	0	0	0
02/21/2022 14:00	0.0	0	0	0	0	0
02/21/2022 15:00	0.0	0	0	0	0	0
02/21/2022 16:00	0.0	0	0	0	0	0
02/21/2022 17:00	0.0	0	0	0	0	0
02/21/2022 18:00	0.0	0	0	0	0	0
02/21/2022 19:00	0.0	0	0	0	0	0
02/21/2022 20:00	0.0	0	0	0	0	0
02/21/2022 21:00	0.0	0	0	0	0	0
02/21/2022 22:00	0.0	0	0	0	0	0
02/21/2022 23:00	68.3	0	1	0	0	0
Average/Sum#:	68.3 #	0 #	1 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	68.3	0	1	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/22/2022 00:00	30.9	0	1	0	0	0
02/22/2022 01:00	84.0	0	1	0	0	0
02/22/2022 02:00	0.0	0	0	0	0	1
02/22/2022 03:00	0.0	0	0	0	0	1
02/22/2022 04:00	0.0	0	0	0	0	1
02/22/2022 05:00	0.0	0	0	0	0	1
02/22/2022 06:00	0.0	0	0	0	0	1
02/22/2022 07:00	0.0	0	0	0	0	1
02/22/2022 08:00	0.0	0	0	0	0	1
02/22/2022 09:00	0.0	0	0	0	0	1
02/22/2022 10:00	0.0	0	0	0	0	1
02/22/2022 11:00	0.0	0	0	0	0	1
02/22/2022 12:00	0.0	0	0	0	0	1
02/22/2022 13:00	0.0	0	0	0	0	1
02/22/2022 14:00	0.0	0	0	0	0	1
02/22/2022 15:00	0.0	0	0	0	0	1
02/22/2022 16:00	0.0	0	0	0	0	1
02/22/2022 17:00	0.0	0	0	0	0	1
02/22/2022 18:00	0.0	0	0	0	0	1
02/22/2022 19:00	0.0	0	0	0	0	1
02/22/2022 20:00	0.0	0	0	0	0	1
02/22/2022 21:00	0.0	0	0	0	0	1
02/22/2022 22:00	0.0	0	0	0	0	1
02/22/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	114.9 #	0 #	2 #	0 #	0 #	22 #
Minimum:	0.0	0	0	0	0	0
Maximum:	84.0	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/23/2022 00:00	0.0	0	0	0	0	1
02/23/2022 01:00	0.0	0	0	0	0	1
02/23/2022 02:00	0.0	0	0	0	0	1
02/23/2022 03:00	0.0	0	0	0	0	1
02/23/2022 04:00	0.0	0	0	0	0	1
02/23/2022 05:00	0.0	0	0	0	0	1
02/23/2022 06:00	0.0	0	0	0	0	1
02/23/2022 07:00	0.0	0	0	0	0	1
02/23/2022 08:00	0.0	0	0	0	0	1
02/23/2022 09:00	0.0	0	0	0	0	1
02/23/2022 10:00	0.0	0	0	0	0	1
02/23/2022 11:00	0.0	0	0	0	0	1
02/23/2022 12:00	0.0	0	0	0	0	1
02/23/2022 13:00	0.0	0	0	0	0	1
02/23/2022 14:00	0.0	0	0	0	0	1
02/23/2022 15:00	0.0	0	0	0	0	1
02/23/2022 16:00	0.0	0	0	0	0	1
02/23/2022 17:00	0.0	0	0	0	0	1
02/23/2022 18:00	0.0	0	0	0	0	1
02/23/2022 19:00	0.0	0	0	0	0	1
02/23/2022 20:00	0.0	0	0	0	0	1
02/23/2022 21:00	0.0	0	0	0	0	1
02/23/2022 22:00	0.0	0	0	0	0	1
02/23/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/24/2022 00:00	0.0	0	0	0	0	1
02/24/2022 01:00	0.0	0	0	0	0	1
02/24/2022 02:00	0.0	0	0	0	0	1
02/24/2022 03:00	0.0	0	0	0	0	1
02/24/2022 04:00	0.0	0	0	0	0	1
02/24/2022 05:00	0.0	0	0	0	0	1
02/24/2022 06:00	0.0	0	0	0	0	1
02/24/2022 07:00	0.0	0	0	0	0	1
02/24/2022 08:00	0.0	0	0	0	0	1
02/24/2022 09:00	0.0	0	0	0	0	1
02/24/2022 10:00	0.0	0	0	0	0	1
02/24/2022 11:00	0.0	0	0	0	0	1
02/24/2022 12:00	0.0	0	0	0	0	1
02/24/2022 13:00	0.0	0	0	0	0	1
02/24/2022 14:00	0.0	0	0	0	0	1
02/24/2022 15:00	0.0	0	0	0	0	1
02/24/2022 16:00	0.0	0	0	0	0	1
02/24/2022 17:00	0.0	0	0	0	0	1
02/24/2022 18:00	0.0	0	0	0	0	1
02/24/2022 19:00	0.0	0	0	0	0	1
02/24/2022 20:00	0.0	0	0	0	0	1
02/24/2022 21:00	0.0	0	0	0	0	1
02/24/2022 22:00	0.0	0	0	0	0	1
02/24/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/25/2022 00:00	0.0	0	0	0	0	1
02/25/2022 01:00	0.0	0	0	0	0	1
02/25/2022 02:00	0.0	0	0	0	0	1
02/25/2022 03:00	0.0	0	0	0	0	1
02/25/2022 04:00	0.0	0	0	0	0	1
02/25/2022 05:00	0.0	0	0	0	0	1
02/25/2022 06:00	0.0	0	0	0	0	1
02/25/2022 07:00	0.0	0	0	0	0	1
02/25/2022 08:00	0.0	0	0	0	0	1
02/25/2022 09:00	0.0	0	0	0	0	1
02/25/2022 10:00	0.0	0	0	0	0	1
02/25/2022 11:00	0.0	0	0	0	0	1
02/25/2022 12:00	0.0	0	0	0	0	1
02/25/2022 13:00	0.0	0	0	0	0	1
02/25/2022 14:00	0.0	0	0	0	0	1
02/25/2022 15:00	0.0	0	0	0	0	1
02/25/2022 16:00	0.0	0	0	0	0	1
02/25/2022 17:00	0.0	0	0	0	0	1
02/25/2022 18:00	0.0	0	0	0	0	1
02/25/2022 19:00	0.0	0	0	0	0	1
02/25/2022 20:00	0.0	0	0	0	0	1
02/25/2022 21:00	0.0	0	0	0	0	1
02/25/2022 22:00	0.0	0	0	0	0	1
02/25/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/26/2022 00:00	0.0	0	0	0	0	1
02/26/2022 01:00	0.0	0	0	0	0	1
02/26/2022 02:00	0.0	0	0	0	0	1
02/26/2022 03:00	0.0	0	0	0	0	1
02/26/2022 04:00	0.0	0	0	0	0	1
02/26/2022 05:00	0.0	0	0	0	0	1
02/26/2022 06:00	0.0	0	0	0	0	1
02/26/2022 07:00	2.7	0	0	0	1	0
02/26/2022 08:00	0.0	0	0	0	0	0
02/26/2022 09:00	0.0	0	0	0	0	0
02/26/2022 10:00	0.0	0	0	0	0	0
02/26/2022 11:00	0.0	0	0	0	0	0
02/26/2022 12:00	0.0	0	0	0	0	0
02/26/2022 13:00	0.0	0	0	0	0	0
02/26/2022 14:00	0.0	0	0	0	0	0
02/26/2022 15:00	15.9	0	1	0	0	0
02/26/2022 16:00	93.1	0	1	0	0	0
02/26/2022 17:00	0.0	0	0	0	0	1
02/26/2022 18:00	0.0	0	0	0	0	1
02/26/2022 19:00	0.0	0	0	0	0	1
02/26/2022 20:00	0.0	0	0	0	0	1
02/26/2022 21:00	0.0	0	0	0	0	1
02/26/2022 22:00	0.0	0	0	0	0	1
02/26/2022 23:00	2.7	0	0	0	1	0
Average/Sum#:	114.4 #	0 #	2 #	0 #	2 #	13 #
Minimum:	0.0	0	0	0	0	0
Maximum:	93.1	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/27/2022 00:00	0.0	0	0	0	0	0
02/27/2022 01:00	0.0	0	0	0	0	0
02/27/2022 02:00	0.0	0	0	0	0	0
02/27/2022 03:00	0.0	0	0	0	0	0
02/27/2022 04:00	0.0	0	0	0	0	0
02/27/2022 05:00	0.0	0	0	0	0	0
02/27/2022 06:00	0.0	0	0	0	0	0
02/27/2022 07:00	0.0	0	0	0	0	0
02/27/2022 08:00	0.0	0	0	0	0	0
02/27/2022 09:00	0.0	0	0	0	0	0
02/27/2022 10:00	0.0	0	0	0	0	0
02/27/2022 11:00	0.0	0	0	0	0	0
02/27/2022 12:00	0.0	0	0	0	0	0
02/27/2022 13:00	0.0	0	0	0	0	0
02/27/2022 14:00	0.0	0	0	0	0	0
02/27/2022 15:00	0.0	0	0	0	0	0
02/27/2022 16:00	0.0	0	0	0	0	0
02/27/2022 17:00	0.0	0	0	0	0	0
02/27/2022 18:00	0.0	0	0	0	0	0
02/27/2022 19:00	0.0	0	0	0	0	0
02/27/2022 20:00	0.0	0	0	0	0	0
02/27/2022 21:00	0.0	0	0	0	0	0
02/27/2022 22:00	0.0	0	0	0	0	0
02/27/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/28/2022 00:00	0.0	0	0	0	0	0
02/28/2022 01:00	0.0	0	0	0	0	0
02/28/2022 02:00	0.0	0	0	0	0	0
02/28/2022 03:00	0.0	0	0	0	0	0
02/28/2022 04:00	0.0	0	0	0	0	0
02/28/2022 05:00	0.0	0	0	0	0	0
02/28/2022 06:00	0.0	0	0	0	0	0
02/28/2022 07:00	0.0	0	0	0	0	0
02/28/2022 08:00	0.0	0	0	0	0	0
02/28/2022 09:00	0.0	0	0	0	0	0
02/28/2022 10:00	0.0	0	0	0	0	0
02/28/2022 11:00	0.0	0	0	0	0	0
02/28/2022 12:00	0.0	0	0	0	0	0
02/28/2022 13:00	63.8	0	1	0	0	0
02/28/2022 14:00	27.2	0	1	0	0	0
02/28/2022 15:00	56.9	0	1	0	0	0
02/28/2022 16:00	0.0	0	0	0	0	1
02/28/2022 17:00	0.0	0	0	0	0	1
02/28/2022 18:00	0.0	0	0	0	0	1
02/28/2022 19:00	0.0	0	0	0	0	1
02/28/2022 20:00	0.0	0	0	0	0	1
02/28/2022 21:00	0.0	0	0	0	0	1
02/28/2022 22:00	4.2	0	0	0	1	0
02/28/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	152.1 #	0 #	3 #	0 #	1 #	6 #
Minimum:	0.0	0	0	0	0	0
Maximum:	63.8	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/01/2022 00:00	0.0	0	0	0	0	0
03/01/2022 01:00	0.0	0	0	0	0	0
03/01/2022 02:00	0.0	0	0	0	0	0
03/01/2022 03:00	0.0	0	0	0	0	0
03/01/2022 04:00	0.0	0	0	0	0	0
03/01/2022 05:00	0.0	0	0	0	0	0
03/01/2022 06:00	0.0	0	0	0	0	0
03/01/2022 07:00	0.0	0	0	0	0	0
03/01/2022 08:00	0.0	0	0	0	0	0
03/01/2022 09:00	0.0	0	0	0	0	0
03/01/2022 10:00	0.0	0	0	0	0	0
03/01/2022 11:00	0.0	0	0	0	0	0
03/01/2022 12:00	0.0	0	0	0	0	0
03/01/2022 13:00	0.0	0	0	0	0	0
03/01/2022 14:00	0.0	0	0	0	0	0
03/01/2022 15:00	0.0	0	0	0	0	0
03/01/2022 16:00	0.0	0	0	0	0	0
03/01/2022 17:00	0.0	0	0	0	0	0
03/01/2022 18:00	0.0	0	0	0	0	0
03/01/2022 19:00	0.0	0	0	0	0	0
03/01/2022 20:00	0.0	0	0	0	0	0
03/01/2022 21:00	0.0	0	0	0	0	0
03/01/2022 22:00	0.0	0	0	0	0	0
03/01/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/02/2022 00:00	0.0	0	0	0	0	0
03/02/2022 01:00	0.0	0	0	0	0	0
03/02/2022 02:00	0.0	0	0	0	0	0
03/02/2022 03:00	0.0	0	0	0	0	0
03/02/2022 04:00	0.0	0	0	0	0	0
03/02/2022 05:00	0.0	0	0	0	0	0
03/02/2022 06:00	0.0	0	0	0	0	0
03/02/2022 07:00	0.0	0	0	0	0	0
03/02/2022 08:00	0.0	0	0	0	0	0
03/02/2022 09:00	0.0	0	0	0	0	0
03/02/2022 10:00	0.0	0	0	0	0	0
03/02/2022 11:00	0.0	0	0	0	0	0
03/02/2022 12:00	0.0	0	0	0	0	0
03/02/2022 13:00	0.0	0	0	0	0	0
03/02/2022 14:00	0.0	0	0	0	0	0
03/02/2022 15:00	0.0	0	0	0	0	0
03/02/2022 16:00	0.0	0	0	0	0	0
03/02/2022 17:00	0.0	0	0	0	0	0
03/02/2022 18:00	0.0	0	0	0	0	0
03/02/2022 19:00	0.0	0	0	0	0	0
03/02/2022 20:00	0.0	0	0	0	0	0
03/02/2022 21:00	0.0	0	0	0	0	0
03/02/2022 22:00	0.0	0	0	0	0	0
03/02/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/03/2022 00:00	0.0	0	0	0	0	0
03/03/2022 01:00	0.0	0	0	0	0	0
03/03/2022 02:00	0.0	0	0	0	0	0
03/03/2022 03:00	0.0	0	0	0	0	0
03/03/2022 04:00	0.0	0	0	0	0	0
03/03/2022 05:00	0.0	0	0	0	0	0
03/03/2022 06:00	0.0	0	0	0	0	0
03/03/2022 07:00	0.0	0	0	0	0	0
03/03/2022 08:00	0.0	0	0	0	0	0
03/03/2022 09:00	0.0	0	0	0	0	0
03/03/2022 10:00	0.0	0	0	0	0	0
03/03/2022 11:00	0.0	0	0	0	0	0
03/03/2022 12:00	0.0	0	0	0	0	0
03/03/2022 13:00	0.0	0	0	0	0	0
03/03/2022 14:00	0.0	0	0	0	0	0
03/03/2022 15:00	0.0	0	0	0	0	0
03/03/2022 16:00	0.0	0	0	0	0	0
03/03/2022 17:00	0.0	0	0	0	0	0
03/03/2022 18:00	0.0	0	0	0	0	0
03/03/2022 19:00	0.0	0	0	0	0	0
03/03/2022 20:00	0.0	0	0	0	0	0
03/03/2022 21:00	0.0	0	0	0	0	0
03/03/2022 22:00	0.0	0	0	0	0	0
03/03/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/04/2022 00:00	0.0	0	0	0	0	0
03/04/2022 01:00	0.0	0	0	0	0	0
03/04/2022 02:00	0.0	0	0	0	0	0
03/04/2022 03:00	0.0	0	0	0	0	0
03/04/2022 04:00	0.0	0	0	0	0	0
03/04/2022 05:00	0.0	0	0	0	0	0
03/04/2022 06:00	0.0	0	0	0	0	0
03/04/2022 07:00	0.0	0	0	0	0	0
03/04/2022 08:00	0.0	0	0	0	0	0
03/04/2022 09:00	0.0	0	0	0	0	0
03/04/2022 10:00	0.0	0	0	0	0	0
03/04/2022 11:00	0.0	0	0	0	0	0
03/04/2022 12:00	0.0	0	0	0	0	0
03/04/2022 13:00	0.0	0	0	0	0	0
03/04/2022 14:00	0.0	0	0	0	0	0
03/04/2022 15:00	0.0	0	0	0	0	0
03/04/2022 16:00	0.0	0	0	0	0	0
03/04/2022 17:00	0.0	0	0	0	0	0
03/04/2022 18:00	0.0	0	0	0	0	0
03/04/2022 19:00	0.0	0	0	0	0	0
03/04/2022 20:00	0.0	0	0	0	0	0
03/04/2022 21:00	0.0	0	0	0	0	0
03/04/2022 22:00	0.0	0	0	0	0	0
03/04/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/05/2022 00:00	0.0	0	0	0	0	0
03/05/2022 01:00	0.0	0	0	0	0	0
03/05/2022 02:00	0.0	0	0	0	0	0
03/05/2022 03:00	0.0	0	0	0	0	0
03/05/2022 04:00	0.0	0	0	0	0	0
03/05/2022 05:00	0.0	0	0	0	0	0
03/05/2022 06:00	0.0	0	0	0	0	0
03/05/2022 07:00	0.0	0	0	0	0	0
03/05/2022 08:00	0.0	0	0	0	0	0
03/05/2022 09:00	0.0	0	0	0	0	0
03/05/2022 10:00	0.0	0	0	0	0	0
03/05/2022 11:00	0.0	0	0	0	0	0
03/05/2022 12:00	0.0	0	0	0	0	0
03/05/2022 13:00	0.0	0	0	0	0	0
03/05/2022 14:00	0.0	0	0	0	0	0
03/05/2022 15:00	0.0	0	0	0	0	0
03/05/2022 16:00	0.0	0	0	0	0	0
03/05/2022 17:00	0.0	0	0	0	0	0
03/05/2022 18:00	0.0	0	0	0	0	0
03/05/2022 19:00	0.0	0	0	0	0	0
03/05/2022 20:00	0.0	0	0	0	0	0
03/05/2022 21:00	0.0	0	0	0	0	0
03/05/2022 22:00	0.0	0	0	0	0	0
03/05/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/06/2022 00:00	0.0	0	0	0	0	0
03/06/2022 01:00	0.0	0	0	0	0	0
03/06/2022 02:00	0.0	0	0	0	0	0
03/06/2022 03:00	0.0	0	0	0	0	0
03/06/2022 04:00	0.0	0	0	0	0	0
03/06/2022 05:00	0.0	0	0	0	0	0
03/06/2022 06:00	0.0	0	0	0	0	0
03/06/2022 07:00	0.0	0	0	0	0	0
03/06/2022 08:00	0.0	0	0	0	0	0
03/06/2022 09:00	0.0	0	0	0	0	0
03/06/2022 10:00	0.0	0	0	0	0	0
03/06/2022 11:00	0.0	0	0	0	0	0
03/06/2022 12:00	0.0	0	0	0	0	0
03/06/2022 13:00	0.0	0	0	0	0	0
03/06/2022 14:00	0.0	0	0	0	0	0
03/06/2022 15:00	0.0	0	0	0	0	0
03/06/2022 16:00	0.0	0	0	0	0	0
03/06/2022 17:00	0.0	0	0	0	0	0
03/06/2022 18:00	0.0	0	0	0	0	0
03/06/2022 19:00	0.0	0	0	0	0	0
03/06/2022 20:00	0.0	0	0	0	0	0
03/06/2022 21:00	0.0	0	0	0	0	0
03/06/2022 22:00	0.0	0	0	0	0	0
03/06/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/07/2022 00:00	0.0	0	0	0	0	0
03/07/2022 01:00	0.0	0	0	0	0	0
03/07/2022 02:00	0.0	0	0	0	0	0
03/07/2022 03:00	0.0	0	0	0	0	0
03/07/2022 04:00	0.0	0	0	0	0	0
03/07/2022 05:00	0.0	0	0	0	0	0
03/07/2022 06:00	0.0	0	0	0	0	0
03/07/2022 07:00	0.0	0	0	0	0	0
03/07/2022 08:00	0.0	0	0	0	0	0
03/07/2022 09:00	0.0	0	0	0	0	0
03/07/2022 10:00	0.0	0	0	0	0	0
03/07/2022 11:00	0.0	0	0	0	0	0
03/07/2022 12:00	0.0	0	0	0	0	0
03/07/2022 13:00	0.0	0	0	0	0	0
03/07/2022 14:00	0.0	0	0	0	0	0
03/07/2022 15:00	0.0	0	0	0	0	0
03/07/2022 16:00	0.0	0	0	0	0	0
03/07/2022 17:00	0.0	0	0	0	0	0
03/07/2022 18:00	0.0	0	0	0	0	0
03/07/2022 19:00	0.0	0	0	0	0	0
03/07/2022 20:00	0.0	0	0	0	0	0
03/07/2022 21:00	0.0	0	0	0	0	0
03/07/2022 22:00	0.0	0	0	0	0	0
03/07/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/08/2022 00:00	0.0	0	0	0	0	0
03/08/2022 01:00	0.0	0	0	0	0	0
03/08/2022 02:00	0.0	0	0	0	0	0
03/08/2022 03:00	0.0	0	0	0	0	0
03/08/2022 04:00	0.0	0	0	0	0	0
03/08/2022 05:00	0.0	0	0	0	0	0
03/08/2022 06:00	0.0	0	0	0	0	0
03/08/2022 07:00	0.0	0	0	0	0	0
03/08/2022 08:00	0.0	0	0	0	0	0
03/08/2022 09:00	0.0	0	0	0	0	0
03/08/2022 10:00	0.0	0	0	0	0	0
03/08/2022 11:00	0.0	0	0	0	0	0
03/08/2022 12:00	0.0	0	0	0	0	0
03/08/2022 13:00	0.0	0	0	0	0	0
03/08/2022 14:00	0.0	0	0	0	0	0
03/08/2022 15:00	0.0	0	0	0	0	0
03/08/2022 16:00	0.0	0	0	0	0	0
03/08/2022 17:00	0.0	0	0	0	0	0
03/08/2022 18:00	0.0	0	0	0	0	0
03/08/2022 19:00	0.0	0	0	0	0	0
03/08/2022 20:00	0.0	0	0	0	0	0
03/08/2022 21:00	0.0	0	0	0	0	0
03/08/2022 22:00	0.0	0	0	0	0	0
03/08/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/09/2022 00:00	0.0	0	0	0	0	0
03/09/2022 01:00	0.0	0	0	0	0	0
03/09/2022 02:00	0.0	0	0	0	0	0
03/09/2022 03:00	0.0	0	0	0	0	0
03/09/2022 04:00	0.0	0	0	0	0	0
03/09/2022 05:00	0.0	0	0	0	0	0
03/09/2022 06:00	0.0	0	0	0	0	0
03/09/2022 07:00	0.0	0	0	0	0	0
03/09/2022 08:00	0.0	0	0	0	0	0
03/09/2022 09:00	0.0	0	0	0	0	0
03/09/2022 10:00	0.0	0	0	0	0	0
03/09/2022 11:00	0.0	0	0	0	0	0
03/09/2022 12:00	0.0	0	0	0	0	0
03/09/2022 13:00	0.0	0	0	0	0	0
03/09/2022 14:00	0.0	0	0	0	0	0
03/09/2022 15:00	0.0	0	0	0	0	0
03/09/2022 16:00	0.0	0	0	0	0	0
03/09/2022 17:00	0.0	0	0	0	0	0
03/09/2022 18:00	0.0	0	0	0	0	0
03/09/2022 19:00	0.0	0	0	0	0	0
03/09/2022 20:00	0.0	0	0	0	0	0
03/09/2022 21:00	0.0	0	0	0	0	0
03/09/2022 22:00	0.0	0	0	0	0	0
03/09/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/10/2022 00:00	0.0	0	0	0	0	0
03/10/2022 01:00	0.0	0	0	0	0	0
03/10/2022 02:00	0.0	0	0	0	0	0
03/10/2022 03:00	0.0	0	0	0	0	0
03/10/2022 04:00	0.0	0	0	0	0	0
03/10/2022 05:00	0.0	0	0	0	0	0
03/10/2022 06:00	0.0	0	0	0	0	0
03/10/2022 07:00	0.0	0	0	0	0	0
03/10/2022 08:00	0.0	0	0	0	0	0
03/10/2022 09:00	0.0	0	0	0	0	0
03/10/2022 10:00	0.0	0	0	0	0	0
03/10/2022 11:00	0.0	0	0	0	0	0
03/10/2022 12:00	0.0	0	0	0	0	0
03/10/2022 13:00	0.0	0	0	0	0	0
03/10/2022 14:00	0.0	0	0	0	0	0
03/10/2022 15:00	0.0	0	0	0	0	0
03/10/2022 16:00	0.0	0	0	0	0	0
03/10/2022 17:00	0.0	0	0	0	0	0
03/10/2022 18:00	0.0	0	0	0	0	0
03/10/2022 19:00	0.0	0	0	0	0	0
03/10/2022 20:00	0.0	0	0	0	0	0
03/10/2022 21:00	0.0	0	0	0	0	0
03/10/2022 22:00	0.0	0	0	0	0	0
03/10/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/11/2022 00:00	0.0	0	0	0	0	0
03/11/2022 01:00	0.0	0	0	0	0	0
03/11/2022 02:00	0.0	0	0	0	0	0
03/11/2022 03:00	0.0	0	0	0	0	0
03/11/2022 04:00	0.0	0	0	0	0	0
03/11/2022 05:00	0.0	0	0	0	0	0
03/11/2022 06:00	0.0	0	0	0	0	0
03/11/2022 07:00	0.0	0	0	0	0	0
03/11/2022 08:00	0.0	0	0	0	0	0
03/11/2022 09:00	0.0	0	0	0	0	0
03/11/2022 10:00	0.0	0	0	0	0	0
03/11/2022 11:00	0.0	0	0	0	0	0
03/11/2022 12:00	0.0	0	0	0	0	0
03/11/2022 13:00	0.0	0	0	0	0	0
03/11/2022 14:00	0.0	0	0	0	0	0
03/11/2022 15:00	0.0	0	0	0	0	0
03/11/2022 16:00	0.0	0	0	0	0	0
03/11/2022 17:00	0.0	0	0	0	0	0
03/11/2022 18:00	0.0	0	0	0	0	0
03/11/2022 19:00	0.0	0	0	0	0	0
03/11/2022 20:00	0.0	0	0	0	0	0
03/11/2022 21:00	0.0	0	0	0	0	0
03/11/2022 22:00	0.0	0	0	0	0	0
03/11/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/12/2022 00:00	0.0	0	0	0	0	0
03/12/2022 01:00	0.0	0	0	0	0	0
03/12/2022 02:00	0.0	0	0	0	0	0
03/12/2022 03:00	0.0	0	0	0	0	0
03/12/2022 04:00	0.0	0	0	0	0	0
03/12/2022 05:00	0.0	0	0	0	0	0
03/12/2022 06:00	0.0	0	0	0	0	0
03/12/2022 07:00	0.0	0	0	0	0	0
03/12/2022 08:00	0.0	0	0	0	0	0
03/12/2022 09:00	0.0	0	0	0	0	0
03/12/2022 10:00	0.0	0	0	0	0	0
03/12/2022 11:00	0.0	0	0	0	0	0
03/12/2022 12:00	0.0	0	0	0	0	0
03/12/2022 13:00	0.0	0	0	0	0	0
03/12/2022 14:00	0.0	0	0	0	0	0
03/12/2022 15:00	0.0	0	0	0	0	0
03/12/2022 16:00	0.0	0	0	0	0	0
03/12/2022 17:00	0.0	0	0	0	0	0
03/12/2022 18:00	0.0	0	0	0	0	0
03/12/2022 19:00	0.0	0	0	0	0	0
03/12/2022 20:00	0.0	0	0	0	0	0
03/12/2022 21:00	0.0	0	0	0	0	0
03/12/2022 22:00	0.0	0	0	0	0	0
03/12/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/13/2022 00:00	0.0	0	0	0	0	0
03/13/2022 01:00	0.0	0	0	0	0	0
03/13/2022 02:00	0.0	0	0	0	0	0
03/13/2022 03:00	0.0	0	0	0	0	0
03/13/2022 04:00	0.0	0	0	0	0	0
03/13/2022 05:00	0.0	0	0	0	0	0
03/13/2022 06:00	0.0	0	0	0	0	0
03/13/2022 07:00	0.0	0	0	0	0	0
03/13/2022 08:00	0.0	0	0	0	0	0
03/13/2022 09:00	0.0	0	0	0	0	0
03/13/2022 10:00	0.0	0	0	0	0	0
03/13/2022 11:00	0.0	0	0	0	0	0
03/13/2022 12:00	0.0	0	0	0	0	0
03/13/2022 13:00	0.0	0	0	0	0	0
03/13/2022 14:00	0.0	0	0	0	0	0
03/13/2022 15:00	0.0	0	0	0	0	0
03/13/2022 16:00	0.0	0	0	0	0	0
03/13/2022 17:00	0.0	0	0	0	0	0
03/13/2022 18:00	0.0	0	0	0	0	0
03/13/2022 19:00	0.0	0	0	0	0	0
03/13/2022 20:00	0.0	0	0	0	0	0
03/13/2022 21:00	0.0	0	0	0	0	0
03/13/2022 22:00	0.0	0	0	0	0	0
03/13/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/14/2022 00:00	0.0	0	0	0	0	0
03/14/2022 01:00	0.0	0	0	0	0	0
03/14/2022 02:00	0.0	0	0	0	0	0
03/14/2022 03:00	0.0	0	0	0	0	0
03/14/2022 04:00	0.0	0	0	0	0	0
03/14/2022 05:00	0.0	0	0	0	0	0
03/14/2022 06:00	0.0	0	0	0	0	0
03/14/2022 07:00	0.0	0	0	0	0	0
03/14/2022 08:00	0.0	0	0	0	0	0
03/14/2022 09:00	0.0	0	0	0	0	0
03/14/2022 10:00	0.0	0	0	0	0	0
03/14/2022 11:00	0.0	0	0	0	0	0
03/14/2022 12:00	0.0	0	0	0	0	0
03/14/2022 13:00	0.0	0	0	0	0	0
03/14/2022 14:00	0.0	0	0	0	0	0
03/14/2022 15:00	0.0	0	0	0	0	0
03/14/2022 16:00	0.0	0	0	0	0	0
03/14/2022 17:00	0.0	0	0	0	0	0
03/14/2022 18:00	0.0	0	0	0	0	0
03/14/2022 19:00	0.0	0	0	0	0	0
03/14/2022 20:00	0.0	0	0	0	0	0
03/14/2022 21:00	0.0	0	0	0	0	0
03/14/2022 22:00	0.0	0	0	0	0	0
03/14/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/15/2022 00:00	0.0	0	0	0	0	0
03/15/2022 01:00	0.0	0	0	0	0	0
03/15/2022 02:00	0.0	0	0	0	0	0
03/15/2022 03:00	0.0	0	0	0	0	0
03/15/2022 04:00	0.0	0	0	0	0	0
03/15/2022 05:00	0.0	0	0	0	0	0
03/15/2022 06:00	0.0	0	0	0	0	0
03/15/2022 07:00	0.0	0	0	0	0	0
03/15/2022 08:00	0.0	0	0	0	0	0
03/15/2022 09:00	0.0	0	0	0	0	0
03/15/2022 10:00	0.0	0	0	0	0	0
03/15/2022 11:00	0.0	0	0	0	0	0
03/15/2022 12:00	0.0	0	0	0	0	0
03/15/2022 13:00	0.0	0	0	0	0	0
03/15/2022 14:00	0.0	0	0	0	0	0
03/15/2022 15:00	0.0	0	0	0	0	0
03/15/2022 16:00	0.0	0	0	0	0	0
03/15/2022 17:00	0.0	0	0	0	0	0
03/15/2022 18:00	0.0	0	0	0	0	0
03/15/2022 19:00	0.0	0	0	0	0	0
03/15/2022 20:00	0.0	0	0	0	0	0
03/15/2022 21:00	0.0	0	0	0	0	0
03/15/2022 22:00	0.0	0	0	0	0	0
03/15/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/16/2022 00:00	0.0	0	0	0	0	0
03/16/2022 01:00	0.0	0	0	0	0	0
03/16/2022 02:00	0.0	0	0	0	0	0
03/16/2022 03:00	0.0	0	0	0	0	0
03/16/2022 04:00	0.0	0	0	0	0	0
03/16/2022 05:00	0.0	0	0	0	0	0
03/16/2022 06:00	0.0	0	0	0	0	0
03/16/2022 07:00	0.0	0	0	0	0	0
03/16/2022 08:00	0.0	0	0	0	0	0
03/16/2022 09:00	0.0	0	0	0	0	0
03/16/2022 10:00	0.0	0	0	0	0	0
03/16/2022 11:00	0.0	0	0	0	0	0
03/16/2022 12:00	0.0	0	0	0	0	0
03/16/2022 13:00	0.0	0	0	0	0	0
03/16/2022 14:00	0.0	0	0	0	0	0
03/16/2022 15:00	0.0	0	0	0	0	0
03/16/2022 16:00	0.0	0	0	0	0	0
03/16/2022 17:00	0.0	0	0	0	0	0
03/16/2022 18:00	0.0	0	0	0	0	0
03/16/2022 19:00	0.0	0	0	0	0	0
03/16/2022 20:00	0.0	0	0	0	0	0
03/16/2022 21:00	0.0	0	0	0	0	0
03/16/2022 22:00	0.0	0	0	0	0	0
03/16/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/17/2022 00:00	0.0	0	0	0	0	0
03/17/2022 01:00	0.0	0	0	0	0	0
03/17/2022 02:00	0.0	0	0	0	0	0
03/17/2022 03:00	0.0	0	0	0	0	0
03/17/2022 04:00	0.0	0	0	0	0	0
03/17/2022 05:00	0.0	0	0	0	0	0
03/17/2022 06:00	0.0	0	0	0	0	0
03/17/2022 07:00	0.0	0	0	0	0	0
03/17/2022 08:00	0.0	0	0	0	0	0
03/17/2022 09:00	0.0	0	0	0	0	0
03/17/2022 10:00	0.0	0	0	0	0	0
03/17/2022 11:00	0.0	0	0	0	0	0
03/17/2022 12:00	0.0	0	0	0	0	0
03/17/2022 13:00	0.0	0	0	0	0	0
03/17/2022 14:00	0.0	0	0	0	0	0
03/17/2022 15:00	0.0	0	0	0	0	0
03/17/2022 16:00	0.0	0	0	0	0	0
03/17/2022 17:00	0.0	0	0	0	0	0
03/17/2022 18:00	0.0	0	0	0	0	0
03/17/2022 19:00	0.0	0	0	0	0	0
03/17/2022 20:00	0.0	0	0	0	0	0
03/17/2022 21:00	0.0	0	0	0	0	0
03/17/2022 22:00	0.0	0	0	0	0	0
03/17/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/18/2022 00:00	0.0	0	0	0	0	0
03/18/2022 01:00	0.0	0	0	0	0	0
03/18/2022 02:00	0.0	0	0	0	0	0
03/18/2022 03:00	0.0	0	0	0	0	0
03/18/2022 04:00	0.0	0	0	0	0	0
03/18/2022 05:00	0.0	0	0	0	0	0
03/18/2022 06:00	0.0	0	0	0	0	0
03/18/2022 07:00	0.0	0	0	0	0	0
03/18/2022 08:00	0.0	0	0	0	0	0
03/18/2022 09:00	0.0	0	0	0	0	0
03/18/2022 10:00	0.0	0	0	0	0	0
03/18/2022 11:00	0.0	0	0	0	0	0
03/18/2022 12:00	0.0	0	0	0	0	0
03/18/2022 13:00	0.0	0	0	0	0	0
03/18/2022 14:00	0.0	0	0	0	0	0
03/18/2022 15:00	0.0	0	0	0	0	0
03/18/2022 16:00	0.0	0	0	0	0	0
03/18/2022 17:00	0.0	0	0	0	0	0
03/18/2022 18:00	0.0	0	0	0	0	0
03/18/2022 19:00	0.0	0	0	0	0	0
03/18/2022 20:00	0.0	0	0	0	0	0
03/18/2022 21:00	0.0	0	0	0	0	0
03/18/2022 22:00	0.0	0	0	0	0	0
03/18/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/19/2022 00:00	0.0	0	0	0	0	0
03/19/2022 01:00	0.0	0	0	0	0	0
03/19/2022 02:00	0.0	0	0	0	0	0
03/19/2022 03:00	0.0	0	0	0	0	0
03/19/2022 04:00	0.0	0	0	0	0	0
03/19/2022 05:00	0.0	0	0	0	0	0
03/19/2022 06:00	0.0	0	0	0	0	0
03/19/2022 07:00	0.0	0	0	0	0	0
03/19/2022 08:00	0.0	0	0	0	0	0
03/19/2022 09:00	0.0	0	0	0	0	0
03/19/2022 10:00	0.0	0	0	0	0	0
03/19/2022 11:00	0.0	0	0	0	0	0
03/19/2022 12:00	0.0	0	0	0	0	0
03/19/2022 13:00	0.0	0	0	0	0	0
03/19/2022 14:00	0.0	0	0	0	0	0
03/19/2022 15:00	0.0	0	0	0	0	0
03/19/2022 16:00	0.0	0	0	0	0	0
03/19/2022 17:00	0.0	0	0	0	0	0
03/19/2022 18:00	0.0	0	0	0	0	0
03/19/2022 19:00	0.0	0	0	0	0	0
03/19/2022 20:00	0.0	0	0	0	0	0
03/19/2022 21:00	0.0	0	0	0	0	0
03/19/2022 22:00	0.0	0	0	0	0	0
03/19/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwelll, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/20/2022 00:00	0.0	0	0	0	0	0
03/20/2022 01:00	0.0	0	0	0	0	0
03/20/2022 02:00	0.0	0	0	0	0	0
03/20/2022 03:00	0.0	0	0	0	0	0
03/20/2022 04:00	0.0	0	0	0	0	0
03/20/2022 05:00	0.0	0	0	0	0	0
03/20/2022 06:00	0.0	0	0	0	0	0
03/20/2022 07:00	0.0	0	0	0	0	0
03/20/2022 08:00	0.0	0	0	0	0	0
03/20/2022 09:00	0.0	0	0	0	0	0
03/20/2022 10:00	0.0	0	0	0	0	0
03/20/2022 11:00	0.0	0	0	0	0	0
03/20/2022 12:00	0.0	0	0	0	0	0
03/20/2022 13:00	0.0	0	0	0	0	0
03/20/2022 14:00	0.0	0	0	0	0	0
03/20/2022 15:00	0.0	0	0	0	0	0
03/20/2022 16:00	0.0	0	0	0	0	0
03/20/2022 17:00	0.0	0	0	0	0	0
03/20/2022 18:00	0.0	0	0	0	0	0
03/20/2022 19:00	0.0	0	0	0	0	0
03/20/2022 20:00	0.0	0	0	0	0	0
03/20/2022 21:00	0.0	0	0	0	0	0
03/20/2022 22:00	0.0	0	0	0	0	0
03/20/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/21/2022 00:00	0.0	0	0	0	0	0
03/21/2022 01:00	0.0	0	0	0	0	0
03/21/2022 02:00	0.0	0	0	0	0	0
03/21/2022 03:00	0.0	0	0	0	0	0
03/21/2022 04:00	0.0	0	0	0	0	0
03/21/2022 05:00	0.0	0	0	0	0	0
03/21/2022 06:00	0.0	0	0	0	0	0
03/21/2022 07:00	0.0	0	0	0	0	0
03/21/2022 08:00	0.0	0	0	0	0	0
03/21/2022 09:00	0.0	0	0	0	0	0
03/21/2022 10:00	0.0	0	0	0	0	0
03/21/2022 11:00	0.0	0	0	0	0	0
03/21/2022 12:00	0.0	0	0	0	0	0
03/21/2022 13:00	0.0	0	0	0	0	0
03/21/2022 14:00	0.0	0	0	0	0	0
03/21/2022 15:00	0.0	0	0	0	0	0
03/21/2022 16:00	0.0	0	0	0	0	0
03/21/2022 17:00	0.0	0	0	0	0	0
03/21/2022 18:00	0.0	0	0	0	0	0
03/21/2022 19:00	0.0	0	0	0	0	0
03/21/2022 20:00	0.0	0	0	0	0	0
03/21/2022 21:00	0.0	0	0	0	0	0
03/21/2022 22:00	0.0	0	0	0	0	0
03/21/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/22/2022 00:00	0.0	0	0	0	0	0
03/22/2022 01:00	0.0	0	0	0	0	0
03/22/2022 02:00	0.0	0	0	0	0	0
03/22/2022 03:00	0.0	0	0	0	0	0
03/22/2022 04:00	0.0	0	0	0	0	0
03/22/2022 05:00	0.0	0	0	0	0	0
03/22/2022 06:00	0.0	0	0	0	0	0
03/22/2022 07:00	0.0	0	0	0	0	0
03/22/2022 08:00	0.0	0	0	0	0	0
03/22/2022 09:00	0.0	0	0	0	0	0
03/22/2022 10:00	0.0	0	0	0	0	0
03/22/2022 11:00	0.0	0	0	0	0	0
03/22/2022 12:00	0.0	0	0	0	0	0
03/22/2022 13:00	0.0	0	0	0	0	0
03/22/2022 14:00	0.0	0	0	0	0	0
03/22/2022 15:00	0.0	0	0	0	0	0
03/22/2022 16:00	0.0	0	0	0	0	0
03/22/2022 17:00	0.0	0	0	0	0	0
03/22/2022 18:00	0.0	0	0	0	0	0
03/22/2022 19:00	0.0	0	0	0	0	0
03/22/2022 20:00	0.0	0	0	0	0	0
03/22/2022 21:00	0.0	0	0	0	0	0
03/22/2022 22:00	0.0	0	0	0	0	0
03/22/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/23/2022 00:00	0.0	0	0	0	0	0
03/23/2022 01:00	0.0	0	0	0	0	0
03/23/2022 02:00	0.0	0	0	0	0	0
03/23/2022 03:00	0.0	0	0	0	0	0
03/23/2022 04:00	0.0	0	0	0	0	0
03/23/2022 05:00	0.0	0	0	0	0	0
03/23/2022 06:00	0.0	0	0	0	0	0
03/23/2022 07:00	0.0	0	0	0	0	0
03/23/2022 08:00	0.0	0	0	0	0	0
03/23/2022 09:00	0.0	0	0	0	0	0
03/23/2022 10:00	0.0	0	0	0	0	0
03/23/2022 11:00	0.0	0	0	0	0	0
03/23/2022 12:00	0.0	0	0	0	0	0
03/23/2022 13:00	0.0	0	0	0	0	0
03/23/2022 14:00	0.0	0	0	0	0	0
03/23/2022 15:00	0.0	0	0	0	0	0
03/23/2022 16:00	0.0	0	0	0	0	0
03/23/2022 17:00	0.0	0	0	0	0	0
03/23/2022 18:00	0.0	0	0	0	0	0
03/23/2022 19:00	0.0	0	0	0	0	0
03/23/2022 20:00	0.0	0	0	0	0	0
03/23/2022 21:00	0.0	0	0	0	0	0
03/23/2022 22:00	0.0	0	0	0	0	0
03/23/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report
CT1 Event CO Lbs



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/24/2022 00:00	0.0	0	0	0	0	0
03/24/2022 01:00	0.0	0	0	0	0	0
03/24/2022 02:00	0.0	0	0	0	0	0
03/24/2022 03:00	0.0	0	0	0	0	0
03/24/2022 04:00	0.0	0	0	0	0	0
03/24/2022 05:00	0.0	0	0	0	0	0
03/24/2022 06:00	0.0	0	0	0	0	0
03/24/2022 07:00	0.0	0	0	0	0	0
03/24/2022 08:00	0.0	0	0	0	0	0
03/24/2022 09:00	0.0	0	0	0	0	0
03/24/2022 10:00	0.0	0	0	0	0	0
03/24/2022 11:00	0.0	0	0	0	0	0
03/24/2022 12:00	0.0	0	0	0	0	0
03/24/2022 13:00	0.0	0	0	0	0	0
03/24/2022 14:00	0.0	0	0	0	0	0
03/24/2022 15:00	0.0	0	0	0	0	0
03/24/2022 16:00	0.0	0	0	0	0	0
03/24/2022 17:00	0.0	0	0	0	0	0
03/24/2022 18:00	0.0	0	0	0	0	0
03/24/2022 19:00	0.0	0	0	0	0	0
03/24/2022 20:00	0.0	0	0	0	0	0
03/24/2022 21:00	0.0	0	0	0	0	0
03/24/2022 22:00	0.0	0	0	0	0	0
03/24/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/25/2022 00:00	0.0	0	0	0	0	0
03/25/2022 01:00	0.0	0	0	0	0	0
03/25/2022 02:00	0.0	0	0	0	0	0
03/25/2022 03:00	0.0	0	0	0	0	0
03/25/2022 04:00	0.0	0	0	0	0	0
03/25/2022 05:00	0.0	0	0	0	0	0
03/25/2022 06:00	0.0	0	0	0	0	0
03/25/2022 07:00	0.0	0	0	0	0	0
03/25/2022 08:00	0.0	0	0	0	0	0
03/25/2022 09:00	0.0	0	0	0	0	0
03/25/2022 10:00	0.0	0	0	0	0	0
03/25/2022 11:00	0.0	0	0	0	0	0
03/25/2022 12:00	0.0	0	0	0	0	0
03/25/2022 13:00	0.0	0	0	0	0	0
03/25/2022 14:00	0.0	0	0	0	0	0
03/25/2022 15:00	0.0	0	0	0	0	0
03/25/2022 16:00	0.0	0	0	0	0	0
03/25/2022 17:00	0.0	0	0	0	0	0
03/25/2022 18:00	0.0	0	0	0	0	0
03/25/2022 19:00	0.0	0	0	0	0	0
03/25/2022 20:00	0.0	0	0	0	0	0
03/25/2022 21:00	0.0	0	0	0	0	0
03/25/2022 22:00	0.0	0	0	0	0	0
03/25/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/26/2022 00:00	0.0	0	0	0	0	0
03/26/2022 01:00	0.0	0	0	0	0	0
03/26/2022 02:00	0.0	0	0	0	0	0
03/26/2022 03:00	0.0	0	0	0	0	0
03/26/2022 04:00	0.0	0	0	0	0	0
03/26/2022 05:00	0.0	0	0	0	0	0
03/26/2022 06:00	0.0	0	0	0	0	0
03/26/2022 07:00	0.0	0	0	0	0	0
03/26/2022 08:00	0.0	0	0	0	0	0
03/26/2022 09:00	0.0	0	0	0	0	0
03/26/2022 10:00	0.0	0	0	0	0	0
03/26/2022 11:00	0.0	0	0	0	0	0
03/26/2022 12:00	0.0	0	0	0	0	0
03/26/2022 13:00	0.0	0	0	0	0	0
03/26/2022 14:00	0.0	0	0	0	0	0
03/26/2022 15:00	0.0	0	0	0	0	0
03/26/2022 16:00	0.0	0	0	0	0	0
03/26/2022 17:00	0.0	0	0	0	0	0
03/26/2022 18:00	0.0	0	0	0	0	0
03/26/2022 19:00	0.0	0	0	0	0	0
03/26/2022 20:00	0.0	0	0	0	0	0
03/26/2022 21:00	0.0	0	0	0	0	0
03/26/2022 22:00	0.0	0	0	0	0	0
03/26/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report
CT1 Event CO Lbs



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/27/2022 00:00	0.0	0	0	0	0	0
03/27/2022 01:00	0.0	0	0	0	0	0
03/27/2022 02:00	0.0	0	0	0	0	0
03/27/2022 03:00	0.0	0	0	0	0	0
03/27/2022 04:00	0.0	0	0	0	0	0
03/27/2022 05:00	0.0	0	0	0	0	0
03/27/2022 06:00	0.0	0	0	0	0	0
03/27/2022 07:00	0.0	0	0	0	0	0
03/27/2022 08:00	0.0	0	0	0	0	0
03/27/2022 09:00	0.0	0	0	0	0	0
03/27/2022 10:00	0.0	0	0	0	0	0
03/27/2022 11:00	0.0	0	0	0	0	0
03/27/2022 12:00	0.0	0	0	0	0	0
03/27/2022 13:00	0.0	0	0	0	0	0
03/27/2022 14:00	0.0	0	0	0	0	0
03/27/2022 15:00	0.0	0	0	0	0	0
03/27/2022 16:00	0.0	0	0	0	0	0
03/27/2022 17:00	0.0	0	0	0	0	0
03/27/2022 18:00	0.0	0	0	0	0	0
03/27/2022 19:00	0.0	0	0	0	0	0
03/27/2022 20:00	0.0	0	0	0	0	0
03/27/2022 21:00	0.0	0	0	0	0	0
03/27/2022 22:00	0.0	0	0	0	0	0
03/27/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/28/2022 00:00	0.0	0	0	0	0	0
03/28/2022 01:00	0.0	0	0	0	0	0
03/28/2022 02:00	0.0	0	0	0	0	0
03/28/2022 03:00	0.0	0	0	0	0	0
03/28/2022 04:00	0.0	0	0	0	0	0
03/28/2022 05:00	0.0	0	0	0	0	0
03/28/2022 06:00	0.0	0	0	0	0	0
03/28/2022 07:00	0.0	0	0	0	0	0
03/28/2022 08:00	0.0	0	0	0	0	0
03/28/2022 09:00	0.0	0	0	0	0	0
03/28/2022 10:00	0.0	0	0	0	0	0
03/28/2022 11:00	0.0	0	0	0	0	0
03/28/2022 12:00	0.0	0	0	0	0	0
03/28/2022 13:00	0.0	0	0	0	0	0
03/28/2022 14:00	0.0	0	0	0	0	0
03/28/2022 15:00	0.0	0	0	0	0	0
03/28/2022 16:00	0.0	0	0	0	0	0
03/28/2022 17:00	0.0	0	0	0	0	0
03/28/2022 18:00	0.0	0	0	0	0	0
03/28/2022 19:00	0.0	0	0	0	0	0
03/28/2022 20:00	0.0	0	0	0	0	0
03/28/2022 21:00	0.0	0	0	0	0	0
03/28/2022 22:00	0.0	0	0	0	0	0
03/28/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/29/2022 00:00	0.0	0	0	0	0	0
03/29/2022 01:00	0.0	0	0	0	0	0
03/29/2022 02:00	0.0	0	0	0	0	0
03/29/2022 03:00	0.0	0	0	0	0	0
03/29/2022 04:00	0.0	0	0	0	0	0
03/29/2022 05:00	0.0	0	0	0	0	0
03/29/2022 06:00	0.0	0	0	0	0	0
03/29/2022 07:00	0.0	0	0	0	0	0
03/29/2022 08:00	0.0	0	0	0	0	0
03/29/2022 09:00	0.0	0	0	0	0	0
03/29/2022 10:00	0.0	0	0	0	0	0
03/29/2022 11:00	0.0	0	0	0	0	0
03/29/2022 12:00	0.0	0	0	0	0	0
03/29/2022 13:00	0.0	0	0	0	0	0
03/29/2022 14:00	0.0	0	0	0	0	0
03/29/2022 15:00	0.0	0	0	0	0	0
03/29/2022 16:00	0.0	0	0	0	0	0
03/29/2022 17:00	0.0	0	0	0	0	0
03/29/2022 18:00	0.0	0	0	0	0	0
03/29/2022 19:00	0.0	0	0	0	0	0
03/29/2022 20:00	0.0	0	0	0	0	0
03/29/2022 21:00	0.0	0	0	0	0	0
03/29/2022 22:00	0.0	0	0	0	0	0
03/29/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/30/2022 00:00	0.0	0	0	0	0	0
03/30/2022 01:00	0.0	0	0	0	0	0
03/30/2022 02:00	0.0	0	0	0	0	0
03/30/2022 03:00	0.0	0	0	0	0	0
03/30/2022 04:00	0.0	0	0	0	0	0
03/30/2022 05:00	0.0	0	0	0	0	0
03/30/2022 06:00	0.0	0	0	0	0	0
03/30/2022 07:00	0.0	0	0	0	0	0
03/30/2022 08:00	0.0	0	0	0	0	0
03/30/2022 09:00	0.0	0	0	0	0	0
03/30/2022 10:00	0.0	0	0	0	0	0
03/30/2022 11:00	0.0	0	0	0	0	0
03/30/2022 12:00	0.0	0	0	0	0	0
03/30/2022 13:00	0.0	0	0	0	0	0
03/30/2022 14:00	0.0	0	0	0	0	0
03/30/2022 15:00	0.0	0	0	0	0	0
03/30/2022 16:00	0.0	0	0	0	0	0
03/30/2022 17:00	0.0	0	0	0	0	0
03/30/2022 18:00	0.0	0	0	0	0	0
03/30/2022 19:00	0.0	0	0	0	0	0
03/30/2022 20:00	0.0	0	0	0	0	0
03/30/2022 21:00	0.0	0	0	0	0	0
03/30/2022 22:00	0.0	0	0	0	0	0
03/30/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwelll, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/31/2022 00:00	0.0	0	0	0	0	0
03/31/2022 01:00	0.0	0	0	0	0	0
03/31/2022 02:00	0.0	0	0	0	0	0
03/31/2022 03:00	0.0	0	0	0	0	0
03/31/2022 04:00	0.0	0	0	0	0	0
03/31/2022 05:00	0.0	0	0	0	0	0
03/31/2022 06:00	0.0	0	0	0	0	0
03/31/2022 07:00	0.0	0	0	0	0	0
03/31/2022 08:00	0.0	0	0	0	0	0
03/31/2022 09:00	0.0	0	0	0	0	0
03/31/2022 10:00	0.0	0	0	0	0	0
03/31/2022 11:00	0.0	0	0	0	0	0
03/31/2022 12:00	0.0	0	0	0	0	0
03/31/2022 13:00	0.0	0	0	0	0	0
03/31/2022 14:00	0.0	0	0	0	0	0
03/31/2022 15:00	0.0	0	0	0	0	0
03/31/2022 16:00	0.0	0	0	0	0	0
03/31/2022 17:00	0.0	0	0	0	0	0
03/31/2022 18:00	0.0	0	0	0	0	0
03/31/2022 19:00	0.0	0	0	0	0	0
03/31/2022 20:00	0.0	0	0	0	0	0
03/31/2022 21:00	0.0	0	0	0	0	0
03/31/2022 22:00	0.0	0	0	0	0	0
03/31/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/01/2022 00:00	0.0	0	0	0	0	1
01/01/2022 01:00	0.0	0	0	0	0	1
01/01/2022 02:00	0.0	0	0	0	0	1
01/01/2022 03:00	0.0	0	0	0	0	1
01/01/2022 04:00	0.0	0	0	0	0	1
01/01/2022 05:00	0.0	0	0	0	0	1
01/01/2022 06:00	0.0	0	0	0	0	1
01/01/2022 07:00	0.0	0	0	0	0	1
01/01/2022 08:00	0.0	0	0	0	0	1
01/01/2022 09:00	0.0	0	0	0	0	1
01/01/2022 10:00	0.0	0	0	0	0	1
01/01/2022 11:00	0.0	0	0	0	0	1
01/01/2022 12:00	0.0	0	0	0	0	1
01/01/2022 13:00	0.0	0	0	0	0	1
01/01/2022 14:00	0.0	0	0	0	0	1
01/01/2022 15:00	0.0	0	0	0	0	1
01/01/2022 16:00	0.0	0	0	0	0	1
01/01/2022 17:00	0.0	0	0	0	0	1
01/01/2022 18:00	0.0	0	0	0	0	1
01/01/2022 19:00	0.0	0	0	0	0	1
01/01/2022 20:00	0.0	0	0	0	0	1
01/01/2022 21:00	0.0	0	0	0	0	1
01/01/2022 22:00	0.0	0	0	0	0	1
01/01/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/02/2022 00:00	0.0	0	0	0	0	1
01/02/2022 01:00	0.0	0	0	0	0	1
01/02/2022 02:00	0.0	0	0	0	0	1
01/02/2022 03:00	0.0	0	0	0	0	1
01/02/2022 04:00	0.0	0	0	0	0	1
01/02/2022 05:00	0.0	0	0	0	0	1
01/02/2022 06:00	0.0	0	0	0	0	1
01/02/2022 07:00	0.0	0	0	0	0	1
01/02/2022 08:00	0.0	0	0	0	0	1
01/02/2022 09:00	0.0	0	0	0	0	1
01/02/2022 10:00	0.0	0	0	0	0	1
01/02/2022 11:00	0.0	0	0	0	0	1
01/02/2022 12:00	0.0	0	0	0	0	1
01/02/2022 13:00	0.0	0	0	0	0	1
01/02/2022 14:00	0.0	0	0	0	0	1
01/02/2022 15:00	0.0	0	0	0	0	1
01/02/2022 16:00	0.0	0	0	0	0	1
01/02/2022 17:00	0.0	0	0	0	0	1
01/02/2022 18:00	0.0	0	0	0	0	1
01/02/2022 19:00	0.0	0	0	0	0	1
01/02/2022 20:00	0.0	0	0	0	0	1
01/02/2022 21:00	0.0	0	0	0	0	1
01/02/2022 22:00	0.0	0	0	0	0	1
01/02/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/03/2022 00:00	0.0	0	0	0	0	1
01/03/2022 01:00	0.0	0	0	0	0	1
01/03/2022 02:00	0.0	0	0	0	0	1
01/03/2022 03:00	0.0	0	0	0	0	1
01/03/2022 04:00	0.0	0	0	0	0	1
01/03/2022 05:00	0.0	0	0	0	0	1
01/03/2022 06:00	0.0	0	0	0	0	1
01/03/2022 07:00	0.0	0	0	0	0	1
01/03/2022 08:00	0.0	0	0	0	0	1
01/03/2022 09:00	0.0	0	0	0	0	1
01/03/2022 10:00	0.0	0	0	0	0	1
01/03/2022 11:00	0.0	0	0	0	0	1
01/03/2022 12:00	0.0	0	0	0	0	1
01/03/2022 13:00	0.0	0	0	0	0	1
01/03/2022 14:00	0.0	0	0	0	0	1
01/03/2022 15:00	0.0	0	0	0	0	1
01/03/2022 16:00	0.0	0	0	0	0	1
01/03/2022 17:00	0.0	0	0	0	0	1
01/03/2022 18:00	0.0	0	0	0	0	1
01/03/2022 19:00	0.0	0	0	0	0	1
01/03/2022 20:00	0.0	0	0	0	0	1
01/03/2022 21:00	0.0	0	0	0	0	1
01/03/2022 22:00	0.0	0	0	0	0	1
01/03/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/04/2022 00:00	0.0	0	0	0	0	1
01/04/2022 01:00	0.0	0	0	0	0	1
01/04/2022 02:00	0.0	0	0	0	0	1
01/04/2022 03:00	0.0	0	0	0	0	1
01/04/2022 04:00	0.0	0	0	0	0	1
01/04/2022 05:00	0.0	0	0	0	0	1
01/04/2022 06:00	0.0	0	0	0	0	1
01/04/2022 07:00	0.0	0	0	0	0	1
01/04/2022 08:00	0.0	0	0	0	0	1
01/04/2022 09:00	0.0	0	0	0	0	1
01/04/2022 10:00	0.0	0	0	0	0	1
01/04/2022 11:00	0.0	0	0	0	0	1
01/04/2022 12:00	0.0	0	0	0	0	1
01/04/2022 13:00	0.0	0	0	0	0	1
01/04/2022 14:00	0.0	0	0	0	0	1
01/04/2022 15:00	0.0	0	0	0	0	1
01/04/2022 16:00	0.0	0	0	0	0	1
01/04/2022 17:00	0.0	0	0	0	0	1
01/04/2022 18:00	0.0	0	0	0	0	1
01/04/2022 19:00	0.0	0	0	0	0	1
01/04/2022 20:00	0.0	0	0	0	0	1
01/04/2022 21:00	0.0	0	0	0	0	1
01/04/2022 22:00	0.0	0	0	0	0	1
01/04/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/05/2022 00:00	0.0	0	0	0	0	1
01/05/2022 01:00	0.0	0	0	0	0	1
01/05/2022 02:00	0.0	0	0	0	0	1
01/05/2022 03:00	0.0	0	0	0	0	1
01/05/2022 04:00	0.0	0	0	0	0	1
01/05/2022 05:00	0.0	0	0	0	0	1
01/05/2022 06:00	0.0	0	0	0	0	1
01/05/2022 07:00	0.0	0	0	0	0	1
01/05/2022 08:00	0.0	0	0	0	0	1
01/05/2022 09:00	0.0	0	0	0	0	1
01/05/2022 10:00	0.0	0	0	0	0	1
01/05/2022 11:00	0.0	0	0	0	0	1
01/05/2022 12:00	0.0	0	0	0	0	1
01/05/2022 13:00	0.0	0	0	0	0	1
01/05/2022 14:00	0.0	0	0	0	0	1
01/05/2022 15:00	0.0	0	0	0	0	1
01/05/2022 16:00	0.0	0	0	0	0	1
01/05/2022 17:00	0.0	0	0	0	0	1
01/05/2022 18:00	0.0	0	0	0	0	1
01/05/2022 19:00	0.0	0	0	0	0	1
01/05/2022 20:00	0.0	0	0	0	0	1
01/05/2022 21:00	0.0	0	0	0	0	1
01/05/2022 22:00	0.0	0	0	0	0	1
01/05/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/06/2022 00:00	0.0	0	0	0	0	1
01/06/2022 01:00	0.0	0	0	0	0	1
01/06/2022 02:00	0.0	0	0	0	0	1
01/06/2022 03:00	0.0	0	0	0	0	1
01/06/2022 04:00	0.0	0	0	0	0	1
01/06/2022 05:00	0.0	0	0	0	0	1
01/06/2022 06:00	0.0	0	0	0	0	1
01/06/2022 07:00	0.0	0	0	0	0	1
01/06/2022 08:00	0.0	0	0	0	0	1
01/06/2022 09:00	0.0	0	0	0	0	1
01/06/2022 10:00	0.0	0	0	0	0	1
01/06/2022 11:00	0.0	0	0	0	0	1
01/06/2022 12:00	0.0	0	0	0	0	1
01/06/2022 13:00	0.0	0	0	0	0	1
01/06/2022 14:00	0.0	0	0	0	0	1
01/06/2022 15:00	0.0	0	0	0	0	1
01/06/2022 16:00	0.0	0	0	0	0	1
01/06/2022 17:00	0.0	0	0	0	0	1
01/06/2022 18:00	0.0	0	0	0	0	1
01/06/2022 19:00	0.0	0	0	0	0	1
01/06/2022 20:00	0.0	0	0	0	0	1
01/06/2022 21:00	0.0	0	0	0	0	1
01/06/2022 22:00	0.0	0	0	0	0	1
01/06/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/07/2022 00:00	0.0	0	0	0	0	1
01/07/2022 01:00	0.0	0	0	0	0	1
01/07/2022 02:00	0.0	0	0	0	0	1
01/07/2022 03:00	0.0	0	0	0	0	1
01/07/2022 04:00	0.0	0	0	0	0	1
01/07/2022 05:00	0.0	0	0	0	0	1
01/07/2022 06:00	0.0	0	0	0	0	1
01/07/2022 07:00	0.0	0	0	0	0	1
01/07/2022 08:00	0.0	0	0	0	0	1
01/07/2022 09:00	0.0	0	0	0	0	1
01/07/2022 10:00	0.0	0	0	0	0	1
01/07/2022 11:00	0.0	0	0	0	0	1
01/07/2022 12:00	0.0	0	0	0	0	1
01/07/2022 13:00	0.0	0	0	0	0	1
01/07/2022 14:00	0.0	0	0	0	0	1
01/07/2022 15:00	0.0	0	0	0	0	1
01/07/2022 16:00	0.0	0	0	0	0	1
01/07/2022 17:00	0.0	0	0	0	0	1
01/07/2022 18:00	0.0	0	0	0	0	1
01/07/2022 19:00	0.0	0	0	0	0	1
01/07/2022 20:00	0.0	0	0	0	0	1
01/07/2022 21:00	0.0	0	0	0	0	1
01/07/2022 22:00	33.5	0	0	0	1	0
01/07/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	33.5 #	0 #	0 #	0 #	1 #	22 #
Minimum:	0.0	0	0	0	0	0
Maximum:	33.5	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/08/2022 00:00	0.0	0	0	0	0	0
01/08/2022 01:00	0.0	0	0	0	0	0
01/08/2022 02:00	0.0	0	0	0	0	0
01/08/2022 03:00	0.0	0	0	0	0	0
01/08/2022 04:00	0.0	0	0	0	0	0
01/08/2022 05:00	0.0	0	0	0	0	0
01/08/2022 06:00	0.0	0	0	0	0	0
01/08/2022 07:00	0.0	0	0	0	0	0
01/08/2022 08:00	0.0	0	0	0	0	0
01/08/2022 09:00	0.0	0	0	0	0	0
01/08/2022 10:00	1,544.7	0	1	0	0	0
01/08/2022 11:00	3,731.4	0	1	0	0	0
01/08/2022 12:00	5,596.8	0	1	0	0	0
01/08/2022 13:00	0.0	0	0	0	0	1
01/08/2022 14:00	0.0	0	0	0	0	1
01/08/2022 15:00	0.0	0	0	0	0	1
01/08/2022 16:00	0.0	0	0	0	0	1
01/08/2022 17:00	0.0	0	0	0	0	1
01/08/2022 18:00	0.0	0	0	0	0	1
01/08/2022 19:00	0.0	0	0	0	0	1
01/08/2022 20:00	0.0	0	0	0	0	1
01/08/2022 21:00	0.0	0	0	0	0	1
01/08/2022 22:00	0.0	0	0	0	0	1
01/08/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	10,872.9 #	0 #	3 #	0 #	0 #	11 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,596.8	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/09/2022 00:00	0.0	0	0	0	0	1
01/09/2022 01:00	0.0	0	0	0	0	1
01/09/2022 02:00	0.0	0	0	0	0	1
01/09/2022 03:00	0.0	0	0	0	0	1
01/09/2022 04:00	0.0	0	0	0	0	1
01/09/2022 05:00	0.0	0	0	0	0	1
01/09/2022 06:00	0.0	0	0	0	0	1
01/09/2022 07:00	0.0	0	0	0	0	1
01/09/2022 08:00	0.0	0	0	0	0	1
01/09/2022 09:00	0.0	0	0	0	0	1
01/09/2022 10:00	0.0	0	0	0	0	1
01/09/2022 11:00	0.0	0	0	0	0	1
01/09/2022 12:00	0.0	0	0	0	0	1
01/09/2022 13:00	0.0	0	0	0	0	1
01/09/2022 14:00	0.0	0	0	0	0	1
01/09/2022 15:00	0.0	0	0	0	0	1
01/09/2022 16:00	0.0	0	0	0	0	1
01/09/2022 17:00	0.0	0	0	0	0	1
01/09/2022 18:00	0.0	0	0	0	0	1
01/09/2022 19:00	0.0	0	0	0	0	1
01/09/2022 20:00	0.0	0	0	0	0	1
01/09/2022 21:00	0.0	0	0	0	0	1
01/09/2022 22:00	0.0	0	0	0	0	1
01/09/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/10/2022 00:00	0.0	0	0	0	0	1
01/10/2022 01:00	0.0	0	0	0	0	1
01/10/2022 02:00	0.0	0	0	0	0	1
01/10/2022 03:00	0.0	0	0	0	0	1
01/10/2022 04:00	0.0	0	0	0	0	1
01/10/2022 05:00	0.0	0	0	0	0	1
01/10/2022 06:00	0.0	0	0	0	0	1
01/10/2022 07:00	0.0	0	0	0	0	1
01/10/2022 08:00	0.0	0	0	0	0	1
01/10/2022 09:00	0.0	0	0	0	0	1
01/10/2022 10:00	0.0	0	0	0	0	1
01/10/2022 11:00	0.0	0	0	0	0	1
01/10/2022 12:00	0.0	0	0	0	0	1
01/10/2022 13:00	0.0	0	0	0	0	1
01/10/2022 14:00	0.0	0	0	0	0	1
01/10/2022 15:00	0.0	0	0	0	0	1
01/10/2022 16:00	0.0	0	0	0	0	1
01/10/2022 17:00	0.0	0	0	0	0	1
01/10/2022 18:00	0.0	0	0	0	0	1
01/10/2022 19:00	0.0	0	0	0	0	1
01/10/2022 20:00	0.0	0	0	0	0	1
01/10/2022 21:00	0.0	0	0	0	0	1
01/10/2022 22:00	0.0	0	0	0	0	1
01/10/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/11/2022 00:00	0.0	0	0	0	0	1
01/11/2022 01:00	0.0	0	0	0	0	1
01/11/2022 02:00	0.0	0	0	0	0	1
01/11/2022 03:00	0.0	0	0	0	0	1
01/11/2022 04:00	0.0	0	0	0	0	1
01/11/2022 05:00	0.0	0	0	0	0	1
01/11/2022 06:00	0.0	0	0	0	0	1
01/11/2022 07:00	0.0	0	0	0	0	1
01/11/2022 08:00	0.0	0	0	0	0	1
01/11/2022 09:00	0.0	0	0	0	0	1
01/11/2022 10:00	0.0	0	0	0	0	1
01/11/2022 11:00	0.0	0	0	0	0	1
01/11/2022 12:00	0.0	0	0	0	0	1
01/11/2022 13:00	0.0	0	0	0	0	1
01/11/2022 14:00	0.0	0	0	0	0	1
01/11/2022 15:00	0.0	0	0	0	0	1
01/11/2022 16:00	0.0	0	0	0	0	1
01/11/2022 17:00	0.0	0	0	0	0	1
01/11/2022 18:00	0.0	0	0	0	0	1
01/11/2022 19:00	0.0	0	0	0	0	1
01/11/2022 20:00	0.0	0	0	0	0	1
01/11/2022 21:00	0.0	0	0	0	0	1
01/11/2022 22:00	0.0	0	0	0	0	1
01/11/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/12/2022 00:00	0.0	0	0	0	0	1
01/12/2022 01:00	0.0	0	0	0	0	1
01/12/2022 02:00	0.0	0	0	0	0	1
01/12/2022 03:00	0.0	0	0	0	0	1
01/12/2022 04:00	0.0	0	0	0	0	1
01/12/2022 05:00	0.0	0	0	0	0	1
01/12/2022 06:00	0.0	0	0	0	0	1
01/12/2022 07:00	0.0	0	0	0	0	1
01/12/2022 08:00	0.0	0	0	0	0	1
01/12/2022 09:00	0.0	0	0	0	0	1
01/12/2022 10:00	0.0	0	0	0	0	1
01/12/2022 11:00	0.0	0	0	0	0	1
01/12/2022 12:00	0.0	0	0	0	0	1
01/12/2022 13:00	0.0	0	0	0	0	1
01/12/2022 14:00	0.0	0	0	0	0	1
01/12/2022 15:00	0.0	0	0	0	0	1
01/12/2022 16:00	0.0	0	0	0	0	1
01/12/2022 17:00	0.0	0	0	0	0	1
01/12/2022 18:00	0.0	0	0	0	0	1
01/12/2022 19:00	0.0	0	0	0	0	1
01/12/2022 20:00	0.0	0	0	0	0	1
01/12/2022 21:00	0.0	0	0	0	0	1
01/12/2022 22:00	0.0	0	0	0	0	1
01/12/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/13/2022 00:00	0.0	0	0	0	0	1
01/13/2022 01:00	0.0	0	0	0	0	1
01/13/2022 02:00	0.0	0	0	0	0	1
01/13/2022 03:00	0.0	0	0	0	0	1
01/13/2022 04:00	0.0	0	0	0	0	1
01/13/2022 05:00	0.0	0	0	0	0	1
01/13/2022 06:00	0.0	0	0	0	0	1
01/13/2022 07:00	0.0	0	0	0	0	1
01/13/2022 08:00	0.0	0	0	0	0	1
01/13/2022 09:00	0.0	0	0	0	0	1
01/13/2022 10:00	0.0	0	0	0	0	1
01/13/2022 11:00	0.0	0	0	0	0	1
01/13/2022 12:00	0.0	0	0	0	0	1
01/13/2022 13:00	0.0	0	0	0	0	1
01/13/2022 14:00	0.0	0	0	0	0	1
01/13/2022 15:00	0.0	0	0	0	0	1
01/13/2022 16:00	0.0	0	0	0	0	1
01/13/2022 17:00	0.0	0	0	0	0	1
01/13/2022 18:00	0.0	0	0	0	0	1
01/13/2022 19:00	0.0	0	0	0	0	1
01/13/2022 20:00	0.0	0	0	0	0	1
01/13/2022 21:00	0.0	0	0	0	0	1
01/13/2022 22:00	0.0	0	0	0	0	1
01/13/2022 23:00	33.8	0	0	0	1	0
Average/Sum#:	33.8 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	33.8	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/14/2022 00:00	0.0	0	0	0	0	0
01/14/2022 01:00	0.0	0	0	0	0	0
01/14/2022 02:00	0.0	0	0	0	0	0
01/14/2022 03:00	0.0	0	0	0	0	0
01/14/2022 04:00	814.6	0	0	1	0	0
01/14/2022 05:00	6,335.5	0	0	1	0	0
01/14/2022 06:00	0.0	0	0	0	0	1
01/14/2022 07:00	0.0	0	0	0	0	1
01/14/2022 08:00	0.0	0	0	0	0	1
01/14/2022 09:00	0.0	0	0	0	0	1
01/14/2022 10:00	0.0	0	0	0	0	1
01/14/2022 11:00	0.0	0	0	0	0	1
01/14/2022 12:00	0.0	0	0	0	0	1
01/14/2022 13:00	0.0	0	0	0	0	1
01/14/2022 14:00	0.0	0	0	0	0	1
01/14/2022 15:00	0.0	0	0	0	0	1
01/14/2022 16:00	0.0	0	0	0	0	1
01/14/2022 17:00	0.0	0	0	0	0	1
01/14/2022 18:00	0.0	0	0	0	0	1
01/14/2022 19:00	0.0	0	0	0	0	1
01/14/2022 20:00	0.0	0	0	0	0	1
01/14/2022 21:00	0.0	0	0	0	0	1
01/14/2022 22:00	0.0	0	0	0	0	1
01/14/2022 23:00	46.4	0	0	0	1	0
Average/Sum#:	7,196.5 #	0 #	0 #	2 #	1 #	17 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,335.5	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/15/2022 00:00	0.0	0	0	0	0	0
01/15/2022 01:00	0.0	0	0	0	0	0
01/15/2022 02:00	0.0	0	0	0	0	0
01/15/2022 03:00	0.0	0	0	0	0	0
01/15/2022 04:00	569.3	0	0	1	0	0
01/15/2022 05:00	6,405.3	0	0	1	0	0
01/15/2022 06:00	0.0	0	0	0	0	1
01/15/2022 07:00	0.0	0	0	0	0	1
01/15/2022 08:00	0.0	0	0	0	0	1
01/15/2022 09:00	0.0	0	0	0	0	1
01/15/2022 10:00	0.0	0	0	0	0	1
01/15/2022 11:00	0.0	0	0	0	0	1
01/15/2022 12:00	0.0	0	0	0	0	1
01/15/2022 13:00	0.0	0	0	0	0	1
01/15/2022 14:00	0.0	0	0	0	0	1
01/15/2022 15:00	0.0	0	0	0	0	1
01/15/2022 16:00	0.0	0	0	0	0	1
01/15/2022 17:00	0.0	0	0	0	0	1
01/15/2022 18:00	0.0	0	0	0	0	1
01/15/2022 19:00	0.0	0	0	0	0	1
01/15/2022 20:00	0.0	0	0	0	0	1
01/15/2022 21:00	0.0	0	0	0	0	1
01/15/2022 22:00	0.0	0	0	0	0	1
01/15/2022 23:00	26.1	0	0	0	1	0
Average/Sum#:	7,000.7 #	0 #	0 #	2 #	1 #	17 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,405.3	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/16/2022 00:00	0.0	0	0	0	0	0
01/16/2022 01:00	0.0	0	0	0	0	0
01/16/2022 02:00	0.0	0	0	0	0	0
01/16/2022 03:00	0.0	0	0	0	0	0
01/16/2022 04:00	0.0	0	0	0	0	0
01/16/2022 05:00	0.0	0	0	0	0	0
01/16/2022 06:00	0.0	0	0	0	0	0
01/16/2022 07:00	0.0	0	0	0	0	0
01/16/2022 08:00	0.0	0	0	0	0	0
01/16/2022 09:00	0.0	0	0	0	0	0
01/16/2022 10:00	0.0	0	0	0	0	0
01/16/2022 11:00	3,362.3	0	1	0	0	0
01/16/2022 12:00	6,559.6	0	1	0	0	0
01/16/2022 13:00	0.0	0	0	0	0	1
01/16/2022 14:00	0.0	0	0	0	0	1
01/16/2022 15:00	0.0	0	0	0	0	1
01/16/2022 16:00	0.0	0	0	0	0	1
01/16/2022 17:00	0.0	0	0	0	0	1
01/16/2022 18:00	0.0	0	0	0	0	1
01/16/2022 19:00	0.0	0	0	0	0	1
01/16/2022 20:00	0.0	0	0	0	0	1
01/16/2022 21:00	0.0	0	0	0	0	1
01/16/2022 22:00	0.0	0	0	0	0	1
01/16/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	9,921.9 #	0 #	2 #	0 #	0 #	11 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,559.6	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/17/2022 00:00	0.0	0	0	0	0	1
01/17/2022 01:00	0.0	0	0	0	0	1
01/17/2022 02:00	0.0	0	0	0	0	1
01/17/2022 03:00	0.0	0	0	0	0	1
01/17/2022 04:00	0.0	0	0	0	0	1
01/17/2022 05:00	0.0	0	0	0	0	1
01/17/2022 06:00	0.0	0	0	0	0	1
01/17/2022 07:00	0.0	0	0	0	0	1
01/17/2022 08:00	0.0	0	0	0	0	1
01/17/2022 09:00	0.0	0	0	0	0	1
01/17/2022 10:00	0.0	0	0	0	0	1
01/17/2022 11:00	0.0	0	0	0	0	1
01/17/2022 12:00	0.0	0	0	0	0	1
01/17/2022 13:00	0.0	0	0	0	0	1
01/17/2022 14:00	0.0	0	0	0	0	1
01/17/2022 15:00	0.0	0	0	0	0	1
01/17/2022 16:00	0.0	0	0	0	0	1
01/17/2022 17:00	0.0	0	0	0	0	1
01/17/2022 18:00	0.0	0	0	0	0	1
01/17/2022 19:00	0.0	0	0	0	0	1
01/17/2022 20:00	0.0	0	0	0	0	1
01/17/2022 21:00	0.0	0	0	0	0	1
01/17/2022 22:00	0.0	0	0	0	0	1
01/17/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/18/2022 00:00	0.0	0	0	0	0	1
01/18/2022 01:00	0.0	0	0	0	0	1
01/18/2022 02:00	0.0	0	0	0	0	1
01/18/2022 03:00	0.0	0	0	0	0	1
01/18/2022 04:00	0.0	0	0	0	0	1
01/18/2022 05:00	0.0	0	0	0	0	1
01/18/2022 06:00	0.0	0	0	0	0	1
01/18/2022 07:00	0.0	0	0	0	0	1
01/18/2022 08:00	0.0	0	0	0	0	1
01/18/2022 09:00	0.0	0	0	0	0	1
01/18/2022 10:00	0.0	0	0	0	0	1
01/18/2022 11:00	0.0	0	0	0	0	1
01/18/2022 12:00	0.0	0	0	0	0	1
01/18/2022 13:00	0.0	0	0	0	0	1
01/18/2022 14:00	0.0	0	0	0	0	1
01/18/2022 15:00	0.0	0	0	0	0	1
01/18/2022 16:00	0.0	0	0	0	0	1
01/18/2022 17:00	0.0	0	0	0	0	1
01/18/2022 18:00	0.0	0	0	0	0	1
01/18/2022 19:00	0.0	0	0	0	0	1
01/18/2022 20:00	0.0	0	0	0	0	1
01/18/2022 21:00	0.0	0	0	0	0	1
01/18/2022 22:00	0.0	0	0	0	0	1
01/18/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/19/2022 00:00	0.0	0	0	0	0	1
01/19/2022 01:00	0.0	0	0	0	0	1
01/19/2022 02:00	0.0	0	0	0	0	1
01/19/2022 03:00	0.0	0	0	0	0	1
01/19/2022 04:00	0.0	0	0	0	0	1
01/19/2022 05:00	0.0	0	0	0	0	1
01/19/2022 06:00	0.0	0	0	0	0	1
01/19/2022 07:00	0.0	0	0	0	0	1
01/19/2022 08:00	0.0	0	0	0	0	1
01/19/2022 09:00	0.0	0	0	0	0	1
01/19/2022 10:00	0.0	0	0	0	0	1
01/19/2022 11:00	0.0	0	0	0	0	1
01/19/2022 12:00	0.0	0	0	0	0	1
01/19/2022 13:00	0.0	0	0	0	0	1
01/19/2022 14:00	0.0	0	0	0	0	1
01/19/2022 15:00	0.0	0	0	0	0	1
01/19/2022 16:00	0.0	0	0	0	0	1
01/19/2022 17:00	0.0	0	0	0	0	1
01/19/2022 18:00	0.0	0	0	0	0	1
01/19/2022 19:00	0.0	0	0	0	0	1
01/19/2022 20:00	0.0	0	0	0	0	1
01/19/2022 21:00	0.0	0	0	0	0	1
01/19/2022 22:00	0.0	0	0	0	0	1
01/19/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/20/2022 00:00	0.0	0	0	0	0	1
01/20/2022 01:00	0.0	0	0	0	0	1
01/20/2022 02:00	0.0	0	0	0	0	1
01/20/2022 03:00	0.0	0	0	0	0	1
01/20/2022 04:00	0.0	0	0	0	0	1
01/20/2022 05:00	0.0	0	0	0	0	1
01/20/2022 06:00	0.0	0	0	0	0	1
01/20/2022 07:00	0.0	0	0	0	0	1
01/20/2022 08:00	0.0	0	0	0	0	1
01/20/2022 09:00	0.0	0	0	0	0	1
01/20/2022 10:00	0.0	0	0	0	0	1
01/20/2022 11:00	0.0	0	0	0	0	1
01/20/2022 12:00	0.0	0	0	0	0	1
01/20/2022 13:00	0.0	0	0	0	0	1
01/20/2022 14:00	0.0	0	0	0	0	1
01/20/2022 15:00	0.0	0	0	0	0	1
01/20/2022 16:00	0.0	0	0	0	0	1
01/20/2022 17:00	0.0	0	0	0	0	1
01/20/2022 18:00	0.0	0	0	0	0	1
01/20/2022 19:00	0.0	0	0	0	0	1
01/20/2022 20:00	0.0	0	0	0	0	1
01/20/2022 21:00	0.0	0	0	0	0	1
01/20/2022 22:00	0.0	0	0	0	0	1
01/20/2022 23:00	34.5	0	0	0	1	0
Average/Sum#:	34.5 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	34.5	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/21/2022 00:00	0.0	0	0	0	0	0
01/21/2022 01:00	0.0	0	0	0	0	0
01/21/2022 02:00	0.0	0	0	0	0	0
01/21/2022 03:00	0.0	0	0	0	0	0
01/21/2022 04:00	0.0	0	0	0	0	0
01/21/2022 05:00	0.0	0	0	0	0	0
01/21/2022 06:00	0.0	0	0	0	0	0
01/21/2022 07:00	0.0	0	0	0	0	0
01/21/2022 08:00	0.0	0	0	0	0	0
01/21/2022 09:00	0.0	0	0	0	0	0
01/21/2022 10:00	0.0	0	0	0	0	0
01/21/2022 11:00	0.0	0	0	0	0	0
01/21/2022 12:00	0.0	0	0	0	0	0
01/21/2022 13:00	0.0	0	0	0	0	0
01/21/2022 14:00	0.0	0	0	0	0	0
01/21/2022 15:00	0.0	0	0	0	0	0
01/21/2022 16:00	0.0	0	0	0	0	0
01/21/2022 17:00	0.0	0	0	0	0	0
01/21/2022 18:00	0.0	0	0	0	0	0
01/21/2022 19:00	0.0	0	0	0	0	0
01/21/2022 20:00	0.0	0	0	0	0	0
01/21/2022 21:00	0.0	0	0	0	0	0
01/21/2022 22:00	0.0	0	0	0	0	0
01/21/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/22/2022 00:00	0.0	0	0	0	0	0
01/22/2022 01:00	0.0	0	0	0	0	0
01/22/2022 02:00	0.0	0	0	0	0	0
01/22/2022 03:00	0.0	0	0	0	0	0
01/22/2022 04:00	0.0	0	0	0	0	0
01/22/2022 05:00	0.0	0	0	0	0	0
01/22/2022 06:00	0.0	0	0	0	0	0
01/22/2022 07:00	0.0	0	0	0	0	0
01/22/2022 08:00	0.0	0	0	0	0	0
01/22/2022 09:00	0.0	0	0	0	0	0
01/22/2022 10:00	0.0	0	0	0	0	0
01/22/2022 11:00	0.0	0	0	0	0	0
01/22/2022 12:00	0.0	0	0	0	0	0
01/22/2022 13:00	0.0	0	0	0	0	0
01/22/2022 14:00	0.0	0	0	0	0	0
01/22/2022 15:00	0.0	0	0	0	0	0
01/22/2022 16:00	0.0	0	0	0	0	0
01/22/2022 17:00	0.0	0	0	0	0	0
01/22/2022 18:00	0.0	0	0	0	0	0
01/22/2022 19:00	0.0	0	0	0	0	0
01/22/2022 20:00	0.0	0	0	0	0	0
01/22/2022 21:00	0.0	0	0	0	0	0
01/22/2022 22:00	0.0	0	0	0	0	0
01/22/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/23/2022 00:00	0.0	0	0	0	0	0
01/23/2022 01:00	0.0	0	0	0	0	0
01/23/2022 02:00	0.0	0	0	0	0	0
01/23/2022 03:00	0.0	0	0	0	0	0
01/23/2022 04:00	0.0	0	0	0	0	0
01/23/2022 05:00	0.0	0	0	0	0	0
01/23/2022 06:00	0.0	0	0	0	0	0
01/23/2022 07:00	0.0	0	0	0	0	0
01/23/2022 08:00	0.0	0	0	0	0	0
01/23/2022 09:00	0.0	0	0	0	0	0
01/23/2022 10:00	0.0	0	0	0	0	0
01/23/2022 11:00	2,330.2	0	1	0	0	0
01/23/2022 12:00	3,685.2	0	1	0	0	0
01/23/2022 13:00	6,898.8	0	1	0	0	0
01/23/2022 14:00	0.0	0	0	0	0	1
01/23/2022 15:00	0.0	0	0	0	0	1
01/23/2022 16:00	0.0	0	0	0	0	1
01/23/2022 17:00	0.0	0	0	0	0	1
01/23/2022 18:00	0.0	0	0	0	0	1
01/23/2022 19:00	0.0	0	0	0	0	1
01/23/2022 20:00	0.0	0	0	0	0	1
01/23/2022 21:00	0.0	0	0	0	0	1
01/23/2022 22:00	0.0	0	0	0	0	1
01/23/2022 23:00	35.9	0	0	0	1	0
Average/Sum#:	12,950.1 #	0 #	3 #	0 #	1 #	9 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,898.8	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/24/2022 00:00	0.0	0	0	0	0	0
01/24/2022 01:00	0.0	0	0	0	0	0
01/24/2022 02:00	0.0	0	0	0	0	0
01/24/2022 03:00	378.7	0	0	1	0	0
01/24/2022 04:00	6,057.6	0	0	1	0	0
01/24/2022 05:00	0.0	0	0	0	0	1
01/24/2022 06:00	0.0	0	0	0	0	1
01/24/2022 07:00	0.0	0	0	0	0	1
01/24/2022 08:00	0.0	0	0	0	0	1
01/24/2022 09:00	0.0	0	0	0	0	1
01/24/2022 10:00	0.0	0	0	0	0	1
01/24/2022 11:00	0.0	0	0	0	0	1
01/24/2022 12:00	0.0	0	0	0	0	1
01/24/2022 13:00	0.0	0	0	0	0	1
01/24/2022 14:00	0.0	0	0	0	0	1
01/24/2022 15:00	0.0	0	0	0	0	1
01/24/2022 16:00	0.0	0	0	0	0	1
01/24/2022 17:00	0.0	0	0	0	0	1
01/24/2022 18:00	0.0	0	0	0	0	1
01/24/2022 19:00	0.0	0	0	0	0	1
01/24/2022 20:00	0.0	0	0	0	0	1
01/24/2022 21:00	0.0	0	0	0	0	1
01/24/2022 22:00	0.0	0	0	0	0	1
01/24/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	6,436.3 #	0 #	0 #	2 #	0 #	19 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,057.6	0	0	1	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/25/2022 00:00	0.0	0	0	0	0	1
01/25/2022 01:00	0.0	0	0	0	0	1
01/25/2022 02:00	0.0	0	0	0	0	1
01/25/2022 03:00	0.0	0	0	0	0	1
01/25/2022 04:00	0.0	0	0	0	0	1
01/25/2022 05:00	0.0	0	0	0	0	1
01/25/2022 06:00	0.0	0	0	0	0	1
01/25/2022 07:00	0.0	0	0	0	0	1
01/25/2022 08:00	19.8	0	0	0	1	0
01/25/2022 09:00	0.0	0	0	0	0	0
01/25/2022 10:00	0.0	0	0	0	0	0
01/25/2022 11:00	0.0	0	0	0	0	0
01/25/2022 12:00	0.0	0	0	0	0	0
01/25/2022 13:00	0.0	0	0	0	0	0
01/25/2022 14:00	0.0	0	0	0	0	0
01/25/2022 15:00	1,397.5	0	0	1	0	0
01/25/2022 16:00	5,065.1	0	0	1	0	0
01/25/2022 17:00	0.0	0	0	0	0	1
01/25/2022 18:00	0.0	0	0	0	0	1
01/25/2022 19:00	0.0	0	0	0	0	1
01/25/2022 20:00	0.0	0	0	0	0	1
01/25/2022 21:00	0.0	0	0	0	0	1
01/25/2022 22:00	0.0	0	0	0	0	1
01/25/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	6,482.4 #	0 #	0 #	2 #	1 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,065.1	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/26/2022 00:00	0.0	0	0	0	0	1
01/26/2022 01:00	0.0	0	0	0	0	1
01/26/2022 02:00	0.0	0	0	0	0	1
01/26/2022 03:00	0.0	0	0	0	0	1
01/26/2022 04:00	0.0	0	0	0	0	1
01/26/2022 05:00	0.0	0	0	0	0	1
01/26/2022 06:00	0.0	0	0	0	0	1
01/26/2022 07:00	0.0	0	0	0	0	1
01/26/2022 08:00	43.2	0	0	0	1	0
01/26/2022 09:00	0.0	0	0	0	0	0
01/26/2022 10:00	0.0	0	0	0	0	0
01/26/2022 11:00	0.0	0	0	0	0	0
01/26/2022 12:00	0.0	0	0	0	0	0
01/26/2022 13:00	0.0	0	0	0	0	0
01/26/2022 14:00	0.0	0	0	0	0	0
01/26/2022 15:00	1,446.5	0	0	1	0	0
01/26/2022 16:00	4,889.2	0	0	1	0	0
01/26/2022 17:00	0.0	0	0	0	0	1
01/26/2022 18:00	0.0	0	0	0	0	1
01/26/2022 19:00	0.0	0	0	0	0	1
01/26/2022 20:00	0.0	0	0	0	0	1
01/26/2022 21:00	0.0	0	0	0	0	1
01/26/2022 22:00	0.0	0	0	0	0	1
01/26/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	6,378.9 #	0 #	0 #	2 #	1 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	4,889.2	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/27/2022 00:00	0.0	0	0	0	0	1
01/27/2022 01:00	0.0	0	0	0	0	1
01/27/2022 02:00	0.0	0	0	0	0	1
01/27/2022 03:00	0.0	0	0	0	0	1
01/27/2022 04:00	0.0	0	0	0	0	1
01/27/2022 05:00	0.0	0	0	0	0	1
01/27/2022 06:00	0.0	0	0	0	0	1
01/27/2022 07:00	0.0	0	0	0	0	1
01/27/2022 08:00	0.0	0	0	0	0	1
01/27/2022 09:00	0.0	0	0	0	0	1
01/27/2022 10:00	35.3	0	0	0	1	0
01/27/2022 11:00	0.0	0	0	0	0	0
01/27/2022 12:00	0.0	0	0	0	0	0
01/27/2022 13:00	0.0	0	0	0	0	0
01/27/2022 14:00	0.0	0	0	0	0	0
01/27/2022 15:00	1,435.8	0	0	1	0	0
01/27/2022 16:00	5,097.3	0	0	1	0	0
01/27/2022 17:00	0.0	0	0	0	0	1
01/27/2022 18:00	0.0	0	0	0	0	1
01/27/2022 19:00	0.0	0	0	0	0	1
01/27/2022 20:00	0.0	0	0	0	0	1
01/27/2022 21:00	0.0	0	0	0	0	1
01/27/2022 22:00	0.0	0	0	0	0	1
01/27/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	6,568.4 #	0 #	0 #	2 #	1 #	17 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,097.3	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/28/2022 00:00	0.0	0	0	0	0	1
01/28/2022 01:00	0.0	0	0	0	0	1
01/28/2022 02:00	0.0	0	0	0	0	1
01/28/2022 03:00	0.0	0	0	0	0	1
01/28/2022 04:00	0.0	0	0	0	0	1
01/28/2022 05:00	0.0	0	0	0	0	1
01/28/2022 06:00	0.0	0	0	0	0	1
01/28/2022 07:00	0.0	0	0	0	0	1
01/28/2022 08:00	0.0	0	0	0	0	1
01/28/2022 09:00	0.0	0	0	0	0	1
01/28/2022 10:00	0.0	0	0	0	0	1
01/28/2022 11:00	0.0	0	0	0	0	1
01/28/2022 12:00	0.0	0	0	0	0	1
01/28/2022 13:00	0.0	0	0	0	0	1
01/28/2022 14:00	0.0	0	0	0	0	1
01/28/2022 15:00	0.0	0	0	0	0	1
01/28/2022 16:00	0.0	0	0	0	0	1
01/28/2022 17:00	0.0	0	0	0	0	1
01/28/2022 18:00	0.0	0	0	0	0	1
01/28/2022 19:00	0.0	0	0	0	0	1
01/28/2022 20:00	0.0	0	0	0	0	1
01/28/2022 21:00	0.0	0	0	0	0	1
01/28/2022 22:00	0.0	0	0	0	0	1
01/28/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/29/2022 00:00	0.0	0	0	0	0	1
01/29/2022 01:00	0.0	0	0	0	0	1
01/29/2022 02:00	0.0	0	0	0	0	1
01/29/2022 03:00	0.0	0	0	0	0	1
01/29/2022 04:00	0.0	0	0	0	0	1
01/29/2022 05:00	0.0	0	0	0	0	1
01/29/2022 06:00	0.0	0	0	0	0	1
01/29/2022 07:00	0.0	0	0	0	0	1
01/29/2022 08:00	0.0	0	0	0	0	1
01/29/2022 09:00	0.0	0	0	0	0	1
01/29/2022 10:00	0.0	0	0	0	0	1
01/29/2022 11:00	0.0	0	0	0	0	1
01/29/2022 12:00	0.0	0	0	0	0	1
01/29/2022 13:00	0.0	0	0	0	0	1
01/29/2022 14:00	0.0	0	0	0	0	1
01/29/2022 15:00	0.0	0	0	0	0	1
01/29/2022 16:00	0.0	0	0	0	0	1
01/29/2022 17:00	0.0	0	0	0	0	1
01/29/2022 18:00	0.0	0	0	0	0	1
01/29/2022 19:00	0.0	0	0	0	0	1
01/29/2022 20:00	0.0	0	0	0	0	1
01/29/2022 21:00	0.0	0	0	0	0	1
01/29/2022 22:00	0.0	0	0	0	0	1
01/29/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/30/2022 00:00	0.0	0	0	0	0	1
01/30/2022 01:00	0.0	0	0	0	0	1
01/30/2022 02:00	0.0	0	0	0	0	1
01/30/2022 03:00	0.0	0	0	0	0	1
01/30/2022 04:00	0.0	0	0	0	0	1
01/30/2022 05:00	0.0	0	0	0	0	1
01/30/2022 06:00	0.0	0	0	0	0	1
01/30/2022 07:00	28.8	0	0	0	1	0
01/30/2022 08:00	0.0	0	0	0	0	0
01/30/2022 09:00	0.0	0	0	0	0	0
01/30/2022 10:00	0.0	0	0	0	0	0
01/30/2022 11:00	0.0	0	0	0	0	0
01/30/2022 12:00	0.0	0	0	0	0	0
01/30/2022 13:00	0.0	0	0	0	0	0
01/30/2022 14:00	0.0	0	0	0	0	0
01/30/2022 15:00	0.0	0	0	0	0	0
01/30/2022 16:00	0.0	0	0	0	0	0
01/30/2022 17:00	0.0	0	0	0	0	0
01/30/2022 18:00	0.0	0	0	0	0	0
01/30/2022 19:00	0.0	0	0	0	0	0
01/30/2022 20:00	0.0	0	0	0	0	0
01/30/2022 21:00	0.0	0	0	0	0	0
01/30/2022 22:00	0.0	0	0	0	0	0
01/30/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	28.8 #	0 #	0 #	0 #	1 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	28.8	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/31/2022 00:00	0.0	0	0	0	0	0
01/31/2022 01:00	0.0	0	0	0	0	0
01/31/2022 02:00	2,360.0	0	1	0	0	0
01/31/2022 03:00	6,001.9	0	1	0	0	0
01/31/2022 04:00	0.0	0	0	0	0	1
01/31/2022 05:00	0.0	0	0	0	0	1
01/31/2022 06:00	0.0	0	0	0	0	1
01/31/2022 07:00	0.0	0	0	0	0	1
01/31/2022 08:00	0.0	0	0	0	0	1
01/31/2022 09:00	0.0	0	0	0	0	1
01/31/2022 10:00	0.0	0	0	0	0	1
01/31/2022 11:00	0.0	0	0	0	0	1
01/31/2022 12:00	0.0	0	0	0	0	1
01/31/2022 13:00	0.0	0	0	0	0	1
01/31/2022 14:00	0.0	0	0	0	0	1
01/31/2022 15:00	0.0	0	0	0	0	1
01/31/2022 16:00	0.0	0	0	0	0	1
01/31/2022 17:00	0.0	0	0	0	0	1
01/31/2022 18:00	0.0	0	0	0	0	1
01/31/2022 19:00	0.0	0	0	0	0	1
01/31/2022 20:00	0.0	0	0	0	0	1
01/31/2022 21:00	0.0	0	0	0	0	1
01/31/2022 22:00	0.0	0	0	0	0	1
01/31/2022 23:00	46.0	0	0	0	1	0
Average/Sum#:	8,407.9 #	0 #	2 #	0 #	1 #	19 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,001.9	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/01/2022 00:00	0.0	0	0	0	0	0
02/01/2022 01:00	0.0	0	0	0	0	0
02/01/2022 02:00	0.0	0	0	0	0	0
02/01/2022 03:00	0.0	0	0	0	0	0
02/01/2022 04:00	0.0	0	0	0	0	0
02/01/2022 05:00	3,950.7	0	0	1	0	0
02/01/2022 06:00	4,253.3	0	0	1	0	0
02/01/2022 07:00	0.0	0	0	0	0	1
02/01/2022 08:00	0.0	0	0	0	0	1
02/01/2022 09:00	0.0	0	0	0	0	1
02/01/2022 10:00	0.0	0	0	0	0	1
02/01/2022 11:00	0.0	0	0	0	0	1
02/01/2022 12:00	0.0	0	0	0	0	1
02/01/2022 13:00	0.0	0	0	0	0	1
02/01/2022 14:00	0.0	0	0	0	0	1
02/01/2022 15:00	0.0	0	0	0	0	1
02/01/2022 16:00	0.0	0	0	0	0	1
02/01/2022 17:00	0.0	0	0	0	0	1
02/01/2022 18:00	0.0	0	0	0	0	1
02/01/2022 19:00	0.0	0	0	0	0	1
02/01/2022 20:00	0.0	0	0	0	0	1
02/01/2022 21:00	0.0	0	0	0	0	1
02/01/2022 22:00	0.0	0	0	0	0	1
02/01/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	8,204.0 #	0 #	0 #	2 #	0 #	17 #
Minimum:	0.0	0	0	0	0	0
Maximum:	4,253.3	0	0	1	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/02/2022 00:00	0.0	0	0	0	0	1
02/02/2022 01:00	0.0	0	0	0	0	1
02/02/2022 02:00	0.0	0	0	0	0	1
02/02/2022 03:00	0.0	0	0	0	0	1
02/02/2022 04:00	0.0	0	0	0	0	1
02/02/2022 05:00	0.0	0	0	0	0	1
02/02/2022 06:00	0.0	0	0	0	0	1
02/02/2022 07:00	0.0	0	0	0	0	1
02/02/2022 08:00	0.0	0	0	0	0	1
02/02/2022 09:00	0.0	0	0	0	0	1
02/02/2022 10:00	50.7	0	0	0	1	0
02/02/2022 11:00	0.0	0	0	0	0	0
02/02/2022 12:00	0.0	0	0	0	0	0
02/02/2022 13:00	0.0	0	0	0	0	0
02/02/2022 14:00	0.0	0	0	0	0	0
02/02/2022 15:00	478.6	0	0	1	0	0
02/02/2022 16:00	6,798.6	0	0	1	0	0
02/02/2022 17:00	867.6	0	0	1	0	0
02/02/2022 18:00	0.0	0	0	0	0	1
02/02/2022 19:00	0.0	0	0	0	0	1
02/02/2022 20:00	0.0	0	0	0	0	1
02/02/2022 21:00	0.0	0	0	0	0	1
02/02/2022 22:00	0.0	0	0	0	0	1
02/02/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	8,195.5 #	0 #	0 #	3 #	1 #	16 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,798.6	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/03/2022 00:00	0.0	0	0	0	0	1
02/03/2022 01:00	0.0	0	0	0	0	1
02/03/2022 02:00	0.0	0	0	0	0	1
02/03/2022 03:00	0.0	0	0	0	0	1
02/03/2022 04:00	0.0	0	0	0	0	1
02/03/2022 05:00	0.0	0	0	0	0	1
02/03/2022 06:00	0.0	0	0	0	0	1
02/03/2022 07:00	0.0	0	0	0	0	1
02/03/2022 08:00	0.0	0	0	0	0	1
02/03/2022 09:00	0.0	0	0	0	0	1
02/03/2022 10:00	0.0	0	0	0	0	1
02/03/2022 11:00	0.0	0	0	0	0	1
02/03/2022 12:00	0.0	0	0	0	0	1
02/03/2022 13:00	0.0	0	0	0	0	1
02/03/2022 14:00	0.0	0	0	0	0	1
02/03/2022 15:00	0.0	0	0	0	0	1
02/03/2022 16:00	0.0	0	0	0	0	1
02/03/2022 17:00	0.0	0	0	0	0	1
02/03/2022 18:00	0.0	0	0	0	0	1
02/03/2022 19:00	0.0	0	0	0	0	1
02/03/2022 20:00	0.0	0	0	0	0	1
02/03/2022 21:00	0.0	0	0	0	0	1
02/03/2022 22:00	0.0	0	0	0	0	1
02/03/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/04/2022 00:00	0.0	0	0	0	0	1
02/04/2022 01:00	0.0	0	0	0	0	1
02/04/2022 02:00	0.0	0	0	0	0	1
02/04/2022 03:00	0.0	0	0	0	0	1
02/04/2022 04:00	0.0	0	0	0	0	1
02/04/2022 05:00	0.0	0	0	0	0	1
02/04/2022 06:00	0.0	0	0	0	0	1
02/04/2022 07:00	0.0	0	0	0	0	1
02/04/2022 08:00	32.2	0	0	0	1	0
02/04/2022 09:00	0.0	0	0	0	0	0
02/04/2022 10:00	0.0	0	0	0	0	0
02/04/2022 11:00	0.0	0	0	0	0	0
02/04/2022 12:00	0.0	0	0	0	0	0
02/04/2022 13:00	0.0	0	0	0	0	0
02/04/2022 14:00	0.0	0	0	0	0	0
02/04/2022 15:00	0.0	0	0	0	0	0
02/04/2022 16:00	5,922.5	0	0	1	0	0
02/04/2022 17:00	2,242.9	0	0	1	0	0
02/04/2022 18:00	0.0	0	0	0	0	1
02/04/2022 19:00	0.0	0	0	0	0	1
02/04/2022 20:00	0.0	0	0	0	0	1
02/04/2022 21:00	0.0	0	0	0	0	1
02/04/2022 22:00	0.0	0	0	0	0	1
02/04/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	8,197.6 #	0 #	0 #	2 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,922.5	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/05/2022 00:00	0.0	0	0	0	0	1
02/05/2022 01:00	0.0	0	0	0	0	1
02/05/2022 02:00	0.0	0	0	0	0	1
02/05/2022 03:00	0.0	0	0	0	0	1
02/05/2022 04:00	0.0	0	0	0	0	1
02/05/2022 05:00	0.0	0	0	0	0	1
02/05/2022 06:00	0.0	0	0	0	0	1
02/05/2022 07:00	0.0	0	0	0	0	1
02/05/2022 08:00	55.6	0	0	0	1	0
02/05/2022 09:00	0.0	0	0	0	0	0
02/05/2022 10:00	0.0	0	0	0	0	0
02/05/2022 11:00	0.0	0	0	0	0	0
02/05/2022 12:00	0.0	0	0	0	0	0
02/05/2022 13:00	1,086.1	0	0	1	0	0
02/05/2022 14:00	6,019.0	0	0	1	0	0
02/05/2022 15:00	0.0	0	0	0	0	1
02/05/2022 16:00	0.0	0	0	0	0	1
02/05/2022 17:00	0.0	0	0	0	0	1
02/05/2022 18:00	0.0	0	0	0	0	1
02/05/2022 19:00	0.0	0	0	0	0	1
02/05/2022 20:00	0.0	0	0	0	0	1
02/05/2022 21:00	0.0	0	0	0	0	1
02/05/2022 22:00	0.0	0	0	0	0	1
02/05/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	7,160.7 #	0 #	0 #	2 #	1 #	17 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,019.0	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/06/2022 00:00	0.0	0	0	0	0	1
02/06/2022 01:00	0.0	0	0	0	0	1
02/06/2022 02:00	0.0	0	0	0	0	1
02/06/2022 03:00	0.0	0	0	0	0	1
02/06/2022 04:00	0.0	0	0	0	0	1
02/06/2022 05:00	0.0	0	0	0	0	1
02/06/2022 06:00	0.0	0	0	0	0	1
02/06/2022 07:00	0.0	0	0	0	0	1
02/06/2022 08:00	26.4	0	0	0	1	0
02/06/2022 09:00	0.0	0	0	0	0	0
02/06/2022 10:00	0.0	0	0	0	0	0
02/06/2022 11:00	0.0	0	0	0	0	0
02/06/2022 12:00	0.0	0	0	0	0	0
02/06/2022 13:00	0.0	0	0	0	0	0
02/06/2022 14:00	1,360.6	0	0	1	0	0
02/06/2022 15:00	5,906.4	0	0	1	0	0
02/06/2022 16:00	0.0	0	0	0	0	1
02/06/2022 17:00	0.0	0	0	0	0	1
02/06/2022 18:00	0.0	0	0	0	0	1
02/06/2022 19:00	0.0	0	0	0	0	1
02/06/2022 20:00	0.0	0	0	0	0	1
02/06/2022 21:00	0.0	0	0	0	0	1
02/06/2022 22:00	0.0	0	0	0	0	1
02/06/2022 23:00	57.9	0	0	0	1	0
Average/Sum#:	7,351.3 #	0 #	0 #	2 #	2 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,906.4	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/07/2022 00:00	0.0	0	0	0	0	0
02/07/2022 01:00	0.0	0	0	0	0	0
02/07/2022 02:00	0.0	0	0	0	0	0
02/07/2022 03:00	0.0	0	0	0	0	0
02/07/2022 04:00	0.0	0	0	0	0	0
02/07/2022 05:00	0.0	0	0	0	0	0
02/07/2022 06:00	0.0	0	0	0	0	0
02/07/2022 07:00	0.0	0	0	0	0	0
02/07/2022 08:00	0.0	0	0	0	0	0
02/07/2022 09:00	0.0	0	0	0	0	0
02/07/2022 10:00	0.0	0	0	0	0	0
02/07/2022 11:00	1,962.4	0	1	0	0	0
02/07/2022 12:00	3,196.6	0	1	0	0	0
02/07/2022 13:00	5,853.5	0	1	0	0	0
02/07/2022 14:00	0.0	0	0	0	0	1
02/07/2022 15:00	0.0	0	0	0	0	1
02/07/2022 16:00	0.0	0	0	0	0	1
02/07/2022 17:00	0.0	0	0	0	0	1
02/07/2022 18:00	0.0	0	0	0	0	1
02/07/2022 19:00	0.0	0	0	0	0	1
02/07/2022 20:00	0.0	0	0	0	0	1
02/07/2022 21:00	0.0	0	0	0	0	1
02/07/2022 22:00	0.0	0	0	0	0	1
02/07/2022 23:00	42.2	0	0	0	1	0
Average/Sum#:	11,054.7 #	0 #	3 #	0 #	1 #	9 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,853.5	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/08/2022 00:00	0.0	0	0	0	0	0
02/08/2022 01:00	0.0	0	0	0	0	0
02/08/2022 02:00	0.0	0	0	0	0	0
02/08/2022 03:00	2,394.2	0	0	1	0	0
02/08/2022 04:00	3,669.9	0	0	1	0	0
02/08/2022 05:00	0.0	0	0	0	0	1
02/08/2022 06:00	0.0	0	0	0	0	1
02/08/2022 07:00	0.0	0	0	0	0	1
02/08/2022 08:00	0.0	0	0	0	0	1
02/08/2022 09:00	0.0	0	0	0	0	1
02/08/2022 10:00	0.0	0	0	0	0	1
02/08/2022 11:00	0.0	0	0	0	0	1
02/08/2022 12:00	0.0	0	0	0	0	1
02/08/2022 13:00	0.0	0	0	0	0	1
02/08/2022 14:00	0.0	0	0	0	0	1
02/08/2022 15:00	0.0	0	0	0	0	1
02/08/2022 16:00	0.0	0	0	0	0	1
02/08/2022 17:00	0.0	0	0	0	0	1
02/08/2022 18:00	0.0	0	0	0	0	1
02/08/2022 19:00	0.0	0	0	0	0	1
02/08/2022 20:00	0.0	0	0	0	0	1
02/08/2022 21:00	0.0	0	0	0	0	1
02/08/2022 22:00	0.0	0	0	0	0	1
02/08/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	6,064.1 #	0 #	0 #	2 #	0 #	19 #
Minimum:	0.0	0	0	0	0	0
Maximum:	3,669.9	0	0	1	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/09/2022 00:00	0.0	0	0	0	0	1
02/09/2022 01:00	0.0	0	0	0	0	1
02/09/2022 02:00	0.0	0	0	0	0	1
02/09/2022 03:00	0.0	0	0	0	0	1
02/09/2022 04:00	0.0	0	0	0	0	1
02/09/2022 05:00	0.0	0	0	0	0	1
02/09/2022 06:00	0.0	0	0	0	0	1
02/09/2022 07:00	0.0	0	0	0	0	1
02/09/2022 08:00	0.0	0	0	0	0	1
02/09/2022 09:00	0.0	0	0	0	0	1
02/09/2022 10:00	0.0	0	0	0	0	1
02/09/2022 11:00	0.0	0	0	0	0	1
02/09/2022 12:00	0.0	0	0	0	0	1
02/09/2022 13:00	0.0	0	0	0	0	1
02/09/2022 14:00	0.0	0	0	0	0	1
02/09/2022 15:00	0.0	0	0	0	0	1
02/09/2022 16:00	0.0	0	0	0	0	1
02/09/2022 17:00	0.0	0	0	0	0	1
02/09/2022 18:00	0.0	0	0	0	0	1
02/09/2022 19:00	0.0	0	0	0	0	1
02/09/2022 20:00	0.0	0	0	0	0	1
02/09/2022 21:00	0.0	0	0	0	0	1
02/09/2022 22:00	0.0	0	0	0	0	1
02/09/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/10/2022 00:00	0.0	0	0	0	0	1
02/10/2022 01:00	0.0	0	0	0	0	1
02/10/2022 02:00	0.0	0	0	0	0	1
02/10/2022 03:00	0.0	0	0	0	0	1
02/10/2022 04:00	0.0	0	0	0	0	1
02/10/2022 05:00	0.0	0	0	0	0	1
02/10/2022 06:00	0.0	0	0	0	0	1
02/10/2022 07:00	0.0	0	0	0	0	1
02/10/2022 08:00	60.4	0	0	0	1	0
02/10/2022 09:00	0.0	0	0	0	0	0
02/10/2022 10:00	0.0	0	0	0	0	0
02/10/2022 11:00	231.4	0	0	1	0	0
02/10/2022 12:00	6,589.9	0	0	1	0	0
02/10/2022 13:00	0.0	0	0	0	0	1
02/10/2022 14:00	0.0	0	0	0	0	1
02/10/2022 15:00	0.0	0	0	0	0	1
02/10/2022 16:00	0.0	0	0	0	0	1
02/10/2022 17:00	0.0	0	0	0	0	1
02/10/2022 18:00	0.0	0	0	0	0	1
02/10/2022 19:00	0.0	0	0	0	0	1
02/10/2022 20:00	0.0	0	0	0	0	1
02/10/2022 21:00	0.0	0	0	0	0	1
02/10/2022 22:00	0.0	0	0	0	0	1
02/10/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	6,881.7 #	0 #	0 #	2 #	1 #	19 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,589.9	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/11/2022 00:00	0.0	0	0	0	0	1
02/11/2022 01:00	57.5	0	0	0	1	0
02/11/2022 02:00	0.0	0	0	0	0	0
02/11/2022 03:00	0.0	0	0	0	0	0
02/11/2022 04:00	0.0	0	0	0	0	0
02/11/2022 05:00	0.0	0	0	0	0	0
02/11/2022 06:00	0.0	0	0	0	0	0
02/11/2022 07:00	0.0	0	0	0	0	0
02/11/2022 08:00	0.0	0	0	0	0	0
02/11/2022 09:00	0.0	0	0	0	0	0
02/11/2022 10:00	0.0	0	0	0	0	0
02/11/2022 11:00	0.0	0	0	0	0	0
02/11/2022 12:00	0.0	0	0	0	0	0
02/11/2022 13:00	0.0	0	0	0	0	0
02/11/2022 14:00	0.0	0	0	0	0	0
02/11/2022 15:00	0.0	0	0	0	0	0
02/11/2022 16:00	0.0	0	0	0	0	0
02/11/2022 17:00	0.0	0	0	0	0	0
02/11/2022 18:00	0.0	0	0	0	0	0
02/11/2022 19:00	0.0	0	0	0	0	0
02/11/2022 20:00	0.0	0	0	0	0	0
02/11/2022 21:00	0.0	0	0	0	0	0
02/11/2022 22:00	0.0	0	0	0	0	0
02/11/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	57.5 #	0 #	0 #	0 #	1 #	1 #
Minimum:	0.0	0	0	0	0	0
Maximum:	57.5	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/12/2022 00:00	0.0	0	0	0	0	0
02/12/2022 01:00	0.0	0	0	0	0	0
02/12/2022 02:00	0.0	0	0	0	0	0
02/12/2022 03:00	0.0	0	0	0	0	0
02/12/2022 04:00	0.0	0	0	0	0	0
02/12/2022 05:00	0.0	0	0	0	0	0
02/12/2022 06:00	0.0	0	0	0	0	0
02/12/2022 07:00	0.0	0	0	0	0	0
02/12/2022 08:00	0.0	0	0	0	0	0
02/12/2022 09:00	0.0	0	0	0	0	0
02/12/2022 10:00	0.0	0	0	0	0	0
02/12/2022 11:00	0.0	0	0	0	0	0
02/12/2022 12:00	0.0	0	0	0	0	0
02/12/2022 13:00	0.0	0	0	0	0	0
02/12/2022 14:00	0.0	0	0	0	0	0
02/12/2022 15:00	0.0	0	0	0	0	0
02/12/2022 16:00	0.0	0	0	0	0	0
02/12/2022 17:00	0.0	0	0	0	0	0
02/12/2022 18:00	0.0	0	0	0	0	0
02/12/2022 19:00	0.0	0	0	0	0	0
02/12/2022 20:00	0.0	0	0	0	0	0
02/12/2022 21:00	0.0	0	0	0	0	0
02/12/2022 22:00	0.0	0	0	0	0	0
02/12/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/13/2022 00:00	0.0	0	0	0	0	0
02/13/2022 01:00	0.0	0	0	0	0	0
02/13/2022 02:00	0.0	0	0	0	0	0
02/13/2022 03:00	0.0	0	0	0	0	0
02/13/2022 04:00	0.0	0	0	0	0	0
02/13/2022 05:00	0.0	0	0	0	0	0
02/13/2022 06:00	0.0	0	0	0	0	0
02/13/2022 07:00	0.0	0	0	0	0	0
02/13/2022 08:00	0.0	0	0	0	0	0
02/13/2022 09:00	0.0	0	0	0	0	0
02/13/2022 10:00	0.0	0	0	0	0	0
02/13/2022 11:00	0.0	0	0	0	0	0
02/13/2022 12:00	0.0	0	0	0	0	0
02/13/2022 13:00	0.0	0	0	0	0	0
02/13/2022 14:00	0.0	0	0	0	0	0
02/13/2022 15:00	0.0	0	0	0	0	0
02/13/2022 16:00	0.0	0	0	0	0	0
02/13/2022 17:00	0.0	0	0	0	0	0
02/13/2022 18:00	0.0	0	0	0	0	0
02/13/2022 19:00	0.0	0	0	0	0	0
02/13/2022 20:00	0.0	0	0	0	0	0
02/13/2022 21:00	0.0	0	0	0	0	0
02/13/2022 22:00	0.0	0	0	0	0	0
02/13/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/14/2022 00:00	0.0	0	0	0	0	0
02/14/2022 01:00	0.0	0	0	0	0	0
02/14/2022 02:00	0.0	0	0	0	0	0
02/14/2022 03:00	0.0	0	0	0	0	0
02/14/2022 04:00	0.0	0	0	0	0	0
02/14/2022 05:00	0.0	0	0	0	0	0
02/14/2022 06:00	0.0	0	0	0	0	0
02/14/2022 07:00	0.0	0	0	0	0	0
02/14/2022 08:00	0.0	0	0	0	0	0
02/14/2022 09:00	0.0	0	0	0	0	0
02/14/2022 10:00	0.0	0	0	0	0	0
02/14/2022 11:00	0.0	0	0	0	0	0
02/14/2022 12:00	0.0	0	0	0	0	0
02/14/2022 13:00	0.0	0	0	0	0	0
02/14/2022 14:00	0.0	0	0	0	0	0
02/14/2022 15:00	0.0	0	0	0	0	0
02/14/2022 16:00	0.0	0	0	0	0	0
02/14/2022 17:00	0.0	0	0	0	0	0
02/14/2022 18:00	0.0	0	0	0	0	0
02/14/2022 19:00	0.0	0	0	0	0	0
02/14/2022 20:00	0.0	0	0	0	0	0
02/14/2022 21:00	0.0	0	0	0	0	0
02/14/2022 22:00	0.0	0	0	0	0	0
02/14/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/15/2022 00:00	0.0	0	0	0	0	0
02/15/2022 01:00	0.0	0	0	0	0	0
02/15/2022 02:00	0.0	0	0	0	0	0
02/15/2022 03:00	0.0	0	0	0	0	0
02/15/2022 04:00	0.0	0	0	0	0	0
02/15/2022 05:00	0.0	0	0	0	0	0
02/15/2022 06:00	0.0	0	0	0	0	0
02/15/2022 07:00	0.0	0	0	0	0	0
02/15/2022 08:00	0.0	0	0	0	0	0
02/15/2022 09:00	0.0	0	0	0	0	0
02/15/2022 10:00	0.0	0	0	0	0	0
02/15/2022 11:00	0.0	0	0	0	0	0
02/15/2022 12:00	0.0	0	0	0	0	0
02/15/2022 13:00	0.0	0	0	0	0	0
02/15/2022 14:00	0.0	0	0	0	0	0
02/15/2022 15:00	0.0	0	0	0	0	0
02/15/2022 16:00	0.0	0	0	0	0	0
02/15/2022 17:00	0.0	0	0	0	0	0
02/15/2022 18:00	0.0	0	0	0	0	0
02/15/2022 19:00	0.0	0	0	0	0	0
02/15/2022 20:00	0.0	0	0	0	0	0
02/15/2022 21:00	0.0	0	0	0	0	0
02/15/2022 22:00	0.0	0	0	0	0	0
02/15/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/16/2022 00:00	0.0	0	0	0	0	0
02/16/2022 01:00	0.0	0	0	0	0	0
02/16/2022 02:00	0.0	0	0	0	0	0
02/16/2022 03:00	0.0	0	0	0	0	0
02/16/2022 04:00	0.0	0	0	0	0	0
02/16/2022 05:00	0.0	0	0	0	0	0
02/16/2022 06:00	0.0	0	0	0	0	0
02/16/2022 07:00	0.0	0	0	0	0	0
02/16/2022 08:00	0.0	0	0	0	0	0
02/16/2022 09:00	0.0	0	0	0	0	0
02/16/2022 10:00	0.0	0	0	0	0	0
02/16/2022 11:00	0.0	0	0	0	0	0
02/16/2022 12:00	0.0	0	0	0	0	0
02/16/2022 13:00	0.0	0	0	0	0	0
02/16/2022 14:00	0.0	0	0	0	0	0
02/16/2022 15:00	0.0	0	0	0	0	0
02/16/2022 16:00	0.0	0	0	0	0	0
02/16/2022 17:00	0.0	0	0	0	0	0
02/16/2022 18:00	0.0	0	0	0	0	0
02/16/2022 19:00	0.0	0	0	0	0	0
02/16/2022 20:00	0.0	0	0	0	0	0
02/16/2022 21:00	0.0	0	0	0	0	0
02/16/2022 22:00	0.0	0	0	0	0	0
02/16/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/17/2022 00:00	0.0	0	0	0	0	0
02/17/2022 01:00	0.0	0	0	0	0	0
02/17/2022 02:00	0.0	0	0	0	0	0
02/17/2022 03:00	0.0	0	0	0	0	0
02/17/2022 04:00	0.0	0	0	0	0	0
02/17/2022 05:00	0.0	0	0	0	0	0
02/17/2022 06:00	0.0	0	0	0	0	0
02/17/2022 07:00	0.0	0	0	0	0	0
02/17/2022 08:00	0.0	0	0	0	0	0
02/17/2022 09:00	0.0	0	0	0	0	0
02/17/2022 10:00	0.0	0	0	0	0	0
02/17/2022 11:00	0.0	0	0	0	0	0
02/17/2022 12:00	0.0	0	0	0	0	0
02/17/2022 13:00	0.0	0	0	0	0	0
02/17/2022 14:00	0.0	0	0	0	0	0
02/17/2022 15:00	0.0	0	0	0	0	0
02/17/2022 16:00	0.0	0	0	0	0	0
02/17/2022 17:00	0.0	0	0	0	0	0
02/17/2022 18:00	0.0	0	0	0	0	0
02/17/2022 19:00	0.0	0	0	0	0	0
02/17/2022 20:00	0.0	0	0	0	0	0
02/17/2022 21:00	0.0	0	0	0	0	0
02/17/2022 22:00	0.0	0	0	0	0	0
02/17/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/18/2022 00:00	0.0	0	0	0	0	0
02/18/2022 01:00	0.0	0	0	0	0	0
02/18/2022 02:00	0.0	0	0	0	0	0
02/18/2022 03:00	0.0	0	0	0	0	0
02/18/2022 04:00	0.0	0	0	0	0	0
02/18/2022 05:00	0.0	0	0	0	0	0
02/18/2022 06:00	0.0	0	0	0	0	0
02/18/2022 07:00	0.0	0	0	0	0	0
02/18/2022 08:00	185.4	1	0	0	0	0
02/18/2022 09:00	3,611.7	1	0	0	0	0
02/18/2022 10:00	3,741.7	1	0	0	0	0
02/18/2022 11:00	6,508.4	1	0	0	0	0
02/18/2022 12:00	6,024.6	1	0	0	0	0
02/18/2022 13:00	0.0	0	0	0	0	1
02/18/2022 14:00	0.0	0	0	0	0	1
02/18/2022 15:00	0.0	0	0	0	0	1
02/18/2022 16:00	0.0	0	0	0	0	1
02/18/2022 17:00	0.0	0	0	0	0	1
02/18/2022 18:00	0.0	0	0	0	0	1
02/18/2022 19:00	0.0	0	0	0	0	1
02/18/2022 20:00	0.0	0	0	0	0	1
02/18/2022 21:00	0.0	0	0	0	0	1
02/18/2022 22:00	0.0	0	0	0	0	1
02/18/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	20,071.8 #	5 #	0 #	0 #	0 #	11 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,508.4	1	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/19/2022 00:00	14.7	0	0	0	1	0
02/19/2022 01:00	0.0	0	0	0	0	0
02/19/2022 02:00	0.0	0	0	0	0	0
02/19/2022 03:00	0.0	0	0	0	0	0
02/19/2022 04:00	0.0	0	0	0	0	0
02/19/2022 05:00	0.0	0	0	0	0	0
02/19/2022 06:00	0.0	0	0	0	0	0
02/19/2022 07:00	0.0	0	0	0	0	0
02/19/2022 08:00	0.0	0	0	0	0	0
02/19/2022 09:00	0.0	0	0	0	0	0
02/19/2022 10:00	0.0	0	0	0	0	0
02/19/2022 11:00	0.0	0	0	0	0	0
02/19/2022 12:00	0.0	0	0	0	0	0
02/19/2022 13:00	0.0	0	0	0	0	0
02/19/2022 14:00	0.0	0	0	0	0	0
02/19/2022 15:00	0.0	0	0	0	0	0
02/19/2022 16:00	0.0	0	0	0	0	0
02/19/2022 17:00	0.0	0	0	0	0	0
02/19/2022 18:00	0.0	0	0	0	0	0
02/19/2022 19:00	0.0	0	0	0	0	0
02/19/2022 20:00	0.0	0	0	0	0	0
02/19/2022 21:00	0.0	0	0	0	0	0
02/19/2022 22:00	0.0	0	0	0	0	0
02/19/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	14.7 #	0 #	0 #	0 #	1 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	14.7	0	0	0	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/20/2022 00:00	0.0	0	0	0	0	0
02/20/2022 01:00	0.0	0	0	0	0	0
02/20/2022 02:00	0.0	0	0	0	0	0
02/20/2022 03:00	0.0	0	0	0	0	0
02/20/2022 04:00	0.0	0	0	0	0	0
02/20/2022 05:00	0.0	0	0	0	0	0
02/20/2022 06:00	0.0	0	0	0	0	0
02/20/2022 07:00	0.0	0	0	0	0	0
02/20/2022 08:00	0.0	0	0	0	0	0
02/20/2022 09:00	0.0	0	0	0	0	0
02/20/2022 10:00	0.0	0	0	0	0	0
02/20/2022 11:00	0.0	0	0	0	0	0
02/20/2022 12:00	0.0	0	0	0	0	0
02/20/2022 13:00	0.0	0	0	0	0	0
02/20/2022 14:00	0.0	0	0	0	0	0
02/20/2022 15:00	0.0	0	0	0	0	0
02/20/2022 16:00	0.0	0	0	0	0	0
02/20/2022 17:00	0.0	0	0	0	0	0
02/20/2022 18:00	0.0	0	0	0	0	0
02/20/2022 19:00	0.0	0	0	0	0	0
02/20/2022 20:00	0.0	0	0	0	0	0
02/20/2022 21:00	0.0	0	0	0	0	0
02/20/2022 22:00	0.0	0	0	0	0	0
02/20/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/21/2022 00:00	0.0	0	0	0	0	0
02/21/2022 01:00	0.0	0	0	0	0	0
02/21/2022 02:00	0.0	0	0	0	0	0
02/21/2022 03:00	0.0	0	0	0	0	0
02/21/2022 04:00	0.0	0	0	0	0	0
02/21/2022 05:00	0.0	0	0	0	0	0
02/21/2022 06:00	0.0	0	0	0	0	0
02/21/2022 07:00	0.0	0	0	0	0	0
02/21/2022 08:00	0.0	0	0	0	0	0
02/21/2022 09:00	0.0	0	0	0	0	0
02/21/2022 10:00	0.0	0	0	0	0	0
02/21/2022 11:00	0.0	0	0	0	0	0
02/21/2022 12:00	0.0	0	0	0	0	0
02/21/2022 13:00	0.0	0	0	0	0	0
02/21/2022 14:00	0.0	0	0	0	0	0
02/21/2022 15:00	0.0	0	0	0	0	0
02/21/2022 16:00	0.0	0	0	0	0	0
02/21/2022 17:00	0.0	0	0	0	0	0
02/21/2022 18:00	0.0	0	0	0	0	0
02/21/2022 19:00	0.0	0	0	0	0	0
02/21/2022 20:00	0.0	0	0	0	0	0
02/21/2022 21:00	0.0	0	0	0	0	0
02/21/2022 22:00	0.0	0	0	0	0	0
02/21/2022 23:00	2,162.0	0	1	0	0	0
Average/Sum#:	2,162.0 #	0 #	1 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	2,162.0	0	1	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/22/2022 00:00	3,627.9	0	1	0	0	0
02/22/2022 01:00	6,468.1	0	1	0	0	0
02/22/2022 02:00	0.0	0	0	0	0	1
02/22/2022 03:00	0.0	0	0	0	0	1
02/22/2022 04:00	0.0	0	0	0	0	1
02/22/2022 05:00	0.0	0	0	0	0	1
02/22/2022 06:00	0.0	0	0	0	0	1
02/22/2022 07:00	0.0	0	0	0	0	1
02/22/2022 08:00	0.0	0	0	0	0	1
02/22/2022 09:00	0.0	0	0	0	0	1
02/22/2022 10:00	0.0	0	0	0	0	1
02/22/2022 11:00	0.0	0	0	0	0	1
02/22/2022 12:00	0.0	0	0	0	0	1
02/22/2022 13:00	0.0	0	0	0	0	1
02/22/2022 14:00	0.0	0	0	0	0	1
02/22/2022 15:00	0.0	0	0	0	0	1
02/22/2022 16:00	0.0	0	0	0	0	1
02/22/2022 17:00	0.0	0	0	0	0	1
02/22/2022 18:00	0.0	0	0	0	0	1
02/22/2022 19:00	0.0	0	0	0	0	1
02/22/2022 20:00	0.0	0	0	0	0	1
02/22/2022 21:00	0.0	0	0	0	0	1
02/22/2022 22:00	0.0	0	0	0	0	1
02/22/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	10,096.0 #	0 #	2 #	0 #	0 #	22 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,468.1	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/23/2022 00:00	0.0	0	0	0	0	1
02/23/2022 01:00	0.0	0	0	0	0	1
02/23/2022 02:00	0.0	0	0	0	0	1
02/23/2022 03:00	0.0	0	0	0	0	1
02/23/2022 04:00	0.0	0	0	0	0	1
02/23/2022 05:00	0.0	0	0	0	0	1
02/23/2022 06:00	0.0	0	0	0	0	1
02/23/2022 07:00	0.0	0	0	0	0	1
02/23/2022 08:00	0.0	0	0	0	0	1
02/23/2022 09:00	0.0	0	0	0	0	1
02/23/2022 10:00	0.0	0	0	0	0	1
02/23/2022 11:00	0.0	0	0	0	0	1
02/23/2022 12:00	0.0	0	0	0	0	1
02/23/2022 13:00	0.0	0	0	0	0	1
02/23/2022 14:00	0.0	0	0	0	0	1
02/23/2022 15:00	0.0	0	0	0	0	1
02/23/2022 16:00	0.0	0	0	0	0	1
02/23/2022 17:00	0.0	0	0	0	0	1
02/23/2022 18:00	0.0	0	0	0	0	1
02/23/2022 19:00	0.0	0	0	0	0	1
02/23/2022 20:00	0.0	0	0	0	0	1
02/23/2022 21:00	0.0	0	0	0	0	1
02/23/2022 22:00	0.0	0	0	0	0	1
02/23/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/24/2022 00:00	0.0	0	0	0	0	1
02/24/2022 01:00	0.0	0	0	0	0	1
02/24/2022 02:00	0.0	0	0	0	0	1
02/24/2022 03:00	0.0	0	0	0	0	1
02/24/2022 04:00	0.0	0	0	0	0	1
02/24/2022 05:00	0.0	0	0	0	0	1
02/24/2022 06:00	0.0	0	0	0	0	1
02/24/2022 07:00	0.0	0	0	0	0	1
02/24/2022 08:00	0.0	0	0	0	0	1
02/24/2022 09:00	0.0	0	0	0	0	1
02/24/2022 10:00	0.0	0	0	0	0	1
02/24/2022 11:00	0.0	0	0	0	0	1
02/24/2022 12:00	0.0	0	0	0	0	1
02/24/2022 13:00	0.0	0	0	0	0	1
02/24/2022 14:00	0.0	0	0	0	0	1
02/24/2022 15:00	0.0	0	0	0	0	1
02/24/2022 16:00	0.0	0	0	0	0	1
02/24/2022 17:00	0.0	0	0	0	0	1
02/24/2022 18:00	0.0	0	0	0	0	1
02/24/2022 19:00	0.0	0	0	0	0	1
02/24/2022 20:00	0.0	0	0	0	0	1
02/24/2022 21:00	0.0	0	0	0	0	1
02/24/2022 22:00	0.0	0	0	0	0	1
02/24/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/25/2022 00:00	0.0	0	0	0	0	1
02/25/2022 01:00	0.0	0	0	0	0	1
02/25/2022 02:00	0.0	0	0	0	0	1
02/25/2022 03:00	0.0	0	0	0	0	1
02/25/2022 04:00	0.0	0	0	0	0	1
02/25/2022 05:00	0.0	0	0	0	0	1
02/25/2022 06:00	0.0	0	0	0	0	1
02/25/2022 07:00	0.0	0	0	0	0	1
02/25/2022 08:00	0.0	0	0	0	0	1
02/25/2022 09:00	0.0	0	0	0	0	1
02/25/2022 10:00	0.0	0	0	0	0	1
02/25/2022 11:00	0.0	0	0	0	0	1
02/25/2022 12:00	0.0	0	0	0	0	1
02/25/2022 13:00	0.0	0	0	0	0	1
02/25/2022 14:00	0.0	0	0	0	0	1
02/25/2022 15:00	0.0	0	0	0	0	1
02/25/2022 16:00	0.0	0	0	0	0	1
02/25/2022 17:00	0.0	0	0	0	0	1
02/25/2022 18:00	0.0	0	0	0	0	1
02/25/2022 19:00	0.0	0	0	0	0	1
02/25/2022 20:00	0.0	0	0	0	0	1
02/25/2022 21:00	0.0	0	0	0	0	1
02/25/2022 22:00	0.0	0	0	0	0	1
02/25/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/26/2022 00:00	0.0	0	0	0	0	1
02/26/2022 01:00	0.0	0	0	0	0	1
02/26/2022 02:00	0.0	0	0	0	0	1
02/26/2022 03:00	0.0	0	0	0	0	1
02/26/2022 04:00	0.0	0	0	0	0	1
02/26/2022 05:00	0.0	0	0	0	0	1
02/26/2022 06:00	0.0	0	0	0	0	1
02/26/2022 07:00	46.8	0	0	0	1	0
02/26/2022 08:00	0.0	0	0	0	0	0
02/26/2022 09:00	0.0	0	0	0	0	0
02/26/2022 10:00	0.0	0	0	0	0	0
02/26/2022 11:00	0.0	0	0	0	0	0
02/26/2022 12:00	0.0	0	0	0	0	0
02/26/2022 13:00	0.0	0	0	0	0	0
02/26/2022 14:00	0.0	0	0	0	0	0
02/26/2022 15:00	1,106.4	0	1	0	0	0
02/26/2022 16:00	5,984.2	0	1	0	0	0
02/26/2022 17:00	0.0	0	0	0	0	1
02/26/2022 18:00	0.0	0	0	0	0	1
02/26/2022 19:00	0.0	0	0	0	0	1
02/26/2022 20:00	0.0	0	0	0	0	1
02/26/2022 21:00	0.0	0	0	0	0	1
02/26/2022 22:00	0.0	0	0	0	0	1
02/26/2022 23:00	30.2	0	0	0	1	0
Average/Sum#:	7,167.6 #	0 #	2 #	0 #	2 #	13 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,984.2	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/27/2022 00:00	0.0	0	0	0	0	0
02/27/2022 01:00	0.0	0	0	0	0	0
02/27/2022 02:00	0.0	0	0	0	0	0
02/27/2022 03:00	0.0	0	0	0	0	0
02/27/2022 04:00	0.0	0	0	0	0	0
02/27/2022 05:00	0.0	0	0	0	0	0
02/27/2022 06:00	0.0	0	0	0	0	0
02/27/2022 07:00	0.0	0	0	0	0	0
02/27/2022 08:00	0.0	0	0	0	0	0
02/27/2022 09:00	0.0	0	0	0	0	0
02/27/2022 10:00	0.0	0	0	0	0	0
02/27/2022 11:00	0.0	0	0	0	0	0
02/27/2022 12:00	0.0	0	0	0	0	0
02/27/2022 13:00	0.0	0	0	0	0	0
02/27/2022 14:00	0.0	0	0	0	0	0
02/27/2022 15:00	0.0	0	0	0	0	0
02/27/2022 16:00	0.0	0	0	0	0	0
02/27/2022 17:00	0.0	0	0	0	0	0
02/27/2022 18:00	0.0	0	0	0	0	0
02/27/2022 19:00	0.0	0	0	0	0	0
02/27/2022 20:00	0.0	0	0	0	0	0
02/27/2022 21:00	0.0	0	0	0	0	0
02/27/2022 22:00	0.0	0	0	0	0	0
02/27/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/28/2022 00:00	0.0	0	0	0	0	0
02/28/2022 01:00	0.0	0	0	0	0	0
02/28/2022 02:00	0.0	0	0	0	0	0
02/28/2022 03:00	0.0	0	0	0	0	0
02/28/2022 04:00	0.0	0	0	0	0	0
02/28/2022 05:00	0.0	0	0	0	0	0
02/28/2022 06:00	0.0	0	0	0	0	0
02/28/2022 07:00	0.0	0	0	0	0	0
02/28/2022 08:00	0.0	0	0	0	0	0
02/28/2022 09:00	0.0	0	0	0	0	0
02/28/2022 10:00	0.0	0	0	0	0	0
02/28/2022 11:00	0.0	0	0	0	0	0
02/28/2022 12:00	0.0	0	0	0	0	0
02/28/2022 13:00	2,477.5	0	1	0	0	0
02/28/2022 14:00	3,738.3	0	1	0	0	0
02/28/2022 15:00	5,652.1	0	1	0	0	0
02/28/2022 16:00	0.0	0	0	0	0	1
02/28/2022 17:00	0.0	0	0	0	0	1
02/28/2022 18:00	0.0	0	0	0	0	1
02/28/2022 19:00	0.0	0	0	0	0	1
02/28/2022 20:00	0.0	0	0	0	0	1
02/28/2022 21:00	0.0	0	0	0	0	1
02/28/2022 22:00	51.2	0	0	0	1	0
02/28/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	11,919.1 #	0 #	3 #	0 #	1 #	6 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,652.1	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/01/2022 00:00	0.0	0	0	0	0	0
03/01/2022 01:00	0.0	0	0	0	0	0
03/01/2022 02:00	0.0	0	0	0	0	0
03/01/2022 03:00	0.0	0	0	0	0	0
03/01/2022 04:00	0.0	0	0	0	0	0
03/01/2022 05:00	0.0	0	0	0	0	0
03/01/2022 06:00	0.0	0	0	0	0	0
03/01/2022 07:00	0.0	0	0	0	0	0
03/01/2022 08:00	0.0	0	0	0	0	0
03/01/2022 09:00	0.0	0	0	0	0	0
03/01/2022 10:00	0.0	0	0	0	0	0
03/01/2022 11:00	0.0	0	0	0	0	0
03/01/2022 12:00	0.0	0	0	0	0	0
03/01/2022 13:00	0.0	0	0	0	0	0
03/01/2022 14:00	0.0	0	0	0	0	0
03/01/2022 15:00	0.0	0	0	0	0	0
03/01/2022 16:00	0.0	0	0	0	0	0
03/01/2022 17:00	0.0	0	0	0	0	0
03/01/2022 18:00	0.0	0	0	0	0	0
03/01/2022 19:00	0.0	0	0	0	0	0
03/01/2022 20:00	0.0	0	0	0	0	0
03/01/2022 21:00	0.0	0	0	0	0	0
03/01/2022 22:00	0.0	0	0	0	0	0
03/01/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/02/2022 00:00	0.0	0	0	0	0	0
03/02/2022 01:00	0.0	0	0	0	0	0
03/02/2022 02:00	0.0	0	0	0	0	0
03/02/2022 03:00	0.0	0	0	0	0	0
03/02/2022 04:00	0.0	0	0	0	0	0
03/02/2022 05:00	0.0	0	0	0	0	0
03/02/2022 06:00	0.0	0	0	0	0	0
03/02/2022 07:00	0.0	0	0	0	0	0
03/02/2022 08:00	0.0	0	0	0	0	0
03/02/2022 09:00	0.0	0	0	0	0	0
03/02/2022 10:00	0.0	0	0	0	0	0
03/02/2022 11:00	0.0	0	0	0	0	0
03/02/2022 12:00	0.0	0	0	0	0	0
03/02/2022 13:00	0.0	0	0	0	0	0
03/02/2022 14:00	0.0	0	0	0	0	0
03/02/2022 15:00	0.0	0	0	0	0	0
03/02/2022 16:00	0.0	0	0	0	0	0
03/02/2022 17:00	0.0	0	0	0	0	0
03/02/2022 18:00	0.0	0	0	0	0	0
03/02/2022 19:00	0.0	0	0	0	0	0
03/02/2022 20:00	0.0	0	0	0	0	0
03/02/2022 21:00	0.0	0	0	0	0	0
03/02/2022 22:00	0.0	0	0	0	0	0
03/02/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/03/2022 00:00	0.0	0	0	0	0	0
03/03/2022 01:00	0.0	0	0	0	0	0
03/03/2022 02:00	0.0	0	0	0	0	0
03/03/2022 03:00	0.0	0	0	0	0	0
03/03/2022 04:00	0.0	0	0	0	0	0
03/03/2022 05:00	0.0	0	0	0	0	0
03/03/2022 06:00	0.0	0	0	0	0	0
03/03/2022 07:00	0.0	0	0	0	0	0
03/03/2022 08:00	0.0	0	0	0	0	0
03/03/2022 09:00	0.0	0	0	0	0	0
03/03/2022 10:00	0.0	0	0	0	0	0
03/03/2022 11:00	0.0	0	0	0	0	0
03/03/2022 12:00	0.0	0	0	0	0	0
03/03/2022 13:00	0.0	0	0	0	0	0
03/03/2022 14:00	0.0	0	0	0	0	0
03/03/2022 15:00	0.0	0	0	0	0	0
03/03/2022 16:00	0.0	0	0	0	0	0
03/03/2022 17:00	0.0	0	0	0	0	0
03/03/2022 18:00	0.0	0	0	0	0	0
03/03/2022 19:00	0.0	0	0	0	0	0
03/03/2022 20:00	0.0	0	0	0	0	0
03/03/2022 21:00	0.0	0	0	0	0	0
03/03/2022 22:00	0.0	0	0	0	0	0
03/03/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/04/2022 00:00	0.0	0	0	0	0	0
03/04/2022 01:00	0.0	0	0	0	0	0
03/04/2022 02:00	0.0	0	0	0	0	0
03/04/2022 03:00	0.0	0	0	0	0	0
03/04/2022 04:00	0.0	0	0	0	0	0
03/04/2022 05:00	0.0	0	0	0	0	0
03/04/2022 06:00	0.0	0	0	0	0	0
03/04/2022 07:00	0.0	0	0	0	0	0
03/04/2022 08:00	0.0	0	0	0	0	0
03/04/2022 09:00	0.0	0	0	0	0	0
03/04/2022 10:00	0.0	0	0	0	0	0
03/04/2022 11:00	0.0	0	0	0	0	0
03/04/2022 12:00	0.0	0	0	0	0	0
03/04/2022 13:00	0.0	0	0	0	0	0
03/04/2022 14:00	0.0	0	0	0	0	0
03/04/2022 15:00	0.0	0	0	0	0	0
03/04/2022 16:00	0.0	0	0	0	0	0
03/04/2022 17:00	0.0	0	0	0	0	0
03/04/2022 18:00	0.0	0	0	0	0	0
03/04/2022 19:00	0.0	0	0	0	0	0
03/04/2022 20:00	0.0	0	0	0	0	0
03/04/2022 21:00	0.0	0	0	0	0	0
03/04/2022 22:00	0.0	0	0	0	0	0
03/04/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 Location: Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/05/2022 00:00	0.0	0	0	0	0	0
03/05/2022 01:00	0.0	0	0	0	0	0
03/05/2022 02:00	0.0	0	0	0	0	0
03/05/2022 03:00	0.0	0	0	0	0	0
03/05/2022 04:00	0.0	0	0	0	0	0
03/05/2022 05:00	0.0	0	0	0	0	0
03/05/2022 06:00	0.0	0	0	0	0	0
03/05/2022 07:00	0.0	0	0	0	0	0
03/05/2022 08:00	0.0	0	0	0	0	0
03/05/2022 09:00	0.0	0	0	0	0	0
03/05/2022 10:00	0.0	0	0	0	0	0
03/05/2022 11:00	0.0	0	0	0	0	0
03/05/2022 12:00	0.0	0	0	0	0	0
03/05/2022 13:00	0.0	0	0	0	0	0
03/05/2022 14:00	0.0	0	0	0	0	0
03/05/2022 15:00	0.0	0	0	0	0	0
03/05/2022 16:00	0.0	0	0	0	0	0
03/05/2022 17:00	0.0	0	0	0	0	0
03/05/2022 18:00	0.0	0	0	0	0	0
03/05/2022 19:00	0.0	0	0	0	0	0
03/05/2022 20:00	0.0	0	0	0	0	0
03/05/2022 21:00	0.0	0	0	0	0	0
03/05/2022 22:00	0.0	0	0	0	0	0
03/05/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/06/2022 00:00	0.0	0	0	0	0	0
03/06/2022 01:00	0.0	0	0	0	0	0
03/06/2022 02:00	0.0	0	0	0	0	0
03/06/2022 03:00	0.0	0	0	0	0	0
03/06/2022 04:00	0.0	0	0	0	0	0
03/06/2022 05:00	0.0	0	0	0	0	0
03/06/2022 06:00	0.0	0	0	0	0	0
03/06/2022 07:00	0.0	0	0	0	0	0
03/06/2022 08:00	0.0	0	0	0	0	0
03/06/2022 09:00	0.0	0	0	0	0	0
03/06/2022 10:00	0.0	0	0	0	0	0
03/06/2022 11:00	0.0	0	0	0	0	0
03/06/2022 12:00	0.0	0	0	0	0	0
03/06/2022 13:00	0.0	0	0	0	0	0
03/06/2022 14:00	0.0	0	0	0	0	0
03/06/2022 15:00	0.0	0	0	0	0	0
03/06/2022 16:00	0.0	0	0	0	0	0
03/06/2022 17:00	0.0	0	0	0	0	0
03/06/2022 18:00	0.0	0	0	0	0	0
03/06/2022 19:00	0.0	0	0	0	0	0
03/06/2022 20:00	0.0	0	0	0	0	0
03/06/2022 21:00	0.0	0	0	0	0	0
03/06/2022 22:00	0.0	0	0	0	0	0
03/06/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/07/2022 00:00	0.0	0	0	0	0	0
03/07/2022 01:00	0.0	0	0	0	0	0
03/07/2022 02:00	0.0	0	0	0	0	0
03/07/2022 03:00	0.0	0	0	0	0	0
03/07/2022 04:00	0.0	0	0	0	0	0
03/07/2022 05:00	0.0	0	0	0	0	0
03/07/2022 06:00	0.0	0	0	0	0	0
03/07/2022 07:00	0.0	0	0	0	0	0
03/07/2022 08:00	0.0	0	0	0	0	0
03/07/2022 09:00	0.0	0	0	0	0	0
03/07/2022 10:00	0.0	0	0	0	0	0
03/07/2022 11:00	0.0	0	0	0	0	0
03/07/2022 12:00	0.0	0	0	0	0	0
03/07/2022 13:00	0.0	0	0	0	0	0
03/07/2022 14:00	0.0	0	0	0	0	0
03/07/2022 15:00	0.0	0	0	0	0	0
03/07/2022 16:00	0.0	0	0	0	0	0
03/07/2022 17:00	0.0	0	0	0	0	0
03/07/2022 18:00	0.0	0	0	0	0	0
03/07/2022 19:00	0.0	0	0	0	0	0
03/07/2022 20:00	0.0	0	0	0	0	0
03/07/2022 21:00	0.0	0	0	0	0	0
03/07/2022 22:00	0.0	0	0	0	0	0
03/07/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/08/2022 00:00	0.0	0	0	0	0	0
03/08/2022 01:00	0.0	0	0	0	0	0
03/08/2022 02:00	0.0	0	0	0	0	0
03/08/2022 03:00	0.0	0	0	0	0	0
03/08/2022 04:00	0.0	0	0	0	0	0
03/08/2022 05:00	0.0	0	0	0	0	0
03/08/2022 06:00	0.0	0	0	0	0	0
03/08/2022 07:00	0.0	0	0	0	0	0
03/08/2022 08:00	0.0	0	0	0	0	0
03/08/2022 09:00	0.0	0	0	0	0	0
03/08/2022 10:00	0.0	0	0	0	0	0
03/08/2022 11:00	0.0	0	0	0	0	0
03/08/2022 12:00	0.0	0	0	0	0	0
03/08/2022 13:00	0.0	0	0	0	0	0
03/08/2022 14:00	0.0	0	0	0	0	0
03/08/2022 15:00	0.0	0	0	0	0	0
03/08/2022 16:00	0.0	0	0	0	0	0
03/08/2022 17:00	0.0	0	0	0	0	0
03/08/2022 18:00	0.0	0	0	0	0	0
03/08/2022 19:00	0.0	0	0	0	0	0
03/08/2022 20:00	0.0	0	0	0	0	0
03/08/2022 21:00	0.0	0	0	0	0	0
03/08/2022 22:00	0.0	0	0	0	0	0
03/08/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/09/2022 00:00	0.0	0	0	0	0	0
03/09/2022 01:00	0.0	0	0	0	0	0
03/09/2022 02:00	0.0	0	0	0	0	0
03/09/2022 03:00	0.0	0	0	0	0	0
03/09/2022 04:00	0.0	0	0	0	0	0
03/09/2022 05:00	0.0	0	0	0	0	0
03/09/2022 06:00	0.0	0	0	0	0	0
03/09/2022 07:00	0.0	0	0	0	0	0
03/09/2022 08:00	0.0	0	0	0	0	0
03/09/2022 09:00	0.0	0	0	0	0	0
03/09/2022 10:00	0.0	0	0	0	0	0
03/09/2022 11:00	0.0	0	0	0	0	0
03/09/2022 12:00	0.0	0	0	0	0	0
03/09/2022 13:00	0.0	0	0	0	0	0
03/09/2022 14:00	0.0	0	0	0	0	0
03/09/2022 15:00	0.0	0	0	0	0	0
03/09/2022 16:00	0.0	0	0	0	0	0
03/09/2022 17:00	0.0	0	0	0	0	0
03/09/2022 18:00	0.0	0	0	0	0	0
03/09/2022 19:00	0.0	0	0	0	0	0
03/09/2022 20:00	0.0	0	0	0	0	0
03/09/2022 21:00	0.0	0	0	0	0	0
03/09/2022 22:00	0.0	0	0	0	0	0
03/09/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/10/2022 00:00	0.0	0	0	0	0	0
03/10/2022 01:00	0.0	0	0	0	0	0
03/10/2022 02:00	0.0	0	0	0	0	0
03/10/2022 03:00	0.0	0	0	0	0	0
03/10/2022 04:00	0.0	0	0	0	0	0
03/10/2022 05:00	0.0	0	0	0	0	0
03/10/2022 06:00	0.0	0	0	0	0	0
03/10/2022 07:00	0.0	0	0	0	0	0
03/10/2022 08:00	0.0	0	0	0	0	0
03/10/2022 09:00	0.0	0	0	0	0	0
03/10/2022 10:00	0.0	0	0	0	0	0
03/10/2022 11:00	0.0	0	0	0	0	0
03/10/2022 12:00	0.0	0	0	0	0	0
03/10/2022 13:00	0.0	0	0	0	0	0
03/10/2022 14:00	0.0	0	0	0	0	0
03/10/2022 15:00	0.0	0	0	0	0	0
03/10/2022 16:00	0.0	0	0	0	0	0
03/10/2022 17:00	0.0	0	0	0	0	0
03/10/2022 18:00	0.0	0	0	0	0	0
03/10/2022 19:00	0.0	0	0	0	0	0
03/10/2022 20:00	0.0	0	0	0	0	0
03/10/2022 21:00	0.0	0	0	0	0	0
03/10/2022 22:00	0.0	0	0	0	0	0
03/10/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/11/2022 00:00	0.0	0	0	0	0	0
03/11/2022 01:00	0.0	0	0	0	0	0
03/11/2022 02:00	0.0	0	0	0	0	0
03/11/2022 03:00	0.0	0	0	0	0	0
03/11/2022 04:00	0.0	0	0	0	0	0
03/11/2022 05:00	0.0	0	0	0	0	0
03/11/2022 06:00	0.0	0	0	0	0	0
03/11/2022 07:00	0.0	0	0	0	0	0
03/11/2022 08:00	0.0	0	0	0	0	0
03/11/2022 09:00	0.0	0	0	0	0	0
03/11/2022 10:00	0.0	0	0	0	0	0
03/11/2022 11:00	0.0	0	0	0	0	0
03/11/2022 12:00	0.0	0	0	0	0	0
03/11/2022 13:00	0.0	0	0	0	0	0
03/11/2022 14:00	0.0	0	0	0	0	0
03/11/2022 15:00	0.0	0	0	0	0	0
03/11/2022 16:00	0.0	0	0	0	0	0
03/11/2022 17:00	0.0	0	0	0	0	0
03/11/2022 18:00	0.0	0	0	0	0	0
03/11/2022 19:00	0.0	0	0	0	0	0
03/11/2022 20:00	0.0	0	0	0	0	0
03/11/2022 21:00	0.0	0	0	0	0	0
03/11/2022 22:00	0.0	0	0	0	0	0
03/11/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/12/2022 00:00	0.0	0	0	0	0	0
03/12/2022 01:00	0.0	0	0	0	0	0
03/12/2022 02:00	0.0	0	0	0	0	0
03/12/2022 03:00	0.0	0	0	0	0	0
03/12/2022 04:00	0.0	0	0	0	0	0
03/12/2022 05:00	0.0	0	0	0	0	0
03/12/2022 06:00	0.0	0	0	0	0	0
03/12/2022 07:00	0.0	0	0	0	0	0
03/12/2022 08:00	0.0	0	0	0	0	0
03/12/2022 09:00	0.0	0	0	0	0	0
03/12/2022 10:00	0.0	0	0	0	0	0
03/12/2022 11:00	0.0	0	0	0	0	0
03/12/2022 12:00	0.0	0	0	0	0	0
03/12/2022 13:00	0.0	0	0	0	0	0
03/12/2022 14:00	0.0	0	0	0	0	0
03/12/2022 15:00	0.0	0	0	0	0	0
03/12/2022 16:00	0.0	0	0	0	0	0
03/12/2022 17:00	0.0	0	0	0	0	0
03/12/2022 18:00	0.0	0	0	0	0	0
03/12/2022 19:00	0.0	0	0	0	0	0
03/12/2022 20:00	0.0	0	0	0	0	0
03/12/2022 21:00	0.0	0	0	0	0	0
03/12/2022 22:00	0.0	0	0	0	0	0
03/12/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/13/2022 00:00	0.0	0	0	0	0	0
03/13/2022 01:00	0.0	0	0	0	0	0
03/13/2022 02:00	0.0	0	0	0	0	0
03/13/2022 03:00	0.0	0	0	0	0	0
03/13/2022 04:00	0.0	0	0	0	0	0
03/13/2022 05:00	0.0	0	0	0	0	0
03/13/2022 06:00	0.0	0	0	0	0	0
03/13/2022 07:00	0.0	0	0	0	0	0
03/13/2022 08:00	0.0	0	0	0	0	0
03/13/2022 09:00	0.0	0	0	0	0	0
03/13/2022 10:00	0.0	0	0	0	0	0
03/13/2022 11:00	0.0	0	0	0	0	0
03/13/2022 12:00	0.0	0	0	0	0	0
03/13/2022 13:00	0.0	0	0	0	0	0
03/13/2022 14:00	0.0	0	0	0	0	0
03/13/2022 15:00	0.0	0	0	0	0	0
03/13/2022 16:00	0.0	0	0	0	0	0
03/13/2022 17:00	0.0	0	0	0	0	0
03/13/2022 18:00	0.0	0	0	0	0	0
03/13/2022 19:00	0.0	0	0	0	0	0
03/13/2022 20:00	0.0	0	0	0	0	0
03/13/2022 21:00	0.0	0	0	0	0	0
03/13/2022 22:00	0.0	0	0	0	0	0
03/13/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/14/2022 00:00	0.0	0	0	0	0	0
03/14/2022 01:00	0.0	0	0	0	0	0
03/14/2022 02:00	0.0	0	0	0	0	0
03/14/2022 03:00	0.0	0	0	0	0	0
03/14/2022 04:00	0.0	0	0	0	0	0
03/14/2022 05:00	0.0	0	0	0	0	0
03/14/2022 06:00	0.0	0	0	0	0	0
03/14/2022 07:00	0.0	0	0	0	0	0
03/14/2022 08:00	0.0	0	0	0	0	0
03/14/2022 09:00	0.0	0	0	0	0	0
03/14/2022 10:00	0.0	0	0	0	0	0
03/14/2022 11:00	0.0	0	0	0	0	0
03/14/2022 12:00	0.0	0	0	0	0	0
03/14/2022 13:00	0.0	0	0	0	0	0
03/14/2022 14:00	0.0	0	0	0	0	0
03/14/2022 15:00	0.0	0	0	0	0	0
03/14/2022 16:00	0.0	0	0	0	0	0
03/14/2022 17:00	0.0	0	0	0	0	0
03/14/2022 18:00	0.0	0	0	0	0	0
03/14/2022 19:00	0.0	0	0	0	0	0
03/14/2022 20:00	0.0	0	0	0	0	0
03/14/2022 21:00	0.0	0	0	0	0	0
03/14/2022 22:00	0.0	0	0	0	0	0
03/14/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/15/2022 00:00	0.0	0	0	0	0	0
03/15/2022 01:00	0.0	0	0	0	0	0
03/15/2022 02:00	0.0	0	0	0	0	0
03/15/2022 03:00	0.0	0	0	0	0	0
03/15/2022 04:00	0.0	0	0	0	0	0
03/15/2022 05:00	0.0	0	0	0	0	0
03/15/2022 06:00	0.0	0	0	0	0	0
03/15/2022 07:00	0.0	0	0	0	0	0
03/15/2022 08:00	0.0	0	0	0	0	0
03/15/2022 09:00	0.0	0	0	0	0	0
03/15/2022 10:00	0.0	0	0	0	0	0
03/15/2022 11:00	0.0	0	0	0	0	0
03/15/2022 12:00	0.0	0	0	0	0	0
03/15/2022 13:00	0.0	0	0	0	0	0
03/15/2022 14:00	0.0	0	0	0	0	0
03/15/2022 15:00	0.0	0	0	0	0	0
03/15/2022 16:00	0.0	0	0	0	0	0
03/15/2022 17:00	0.0	0	0	0	0	0
03/15/2022 18:00	0.0	0	0	0	0	0
03/15/2022 19:00	0.0	0	0	0	0	0
03/15/2022 20:00	0.0	0	0	0	0	0
03/15/2022 21:00	0.0	0	0	0	0	0
03/15/2022 22:00	0.0	0	0	0	0	0
03/15/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/16/2022 00:00	0.0	0	0	0	0	0
03/16/2022 01:00	0.0	0	0	0	0	0
03/16/2022 02:00	0.0	0	0	0	0	0
03/16/2022 03:00	0.0	0	0	0	0	0
03/16/2022 04:00	0.0	0	0	0	0	0
03/16/2022 05:00	0.0	0	0	0	0	0
03/16/2022 06:00	0.0	0	0	0	0	0
03/16/2022 07:00	0.0	0	0	0	0	0
03/16/2022 08:00	0.0	0	0	0	0	0
03/16/2022 09:00	0.0	0	0	0	0	0
03/16/2022 10:00	0.0	0	0	0	0	0
03/16/2022 11:00	0.0	0	0	0	0	0
03/16/2022 12:00	0.0	0	0	0	0	0
03/16/2022 13:00	0.0	0	0	0	0	0
03/16/2022 14:00	0.0	0	0	0	0	0
03/16/2022 15:00	0.0	0	0	0	0	0
03/16/2022 16:00	0.0	0	0	0	0	0
03/16/2022 17:00	0.0	0	0	0	0	0
03/16/2022 18:00	0.0	0	0	0	0	0
03/16/2022 19:00	0.0	0	0	0	0	0
03/16/2022 20:00	0.0	0	0	0	0	0
03/16/2022 21:00	0.0	0	0	0	0	0
03/16/2022 22:00	0.0	0	0	0	0	0
03/16/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/17/2022 00:00	0.0	0	0	0	0	0
03/17/2022 01:00	0.0	0	0	0	0	0
03/17/2022 02:00	0.0	0	0	0	0	0
03/17/2022 03:00	0.0	0	0	0	0	0
03/17/2022 04:00	0.0	0	0	0	0	0
03/17/2022 05:00	0.0	0	0	0	0	0
03/17/2022 06:00	0.0	0	0	0	0	0
03/17/2022 07:00	0.0	0	0	0	0	0
03/17/2022 08:00	0.0	0	0	0	0	0
03/17/2022 09:00	0.0	0	0	0	0	0
03/17/2022 10:00	0.0	0	0	0	0	0
03/17/2022 11:00	0.0	0	0	0	0	0
03/17/2022 12:00	0.0	0	0	0	0	0
03/17/2022 13:00	0.0	0	0	0	0	0
03/17/2022 14:00	0.0	0	0	0	0	0
03/17/2022 15:00	0.0	0	0	0	0	0
03/17/2022 16:00	0.0	0	0	0	0	0
03/17/2022 17:00	0.0	0	0	0	0	0
03/17/2022 18:00	0.0	0	0	0	0	0
03/17/2022 19:00	0.0	0	0	0	0	0
03/17/2022 20:00	0.0	0	0	0	0	0
03/17/2022 21:00	0.0	0	0	0	0	0
03/17/2022 22:00	0.0	0	0	0	0	0
03/17/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/18/2022 00:00	0.0	0	0	0	0	0
03/18/2022 01:00	0.0	0	0	0	0	0
03/18/2022 02:00	0.0	0	0	0	0	0
03/18/2022 03:00	0.0	0	0	0	0	0
03/18/2022 04:00	0.0	0	0	0	0	0
03/18/2022 05:00	0.0	0	0	0	0	0
03/18/2022 06:00	0.0	0	0	0	0	0
03/18/2022 07:00	0.0	0	0	0	0	0
03/18/2022 08:00	0.0	0	0	0	0	0
03/18/2022 09:00	0.0	0	0	0	0	0
03/18/2022 10:00	0.0	0	0	0	0	0
03/18/2022 11:00	0.0	0	0	0	0	0
03/18/2022 12:00	0.0	0	0	0	0	0
03/18/2022 13:00	0.0	0	0	0	0	0
03/18/2022 14:00	0.0	0	0	0	0	0
03/18/2022 15:00	0.0	0	0	0	0	0
03/18/2022 16:00	0.0	0	0	0	0	0
03/18/2022 17:00	0.0	0	0	0	0	0
03/18/2022 18:00	0.0	0	0	0	0	0
03/18/2022 19:00	0.0	0	0	0	0	0
03/18/2022 20:00	0.0	0	0	0	0	0
03/18/2022 21:00	0.0	0	0	0	0	0
03/18/2022 22:00	0.0	0	0	0	0	0
03/18/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/19/2022 00:00	0.0	0	0	0	0	0
03/19/2022 01:00	0.0	0	0	0	0	0
03/19/2022 02:00	0.0	0	0	0	0	0
03/19/2022 03:00	0.0	0	0	0	0	0
03/19/2022 04:00	0.0	0	0	0	0	0
03/19/2022 05:00	0.0	0	0	0	0	0
03/19/2022 06:00	0.0	0	0	0	0	0
03/19/2022 07:00	0.0	0	0	0	0	0
03/19/2022 08:00	0.0	0	0	0	0	0
03/19/2022 09:00	0.0	0	0	0	0	0
03/19/2022 10:00	0.0	0	0	0	0	0
03/19/2022 11:00	0.0	0	0	0	0	0
03/19/2022 12:00	0.0	0	0	0	0	0
03/19/2022 13:00	0.0	0	0	0	0	0
03/19/2022 14:00	0.0	0	0	0	0	0
03/19/2022 15:00	0.0	0	0	0	0	0
03/19/2022 16:00	0.0	0	0	0	0	0
03/19/2022 17:00	0.0	0	0	0	0	0
03/19/2022 18:00	0.0	0	0	0	0	0
03/19/2022 19:00	0.0	0	0	0	0	0
03/19/2022 20:00	0.0	0	0	0	0	0
03/19/2022 21:00	0.0	0	0	0	0	0
03/19/2022 22:00	0.0	0	0	0	0	0
03/19/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/20/2022 00:00	0.0	0	0	0	0	0
03/20/2022 01:00	0.0	0	0	0	0	0
03/20/2022 02:00	0.0	0	0	0	0	0
03/20/2022 03:00	0.0	0	0	0	0	0
03/20/2022 04:00	0.0	0	0	0	0	0
03/20/2022 05:00	0.0	0	0	0	0	0
03/20/2022 06:00	0.0	0	0	0	0	0
03/20/2022 07:00	0.0	0	0	0	0	0
03/20/2022 08:00	0.0	0	0	0	0	0
03/20/2022 09:00	0.0	0	0	0	0	0
03/20/2022 10:00	0.0	0	0	0	0	0
03/20/2022 11:00	0.0	0	0	0	0	0
03/20/2022 12:00	0.0	0	0	0	0	0
03/20/2022 13:00	0.0	0	0	0	0	0
03/20/2022 14:00	0.0	0	0	0	0	0
03/20/2022 15:00	0.0	0	0	0	0	0
03/20/2022 16:00	0.0	0	0	0	0	0
03/20/2022 17:00	0.0	0	0	0	0	0
03/20/2022 18:00	0.0	0	0	0	0	0
03/20/2022 19:00	0.0	0	0	0	0	0
03/20/2022 20:00	0.0	0	0	0	0	0
03/20/2022 21:00	0.0	0	0	0	0	0
03/20/2022 22:00	0.0	0	0	0	0	0
03/20/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/21/2022 00:00	0.0	0	0	0	0	0
03/21/2022 01:00	0.0	0	0	0	0	0
03/21/2022 02:00	0.0	0	0	0	0	0
03/21/2022 03:00	0.0	0	0	0	0	0
03/21/2022 04:00	0.0	0	0	0	0	0
03/21/2022 05:00	0.0	0	0	0	0	0
03/21/2022 06:00	0.0	0	0	0	0	0
03/21/2022 07:00	0.0	0	0	0	0	0
03/21/2022 08:00	0.0	0	0	0	0	0
03/21/2022 09:00	0.0	0	0	0	0	0
03/21/2022 10:00	0.0	0	0	0	0	0
03/21/2022 11:00	0.0	0	0	0	0	0
03/21/2022 12:00	0.0	0	0	0	0	0
03/21/2022 13:00	0.0	0	0	0	0	0
03/21/2022 14:00	0.0	0	0	0	0	0
03/21/2022 15:00	0.0	0	0	0	0	0
03/21/2022 16:00	0.0	0	0	0	0	0
03/21/2022 17:00	0.0	0	0	0	0	0
03/21/2022 18:00	0.0	0	0	0	0	0
03/21/2022 19:00	0.0	0	0	0	0	0
03/21/2022 20:00	0.0	0	0	0	0	0
03/21/2022 21:00	0.0	0	0	0	0	0
03/21/2022 22:00	0.0	0	0	0	0	0
03/21/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/22/2022 00:00	0.0	0	0	0	0	0
03/22/2022 01:00	0.0	0	0	0	0	0
03/22/2022 02:00	0.0	0	0	0	0	0
03/22/2022 03:00	0.0	0	0	0	0	0
03/22/2022 04:00	0.0	0	0	0	0	0
03/22/2022 05:00	0.0	0	0	0	0	0
03/22/2022 06:00	0.0	0	0	0	0	0
03/22/2022 07:00	0.0	0	0	0	0	0
03/22/2022 08:00	0.0	0	0	0	0	0
03/22/2022 09:00	0.0	0	0	0	0	0
03/22/2022 10:00	0.0	0	0	0	0	0
03/22/2022 11:00	0.0	0	0	0	0	0
03/22/2022 12:00	0.0	0	0	0	0	0
03/22/2022 13:00	0.0	0	0	0	0	0
03/22/2022 14:00	0.0	0	0	0	0	0
03/22/2022 15:00	0.0	0	0	0	0	0
03/22/2022 16:00	0.0	0	0	0	0	0
03/22/2022 17:00	0.0	0	0	0	0	0
03/22/2022 18:00	0.0	0	0	0	0	0
03/22/2022 19:00	0.0	0	0	0	0	0
03/22/2022 20:00	0.0	0	0	0	0	0
03/22/2022 21:00	0.0	0	0	0	0	0
03/22/2022 22:00	0.0	0	0	0	0	0
03/22/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/23/2022 00:00	0.0	0	0	0	0	0
03/23/2022 01:00	0.0	0	0	0	0	0
03/23/2022 02:00	0.0	0	0	0	0	0
03/23/2022 03:00	0.0	0	0	0	0	0
03/23/2022 04:00	0.0	0	0	0	0	0
03/23/2022 05:00	0.0	0	0	0	0	0
03/23/2022 06:00	0.0	0	0	0	0	0
03/23/2022 07:00	0.0	0	0	0	0	0
03/23/2022 08:00	0.0	0	0	0	0	0
03/23/2022 09:00	0.0	0	0	0	0	0
03/23/2022 10:00	0.0	0	0	0	0	0
03/23/2022 11:00	0.0	0	0	0	0	0
03/23/2022 12:00	0.0	0	0	0	0	0
03/23/2022 13:00	0.0	0	0	0	0	0
03/23/2022 14:00	0.0	0	0	0	0	0
03/23/2022 15:00	0.0	0	0	0	0	0
03/23/2022 16:00	0.0	0	0	0	0	0
03/23/2022 17:00	0.0	0	0	0	0	0
03/23/2022 18:00	0.0	0	0	0	0	0
03/23/2022 19:00	0.0	0	0	0	0	0
03/23/2022 20:00	0.0	0	0	0	0	0
03/23/2022 21:00	0.0	0	0	0	0	0
03/23/2022 22:00	0.0	0	0	0	0	0
03/23/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/24/2022 00:00	0.0	0	0	0	0	0
03/24/2022 01:00	0.0	0	0	0	0	0
03/24/2022 02:00	0.0	0	0	0	0	0
03/24/2022 03:00	0.0	0	0	0	0	0
03/24/2022 04:00	0.0	0	0	0	0	0
03/24/2022 05:00	0.0	0	0	0	0	0
03/24/2022 06:00	0.0	0	0	0	0	0
03/24/2022 07:00	0.0	0	0	0	0	0
03/24/2022 08:00	0.0	0	0	0	0	0
03/24/2022 09:00	0.0	0	0	0	0	0
03/24/2022 10:00	0.0	0	0	0	0	0
03/24/2022 11:00	0.0	0	0	0	0	0
03/24/2022 12:00	0.0	0	0	0	0	0
03/24/2022 13:00	0.0	0	0	0	0	0
03/24/2022 14:00	0.0	0	0	0	0	0
03/24/2022 15:00	0.0	0	0	0	0	0
03/24/2022 16:00	0.0	0	0	0	0	0
03/24/2022 17:00	0.0	0	0	0	0	0
03/24/2022 18:00	0.0	0	0	0	0	0
03/24/2022 19:00	0.0	0	0	0	0	0
03/24/2022 20:00	0.0	0	0	0	0	0
03/24/2022 21:00	0.0	0	0	0	0	0
03/24/2022 22:00	0.0	0	0	0	0	0
03/24/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/25/2022 00:00	0.0	0	0	0	0	0
03/25/2022 01:00	0.0	0	0	0	0	0
03/25/2022 02:00	0.0	0	0	0	0	0
03/25/2022 03:00	0.0	0	0	0	0	0
03/25/2022 04:00	0.0	0	0	0	0	0
03/25/2022 05:00	0.0	0	0	0	0	0
03/25/2022 06:00	0.0	0	0	0	0	0
03/25/2022 07:00	0.0	0	0	0	0	0
03/25/2022 08:00	0.0	0	0	0	0	0
03/25/2022 09:00	0.0	0	0	0	0	0
03/25/2022 10:00	0.0	0	0	0	0	0
03/25/2022 11:00	0.0	0	0	0	0	0
03/25/2022 12:00	0.0	0	0	0	0	0
03/25/2022 13:00	0.0	0	0	0	0	0
03/25/2022 14:00	0.0	0	0	0	0	0
03/25/2022 15:00	0.0	0	0	0	0	0
03/25/2022 16:00	0.0	0	0	0	0	0
03/25/2022 17:00	0.0	0	0	0	0	0
03/25/2022 18:00	0.0	0	0	0	0	0
03/25/2022 19:00	0.0	0	0	0	0	0
03/25/2022 20:00	0.0	0	0	0	0	0
03/25/2022 21:00	0.0	0	0	0	0	0
03/25/2022 22:00	0.0	0	0	0	0	0
03/25/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/26/2022 00:00	0.0	0	0	0	0	0
03/26/2022 01:00	0.0	0	0	0	0	0
03/26/2022 02:00	0.0	0	0	0	0	0
03/26/2022 03:00	0.0	0	0	0	0	0
03/26/2022 04:00	0.0	0	0	0	0	0
03/26/2022 05:00	0.0	0	0	0	0	0
03/26/2022 06:00	0.0	0	0	0	0	0
03/26/2022 07:00	0.0	0	0	0	0	0
03/26/2022 08:00	0.0	0	0	0	0	0
03/26/2022 09:00	0.0	0	0	0	0	0
03/26/2022 10:00	0.0	0	0	0	0	0
03/26/2022 11:00	0.0	0	0	0	0	0
03/26/2022 12:00	0.0	0	0	0	0	0
03/26/2022 13:00	0.0	0	0	0	0	0
03/26/2022 14:00	0.0	0	0	0	0	0
03/26/2022 15:00	0.0	0	0	0	0	0
03/26/2022 16:00	0.0	0	0	0	0	0
03/26/2022 17:00	0.0	0	0	0	0	0
03/26/2022 18:00	0.0	0	0	0	0	0
03/26/2022 19:00	0.0	0	0	0	0	0
03/26/2022 20:00	0.0	0	0	0	0	0
03/26/2022 21:00	0.0	0	0	0	0	0
03/26/2022 22:00	0.0	0	0	0	0	0
03/26/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/27/2022 00:00	0.0	0	0	0	0	0
03/27/2022 01:00	0.0	0	0	0	0	0
03/27/2022 02:00	0.0	0	0	0	0	0
03/27/2022 03:00	0.0	0	0	0	0	0
03/27/2022 04:00	0.0	0	0	0	0	0
03/27/2022 05:00	0.0	0	0	0	0	0
03/27/2022 06:00	0.0	0	0	0	0	0
03/27/2022 07:00	0.0	0	0	0	0	0
03/27/2022 08:00	0.0	0	0	0	0	0
03/27/2022 09:00	0.0	0	0	0	0	0
03/27/2022 10:00	0.0	0	0	0	0	0
03/27/2022 11:00	0.0	0	0	0	0	0
03/27/2022 12:00	0.0	0	0	0	0	0
03/27/2022 13:00	0.0	0	0	0	0	0
03/27/2022 14:00	0.0	0	0	0	0	0
03/27/2022 15:00	0.0	0	0	0	0	0
03/27/2022 16:00	0.0	0	0	0	0	0
03/27/2022 17:00	0.0	0	0	0	0	0
03/27/2022 18:00	0.0	0	0	0	0	0
03/27/2022 19:00	0.0	0	0	0	0	0
03/27/2022 20:00	0.0	0	0	0	0	0
03/27/2022 21:00	0.0	0	0	0	0	0
03/27/2022 22:00	0.0	0	0	0	0	0
03/27/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/28/2022 00:00	0.0	0	0	0	0	0
03/28/2022 01:00	0.0	0	0	0	0	0
03/28/2022 02:00	0.0	0	0	0	0	0
03/28/2022 03:00	0.0	0	0	0	0	0
03/28/2022 04:00	0.0	0	0	0	0	0
03/28/2022 05:00	0.0	0	0	0	0	0
03/28/2022 06:00	0.0	0	0	0	0	0
03/28/2022 07:00	0.0	0	0	0	0	0
03/28/2022 08:00	0.0	0	0	0	0	0
03/28/2022 09:00	0.0	0	0	0	0	0
03/28/2022 10:00	0.0	0	0	0	0	0
03/28/2022 11:00	0.0	0	0	0	0	0
03/28/2022 12:00	0.0	0	0	0	0	0
03/28/2022 13:00	0.0	0	0	0	0	0
03/28/2022 14:00	0.0	0	0	0	0	0
03/28/2022 15:00	0.0	0	0	0	0	0
03/28/2022 16:00	0.0	0	0	0	0	0
03/28/2022 17:00	0.0	0	0	0	0	0
03/28/2022 18:00	0.0	0	0	0	0	0
03/28/2022 19:00	0.0	0	0	0	0	0
03/28/2022 20:00	0.0	0	0	0	0	0
03/28/2022 21:00	0.0	0	0	0	0	0
03/28/2022 22:00	0.0	0	0	0	0	0
03/28/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/29/2022 00:00	0.0	0	0	0	0	0
03/29/2022 01:00	0.0	0	0	0	0	0
03/29/2022 02:00	0.0	0	0	0	0	0
03/29/2022 03:00	0.0	0	0	0	0	0
03/29/2022 04:00	0.0	0	0	0	0	0
03/29/2022 05:00	0.0	0	0	0	0	0
03/29/2022 06:00	0.0	0	0	0	0	0
03/29/2022 07:00	0.0	0	0	0	0	0
03/29/2022 08:00	0.0	0	0	0	0	0
03/29/2022 09:00	0.0	0	0	0	0	0
03/29/2022 10:00	0.0	0	0	0	0	0
03/29/2022 11:00	0.0	0	0	0	0	0
03/29/2022 12:00	0.0	0	0	0	0	0
03/29/2022 13:00	0.0	0	0	0	0	0
03/29/2022 14:00	0.0	0	0	0	0	0
03/29/2022 15:00	0.0	0	0	0	0	0
03/29/2022 16:00	0.0	0	0	0	0	0
03/29/2022 17:00	0.0	0	0	0	0	0
03/29/2022 18:00	0.0	0	0	0	0	0
03/29/2022 19:00	0.0	0	0	0	0	0
03/29/2022 20:00	0.0	0	0	0	0	0
03/29/2022 21:00	0.0	0	0	0	0	0
03/29/2022 22:00	0.0	0	0	0	0	0
03/29/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/30/2022 00:00	0.0	0	0	0	0	0
03/30/2022 01:00	0.0	0	0	0	0	0
03/30/2022 02:00	0.0	0	0	0	0	0
03/30/2022 03:00	0.0	0	0	0	0	0
03/30/2022 04:00	0.0	0	0	0	0	0
03/30/2022 05:00	0.0	0	0	0	0	0
03/30/2022 06:00	0.0	0	0	0	0	0
03/30/2022 07:00	0.0	0	0	0	0	0
03/30/2022 08:00	0.0	0	0	0	0	0
03/30/2022 09:00	0.0	0	0	0	0	0
03/30/2022 10:00	0.0	0	0	0	0	0
03/30/2022 11:00	0.0	0	0	0	0	0
03/30/2022 12:00	0.0	0	0	0	0	0
03/30/2022 13:00	0.0	0	0	0	0	0
03/30/2022 14:00	0.0	0	0	0	0	0
03/30/2022 15:00	0.0	0	0	0	0	0
03/30/2022 16:00	0.0	0	0	0	0	0
03/30/2022 17:00	0.0	0	0	0	0	0
03/30/2022 18:00	0.0	0	0	0	0	0
03/30/2022 19:00	0.0	0	0	0	0	0
03/30/2022 20:00	0.0	0	0	0	0	0
03/30/2022 21:00	0.0	0	0	0	0	0
03/30/2022 22:00	0.0	0	0	0	0	0
03/30/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf	Unit CT1 Startup, Cold, TF	Unit CT1 Startup, Warm, TF	Unit CT1 Startup, Hot, TF	Unit CT1 Shutdown, TF	Unit CT1 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/31/2022 00:00	0.0	0	0	0	0	0
03/31/2022 01:00	0.0	0	0	0	0	0
03/31/2022 02:00	0.0	0	0	0	0	0
03/31/2022 03:00	0.0	0	0	0	0	0
03/31/2022 04:00	0.0	0	0	0	0	0
03/31/2022 05:00	0.0	0	0	0	0	0
03/31/2022 06:00	0.0	0	0	0	0	0
03/31/2022 07:00	0.0	0	0	0	0	0
03/31/2022 08:00	0.0	0	0	0	0	0
03/31/2022 09:00	0.0	0	0	0	0	0
03/31/2022 10:00	0.0	0	0	0	0	0
03/31/2022 11:00	0.0	0	0	0	0	0
03/31/2022 12:00	0.0	0	0	0	0	0
03/31/2022 13:00	0.0	0	0	0	0	0
03/31/2022 14:00	0.0	0	0	0	0	0
03/31/2022 15:00	0.0	0	0	0	0	0
03/31/2022 16:00	0.0	0	0	0	0	0
03/31/2022 17:00	0.0	0	0	0	0	0
03/31/2022 18:00	0.0	0	0	0	0	0
03/31/2022 19:00	0.0	0	0	0	0	0
03/31/2022 20:00	0.0	0	0	0	0	0
03/31/2022 21:00	0.0	0	0	0	0	0
03/31/2022 22:00	0.0	0	0	0	0	0
03/31/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/01/2022 00:00	0.0	0	0	0	0	1
01/01/2022 01:00	0.0	0	0	0	0	1
01/01/2022 02:00	0.0	0	0	0	0	1
01/01/2022 03:00	0.0	0	0	0	0	1
01/01/2022 04:00	0.0	0	0	0	0	1
01/01/2022 05:00	0.0	0	0	0	0	1
01/01/2022 06:00	0.0	0	0	0	0	1
01/01/2022 07:00	0.0	0	0	0	0	1
01/01/2022 08:00	0.0	0	0	0	0	1
01/01/2022 09:00	0.8	0	0	0	1	0
01/01/2022 10:00	0.0	0	0	0	0	0
01/01/2022 11:00	0.0	0	0	0	0	0
01/01/2022 12:00	0.0	0	0	0	0	0
01/01/2022 13:00	0.0	0	0	0	0	0
01/01/2022 14:00	0.0	0	0	0	0	0
01/01/2022 15:00	0.0	0	0	0	0	0
01/01/2022 16:00	11.3	0	0	1	0	0
01/01/2022 17:00	50.8	0	0	1	0	0
01/01/2022 18:00	0.0	0	0	0	0	1
01/01/2022 19:00	0.0	0	0	0	0	1
01/01/2022 20:00	0.0	0	0	0	0	1
01/01/2022 21:00	0.0	0	0	0	0	1
01/01/2022 22:00	0.0	0	0	0	0	1
01/01/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	62.9 #	0 #	0 #	2 #	1 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	50.8	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb	Unit CT2 Startup, Cold, TF	Unit CT2 Startup, Warm, TF	Unit CT2 Startup, Hot, TF	Unit CT2 Shutdown, TF	Unit CT2 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/02/2022 00:00	0.0	0	0	0	0	1
01/02/2022 01:00	0.0	0	0	0	0	1
01/02/2022 02:00	0.0	0	0	0	0	1
01/02/2022 03:00	0.0	0	0	0	0	1
01/02/2022 04:00	0.0	0	0	0	0	1
01/02/2022 05:00	0.0	0	0	0	0	1
01/02/2022 06:00	0.0	0	0	0	0	1
01/02/2022 07:00	0.0	0	0	0	0	1
01/02/2022 08:00	0.0	0	0	0	0	1
01/02/2022 09:00	0.8	0	0	0	1	0
01/02/2022 10:00	0.0	0	0	0	0	0
01/02/2022 11:00	0.0	0	0	0	0	0
01/02/2022 12:00	0.0	0	0	0	0	0
01/02/2022 13:00	0.0	0	0	0	0	0
01/02/2022 14:00	0.0	0	0	0	0	0
01/02/2022 15:00	0.0	0	0	0	0	0
01/02/2022 16:00	8.4	0	0	1	0	0
01/02/2022 17:00	42.3	0	0	1	0	0
01/02/2022 18:00	0.0	0	0	0	0	1
01/02/2022 19:00	0.0	0	0	0	0	1
01/02/2022 20:00	0.0	0	0	0	0	1
01/02/2022 21:00	0.0	0	0	0	0	1
01/02/2022 22:00	0.0	0	0	0	0	1
01/02/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	51.5 #	0 #	0 #	2 #	1 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	42.3	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb	Unit CT2 Startup, Cold, TF	Unit CT2 Startup, Warm, TF	Unit CT2 Startup, Hot, TF	Unit CT2 Shutdown, TF	Unit CT2 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/03/2022 00:00	0.0	0	0	0	0	1
01/03/2022 01:00	0.0	0	0	0	0	1
01/03/2022 02:00	0.0	0	0	0	0	1
01/03/2022 03:00	0.0	0	0	0	0	1
01/03/2022 04:00	0.0	0	0	0	0	1
01/03/2022 05:00	0.0	0	0	0	0	1
01/03/2022 06:00	0.0	0	0	0	0	1
01/03/2022 07:00	0.0	0	0	0	0	1
01/03/2022 08:00	0.0	0	0	0	0	1
01/03/2022 09:00	0.0	0	0	0	0	1
01/03/2022 10:00	0.0	0	0	0	0	1
01/03/2022 11:00	0.0	0	0	0	0	1
01/03/2022 12:00	0.0	0	0	0	0	1
01/03/2022 13:00	0.0	0	0	0	0	1
01/03/2022 14:00	0.0	0	0	0	0	1
01/03/2022 15:00	0.0	0	0	0	0	1
01/03/2022 16:00	0.0	0	0	0	0	1
01/03/2022 17:00	0.0	0	0	0	0	1
01/03/2022 18:00	0.0	0	0	0	0	1
01/03/2022 19:00	0.0	0	0	0	0	1
01/03/2022 20:00	0.0	0	0	0	0	1
01/03/2022 21:00	0.0	0	0	0	0	1
01/03/2022 22:00	0.0	0	0	0	0	1
01/03/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb	Unit CT2 Startup, Cold, TF	Unit CT2 Startup, Warm, TF	Unit CT2 Startup, Hot, TF	Unit CT2 Shutdown, TF	Unit CT2 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/04/2022 00:00	0.0	0	0	0	0	1
01/04/2022 01:00	0.0	0	0	0	0	1
01/04/2022 02:00	0.0	0	0	0	0	1
01/04/2022 03:00	0.0	0	0	0	0	1
01/04/2022 04:00	0.0	0	0	0	0	1
01/04/2022 05:00	0.0	0	0	0	0	1
01/04/2022 06:00	0.0	0	0	0	0	1
01/04/2022 07:00	0.0	0	0	0	0	1
01/04/2022 08:00	0.0	0	0	0	0	1
01/04/2022 09:00	0.0	0	0	0	0	1
01/04/2022 10:00	0.0	0	0	0	0	1
01/04/2022 11:00	0.0	0	0	0	0	1
01/04/2022 12:00	0.0	0	0	0	0	1
01/04/2022 13:00	0.0	0	0	0	0	1
01/04/2022 14:00	0.0	0	0	0	0	1
01/04/2022 15:00	0.0	0	0	0	0	1
01/04/2022 16:00	0.0	0	0	0	0	1
01/04/2022 17:00	0.0	0	0	0	0	1
01/04/2022 18:00	0.0	0	0	0	0	1
01/04/2022 19:00	0.0	0	0	0	0	1
01/04/2022 20:00	0.0	0	0	0	0	1
01/04/2022 21:00	0.0	0	0	0	0	1
01/04/2022 22:00	0.0	0	0	0	0	1
01/04/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb	Unit CT2 Startup, Cold, TF	Unit CT2 Startup, Warm, TF	Unit CT2 Startup, Hot, TF	Unit CT2 Shutdown, TF	Unit CT2 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/05/2022 00:00	0.0	0	0	0	0	1
01/05/2022 01:00	0.0	0	0	0	0	1
01/05/2022 02:00	0.0	0	0	0	0	1
01/05/2022 03:00	0.0	0	0	0	0	1
01/05/2022 04:00	0.0	0	0	0	0	1
01/05/2022 05:00	0.0	0	0	0	0	1
01/05/2022 06:00	0.0	0	0	0	0	1
01/05/2022 07:00	0.0	0	0	0	0	1
01/05/2022 08:00	0.0	0	0	0	0	1
01/05/2022 09:00	0.0	0	0	0	0	1
01/05/2022 10:00	0.0	0	0	0	0	1
01/05/2022 11:00	0.0	0	0	0	0	1
01/05/2022 12:00	0.0	0	0	0	0	1
01/05/2022 13:00	0.0	0	0	0	0	1
01/05/2022 14:00	0.0	0	0	0	0	1
01/05/2022 15:00	0.0	0	0	0	0	1
01/05/2022 16:00	0.0	0	0	0	0	1
01/05/2022 17:00	0.0	0	0	0	0	1
01/05/2022 18:00	0.0	0	0	0	0	1
01/05/2022 19:00	0.0	0	0	0	0	1
01/05/2022 20:00	0.0	0	0	0	0	1
01/05/2022 21:00	0.0	0	0	0	0	1
01/05/2022 22:00	0.0	0	0	0	0	1
01/05/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb	Unit CT2 Startup, Cold, TF	Unit CT2 Startup, Warm, TF	Unit CT2 Startup, Hot, TF	Unit CT2 Shutdown, TF	Unit CT2 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/06/2022 00:00	0.0	0	0	0	0	1
01/06/2022 01:00	0.0	0	0	0	0	1
01/06/2022 02:00	0.0	0	0	0	0	1
01/06/2022 03:00	0.0	0	0	0	0	1
01/06/2022 04:00	0.0	0	0	0	0	1
01/06/2022 05:00	0.0	0	0	0	0	1
01/06/2022 06:00	0.0	0	0	0	0	1
01/06/2022 07:00	0.0	0	0	0	0	1
01/06/2022 08:00	0.0	0	0	0	0	1
01/06/2022 09:00	0.0	0	0	0	0	1
01/06/2022 10:00	0.0	0	0	0	0	1
01/06/2022 11:00	0.0	0	0	0	0	1
01/06/2022 12:00	0.0	0	0	0	0	1
01/06/2022 13:00	0.0	0	0	0	0	1
01/06/2022 14:00	0.0	0	0	0	0	1
01/06/2022 15:00	0.0	0	0	0	0	1
01/06/2022 16:00	0.0	0	0	0	0	1
01/06/2022 17:00	0.0	0	0	0	0	1
01/06/2022 18:00	0.0	0	0	0	0	1
01/06/2022 19:00	0.0	0	0	0	0	1
01/06/2022 20:00	0.0	0	0	0	0	1
01/06/2022 21:00	0.0	0	0	0	0	1
01/06/2022 22:00	0.0	0	0	0	0	1
01/06/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb	Unit CT2 Startup, Cold, TF	Unit CT2 Startup, Warm, TF	Unit CT2 Startup, Hot, TF	Unit CT2 Shutdown, TF	Unit CT2 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/07/2022 00:00	0.0	0	0	0	0	1
01/07/2022 01:00	0.0	0	0	0	0	1
01/07/2022 02:00	0.0	0	0	0	0	1
01/07/2022 03:00	0.0	0	0	0	0	1
01/07/2022 04:00	0.0	0	0	0	0	1
01/07/2022 05:00	0.0	0	0	0	0	1
01/07/2022 06:00	0.0	0	0	0	0	1
01/07/2022 07:00	0.0	0	0	0	0	1
01/07/2022 08:00	0.0	0	0	0	0	1
01/07/2022 09:00	0.0	0	0	0	0	1
01/07/2022 10:00	0.0	0	0	0	0	1
01/07/2022 11:00	0.0	0	0	0	0	1
01/07/2022 12:00	0.0	0	0	0	0	1
01/07/2022 13:00	0.0	0	0	0	0	1
01/07/2022 14:00	0.0	0	0	0	0	1
01/07/2022 15:00	0.0	0	0	0	0	1
01/07/2022 16:00	0.0	0	0	0	0	1
01/07/2022 17:00	0.0	0	0	0	0	1
01/07/2022 18:00	0.0	0	0	0	0	1
01/07/2022 19:00	0.0	0	0	0	0	1
01/07/2022 20:00	0.0	0	0	0	0	1
01/07/2022 21:00	0.0	0	0	0	0	1
01/07/2022 22:00	1.4	0	0	0	1	0
01/07/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	1.4 #	0 #	0 #	0 #	1 #	22 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.4	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb	Unit CT2 Startup, Cold, TF	Unit CT2 Startup, Warm, TF	Unit CT2 Startup, Hot, TF	Unit CT2 Shutdown, TF	Unit CT2 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/08/2022 00:00	0.0	0	0	0	0	0
01/08/2022 01:00	0.0	0	0	0	0	0
01/08/2022 02:00	0.0	0	0	0	0	0
01/08/2022 03:00	0.0	0	0	0	0	0
01/08/2022 04:00	0.0	0	0	0	0	0
01/08/2022 05:00	0.0	0	0	0	0	0
01/08/2022 06:00	0.0	0	0	0	0	0
01/08/2022 07:00	0.0	0	0	0	0	0
01/08/2022 08:00	0.0	0	0	0	0	0
01/08/2022 09:00	0.0	0	0	0	0	0
01/08/2022 10:00	0.0	0	0	0	0	0
01/08/2022 11:00	0.0	0	0	0	0	0
01/08/2022 12:00	0.0	0	0	0	0	0
01/08/2022 13:00	0.0	0	0	0	0	0
01/08/2022 14:00	0.0	0	0	0	0	0
01/08/2022 15:00	56.2	0	1	0	0	0
01/08/2022 16:00	21.8	0	1	0	0	0
01/08/2022 17:00	0.0	0	0	0	0	1
01/08/2022 18:00	0.0	0	0	0	0	1
01/08/2022 19:00	0.0	0	0	0	0	1
01/08/2022 20:00	0.0	0	0	0	0	1
01/08/2022 21:00	0.0	0	0	0	0	1
01/08/2022 22:00	0.0	0	0	0	0	1
01/08/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	78.0 #	0 #	2 #	0 #	0 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	56.2	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb	Unit CT2 Startup, Cold, TF	Unit CT2 Startup, Warm, TF	Unit CT2 Startup, Hot, TF	Unit CT2 Shutdown, TF	Unit CT2 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/09/2022 00:00	0.0	0	0	0	0	1
01/09/2022 01:00	0.0	0	0	0	0	1
01/09/2022 02:00	0.0	0	0	0	0	1
01/09/2022 03:00	0.0	0	0	0	0	1
01/09/2022 04:00	0.0	0	0	0	0	1
01/09/2022 05:00	0.0	0	0	0	0	1
01/09/2022 06:00	0.0	0	0	0	0	1
01/09/2022 07:00	0.0	0	0	0	0	1
01/09/2022 08:00	0.0	0	0	0	0	1
01/09/2022 09:00	0.0	0	0	0	0	1
01/09/2022 10:00	0.0	0	0	0	0	1
01/09/2022 11:00	0.0	0	0	0	0	1
01/09/2022 12:00	0.0	0	0	0	0	1
01/09/2022 13:00	0.0	0	0	0	0	1
01/09/2022 14:00	0.0	0	0	0	0	1
01/09/2022 15:00	0.0	0	0	0	0	1
01/09/2022 16:00	0.0	0	0	0	0	1
01/09/2022 17:00	0.0	0	0	0	0	1
01/09/2022 18:00	0.0	0	0	0	0	1
01/09/2022 19:00	0.0	0	0	0	0	1
01/09/2022 20:00	0.0	0	0	0	0	1
01/09/2022 21:00	0.0	0	0	0	0	1
01/09/2022 22:00	0.0	0	0	0	0	1
01/09/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb	Unit CT2 Startup, Cold, TF	Unit CT2 Startup, Warm, TF	Unit CT2 Startup, Hot, TF	Unit CT2 Shutdown, TF	Unit CT2 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/10/2022 00:00	0.0	0	0	0	0	1
01/10/2022 01:00	0.6	0	0	0	1	0
01/10/2022 02:00	0.0	0	0	0	0	0
01/10/2022 03:00	0.0	0	0	0	0	0
01/10/2022 04:00	0.0	0	0	0	0	0
01/10/2022 05:00	0.0	0	0	0	0	0
01/10/2022 06:00	27.1	0	0	1	0	0
01/10/2022 07:00	16.7	0	0	1	0	0
01/10/2022 08:00	0.0	0	0	0	0	1
01/10/2022 09:00	0.0	0	0	0	0	1
01/10/2022 10:00	0.0	0	0	0	0	1
01/10/2022 11:00	0.0	0	0	0	0	1
01/10/2022 12:00	0.0	0	0	0	0	1
01/10/2022 13:00	0.0	0	0	0	0	1
01/10/2022 14:00	0.0	0	0	0	0	1
01/10/2022 15:00	0.0	0	0	0	0	1
01/10/2022 16:00	0.0	0	0	0	0	1
01/10/2022 17:00	0.0	0	0	0	0	1
01/10/2022 18:00	0.0	0	0	0	0	1
01/10/2022 19:00	0.0	0	0	0	0	1
01/10/2022 20:00	0.0	0	0	0	0	1
01/10/2022 21:00	0.0	0	0	0	0	1
01/10/2022 22:00	0.0	0	0	0	0	1
01/10/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	44.4 #	0 #	0 #	2 #	1 #	17 #
Minimum:	0.0	0	0	0	0	0
Maximum:	27.1	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb	Unit CT2 Startup, Cold, TF	Unit CT2 Startup, Warm, TF	Unit CT2 Startup, Hot, TF	Unit CT2 Shutdown, TF	Unit CT2 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/11/2022 00:00	0.0	0	0	0	0	1
01/11/2022 01:00	0.0	0	0	0	0	1
01/11/2022 02:00	0.0	0	0	0	0	1
01/11/2022 03:00	0.0	0	0	0	0	1
01/11/2022 04:00	0.0	0	0	0	0	1
01/11/2022 05:00	0.0	0	0	0	0	1
01/11/2022 06:00	0.0	0	0	0	0	1
01/11/2022 07:00	0.0	0	0	0	0	1
01/11/2022 08:00	0.0	0	0	0	0	1
01/11/2022 09:00	0.0	0	0	0	0	1
01/11/2022 10:00	0.0	0	0	0	0	1
01/11/2022 11:00	0.0	0	0	0	0	1
01/11/2022 12:00	0.0	0	0	0	0	1
01/11/2022 13:00	0.0	0	0	0	0	1
01/11/2022 14:00	0.0	0	0	0	0	1
01/11/2022 15:00	0.0	0	0	0	0	1
01/11/2022 16:00	0.0	0	0	0	0	1
01/11/2022 17:00	0.0	0	0	0	0	1
01/11/2022 18:00	0.0	0	0	0	0	1
01/11/2022 19:00	0.0	0	0	0	0	1
01/11/2022 20:00	0.0	0	0	0	0	1
01/11/2022 21:00	0.0	0	0	0	0	1
01/11/2022 22:00	0.0	0	0	0	0	1
01/11/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb	Unit CT2 Startup, Cold, TF	Unit CT2 Startup, Warm, TF	Unit CT2 Startup, Hot, TF	Unit CT2 Shutdown, TF	Unit CT2 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/12/2022 00:00	0.7	0	0	0	1	0
01/12/2022 01:00	0.0	0	0	0	0	0
01/12/2022 02:00	0.0	0	0	0	0	0
01/12/2022 03:00	0.0	0	0	0	0	0
01/12/2022 04:00	0.0	0	0	0	0	0
01/12/2022 05:00	0.0	0	0	0	0	0
01/12/2022 06:00	0.0	0	0	0	0	0
01/12/2022 07:00	0.0	0	0	0	0	0
01/12/2022 08:00	0.0	0	0	0	0	0
01/12/2022 09:00	15.8	0	1	0	0	0
01/12/2022 10:00	57.4	0	1	0	0	0
01/12/2022 11:00	0.0	0	0	0	0	1
01/12/2022 12:00	0.0	0	0	0	0	1
01/12/2022 13:00	0.0	0	0	0	0	1
01/12/2022 14:00	0.0	0	0	0	0	1
01/12/2022 15:00	0.0	0	0	0	0	1
01/12/2022 16:00	0.0	0	0	0	0	1
01/12/2022 17:00	0.0	0	0	0	0	1
01/12/2022 18:00	0.0	0	0	0	0	1
01/12/2022 19:00	0.0	0	0	0	0	1
01/12/2022 20:00	0.0	0	0	0	0	1
01/12/2022 21:00	0.0	0	0	0	0	1
01/12/2022 22:00	0.0	0	0	0	0	1
01/12/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	73.9 #	0 #	2 #	0 #	1 #	13 #
Minimum:	0.0	0	0	0	0	0
Maximum:	57.4	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb	Unit CT2 Startup, Cold, TF	Unit CT2 Startup, Warm, TF	Unit CT2 Startup, Hot, TF	Unit CT2 Shutdown, TF	Unit CT2 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/13/2022 00:00	0.0	0	0	0	0	1
01/13/2022 01:00	0.0	0	0	0	0	1
01/13/2022 02:00	0.0	0	0	0	0	1
01/13/2022 03:00	0.0	0	0	0	0	1
01/13/2022 04:00	0.0	0	0	0	0	1
01/13/2022 05:00	0.0	0	0	0	0	1
01/13/2022 06:00	0.0	0	0	0	0	1
01/13/2022 07:00	0.0	0	0	0	0	1
01/13/2022 08:00	0.0	0	0	0	0	1
01/13/2022 09:00	0.0	0	0	0	0	1
01/13/2022 10:00	0.0	0	0	0	0	1
01/13/2022 11:00	0.0	0	0	0	0	1
01/13/2022 12:00	0.0	0	0	0	0	1
01/13/2022 13:00	0.0	0	0	0	0	1
01/13/2022 14:00	0.0	0	0	0	0	1
01/13/2022 15:00	0.0	0	0	0	0	1
01/13/2022 16:00	0.0	0	0	0	0	1
01/13/2022 17:00	0.0	0	0	0	0	1
01/13/2022 18:00	0.0	0	0	0	0	1
01/13/2022 19:00	0.0	0	0	0	0	1
01/13/2022 20:00	0.0	0	0	0	0	1
01/13/2022 21:00	0.0	0	0	0	0	1
01/13/2022 22:00	0.0	0	0	0	0	1
01/13/2022 23:00	1.4	0	0	0	1	0
Average/Sum#:	1.4 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.4	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb	Unit CT2 Startup, Cold, TF	Unit CT2 Startup, Warm, TF	Unit CT2 Startup, Hot, TF	Unit CT2 Shutdown, TF	Unit CT2 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/14/2022 00:00	0.0	0	0	0	0	0
01/14/2022 01:00	0.0	0	0	0	0	0
01/14/2022 02:00	0.0	0	0	0	0	0
01/14/2022 03:00	0.0	0	0	0	0	0
01/14/2022 04:00	0.0	0	0	0	0	0
01/14/2022 05:00	0.0	0	0	0	0	0
01/14/2022 06:00	0.0	0	0	0	0	0
01/14/2022 07:00	0.0	0	0	0	0	0
01/14/2022 08:00	0.0	0	0	0	0	0
01/14/2022 09:00	0.0	0	0	0	0	0
01/14/2022 10:00	0.0	0	0	0	0	0
01/14/2022 11:00	0.0	0	0	0	0	0
01/14/2022 12:00	0.0	0	0	0	0	0
01/14/2022 13:00	43.2	0	1	0	0	0
01/14/2022 14:00	27.1	0	1	0	0	0
01/14/2022 15:00	0.0	0	0	0	0	1
01/14/2022 16:00	0.0	0	0	0	0	1
01/14/2022 17:00	0.0	0	0	0	0	1
01/14/2022 18:00	0.0	0	0	0	0	1
01/14/2022 19:00	0.0	0	0	0	0	1
01/14/2022 20:00	0.0	0	0	0	0	1
01/14/2022 21:00	0.0	0	0	0	0	1
01/14/2022 22:00	0.0	0	0	0	0	1
01/14/2022 23:00	1.2	0	0	0	1	0
Average/Sum#:	71.5 #	0 #	2 #	0 #	1 #	8 #
Minimum:	0.0	0	0	0	0	0
Maximum:	43.2	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb	Unit CT2 Startup, Cold, TF	Unit CT2 Startup, Warm, TF	Unit CT2 Startup, Hot, TF	Unit CT2 Shutdown, TF	Unit CT2 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/15/2022 00:00	0.0	0	0	0	0	0
01/15/2022 01:00	0.0	0	0	0	0	0
01/15/2022 02:00	0.0	0	0	0	0	0
01/15/2022 03:00	0.0	0	0	0	0	0
01/15/2022 04:00	0.0	0	0	0	0	0
01/15/2022 05:00	0.0	0	0	0	0	0
01/15/2022 06:00	0.0	0	0	0	0	0
01/15/2022 07:00	0.0	0	0	0	0	0
01/15/2022 08:00	0.0	0	0	0	0	0
01/15/2022 09:00	0.0	0	0	0	0	0
01/15/2022 10:00	0.0	0	0	0	0	0
01/15/2022 11:00	0.0	0	0	0	0	0
01/15/2022 12:00	0.0	0	0	0	0	0
01/15/2022 13:00	0.0	0	0	0	0	0
01/15/2022 14:00	47.1	0	1	0	0	0
01/15/2022 15:00	29.6	0	1	0	0	0
01/15/2022 16:00	0.0	0	0	0	0	1
01/15/2022 17:00	0.0	0	0	0	0	1
01/15/2022 18:00	0.0	0	0	0	0	1
01/15/2022 19:00	0.0	0	0	0	0	1
01/15/2022 20:00	0.0	0	0	0	0	1
01/15/2022 21:00	0.0	0	0	0	0	1
01/15/2022 22:00	0.0	0	0	0	0	1
01/15/2022 23:00	0.9	0	0	0	1	0
Average/Sum#:	77.6 #	0 #	2 #	0 #	1 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	47.1	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb	Unit CT2 Startup, Cold, TF	Unit CT2 Startup, Warm, TF	Unit CT2 Startup, Hot, TF	Unit CT2 Shutdown, TF	Unit CT2 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/16/2022 00:00	0.0	0	0	0	0	0
01/16/2022 01:00	0.0	0	0	0	0	0
01/16/2022 02:00	0.0	0	0	0	0	0
01/16/2022 03:00	0.0	0	0	0	0	0
01/16/2022 04:00	0.0	0	0	0	0	0
01/16/2022 05:00	0.0	0	0	0	0	0
01/16/2022 06:00	0.0	0	0	0	0	0
01/16/2022 07:00	0.0	0	0	0	0	0
01/16/2022 08:00	0.0	0	0	0	0	0
01/16/2022 09:00	0.0	0	0	0	0	0
01/16/2022 10:00	0.0	0	0	0	0	0
01/16/2022 11:00	0.0	0	0	0	0	0
01/16/2022 12:00	0.0	0	0	0	0	0
01/16/2022 13:00	0.0	0	0	0	0	0
01/16/2022 14:00	0.0	0	0	0	0	0
01/16/2022 15:00	22.6	0	1	0	0	0
01/16/2022 16:00	55.1	0	1	0	0	0
01/16/2022 17:00	0.3	0	1	0	0	0
01/16/2022 18:00	0.0	0	0	0	0	1
01/16/2022 19:00	0.0	0	0	0	0	1
01/16/2022 20:00	0.0	0	0	0	0	1
01/16/2022 21:00	0.0	0	0	0	0	1
01/16/2022 22:00	0.0	0	0	0	0	1
01/16/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	78.0 #	0 #	3 #	0 #	0 #	6 #
Minimum:	0.0	0	0	0	0	0
Maximum:	55.1	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb	Unit CT2 Startup, Cold, TF	Unit CT2 Startup, Warm, TF	Unit CT2 Startup, Hot, TF	Unit CT2 Shutdown, TF	Unit CT2 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/17/2022 00:00	0.0	0	0	0	0	1
01/17/2022 01:00	0.0	0	0	0	0	1
01/17/2022 02:00	0.0	0	0	0	0	1
01/17/2022 03:00	0.0	0	0	0	0	1
01/17/2022 04:00	0.0	0	0	0	0	1
01/17/2022 05:00	0.0	0	0	0	0	1
01/17/2022 06:00	0.0	0	0	0	0	1
01/17/2022 07:00	0.0	0	0	0	0	1
01/17/2022 08:00	0.0	0	0	0	0	1
01/17/2022 09:00	0.0	0	0	0	0	1
01/17/2022 10:00	0.0	0	0	0	0	1
01/17/2022 11:00	0.0	0	0	0	0	1
01/17/2022 12:00	0.0	0	0	0	0	1
01/17/2022 13:00	0.0	0	0	0	0	1
01/17/2022 14:00	0.0	0	0	0	0	1
01/17/2022 15:00	0.0	0	0	0	0	1
01/17/2022 16:00	0.0	0	0	0	0	1
01/17/2022 17:00	0.0	0	0	0	0	1
01/17/2022 18:00	0.0	0	0	0	0	1
01/17/2022 19:00	0.0	0	0	0	0	1
01/17/2022 20:00	0.0	0	0	0	0	1
01/17/2022 21:00	0.0	0	0	0	0	1
01/17/2022 22:00	0.0	0	0	0	0	1
01/17/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb	Unit CT2 Startup, Cold, TF	Unit CT2 Startup, Warm, TF	Unit CT2 Startup, Hot, TF	Unit CT2 Shutdown, TF	Unit CT2 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/18/2022 00:00	0.0	0	0	0	0	1
01/18/2022 01:00	0.0	0	0	0	0	1
01/18/2022 02:00	0.0	0	0	0	0	1
01/18/2022 03:00	0.0	0	0	0	0	1
01/18/2022 04:00	0.0	0	0	0	0	1
01/18/2022 05:00	0.0	0	0	0	0	1
01/18/2022 06:00	0.0	0	0	0	0	1
01/18/2022 07:00	0.0	0	0	0	0	1
01/18/2022 08:00	0.0	0	0	0	0	1
01/18/2022 09:00	0.0	0	0	0	0	1
01/18/2022 10:00	0.0	0	0	0	0	1
01/18/2022 11:00	0.0	0	0	0	0	1
01/18/2022 12:00	0.0	0	0	0	0	1
01/18/2022 13:00	0.0	0	0	0	0	1
01/18/2022 14:00	0.0	0	0	0	0	1
01/18/2022 15:00	0.0	0	0	0	0	1
01/18/2022 16:00	0.0	0	0	0	0	1
01/18/2022 17:00	0.0	0	0	0	0	1
01/18/2022 18:00	0.0	0	0	0	0	1
01/18/2022 19:00	0.0	0	0	0	0	1
01/18/2022 20:00	0.0	0	0	0	0	1
01/18/2022 21:00	0.0	0	0	0	0	1
01/18/2022 22:00	0.0	0	0	0	0	1
01/18/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb	Unit CT2 Startup, Cold, TF	Unit CT2 Startup, Warm, TF	Unit CT2 Startup, Hot, TF	Unit CT2 Shutdown, TF	Unit CT2 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/19/2022 00:00	0.0	0	0	0	0	1
01/19/2022 01:00	0.0	0	0	0	0	1
01/19/2022 02:00	0.0	0	0	0	0	1
01/19/2022 03:00	0.0	0	0	0	0	1
01/19/2022 04:00	0.0	0	0	0	0	1
01/19/2022 05:00	0.0	0	0	0	0	1
01/19/2022 06:00	0.0	0	0	0	0	1
01/19/2022 07:00	0.0	0	0	0	0	1
01/19/2022 08:00	0.0	0	0	0	0	1
01/19/2022 09:00	0.0	0	0	0	0	1
01/19/2022 10:00	0.0	0	0	0	0	1
01/19/2022 11:00	0.0	0	0	0	0	1
01/19/2022 12:00	0.0	0	0	0	0	1
01/19/2022 13:00	0.0	0	0	0	0	1
01/19/2022 14:00	0.0	0	0	0	0	1
01/19/2022 15:00	0.0	0	0	0	0	1
01/19/2022 16:00	0.0	0	0	0	0	1
01/19/2022 17:00	0.0	0	0	0	0	1
01/19/2022 18:00	0.0	0	0	0	0	1
01/19/2022 19:00	0.0	0	0	0	0	1
01/19/2022 20:00	0.0	0	0	0	0	1
01/19/2022 21:00	0.0	0	0	0	0	1
01/19/2022 22:00	0.0	0	0	0	0	1
01/19/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb	Unit CT2 Startup, Cold, TF	Unit CT2 Startup, Warm, TF	Unit CT2 Startup, Hot, TF	Unit CT2 Shutdown, TF	Unit CT2 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/20/2022 00:00	0.0	0	0	0	0	1
01/20/2022 01:00	0.0	0	0	0	0	1
01/20/2022 02:00	0.0	0	0	0	0	1
01/20/2022 03:00	0.0	0	0	0	0	1
01/20/2022 04:00	0.0	0	0	0	0	1
01/20/2022 05:00	0.0	0	0	0	0	1
01/20/2022 06:00	0.0	0	0	0	0	1
01/20/2022 07:00	0.0	0	0	0	0	1
01/20/2022 08:00	0.0	0	0	0	0	1
01/20/2022 09:00	0.7	0	0	0	1	0
01/20/2022 10:00	0.0	0	0	0	0	0
01/20/2022 11:00	0.0	0	0	0	0	0
01/20/2022 12:00	0.0	0	0	0	0	0
01/20/2022 13:00	0.0	0	0	0	0	0
01/20/2022 14:00	0.0	0	0	0	0	0
01/20/2022 15:00	0.0	0	0	0	0	0
01/20/2022 16:00	22.7	0	0	1	0	0
01/20/2022 17:00	25.7	0	0	1	0	0
01/20/2022 18:00	0.0	0	0	0	0	1
01/20/2022 19:00	0.0	0	0	0	0	1
01/20/2022 20:00	0.0	0	0	0	0	1
01/20/2022 21:00	0.0	0	0	0	0	1
01/20/2022 22:00	0.0	0	0	0	0	1
01/20/2022 23:00	1.2	0	0	0	1	0
Average/Sum#:	50.3 #	0 #	0 #	2 #	2 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	25.7	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb	Unit CT2 Startup, Cold, TF	Unit CT2 Startup, Warm, TF	Unit CT2 Startup, Hot, TF	Unit CT2 Shutdown, TF	Unit CT2 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/21/2022 00:00	0.0	0	0	0	0	0
01/21/2022 01:00	0.0	0	0	0	0	0
01/21/2022 02:00	0.0	0	0	0	0	0
01/21/2022 03:00	0.0	0	0	0	0	0
01/21/2022 04:00	0.0	0	0	0	0	0
01/21/2022 05:00	0.0	0	0	0	0	0
01/21/2022 06:00	0.0	0	0	0	0	0
01/21/2022 07:00	0.0	0	0	0	0	0
01/21/2022 08:00	0.0	0	0	0	0	0
01/21/2022 09:00	0.0	0	0	0	0	0
01/21/2022 10:00	0.0	0	0	0	0	0
01/21/2022 11:00	0.0	0	0	0	0	0
01/21/2022 12:00	0.0	0	0	0	0	0
01/21/2022 13:00	0.0	0	0	0	0	0
01/21/2022 14:00	0.0	0	0	0	0	0
01/21/2022 15:00	0.0	0	0	0	0	0
01/21/2022 16:00	0.0	0	0	0	0	0
01/21/2022 17:00	0.0	0	0	0	0	0
01/21/2022 18:00	0.0	0	0	0	0	0
01/21/2022 19:00	0.0	0	0	0	0	0
01/21/2022 20:00	0.0	0	0	0	0	0
01/21/2022 21:00	0.0	0	0	0	0	0
01/21/2022 22:00	0.0	0	0	0	0	0
01/21/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb	Unit CT2 Startup, Cold, TF	Unit CT2 Startup, Warm, TF	Unit CT2 Startup, Hot, TF	Unit CT2 Shutdown, TF	Unit CT2 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/22/2022 00:00	0.0	0	0	0	0	0
01/22/2022 01:00	0.0	0	0	0	0	0
01/22/2022 02:00	0.0	0	0	0	0	0
01/22/2022 03:00	0.0	0	0	0	0	0
01/22/2022 04:00	0.0	0	0	0	0	0
01/22/2022 05:00	0.0	0	0	0	0	0
01/22/2022 06:00	0.0	0	0	0	0	0
01/22/2022 07:00	0.0	0	0	0	0	0
01/22/2022 08:00	0.0	0	0	0	0	0
01/22/2022 09:00	0.0	0	0	0	0	0
01/22/2022 10:00	0.0	0	0	0	0	0
01/22/2022 11:00	0.0	0	0	0	0	0
01/22/2022 12:00	0.0	0	0	0	0	0
01/22/2022 13:00	0.0	0	0	0	0	0
01/22/2022 14:00	0.0	0	0	0	0	0
01/22/2022 15:00	0.0	0	0	0	0	0
01/22/2022 16:00	0.0	0	0	0	0	0
01/22/2022 17:00	0.0	0	0	0	0	0
01/22/2022 18:00	0.0	0	0	0	0	0
01/22/2022 19:00	0.0	0	0	0	0	0
01/22/2022 20:00	0.0	0	0	0	0	0
01/22/2022 21:00	0.0	0	0	0	0	0
01/22/2022 22:00	0.0	0	0	0	0	0
01/22/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb	Unit CT2 Startup, Cold, TF	Unit CT2 Startup, Warm, TF	Unit CT2 Startup, Hot, TF	Unit CT2 Shutdown, TF	Unit CT2 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/23/2022 00:00	0.0	0	0	0	0	0
01/23/2022 01:00	0.0	0	0	0	0	0
01/23/2022 02:00	0.0	0	0	0	0	0
01/23/2022 03:00	0.0	0	0	0	0	0
01/23/2022 04:00	0.0	0	0	0	0	0
01/23/2022 05:00	0.0	0	0	0	0	0
01/23/2022 06:00	0.0	0	0	0	0	0
01/23/2022 07:00	0.0	0	0	0	0	0
01/23/2022 08:00	0.0	0	0	0	0	0
01/23/2022 09:00	0.0	0	0	0	0	0
01/23/2022 10:00	0.0	0	0	0	0	0
01/23/2022 11:00	0.0	0	0	0	0	0
01/23/2022 12:00	0.0	0	0	0	0	0
01/23/2022 13:00	0.0	0	0	0	0	0
01/23/2022 14:00	0.0	0	0	0	0	0
01/23/2022 15:00	0.0	0	0	0	0	0
01/23/2022 16:00	25.3	0	1	0	0	0
01/23/2022 17:00	93.7	0	1	0	0	0
01/23/2022 18:00	0.0	0	0	0	0	1
01/23/2022 19:00	0.0	0	0	0	0	1
01/23/2022 20:00	0.0	0	0	0	0	1
01/23/2022 21:00	0.0	0	0	0	0	1
01/23/2022 22:00	0.0	0	0	0	0	1
01/23/2022 23:00	1.7	0	0	0	1	0
Average/Sum#:	120.7 #	0 #	2 #	0 #	1 #	5 #
Minimum:	0.0	0	0	0	0	0
Maximum:	93.7	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb	Unit CT2 Startup, Cold, TF	Unit CT2 Startup, Warm, TF	Unit CT2 Startup, Hot, TF	Unit CT2 Shutdown, TF	Unit CT2 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/24/2022 00:00	0.0	0	0	0	0	0
01/24/2022 01:00	0.0	0	0	0	0	0
01/24/2022 02:00	0.0	0	0	0	0	0
01/24/2022 03:00	0.0	0	0	0	0	0
01/24/2022 04:00	0.0	0	0	0	0	0
01/24/2022 05:00	0.0	0	0	0	0	0
01/24/2022 06:00	0.0	0	0	0	0	0
01/24/2022 07:00	0.0	0	0	0	0	0
01/24/2022 08:00	0.0	0	0	0	0	0
01/24/2022 09:00	0.0	0	0	0	0	0
01/24/2022 10:00	0.0	0	0	0	0	0
01/24/2022 11:00	0.0	0	0	0	0	0
01/24/2022 12:00	0.0	0	0	0	0	0
01/24/2022 13:00	0.0	0	0	0	0	0
01/24/2022 14:00	47.3	0	1	0	0	0
01/24/2022 15:00	19.5	0	1	0	0	0
01/24/2022 16:00	0.0	0	0	0	0	1
01/24/2022 17:00	0.0	0	0	0	0	1
01/24/2022 18:00	0.0	0	0	0	0	1
01/24/2022 19:00	0.0	0	0	0	0	1
01/24/2022 20:00	0.0	0	0	0	0	1
01/24/2022 21:00	0.0	0	0	0	0	1
01/24/2022 22:00	0.0	0	0	0	0	1
01/24/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	66.8 #	0 #	2 #	0 #	0 #	8 #
Minimum:	0.0	0	0	0	0	0
Maximum:	47.3	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb	Unit CT2 Startup, Cold, TF	Unit CT2 Startup, Warm, TF	Unit CT2 Startup, Hot, TF	Unit CT2 Shutdown, TF	Unit CT2 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/25/2022 00:00	0.0	0	0	0	0	1
01/25/2022 01:00	0.0	0	0	0	0	1
01/25/2022 02:00	0.0	0	0	0	0	1
01/25/2022 03:00	0.0	0	0	0	0	1
01/25/2022 04:00	0.0	0	0	0	0	1
01/25/2022 05:00	0.0	0	0	0	0	1
01/25/2022 06:00	0.0	0	0	0	0	1
01/25/2022 07:00	0.0	0	0	0	0	1
01/25/2022 08:00	1.0	0	0	0	1	0
01/25/2022 09:00	0.0	0	0	0	0	0
01/25/2022 10:00	0.0	0	0	0	0	0
01/25/2022 11:00	0.4	0	0	1	0	0
01/25/2022 12:00	26.0	0	0	1	0	0
01/25/2022 13:00	0.0	0	0	0	0	1
01/25/2022 14:00	0.0	0	0	0	0	1
01/25/2022 15:00	0.0	0	0	0	0	1
01/25/2022 16:00	0.0	0	0	0	0	1
01/25/2022 17:00	0.0	0	0	0	0	1
01/25/2022 18:00	0.0	0	0	0	0	1
01/25/2022 19:00	0.0	0	0	0	0	1
01/25/2022 20:00	0.0	0	0	0	0	1
01/25/2022 21:00	0.0	0	0	0	0	1
01/25/2022 22:00	0.0	0	0	0	0	1
01/25/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	27.4 #	0 #	0 #	2 #	1 #	19 #
Minimum:	0.0	0	0	0	0	0
Maximum:	26.0	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb	Unit CT2 Startup, Cold, TF	Unit CT2 Startup, Warm, TF	Unit CT2 Startup, Hot, TF	Unit CT2 Shutdown, TF	Unit CT2 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/26/2022 00:00	0.0	0	0	0	0	1
01/26/2022 01:00	0.0	0	0	0	0	1
01/26/2022 02:00	0.0	0	0	0	0	1
01/26/2022 03:00	0.0	0	0	0	0	1
01/26/2022 04:00	0.0	0	0	0	0	1
01/26/2022 05:00	0.0	0	0	0	0	1
01/26/2022 06:00	0.0	0	0	0	0	1
01/26/2022 07:00	0.0	0	0	0	0	1
01/26/2022 08:00	1.3	0	0	0	1	0
01/26/2022 09:00	0.0	0	0	0	0	0
01/26/2022 10:00	0.0	0	0	0	0	0
01/26/2022 11:00	0.3	0	0	1	0	0
01/26/2022 12:00	28.2	0	0	1	0	0
01/26/2022 13:00	0.0	0	0	0	0	1
01/26/2022 14:00	0.0	0	0	0	0	1
01/26/2022 15:00	0.0	0	0	0	0	1
01/26/2022 16:00	0.0	0	0	0	0	1
01/26/2022 17:00	0.0	0	0	0	0	1
01/26/2022 18:00	0.0	0	0	0	0	1
01/26/2022 19:00	0.0	0	0	0	0	1
01/26/2022 20:00	0.0	0	0	0	0	1
01/26/2022 21:00	0.0	0	0	0	0	1
01/26/2022 22:00	0.0	0	0	0	0	1
01/26/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	29.8 #	0 #	0 #	2 #	1 #	19 #
Minimum:	0.0	0	0	0	0	0
Maximum:	28.2	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb	Unit CT2 Startup, Cold, TF	Unit CT2 Startup, Warm, TF	Unit CT2 Startup, Hot, TF	Unit CT2 Shutdown, TF	Unit CT2 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/27/2022 00:00	0.0	0	0	0	0	1
01/27/2022 01:00	0.0	0	0	0	0	1
01/27/2022 02:00	0.0	0	0	0	0	1
01/27/2022 03:00	0.0	0	0	0	0	1
01/27/2022 04:00	0.0	0	0	0	0	1
01/27/2022 05:00	0.0	0	0	0	0	1
01/27/2022 06:00	0.0	0	0	0	0	1
01/27/2022 07:00	0.0	0	0	0	0	1
01/27/2022 08:00	0.0	0	0	0	0	1
01/27/2022 09:00	0.0	0	0	0	0	1
01/27/2022 10:00	0.0	0	0	0	0	1
01/27/2022 11:00	0.0	0	0	0	0	1
01/27/2022 12:00	0.0	0	0	0	0	1
01/27/2022 13:00	0.0	0	0	0	0	1
01/27/2022 14:00	0.0	0	0	0	0	1
01/27/2022 15:00	0.0	0	0	0	0	1
01/27/2022 16:00	0.0	0	0	0	0	1
01/27/2022 17:00	0.0	0	0	0	0	1
01/27/2022 18:00	0.0	0	0	0	0	1
01/27/2022 19:00	0.0	0	0	0	0	1
01/27/2022 20:00	0.0	0	0	0	0	1
01/27/2022 21:00	0.0	0	0	0	0	1
01/27/2022 22:00	0.0	0	0	0	0	1
01/27/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb	Unit CT2 Startup, Cold, TF	Unit CT2 Startup, Warm, TF	Unit CT2 Startup, Hot, TF	Unit CT2 Shutdown, TF	Unit CT2 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/28/2022 00:00	0.0	0	0	0	0	1
01/28/2022 01:00	0.0	0	0	0	0	1
01/28/2022 02:00	0.0	0	0	0	0	1
01/28/2022 03:00	0.0	0	0	0	0	1
01/28/2022 04:00	0.0	0	0	0	0	1
01/28/2022 05:00	0.0	0	0	0	0	1
01/28/2022 06:00	0.0	0	0	0	0	1
01/28/2022 07:00	0.0	0	0	0	0	1
01/28/2022 08:00	0.0	0	0	0	0	1
01/28/2022 09:00	0.0	0	0	0	0	1
01/28/2022 10:00	0.0	0	0	0	0	1
01/28/2022 11:00	0.0	0	0	0	0	1
01/28/2022 12:00	0.0	0	0	0	0	1
01/28/2022 13:00	0.0	0	0	0	0	1
01/28/2022 14:00	0.0	0	0	0	0	1
01/28/2022 15:00	0.0	0	0	0	0	1
01/28/2022 16:00	0.0	0	0	0	0	1
01/28/2022 17:00	0.0	0	0	0	0	1
01/28/2022 18:00	0.0	0	0	0	0	1
01/28/2022 19:00	0.0	0	0	0	0	1
01/28/2022 20:00	0.0	0	0	0	0	1
01/28/2022 21:00	0.0	0	0	0	0	1
01/28/2022 22:00	0.0	0	0	0	0	1
01/28/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb	Unit CT2 Startup, Cold, TF	Unit CT2 Startup, Warm, TF	Unit CT2 Startup, Hot, TF	Unit CT2 Shutdown, TF	Unit CT2 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/29/2022 00:00	0.0	0	0	0	0	1
01/29/2022 01:00	0.0	0	0	0	0	1
01/29/2022 02:00	0.0	0	0	0	0	1
01/29/2022 03:00	0.0	0	0	0	0	1
01/29/2022 04:00	0.0	0	0	0	0	1
01/29/2022 05:00	0.0	0	0	0	0	1
01/29/2022 06:00	0.0	0	0	0	0	1
01/29/2022 07:00	0.0	0	0	0	0	1
01/29/2022 08:00	0.0	0	0	0	0	1
01/29/2022 09:00	0.0	0	0	0	0	1
01/29/2022 10:00	0.0	0	0	0	0	1
01/29/2022 11:00	0.0	0	0	0	0	1
01/29/2022 12:00	0.0	0	0	0	0	1
01/29/2022 13:00	0.0	0	0	0	0	1
01/29/2022 14:00	0.0	0	0	0	0	1
01/29/2022 15:00	0.0	0	0	0	0	1
01/29/2022 16:00	0.0	0	0	0	0	1
01/29/2022 17:00	0.0	0	0	0	0	1
01/29/2022 18:00	0.0	0	0	0	0	1
01/29/2022 19:00	0.0	0	0	0	0	1
01/29/2022 20:00	0.0	0	0	0	0	1
01/29/2022 21:00	0.0	0	0	0	0	1
01/29/2022 22:00	0.0	0	0	0	0	1
01/29/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb	Unit CT2 Startup, Cold, TF	Unit CT2 Startup, Warm, TF	Unit CT2 Startup, Hot, TF	Unit CT2 Shutdown, TF	Unit CT2 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/30/2022 00:00	0.0	0	0	0	0	1
01/30/2022 01:00	0.0	0	0	0	0	1
01/30/2022 02:00	0.0	0	0	0	0	1
01/30/2022 03:00	0.0	0	0	0	0	1
01/30/2022 04:00	0.0	0	0	0	0	1
01/30/2022 05:00	0.0	0	0	0	0	1
01/30/2022 06:00	0.0	0	0	0	0	1
01/30/2022 07:00	1.3	0	0	0	1	0
01/30/2022 08:00	0.0	0	0	0	0	0
01/30/2022 09:00	0.0	0	0	0	0	0
01/30/2022 10:00	0.0	0	0	0	0	0
01/30/2022 11:00	0.0	0	0	0	0	0
01/30/2022 12:00	0.0	0	0	0	0	0
01/30/2022 13:00	0.0	0	0	0	0	0
01/30/2022 14:00	6.4	0	0	1	0	0
01/30/2022 15:00	76.4	0	0	1	0	0
01/30/2022 16:00	0.0	0	0	0	0	1
01/30/2022 17:00	0.0	0	0	0	0	1
01/30/2022 18:00	0.0	0	0	0	0	1
01/30/2022 19:00	0.0	0	0	0	0	1
01/30/2022 20:00	0.0	0	0	0	0	1
01/30/2022 21:00	0.0	0	0	0	0	1
01/30/2022 22:00	0.0	0	0	0	0	1
01/30/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	84.1 #	0 #	0 #	2 #	1 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	76.4	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb	Unit CT2 Startup, Cold, TF	Unit CT2 Startup, Warm, TF	Unit CT2 Startup, Hot, TF	Unit CT2 Shutdown, TF	Unit CT2 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/31/2022 00:00	0.0	0	0	0	0	1
01/31/2022 01:00	0.0	0	0	0	0	1
01/31/2022 02:00	0.0	0	0	0	0	1
01/31/2022 03:00	0.0	0	0	0	0	1
01/31/2022 04:00	0.0	0	0	0	0	1
01/31/2022 05:00	0.0	0	0	0	0	1
01/31/2022 06:00	0.0	0	0	0	0	1
01/31/2022 07:00	0.0	0	0	0	0	1
01/31/2022 08:00	0.0	0	0	0	0	1
01/31/2022 09:00	0.0	0	0	0	0	1
01/31/2022 10:00	0.0	0	0	0	0	1
01/31/2022 11:00	0.0	0	0	0	0	1
01/31/2022 12:00	0.0	0	0	0	0	1
01/31/2022 13:00	0.0	0	0	0	0	1
01/31/2022 14:00	0.0	0	0	0	0	1
01/31/2022 15:00	0.0	0	0	0	0	1
01/31/2022 16:00	0.0	0	0	0	0	1
01/31/2022 17:00	0.0	0	0	0	0	1
01/31/2022 18:00	0.0	0	0	0	0	1
01/31/2022 19:00	0.0	0	0	0	0	1
01/31/2022 20:00	0.0	0	0	0	0	1
01/31/2022 21:00	0.0	0	0	0	0	1
01/31/2022 22:00	0.0	0	0	0	0	1
01/31/2022 23:00	1.3	0	0	0	1	0
Average/Sum#:	1.3 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.3	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb	Unit CT2 Startup, Cold, TF	Unit CT2 Startup, Warm, TF	Unit CT2 Startup, Hot, TF	Unit CT2 Shutdown, TF	Unit CT2 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/01/2022 00:00	0.0	0	0	0	0	0
02/01/2022 01:00	0.0	0	0	0	0	0
02/01/2022 02:00	0.0	0	0	0	0	0
02/01/2022 03:00	19.0	0	0	1	0	0
02/01/2022 04:00	6.5	0	0	1	0	0
02/01/2022 05:00	0.0	0	0	0	0	1
02/01/2022 06:00	0.0	0	0	0	0	1
02/01/2022 07:00	0.0	0	0	0	0	1
02/01/2022 08:00	0.0	0	0	0	0	1
02/01/2022 09:00	0.0	0	0	0	0	1
02/01/2022 10:00	0.0	0	0	0	0	1
02/01/2022 11:00	0.0	0	0	0	0	1
02/01/2022 12:00	0.0	0	0	0	0	1
02/01/2022 13:00	0.0	0	0	0	0	1
02/01/2022 14:00	0.0	0	0	0	0	1
02/01/2022 15:00	0.0	0	0	0	0	1
02/01/2022 16:00	0.0	0	0	0	0	1
02/01/2022 17:00	0.0	0	0	0	0	1
02/01/2022 18:00	0.0	0	0	0	0	1
02/01/2022 19:00	0.0	0	0	0	0	1
02/01/2022 20:00	0.0	0	0	0	0	1
02/01/2022 21:00	0.0	0	0	0	0	1
02/01/2022 22:00	0.0	0	0	0	0	1
02/01/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	25.5 #	0 #	0 #	2 #	0 #	19 #
Minimum:	0.0	0	0	0	0	0
Maximum:	19.0	0	0	1	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb	Unit CT2 Startup, Cold, TF	Unit CT2 Startup, Warm, TF	Unit CT2 Startup, Hot, TF	Unit CT2 Shutdown, TF	Unit CT2 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/02/2022 00:00	0.0	0	0	0	0	1
02/02/2022 01:00	0.0	0	0	0	0	1
02/02/2022 02:00	0.0	0	0	0	0	1
02/02/2022 03:00	0.0	0	0	0	0	1
02/02/2022 04:00	0.0	0	0	0	0	1
02/02/2022 05:00	0.0	0	0	0	0	1
02/02/2022 06:00	0.0	0	0	0	0	1
02/02/2022 07:00	0.0	0	0	0	0	1
02/02/2022 08:00	0.0	0	0	0	0	1
02/02/2022 09:00	0.0	0	0	0	0	1
02/02/2022 10:00	0.0	0	0	0	0	1
02/02/2022 11:00	0.0	0	0	0	0	1
02/02/2022 12:00	0.0	0	0	0	0	1
02/02/2022 13:00	0.0	0	0	0	0	1
02/02/2022 14:00	0.0	0	0	0	0	1
02/02/2022 15:00	0.0	0	0	0	0	1
02/02/2022 16:00	0.0	0	0	0	0	1
02/02/2022 17:00	0.0	0	0	0	0	1
02/02/2022 18:00	0.0	0	0	0	0	1
02/02/2022 19:00	0.0	0	0	0	0	1
02/02/2022 20:00	0.0	0	0	0	0	1
02/02/2022 21:00	0.0	0	0	0	0	1
02/02/2022 22:00	0.0	0	0	0	0	1
02/02/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb	Unit CT2 Startup, Cold, TF	Unit CT2 Startup, Warm, TF	Unit CT2 Startup, Hot, TF	Unit CT2 Shutdown, TF	Unit CT2 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/03/2022 00:00	0.0	0	0	0	0	1
02/03/2022 01:00	0.0	0	0	0	0	1
02/03/2022 02:00	0.0	0	0	0	0	1
02/03/2022 03:00	0.0	0	0	0	0	1
02/03/2022 04:00	0.0	0	0	0	0	1
02/03/2022 05:00	0.0	0	0	0	0	1
02/03/2022 06:00	0.0	0	0	0	0	1
02/03/2022 07:00	0.0	0	0	0	0	1
02/03/2022 08:00	0.0	0	0	0	0	1
02/03/2022 09:00	0.0	0	0	0	0	1
02/03/2022 10:00	0.0	0	0	0	0	1
02/03/2022 11:00	0.0	0	0	0	0	1
02/03/2022 12:00	0.0	0	0	0	0	1
02/03/2022 13:00	0.0	0	0	0	0	1
02/03/2022 14:00	0.0	0	0	0	0	1
02/03/2022 15:00	0.0	0	0	0	0	1
02/03/2022 16:00	0.0	0	0	0	0	1
02/03/2022 17:00	0.0	0	0	0	0	1
02/03/2022 18:00	0.0	0	0	0	0	1
02/03/2022 19:00	0.0	0	0	0	0	1
02/03/2022 20:00	0.0	0	0	0	0	1
02/03/2022 21:00	0.0	0	0	0	0	1
02/03/2022 22:00	0.0	0	0	0	0	1
02/03/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb	Unit CT2 Startup, Cold, TF	Unit CT2 Startup, Warm, TF	Unit CT2 Startup, Hot, TF	Unit CT2 Shutdown, TF	Unit CT2 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/04/2022 00:00	0.0	0	0	0	0	1
02/04/2022 01:00	0.0	0	0	0	0	1
02/04/2022 02:00	0.0	0	0	0	0	1
02/04/2022 03:00	0.0	0	0	0	0	1
02/04/2022 04:00	0.0	0	0	0	0	1
02/04/2022 05:00	0.0	0	0	0	0	1
02/04/2022 06:00	0.0	0	0	0	0	1
02/04/2022 07:00	0.0	0	0	0	0	1
02/04/2022 08:00	1.3	0	0	0	1	0
02/04/2022 09:00	0.0	0	0	0	0	0
02/04/2022 10:00	0.0	0	0	0	0	0
02/04/2022 11:00	3.1	0	0	1	0	0
02/04/2022 12:00	31.6	0	0	1	0	0
02/04/2022 13:00	0.0	0	0	0	0	1
02/04/2022 14:00	0.0	0	0	0	0	1
02/04/2022 15:00	0.0	0	0	0	0	1
02/04/2022 16:00	0.0	0	0	0	0	1
02/04/2022 17:00	0.0	0	0	0	0	1
02/04/2022 18:00	0.0	0	0	0	0	1
02/04/2022 19:00	0.0	0	0	0	0	1
02/04/2022 20:00	0.0	0	0	0	0	1
02/04/2022 21:00	0.0	0	0	0	0	1
02/04/2022 22:00	0.0	0	0	0	0	1
02/04/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	36.0 #	0 #	0 #	2 #	1 #	19 #
Minimum:	0.0	0	0	0	0	0
Maximum:	31.6	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb	Unit CT2 Startup, Cold, TF	Unit CT2 Startup, Warm, TF	Unit CT2 Startup, Hot, TF	Unit CT2 Shutdown, TF	Unit CT2 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/05/2022 00:00	0.0	0	0	0	0	1
02/05/2022 01:00	0.0	0	0	0	0	1
02/05/2022 02:00	0.0	0	0	0	0	1
02/05/2022 03:00	0.0	0	0	0	0	1
02/05/2022 04:00	0.0	0	0	0	0	1
02/05/2022 05:00	0.0	0	0	0	0	1
02/05/2022 06:00	0.0	0	0	0	0	1
02/05/2022 07:00	0.0	0	0	0	0	1
02/05/2022 08:00	1.3	0	0	0	1	0
02/05/2022 09:00	0.0	0	0	0	0	0
02/05/2022 10:00	0.0	0	0	0	0	0
02/05/2022 11:00	0.0	0	0	0	0	0
02/05/2022 12:00	0.0	0	0	0	0	0
02/05/2022 13:00	0.0	0	0	0	0	0
02/05/2022 14:00	0.0	0	0	0	0	0
02/05/2022 15:00	0.0	0	0	0	0	0
02/05/2022 16:00	0.0	0	0	0	0	0
02/05/2022 17:00	25.5	0	1	0	0	0
02/05/2022 18:00	44.6	0	1	0	0	0
02/05/2022 19:00	0.0	0	0	0	0	1
02/05/2022 20:00	0.0	0	0	0	0	1
02/05/2022 21:00	0.0	0	0	0	0	1
02/05/2022 22:00	0.0	0	0	0	0	1
02/05/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	71.4 #	0 #	2 #	0 #	1 #	13 #
Minimum:	0.0	0	0	0	0	0
Maximum:	44.6	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb	Unit CT2 Startup, Cold, TF	Unit CT2 Startup, Warm, TF	Unit CT2 Startup, Hot, TF	Unit CT2 Shutdown, TF	Unit CT2 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/06/2022 00:00	0.0	0	0	0	0	1
02/06/2022 01:00	0.0	0	0	0	0	1
02/06/2022 02:00	0.0	0	0	0	0	1
02/06/2022 03:00	0.0	0	0	0	0	1
02/06/2022 04:00	0.0	0	0	0	0	1
02/06/2022 05:00	0.0	0	0	0	0	1
02/06/2022 06:00	0.0	0	0	0	0	1
02/06/2022 07:00	0.0	0	0	0	0	1
02/06/2022 08:00	0.7	0	0	0	1	0
02/06/2022 09:00	0.0	0	0	0	0	0
02/06/2022 10:00	0.0	0	0	0	0	0
02/06/2022 11:00	0.0	0	0	0	0	0
02/06/2022 12:00	0.0	0	0	0	0	0
02/06/2022 13:00	0.0	0	0	0	0	0
02/06/2022 14:00	0.0	0	0	0	0	0
02/06/2022 15:00	0.0	0	0	0	0	0
02/06/2022 16:00	0.0	0	0	0	0	0
02/06/2022 17:00	0.0	0	0	0	0	0
02/06/2022 18:00	0.0	0	0	0	0	0
02/06/2022 19:00	0.0	0	0	0	0	0
02/06/2022 20:00	0.0	0	0	0	0	0
02/06/2022 21:00	0.0	0	0	0	0	0
02/06/2022 22:00	0.0	0	0	0	0	0
02/06/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.7 #	0 #	0 #	0 #	1 #	8 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.7	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb	Unit CT2 Startup, Cold, TF	Unit CT2 Startup, Warm, TF	Unit CT2 Startup, Hot, TF	Unit CT2 Shutdown, TF	Unit CT2 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/07/2022 00:00	0.0	0	0	0	0	0
02/07/2022 01:00	0.0	0	0	0	0	0
02/07/2022 02:00	0.0	0	0	0	0	0
02/07/2022 03:00	0.0	0	0	0	0	0
02/07/2022 04:00	0.0	0	0	0	0	0
02/07/2022 05:00	0.0	0	0	0	0	0
02/07/2022 06:00	0.0	0	0	0	0	0
02/07/2022 07:00	0.0	0	0	0	0	0
02/07/2022 08:00	0.0	0	0	0	0	0
02/07/2022 09:00	0.0	0	0	0	0	0
02/07/2022 10:00	0.0	0	0	0	0	0
02/07/2022 11:00	0.0	0	0	0	0	0
02/07/2022 12:00	0.0	0	0	0	0	0
02/07/2022 13:00	0.0	0	0	0	0	0
02/07/2022 14:00	0.0	0	0	0	0	0
02/07/2022 15:00	0.0	0	0	0	0	0
02/07/2022 16:00	47.6	0	1	0	0	0
02/07/2022 17:00	41.2	0	1	0	0	0
02/07/2022 18:00	0.0	0	0	0	0	1
02/07/2022 19:00	0.0	0	0	0	0	1
02/07/2022 20:00	0.0	0	0	0	0	1
02/07/2022 21:00	0.0	0	0	0	0	1
02/07/2022 22:00	0.0	0	0	0	0	1
02/07/2022 23:00	1.3	0	0	0	1	0
Average/Sum#:	90.1 #	0 #	2 #	0 #	1 #	5 #
Minimum:	0.0	0	0	0	0	0
Maximum:	47.6	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb	Unit CT2 Startup, Cold, TF	Unit CT2 Startup, Warm, TF	Unit CT2 Startup, Hot, TF	Unit CT2 Shutdown, TF	Unit CT2 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/08/2022 00:00	0.0	0	0	0	0	0
02/08/2022 01:00	0.0	0	0	0	0	0
02/08/2022 02:00	0.0	0	0	0	0	0
02/08/2022 03:00	0.0	0	0	0	0	0
02/08/2022 04:00	0.0	0	0	0	0	0
02/08/2022 05:00	11.9	0	0	1	0	0
02/08/2022 06:00	25.4	0	0	1	0	0
02/08/2022 07:00	0.0	0	0	0	0	1
02/08/2022 08:00	0.0	0	0	0	0	1
02/08/2022 09:00	0.0	0	0	0	0	1
02/08/2022 10:00	0.0	0	0	0	0	1
02/08/2022 11:00	0.0	0	0	0	0	1
02/08/2022 12:00	0.0	0	0	0	0	1
02/08/2022 13:00	0.0	0	0	0	0	1
02/08/2022 14:00	0.0	0	0	0	0	1
02/08/2022 15:00	0.0	0	0	0	0	1
02/08/2022 16:00	0.0	0	0	0	0	1
02/08/2022 17:00	0.0	0	0	0	0	1
02/08/2022 18:00	0.0	0	0	0	0	1
02/08/2022 19:00	0.0	0	0	0	0	1
02/08/2022 20:00	0.0	0	0	0	0	1
02/08/2022 21:00	0.0	0	0	0	0	1
02/08/2022 22:00	0.9	0	0	0	1	0
02/08/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	38.2 #	0 #	0 #	2 #	1 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	25.4	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb	Unit CT2 Startup, Cold, TF	Unit CT2 Startup, Warm, TF	Unit CT2 Startup, Hot, TF	Unit CT2 Shutdown, TF	Unit CT2 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/09/2022 00:00	0.0	0	0	0	0	0
02/09/2022 01:00	0.0	0	0	0	0	0
02/09/2022 02:00	0.0	0	0	0	0	0
02/09/2022 03:00	0.0	0	0	0	0	0
02/09/2022 04:00	0.0	0	0	0	0	0
02/09/2022 05:00	0.0	0	0	0	0	0
02/09/2022 06:00	0.0	0	0	0	0	0
02/09/2022 07:00	0.0	0	0	0	0	0
02/09/2022 08:00	0.0	0	0	0	0	0
02/09/2022 09:00	0.0	0	0	0	0	0
02/09/2022 10:00	0.0	0	0	0	0	0
02/09/2022 11:00	0.0	0	0	0	0	0
02/09/2022 12:00	0.0	0	0	0	0	0
02/09/2022 13:00	0.0	0	0	0	0	0
02/09/2022 14:00	0.0	0	0	0	0	0
02/09/2022 15:00	0.0	0	0	0	0	0
02/09/2022 16:00	75.6	0	1	0	0	0
02/09/2022 17:00	0.5	0	1	0	0	0
02/09/2022 18:00	0.0	0	0	0	0	1
02/09/2022 19:00	0.0	0	0	0	0	1
02/09/2022 20:00	0.0	0	0	0	0	1
02/09/2022 21:00	0.0	0	0	0	0	1
02/09/2022 22:00	0.0	0	0	0	0	1
02/09/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	76.1 #	0 #	2 #	0 #	0 #	6 #
Minimum:	0.0	0	0	0	0	0
Maximum:	75.6	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb	Unit CT2 Startup, Cold, TF	Unit CT2 Startup, Warm, TF	Unit CT2 Startup, Hot, TF	Unit CT2 Shutdown, TF	Unit CT2 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/10/2022 00:00	0.0	0	0	0	0	1
02/10/2022 01:00	0.0	0	0	0	0	1
02/10/2022 02:00	0.0	0	0	0	0	1
02/10/2022 03:00	0.0	0	0	0	0	1
02/10/2022 04:00	0.0	0	0	0	0	1
02/10/2022 05:00	0.0	0	0	0	0	1
02/10/2022 06:00	0.0	0	0	0	0	1
02/10/2022 07:00	0.0	0	0	0	0	1
02/10/2022 08:00	1.3	0	0	0	1	0
02/10/2022 09:00	0.0	0	0	0	0	0
02/10/2022 10:00	0.0	0	0	0	0	0
02/10/2022 11:00	0.0	0	0	0	0	0
02/10/2022 12:00	0.0	0	0	0	0	0
02/10/2022 13:00	0.0	0	0	0	0	0
02/10/2022 14:00	0.0	0	0	0	0	0
02/10/2022 15:00	0.3	0	0	1	0	0
02/10/2022 16:00	66.7	0	0	1	0	0
02/10/2022 17:00	0.0	0	0	0	0	1
02/10/2022 18:00	0.0	0	0	0	0	1
02/10/2022 19:00	0.0	0	0	0	0	1
02/10/2022 20:00	0.0	0	0	0	0	1
02/10/2022 21:00	0.0	0	0	0	0	1
02/10/2022 22:00	0.0	0	0	0	0	1
02/10/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	68.3 #	0 #	0 #	2 #	1 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	66.7	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb	Unit CT2 Startup, Cold, TF	Unit CT2 Startup, Warm, TF	Unit CT2 Startup, Hot, TF	Unit CT2 Shutdown, TF	Unit CT2 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/11/2022 00:00	0.0	0	0	0	0	1
02/11/2022 01:00	1.0	0	0	0	1	0
02/11/2022 02:00	0.0	0	0	0	0	0
02/11/2022 03:00	0.0	0	0	0	0	0
02/11/2022 04:00	0.0	0	0	0	0	0
02/11/2022 05:00	0.0	0	0	0	0	0
02/11/2022 06:00	0.0	0	0	0	0	0
02/11/2022 07:00	0.0	0	0	0	0	0
02/11/2022 08:00	0.0	0	0	0	0	0
02/11/2022 09:00	0.0	0	0	0	0	0
02/11/2022 10:00	0.0	0	0	0	0	0
02/11/2022 11:00	0.0	0	0	0	0	0
02/11/2022 12:00	0.0	0	0	0	0	0
02/11/2022 13:00	0.0	0	0	0	0	0
02/11/2022 14:00	0.0	0	0	0	0	0
02/11/2022 15:00	0.0	0	0	0	0	0
02/11/2022 16:00	0.0	0	0	0	0	0
02/11/2022 17:00	0.0	0	0	0	0	0
02/11/2022 18:00	0.0	0	0	0	0	0
02/11/2022 19:00	0.0	0	0	0	0	0
02/11/2022 20:00	0.0	0	0	0	0	0
02/11/2022 21:00	0.0	0	0	0	0	0
02/11/2022 22:00	0.0	0	0	0	0	0
02/11/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	1.0 #	0 #	0 #	0 #	1 #	1 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.0	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb	Unit CT2 Startup, Cold, TF	Unit CT2 Startup, Warm, TF	Unit CT2 Startup, Hot, TF	Unit CT2 Shutdown, TF	Unit CT2 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/12/2022 00:00	0.0	0	0	0	0	0
02/12/2022 01:00	0.0	0	0	0	0	0
02/12/2022 02:00	0.0	0	0	0	0	0
02/12/2022 03:00	0.0	0	0	0	0	0
02/12/2022 04:00	0.0	0	0	0	0	0
02/12/2022 05:00	0.0	0	0	0	0	0
02/12/2022 06:00	0.0	0	0	0	0	0
02/12/2022 07:00	0.0	0	0	0	0	0
02/12/2022 08:00	0.0	0	0	0	0	0
02/12/2022 09:00	0.0	0	0	0	0	0
02/12/2022 10:00	0.0	0	0	0	0	0
02/12/2022 11:00	0.0	0	0	0	0	0
02/12/2022 12:00	0.0	0	0	0	0	0
02/12/2022 13:00	0.0	0	0	0	0	0
02/12/2022 14:00	0.0	0	0	0	0	0
02/12/2022 15:00	0.0	0	0	0	0	0
02/12/2022 16:00	0.0	0	0	0	0	0
02/12/2022 17:00	0.0	0	0	0	0	0
02/12/2022 18:00	0.0	0	0	0	0	0
02/12/2022 19:00	0.0	0	0	0	0	0
02/12/2022 20:00	0.0	0	0	0	0	0
02/12/2022 21:00	0.0	0	0	0	0	0
02/12/2022 22:00	0.0	0	0	0	0	0
02/12/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb	Unit CT2 Startup, Cold, TF	Unit CT2 Startup, Warm, TF	Unit CT2 Startup, Hot, TF	Unit CT2 Shutdown, TF	Unit CT2 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/13/2022 00:00	0.0	0	0	0	0	0
02/13/2022 01:00	0.0	0	0	0	0	0
02/13/2022 02:00	0.0	0	0	0	0	0
02/13/2022 03:00	0.0	0	0	0	0	0
02/13/2022 04:00	0.0	0	0	0	0	0
02/13/2022 05:00	0.0	0	0	0	0	0
02/13/2022 06:00	0.0	0	0	0	0	0
02/13/2022 07:00	0.0	0	0	0	0	0
02/13/2022 08:00	0.0	0	0	0	0	0
02/13/2022 09:00	0.0	0	0	0	0	0
02/13/2022 10:00	0.0	0	0	0	0	0
02/13/2022 11:00	0.0	0	0	0	0	0
02/13/2022 12:00	0.0	0	0	0	0	0
02/13/2022 13:00	0.0	0	0	0	0	0
02/13/2022 14:00	0.0	0	0	0	0	0
02/13/2022 15:00	0.0	0	0	0	0	0
02/13/2022 16:00	0.0	0	0	0	0	0
02/13/2022 17:00	0.0	0	0	0	0	0
02/13/2022 18:00	0.0	0	0	0	0	0
02/13/2022 19:00	0.0	0	0	0	0	0
02/13/2022 20:00	0.0	0	0	0	0	0
02/13/2022 21:00	0.0	0	0	0	0	0
02/13/2022 22:00	0.0	0	0	0	0	0
02/13/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb	Unit CT2 Startup, Cold, TF	Unit CT2 Startup, Warm, TF	Unit CT2 Startup, Hot, TF	Unit CT2 Shutdown, TF	Unit CT2 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/14/2022 00:00	0.0	0	0	0	0	0
02/14/2022 01:00	0.0	0	0	0	0	0
02/14/2022 02:00	0.0	0	0	0	0	0
02/14/2022 03:00	0.0	0	0	0	0	0
02/14/2022 04:00	0.0	0	0	0	0	0
02/14/2022 05:00	0.0	0	0	0	0	0
02/14/2022 06:00	0.0	0	0	0	0	0
02/14/2022 07:00	0.0	0	0	0	0	0
02/14/2022 08:00	0.0	0	0	0	0	0
02/14/2022 09:00	0.0	0	0	0	0	0
02/14/2022 10:00	0.0	0	0	0	0	0
02/14/2022 11:00	0.0	0	0	0	0	0
02/14/2022 12:00	0.0	0	0	0	0	0
02/14/2022 13:00	0.0	0	0	0	0	0
02/14/2022 14:00	0.0	0	0	0	0	0
02/14/2022 15:00	0.0	0	0	0	0	0
02/14/2022 16:00	0.0	0	0	0	0	0
02/14/2022 17:00	0.0	0	0	0	0	0
02/14/2022 18:00	0.0	0	0	0	0	0
02/14/2022 19:00	0.0	0	0	0	0	0
02/14/2022 20:00	0.0	0	0	0	0	0
02/14/2022 21:00	0.0	0	0	0	0	0
02/14/2022 22:00	0.0	0	0	0	0	0
02/14/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb	Unit CT2 Startup, Cold, TF	Unit CT2 Startup, Warm, TF	Unit CT2 Startup, Hot, TF	Unit CT2 Shutdown, TF	Unit CT2 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/15/2022 00:00	0.0	0	0	0	0	0
02/15/2022 01:00	0.0	0	0	0	0	0
02/15/2022 02:00	0.0	0	0	0	0	0
02/15/2022 03:00	0.0	0	0	0	0	0
02/15/2022 04:00	0.0	0	0	0	0	0
02/15/2022 05:00	0.0	0	0	0	0	0
02/15/2022 06:00	0.0	0	0	0	0	0
02/15/2022 07:00	0.0	0	0	0	0	0
02/15/2022 08:00	0.0	0	0	0	0	0
02/15/2022 09:00	0.0	0	0	0	0	0
02/15/2022 10:00	0.0	0	0	0	0	0
02/15/2022 11:00	0.0	0	0	0	0	0
02/15/2022 12:00	0.0	0	0	0	0	0
02/15/2022 13:00	0.0	0	0	0	0	0
02/15/2022 14:00	0.0	0	0	0	0	0
02/15/2022 15:00	0.0	0	0	0	0	0
02/15/2022 16:00	0.0	0	0	0	0	0
02/15/2022 17:00	0.0	0	0	0	0	0
02/15/2022 18:00	0.0	0	0	0	0	0
02/15/2022 19:00	0.0	0	0	0	0	0
02/15/2022 20:00	0.0	0	0	0	0	0
02/15/2022 21:00	0.0	0	0	0	0	0
02/15/2022 22:00	0.0	0	0	0	0	0
02/15/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb	Unit CT2 Startup, Cold, TF	Unit CT2 Startup, Warm, TF	Unit CT2 Startup, Hot, TF	Unit CT2 Shutdown, TF	Unit CT2 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/16/2022 00:00	0.0	0	0	0	0	0
02/16/2022 01:00	0.0	0	0	0	0	0
02/16/2022 02:00	0.0	0	0	0	0	0
02/16/2022 03:00	0.0	0	0	0	0	0
02/16/2022 04:00	0.0	0	0	0	0	0
02/16/2022 05:00	0.0	0	0	0	0	0
02/16/2022 06:00	0.0	0	0	0	0	0
02/16/2022 07:00	0.0	0	0	0	0	0
02/16/2022 08:00	0.0	0	0	0	0	0
02/16/2022 09:00	0.0	0	0	0	0	0
02/16/2022 10:00	0.0	0	0	0	0	0
02/16/2022 11:00	0.0	0	0	0	0	0
02/16/2022 12:00	0.0	0	0	0	0	0
02/16/2022 13:00	0.0	0	0	0	0	0
02/16/2022 14:00	0.0	0	0	0	0	0
02/16/2022 15:00	0.0	0	0	0	0	0
02/16/2022 16:00	0.0	0	0	0	0	0
02/16/2022 17:00	0.0	0	0	0	0	0
02/16/2022 18:00	0.0	0	0	0	0	0
02/16/2022 19:00	0.0	0	0	0	0	0
02/16/2022 20:00	0.0	0	0	0	0	0
02/16/2022 21:00	0.0	0	0	0	0	0
02/16/2022 22:00	0.0	0	0	0	0	0
02/16/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb	Unit CT2 Startup, Cold, TF	Unit CT2 Startup, Warm, TF	Unit CT2 Startup, Hot, TF	Unit CT2 Shutdown, TF	Unit CT2 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/17/2022 00:00	0.0	0	0	0	0	0
02/17/2022 01:00	0.0	0	0	0	0	0
02/17/2022 02:00	0.0	0	0	0	0	0
02/17/2022 03:00	0.0	0	0	0	0	0
02/17/2022 04:00	0.0	0	0	0	0	0
02/17/2022 05:00	0.0	0	0	0	0	0
02/17/2022 06:00	0.0	0	0	0	0	0
02/17/2022 07:00	0.0	0	0	0	0	0
02/17/2022 08:00	0.0	0	0	0	0	0
02/17/2022 09:00	0.0	0	0	0	0	0
02/17/2022 10:00	0.0	0	0	0	0	0
02/17/2022 11:00	0.0	0	0	0	0	0
02/17/2022 12:00	0.0	0	0	0	0	0
02/17/2022 13:00	0.0	0	0	0	0	0
02/17/2022 14:00	0.0	0	0	0	0	0
02/17/2022 15:00	0.0	0	0	0	0	0
02/17/2022 16:00	0.0	0	0	0	0	0
02/17/2022 17:00	0.0	0	0	0	0	0
02/17/2022 18:00	0.0	0	0	0	0	0
02/17/2022 19:00	0.0	0	0	0	0	0
02/17/2022 20:00	0.0	0	0	0	0	0
02/17/2022 21:00	0.0	0	0	0	0	0
02/17/2022 22:00	0.0	0	0	0	0	0
02/17/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb	Unit CT2 Startup, Cold, TF	Unit CT2 Startup, Warm, TF	Unit CT2 Startup, Hot, TF	Unit CT2 Shutdown, TF	Unit CT2 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/18/2022 00:00	0.0	0	0	0	0	0
02/18/2022 01:00	0.0	0	0	0	0	0
02/18/2022 02:00	0.0	0	0	0	0	0
02/18/2022 03:00	0.0	0	0	0	0	0
02/18/2022 04:00	0.0	0	0	0	0	0
02/18/2022 05:00	0.0	0	0	0	0	0
02/18/2022 06:00	0.0	0	0	0	0	0
02/18/2022 07:00	0.0	0	0	0	0	0
02/18/2022 08:00	0.0	0	0	0	0	0
02/18/2022 09:00	0.0	0	0	0	0	0
02/18/2022 10:00	0.0	0	0	0	0	0
02/18/2022 11:00	0.0	0	0	0	0	0
02/18/2022 12:00	0.0	0	0	0	0	0
02/18/2022 13:00	0.0	0	0	0	0	0
02/18/2022 14:00	0.0	0	0	0	0	0
02/18/2022 15:00	79.5	1	0	0	0	0
02/18/2022 16:00	65.4	1	0	0	0	0
02/18/2022 17:00	0.0	0	0	0	0	1
02/18/2022 18:00	0.0	0	0	0	0	1
02/18/2022 19:00	0.0	0	0	0	0	1
02/18/2022 20:00	0.0	0	0	0	0	1
02/18/2022 21:00	0.0	0	0	0	0	1
02/18/2022 22:00	0.0	0	0	0	0	1
02/18/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	144.9 #	2 #	0 #	0 #	0 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	79.5	1	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb	Unit CT2 Startup, Cold, TF	Unit CT2 Startup, Warm, TF	Unit CT2 Startup, Hot, TF	Unit CT2 Shutdown, TF	Unit CT2 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/19/2022 00:00	1.3	0	0	0	1	0
02/19/2022 01:00	0.0	0	0	0	0	0
02/19/2022 02:00	0.0	0	0	0	0	0
02/19/2022 03:00	0.0	0	0	0	0	0
02/19/2022 04:00	0.0	0	0	0	0	0
02/19/2022 05:00	0.0	0	0	0	0	0
02/19/2022 06:00	0.0	0	0	0	0	0
02/19/2022 07:00	0.0	0	0	0	0	0
02/19/2022 08:00	0.0	0	0	0	0	0
02/19/2022 09:00	0.0	0	0	0	0	0
02/19/2022 10:00	0.0	0	0	0	0	0
02/19/2022 11:00	0.0	0	0	0	0	0
02/19/2022 12:00	0.0	0	0	0	0	0
02/19/2022 13:00	0.0	0	0	0	0	0
02/19/2022 14:00	0.0	0	0	0	0	0
02/19/2022 15:00	0.0	0	0	0	0	0
02/19/2022 16:00	0.0	0	0	0	0	0
02/19/2022 17:00	0.0	0	0	0	0	0
02/19/2022 18:00	0.0	0	0	0	0	0
02/19/2022 19:00	0.0	0	0	0	0	0
02/19/2022 20:00	0.0	0	0	0	0	0
02/19/2022 21:00	0.0	0	0	0	0	0
02/19/2022 22:00	0.0	0	0	0	0	0
02/19/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	1.3 #	0 #	0 #	0 #	1 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.3	0	0	0	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb	Unit CT2 Startup, Cold, TF	Unit CT2 Startup, Warm, TF	Unit CT2 Startup, Hot, TF	Unit CT2 Shutdown, TF	Unit CT2 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/20/2022 00:00	0.0	0	0	0	0	0
02/20/2022 01:00	0.0	0	0	0	0	0
02/20/2022 02:00	0.0	0	0	0	0	0
02/20/2022 03:00	0.0	0	0	0	0	0
02/20/2022 04:00	0.0	0	0	0	0	0
02/20/2022 05:00	0.0	0	0	0	0	0
02/20/2022 06:00	0.0	0	0	0	0	0
02/20/2022 07:00	0.0	0	0	0	0	0
02/20/2022 08:00	0.0	0	0	0	0	0
02/20/2022 09:00	0.0	0	0	0	0	0
02/20/2022 10:00	0.0	0	0	0	0	0
02/20/2022 11:00	0.0	0	0	0	0	0
02/20/2022 12:00	0.0	0	0	0	0	0
02/20/2022 13:00	0.0	0	0	0	0	0
02/20/2022 14:00	0.0	0	0	0	0	0
02/20/2022 15:00	0.0	0	0	0	0	0
02/20/2022 16:00	0.0	0	0	0	0	0
02/20/2022 17:00	0.0	0	0	0	0	0
02/20/2022 18:00	0.0	0	0	0	0	0
02/20/2022 19:00	0.0	0	0	0	0	0
02/20/2022 20:00	0.0	0	0	0	0	0
02/20/2022 21:00	0.0	0	0	0	0	0
02/20/2022 22:00	0.0	0	0	0	0	0
02/20/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb	Unit CT2 Startup, Cold, TF	Unit CT2 Startup, Warm, TF	Unit CT2 Startup, Hot, TF	Unit CT2 Shutdown, TF	Unit CT2 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/21/2022 00:00	0.0	0	0	0	0	0
02/21/2022 01:00	0.0	0	0	0	0	0
02/21/2022 02:00	0.0	0	0	0	0	0
02/21/2022 03:00	0.0	0	0	0	0	0
02/21/2022 04:00	0.0	0	0	0	0	0
02/21/2022 05:00	0.0	0	0	0	0	0
02/21/2022 06:00	0.0	0	0	0	0	0
02/21/2022 07:00	0.0	0	0	0	0	0
02/21/2022 08:00	0.0	0	0	0	0	0
02/21/2022 09:00	0.0	0	0	0	0	0
02/21/2022 10:00	0.0	0	0	0	0	0
02/21/2022 11:00	0.0	0	0	0	0	0
02/21/2022 12:00	0.0	0	0	0	0	0
02/21/2022 13:00	0.0	0	0	0	0	0
02/21/2022 14:00	0.0	0	0	0	0	0
02/21/2022 15:00	0.0	0	0	0	0	0
02/21/2022 16:00	0.0	0	0	0	0	0
02/21/2022 17:00	0.0	0	0	0	0	0
02/21/2022 18:00	0.0	0	0	0	0	0
02/21/2022 19:00	0.0	0	0	0	0	0
02/21/2022 20:00	0.0	0	0	0	0	0
02/21/2022 21:00	0.0	0	0	0	0	0
02/21/2022 22:00	0.0	0	0	0	0	0
02/21/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb	Unit CT2 Startup, Cold, TF	Unit CT2 Startup, Warm, TF	Unit CT2 Startup, Hot, TF	Unit CT2 Shutdown, TF	Unit CT2 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/22/2022 00:00	0.0	0	0	0	0	0
02/22/2022 01:00	0.0	0	0	0	0	0
02/22/2022 02:00	0.0	0	0	0	0	0
02/22/2022 03:00	0.0	0	0	0	0	0
02/22/2022 04:00	32.3	1	0	0	0	0
02/22/2022 05:00	65.5	1	0	0	0	0
02/22/2022 06:00	0.0	0	0	0	0	1
02/22/2022 07:00	0.0	0	0	0	0	1
02/22/2022 08:00	0.0	0	0	0	0	1
02/22/2022 09:00	0.0	0	0	0	0	1
02/22/2022 10:00	0.0	0	0	0	0	1
02/22/2022 11:00	0.0	0	0	0	0	1
02/22/2022 12:00	0.0	0	0	0	0	1
02/22/2022 13:00	0.0	0	0	0	0	1
02/22/2022 14:00	0.0	0	0	0	0	1
02/22/2022 15:00	0.0	0	0	0	0	1
02/22/2022 16:00	0.0	0	0	0	0	1
02/22/2022 17:00	0.0	0	0	0	0	1
02/22/2022 18:00	0.0	0	0	0	0	1
02/22/2022 19:00	0.0	0	0	0	0	1
02/22/2022 20:00	0.0	0	0	0	0	1
02/22/2022 21:00	0.0	0	0	0	0	1
02/22/2022 22:00	0.0	0	0	0	0	1
02/22/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	97.8 #	2 #	0 #	0 #	0 #	18 #
Minimum:	0.0	0	0	0	0	0
Maximum:	65.5	1	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb	Unit CT2 Startup, Cold, TF	Unit CT2 Startup, Warm, TF	Unit CT2 Startup, Hot, TF	Unit CT2 Shutdown, TF	Unit CT2 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/23/2022 00:00	0.0	0	0	0	0	1
02/23/2022 01:00	0.0	0	0	0	0	1
02/23/2022 02:00	0.0	0	0	0	0	1
02/23/2022 03:00	0.0	0	0	0	0	1
02/23/2022 04:00	0.0	0	0	0	0	1
02/23/2022 05:00	0.0	0	0	0	0	1
02/23/2022 06:00	0.0	0	0	0	0	1
02/23/2022 07:00	0.0	0	0	0	0	1
02/23/2022 08:00	0.0	0	0	0	0	1
02/23/2022 09:00	0.0	0	0	0	0	1
02/23/2022 10:00	0.0	0	0	0	0	1
02/23/2022 11:00	0.0	0	0	0	0	1
02/23/2022 12:00	0.0	0	0	0	0	1
02/23/2022 13:00	0.0	0	0	0	0	1
02/23/2022 14:00	0.0	0	0	0	0	1
02/23/2022 15:00	0.0	0	0	0	0	1
02/23/2022 16:00	0.0	0	0	0	0	1
02/23/2022 17:00	0.0	0	0	0	0	1
02/23/2022 18:00	0.0	0	0	0	0	1
02/23/2022 19:00	0.0	0	0	0	0	1
02/23/2022 20:00	0.0	0	0	0	0	1
02/23/2022 21:00	0.0	0	0	0	0	1
02/23/2022 22:00	0.0	0	0	0	0	1
02/23/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb	Unit CT2 Startup, Cold, TF	Unit CT2 Startup, Warm, TF	Unit CT2 Startup, Hot, TF	Unit CT2 Shutdown, TF	Unit CT2 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/24/2022 00:00	0.0	0	0	0	0	1
02/24/2022 01:00	0.0	0	0	0	0	1
02/24/2022 02:00	0.0	0	0	0	0	1
02/24/2022 03:00	0.0	0	0	0	0	1
02/24/2022 04:00	0.0	0	0	0	0	1
02/24/2022 05:00	0.0	0	0	0	0	1
02/24/2022 06:00	0.0	0	0	0	0	1
02/24/2022 07:00	0.0	0	0	0	0	1
02/24/2022 08:00	0.0	0	0	0	0	1
02/24/2022 09:00	0.0	0	0	0	0	1
02/24/2022 10:00	0.0	0	0	0	0	1
02/24/2022 11:00	0.0	0	0	0	0	1
02/24/2022 12:00	0.0	0	0	0	0	1
02/24/2022 13:00	0.0	0	0	0	0	1
02/24/2022 14:00	0.0	0	0	0	0	1
02/24/2022 15:00	0.0	0	0	0	0	1
02/24/2022 16:00	0.0	0	0	0	0	1
02/24/2022 17:00	0.0	0	0	0	0	1
02/24/2022 18:00	0.0	0	0	0	0	1
02/24/2022 19:00	0.0	0	0	0	0	1
02/24/2022 20:00	0.0	0	0	0	0	1
02/24/2022 21:00	0.0	0	0	0	0	1
02/24/2022 22:00	0.0	0	0	0	0	1
02/24/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb	Unit CT2 Startup, Cold, TF	Unit CT2 Startup, Warm, TF	Unit CT2 Startup, Hot, TF	Unit CT2 Shutdown, TF	Unit CT2 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/25/2022 00:00	0.0	0	0	0	0	1
02/25/2022 01:00	0.0	0	0	0	0	1
02/25/2022 02:00	0.0	0	0	0	0	1
02/25/2022 03:00	0.0	0	0	0	0	1
02/25/2022 04:00	0.0	0	0	0	0	1
02/25/2022 05:00	0.0	0	0	0	0	1
02/25/2022 06:00	0.0	0	0	0	0	1
02/25/2022 07:00	0.0	0	0	0	0	1
02/25/2022 08:00	0.0	0	0	0	0	1
02/25/2022 09:00	0.0	0	0	0	0	1
02/25/2022 10:00	0.0	0	0	0	0	1
02/25/2022 11:00	0.0	0	0	0	0	1
02/25/2022 12:00	0.0	0	0	0	0	1
02/25/2022 13:00	0.0	0	0	0	0	1
02/25/2022 14:00	0.0	0	0	0	0	1
02/25/2022 15:00	0.0	0	0	0	0	1
02/25/2022 16:00	0.0	0	0	0	0	1
02/25/2022 17:00	0.0	0	0	0	0	1
02/25/2022 18:00	0.0	0	0	0	0	1
02/25/2022 19:00	0.0	0	0	0	0	1
02/25/2022 20:00	0.0	0	0	0	0	1
02/25/2022 21:00	0.0	0	0	0	0	1
02/25/2022 22:00	0.0	0	0	0	0	1
02/25/2022 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb	Unit CT2 Startup, Cold, TF	Unit CT2 Startup, Warm, TF	Unit CT2 Startup, Hot, TF	Unit CT2 Shutdown, TF	Unit CT2 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/26/2022 00:00	0.0	0	0	0	0	1
02/26/2022 01:00	0.0	0	0	0	0	1
02/26/2022 02:00	0.0	0	0	0	0	1
02/26/2022 03:00	0.0	0	0	0	0	1
02/26/2022 04:00	0.0	0	0	0	0	1
02/26/2022 05:00	0.0	0	0	0	0	1
02/26/2022 06:00	0.0	0	0	0	0	1
02/26/2022 07:00	1.3	0	0	0	1	0
02/26/2022 08:00	0.0	0	0	0	0	0
02/26/2022 09:00	0.0	0	0	0	0	0
02/26/2022 10:00	0.0	0	0	0	0	0
02/26/2022 11:00	0.0	0	0	0	0	0
02/26/2022 12:00	0.0	0	0	0	0	0
02/26/2022 13:00	0.0	0	0	0	0	0
02/26/2022 14:00	0.0	0	0	0	0	0
02/26/2022 15:00	0.0	0	0	0	0	0
02/26/2022 16:00	0.0	0	0	0	0	0
02/26/2022 17:00	0.0	0	0	0	0	0
02/26/2022 18:00	0.0	0	0	0	0	0
02/26/2022 19:00	0.0	0	0	0	0	0
02/26/2022 20:00	0.0	0	0	0	0	0
02/26/2022 21:00	0.0	0	0	0	0	0
02/26/2022 22:00	0.0	0	0	0	0	0
02/26/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	1.3 #	0 #	0 #	0 #	1 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.3	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb	Unit CT2 Startup, Cold, TF	Unit CT2 Startup, Warm, TF	Unit CT2 Startup, Hot, TF	Unit CT2 Shutdown, TF	Unit CT2 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/27/2022 00:00	0.0	0	0	0	0	0
02/27/2022 01:00	0.0	0	0	0	0	0
02/27/2022 02:00	0.0	0	0	0	0	0
02/27/2022 03:00	0.0	0	0	0	0	0
02/27/2022 04:00	0.0	0	0	0	0	0
02/27/2022 05:00	0.0	0	0	0	0	0
02/27/2022 06:00	0.0	0	0	0	0	0
02/27/2022 07:00	0.0	0	0	0	0	0
02/27/2022 08:00	0.0	0	0	0	0	0
02/27/2022 09:00	0.0	0	0	0	0	0
02/27/2022 10:00	0.0	0	0	0	0	0
02/27/2022 11:00	0.0	0	0	0	0	0
02/27/2022 12:00	0.0	0	0	0	0	0
02/27/2022 13:00	0.0	0	0	0	0	0
02/27/2022 14:00	0.0	0	0	0	0	0
02/27/2022 15:00	0.0	0	0	0	0	0
02/27/2022 16:00	0.0	0	0	0	0	0
02/27/2022 17:00	0.0	0	0	0	0	0
02/27/2022 18:00	0.0	0	0	0	0	0
02/27/2022 19:00	0.0	0	0	0	0	0
02/27/2022 20:00	0.0	0	0	0	0	0
02/27/2022 21:00	0.0	0	0	0	0	0
02/27/2022 22:00	0.0	0	0	0	0	0
02/27/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb	Unit CT2 Startup, Cold, TF	Unit CT2 Startup, Warm, TF	Unit CT2 Startup, Hot, TF	Unit CT2 Shutdown, TF	Unit CT2 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/28/2022 00:00	0.0	0	0	0	0	0
02/28/2022 01:00	0.0	0	0	0	0	0
02/28/2022 02:00	0.0	0	0	0	0	0
02/28/2022 03:00	0.0	0	0	0	0	0
02/28/2022 04:00	0.0	0	0	0	0	0
02/28/2022 05:00	0.0	0	0	0	0	0
02/28/2022 06:00	0.0	0	0	0	0	0
02/28/2022 07:00	0.0	0	0	0	0	0
02/28/2022 08:00	0.0	0	0	0	0	0
02/28/2022 09:00	0.0	0	0	0	0	0
02/28/2022 10:00	0.0	0	0	0	0	0
02/28/2022 11:00	0.0	0	0	0	0	0
02/28/2022 12:00	0.0	0	0	0	0	0
02/28/2022 13:00	0.0	0	0	0	0	0
02/28/2022 14:00	0.0	0	0	0	0	0
02/28/2022 15:00	0.0	0	0	0	0	0
02/28/2022 16:00	0.0	0	0	0	0	0
02/28/2022 17:00	0.0	0	0	0	0	0
02/28/2022 18:00	0.0	0	0	0	0	0
02/28/2022 19:00	0.0	0	0	0	0	0
02/28/2022 20:00	0.0	0	0	0	0	0
02/28/2022 21:00	0.0	0	0	0	0	0
02/28/2022 22:00	0.0	0	0	0	0	0
02/28/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb	Unit CT2 Startup, Cold, TF	Unit CT2 Startup, Warm, TF	Unit CT2 Startup, Hot, TF	Unit CT2 Shutdown, TF	Unit CT2 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/01/2022 00:00	0.0	0	0	0	0	0
03/01/2022 01:00	0.0	0	0	0	0	0
03/01/2022 02:00	0.0	0	0	0	0	0
03/01/2022 03:00	0.0	0	0	0	0	0
03/01/2022 04:00	0.0	0	0	0	0	0
03/01/2022 05:00	0.0	0	0	0	0	0
03/01/2022 06:00	0.0	0	0	0	0	0
03/01/2022 07:00	0.0	0	0	0	0	0
03/01/2022 08:00	0.0	0	0	0	0	0
03/01/2022 09:00	0.0	0	0	0	0	0
03/01/2022 10:00	0.0	0	0	0	0	0
03/01/2022 11:00	0.0	0	0	0	0	0
03/01/2022 12:00	0.0	0	0	0	0	0
03/01/2022 13:00	0.0	0	0	0	0	0
03/01/2022 14:00	0.0	0	0	0	0	0
03/01/2022 15:00	0.0	0	0	0	0	0
03/01/2022 16:00	0.0	0	0	0	0	0
03/01/2022 17:00	0.0	0	0	0	0	0
03/01/2022 18:00	0.0	0	0	0	0	0
03/01/2022 19:00	0.0	0	0	0	0	0
03/01/2022 20:00	0.0	0	0	0	0	0
03/01/2022 21:00	0.0	0	0	0	0	0
03/01/2022 22:00	0.0	0	0	0	0	0
03/01/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb	Unit CT2 Startup, Cold, TF	Unit CT2 Startup, Warm, TF	Unit CT2 Startup, Hot, TF	Unit CT2 Shutdown, TF	Unit CT2 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/02/2022 00:00	0.0	0	0	0	0	0
03/02/2022 01:00	0.0	0	0	0	0	0
03/02/2022 02:00	0.0	0	0	0	0	0
03/02/2022 03:00	0.0	0	0	0	0	0
03/02/2022 04:00	0.0	0	0	0	0	0
03/02/2022 05:00	0.0	0	0	0	0	0
03/02/2022 06:00	0.0	0	0	0	0	0
03/02/2022 07:00	0.0	0	0	0	0	0
03/02/2022 08:00	0.0	0	0	0	0	0
03/02/2022 09:00	0.0	0	0	0	0	0
03/02/2022 10:00	0.0	0	0	0	0	0
03/02/2022 11:00	0.0	0	0	0	0	0
03/02/2022 12:00	0.0	0	0	0	0	0
03/02/2022 13:00	0.0	0	0	0	0	0
03/02/2022 14:00	0.0	0	0	0	0	0
03/02/2022 15:00	0.0	0	0	0	0	0
03/02/2022 16:00	0.0	0	0	0	0	0
03/02/2022 17:00	0.0	0	0	0	0	0
03/02/2022 18:00	0.0	0	0	0	0	0
03/02/2022 19:00	0.0	0	0	0	0	0
03/02/2022 20:00	0.0	0	0	0	0	0
03/02/2022 21:00	0.0	0	0	0	0	0
03/02/2022 22:00	0.0	0	0	0	0	0
03/02/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb	Unit CT2 Startup, Cold, TF	Unit CT2 Startup, Warm, TF	Unit CT2 Startup, Hot, TF	Unit CT2 Shutdown, TF	Unit CT2 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/03/2022 00:00	0.0	0	0	0	0	0
03/03/2022 01:00	0.0	0	0	0	0	0
03/03/2022 02:00	0.0	0	0	0	0	0
03/03/2022 03:00	0.0	0	0	0	0	0
03/03/2022 04:00	0.0	0	0	0	0	0
03/03/2022 05:00	0.0	0	0	0	0	0
03/03/2022 06:00	0.0	0	0	0	0	0
03/03/2022 07:00	0.0	0	0	0	0	0
03/03/2022 08:00	0.0	0	0	0	0	0
03/03/2022 09:00	0.0	0	0	0	0	0
03/03/2022 10:00	0.0	0	0	0	0	0
03/03/2022 11:00	0.0	0	0	0	0	0
03/03/2022 12:00	0.0	0	0	0	0	0
03/03/2022 13:00	0.0	0	0	0	0	0
03/03/2022 14:00	0.0	0	0	0	0	0
03/03/2022 15:00	0.0	0	0	0	0	0
03/03/2022 16:00	0.0	0	0	0	0	0
03/03/2022 17:00	0.0	0	0	0	0	0
03/03/2022 18:00	0.0	0	0	0	0	0
03/03/2022 19:00	0.0	0	0	0	0	0
03/03/2022 20:00	0.0	0	0	0	0	0
03/03/2022 21:00	0.0	0	0	0	0	0
03/03/2022 22:00	0.0	0	0	0	0	0
03/03/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb	Unit CT2 Startup, Cold, TF	Unit CT2 Startup, Warm, TF	Unit CT2 Startup, Hot, TF	Unit CT2 Shutdown, TF	Unit CT2 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/04/2022 00:00	0.0	0	0	0	0	0
03/04/2022 01:00	0.0	0	0	0	0	0
03/04/2022 02:00	0.0	0	0	0	0	0
03/04/2022 03:00	0.0	0	0	0	0	0
03/04/2022 04:00	0.0	0	0	0	0	0
03/04/2022 05:00	0.0	0	0	0	0	0
03/04/2022 06:00	0.0	0	0	0	0	0
03/04/2022 07:00	0.0	0	0	0	0	0
03/04/2022 08:00	0.0	0	0	0	0	0
03/04/2022 09:00	0.0	0	0	0	0	0
03/04/2022 10:00	0.0	0	0	0	0	0
03/04/2022 11:00	0.0	0	0	0	0	0
03/04/2022 12:00	0.0	0	0	0	0	0
03/04/2022 13:00	0.0	0	0	0	0	0
03/04/2022 14:00	0.0	0	0	0	0	0
03/04/2022 15:00	0.0	0	0	0	0	0
03/04/2022 16:00	0.0	0	0	0	0	0
03/04/2022 17:00	0.0	0	0	0	0	0
03/04/2022 18:00	0.0	0	0	0	0	0
03/04/2022 19:00	0.0	0	0	0	0	0
03/04/2022 20:00	0.0	0	0	0	0	0
03/04/2022 21:00	0.0	0	0	0	0	0
03/04/2022 22:00	0.0	0	0	0	0	0
03/04/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb	Unit CT2 Startup, Cold, TF	Unit CT2 Startup, Warm, TF	Unit CT2 Startup, Hot, TF	Unit CT2 Shutdown, TF	Unit CT2 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/05/2022 00:00	0.0	0	0	0	0	0
03/05/2022 01:00	0.0	0	0	0	0	0
03/05/2022 02:00	0.0	0	0	0	0	0
03/05/2022 03:00	0.0	0	0	0	0	0
03/05/2022 04:00	0.0	0	0	0	0	0
03/05/2022 05:00	0.0	0	0	0	0	0
03/05/2022 06:00	0.0	0	0	0	0	0
03/05/2022 07:00	0.0	0	0	0	0	0
03/05/2022 08:00	0.0	0	0	0	0	0
03/05/2022 09:00	0.0	0	0	0	0	0
03/05/2022 10:00	0.0	0	0	0	0	0
03/05/2022 11:00	0.0	0	0	0	0	0
03/05/2022 12:00	0.0	0	0	0	0	0
03/05/2022 13:00	0.0	0	0	0	0	0
03/05/2022 14:00	0.0	0	0	0	0	0
03/05/2022 15:00	0.0	0	0	0	0	0
03/05/2022 16:00	0.0	0	0	0	0	0
03/05/2022 17:00	0.0	0	0	0	0	0
03/05/2022 18:00	0.0	0	0	0	0	0
03/05/2022 19:00	0.0	0	0	0	0	0
03/05/2022 20:00	0.0	0	0	0	0	0
03/05/2022 21:00	0.0	0	0	0	0	0
03/05/2022 22:00	0.0	0	0	0	0	0
03/05/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb	Unit CT2 Startup, Cold, TF	Unit CT2 Startup, Warm, TF	Unit CT2 Startup, Hot, TF	Unit CT2 Shutdown, TF	Unit CT2 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/06/2022 00:00	0.0	0	0	0	0	0
03/06/2022 01:00	0.0	0	0	0	0	0
03/06/2022 02:00	0.0	0	0	0	0	0
03/06/2022 03:00	0.0	0	0	0	0	0
03/06/2022 04:00	0.0	0	0	0	0	0
03/06/2022 05:00	0.0	0	0	0	0	0
03/06/2022 06:00	0.0	0	0	0	0	0
03/06/2022 07:00	0.0	0	0	0	0	0
03/06/2022 08:00	0.0	0	0	0	0	0
03/06/2022 09:00	0.0	0	0	0	0	0
03/06/2022 10:00	0.0	0	0	0	0	0
03/06/2022 11:00	0.0	0	0	0	0	0
03/06/2022 12:00	0.0	0	0	0	0	0
03/06/2022 13:00	0.0	0	0	0	0	0
03/06/2022 14:00	0.0	0	0	0	0	0
03/06/2022 15:00	0.0	0	0	0	0	0
03/06/2022 16:00	0.0	0	0	0	0	0
03/06/2022 17:00	0.0	0	0	0	0	0
03/06/2022 18:00	0.0	0	0	0	0	0
03/06/2022 19:00	0.0	0	0	0	0	0
03/06/2022 20:00	0.0	0	0	0	0	0
03/06/2022 21:00	0.0	0	0	0	0	0
03/06/2022 22:00	0.0	0	0	0	0	0
03/06/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb	Unit CT2 Startup, Cold, TF	Unit CT2 Startup, Warm, TF	Unit CT2 Startup, Hot, TF	Unit CT2 Shutdown, TF	Unit CT2 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/07/2022 00:00	0.0	0	0	0	0	0
03/07/2022 01:00	0.0	0	0	0	0	0
03/07/2022 02:00	0.0	0	0	0	0	0
03/07/2022 03:00	0.0	0	0	0	0	0
03/07/2022 04:00	0.0	0	0	0	0	0
03/07/2022 05:00	0.0	0	0	0	0	0
03/07/2022 06:00	0.0	0	0	0	0	0
03/07/2022 07:00	0.0	0	0	0	0	0
03/07/2022 08:00	0.0	0	0	0	0	0
03/07/2022 09:00	0.0	0	0	0	0	0
03/07/2022 10:00	0.0	0	0	0	0	0
03/07/2022 11:00	0.0	0	0	0	0	0
03/07/2022 12:00	0.0	0	0	0	0	0
03/07/2022 13:00	0.0	0	0	0	0	0
03/07/2022 14:00	0.0	0	0	0	0	0
03/07/2022 15:00	0.0	0	0	0	0	0
03/07/2022 16:00	0.0	0	0	0	0	0
03/07/2022 17:00	0.0	0	0	0	0	0
03/07/2022 18:00	0.0	0	0	0	0	0
03/07/2022 19:00	0.0	0	0	0	0	0
03/07/2022 20:00	0.0	0	0	0	0	0
03/07/2022 21:00	0.0	0	0	0	0	0
03/07/2022 22:00	0.0	0	0	0	0	0
03/07/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb	Unit CT2 Startup, Cold, TF	Unit CT2 Startup, Warm, TF	Unit CT2 Startup, Hot, TF	Unit CT2 Shutdown, TF	Unit CT2 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/08/2022 00:00	0.0	0	0	0	0	0
03/08/2022 01:00	0.0	0	0	0	0	0
03/08/2022 02:00	0.0	0	0	0	0	0
03/08/2022 03:00	0.0	0	0	0	0	0
03/08/2022 04:00	0.0	0	0	0	0	0
03/08/2022 05:00	0.0	0	0	0	0	0
03/08/2022 06:00	0.0	0	0	0	0	0
03/08/2022 07:00	0.0	0	0	0	0	0
03/08/2022 08:00	0.0	0	0	0	0	0
03/08/2022 09:00	0.0	0	0	0	0	0
03/08/2022 10:00	0.0	0	0	0	0	0
03/08/2022 11:00	0.0	0	0	0	0	0
03/08/2022 12:00	0.0	0	0	0	0	0
03/08/2022 13:00	0.0	0	0	0	0	0
03/08/2022 14:00	0.0	0	0	0	0	0
03/08/2022 15:00	0.0	0	0	0	0	0
03/08/2022 16:00	0.0	0	0	0	0	0
03/08/2022 17:00	0.0	0	0	0	0	0
03/08/2022 18:00	0.0	0	0	0	0	0
03/08/2022 19:00	0.0	0	0	0	0	0
03/08/2022 20:00	0.0	0	0	0	0	0
03/08/2022 21:00	0.0	0	0	0	0	0
03/08/2022 22:00	0.0	0	0	0	0	0
03/08/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb	Unit CT2 Startup, Cold, TF	Unit CT2 Startup, Warm, TF	Unit CT2 Startup, Hot, TF	Unit CT2 Shutdown, TF	Unit CT2 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/09/2022 00:00	0.0	0	0	0	0	0
03/09/2022 01:00	0.0	0	0	0	0	0
03/09/2022 02:00	0.0	0	0	0	0	0
03/09/2022 03:00	0.0	0	0	0	0	0
03/09/2022 04:00	0.0	0	0	0	0	0
03/09/2022 05:00	0.0	0	0	0	0	0
03/09/2022 06:00	0.0	0	0	0	0	0
03/09/2022 07:00	0.0	0	0	0	0	0
03/09/2022 08:00	0.0	0	0	0	0	0
03/09/2022 09:00	0.0	0	0	0	0	0
03/09/2022 10:00	0.0	0	0	0	0	0
03/09/2022 11:00	0.0	0	0	0	0	0
03/09/2022 12:00	0.0	0	0	0	0	0
03/09/2022 13:00	0.0	0	0	0	0	0
03/09/2022 14:00	0.0	0	0	0	0	0
03/09/2022 15:00	0.0	0	0	0	0	0
03/09/2022 16:00	0.0	0	0	0	0	0
03/09/2022 17:00	0.0	0	0	0	0	0
03/09/2022 18:00	0.0	0	0	0	0	0
03/09/2022 19:00	0.0	0	0	0	0	0
03/09/2022 20:00	0.0	0	0	0	0	0
03/09/2022 21:00	0.0	0	0	0	0	0
03/09/2022 22:00	0.0	0	0	0	0	0
03/09/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb	Unit CT2 Startup, Cold, TF	Unit CT2 Startup, Warm, TF	Unit CT2 Startup, Hot, TF	Unit CT2 Shutdown, TF	Unit CT2 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/10/2022 00:00	0.0	0	0	0	0	0
03/10/2022 01:00	0.0	0	0	0	0	0
03/10/2022 02:00	0.0	0	0	0	0	0
03/10/2022 03:00	0.0	0	0	0	0	0
03/10/2022 04:00	0.0	0	0	0	0	0
03/10/2022 05:00	0.0	0	0	0	0	0
03/10/2022 06:00	0.0	0	0	0	0	0
03/10/2022 07:00	0.0	0	0	0	0	0
03/10/2022 08:00	0.0	0	0	0	0	0
03/10/2022 09:00	0.0	0	0	0	0	0
03/10/2022 10:00	0.0	0	0	0	0	0
03/10/2022 11:00	0.0	0	0	0	0	0
03/10/2022 12:00	0.0	0	0	0	0	0
03/10/2022 13:00	0.0	0	0	0	0	0
03/10/2022 14:00	0.0	0	0	0	0	0
03/10/2022 15:00	0.0	0	0	0	0	0
03/10/2022 16:00	0.0	0	0	0	0	0
03/10/2022 17:00	0.0	0	0	0	0	0
03/10/2022 18:00	0.0	0	0	0	0	0
03/10/2022 19:00	0.0	0	0	0	0	0
03/10/2022 20:00	0.0	0	0	0	0	0
03/10/2022 21:00	0.0	0	0	0	0	0
03/10/2022 22:00	0.0	0	0	0	0	0
03/10/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb	Unit CT2 Startup, Cold, TF	Unit CT2 Startup, Warm, TF	Unit CT2 Startup, Hot, TF	Unit CT2 Shutdown, TF	Unit CT2 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/11/2022 00:00	0.0	0	0	0	0	0
03/11/2022 01:00	0.0	0	0	0	0	0
03/11/2022 02:00	0.0	0	0	0	0	0
03/11/2022 03:00	0.0	0	0	0	0	0
03/11/2022 04:00	0.0	0	0	0	0	0
03/11/2022 05:00	0.0	0	0	0	0	0
03/11/2022 06:00	0.0	0	0	0	0	0
03/11/2022 07:00	0.0	0	0	0	0	0
03/11/2022 08:00	0.0	0	0	0	0	0
03/11/2022 09:00	0.0	0	0	0	0	0
03/11/2022 10:00	0.0	0	0	0	0	0
03/11/2022 11:00	0.0	0	0	0	0	0
03/11/2022 12:00	0.0	0	0	0	0	0
03/11/2022 13:00	0.0	0	0	0	0	0
03/11/2022 14:00	0.0	0	0	0	0	0
03/11/2022 15:00	0.0	0	0	0	0	0
03/11/2022 16:00	0.0	0	0	0	0	0
03/11/2022 17:00	0.0	0	0	0	0	0
03/11/2022 18:00	0.0	0	0	0	0	0
03/11/2022 19:00	0.0	0	0	0	0	0
03/11/2022 20:00	0.0	0	0	0	0	0
03/11/2022 21:00	0.0	0	0	0	0	0
03/11/2022 22:00	0.0	0	0	0	0	0
03/11/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb	Unit CT2 Startup, Cold, TF	Unit CT2 Startup, Warm, TF	Unit CT2 Startup, Hot, TF	Unit CT2 Shutdown, TF	Unit CT2 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/12/2022 00:00	0.0	0	0	0	0	0
03/12/2022 01:00	0.0	0	0	0	0	0
03/12/2022 02:00	0.0	0	0	0	0	0
03/12/2022 03:00	0.0	0	0	0	0	0
03/12/2022 04:00	0.0	0	0	0	0	0
03/12/2022 05:00	0.0	0	0	0	0	0
03/12/2022 06:00	0.0	0	0	0	0	0
03/12/2022 07:00	0.0	0	0	0	0	0
03/12/2022 08:00	0.0	0	0	0	0	0
03/12/2022 09:00	0.0	0	0	0	0	0
03/12/2022 10:00	0.0	0	0	0	0	0
03/12/2022 11:00	0.0	0	0	0	0	0
03/12/2022 12:00	0.0	0	0	0	0	0
03/12/2022 13:00	0.0	0	0	0	0	0
03/12/2022 14:00	0.0	0	0	0	0	0
03/12/2022 15:00	0.0	0	0	0	0	0
03/12/2022 16:00	0.0	0	0	0	0	0
03/12/2022 17:00	0.0	0	0	0	0	0
03/12/2022 18:00	0.0	0	0	0	0	0
03/12/2022 19:00	0.0	0	0	0	0	0
03/12/2022 20:00	0.0	0	0	0	0	0
03/12/2022 21:00	0.0	0	0	0	0	0
03/12/2022 22:00	0.0	0	0	0	0	0
03/12/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb	Unit CT2 Startup, Cold, TF	Unit CT2 Startup, Warm, TF	Unit CT2 Startup, Hot, TF	Unit CT2 Shutdown, TF	Unit CT2 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/13/2022 00:00	0.0	0	0	0	0	0
03/13/2022 01:00	0.0	0	0	0	0	0
03/13/2022 02:00	0.0	0	0	0	0	0
03/13/2022 03:00	0.0	0	0	0	0	0
03/13/2022 04:00	0.0	0	0	0	0	0
03/13/2022 05:00	0.0	0	0	0	0	0
03/13/2022 06:00	0.0	0	0	0	0	0
03/13/2022 07:00	0.0	0	0	0	0	0
03/13/2022 08:00	0.0	0	0	0	0	0
03/13/2022 09:00	0.0	0	0	0	0	0
03/13/2022 10:00	0.0	0	0	0	0	0
03/13/2022 11:00	0.0	0	0	0	0	0
03/13/2022 12:00	0.0	0	0	0	0	0
03/13/2022 13:00	0.0	0	0	0	0	0
03/13/2022 14:00	0.0	0	0	0	0	0
03/13/2022 15:00	0.0	0	0	0	0	0
03/13/2022 16:00	0.0	0	0	0	0	0
03/13/2022 17:00	0.0	0	0	0	0	0
03/13/2022 18:00	0.0	0	0	0	0	0
03/13/2022 19:00	0.0	0	0	0	0	0
03/13/2022 20:00	0.0	0	0	0	0	0
03/13/2022 21:00	0.0	0	0	0	0	0
03/13/2022 22:00	0.0	0	0	0	0	0
03/13/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb	Unit CT2 Startup, Cold, TF	Unit CT2 Startup, Warm, TF	Unit CT2 Startup, Hot, TF	Unit CT2 Shutdown, TF	Unit CT2 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/14/2022 00:00	0.0	0	0	0	0	0
03/14/2022 01:00	0.0	0	0	0	0	0
03/14/2022 02:00	0.0	0	0	0	0	0
03/14/2022 03:00	0.0	0	0	0	0	0
03/14/2022 04:00	0.0	0	0	0	0	0
03/14/2022 05:00	0.0	0	0	0	0	0
03/14/2022 06:00	0.0	0	0	0	0	0
03/14/2022 07:00	0.0	0	0	0	0	0
03/14/2022 08:00	0.0	0	0	0	0	0
03/14/2022 09:00	0.0	0	0	0	0	0
03/14/2022 10:00	0.0	0	0	0	0	0
03/14/2022 11:00	0.0	0	0	0	0	0
03/14/2022 12:00	0.0	0	0	0	0	0
03/14/2022 13:00	0.0	0	0	0	0	0
03/14/2022 14:00	0.0	0	0	0	0	0
03/14/2022 15:00	0.0	0	0	0	0	0
03/14/2022 16:00	0.0	0	0	0	0	0
03/14/2022 17:00	0.0	0	0	0	0	0
03/14/2022 18:00	0.0	0	0	0	0	0
03/14/2022 19:00	0.0	0	0	0	0	0
03/14/2022 20:00	0.0	0	0	0	0	0
03/14/2022 21:00	0.0	0	0	0	0	0
03/14/2022 22:00	0.0	0	0	0	0	0
03/14/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb	Unit CT2 Startup, Cold, TF	Unit CT2 Startup, Warm, TF	Unit CT2 Startup, Hot, TF	Unit CT2 Shutdown, TF	Unit CT2 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/15/2022 00:00	0.0	0	0	0	0	0
03/15/2022 01:00	0.0	0	0	0	0	0
03/15/2022 02:00	0.0	0	0	0	0	0
03/15/2022 03:00	0.0	0	0	0	0	0
03/15/2022 04:00	0.0	0	0	0	0	0
03/15/2022 05:00	0.0	0	0	0	0	0
03/15/2022 06:00	0.0	0	0	0	0	0
03/15/2022 07:00	0.0	0	0	0	0	0
03/15/2022 08:00	0.0	0	0	0	0	0
03/15/2022 09:00	0.0	0	0	0	0	0
03/15/2022 10:00	0.0	0	0	0	0	0
03/15/2022 11:00	0.0	0	0	0	0	0
03/15/2022 12:00	0.0	0	0	0	0	0
03/15/2022 13:00	0.0	0	0	0	0	0
03/15/2022 14:00	0.0	0	0	0	0	0
03/15/2022 15:00	0.0	0	0	0	0	0
03/15/2022 16:00	0.0	0	0	0	0	0
03/15/2022 17:00	0.0	0	0	0	0	0
03/15/2022 18:00	0.0	0	0	0	0	0
03/15/2022 19:00	0.0	0	0	0	0	0
03/15/2022 20:00	0.0	0	0	0	0	0
03/15/2022 21:00	0.0	0	0	0	0	0
03/15/2022 22:00	0.0	0	0	0	0	0
03/15/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb	Unit CT2 Startup, Cold, TF	Unit CT2 Startup, Warm, TF	Unit CT2 Startup, Hot, TF	Unit CT2 Shutdown, TF	Unit CT2 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/16/2022 00:00	0.0	0	0	0	0	0
03/16/2022 01:00	0.0	0	0	0	0	0
03/16/2022 02:00	0.0	0	0	0	0	0
03/16/2022 03:00	0.0	0	0	0	0	0
03/16/2022 04:00	0.0	0	0	0	0	0
03/16/2022 05:00	0.0	0	0	0	0	0
03/16/2022 06:00	0.0	0	0	0	0	0
03/16/2022 07:00	0.0	0	0	0	0	0
03/16/2022 08:00	0.0	0	0	0	0	0
03/16/2022 09:00	0.0	0	0	0	0	0
03/16/2022 10:00	0.0	0	0	0	0	0
03/16/2022 11:00	0.0	0	0	0	0	0
03/16/2022 12:00	0.0	0	0	0	0	0
03/16/2022 13:00	0.0	0	0	0	0	0
03/16/2022 14:00	0.0	0	0	0	0	0
03/16/2022 15:00	0.0	0	0	0	0	0
03/16/2022 16:00	0.0	0	0	0	0	0
03/16/2022 17:00	0.0	0	0	0	0	0
03/16/2022 18:00	0.0	0	0	0	0	0
03/16/2022 19:00	0.0	0	0	0	0	0
03/16/2022 20:00	0.0	0	0	0	0	0
03/16/2022 21:00	0.0	0	0	0	0	0
03/16/2022 22:00	0.0	0	0	0	0	0
03/16/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb	Unit CT2 Startup, Cold, TF	Unit CT2 Startup, Warm, TF	Unit CT2 Startup, Hot, TF	Unit CT2 Shutdown, TF	Unit CT2 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/17/2022 00:00	0.0	0	0	0	0	0
03/17/2022 01:00	0.0	0	0	0	0	0
03/17/2022 02:00	0.0	0	0	0	0	0
03/17/2022 03:00	0.0	0	0	0	0	0
03/17/2022 04:00	0.0	0	0	0	0	0
03/17/2022 05:00	0.0	0	0	0	0	0
03/17/2022 06:00	0.0	0	0	0	0	0
03/17/2022 07:00	0.0	0	0	0	0	0
03/17/2022 08:00	0.0	0	0	0	0	0
03/17/2022 09:00	0.0	0	0	0	0	0
03/17/2022 10:00	0.0	0	0	0	0	0
03/17/2022 11:00	0.0	0	0	0	0	0
03/17/2022 12:00	0.0	0	0	0	0	0
03/17/2022 13:00	0.0	0	0	0	0	0
03/17/2022 14:00	0.0	0	0	0	0	0
03/17/2022 15:00	0.0	0	0	0	0	0
03/17/2022 16:00	0.0	0	0	0	0	0
03/17/2022 17:00	0.0	0	0	0	0	0
03/17/2022 18:00	0.0	0	0	0	0	0
03/17/2022 19:00	0.0	0	0	0	0	0
03/17/2022 20:00	0.0	0	0	0	0	0
03/17/2022 21:00	0.0	0	0	0	0	0
03/17/2022 22:00	0.0	0	0	0	0	0
03/17/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb	Unit CT2 Startup, Cold, TF	Unit CT2 Startup, Warm, TF	Unit CT2 Startup, Hot, TF	Unit CT2 Shutdown, TF	Unit CT2 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/18/2022 00:00	0.0	0	0	0	0	0
03/18/2022 01:00	0.0	0	0	0	0	0
03/18/2022 02:00	0.0	0	0	0	0	0
03/18/2022 03:00	0.0	0	0	0	0	0
03/18/2022 04:00	0.0	0	0	0	0	0
03/18/2022 05:00	0.0	0	0	0	0	0
03/18/2022 06:00	0.0	0	0	0	0	0
03/18/2022 07:00	0.0	0	0	0	0	0
03/18/2022 08:00	0.0	0	0	0	0	0
03/18/2022 09:00	0.0	0	0	0	0	0
03/18/2022 10:00	0.0	0	0	0	0	0
03/18/2022 11:00	0.0	0	0	0	0	0
03/18/2022 12:00	0.0	0	0	0	0	0
03/18/2022 13:00	0.0	0	0	0	0	0
03/18/2022 14:00	0.0	0	0	0	0	0
03/18/2022 15:00	0.0	0	0	0	0	0
03/18/2022 16:00	0.0	0	0	0	0	0
03/18/2022 17:00	0.0	0	0	0	0	0
03/18/2022 18:00	0.0	0	0	0	0	0
03/18/2022 19:00	0.0	0	0	0	0	0
03/18/2022 20:00	0.0	0	0	0	0	0
03/18/2022 21:00	0.0	0	0	0	0	0
03/18/2022 22:00	0.0	0	0	0	0	0
03/18/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb	Unit CT2 Startup, Cold, TF	Unit CT2 Startup, Warm, TF	Unit CT2 Startup, Hot, TF	Unit CT2 Shutdown, TF	Unit CT2 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/19/2022 00:00	0.0	0	0	0	0	0
03/19/2022 01:00	0.0	0	0	0	0	0
03/19/2022 02:00	0.0	0	0	0	0	0
03/19/2022 03:00	0.0	0	0	0	0	0
03/19/2022 04:00	0.0	0	0	0	0	0
03/19/2022 05:00	0.0	0	0	0	0	0
03/19/2022 06:00	0.0	0	0	0	0	0
03/19/2022 07:00	0.0	0	0	0	0	0
03/19/2022 08:00	0.0	0	0	0	0	0
03/19/2022 09:00	0.0	0	0	0	0	0
03/19/2022 10:00	0.0	0	0	0	0	0
03/19/2022 11:00	0.0	0	0	0	0	0
03/19/2022 12:00	0.0	0	0	0	0	0
03/19/2022 13:00	0.0	0	0	0	0	0
03/19/2022 14:00	0.0	0	0	0	0	0
03/19/2022 15:00	0.0	0	0	0	0	0
03/19/2022 16:00	0.0	0	0	0	0	0
03/19/2022 17:00	0.0	0	0	0	0	0
03/19/2022 18:00	0.0	0	0	0	0	0
03/19/2022 19:00	0.0	0	0	0	0	0
03/19/2022 20:00	0.0	0	0	0	0	0
03/19/2022 21:00	0.0	0	0	0	0	0
03/19/2022 22:00	0.0	0	0	0	0	0
03/19/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb	Unit CT2 Startup, Cold, TF	Unit CT2 Startup, Warm, TF	Unit CT2 Startup, Hot, TF	Unit CT2 Shutdown, TF	Unit CT2 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/20/2022 00:00	0.0	0	0	0	0	0
03/20/2022 01:00	0.0	0	0	0	0	0
03/20/2022 02:00	0.0	0	0	0	0	0
03/20/2022 03:00	0.0	0	0	0	0	0
03/20/2022 04:00	0.0	0	0	0	0	0
03/20/2022 05:00	0.0	0	0	0	0	0
03/20/2022 06:00	0.0	0	0	0	0	0
03/20/2022 07:00	0.0	0	0	0	0	0
03/20/2022 08:00	0.0	0	0	0	0	0
03/20/2022 09:00	0.0	0	0	0	0	0
03/20/2022 10:00	0.0	0	0	0	0	0
03/20/2022 11:00	0.0	0	0	0	0	0
03/20/2022 12:00	0.0	0	0	0	0	0
03/20/2022 13:00	0.0	0	0	0	0	0
03/20/2022 14:00	0.0	0	0	0	0	0
03/20/2022 15:00	0.0	0	0	0	0	0
03/20/2022 16:00	0.0	0	0	0	0	0
03/20/2022 17:00	0.0	0	0	0	0	0
03/20/2022 18:00	0.0	0	0	0	0	0
03/20/2022 19:00	0.0	0	0	0	0	0
03/20/2022 20:00	0.0	0	0	0	0	0
03/20/2022 21:00	0.0	0	0	0	0	0
03/20/2022 22:00	0.0	0	0	0	0	0
03/20/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb	Unit CT2 Startup, Cold, TF	Unit CT2 Startup, Warm, TF	Unit CT2 Startup, Hot, TF	Unit CT2 Shutdown, TF	Unit CT2 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/21/2022 00:00	0.0	0	0	0	0	0
03/21/2022 01:00	0.0	0	0	0	0	0
03/21/2022 02:00	0.0	0	0	0	0	0
03/21/2022 03:00	0.0	0	0	0	0	0
03/21/2022 04:00	0.0	0	0	0	0	0
03/21/2022 05:00	0.0	0	0	0	0	0
03/21/2022 06:00	0.0	0	0	0	0	0
03/21/2022 07:00	0.0	0	0	0	0	0
03/21/2022 08:00	0.0	0	0	0	0	0
03/21/2022 09:00	0.0	0	0	0	0	0
03/21/2022 10:00	0.0	0	0	0	0	0
03/21/2022 11:00	0.0	0	0	0	0	0
03/21/2022 12:00	0.0	0	0	0	0	0
03/21/2022 13:00	0.0	0	0	0	0	0
03/21/2022 14:00	0.0	0	0	0	0	0
03/21/2022 15:00	0.0	0	0	0	0	0
03/21/2022 16:00	0.0	0	0	0	0	0
03/21/2022 17:00	0.0	0	0	0	0	0
03/21/2022 18:00	0.0	0	0	0	0	0
03/21/2022 19:00	0.0	0	0	0	0	0
03/21/2022 20:00	0.0	0	0	0	0	0
03/21/2022 21:00	0.0	0	0	0	0	0
03/21/2022 22:00	0.0	0	0	0	0	0
03/21/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb	Unit CT2 Startup, Cold, TF	Unit CT2 Startup, Warm, TF	Unit CT2 Startup, Hot, TF	Unit CT2 Shutdown, TF	Unit CT2 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/22/2022 00:00	0.0	0	0	0	0	0
03/22/2022 01:00	0.0	0	0	0	0	0
03/22/2022 02:00	0.0	0	0	0	0	0
03/22/2022 03:00	0.0	0	0	0	0	0
03/22/2022 04:00	0.0	0	0	0	0	0
03/22/2022 05:00	0.0	0	0	0	0	0
03/22/2022 06:00	0.0	0	0	0	0	0
03/22/2022 07:00	0.0	0	0	0	0	0
03/22/2022 08:00	0.0	0	0	0	0	0
03/22/2022 09:00	0.0	0	0	0	0	0
03/22/2022 10:00	0.0	0	0	0	0	0
03/22/2022 11:00	0.0	0	0	0	0	0
03/22/2022 12:00	0.0	0	0	0	0	0
03/22/2022 13:00	0.0	0	0	0	0	0
03/22/2022 14:00	0.0	0	0	0	0	0
03/22/2022 15:00	0.0	0	0	0	0	0
03/22/2022 16:00	0.0	0	0	0	0	0
03/22/2022 17:00	0.0	0	0	0	0	0
03/22/2022 18:00	0.0	0	0	0	0	0
03/22/2022 19:00	0.0	0	0	0	0	0
03/22/2022 20:00	0.0	0	0	0	0	0
03/22/2022 21:00	0.0	0	0	0	0	0
03/22/2022 22:00	0.0	0	0	0	0	0
03/22/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb	Unit CT2 Startup, Cold, TF	Unit CT2 Startup, Warm, TF	Unit CT2 Startup, Hot, TF	Unit CT2 Shutdown, TF	Unit CT2 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/23/2022 00:00	0.0	0	0	0	0	0
03/23/2022 01:00	0.0	0	0	0	0	0
03/23/2022 02:00	0.0	0	0	0	0	0
03/23/2022 03:00	0.0	0	0	0	0	0
03/23/2022 04:00	0.0	0	0	0	0	0
03/23/2022 05:00	0.0	0	0	0	0	0
03/23/2022 06:00	0.0	0	0	0	0	0
03/23/2022 07:00	0.0	0	0	0	0	0
03/23/2022 08:00	0.0	0	0	0	0	0
03/23/2022 09:00	0.0	0	0	0	0	0
03/23/2022 10:00	0.0	0	0	0	0	0
03/23/2022 11:00	0.0	0	0	0	0	0
03/23/2022 12:00	0.0	0	0	0	0	0
03/23/2022 13:00	0.0	0	0	0	0	0
03/23/2022 14:00	0.0	0	0	0	0	0
03/23/2022 15:00	0.0	0	0	0	0	0
03/23/2022 16:00	0.0	0	0	0	0	0
03/23/2022 17:00	0.0	0	0	0	0	0
03/23/2022 18:00	0.0	0	0	0	0	0
03/23/2022 19:00	0.0	0	0	0	0	0
03/23/2022 20:00	0.0	0	0	0	0	0
03/23/2022 21:00	0.0	0	0	0	0	0
03/23/2022 22:00	0.0	0	0	0	0	0
03/23/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwelll, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb	Unit CT2 Startup, Cold, TF	Unit CT2 Startup, Warm, TF	Unit CT2 Startup, Hot, TF	Unit CT2 Shutdown, TF	Unit CT2 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/24/2022 00:00	0.0	0	0	0	0	0
03/24/2022 01:00	0.0	0	0	0	0	0
03/24/2022 02:00	0.0	0	0	0	0	0
03/24/2022 03:00	0.0	0	0	0	0	0
03/24/2022 04:00	0.0	0	0	0	0	0
03/24/2022 05:00	0.0	0	0	0	0	0
03/24/2022 06:00	0.0	0	0	0	0	0
03/24/2022 07:00	0.0	0	0	0	0	0
03/24/2022 08:00	0.0	0	0	0	0	0
03/24/2022 09:00	0.0	0	0	0	0	0
03/24/2022 10:00	0.0	0	0	0	0	0
03/24/2022 11:00	0.0	0	0	0	0	0
03/24/2022 12:00	0.0	0	0	0	0	0
03/24/2022 13:00	0.0	0	0	0	0	0
03/24/2022 14:00	0.0	0	0	0	0	0
03/24/2022 15:00	0.0	0	0	0	0	0
03/24/2022 16:00	0.0	0	0	0	0	0
03/24/2022 17:00	0.0	0	0	0	0	0
03/24/2022 18:00	0.0	0	0	0	0	0
03/24/2022 19:00	0.0	0	0	0	0	0
03/24/2022 20:00	0.0	0	0	0	0	0
03/24/2022 21:00	0.0	0	0	0	0	0
03/24/2022 22:00	0.0	0	0	0	0	0
03/24/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb	Unit CT2 Startup, Cold, TF	Unit CT2 Startup, Warm, TF	Unit CT2 Startup, Hot, TF	Unit CT2 Shutdown, TF	Unit CT2 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/25/2022 00:00	0.0	0	0	0	0	0
03/25/2022 01:00	0.0	0	0	0	0	0
03/25/2022 02:00	0.0	0	0	0	0	0
03/25/2022 03:00	0.0	0	0	0	0	0
03/25/2022 04:00	0.0	0	0	0	0	0
03/25/2022 05:00	0.0	0	0	0	0	0
03/25/2022 06:00	0.0	0	0	0	0	0
03/25/2022 07:00	0.0	0	0	0	0	0
03/25/2022 08:00	0.0	0	0	0	0	0
03/25/2022 09:00	0.0	0	0	0	0	0
03/25/2022 10:00	0.0	0	0	0	0	0
03/25/2022 11:00	0.0	0	0	0	0	0
03/25/2022 12:00	0.0	0	0	0	0	0
03/25/2022 13:00	0.0	0	0	0	0	0
03/25/2022 14:00	0.0	0	0	0	0	0
03/25/2022 15:00	0.0	0	0	0	0	0
03/25/2022 16:00	0.0	0	0	0	0	0
03/25/2022 17:00	0.0	0	0	0	0	0
03/25/2022 18:00	0.0	0	0	0	0	0
03/25/2022 19:00	0.0	0	0	0	0	0
03/25/2022 20:00	0.0	0	0	0	0	0
03/25/2022 21:00	0.0	0	0	0	0	0
03/25/2022 22:00	0.0	0	0	0	0	0
03/25/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb	Unit CT2 Startup, Cold, TF	Unit CT2 Startup, Warm, TF	Unit CT2 Startup, Hot, TF	Unit CT2 Shutdown, TF	Unit CT2 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/26/2022 00:00	0.0	0	0	0	0	0
03/26/2022 01:00	0.0	0	0	0	0	0
03/26/2022 02:00	0.0	0	0	0	0	0
03/26/2022 03:00	0.0	0	0	0	0	0
03/26/2022 04:00	0.0	0	0	0	0	0
03/26/2022 05:00	0.0	0	0	0	0	0
03/26/2022 06:00	0.0	0	0	0	0	0
03/26/2022 07:00	0.0	0	0	0	0	0
03/26/2022 08:00	0.0	0	0	0	0	0
03/26/2022 09:00	0.0	0	0	0	0	0
03/26/2022 10:00	0.0	0	0	0	0	0
03/26/2022 11:00	0.0	0	0	0	0	0
03/26/2022 12:00	0.0	0	0	0	0	0
03/26/2022 13:00	0.0	0	0	0	0	0
03/26/2022 14:00	0.0	0	0	0	0	0
03/26/2022 15:00	0.0	0	0	0	0	0
03/26/2022 16:00	0.0	0	0	0	0	0
03/26/2022 17:00	0.0	0	0	0	0	0
03/26/2022 18:00	0.0	0	0	0	0	0
03/26/2022 19:00	0.0	0	0	0	0	0
03/26/2022 20:00	0.0	0	0	0	0	0
03/26/2022 21:00	0.0	0	0	0	0	0
03/26/2022 22:00	0.0	0	0	0	0	0
03/26/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb	Unit CT2 Startup, Cold, TF	Unit CT2 Startup, Warm, TF	Unit CT2 Startup, Hot, TF	Unit CT2 Shutdown, TF	Unit CT2 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/27/2022 00:00	0.0	0	0	0	0	0
03/27/2022 01:00	0.0	0	0	0	0	0
03/27/2022 02:00	0.0	0	0	0	0	0
03/27/2022 03:00	0.0	0	0	0	0	0
03/27/2022 04:00	0.0	0	0	0	0	0
03/27/2022 05:00	0.0	0	0	0	0	0
03/27/2022 06:00	0.0	0	0	0	0	0
03/27/2022 07:00	0.0	0	0	0	0	0
03/27/2022 08:00	0.0	0	0	0	0	0
03/27/2022 09:00	0.0	0	0	0	0	0
03/27/2022 10:00	0.0	0	0	0	0	0
03/27/2022 11:00	0.0	0	0	0	0	0
03/27/2022 12:00	0.0	0	0	0	0	0
03/27/2022 13:00	0.0	0	0	0	0	0
03/27/2022 14:00	0.0	0	0	0	0	0
03/27/2022 15:00	0.0	0	0	0	0	0
03/27/2022 16:00	0.0	0	0	0	0	0
03/27/2022 17:00	0.0	0	0	0	0	0
03/27/2022 18:00	0.0	0	0	0	0	0
03/27/2022 19:00	0.0	0	0	0	0	0
03/27/2022 20:00	0.0	0	0	0	0	0
03/27/2022 21:00	0.0	0	0	0	0	0
03/27/2022 22:00	0.0	0	0	0	0	0
03/27/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb	Unit CT2 Startup, Cold, TF	Unit CT2 Startup, Warm, TF	Unit CT2 Startup, Hot, TF	Unit CT2 Shutdown, TF	Unit CT2 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/28/2022 00:00	0.0	0	0	0	0	0
03/28/2022 01:00	0.0	0	0	0	0	0
03/28/2022 02:00	0.0	0	0	0	0	0
03/28/2022 03:00	0.0	0	0	0	0	0
03/28/2022 04:00	0.0	0	0	0	0	0
03/28/2022 05:00	0.0	0	0	0	0	0
03/28/2022 06:00	0.0	0	0	0	0	0
03/28/2022 07:00	0.0	0	0	0	0	0
03/28/2022 08:00	0.0	0	0	0	0	0
03/28/2022 09:00	0.0	0	0	0	0	0
03/28/2022 10:00	0.0	0	0	0	0	0
03/28/2022 11:00	0.0	0	0	0	0	0
03/28/2022 12:00	0.0	0	0	0	0	0
03/28/2022 13:00	0.0	0	0	0	0	0
03/28/2022 14:00	0.0	0	0	0	0	0
03/28/2022 15:00	0.0	0	0	0	0	0
03/28/2022 16:00	0.0	0	0	0	0	0
03/28/2022 17:00	0.0	0	0	0	0	0
03/28/2022 18:00	0.0	0	0	0	0	0
03/28/2022 19:00	0.0	0	0	0	0	0
03/28/2022 20:00	0.0	0	0	0	0	0
03/28/2022 21:00	0.0	0	0	0	0	0
03/28/2022 22:00	0.0	0	0	0	0	0
03/28/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb	Unit CT2 Startup, Cold, TF	Unit CT2 Startup, Warm, TF	Unit CT2 Startup, Hot, TF	Unit CT2 Shutdown, TF	Unit CT2 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/29/2022 00:00	0.0	0	0	0	0	0
03/29/2022 01:00	0.0	0	0	0	0	0
03/29/2022 02:00	0.0	0	0	0	0	0
03/29/2022 03:00	0.0	0	0	0	0	0
03/29/2022 04:00	0.0	0	0	0	0	0
03/29/2022 05:00	0.0	0	0	0	0	0
03/29/2022 06:00	0.0	0	0	0	0	0
03/29/2022 07:00	0.0	0	0	0	0	0
03/29/2022 08:00	0.0	0	0	0	0	0
03/29/2022 09:00	0.0	0	0	0	0	0
03/29/2022 10:00	0.0	0	0	0	0	0
03/29/2022 11:00	0.0	0	0	0	0	0
03/29/2022 12:00	0.0	0	0	0	0	0
03/29/2022 13:00	0.0	0	0	0	0	0
03/29/2022 14:00	0.0	0	0	0	0	0
03/29/2022 15:00	0.0	0	0	0	0	0
03/29/2022 16:00	0.0	0	0	0	0	0
03/29/2022 17:00	0.0	0	0	0	0	0
03/29/2022 18:00	0.0	0	0	0	0	0
03/29/2022 19:00	0.0	0	0	0	0	0
03/29/2022 20:00	0.0	0	0	0	0	0
03/29/2022 21:00	0.0	0	0	0	0	0
03/29/2022 22:00	0.0	0	0	0	0	0
03/29/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb	Unit CT2 Startup, Cold, TF	Unit CT2 Startup, Warm, TF	Unit CT2 Startup, Hot, TF	Unit CT2 Shutdown, TF	Unit CT2 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/30/2022 00:00	0.0	0	0	0	0	0
03/30/2022 01:00	0.0	0	0	0	0	0
03/30/2022 02:00	0.0	0	0	0	0	0
03/30/2022 03:00	0.0	0	0	0	0	0
03/30/2022 04:00	0.0	0	0	0	0	0
03/30/2022 05:00	0.0	0	0	0	0	0
03/30/2022 06:00	0.0	0	0	0	0	0
03/30/2022 07:00	0.0	0	0	0	0	0
03/30/2022 08:00	0.0	0	0	0	0	0
03/30/2022 09:00	0.0	0	0	0	0	0
03/30/2022 10:00	0.0	0	0	0	0	0
03/30/2022 11:00	0.0	0	0	0	0	0
03/30/2022 12:00	0.0	0	0	0	0	0
03/30/2022 13:00	0.0	0	0	0	0	0
03/30/2022 14:00	0.0	0	0	0	0	0
03/30/2022 15:00	0.0	0	0	0	0	0
03/30/2022 16:00	0.0	0	0	0	0	0
03/30/2022 17:00	0.0	0	0	0	0	0
03/30/2022 18:00	0.0	0	0	0	0	0
03/30/2022 19:00	0.0	0	0	0	0	0
03/30/2022 20:00	0.0	0	0	0	0	0
03/30/2022 21:00	0.0	0	0	0	0	0
03/30/2022 22:00	0.0	0	0	0	0	0
03/30/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb	Unit CT2 Startup, Cold, TF	Unit CT2 Startup, Warm, TF	Unit CT2 Startup, Hot, TF	Unit CT2 Shutdown, TF	Unit CT2 NormalOp, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/31/2022 00:00	0.0	0	0	0	0	0
03/31/2022 01:00	0.0	0	0	0	0	0
03/31/2022 02:00	0.0	0	0	0	0	0
03/31/2022 03:00	0.0	0	0	0	0	0
03/31/2022 04:00	0.0	0	0	0	0	0
03/31/2022 05:00	0.0	0	0	0	0	0
03/31/2022 06:00	0.0	0	0	0	0	0
03/31/2022 07:00	0.0	0	0	0	0	0
03/31/2022 08:00	0.0	0	0	0	0	0
03/31/2022 09:00	0.0	0	0	0	0	0
03/31/2022 10:00	0.0	0	0	0	0	0
03/31/2022 11:00	0.0	0	0	0	0	0
03/31/2022 12:00	0.0	0	0	0	0	0
03/31/2022 13:00	0.0	0	0	0	0	0
03/31/2022 14:00	0.0	0	0	0	0	0
03/31/2022 15:00	0.0	0	0	0	0	0
03/31/2022 16:00	0.0	0	0	0	0	0
03/31/2022 17:00	0.0	0	0	0	0	0
03/31/2022 18:00	0.0	0	0	0	0	0
03/31/2022 19:00	0.0	0	0	0	0	0
03/31/2022 20:00	0.0	0	0	0	0	0
03/31/2022 21:00	0.0	0	0	0	0	0
03/31/2022 22:00	0.0	0	0	0	0	0
03/31/2022 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Pound Per Event Report

CT2 - CO Lbs



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION

Generated: 04/11/2022 09:54 Location: Maxwell, CA

Tag Name: CT2_CO_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 937.60 Hours

Non-Operating Time: 1,222.40 Hours Report Time: 2,160.00 Hours

Unit Operation and Excess Events

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
01/01/2022 09:19 01/01/2022 09:24 Shut Down - Gas	6	0.9	483.5		
01/01/2022 16:42 01/01/2022 17:52 Hot Start - Gas	71	61.6	679.6		
01/02/2022 09:19 01/02/2022 09:24 Shut Down - Gas	6	0.9	483.5		
01/02/2022 16:42 01/02/2022 17:50 Hot Start - Gas	69	63.4	679.6		
01/07/2022 22:24 01/07/2022 22:29 Shut Down - Gas	6	0.7	483.5		
01/08/2022 15:06 01/08/2022 16:36 Warm Start - Gas	91	85.3	790.5		
01/10/2022 01:49 01/10/2022 01:54 Shut Down - Gas	6	0.8	483.5		
01/10/2022 06:17 01/10/2022 07:29 Hot Start - Gas	73	68.0	679.6		
01/12/2022 00:19 01/12/2022 00:23 Shut Down - Gas	5	0.5	483.5		
01/12/2022 09:40 01/12/2022 10:58 Warm Start - Gas	79	77.9	790.5		
01/13/2022 23:23 01/13/2022 23:28 Shut Down - Gas	6	0.5	483.5		
01/14/2022 13:18 01/14/2022 14:40 Warm Start - Gas	83	58.6	790.5		
01/14/2022 23:23 01/14/2022 23:28 Shut Down - Gas	6	0.9	483.5		

Pound Per Event Report

CT2 - CO Lbs



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION

Generated: 04/11/2022 09:54 Location: Maxwell, CA

Tag Name: CT2_CO_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 937.60 Hours

Non-Operating Time: 1,222.40 Hours Report Time: 2,160.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
01/15/2022 14:06 01/15/2022 15:41 Warm Start - Gas	96	63.0	790.5		
01/15/2022 23:39 01/15/2022 23:43 Shut Down - Gas	5	0.6	483.5		
01/16/2022 15:35 01/16/2022 17:05 Warm Start - Gas	91	76.2	790.5		
01/20/2022 09:21 01/20/2022 09:25 Shut Down - Gas	5	0.6	483.5		
01/20/2022 16:28 01/20/2022 17:36 Hot Start - Gas	69	64.7	679.6		
01/20/2022 23:23 01/20/2022 23:27 Shut Down - Gas	5	0.6	483.5		
01/23/2022 16:32 01/23/2022 17:58 Warm Start - Gas	87	95.5	790.5		
01/23/2022 23:23 01/23/2022 23:28 Shut Down - Gas	6	0.7	483.5		
01/24/2022 14:05 01/24/2022 15:35 Warm Start - Gas	91	64.6	790.5		
01/25/2022 08:40 01/25/2022 08:44 Shut Down - Gas	5	0.1	483.5		
01/25/2022 11:47 01/25/2022 12:50 Hot Start - Gas	64	38.9	679.6		
01/26/2022 08:38 01/26/2022 08:43 Shut Down - Gas	6	0.6	483.5		
01/26/2022 11:47 01/26/2022 12:49 Hot Start - Gas	63	36.6	679.6		
01/30/2022 07:40 01/30/2022 07:45 Shut Down - Gas	6	0.7	483.5		

Pound Per Event Report

CT2 - CO Lbs



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION

Generated: 04/11/2022 09:54 Location: Maxwell, CA

Tag Name: CT2_CO_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 937.60 Hours

Non-Operating Time: 1,222.40 Hours Report Time: 2,160.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
01/30/2022 14:46 01/30/2022 15:54 Hot Start - Gas	69	75.1	679.6		
01/31/2022 23:23 01/31/2022 23:28 Shut Down - Gas	6	0.8	483.5		
02/01/2022 03:05 02/01/2022 04:17 Hot Start - Gas	73	53.0	679.6		
02/04/2022 08:23 02/04/2022 08:28 Shut Down - Gas	6	0.7	483.5		
02/04/2022 11:29 02/04/2022 12:49 Hot Start - Gas	81	63.7	679.6		
02/05/2022 08:23 02/05/2022 08:28 Shut Down - Gas	6	1.1	483.5		
02/05/2022 17:33 02/05/2022 18:56 Warm Start - Gas	84	45.7	790.5		
02/06/2022 08:06 02/06/2022 08:10 Shut Down - Gas	5	0.4	483.5		
02/07/2022 16:18 02/07/2022 17:50 Warm Start - Gas	93	87.7	790.5		
02/07/2022 23:23 02/07/2022 23:28 Shut Down - Gas	6	0.8	483.5		
02/08/2022 05:25 02/08/2022 06:44 Hot Start - Gas	80	63.6	679.6		
02/08/2022 22:19 02/08/2022 22:24 Shut Down - Gas	6	0.6	483.5		
02/09/2022 16:08 02/09/2022 17:05 Warm Start - Gas	58	52.0	790.5		
02/10/2022 08:08 02/10/2022 08:13 Shut Down - Gas	6	1.0	483.5		

Pound Per Event Report

CT2 - CO Lbs



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION

Generated: 04/11/2022 09:54 Location: Maxwell, CA

Tag Name: CT2_CO_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 937.60 Hours

Non-Operating Time: 1,222.40 Hours Report Time: 2,160.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
02/10/2022 15:51 02/10/2022 16:55 Hot Start - Gas	65	53.3	679.6		
02/11/2022 01:03 02/11/2022 01:07 Shut Down - Gas	5	0.6	483.5		
02/18/2022 15:04 02/18/2022 16:53 Cold Start - Gas	110	112.7	1,355.6		
02/19/2022 00:23 02/19/2022 00:28 Shut Down - Gas	6	0.9	483.5		
02/22/2022 04:27 02/22/2022 05:50 Cold Start - Gas	84	107.1	1,355.6		
02/26/2022 07:23 02/26/2022 07:28 Shut Down - Gas	6	0.7	483.5		

No excess emissions were found in the reporting period.

Pound Per Event Report
CT2 - CO Lbs



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 09:54 Location: Maxwell, CA
Tag Name: CT2_CO_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission
Total Operating Time: 937.60 Hours
Non-Operating Time: 1,222.40 Hours Report Time: 2,160.00 Hours

Event Invalid Information

No invalid events were found in the reporting period.

Pound Per Event Report

CT2 - CO Lbs



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION

Generated: 04/11/2022 09:54 Location: Maxwell, CA

Tag Name: CT2_CO_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 937.60 Hours

Non-Operating Time: 1,222.40 Hours Report Time: 2,160.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary

1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary

1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime in Minute(s)	0
3. Total Downtime as a percentage of operating time	0.00
4. Total Availability as a percentage of operating time	100.00

Pound Per Event Report

CT2 - NOx Lbs



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION

Generated: 04/11/2022 09:55

Location: Maxwell, CA

Tag Name: CT2_NOx_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 825.67 Hours

Non-Operating Time: 1,334.33 Hours

Report Time: 2,160.00 Hours

Unit Operation and Excess Events

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
01/01/2022 09:19 01/01/2022 09:24 Shut Down - Gas	6	0.24	115.00		
01/01/2022 16:42 01/01/2022 17:52 Hot Start - Gas	71	63.31	259.90		
01/02/2022 09:19 01/02/2022 09:24 Shut Down - Gas	6	0.22	115.00		
01/02/2022 16:42 01/02/2022 17:50 Hot Start - Gas	69	53.61	259.90		
01/07/2022 22:24 01/07/2022 22:29 Shut Down - Gas	6	0.20	115.00		
01/08/2022 15:06 01/08/2022 16:36 Warm Start - Gas	91	85.94	456.20		
01/10/2022 01:49 01/10/2022 01:54 Shut Down - Gas	6	0.22	115.00		
01/10/2022 06:17 01/10/2022 07:29 Hot Start - Gas	73	44.78	259.90		
01/12/2022 00:19 01/12/2022 00:23 Shut Down - Gas	5	0.15	115.00		
01/12/2022 09:40 01/12/2022 10:58 Warm Start - Gas	79	69.98	456.20		
01/13/2022 23:23 01/13/2022 23:28 Shut Down - Gas	6	0.19	115.00		
01/14/2022 13:18 01/14/2022 14:40 Warm Start - Gas	83	78.76	456.20		
01/14/2022 23:23 01/14/2022 23:28 Shut Down - Gas	6	0.28	115.00		

Pound Per Event Report

CT2 - NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/11/2022 09:55

Location: Maxwell, CA

Tag Name: CT2_NOx_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 825.67 Hours

Non-Operating Time: 1,334.33 Hours

Report Time: 2,160.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
01/15/2022 14:06 01/15/2022 15:41 Warm Start - Gas	96	83.34	456.20		
01/15/2022 23:39 01/15/2022 23:43 Shut Down - Gas	5	0.18	115.00		
01/16/2022 15:35 01/16/2022 17:05 Warm Start - Gas	91	76.73	456.20		
01/20/2022 09:21 01/20/2022 09:25 Shut Down - Gas	5	0.15	115.00		
01/20/2022 16:28 01/20/2022 17:36 Hot Start - Gas	69	57.43	259.90		
01/20/2022 23:23 01/20/2022 23:27 Shut Down - Gas	5	0.17	115.00		
01/23/2022 16:32 01/23/2022 17:58 Warm Start - Gas	87	113.62	456.20		
01/23/2022 23:23 01/23/2022 23:28 Shut Down - Gas	6	0.22	115.00		
01/24/2022 14:05 01/24/2022 15:35 Warm Start - Gas	91	76.50	456.20		
01/25/2022 08:40 01/25/2022 08:44 Shut Down - Gas	5	0.11	115.00		
01/25/2022 11:47 01/25/2022 12:50 Hot Start - Gas	64	29.55	259.90		
01/26/2022 08:38 01/26/2022 08:43 Shut Down - Gas	6	0.21	115.00		
01/26/2022 11:47 01/26/2022 12:49 Hot Start - Gas	63	31.66	259.90		
01/30/2022 07:40 01/30/2022 07:45 Shut Down - Gas	6	0.24	115.00		

Pound Per Event Report

CT2 - NOx Lbs



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION

Generated: 04/11/2022 09:55

Location: Maxwell, CA

Tag Name: CT2_NOx_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 825.67 Hours

Non-Operating Time: 1,334.33 Hours

Report Time: 2,160.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
01/30/2022 14:46 01/30/2022 15:54 Hot Start - Gas	69	80.21	259.90		
01/31/2022 23:23 01/31/2022 23:28 Shut Down - Gas	6	0.30	115.00		
02/01/2022 03:05 02/01/2022 04:17 Hot Start - Gas	73	37.43	259.90		
02/04/2022 08:23 02/04/2022 08:28 Shut Down - Gas	6	0.25	115.00		
02/04/2022 11:29 02/04/2022 12:49 Hot Start - Gas	81	38.31	259.90		
02/05/2022 08:23 02/05/2022 08:28 Shut Down - Gas	6	0.47	115.00		
02/05/2022 17:33 02/05/2022 18:56 Warm Start - Gas	84	70.68	456.20		
02/06/2022 08:06 02/06/2022 08:10 Shut Down - Gas	5	0.08	115.00		
02/07/2022 16:18 02/07/2022 17:50 Warm Start - Gas	93	93.24	456.20		
02/07/2022 23:23 02/07/2022 23:28 Shut Down - Gas	6	0.30	115.00		
02/08/2022 05:25 02/08/2022 06:44 Hot Start - Gas	80	43.26	259.90		
02/08/2022 22:19 02/08/2022 22:24 Shut Down - Gas	6	0.16	115.00		
02/09/2022 16:08 02/09/2022 17:05 Warm Start - Gas	58	77.17	456.20		
02/10/2022 08:08 02/10/2022 08:13 Shut Down - Gas	6	0.38	115.00		

Pound Per Event Report

CT2 - NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/11/2022 09:55 **Location:** Maxwell, CA

Tag Name: CT2_NOx_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 825.67 Hours

Non-Operating Time: 1,334.33 Hours Report Time: 2,160.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
02/10/2022 15:51 02/10/2022 16:55 Hot Start - Gas	65	63.46	259.90		
02/11/2022 01:03 02/11/2022 01:07 Shut Down - Gas	5	0.09	115.00		
02/18/2022 15:04 02/18/2022 16:53 Cold Start - Gas	110	146.98	779.10		
02/19/2022 00:23 02/19/2022 00:28 Shut Down - Gas	6	0.34	115.00		
02/22/2022 04:27 02/22/2022 05:50 Cold Start - Gas	84	97.32	779.10		
02/26/2022 07:23 02/26/2022 07:28 Shut Down - Gas	6	0.28	115.00		

No excess emissions were found in the reporting period.

Pound Per Event Report

CT2 - NOx Lbs



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/11/2022 09:55 **Location:** Maxwell, CA

Tag Name: CT2_NOx_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 825.67 Hours

Non-Operating Time: 1,334.33 Hours Report Time: 2,160.00 Hours

Event Invalid Information

No invalid events were found in the reporting period.

Pound Per Event Report

CT2 - NOx Lbs



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION

Generated: 04/11/2022 09:55 Location: Maxwell, CA

Tag Name: CT2_NOx_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 825.67 Hours

Non-Operating Time: 1,334.33 Hours

Report Time: 2,160.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary

1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary

1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime in Minute(s)	0
3. Total Downtime as a percentage of operating time	0.00
4. Total Availability as a percentage of operating time	100.00

CT1 Process Event Report

CT1 Cold and Hot Startup Events



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 09:57 Location: Maxwell, CA

Unit offline

Tag Name: CT1_UnitOn_TF_1H

Offline Periods		
Start Time	End Time	Duration in Hour(s)
01/07/2022 23:00	01/08/2022 09:00	11
01/14/2022 00:00	01/14/2022 03:00	4
01/15/2022 00:00	01/15/2022 03:00	4
01/16/2022 00:00	01/16/2022 10:00	11
01/21/2022 00:00	01/23/2022 10:00	59
01/24/2022 00:00	01/24/2022 02:00	3
01/25/2022 09:00	01/25/2022 14:00	6
01/26/2022 09:00	01/26/2022 14:00	6
01/27/2022 11:00	01/27/2022 14:00	4
01/30/2022 08:00	01/31/2022 01:00	18
02/01/2022 00:00	02/01/2022 04:00	5
02/02/2022 11:00	02/02/2022 14:00	4
02/04/2022 09:00	02/04/2022 15:00	7
02/05/2022 09:00	02/05/2022 12:00	4
02/06/2022 09:00	02/06/2022 13:00	5
02/07/2022 00:00	02/07/2022 10:00	11
02/08/2022 00:00	02/08/2022 02:00	3
02/10/2022 09:00	02/10/2022 10:00	2
02/11/2022 02:00	02/18/2022 07:00	174
02/19/2022 01:00	02/21/2022 22:00	70
02/26/2022 08:00	02/26/2022 14:00	7
02/27/2022 00:00	02/28/2022 12:00	37
02/28/2022 23:00	03/31/2022 23:00	745

CT1 Process Event Report
CT1 Cold and Hot Startup Events



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 09:57 Location: Maxwell, CA

Operating Time Summary

Available Data for Report (excludes missing data):	2,160.00 Hour(s)
Total Offline:	1,200.00 Hour(s)
Offline Percentage:	55.56 %
Total Online:	960.00 Hour(s)
Online Percentage:	44.44 %

CT1 Process Event Report

CT1 Cold and Hot Startup Events



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 09:57 Location: Maxwell, CA

Startup/Shutdown

Number	Start Time	End Time	Event Type	Duration
1	01/08/2022 10:00	01/08/2022 12:00	Warm Startup	3
2	01/14/2022 04:00	01/14/2022 05:00	Hot Startup	2
3	01/15/2022 04:00	01/15/2022 05:00	Hot Startup	2
4	01/16/2022 11:00	01/16/2022 12:00	Warm Startup	2
5	01/23/2022 11:00	01/23/2022 13:00	Warm Startup	3
6	01/24/2022 03:00	01/24/2022 04:00	Hot Startup	2
7	01/25/2022 15:00	01/25/2022 16:00	Hot Startup	2
8	01/26/2022 15:00	01/26/2022 16:00	Hot Startup	2
9	01/27/2022 15:00	01/27/2022 16:00	Hot Startup	2
10	01/31/2022 02:00	01/31/2022 03:00	Warm Startup	2
11	02/01/2022 05:00	02/01/2022 06:00	Hot Startup	2
12	02/02/2022 15:00	02/02/2022 17:00	Hot Startup	3
13	02/04/2022 16:00	02/04/2022 17:00	Hot Startup	2
14	02/05/2022 13:00	02/05/2022 14:00	Hot Startup	2
15	02/06/2022 14:00	02/06/2022 15:00	Hot Startup	2
16	02/07/2022 11:00	02/07/2022 13:00	Warm Startup	3
17	02/08/2022 03:00	02/08/2022 04:00	Hot Startup	2
18	02/10/2022 11:00	02/10/2022 12:00	Hot Startup	2
19	02/18/2022 08:00	02/18/2022 12:00	Cold Startup	5
20	02/21/2022 23:00	02/22/2022 01:00	Warm Startup	3
21	02/26/2022 15:00	02/26/2022 16:00	Warm Startup	2
22	02/28/2022 13:00	02/28/2022 15:00	Warm Startup	3

CT1 Process Event Report

CT1 Cold and Hot Startup Events



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:57 **Location:** Maxwell, CA

CT1 Process Event Report

CT1 Cold and Hot Startup Events



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:57 **Location:** Maxwell, CA

Startup/Shutdown Event Summary

	# Events	Duration	Duration %
Cold Startup	1	5	0.52
Hot Startup/Startup Shutdown Event Text 02 Add	13	27	2.81
Warm Startup	8	21	2.19
Total Process Events:	22	53	5.52

Total Report Time:	2,160 Hour(s)
Total Operating Time:	960 Hour(s)
Total Startup Time:	53 Hour(s)
Total Shutdown Time:	0 Hour(s)
Total Startup/Shutdown Time:	53 Hour(s)
Total Startup/Shutdown Time as a Percentage of Total Operating Time:	5.52 %

CT2 Process Event Report

CT2 cold and Hot Startup Events



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 09:58 Location: Maxwell, CA

Unit offline

Tag Name: CT2_UnitOn_TF_1H

Offline Periods		
Start Time	End Time	Duration in Hour(s)
01/01/2022 10:00	01/01/2022 15:00	6
01/02/2022 10:00	01/02/2022 15:00	6
01/07/2022 23:00	01/08/2022 14:00	16
01/10/2022 02:00	01/10/2022 05:00	4
01/12/2022 01:00	01/12/2022 08:00	8
01/14/2022 00:00	01/14/2022 12:00	13
01/15/2022 00:00	01/15/2022 13:00	14
01/16/2022 00:00	01/16/2022 14:00	15
01/20/2022 10:00	01/20/2022 15:00	6
01/21/2022 00:00	01/23/2022 15:00	64
01/24/2022 00:00	01/24/2022 13:00	14
01/25/2022 09:00	01/25/2022 10:00	2
01/26/2022 09:00	01/26/2022 10:00	2
01/30/2022 08:00	01/30/2022 13:00	6
02/01/2022 00:00	02/01/2022 02:00	3
02/04/2022 09:00	02/04/2022 10:00	2
02/05/2022 09:00	02/05/2022 16:00	8
02/06/2022 09:00	02/07/2022 15:00	31
02/08/2022 00:00	02/08/2022 04:00	5
02/08/2022 23:00	02/09/2022 15:00	17
02/10/2022 09:00	02/10/2022 14:00	6
02/11/2022 02:00	02/18/2022 14:00	181
02/19/2022 01:00	02/22/2022 03:00	75
02/26/2022 08:00	03/31/2022 23:00	808

CT2 Process Event Report
CT2 Cold and Hot Startup Events



From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: COLUSA GENERATING STATION
Generated: 04/11/2022 09:58 Location: Maxwell, CA

Operating Time Summary

Available Data for Report (excludes missing data):	2,160.00 Hour(s)
Total Offline:	1,312.00 Hour(s)
Offline Percentage:	60.74 %
Total Online:	848.00 Hour(s)
Online Percentage:	39.26 %

CT2 Process Event Report

CT2 cold and Hot Startup Events



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:58 **Location:** Maxwell, CA

Startup/Shutdown

Number	Start Time	End Time	Event Type	Duration
1	01/01/2022 16:00	01/01/2022 17:00	Hot Startup	2
2	01/02/2022 16:00	01/02/2022 17:00	Hot Startup	2
3	01/08/2022 15:00	01/08/2022 16:00	Warm startup	2
4	01/10/2022 06:00	01/10/2022 07:00	Hot Startup	2
5	01/12/2022 09:00	01/12/2022 10:00	Warm startup	2
6	01/14/2022 13:00	01/14/2022 14:00	Warm startup	2
7	01/15/2022 14:00	01/15/2022 15:00	Warm startup	2
8	01/16/2022 15:00	01/16/2022 17:00	Warm startup	3
9	01/20/2022 16:00	01/20/2022 17:00	Hot Startup	2
10	01/23/2022 16:00	01/23/2022 17:00	Warm startup	2
11	01/24/2022 14:00	01/24/2022 15:00	Warm startup	2
12	01/25/2022 11:00	01/25/2022 12:00	Hot Startup	2
13	01/26/2022 11:00	01/26/2022 12:00	Hot Startup	2
14	01/30/2022 14:00	01/30/2022 15:00	Hot Startup	2
15	02/01/2022 03:00	02/01/2022 04:00	Hot Startup	2
16	02/04/2022 11:00	02/04/2022 12:00	Hot Startup	2
17	02/05/2022 17:00	02/05/2022 18:00	Warm startup	2
18	02/07/2022 16:00	02/07/2022 17:00	Warm startup	2
19	02/08/2022 05:00	02/08/2022 06:00	Hot Startup	2
20	02/09/2022 16:00	02/09/2022 17:00	Warm startup	2
21	02/10/2022 15:00	02/10/2022 16:00	Hot Startup	2
22	02/18/2022 15:00	02/18/2022 16:00	Cold Startup	2

CT2 Process Event Report

CT2 Cold and Hot Startup Events



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:58 **Location:** Maxwell, CA

Number	Start Time	End Time	Event Type	Duration
23	02/22/2022 04:00	02/22/2022 05:00	Cold Startup	2

CT2 Process Event Report

CT2 Cold and Hot Startup Events



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/11/2022 09:58 **Location:** Maxwell, CA

Startup/Shutdown Event Summary

	# Events	Duration	Duration %
Cold Startup	2	4	0.47
Hot Startup	11	22	2.59
Warm startup	10	21	2.48
Total Process Events:	23	47	5.54

Total Report Time:	2,160 Hour(s)
Total Operating Time:	848 Hour(s)
Total Startup Time:	47 Hour(s)
Total Shutdown Time:	0 Hour(s)
Total Startup/Shutdown Time:	47 Hour(s)
Total Startup/Shutdown Time as a Percentage of Total Operating Time:	5.54 %

ATTACHMENT 13
Water Bath Heater Operations
FCD: AQ-17
Title V: #6

The Natural Gas Fired Water Bath Heater did not operate in the 1st Quarter of 2022.

ATTACHMENT 14

Certification Report

FCD: AQ-22
Title V: #13

CERTIFICATION REPORT

(FORM 3.17-K1)

DISTRICT:

Colusa County Air Pollution Control District

► DISTRICT USE ONLY ◀**DISTRICT ID:****COMPANY NAME:**

Pacific Gas and Electric

FACILITY NAME:

Colusa Generating Station

I. FACILITY INFORMATION

1. Company Name: Pacific Gas and Electric
2. Facility Name (if different than Company Name): Colusa Generating Station
3. Mailing Address: 4780 Dirks Rd , Maxwell CA 95955
4. Street Address or Source Location: Same
5. Facility Permit Number: 21006-0259

II. GENERAL INFORMATION

1. Reporting period (specify dates): January 1 - March 31, 2022
2. Due date for submittal of report: April 30, 2022
3. Type of submittal: ☒ Monitoring Report (complete Section III below)
☐ Compliance Schedule Progress Report (complete Section IV of Form 3.17-K2)
☐ Compliance Certification (complete Section V of Form 3.17-K2)

III. MONITORING REPORT INFORMATION

1. Were deviations from monitoring requirements encountered during the reporting period?☒ No ☐ Yes (If Yes, complete Form 3.17-L)